

**FOURTH QUARTERLY REPORT
INITIAL YEAR OF GROUNDWATER
TREATMENT FACILITY OPERATION**

VOLUME 1 of 2



SUBMITTED TO:

**TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS**

JULY 1993

**FOURTH QUARTERLY REPORT
INITIAL YEAR
OF
GROUNDWATER TREATMENT FACILITY OPERATION**

**TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS**

**Prepared By:
Lockwood, Kessler & Bartlett, Inc.
Consulting Engineers
One Aerial Way
Syosset, New York 11791**

July 1993

TABLE OF CONTENTS

	<u>Page No.</u>
SECTION 1.0 - INTRODUCTION	
1.1 Purpose of this Document	1
1.2 Scope of this Document	1
SECTION 2.0 - BACKGROUND INFORMATION	
2.1 Site History	2
2.2 Consent Decree Requirements Pertaining to Plume Remediation	3
2.2.1 Requirements for Groundwater Monitoring	3
2.2.2 Treatment Facility Discharge Limitations and Monitoring Requirements	4
SECTION 3.0 - GROUNDWATER TREATMENT FACILITY OPERATIONS	
3.1 Theory of Operation	10
3.2 Physical Plant	10
3.3 Initial Operating Conditions	11
3.4 Monitoring Functions	11
3.4.1 Daily Operations Reports	11
3.4.2 Organic Analyses Reports	11
3.4.3 Inorganic Analyses Reports	12
3.4.4 State Pollution Discharge Elimination System (SPDES) Reports	12
3.4.5 Air Stripper Emissions Testing	14
SECTION 4.0 - GROUNDWATER MONITORING PROGRAM	
4.1 General	15
4.1.1 Field Sampling Protocols	15
4.1.2 Well Construction Details	16
4.2 Hydraulic Monitoring	17
4.2.1 Monthly Water Level Measurements - January, February and March, 1993	17
4.3 Groundwater Quality and Quarterly Monitoring	21
4.3.1 Analyses of Volatile Organic compound (VOC) Data - January 1993	22
4.3.2 Delineation of the VOC Plume	24
4.3.3 Analysis of Inorganic compound Data - January 1993	25
4.4 Hydraulic Evaluation of the Groundwater Remediation System	26
4.4.1 Effective Capture Zone	26
4.4.2 Effects of Mounding Due to Recharge	27
4.4.3 Evaluation of System Pumpage	28

TABLE OF CONTENTS (Cont'd.)

	<u>Page No.</u>
SECTION 5.0 - DISCUSSION AND RECOMMENDATIONS	
5.1 Discussion	30
5.1.1 Facility Operations	30
5.1.2 Hydraulic Control of the VOC Plume	38
5.1.3 Remediation of Potential Groundwater Plumes from Other Sources	41
5.2 Recommendations	49
5.2.1 Groundwater Treatment Facility	49
5.2.2 Groundwater Monitoring Program	49

LIST OF TABLES

	<u>PAGE NO.</u>
1. Effluent Limitations/Volatile Organic Compounds (VOC's)	5
2. Effluent Limitations/Inorganics	6
3. Applicable Air Discharge Requirements for Air Stripping Treatment System	8
4. Analytical Methods	13

LIST OF FIGURES

1. Temporal Variation in Facility Influent	31
2. Temporal Comparison of Influent/Effluent Total VOC Concentrations	33
3. Temporal Variation in Facility Influent VOC Concentrations	34
4. Temporal Variation in Treatment Efficiency	35
5. Temporal Variation in Wellfield VOC Concentrations	36
6. Correlation of Recovery Well and Hydraulic Data	39
7. Temporal Variation in VOC Concentrations at Recovery Well No. 1	43
8. Temporal Variation in VOC Concentrations at Recovery Well No. 2	44
9. Temporal Variation in VOC Concentrations at Recovery Well No. 3	45
10. Temporal Variation in VOC Concentrations at Recovery Well No. 4	46
11. Temporal Variation in VOC Concentrations at Recovery Well No. 5	47
12. Temporal Variation In Wellfield Tetrachloroethene Concentrations	50

Filename: TOC4.DOC
Directory: B:\4Q
Template: C:\WINWORD\NORMAL.DOT
Title: toc4
Author: CAROL SHANNON
Subject: table of contents
Keywords: rap, 4th quarter
Comments: r.w. 5-93
Create Date: 05/26/93 01:34 PM
Revision Number: 8
Last Saved Date: 07/20/93 01:28 PM
Last Saved By: CAROL SHANNON
Total Editing Time: 16 Minutes
Last Printed: 07/20/93 01:28 PM
As of Last Complete Printing
Number of Pages: 2
Number of Words: 258
Number of Characters: 1,931

LIST OF APPENDICES

- A. Location Plan
- B. Daily Operations Reports, January 1 through March 31, 1993
- C. Self-Monitoring Organic Analyses
- D. Self-Monitoring Inorganic Analyses
- E. SPDES Reports
- F. "Air Stripper Stack Emissions Survey," June 1993 (Third Quarter results)
- G. "Quarterly Monitoring Report Fourth Quarter Results," June 1993

SECTION 1.0

INTRODUCTION

1.1 Purpose of this Document

The initial year of operation for the Groundwater Treatment Facility (GTF) located at the Oyster Bay Solid Waste Disposal Complex (OBSWDC) in Old Bethpage commenced on April 1, 1992. Pursuant to the terms of the Town of Oyster Bay's Consent Decree (83 CIV 5357) with the State of New York, the Town is required to submit quarterly operating reports to the NYSDEC. These reports shall contain sufficient operating data to demonstrate compliance with the terms of the Consent Decree. This document is the fourth quarterly report submitted in satisfaction of this requirement, and covers the period from January 1 through March 31, 1993. An annual report summarizing the initial year of operation will be issued separately.

1.2 Scope of this Document

This document provides a review of the various monitoring programs that have been undertaken at OBSWDC in satisfaction of the Town's responsibilities outlined on Pages 22-23 in Appendix A of the Consent Decree. This document is divided into five sections and seven appendices.

The sections are informational in nature and discuss the observations noted in the facility's performance and data collected in the reporting period. The appendices contain the raw data or reports collected from various sources relating to the facility's operations during the reporting period.

SECTION 2.0

BACKGROUND INFORMATION

2.1 Site History

The OBSWDC is located in eastern Nassau County on Long Island, N.Y. The complex, which had been in operation since 1958, was used for the processing and disposal of all non-hazardous waste generated in the Town of Oyster Bay. Those wastes were burned in two on-site incinerators, and excess materials were compacted and baled for disposal in the adjacent landfill. The landfill also accepted incinerator ash and residue, as well as raw MSW bypassed around the incinerators during periods of maintenance downtime. In April, 1986 all landfilling and incineration activities ceased, and the Town began to ship, off site, all solid wastes collected and not recycled. Presently, the site operations largely consist of operating the Town's scalehouse, solid waste transfer station, recycling program, clean fill disposal site, gas control system, power generating facility, leachate and groundwater treatment systems, and a vehicle maintenance garage.

In June 1988, the Town entered into a Consent Decree (83 CIV 5357) with the State of New York. That document requires the Town to perform the following actions:

- Design, construct and operate a groundwater treatment facility in order to contain, recover and remediate the off-site groundwater plume associated with the OBSWDC.
- Design and construct an acceptable landfill cap.
- Continue to operate the leachate treatment facility.
- Continue to operate the landfill gas migration control system.

- Perform various monitoring functions designed to assess the adequacy of the remediation efforts.

This document concerns the operations of the Groundwater Treatment Facility (GTF), which is located in the northeast corner of the site off Winding Road. The GTF began normal operations on April 1, 1992. In early 1992, the final capping activities at the top of the closed landfill were initiated. The Town is also continuing to maintain the operation of its leachate treatment and landfill gas collection facilities.

2.2 Consent Decree Requirements Pertaining to Plume Remediation

2.2.1 Requirements for Groundwater Monitoring

The nature and extent of the area to be remediated (the 'plume') under the terms and conditions of the Consent Decree was defined in the report "OBSWDC Offsite Groundwater Monitoring Program, Old Bethpage, Long Island, New York", Geraghty & Miller, Inc., September 1986.

In order to verify hydraulic containment of the plume by the recovery well system, and to assess the progress of the cleanup, a Groundwater Monitoring Program has been implemented by the Town according to the requirements as set forth in the Consent Decree. Accordingly, the Groundwater Monitoring Program must consist of the following elements:

Hydraulic Monitoring Monthly (operational) rounds of water level measurements in the required monitoring wells until equilibrium and appropriate drawdown has been established; and quarterly water level monitoring thereafter so long as hydraulic control of the plume is maintained.

Groundwater Quality Monitoring A baseline comprehensive First Round monitoring in the required wells prior to start up of the treatment system; followed by Quarterly Monitoring of groundwater quality until the Termination Criteria, as defined in the Consent Decree, has been attained; and Termination Monitoring thereafter for a minimum of five full years (20 quarters).

To fulfill the requirements of the Consent Decree, the following hydraulic monitoring and groundwater quality sampling was accomplished during the fourth operational quarter at the OBSWDC: 1) three rounds of monthly water level measurements during January, February and March, 1993; and 2) one round of groundwater quality sampling performed during January 1993.

Analytical protocols for the above quarterly sampling round consisted of Volatile Organic Compound (VOC) analyses (EPA Method 601 and 602), dissolved metals and other parameters (EPA-40 CFR Part 136.3 for Individual Analyses), plus additional parameters, as per Table 6 of the Consent Decree. As required by the Consent Decree, a total of 16 monitoring wells were sampled, including one landfill well (LF-1) sampled for leachate parameters only, according to the above required EPA protocol.

2.2.2 Treatment Facility Discharge Limitations and Monitoring Requirements

The Town's Consent Decree placed certain limitations on the water discharges from the GTF, and are tabulated in that document. Some water effluent discharge VOC limitations were modified in a letter to the Town from the New York State Department of Law. That modified list is reproduced here as Table 1. Effluent discharge limitations pertaining to this facility concerning inorganic and other physical parameters are listed in Table 2. The Town began monthly SPDES monitoring of the air stripper effluent in April, 1992 for the parameters in Tables 1 and 2 and

TABLE 1

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

EFFLUENT LIMITATIONS*
VOLATILE ORGANIC COMPOUNDS

CHEMICAL CONSTITUENT	ALLOWABLE EFFLUENT CONCENTRATION (ug/l)
TOTAL VOCs	100
BENZENE	ND
BROMODICHLOROMETHANE	50 **
BROMOFORM	50 **
CARBON TETRACHLORIDE	5
CHLOROBENZENE	5
CHLORODIBROMOMETHANE	50 **
CHLOROETHANE	5
CHLOROFORM	100 **
DICHLOROBENZENE o&p	4.7
DICHLORBENZENE o,m&p	50
1,1 DICHLOROETHANE	5
1,2 DICHLOROETHANE	5
1,1 DICHLOROETHENE	0.07
1,2 DICHLOROETHENE cis	5
1,2 DICHLOROETHENE trans	5
1,2 DICHLOROPROPANE	5
ETHYLBENZENE	50
METHYLENE CHLORIDE	5
TETRACHLOROETHENE	0.7
TOLUENE	5
1,1,1 TRICHLOROETHANE	5
TRICHLOROETHYLENE	5
VINYL CHLORIDE	2
XYLENE o	5
XYLENE m	5
XYLENE p	5
XYLENE o,m&p	50

* REGULATORY EFFLUENT DISCHARGE STANDARDS AS
 SPECIFIED IN THE CONSENT DECREE AND AS MODIFIED BY
 11/10/88 LETTER TO THE TOWN.

** TOTAL CONCENTRATION OF THESE FOUR TRIHALOMETHANES
 SHALL NOT EXCEED 100 ug/l.

TABLE 2

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

EFFLUENT LIMITATIONS*
INORGANICS

CHEMICAL CONSTITUENT	ALLOWABLE EFFLUENT CONCENTRATION (mg/l)
BARIUM	1
CADMIUM	0.01
CHLORIDE	250
CHROMIUM (hex)	0.05
COPPER	1
CYANIDE	0.2
IRON	0.3
LEAD	0.025
MAGNESIUM	35
MANGANESE	0.3
MERCURY	0.002
SILVER	0.05
ZINC	5
TOTAL DISSOLVED SOLIDS	500
NITRATE	10
SULFATE	250
PHENOLS (total)	0.001

* REGULATORY EFFLUENT DISCHARGE STANDARDS AS
 SPECIFIED IN THE CONSENT DECREE AND AS MODIFIED BY
 11/10/88 LETTER TO THE TOWN.

continued during this reporting period. This testing is performed by a New York State certified laboratory. The Consent Decree also placed limitations on the air stripper discharges from the GTF. That list, as it appears in the Consent Decree, is reproduced here as Table 3.

The Town began quarterly monitoring of the air stripper stack emissions on May 28, 1992. The third quarterly emissions monitoring took place on December 14, 1992. Analyses are performed by a New York State certified laboratory, and the results compared to the limitations stipulated in the Consent Decree and the most recent revision of NYSDEC Air Guide No. 1, effective June 1991.

In April 1993, after numerous discussions between the Town and NYSDEC, the Town was advised that the ambient air guideline for tetrachloroethane (PCE), published in the 1991 edition of NYSDEC Air Guide No. 1, was in error. The Town was further advised that the correct guideline was some fifteen times higher than the previously published number. Lastly, the Town was advised that NYSDEC will apply the ambient air guidelines at the OBSWDC property line to determine if the air stripper stack discharge is acceptable.

In addition to the above requirements, the Town is also required to perform certain self-monitoring functions, relating to recording comprehensive flow measurements through the plant and maintaining a record of downtime. The Town has enhanced its self-monitoring abilities with the installation of an onsite laboratory. This laboratory monitors the groundwater in the vicinity of each recovery well on a weekly basis, as well as the day-to-day treatment system performance, allowing plant personnel to make process adjustments when necessary. Daily monitoring may also warn the operator of equipment malfunction or the need for maintenance. Weekly monitoring of the recovery wellfield will

TABLE 3

APPLICABLE AIR DISCHARGE
REQUIREMENTS FOR AIR STRIPPING
TREATMENT SYSTEM*

Constituent	-Ambient Air Concentrations-	NYSDEC Annual Guideline ($\mu\text{g}/\text{m}^3$)
Vinyl Chloride	4.00E-01	
Freon 13	3.00E-02	
Methylene Chloride	1.17E+03	
1,1-Dichloroethane	2.70E+03	
1,2-Dichloroethene	2.63E+03	
Chloroform	1.67E+02	
1,1,1,-Trichloroethane	3.80E+04	
Carbon Tetrachloride	1.00E+02	
1,2-Dichloroethane	2.00E+01	
Trichloroethylene	9.00E+02	
1,2,-Dichloropropane	1.17E+03	
Bromodichloromethane	3.00E-02	
Tetrachloroethylene	1.12E+03	
Chlorodibromomethane	3.00E-02	
Bromoform	1.67E+01	
Benzene	1.00E+02	
Toluene	7.50E+03	
Ethyl Benzene	1.45E+03	
(m) Xylene	1.45E+03	
(o&p) Xylene	1.45E+03	
(n) Dichlorobenzene	3.00E-02	
(o) Dichlorobenzene	1.00E+03	
(p) Dichlorobenzene	1.50E+03	
Chloroethane	5.20E+04	
1,1,-Dichloroethylene	6.67E+01	
Chlorobenzene	1.17E+03	
Ammonia	3.60E+02	

* Established per New York State Department of Environmental Conservation Air Guide No. 1 for Toxic Air Contaminants. If any federal National Ambient Air Quality Standards or National Emission Standards for Hazardous Air Pollutants are promulgated which are more stringent than these State guidelines, the more stringent standard shall apply.

assist the Town in establishing the initiation of Termination
Monitoring as proscribed in the Consent Decree.

SECTION 3.0

GROUNDWATER TREATMENT FACILITY OPERATIONS

3.1 Theory of Operation

A system of five (5) groundwater recovery wells was installed by the Town at the leading edge of the volatile organic compounds (VOC) plume, located in the Bethpage State Park. The location of the recovery wells/recharge basin are shown in Appendix A of this report.

The combined flow from all wells is directed through common transmission piping to the air stripper wet well. A triplex pump arrangement delivers the collected groundwater to the top of the air stripper containing proprietary packing media. As the groundwater passes through and wets the packing, it is contacted with air directed into the bottom of the air stripper. Dissolved VOC's pass from the liquid phase (groundwater) into the gas phase (air) and exit the stripper through a stack. The treated groundwater is directed into a receiving wet well where another triplex pump arrangement delivers it to a combination of eight (8) diffusion wells in a recharge basin (Recharge Basin No.1), located hydraulically upgradient of the landfill on the west perimeter of the site.

3.2 Physical Plant

The Groundwater Treatment Facility (GTF) consists of the following major components:

- five (5) recovery wells to deliver a combined maximum design flow of approximately 1.5 MGD.
- treatment plant building housing the control room, laboratory, wet wells, pumps, acid rinse system, and chemical holding tanks.

- air stripper and proprietary media.
- recharge basin/diffusion wells.
- transmission piping.

3.3 Initial Operating Conditions

On April 1, 1992, the facility pumped approximately 1.5 MGD of groundwater from the five (5) recovery wells located in the Bethpage State Park. This flow was processed through an air stripper operating at a nominal 1050 GPM forward hydraulic flow and approximately 10,400 SCFM of atmospheric air. The treatment plant design and the initial operating conditions are based on continuous twenty-four hours, seven days per week operation. Some adjustments to water and air flows were made during this reporting period.

3.4 Monitoring Functions

3.4.1 Daily Operations Reports

The control console located at the GTF provides continuous readouts to the operating personnel of pumpage rates from each production well through the plant. Hourly, the operating personnel transfer these readings onto a "Daily Operations Report". One report is completed each shift. A box is provided for the written observations made by those personnel concerning plant operations. These reports for the third operating quarter, from January 1 through March 31, 1993, are reproduced in Appendix B.

3.4.2 Organic Analyses Reports

The Town installed a gas chromatograph at the facility laboratory to self-monitor the day to day treatment efficiency of the facility. During the operating quarter, to assure compliance, influent and effluent samples were taken regularly at the facility and analyzed for VOC's. Originally the sampling and analysis schedule operated daily, Monday through Friday, but was adjusted to three days per week near the end of the second quarter, as it became apparent that treatment efficiency remained high under varying inlet conditions. This procedure was continued during this quarter. In addition, weekly samples from the recovery wellfield are also analyzed for VOC's. All VOC self-monitoring data is reproduced in Appendix C.

3.4.3 Inorganic Analyses Reports

The Town also installed at the facility laboratory, equipment to self-monitor other water quality parameters. These measurements are generally taken to forewarn the operating personnel of changes in the influent or effluent signaling potential equipment problems requiring maintenance. Therefore, soluble iron is occasionally monitored through the air stripper to quantify the potential for iron fouling of the packing media. Dissolved oxygen is measured in the effluent to assure proper blower operation and that the influent has been thoroughly aerated. All inorganic self-monitoring data is reproduced in Appendix D.

3.4.4 State Pollution Discharge Elimination System (SPDES) Reports

In addition to self-monitoring, the Town sends monthly facility effluent samples to a New York State certified laboratory for organic and inorganic analyses. The analyses performed are those required by the Consent Decree, reproduced here as Table 4 as it appears in that document. The monthly SPDES reports from the certified laboratory are reproduced in this document as Appendix E.

TABLE 4

Analytical Methods

<u>Parameter</u>	<u>Analytical Method</u>	<u>Preservation</u>	<u>Sample</u>	<u>Holding</u>
Chloride	SM 407 A	None		28 Days
Ammonia	SM 417B, EPA 350.2	Cool to 4°C pH 2 w/H ₂ SO ₄		28 Days
Iron	SM 303B, EPA 236.1	Field filter. Cool to 4°C. pH 2 w/HNO ₃		6 Months
Hardness	SM 314B, EPA 130.2	Cool to 4°C		6 Months
Alkalinity	SM 403, EPA 310.1	Cool to 4°C		14 Days
pH (measured in field)	SM 423	None		Analyze Immediately
Specific Conductance (measured in field)	SM 205	Cool to 4°C		28 Days
VOCs	EPA 601 and 602	Cool to 4°C		14 Days
Metals and others*	EPA 40 CFR 136.3 (Individual Analyses)	As per Individual method		As per Individual method

*Aluminum, Copper, Lead, Manganese, Nickel, Sodium, Zinc, Chromium (VI), Chromium, Mercury, Potassium, Magnesium, Calcium, Total Dissolved Solids, Nitrate, Sulfate, Carbonate, Total Kjeldahl Nitrogen, Bicarbonate Alkalinity, Cyanide, Phenols, and Barium.

3.4.5 Air Stripper Emissions Testing

The third quarterly emissions test of the air stripper was performed on December 14, 1992. The testing procedure involves obtaining twelve gas samples from the air stripper stack, and to obtain meaningful results, the test is performed during normal facility operations. Hydraulic data is collected in the normal manner. (See Section 3.4.1). The data contained in the "Daily Operations Report" spanning the test period is used to establish the mass quantities of materials emitted by the treatment process per unit of time. The subcontractors report of his findings is reproduced in Appendix F. The fourth quarterly sampling was performed on March 25, 1993, the results of which will be reported in the next quarterly report.

SECTION 4.0

GROUNDWATER MONITORING PROGRAM

4.1 General

In compliance with the Consent Decree for the Old Bethpage Landfill, the following groundwater monitoring related activities were performed during the fourth operational quarter (from January 1 through March 31, 1993) of the Groundwater Treatment Facility (GTF):

- 1) One round of quarterly groundwater quality samples collected from January 5 through January 8, 1993; and
- 2) Three rounds of monthly (operational) water level measurements collected on January 5, February 5 and March 8, 1993.

Geraghty & Miller, Inc. (G&M), Plainview, Long Island, performed all of the hydraulic and groundwater quality monitoring at the site.

The data collected is summarized and evaluated in a document entitled "Quarterly Monitoring Report, Fourth (Operational) Quarter Results, Old Bethpage Landfill", June, 1993 and is presented in its entirety in Appendix G.

4.1.1 Field Sampling Protocols

Except as noted in the subcontractors report (see Appendix G), field sampling procedures used during the January, 1993 Sampling Round were those that were previously submitted to the NYSDEC in July, 1991 by the Town of Oyster Bay, entitled "Protocols for Sampling Groundwater Under the Old Bethpage Solid Waste Disposal Complex Remedial Action Plan". A copy of those field sampling protocols is contained in Appendix G. Evacuation data and

sampling data/field parameters for each well sampled are included on the Water-Sampling Logs in Appendix G. Field Quality Assurance/Quality Control samples utilized during this fourth quarterly sampling round consisted of three field blanks (FB-18B, FB-18C and FB-26) and three daily trip blanks (TB-16, TB-17 and TB-18) analyzed for VOC's only. The field/trip blanks were used to gauge the level of background (VOC) contamination, if any, from sources other than the well. In addition, the duplicate sample was taken from an anonymous well (6C-Rep) and analyzed for the full list of parameters to determine the laboratory precision of the analytical results. The field QA/QC procedures utilized were in conformance with Sections IV.A, IV.B, and IV.C of the Consent Decree.

A stainless steel submersible pump or teflon bailer was used for the evacuation and sampling of Well 30B and OBS-1, respectively, since those wells are not fitted with dedicated sampling equipment. All downhole equipment utilized for sampling which was not dedicated (i.e. used in other wells) was thoroughly sanitized prior to use in a particular well.

4.1.2 Elevation of Recovery Well Screens

Elevations of the well screen intervals (in feet above and below Mean Sea Level) (MSL) were assigned to the following zones for data correlation and water level mapping purposes:

- Water Table Zone - 76 to 43 above MSL
- Shallow Potentiometric Zone - 30 above to 30 below MSL
- Deep Potentiometric Zone - 65 to 157 below MSL

The five recovery well screen intervals are included in both the shallow and deep potentiometric zones.

4.2 Hydraulic Monitoring

The purpose of the hydraulic monitoring is twofold: 1) to delineate the effective capture zone of the groundwater recovery wells so that hydraulic containment of the VOC plume can be demonstrated; and 2) to determine the extent of mounding in the recharge basin area, and the effect of the mounding, if any, on local groundwater flow patterns.

Static water levels were measured to the nearest .01 foot with an electronic water level meter (SLOPE INDICATOR) instead of with the chalk and tape method as referenced in the Consent Decree. In situ dedicated sampling equipment prevented the use of a chalk and tape. The electronic tape is generally considered to be more accurate than a chalk and tape.

Water level measurements collected during the monthly (hydraulic) monitoring rounds were converted to elevations relative to MSL and plotted on a Site Location Map. (See Appendix A, Location Plan). The data points (water level elevations) were then contoured to produce the water table, shallow potentiometric, and deep potentiometric surface maps shown in Figures 1 through 9 of Appendix G. The approximate extent of the VOC plume (based upon the January 1993 sampling data) and the limiting flow lines of the effective capture zone were also drawn on the maps. Contour lines are dashed where the data points are less than optimum; the limiting flow lines drawn through these areas are approximate.

4.2.1 Monthly Water Level Measurements - January, February and March, 1993

The monthly (operational) water level data were collected on January 5, February 5 and March 8, 1993 and are summarized in Tables 1, 2 and 3 of Appendix G. The data are contoured in Figures 1 through 9 for the water table, shallow potentiometric, and deep potentiometric zones of the aquifer. As required for

the Consent Decree, the following wells were incorporated into the hydraulic monitoring:

- all 23 off-site wells (i.e. 5A, 5B, 6A, 6B, etc.)
- existing Phase I, II, and III wells (LF-1 through LF 4)
- the well at Melville Road (N9980)
- Farmingdale Public Supply Wells 1-3 and 2-2
- Pump Test Observation Wells OBS-1 and OBS-2
- Groundwater Remediation Wells RW-1 through RW-5
- Wells upgradient of the recharge basin (29A, B and 30A,B)

In addition, Wells TW-1, TW-2 and TW-3, which were installed in the former Phase II "Pit" area of the landfill, have been added to the monitoring well network to supplement water table mapping. Water level measurements in Farmingdale Public Supply Well Nos. 1-3 and 2-2 were obtained by water district personnel to the nearest 0.5 foot. Water levels could not be obtained in Upgradient Well 9-A during the January sampling round, and water level data for this well is suspect in the following rounds, apparently because gravel pack has entered the well. Upgradient Well MW-29A was found to be dry during the January and March 1993 sampling rounds. Water levels were routinely measured in monitoring wells 6A and 6B during the fourth quarter after scheduled maintenance was performed in these wells.

January 5, 1993 Water Level Elevations

Contour maps depicting the elevations of the water table, shallow potentiometric, and deep potentiometric surfaces on January 5, 1993 are shown in Figures 1 through 3 in Appendix G. In general, compared to earlier rounds conducted during the third operating quarter, water level elevations from this round revealed similar groundwater flow directions. As shown in Figures 1 through 3, groundwater flow directions are to the southeast across the project area, with the exception of radially inward flow from the south, east and western parts of the capture zone toward the

recovery wells. In general, these groundwater flow directions are compatible with the regional (southerly) flow direction, as reported by the United States Geological Survey.

Groundwater elevations observed for the January 5, 1993 round for the water table surface ranged from approximately 70.8 feet above MSL in the recharge basin area (north of the landfill) to 56.5 feet MSL (south of the landfill site) in Well No. N9980 just south of Melville Road. Localized mounding of the water table was observed immediately adjacent to the groundwater remediation system recharge basin, at an elevation approximately equal to that observed during the third operational quarter of the system.

Groundwater elevations of the shallow/deep potentiometric zones of the aquifer during the January monitoring round ranged from approximately 69.0 feet above MSL upgradient of the site to 48.3 feet MSL in remediation Well RW-2 downgradient of the site in the capture zone area. Groundwater elevations south of approximate location of the stagnation point (which delineates the southern boundary of the capture zone), ranged from about 58.0 feet above MSL near the stagnation point to 56.5 feet MSL in the area along Melville Road (see Figures 2 and 3 in Appendix G)

Groundwater elevations in remediation well RW-1 during the January sampling round were found to increase relative to the previous (December 1992) monitoring round because RW-1 was off-line during the time of the water level measurements.

Conversely, water levels decreased in remediation well RW-2 because RW-2 was brought back online prior to the January 5th water level monitoring round. However, as shown in Figures 2 and 3 of Appendix G, hydraulic control over the VOC plume was maintained throughout this period.

February 5, 1993 Water Level Elevations

Contour maps depicting elevations of the water table, the shallow potentiometric surface, and deep potentiometric surface during February 5, 1993 are shown in Figure 4 through 6 in Appendix G. In general, compared to the January 5, 1993 round, water level elevation data from this round revealed similar groundwater flow directions across the site. Water level elevations for the water table ranged from approximately 71.3 feet above MSL (north of the landfill) to 56.6 feet MSL (south of the landfill site). Localized mounding, immediately adjacent to the groundwater remediation system recharge basin, was also observed during this round.

Groundwater elevations in the shallow/deep potentiometric zones ranged from approximately 69.0 feet above MSL in the recharge basin area to 51.3 feet MSL in Well RW-3 in the capture zone. South of the stagnation point, groundwater elevations ranged from approximately 59.0 feet MSL near the south edge of the capture zone to 56 feet MSL in Well N9980 near Melville Road. On average, groundwater flow directions were similar to those recorded during the January 1993 water level monitoring round.

Relative to the January 5th monitoring round as described above, water level elevations fluctuated in response to bringing remediation well RW-1 back online and the temporary shutdown of Well MW-2 for maintenance purposes. Hydraulic control over the VOC plume was maintained throughout this period as evident by the limiting flow lines shown in Appendix G, Figures 5 and 6.

March 8, 1993 Water Level Elevations

Contour maps depicting elevations of the water table, shallow and deep potentiometric surfaces on March 8, 1993 are shown in Figures 7 through 9 in Appendix G. In general, water level elevations in the capture zone decreased during this monitoring

round due to remediation well RW-2 being brought back online. A comparison of the March 8, 1993 water elevation data with that of the 1991 baseline monitoring round reveals an average decline in water levels of approximately three feet across the study area. Localized mounding was also observed in the upgradient recharge basin area, similar to that reported for the previous monitoring rounds. Except for some localized radial flow patterns in the area of Recharge Basin No. 1 and the capture zone area, groundwater flow directions during this round were to the southeast and, were compatible with the regional flow direction.

4.3 Groundwater Quality and Quarterly Monitoring

In accordance with the requirements of the Consent Decree, a quarterly round of groundwater quality sampling was conducted at the Old Bethpage landfill site between January 5 and January 26, 1993. Wells sampled as part of the quarterly groundwater monitoring program, as specified in Section II.B.3 of the Consent Decree, are as follows:

Offsite Wells:	5B
	6A, 6B, 6C, 6E, 6F
	9B, 9C
	11A, 11B
	7B
Observation Well:	OBS-1
Upgradient Well:	M-30B
Landfill Well:	LF-1

MW-30B was sampled as the upgradient well because MW-29A, which was sampled in previous rounds, was found to be dry. MW-30B is located approximately 300 feet southwest of MW-29A, as show in Appendix A. Monitoring well MW-9B was sampled independently on January 26, 1993 following routine maintenance in that well.

Except for Landfill Well LF-1 which was analyzed for leachate parameters only (as per Table 6 in the Consent Decree), all groundwater samples collected were analyzed for Volatile Organic Compounds (VOC's); dissolved (filtered) Metals; total (unfiltered) Metals; and leachate parameters, as required by Table 6.

The results of the quarterly monitoring are summarized in Tables 5, 6 and 7 of Appendix G; the certified laboratory data reports are also presented in Appendix G of this Report. According to the data reports, VOC's were not found in any of the four trip blanks that were analyzed, and duplicate sampling results (i.e. 6C-Rep) were found to be within acceptable limits for all analyses. However, one of the three field blanks which were taken (FB-18B) showed a chloroform concentration of 10 ug/l; however, since no chloroform was found in any of the monitoring well samples, data validation is not required for this analyte. Artifact compounds currently recognized by the Consent Decree were not detected in any of the samples analyzed.

In general, because the groundwater recovery system was designed to capture and treat the VOC portion of the landfill plume, the data analyses focuses on VOC contamination. Analysis of the leachate (inorganic) portion of the landfill plume is limited to a comparison of inorganic data/plume dimensions as previously reported. For reference, all data collected during the January 1993 round are compared to the third quarter data (LKB, May 1993), as well as to the 1991 baseline data (LKB, September 1992).

4.3.1 Analyses of Volatile Organic Compound (VOC) Data - October, 1992

As described in the Third Quarterly Report, three groupings of VOC's were identified in different parts of the study area. These groupings are as follows: 1) volatile halogenated organics (VHOS) except tetrachloroethene; 2) volatile aromatic

hydrocarbons; and 3) tetrachloroethene. An analysis of the VOC grouping is given below and in the groundwater sampling discussion in Appendix G.

The most dominant compounds detected in the first grouping, in terms of occurrence and concentration, were: 1,2-dichloroethene and trichloroethene, at concentrations of 0-79 ug/l and 0-19 ug/l, respectively. Other VHOs were also detected in groundwater samples but in fewer wells and in trace quantities ranging from 0-4 ug/l. Well OBS-1 had the highest concentrations of VHOs detected, followed by Wells 8A and 7B. In general, except for an increase in 1,2-dichloroethene from 34 ug/l to 79 ug/l in Well OBS-1, concentrations of trichloroethene, 1,1-trichloroethene and 1,1-dichloroethene were lower in the January 1993 round than in the October 1992 round.

Figure 10 in Appendix G illustrates the approximate lateral extent of VHO's during the January 1993 sampling round. Based upon the groundwater sampling data, it appears that the lateral extent of VHO's during this round is comparable to that reported during the July/August 1991 baseline sampling round. However, the overall decrease in the concentrations of these contaminants, presumably in response to the groundwater remediation, would imply a reduction in the horizontal/vertical extent of the VHO plume.

The second VOC grouping, aromatic hydrocarbons, which consist of benzene, ethylbenzene, chlorobenzene, p-dichlorobenzene, and o-dichlorobenzene, were detected in a more limited area than the first grouping. The highest concentrations of aromatic hydrocarbons were detected in Well OBS-1 (137 ug/l), Well 5B (13 ug/l) and Well 9C (12 ug/l). Benzene and p-dichlorobenzene were the dominant aromatic compounds detected. The concentration of benzene was found to increase in Well OBS-1 (which is downgradient of the Nassau County Fireman's Training Center) from non-detect in October 1992 to 110 ug/l in January 1993. The

concentration of p-dichlorobenzene has generally decreased during this same period. The only other aromatic hydrocarbon to show an increase in concentration was chlorobenzene, which increased slightly in Wells 5A, 6A and 6B during the period.

The approximate lateral extent of the aromatic hydrocarbon plume based on the January 1993 data is illustrated in Appendix G, Figure 11. A comparison of the January 1993 aromatics plume with that of the baseline 1991 plume (LKB, September 1992) reveals an apparent decrease in lateral extent of the aromatic plume near the eastern plume boundary.

The third VOC grouping, tetrachloroethene, exhibits a very different distribution than the first two VOC groupings. Figure 12 illustrates the approximate lateral extent of tetrachloroethene in January 1993. Based upon the groundwater sampling data, the January 1993 lateral extent for tetrachloroethene appears to be similar to the two separate plumes (east and west) apparent from the October 1992 and July/August 1991 (baseline round) data. The highest concentration of tetrachloroethene was detected in Well 8A, followed by Wells 7B and OBS-1. Concentrations of tetrachloroethene detected in the January 1993 round decreased in Wells 6E, 8A, and 7B from 3 to 2 ug/l, 260 to 250 ug/l, and 340 to 110 ug/l, respectively, when compared to the October 1992 data. The concentration of tetrachloroethene detected in the January 1993 round increased in Wells 6A and OBS-1 from not detected to 1 ug/l and 12 to 27 ug/l, respectively, when compared with October 1992 data.

4.3.2 Delineation of the VOC Plume

The position of the total Volatile Organic Compound (VOC) plume, which includes a composite of the three VOC groupings as described above, has been delineated on Figures 1 through 6 in Appendix G. The outline (hatched area) represents the

approximate maximum horizontal extent of the plume within the aquifer at the time of the January 1993 Quarterly Sampling Round. A review of VOC plume outlines in Appendix A suggests that the approximate length of the plume downgradient of the landfill is 4,000 feet and the maximum width of the plume is about 3,000 feet. A comparison of the current lateral extent of the composite VOC plume with previous third quarter and baseline mapping efforts appears to indicate no significant change in the position of the plume.

However, since groundwater in the capture zone has been moving towards the recovery wells for approximately one year, theoretically, the southernmost extent of the VOC plume should have been reduced. This apparent discrepancy may be accounted for by realizing that the southern boundary of the plume line(s) was estimated by using a less than ideal distribution of monitoring well sampling points.

4.3.3 Analysis of Inorganic Compound Data - January 1993

Inorganic data collected during the January 1993 groundwater quality sampling round are summarized in Tables 6 and 7 in Appendix G. Specifically, the landfill leachate plume exhibits its greatest approximate lateral extent in the middle zone (the approximate elevation of the "B" and "C" wells, which is roughly equivalent to the shallow potentiometric zone) and its greatest approximate thickness (approximately 200 ft) in Well Cluster 6. The highest concentrations of ammonia, potassium, alkalinity (i.e. more basic) detected in the January 1993 round were found in Wells 5B, 6B, 6C, 9C, and LF-1. Manganese, iron, and zinc were detected at their highest concentrations in the January 1993 round in Wells LF-1, M-30B, and OBS-1, respectively. The highest concentrations of hardness, chloride and specific conductivity were detected in Well Cluster 6 and Wells 5B, 8B, 9C, LF-1, and M-30B. Specific conductivity, temperature, Ph and overall water

quality were measured in the field during groundwater sampling and are summarized on the data Sampling Logs in Appendix G.

Concentrations of the leachate indicators in the January 1993 round have remained consistent with the results from the October 1992 round. Compared to the October 1992 data, the concentrations of iron detected in the January 1993 round in Well 9B increased greater than two orders of magnitudes and decreased approximately 6 times in Well M-30B. In addition, the concentrations of ammonia, alkalinity, and potassium detected in January 1993 samples from Wells 6C, LF-1, and M-30B are approximately half the concentrations detected in October 1992.

4.4 Hydraulic Evaluation of the Groundwater Remediation System

4.4.1 Effective Capture Zone

Figures 1 through 9 show the configuration of the water table shallow and deep potentiometric surfaces, relative to the position of the VOC plume, for the January 5, February 5, and March 8, 1993 water level monitoring rounds. In addition, limiting flow lines depicting the effective capture zone are shown on the shallow and deep potentiometric maps. Evaluation of the horizontal and vertical extent of potentiometric contours (i.e. effective capture zone) verifies that during the fourth quarter the full extent of the VOC plume has been captured.

Average water level elevations across the study area have decreased approximately three feet since the 1991 (pre-pumping) baseline water level rounds, and drawdown in the capture zone has ranged from approximately 10 to 12 feet since the start of pumping in April 1992. Mean water level elevations in the capture zone, as measured in the five recovery wells, have shown a steady decline over the first and second operational quarters (from 55.4 to 53.7 feet MSL), and have shown a fluctuating but generally increasing trend during the third and fourth quarters (Figure 6). These fluctuations (from 54.0 to 55.8 feet MSL) are

mostly due to Wells RW-1 and RW-2 being off-line during the January and February, 1993 monitoring round, respectively. In addition, the general increasing trend in water levels may be influenced by fluctuations in the water table and potentiometric surfaces.

Based upon the limiting flow lines of the capture zones, as presented in Appendix G, the average facility flow of 1.39 MGD during this quarter has maintained hydraulic control over the VOC plume. Furthermore, capture of the VOC plume has been maintained during the first four operating quarters, where average facility flow has varied from approximately .90 to 1.42 MGD regardless of the seasonal effects. Therefore, the frequency of hydraulic monitoring can be safely reduced from monthly to quarterly.

4.4.2 Effects of Mounding Due to Recharge

Figures 1, 4 and 7 in Appendix G show the configuration of the water table and mounding in the area of Recharge Basin No. 1 during the January, February, and March 1993 hydraulic monitoring rounds. Data presented in these Figures indicate localized mounding of the water table immediately adjacent to the recharge basin, resulting in a radially outward flow pattern. The elevation of the top of the mound is estimated to range from approximately 70-71 feet above MSL during the fourth operating quarter, which is similar to that reported for the previous quarter (LKB, April 1993). The modification of the local groundwater flow pattern resulting from the mounding is largely restricted to the northwest corner of the landfill property.

During February and March of the Fourth Quarter, standing water was measured at 127 to 128 feet MSL in the recharge basin (26 to 28 feet of standing water). The staff gauge was submerged during the January monitoring round indicating a minimum of 28 feet of standing water in the basins at that time. The standing water in the basin is the equilibrium water level for the recharge basin

system, and is interpreted to be the result of slow seepage of effluent (and runoff water) through the leaching wells/recharge basin and soil. Hydraulic monitoring at the landfill indicates that the standing water in the basin does not significantly add to the elevation of the mounding that was observed and, consequently, does not adversely affect groundwater flow conditions in the area.

4.4.3 Evaluation of System Pumpage

Wellfield operation (see Daily Operating Reports - Appendix B) was reviewed for the period January 1 through March 31, 1993 to estimate: 1) total system flow or system pumpage; and 2) well flow for the individual recovery wells. During the fourth quarter, the actual average system flow, as determined by air stripper operating parameters, was approximately 1.32 MGD.

The groundwater recovery system was fully operational for approximately 53 of the 90 day reporting period. A summary of the daily pumpage records and estimated average system flows, in GPM, is presented in Table 4, Appendix G.

The minimum, maximum and mean average daily pumpage rates (gallons per minute) for each recovery well during January, February and March of the fourth operating quarter are summarized below:

	<u>January 1993</u>		
	<u>Gallons Per Minute</u>		
	<u>Minimum</u>	<u>Maximum</u>	<u>Mean</u>
RW-1	116	200	191
RW-2	94	260	221
RW-3	116	200	191
RW-4	134	218	197
RW-5	117	200	194

February 1993

Gallons Per Minute

	<u>Minimum</u>	<u>Maximum</u>	<u>Mean</u>
RW-1	141	200	194
RW-2	0	256	228
RW-3	141	201	195
RW-4	153	233	220
RW-5	142	201	195

March 1993

Gallons Per Minute

	<u>Minimum</u>	<u>Maximum</u>	<u>Mean</u>
RW-1	0	200	195
RW-2	0	260	244
RW-3	0	200	187
RW-4	0	217	203
RW-5	0	200	188

The average daily pumpage rates do not include days where there was no pumpage in an individual recovery well. The average fourth quarter total system pumpage calculated from this data is 1,014 gallons per minute (1.46 MGD), which is about ten percent greater than that determined from the air stripper effluent flows (1.32 MGD). This discrepancy results from the normal intermittent operation of the recovery well pumps that are designed to maintain a relatively constant system flow.

Average daily pumpage rates during the fourth quarter, as shown above, varied within a tight range (± 6 gpm) in Wells RW-1, RW-3 and RW-5, and in a somewhat higher range (± 23 gpm) in Wells RW-2 and RW-4. These variations in pumping rates between the two groups of wells may be related to the greater aquifer hydraulic conductivities adjacent to the well screens in RW-2 and RW-4.

SECTION 5.0

FINDINGS AND RECOMMENDATIONS

5.1 Discussion

5.1.1 Facility Operations


A review of the "Daily Operations Reports" (Appendix B) for the period reported shows that the facility maintained an on-line performance of nearly 95 percent, and when operating, processed an average of 1.39 MGD. Over this 90-day period, nearly 119 million gallons of groundwater were pumped, treated and recharged at an actual average flow of 1.32 MGD (Figure 1).

The on-line performance record of the facility during this quarter was affected primarily by downtime due to installation of electrical wiring improvements resulting from damage caused by severe thunderstorm activity during the summer of 1992 (about 57.5 hours or 50.4 % of the downtime total). The second major cause of facility downtime was due to power outages caused by nearby underground utility repairs performed by Long Island Lighting Company (LILCO) (about 50 hours or 43.8% of the downtime total). The remaining facility downtime was devoted to acid washing of the air stripper internals, a periodic maintenance procedure. No downtime was recorded during this period from emergency shutdowns due to imminent thunderstorm activity.

The policy of an emergency shutdown during thunderstorm activity was initiated by the Town during the summer of 1992, has been reported previously, and is now a permanent feature of the facility operating procedures. During this reporting period, the installation of surge suppressor equipment at the facility was completed.

TEMPORAL VARIATION IN FACILITY INFLUENT FLOW

FIGURE 1



When the non-facility related downtime due to LILCO is discounted, the on-line performance of the facility increases to 97 percent.

Based on certified laboratory (Appendix E) and self-monitoring data (Appendix C), total influent VOC's during the quarter averaged 233 ppb, and total effluent VOC's for the same period average 1.42 ppb (Figure 2). The influent analyses showed a somewhat wider variation in total VOC's than the previous two quarters, and demonstrated a general downward trend (Figure 3). Much of the downward trend can be attributed to an overall concentration decrease in tetrachloroethene and 1,2 dichloroethene.


Although the average total VOC influent loading fell about twenty-three percent over the previous quarter, overall average treatment efficiency remained the same at about 99.4 percent (Figure 4). On the basis of three SPDES effluent analytical reports by a certified laboratory, and thirty four self-monitoring reports, no parameters were found to be above guideline concentrations during this period.

Removal efficiencies have remained high for three reasons. First, a five well recovery system tends to dampen out large variations in influent VOC concentrations to the air stripper as shown in Figure 5. Although very large variations occur in specific VOC concentrations at individual production wells over time, the overall influent total VOC concentration to the facility normally varied by less than plus/minus 35 percent of the average.

Secondly, the air/water ratio has been maintained higher than 60/1 called for in the manufacturer's design literature. Higher air/water ratios typically will improve to a degree air stripper efficiency to a degree simply by contacting greater volumes of air with the stripper influent. Occasionally, additional


FIGURE 2

TEMPORAL COMPARISON OF INFLUENT/EFFLUENT TOTAL VOC CONCENTRATIONS



TEMPORAL VARIATION IN FACILITY INFLUENT VOC CONCENTRATIONS

FIGURE 3




FOURTH OPERATIONAL QUARTER, 1992-1993

TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY


FIGURE 4

TEMPORAL VARIATION IN TREATMENT EFFICIENCY



TEMPORAL VARIATION IN WELLFIELD TOTAL VOC CONCENTRATIONS

— RECOVERY WELL No. 1 ● RECOVERY WELL No. 2 ○ RECOVERY WELL No. 3 ■ RECOVERY WELL No. 4 □ RECOVERY WELL No. 5
 — AVERAGE INFLUENT - - - FACILITY INFLUENT



FOURTH OPERATIONAL QUARTER, 1992-1993

TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

efficiency can be gained as greater air volumes force the downward flow more evenly across the diameter of the vessel, thus minimizing channeling and "dead" spots in the packing. Some evidence of channeling was evident during an inspection made in February 1993.

Lastly, a high awareness exists among operating personnel regarding maintenance of the stripper internals through observation of the tower packing, where iron deposit fouling can cause a drop in process efficiency. The initial acid washing of the tower internals was performed on March 14, 1992 and removed all visible signs of deposits. During this quarter, the third "acid wash" was performed on March 2, 1993 and removed additional iron deposits. Additional "acid washes" will be performed during 1993 as required.

Therefore, on the basis of the analytical work performed, no additional treatment units are currently required to remove VOC's, since all applicable guideline values are consistently satisfied.

On the basis of three analytical reports from a certified laboratory (Appendix E) and monitoring performed at the Town laboratory (Appendix D), no inorganic parameters were found to be above guideline concentrations. Air flow to the stripper tower had been increased during the second quarter in anticipation of oxidizing additional soluble iron to a precipitate form on the packing media. Iron deposits on the packing are removed during scheduled acid washing of the stripper tower as described previously.

Therefore, on the basis of the analytical work performed, no additional treatment units are currently required to remove iron or other trace inorganic constituents, since all applicable guideline values are consistently satisfied.

A review of the third quarterly air stripper emissions data (Appendix F) indicates that after appropriate modeling to predict annual impacts at the property line using the measured emissions rates, no compound exceeded the NYSDEC Air Guide No. 1 limitations, as originally specified in the Consent Decree.

Since the Consent Decree has been signed and construction began on the Groundwater Treatment Facility, the applicable air discharge limitations were revised, effective June 1991. More recently, the Town has been advised by NYSDEC of certain clarifications to Air Guide No. 1 pertaining to tetrachloroethene (PCE). The results from this stack test indicate that after appropriate modeling to predict annual impacts at the property line using the measured emission rates, no compound exceeded these revised and clarified guidelines.


Therefore, on the basis of the analytical work performed, no additional treatment units are currently required to remove VOC's from the air stripper stack exhaust, since all applicable guideline values are satisfied.

5.1.2 Hydraulic Control of the VOC Plume

In order to evaluate the effect of changing system flow and seasonal variables on water levels in the capture zone, data on system pumpage, water level elevations, and important hydrologic variables were compiled and analyzed by both graphical and statistical methods. Trends in facility flow, monthly rainfall, evapotranspiration and water levels are presented in Figure 6 for the 1992-1993 operational year. Facility flow was compiled from daily pumpage records (i.e., daily operating reports) during times when monthly water level monitoring rounds were being conducted; water level data represents the mean water level elevation in the five recovery wells during the water level monitoring rounds. Precipitation data was obtained on a weekly/monthly basis from a rain gauging station located less

CORRELATION OF RECOVERY WELL AND HYDRAULIC DATA

FIGURE 6



1992-1993 OPERATIONAL YEAR

TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

than one mile from the OBSWDC; data on evapotranspiration was taken from a standard curve that was part of a soil-moisture budget for New York City and vicinity.

Regression analysis of the above data indicated moderately good correlation ($R=0.74$) between facility flow and water level elevations in the capture zone. During the fourth quarter, water elevations in the recovery wells decreased each time the total system flow increased. However, precipitation and evapotranspiration showed poor correlation with facility flow ($R=0.21$ to 0.29). Therefore, it appears that on a daily or short-term basis, system pumpage is the main variable that exerts hydraulic control over the VOC plume; the seasonal effects (i.e., changing groundwater levels due to hydrologic variables) may impart a trend to the water levels over a longer term but will have a relatively minor effect on exerting hydraulic control over the plume.

The slight increasing trend in groundwater elevations observed during the fourth quarter, as shown in Figure 6, may be the result of increased seasonal groundwater recharge. This interpretation is supported by data from the Groundwater Treatment Facility which shows an overall increase in average daily system flow over the third quarter (from 1.32 to 1.39 MGD) which should act to decrease water levels. Nevertheless, evaluation of the data supports the recommendation that if the average facility flow is maintained at the current fourth quarter levels, regardless of seasonal effects, hydraulic monitoring can safely be reduced from monthly to quarterly monitoring.

As discussed in Section 4.4.1, hydraulic control of the VOC plume had been maintained during the fourth quarter, although portions of the wellfield, primarily RW-1 and RW-2, were down for repair. The effect of this well-specific reduction in system pumpage on the extent and configuration of the capture zone can be evaluated by comparing the shallow potentiometric surface contours in

Figures 2, 5 and 8 in Appendix G. Taking recovery Well RW-1 off line had apparently resulted in a reduction in area of the southwest side of the capture zone (with RW-1 now being outside the area of well-defined capture) and a shifting of the maximum drawdown approximately 500 feet to the southwest from Well RW3 to RW-2. Analysis of the limiting flow lines under this pumping scenario indicates that contaminants within the far west side of the plume will still be captured (i.e., from potential sources upgradient of RW-1); however, they will now move toward recovery Well RW-2 at a lower velocity because of the overall reduction hydraulic gradients in the area of RW-1.

Referring to Figures 5 and 8 of Appendix G, the reduction in pumpage from Well RW-2 had not resulted in a noticeable decrease in the total area of the capture zone (compare closed contour line 59 feet MSL) but had resulted in a stronger easterly and westerly component of flow within the capture zone. Under this pumping scenario, groundwater and thus contaminant flow paths are traveling away from static Well RW-2 and toward Wells RW-3 and RW-1; maximum drawdown was found to be bimodal and occurring in Wells RW-1 and RW-3. The width of the capture zone had apparently been reduced in the area of RW-2, presumably because of the tendency to form a line of stagnation between pumping Wells RW-1 and RW-3. For this reason, continuous downtime in recovery Well RW-2 should be kept to a minimum. Qualitative evaluation of the extent of capture, as related to hydraulic control of the VOC plume and potential upgradient sources, will be expanded to include all first year hydraulic monitoring rounds for the 1992 to 1993 annual report.

5.1.3 Remediation of Potential Groundwater Plumes from Other Sources


In addition to monitoring influent and effluent conditions at the facility, the Town regularly monitors VOC concentrations at each recovery well. This analytical data collected during the fourth

quarter (Appendix C) indicates that a general decrease in total VOC concentrations at each recovery well has occurred as shown in Figures 7 through 11. Furthermore, groundwater quality data collected from the Town's groundwater monitoring wells also show a decrease in VOC's during the fourth quarter. Analysis of the above data appears to indicate that the decrease in VOC's may be the result of the recovery of less contaminated plume water in the vicinity of Well Cluster 7 as described below.

As shown in Table 5 in Appendix G, total VOC's in the groundwater monitoring wells have decreased by about 30 percent since the third quarter sampling round. This decrease in VOC's is largely due to the reduction in tetrachloroethene (from 340 to 110 ug/l) in monitoring well 7B, which is located hydraulically downgradient of the former Claremont Polychemical Facility. Presumably, this reduction in tetrachloroethene is the result of changes in spatial and temporal concentrations of tetrachloroethene within the aquifer. Moreover, since Well 7B is located near the inner portion of the capture zone and within the VOC plume area (see Figure 8), it also appears likely that the decrease in VOC's/tetrachloroethene is the result of capture and remediation of part of the highly concentrated plume in the vicinity of Well Cluster 7. The removal of the most highly concentrated plume water from this area would reduce (i.e. dilute) overall wellfield VOC concentrations because progressively less contaminated groundwater would be captured.

With an estimated groundwater flow rate of approximately two feet per day in the capture zone (based upon groundwater flow model data and hydraulic gradients during pumping), groundwater and thus VOC contamination has been captured within a distance of about 750 feet from the recovery wells since the start of pumping in April 1992. With continued pumping, as the tetrachloroethene-concentrated plume in the vicinity of well cluster 8 (located near the south side of the Claremont Polychemical facility) moves closer to Recovery Wells, RW-4 and RW-5, concentrations of VOCs

TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No.1




FOURTH OPERATIONAL QUARTER, 1992-1993
TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No. 2



TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No.3


FIGURE 9



FOURTH OPERATIONAL, 1992-1993


TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No.4



TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No.5

FIGURE 11



FOURTH OPERATIONAL QUARTER, 1992-1993

TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

should begin to show an increasing trend in those wells at some time in the future.

In addition to decreasing VOC concentrations resulting from groundwater remediation, long-term trends in the aquifer may, to some extent, also be affected by one or more of the following: 1) dilution of wellfield VOC's by overpumping and drawing in less contaminated groundwater from outside of the plume; 2) dilution of VOC's by seasonal groundwater recharge within the capture zone; and 3) changing geochemical conditions within the aquifer from pumping induced causes, most notably from sorption/desorption of VOC's by the aquifer materials. Continued analysis of water quality data from the Town's monitoring programs will be necessary to evaluate what extent these factors may be having on influent VOC concentrations.

Close inspection of Figures 7 through 11 indicates that the groundwater composition around each production well exhibits a unique chemical "signature" defined both by chemical species and concentration. Recovery Wells, RW-1, 2 and 3 are heavily influenced by VOC's known to be in the plume from OBSWDC, whereas Recovery Wells 4 and 5 are almost entirely composed of tetrachloroethene, a compound previously noted only in trace amounts on and around the OBSWDC.

A known Superfund site, the Claremont Polychemical manufacturing and storage facility, is located near the northernmost part of what has been identified as the tetrachloroethene plume (see Appendix G, Fig. 12). Tetrachloroethene is a major contaminant historically associated with that site. Furthermore, groundwater and contaminant flow patterns have been shown to travel southeastward or downgradient from the Claremont Polychemical site and is intercepted by Recovery Wells, RW-4 and 5. Geographically, the Claremont Polychemical facility is closest to Recovery Well No. 5, the distance increasing to Recovery Well No. 4, No. 3, etc., and the recorded concentration levels of

tetrachloroethene decline with increasing distance from the site. This relationship is illustrated in Figure 12.

Representatives of the various regulatory agencies and other interested parties have been alerted to this phenomena. However, additional hydrogeological study is required to establish what, if any, link may exist between elevated VOC levels in certain recovery wells and the Claremont Polychemical facility.

5.2 Recommendations

5.2.1 Groundwater Treatment Facility

Certain enhancements performed to the facility control system during the preceding quarter helped to increase on-line performance significantly. Continued quantitative maintenance and facility improvements will be implemented as required.

Under the current operating conditions, the analytical results compiled during this quarter do not support the need for additional groundwater or air stripper exhaust treatment units at this time.

In addition to maintaining and enhancing the facility operation as previously discussed, the Town will continue the GTF monitoring programs put into place since startup. This data, collected from a variety of sources, will form the basis for future facility improvements or adjustments, as required.


5.2.2 Recommendations - Groundwater Monitoring Program

Data presented in Appendix G - Figures 1 to 9 indicates that the actual average facility flow during the fourth quarter (1.32 MGD) is sufficient to maintain hydraulic control over the full extent of the VOC plume. In addition, except for tetrachloroethene detected in a limited number of monitoring wells (which appears

TEMPORAL VARIATION IN WELLFIELD TETRACHLOROETHENE CONCENTRATIONS

B088-12, 140PCE-XLC, FIG 12. 40-HLP, 5/28/83, REV 6/23/83

FIGURE 12



FOURTH OPERATIONAL QUARTER, 1992-1993

TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

to be from sources other than the landfill), concentrations of VOC's detected in the January 1993 sampling round, and in previous sampling rounds, has decreased since the July/August baseline sampling round. Therefore, modification to the system pumpage is not required at this time and the recovery wells can continue to be pumped at their current rate.

Some reduction in flow from the recovery wellfield may be possible without compromising hydraulic control of the VOC plume. Flow reduction may be accomplished by throttling flow from the wellfield or selective wells, taking one or more wells out of operation for some period of time or a combination of these techniques. Although some cost savings can be realized if flow reduction is implemented, the real benefit is in reducing the hydraulic loading on the facility recharge basin. To determine the minimum wellfield pumpage required to maintain proper containment, the flow time can be reduced incrementally (10 percent), and the frequency of hydraulic monitoring increased to weekly until a new capture zone is established.


Based upon the present demonstrated hydraulic control over the VOC plume regardless of the variations in total system flows and seasonal groundwater recharge, the frequency of hydraulic monitoring can be reduced from monthly to quarterly. Any reduction in testing frequency specified in the Consent Decree will require the concurrence of the regulatory agencies. The quarterly groundwater sampling program should be continued without change.

As discussed previously, certain production wells have shown unusual amounts of tetrachloroethene, a chemical not historically associated with OBSWDC, but one of the primary chemical parameters associated with the Claremont Polychemical facility. Groundwater flow direction and chemical analyses indicate that this site may be a contributor of contamination around these wells. Additional data is required to establish that

relationship, if one exists, and to develop an effective contaminant/treatment strategy. Another study of the phenomenon will require the installation of additional monitoring wells between the Claremont Polychemical facility and the wellfield, and sampling of existing wells in and around the Claremont Polychemical facility. Furthermore, since well No. 9a was found to be damaged, that well should be repaired or replaced to allow water levels to be monitored at that location.

APPENDIX A

LOCATION PLAN



APPENDIX B

**DAILY OPERATIONS REPORTS
JANUARY1 Through MARCH 31, 1993**

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-01-01-13
DATE	1-1-93

DAILY OPERATIONS WORKSHEET									
WELL SYSTEMS & AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	STRIPPER FLOW	BLOWER AIR FLOW CFM	AIR PRESSURE INPS WC	EFFLUENT FLOW MGS/SEC
3 PM	190	198	204	198	945	1034	1079	10540.00	NA
4 PM	199	196	198	199	201	948	1049	10166.40	NA
5 PM	143	199	201	203	200	955	1073	1097	9813.40
6 PM	204	199	190	200	202	939	1030	1097	9813.40
7 PM	200	193	199	204	203	944	1053	1103	9813.40
8 PM	204	193	205	197	198	936	1075	1129	9813.40
9 PM	206	196	189	206	200	948	1032	1103	9813.40
10 PM	201	195	192	206	200	940	1052	1102	9813.40
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 AS pump down
 A.S & P.F. Pumps SHUTTING OFF TOGETHER

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

THE ID	93-01-02-11
DATE	1-2-93

AVERAGE PER OPERATING PARAMETERS									
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESSURE Flow GPM	BLOWER Air Flow SCFM	AIR PRESSURE INCHES HG
1 PM	204	199	197	204	201	957	1073	1102	10166.40
2 AM	206	193	200	197	200	948	1031	1096	10166.40
3 AM	204	196	200	196	199	948	1052	1106	10166.40
4 AM	198	198	196	196	199	939	1076	1100	9813.40
5 AM	193	199	194	204	199	949	1038	1100	11813.40
6 AM	195	200	188	194	201	937	1065	1104	9389.80
7 AM	199	197	206	193	196	957	596	8001	9389.80
8 AM	195	200	204	195	198	962	1044	1105	9389.80
9 AM	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 A/S pump out for repair
 A/S + P/E pumps shutdown off together

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

THE ID	93-01-02-12
DATE	1-2-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE GAU	AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	EFFLUENT FLOW L/GAL	SUPERVISOR NAME	
7 AM	191	195	205	197	199	4956	1057	1047	9389.80	287	468	NUX	
8 AM	192	200	190	204	200	950	1078	680	10166.40	107000	56	FALLAW	
9 AM	200	199	195	200	200	947	1035	1100	10166.40	11000	119		
10 AM	203	194	203	195	201	956	1059	1107	10166.40	107000	113		
11 AM	201	200	193	204	201	937	1049	687	10166.40	68700	234		
12 PM	196	198	184	205	198	946	1043	1001	9813.40	100100	298		
1 PM	196	194	201	192	199	938	1060	1117	9813.40	9813.40	351		
2 PM	199	192	204	195	200	962	1022	1100	10540.00	10540.00	414	✓	
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

#1ajs Pump out for Repair

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

F.I.D.	93-01-02-13
Date	1-2-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWER AIR FLOW	AIR PRESSURE INCS/LC	EFFLUENT FLOW L/GALS	SUPERVISOR COMMENTS
3 PM	196	195	199	201	200	949	1048	1103	10166.40	Gauge	464 N/A
4 PM	203	202	192	195	200	948	1075	1102	10166.40	NOT	54 CAVALLARO
5 PM	197	202	205	200	197	955	1030	1094	9813.70	WORTH INC	116
6 PM	204	193	208	198	199	955	1057	1098	9813.70		172
7 PM	193	200	188	203	198	945	1072	1113	10166.40		234
8 PM	192	205	188	203	201	948	1040	1099	9813.40		292
9 PM	190	199	190	202	200	954	1068	1104	9813.40		346
10 PM	189	200	194	204	200	962	1032	1076	9813.40	✓	414
11 PM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

41 A.S. Pump down for Repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

TUE 01	93-01-03-11
PART	1-3-43
DATE	

WELL SYSTEMS							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE FLOW	BLOWDOWN AIR FLOW	AIR PRESSURE INCHES HG	EFFLUENT FLOW	EFFLUENT PRESSURE INCHES HG	SUPERVISOR NAME	
11PM	196	203	208	193	200	957	1042	1101	9813.40	468	ROGERS		
12AM	203	203	201	204	198	949	1072	1101	9813.40	50	FALCIANO		
1AM	194	203	202	192	200	947	1027	1097	9813.40	117			
2AM	192	202	195	205	200	958	1050	1102	10166.40	173			
3AM	204	200	188	198	200	953	1078	1100	10166.40	221			
4AM	197	204	209	192	202	960	1035	1103	10166.40	293			
5AM	194	198	205	203	199	957	1059	1102	10166.40	345			
6AM	202	202	194	196	200	943	593	0001	10590.80	410			
7AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 A/S Pump out for Repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY

DEPARTMENT OF PUBLIC WORKS

GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

DAY SHIFT

93-01-03-12
1-3-a3

REMARKS

~~THE A/S Pump out for Repairs~~

NOTES

- 1- THE SYSTEM FLOW, SHIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILED	93-01-03-13
BY	JAN. 3, 1993

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	BLOWER AIR FLOW CFM	AIR STRIPPER OPERATING PARAMETERS		
										AIR PRESSURE REGUL.	AIR FLOW REGUL.	EFFLUENT FLOW GAL/MIN
3 PM	193	203	196	204	197	960	1042	1097	10166.10	NOT READING	461	N/A
4 PM	200	193	199	201	200	857	1067	1100	10390.0	1	54	1704 GALLS
5 PM	191	200	200	194	200	967	1057	1078	10390.00		124	
6 PM	192	208	195	206	199	950	1047	1102	10590.00		179	
7 PM	196	207	195	203	200	968	1032	1099	10390.00		231	
8 PM	191	206	204	196	200	955	1035	1096	10166.40		300	
9 PM	204	305	201	192	200	965	1052	1100	10166.70	Y	357	
10 PM	206	199	192	202	190	946	1031	1096	10942.00		410	
11 PM												
OVERALL	NA	NA	NA	NA	NA	NA						

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 NIGHT SHIFT

THEIR DATE	93-01-04-13
JAN 4, 1993	

WELL STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	EFFLUENT FLOW
	gpm	gpm	gpm	gpm	gpm	gpm	gpm
1 PM	198	202	204	200	950	1043	1095
2 AM	192	199	203	204	962	1064	1100
3 AM	196	198	204	198	943	582	1094
4 AM	204	203	188	196	200	963	1046
5 AM	195	203	196	199	199	968	1072
6 AM	203	202	204	196	199	957	1033
7 AM	202	203	202	197	200	948	1060
8 AM	199	198	202	205	198	963	1039
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-01-04-12
DATE	JAN 4, 1993

WELL SYSTEM OPERATION

TIME	WELL SYSTEM OPERATION			AIR STRIPPER OPERATING PARAMETERS		
	WELL Flow	WELL Flow	WELL Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow
	gpm	gpm	gpm	gpm	gpm	cm
7 AM	200	188	196	200	954	1036
8 AM	194	203	201	195	958	1064
9 AM	196	204	199	204	951	578
10 AM	191	205	196	206	200	1044
11 AM	205	202	197	199	194	1073
12 PM	201	201	206	200	199	1033
1 PM	192	201	193	204	200	1958
2 PM	196	201	196	200	200	591
3 PM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

#1 AFS Pump out Sea Repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	1-41-93
DATE	9-30-94-13

AVERAGE	NA							
---------	----	----	----	----	----	----	----	----

93-01-04-13
 1-4-93

AIR STRIPPER OPERATING PARAMETERS								
TIME	WELL FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	BLOWED AIR FLOW CFM	EFFLUENT FLOW INCHES WC
3 PM	202	208	202	200	956	1046	10166.40	466
4 PM	201	200	200	202	957	1022	10590.00	60
5 PM	197	198	191	198	974	1039	1097	10166.40
6 PM	204	217	191	204	199	1069	1103	10166.40
7 PM	202	223	206	195	202	978	1035	1099
8 PM	200	223	201	200	200	982	1067	1108
9 PM	194	225	206	204	200	991	1034	1103
10 PM	204	228	196	198	200	985	1077	682
11 PM								
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

A/S #1 OUT FOR PLEA/R
 A/S Pump Station High water level @ 1555

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

DATE	93-01-05-11
TIME	1-5-93

AERATED STRIPPING & CHAMBERS						
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM Flow	STRIPPER Flow	BLOWER Air Flow
11 PM	204	230	193	205	203	985
12 AM	205	233	189	195	202	981
1 AM	193	235	199	205	200	990
2 AM	203	233	194	197	197	993
3 AM	204	235	199	194	203	987
4 AM	203	237	197	196	201	989
5 AM	192	237	206	196	200	990
6 AM	204	236	200	198	200	995
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

THE ID	92 010512
DATE	1-5-92

TIME	WELL INFORMATION					AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AF FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
7AM	193	236	194	202	200	994	1079	676	10590.00	482	CWZD
8AM	192	240	194	203	201	993	1049	1195	10590.00	68	FACITNO
9AM	204	238	194	202	200	1004	1030	1049	10590.00	132	
10AM	204	235	197	204	198	987	1062	1197	10590.00	184	
11AM	198	240	194	205	200	1002	1032	1032	1066.40	256	
12PM	OFF	258	192	195	201	813	1071	1058	10166.40	311	
1PM	OFF	256	190	208	201	823	1076	684	10166.40	361	
2PM	OFF	256	196	206	201	839	598	1	10166.40	440	
3PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

A/S DUT FOR REPAIR

A/S Pump Station water level/High
 PRESSURE Filter pump station Level/High (Reset on/off switch)
 115hp PCL ON STATION #1

1200hrs start down to well as per P.C. I.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FEB 13
 2011
 221157923

WELL PRODUCTION

TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	AIR STRIPPER OPERATING PARAMETERS						
					SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWN AIR FLOW	AIR PRESSURE INCHES HG	EFFLUENT FLOW M3/H	SUPERVISOR SIGNATURE
3 PM	0EF	258	191	203	200	823	1031	1052	10166.40	NOT SUCCE	RODGERES
4 PM	0EF	259	204	191	200	838	585	1037	10166.40	✓	574
5 PM	0EF	259	198	204	200	813	597	1027	10166.40	✓	11042
6 PM	199	0FF	208	192	201	762	1032	1181	10166.40	✓	1071
7 PM	193	0EF	193	206	201	764	595	733	10550.00	✓	197
8 PM	203	232	196	198	200	969	1076	1344	10943.00	✓	257
9 PM	195	232	200	195	200	973	1049	1310	10943.00	✓	315
10 PM	193	234	202	204	200	978	591	717	10580.00	✓	374
11 PM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

PRODUCTION WELL STATION 1/0 1 Down ~~1~~
 For Repair (P.C.I. DN SITE)
 Production well station 1/0 2 Down for
 Repair

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

ITEM #	93-01-06-11
DATE	JAN 6, 1993

WATER SYSTEM LOG							AFTER STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWDOWN AIR FLOW SCFM	AT PRESSURE GAUGE INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR OPERATOR INITIALS
11 PM	205	232	198	196	201	976	1057	723	10590.50	NOT READING	430
12 AM	204	236	196	197	196	978	1035	1187	10590.50	↑	70
1 AM	200	233	203	204	199	975	1064	1188	10590.50		DANIELS
2 AM	196	233	199	201	200	982	1038	1188	10590.50		122
3 AM	194	234	196	198	198	981	1080	1124	10166.40		191
4 AM	194	233	194	201	200	972	1052	1132	10166.40		242
5 AM	203	230	191	203	200	975	386	290-01	10166.40	✓	308
6 AM	203	235	200	203	199	981	10253	1084	102166.40		376
7 AM											432
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

93-01-06/62
 TAN 6/19/93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW cm³/min	PRESSURE FLOW cm³/min	FLOW INCHES/sec	EFFLUENT FLOW M3/HRS	AIR PRESSURE INCHES Hg	SUPERVISOR OPERATOR INITIALS		
7 AM	203	236	202	200	198	977	1031	1059	105200	498	Galicano		
8 AM	206	OFF	203	196	200	156	1040	1061	105400	52	Covaco		
9 AM	203	OFF	200	191	196	778	1053	1057	981340	97			
10 AM	192	257	044	202	200	805	1019	1060	103200	145			
11 AM	192	252	055	197	200	801	584	8001	10166.40	200			
12 PM	196	222	200	202	197	958	599	8001	10166.40	236			
1 PM	195	242	195	044	198	797	1036	1190	10166.40	300			
2 PM	202	244	203	064	147	751	1068	1068	10364.0	340			
3 PM													
4 PM													
5 PM													
6 PM													
7 PM													
8 PM													
9 PM													
10 PM													
11 PM													
12 AM													

REMARKS

A/S #1 Out For Repair
 PUMP ON SITE 0710 hrs,
 (Well #2 OFF (pump) 0745 hrs,
 shut all wells off line at 0008 hrs
 back on line at 0920 hrs. #3 OFF
 4/1 Well #4 off 1140 hrs - on 1150 hrs
 Well #4 off 1300 hrs

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

7:30 PM	93 - 01 - 06 - 13
7:45 PM	1-6 - 93

TIME	WELL SYSTEM DATA			AIR STRIPPER OPERATING PARAMETERS							
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow	BLOWER AIR Flow	AIR PRESSURE	EFFLUENT FLOW	SUPERVISOR COMMENTS	OPERATOR COMMENTS
3PM	208	244	194	6FF	200	790	1071	1102	10166.40	WORKING	RODGERS - 4 HRS
4PM	203	235	201	197	199	980	1033	1088	10590.00	6.2	CAVALLARO
5PM	196	236	200	204	203	976	1068	1097	10166.40	123	LLOYD - 4 HRS
6PM	204	237	197	196	200	981	1045	1094	10590.00	181	
7PM	194	237	203	197	201	978	1029	1079	10270.00	246	
8PM	199	235	204	196	200	979	1065	1096	10166.40	302	
9PM	196	237	202	200	200	978	1037	1093	10166.40	364	
10PM	192	238	203	204	200	989	583	1074	10166.40	430	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#4 WELL OFF. P.C.T. RL K.B making adjustment
 #1 AS Pump Down
 AS + P.F. Pumps shutting off together
 1500 - #4 WELL BACK ON LINE

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID:	93-01-07-11
DATE:	1-7-93

WELL OPERATIONS								AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FILTER FLOW	BLOWDOWN AIR FLOW	AIR PRESSURE INPSIWC	EFFLUENT FLOW	SUPERVISOR COMMENTS		
1 PM	203	237	203	197	200	975	1050	1101	10166.40	NOT	490	LLOYD	
12 AM	195	240	195	199	200	978	1031	1094	10166.40	WORKING	61	DeWEEES	
1 AM	205	288	198	200	200	985	1069	1098	10166.40				
2 AM	198	240	202	192	198	984	1034	1091	10590.00				
3 AM	198	240	196	200	200	974	586	1073	10590.00				
4 AM	204	236	198	201	200	978	1065	1098	10590.00				
5 AM	198	240	196	204	201	983	1036	1091	10590.00				
6 AM	194	240	204	199	201	987	1077	1088	10590.00				
7 AM													
8 AM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93 010712
DATE	1-7-93

WELL HEAD OPERATION

TIME	WELL HEAD OPERATION			AIR STRIPPER OPERATING PARAMETERS		
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow cm Hg
7 AM	204	238	196	200	982	1047
8 AM	200	239	201	200	983	1085
9 AM	203	238	196	200	974	1097
10 AM	192	236	205	200	981	1054
11 AM	193	239	204	200	985	1040
12 PM	191	260	198	04	201	889
1 PM	—	—	—	—	—	—
2 PM	—	—	—	202	196	0001
3 PM	—	—	—	—	—	—
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

A/S #1 out for Repairs
 P.C. I on site 10:45
 Well #4 adjusting well
 All wells shutdown 12:15.

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

93-01-07-13
1-7-93

WELL SYSTEM OPERATION						AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL FLOW	WELL HEAD FLOW	WELL SYSTEM FLOW	WELL HEAD PRESSURE	WELL SYSTEM PRESSURE	STRIPPER FLOW	STRIPPER AIR FLOW	BROWER AIR FLOW	AIR PRESSURE	EFFLUENT FLOW	SUPERVISOR COMMENTS
	GPM	GPM	GPM	PSI	PSI	GPM	CFM	CFM	PSI	MGD	NOTES
3 PM	OFF	OFF	189	OFF	240	0000	0000	10570.00	227Kg	348	SCHADLER
4 PM	OFF	OFF	199	OFF	242	0000	0000	10570.00		20	CARULLARO
5 PM	OFF	OFF	192	200	567	10m ³ /91	10m ³ /76	10570.00		18	
6 PM	188	OFF	202	201	577	10m ³ /567	10.91	10570.00		76	
7 PM	204	OFF	191	196	711	10m ³ /579	10m ³ /77	10166.40		11.5	
8 PM	207	OFF	201	199	762	10m ³ /605	1106	10166.40		148	
9 PM	196	226	201	199	200	973	1067	1095	10570.00	198	
10 PM	202	232	196	198	200	979	1040	1092	10166.40	260	
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#14 S. Pump down
 AS-PF Pumps shutting off Tog & Ther
 15 50-PC-T RLK6 working on wells # 1-2-3 - 5
 16 40-wells # 1-2-5 BACK ON LINE
 20 40-wells # 2-3 BACK ON LINE

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID	93-01-08 - 11
DATE	1-8-93

WELL STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM Flow	STRIPPER Flow	BLOWDOWN Flow	AIR PRESSURE
	GPM	GPM	GPM	GPM	GPM	GPM	PSI
1 PM	197	234	200	201	198	995	59.5
2 AM	200	232	202	207	195	1001	1042
3 AM	200	299	194	192	200	1000	1032
4 AM	204	239	195	193	200	994	1085
5 AM	195	240	194	204	200	1000	1070
6 AM	200	240	201	203	200	995	1097
7 AM	197	240	197	203	200	1003	1038
AVERAGE	NA	NA	NA	NA	NA	1089	10166.40
							428

REMARKS

NOTES

- 1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	92 010812
	9-9-93

WELL SYSTEM DATA

TIME	WELL SYSTEM			AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	STRIPPER FLOW GPM	PRESSURE FILTER FLOW GPM	AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW GALLS/MIN	SUPERVISOR INITIALS
7 AM	197	240	203	195	199	999	579	1067	1094300	Jix
8 AM	240	240	196	199	201	1000	1052	1092	1094300	S7
9 AM	241	197	196	200	1004	1028	1090	1090	1094300	Con 20
10 AM	196	232	203	199	200	998	1070	683	1094300	126
11 AM	194	240	200	204	198	992	1046	1095	1094300	180
12 PM	202	240	203	196	201	996	1028	1088	1094300	312
1 PM	234	236	203	197	200	1000	1077	684	1094300	359
2 PM	241	236	202	194	199	1000	1075	1090	1094300	425
3 PM										
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

A/S #1 out for Repair

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #:	93-01-08 - 13
DATE:	1-8-93

TIME	WELL PUMPING		WELL 3		WELL 4		WELL 5		SYSTEM FLOW		STRIPPER FLOW		PRESSURE FILTER FLOW		BLOWER AIR FLOW		AIR STRIPPER AIR FLOW		AIR STRIPPER OPERATING PARAMETERS		
	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW
3 PM	192	240	199	203	200	1005	1025	1084	9813.40	9813.40	working	492	SCHADLER								
4 PM	200	237	202	203	200	1006	1061	1094	1016.40	1016.40		54	CAVALLARO								
5 PM	204	240	200	198	200	1024	1037	1093	9813.40	9813.40											
6 PM	195	236	199	200	199	997	1067	1109	10590.00	10590.00											
7 PM	193	237	200	201	202	999	1054	1085	10190.00	10190.00											
8 PM	192	240	196	207	198	1004	1033	1090	10590.00	10590.00											
9 PM	204	236	200	198	200	1005	1076	1107	10590.00	10590.00											
10 PM	190	217	202	201	197	999	1035	1081	10590.00	10590.00											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump Down
 A S Y P.F. Pump Shutting off Together

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID	93-01-09-11
DATE	1-9-93

WATER TREATMENT LOG							AIR STRIPPER OPERATING PARAMETERS					
Time	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow	BLOWDOWN Airflow	AIR PRESSURE INPSIG	EFFLUENT Flow	EFFLUENT NIGHTS	SUPERVISOR OPEN/DH NOTIFS
1 PM	194	240	200	197	199	1005	1027	1085	1094300	461	SWAHLER	
2 AM	203	240	196	200	200	1065	1046	105400	40	50	FALCON	
3 AM	196	241	202	200	198	1002	1039	1093	1016640	114		
4 AM	202	243	196	196	200	1001	1024	1086	1016640	178		
5 AM	196	240	202	201	200	1007	1057	1095	181320	232		
6 AM	193	243	197	204	198	999	1038	1092	981340	298		
7 AM	198	243	198	203	198	1010	572	1078	981340	36.5		
8 AM	212	203	195	203	98	1058	1055	1095	181340	421		
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

#1 A/C PUMP OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-01-09-12
	1-9-93

WELL SYSTEM OPERATION					AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	BLOWER FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGD	SUPERVISORY OPERATOR INITIALS	
7 AM	197	24A	197	200	200	1011	1033	1086	9813.40	Not Working	
8 AM	19A	246	202	204	197	1003	572	1075	10166.40	60 FALCIAO	
9 AM	202	243	197	202	200	1004	1055	1043	10166.40		
10 AM	204	246	196	198	201	1007	1035	1001	10540.00		
11 AM	195	244	203	204	200	1009	1024	1083	10540.00		
12 PM	202	244	195	204	200	1007	1058	1047	10590.00		
1 PM	195	248	197	204	201	1005	1037	1084	10043.00		
2 PM	204	247	196	201	199	1009	1024	1083	10540.00		
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 A/s Pump out for Repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

93-01-09-13	93-01-09-13
	1-9-93

WELL PUMPING ACTIVITY								ABOVE STRIPPER OPERATING DATA METERS			
TIME	WELL Flow	WELL Flow	WELL Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE FLOW	BLOWER AIR FLOW	AIR PRESSURE	EFFLUENT FLOW	SUPERVISOR NAME	OPERATOR NAME
3 PM	199	247	199	195	202	1007	1063	1096	10510.00	NA	NA
4 PM	193	248	197	201	199	1004	1040	1092	10590.00	62	CAVALLARO
5 PM	194	248	203	195	198	1008	1027	1085	10590.00		
6 PM	200	248	201	193	200	1008	1033	1069	10166.40		
7 PM	196	240	201	204	200	1009	1070	1099	10166.40		
8 PM	201	249	196	200	200	1012	1043	1096	10166.40		
9 PM	206	250	196	195	200	1009	1026	1089	10166.40		
10 PM	197	248	199	197	200	1007	1075	1106	10166.40		
11 PM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump down
 A.S.P. pumps shutting off together

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

RECORD DATE	93-01-10-11
DATA DATE	1-10-93

TIME	WELL PUMPATION RATE			AIR STRIPPER OPERATING PARAMETERS		
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW
	GPM	GPM	GPM	GPM	GPM	CFM
11 PM	200	250	200	2CA	200	1011
12 AM	193	250	200	196	200	1006
1 AM	202	252	194	205	200	1009
2 AM	194	244	204	196	201	1005
3 AM	194	252	200	194	201	1008
4 AM	202	252	197	198	200	1016
5 AM	190	250	202	200	1013	1011
6 AM	194	252	196	201	198	1011
7 AM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S PUMP OUT FOR REPAIRS
 A/S & D/F PUMPS SHUTTING OFF TOGETHER

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE#	93 01 1012
DATE	1-10-93

WELL FIELD OPERATION GAL/SEC/MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL LOW PSI	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW GALLS	SUPERVISOR OPERATOR INITIALS				
7 AM	196	252	201	196	700	101.3	1034	1092	10166.40	497	NIX				
8 AM	191	254	203	197	704	100.9	1024	1083	10166.40	65	Conzo				
9 AM	197	252	203	198	701.2	101.9	1074	1066.40	10166.40	127					
10 AM	203	254	195	198	700	101.3	584	673	10166.40	183					
11 AM	197	252	203	197	700	100.7	1055	1092	10166.40	243					
12 PM	196	252	203	204	700	101.9	1035	1082	10166.40	307					
1 PM	196	255	200	201	700	101.8	1025	1082	10166.40	375					
2 PM	194	254	200	197	700	100.5	1036	1092	10166.40	430					
3 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

REMARKS

#1 pump out for repair

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE ID	93-01-10-15
DATE	10 JANUARY 1987

WELL SYSTEM OPERATION DATA FOR THIS SHIFT							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESS FIL. GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
3 PM	196	257	201	204	201	1012	1070	1099	10166.40	1107	493
4 PM	192	248	204	196	198	1013	1045	1054	10166.40	Working	
5 PM	193	251	198	202	201	1014	1035	1093	10166.40		Devezis
6 PM	200	252	203	204	198	1013	1024	1056	9813.40		MM
7 PM	202	252	200	196	200	1011	1066	1085	10166.40		
8 PM	200	253	200	198	200	1010	1044	1093	10166.40		240
9 PM	195	252	200	196	201	1003	1030	1083	10166.40		304
10 PM	203	256	197	195	201	1012	1022	1080	10166.40	↓	373
11 PM										↓	442
REMARKS	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

#1 AS. Pump down for repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

TIME	83-01-11
DATE	JAN 11 1983

WELL REPORT

AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	BLOWERS AIR FLOW
	gpm	gpm	gpm	gpm	gpm	cfm
11 PM	203	197	203	200	1007	1095
12 AM	196	196	203	201	1012	1043
1 AM	193	201	202	200	1013	1023
2 AM	199	202	202	200	1014	1023
3 AM	200	196	196	196	1010	1060
4 AM	196	203	203	203	1005	1041
5 AM	204	206	193	199	1006	1038
6 AM	202	200	196	198	1010	1022
7 AM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

REF ID:	93-01-11-12
Date:	5/4/11 1923

WELL FIELD OPERATION ON SITE							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR INITIALS		
7 AM	203	253	203	196	700	1005	1058	1096	10500.00	No +	490	CANZO	
8 AM	196	256	197	204	200	1003	1039	1092	10166.40	W.B KING	65	FACIANO	
9 AM	204	256	203	195	200	1009	1027	1084	10166.40		131		
10 AM	198	256	203	197	200	1008	581	1068	10540.00		195		
11 AM	203	256	202	196	200	1004	1054	1045	10166.40		249		
12 PM	203	256	200	197	200	1007	1041	1091	10500.00		31A		
1 PM	198	256	201	200	200	1008	1028	1082	10166.40		377		
2 PM	190	OF	204	205	196	746	575	1075	10043.00	Y	444		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

A/S # 1 Pump Out for Reptir
 P.C.I. on site 1:15 on Well # 2

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-01-11-13
DATE	1-11-93

WELL SYSTEM OPERATION

TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL SYSTEM		STRIPPER FLOW	PRESSURE FLOW	BLOWER FLOW	AIR PRESSURE INCHES HG	EFFLUENT FLOW MEAS.	SUPERVISOR ON DUTY
				FLOW	FLOW						
3 PM	OFF	OFF	201	200	200	640	1032	1095	10166.40	NOT WORKING	SCHADLER
4 PM	OFF	OFF	209	207	201	628	1030 ^a or 6032	1092 ^b or 678	10166.40		
5 PM	198	OFF	199	189	200	765 ^c	10590 ^d or 673	1097	98/3.70		44 CAVALLARO
6 PM	200	244	201	201	200	996	1052	1097	98/3.70		
7 PM	199	253	198	197	200	995 ^e	1032	1092	98/3.70		
8 PM	198	256	200	202	200	1006	1022	1082	98/3.70		
9 PM	200	256	198	200	198	1003	1020	1079	10166.40		
10 PM	201	259	200	197	200	1005	1047	1096	10166.40		
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S.P. Pump Down
 A.S.T.P.F. Pumps Shutting off Together
 P.C.I. + L.K.B. Working or THE WEEKS
 P.C.I. + L.K.B. OFF SITE AT 16:30

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

TIME	73-01-12 - 11 PM
DATE	JAN 12, 1993

WELL PUMP OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow	BLOWDOWN Air Flow	AIR PRESSURE INCHES HG	EFFLUENT Flow GPM	SUPERVISOR OPEN/TOP VALVES
11 PM	195	232	201	196	200	1005	1064	1090	10.66 .01	101	LLOYD
12 AM	198	232	201	195	200	1003	1023	1092	10.66 .01	101	DUNNEUS
1 AM	198	232	200	194	201	1009	1038	1086	10.66 .01	101	
2 AM	197	230	196	203	200	1008	1025	1083	10.66 .01	101	
3 AM	200	230	195	204	197	1012	1024	1076	10.66 .01	101	
4 AM	199	258	198	194	200	1004	1066	1097	10.66 .01	101	
5 AM	201	256	204	195	200	1010	1042	1094	10.66 .01	101	
6 AM	200	259	200	194	201	102	1033	1089	10.66 .01	101	
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE ID:	93-O1-12-12
DATE:	JAN 12, 1993

WELL SYSTEM OPERATION						AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL LOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGD	SUPERVISOR OPERATOR INITIALS
7 AM	199	257	203	201	1008	1026	1082	106640	ND	4.92	CONZO
8 AM	199	255	202	194	1004	1073	1075	1016640	ND	5.9	FALUANO
9 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
1 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S PUMP OUT FOR REPAIRS
 Fred been P.C.I. on site at 0725 hrs.
 Plant shut down at 0800 hrs. for P.C.I.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-01-12 - 13
TIME	1-2-93

WELL SYSTEM OPERATION

AIR & STRIPPER OPERATING PARAMETERS						
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW
3 PM	OFF	—	—	—	—	—
4 PM	OFF	—	—	—	—	—
5 PM	OFF	—	—	—	—	—
6 PM	OFF	—	—	—	—	—
7:21	201	OFF	196	193	201	763
8:31	199	OFF	192	204	200	762
9:31	202	OFF	198	202	200	773
10 PM	194	OFF	194	205	201	768
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

1500- PLANT DOWNTIME WORKING ON PUMP
 1800- PLANT ON LINE. #1-3 445'WELL S.O.N
 1800- Running A.S Pumps on MANUAL. Work work in Auto

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

THEID:	93-01-13-11
DATE:	7-3-93

WELL HEAD OPERATION

TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESSURE Flow GPM	BLOWER Air Flow SCFM	AIR PRESSURE INCHES WG	EFFLUENT Flow GPM	SUPERVISOR Signature
11 PM	200	OFF	208	188	200	764	0000	1074	1066.40	237	Lloyd
12 AM	196		206	189	199	765	1059	1086	1066.40	40	Deonius
1 AM	194		202	206	200	783	1061	681	907.40		
2 AM	200		195	192	201	764	1064	680	1071.40	130	
3 AM	194		193	207	201	768	1050	1024	9813.40	182	
4 AM	191		201	206	202	774	1041	1090	9813.40	231	
5 AM	196		206	197	194	752	0000	1081	9813.40	284	
6 AM	197		204	200	202	763	1029	1087	9813.40	323	
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

ESTATE	9.3 - 01 - 1.3 - 12
DATE	7-13-93

WELL SYSTEM OPERATION						AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	BLOWER FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGD	SUPERVISORY OPERATOR INITIALS
7 AM	200	OFF	198	197	202	576	1017	1043.00	NET	376	FALCIANO
8 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	Working	37	CANZO
9 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF			
10 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF			
11 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF			
12 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF			
1 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF			
2 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF			
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

- * 1 A/S DUMP OUT FOR REPAIRS
- * 2 WELL OFF
- DC1 ON SITE 0745
- System Down 0755 / PC1

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

93-01-13	1-13-93
----------	---------

WATER TREATMENT										AIR STRIPPER OPERATING DATA METERS			
TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWDOWN AIR FLOW	AIR PRESSURE	EFFLUENT FLOW	EFFLUENT FLOW	SUPERVISOR COMMENTS	
3 PM	OFF												
4 PM	200	248	200	198	199	1000	1060	1078	9389.80	NOT WORKING	40	SCHADLER	
5 PM	199	252	202	195	199	1000	1037	1075	9389.80			36	
6 PM	200	257	198	201	197	1010	1027	1075	10166.40			103	
7 PM	197	257	198	203	199	1009	1021	1070	9813.40			167	
8 PM	196	256	199	204	201	1007	1064	1097	9813.40			219	
9 PM	200	256	200	202	200	1011	1044	1092	9389.80			284	
10 PM	200	257	197	196	200	1001	1032	1089	9389.80			347	
11 PM													
LAST PAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

1.5 to 2.0 PLANT DOWN. P.C.I. WORKING ON PAILL
 BOTH A.S. PUMPS SHUTTING OFF TOGETHER. SAME PROBLEM WITH P.F. PUMPS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

THURSDAY	9.3 - 01-141-11
DATE	1-14-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE FLOW	BLOWDOWN	AIR STRIPPER	EFFLUENT FLOW	SUPERVISOR SIGNATURE
	gpm	gpm	gpm	gpm	gpm	gpm	gpm	gpm	NECESSARY	MEASUREMENTS	OR COMMENTS
11 PM	200	259	203	195	200	1011	1025	1081	9813.70	1	LLOYD
12 AM	197	258	199	204	200	1005	597	682	9813.40		6/1
1 AM	198	256	201	204	196	1013	1054	1095	9813.40		153
2 AM	199	260	200	196	199	1010	1040	1092	9813.40		190
3 AM	197	259	196	205	199	1012	1031	1087	9813.40		252
4 AM	201	260	194	204	200	1012	1025	1081	9813.40		313
5 AM	200	260	196	204	200	1012	1033	1100	9813.40		380
6 AM	201	258	194	195	200	1006	1047	1095	9813.70		442
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93011412
DATE	1-14-93

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	EFFLUENT FLOW CM	AIR PRESSURE INCHES WC	SUPERVISOR INITIALS	EFFLUENT FLOW INCHES WC	AIR PRESSURE INCHES WC	SUPERVISOR INITIALS		
7 AM	196	256	199	263	200	1016	1035	1092	9107.40		502	7045.			
8 AM	201	258	196	204	200	1009	1027	1084	9107.40		64	100			
9 AM	201	256	196	199	201	1012	583	665	9813.40		31				
10 AM	196	257	201	196	200	1005	1058	1095	9389.80		184				
11 AM	200	259	202	197	180	1006	1042	1092	9813.40		245				
12 PM	201	256	198	197	201	1011	1032	1087	10443.00		312				
1 PM	194	256	203	201	204	1012	1026	1080	10943.0		370				
2 PM	201	256	125	200	191	1003	600	673	10843.0		470				
3 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

A/3 Pump #1 Down - Set Point Select Not there?

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE ID:	93-01-14-13
DATE:	1-14-93

WELL FIELD OPERATION DATA SHEET								AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE	BLOWER FLOW	AIR FLOW	EFFLUENT FLOW	SUPERVISOR		
	gpm	gpm	gpm	gpm	gpm	gpm	inches wc	gpm	cfm	gpm	OPERATOR INITIALS		
3 PM	200	257	262	198	199	1010	1048	1092	9389.80	6.25Kw	495	S. HADLER	
4 PM	201	258	198	196	200	1009	1039	1089	98.340		62	C. MALLARO	
5 PM	195	259	198	205	200	1011	1030	1081	9813.40				127
6 PM	200	259	202	194	200	1009	1025	1075	9389.80				189
7 PM	199	256	197	203	199	1007	1069	1101	9389.80				245
8 PM	201	258	204	195	200	1008	1047	1097	9389.80				309
9 PM	200	258	197	199	200	1006	1032	1090	9813.40				375
10 PM	201	258	200	198	200	1010	1028	1084	9813.40				440
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

12:30 AM SHUTTING OFF TOWER. SAME PROBLEM WITH PFF PUMPS

- 1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

NOTES

- 1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID	93-01-15-11
DATE	1-15-93

TIME	WATER TREATMENT SYSTEM				AEROSTripper OPERATING PARAMETERS			
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow	BLOWER Air Flow
	GPM	GPM	GPM	GPM	GPM	GPM	GPM	CFM
1 PM	200	260	197	204	199	1010	1024	1079
2 AM	200	257	199	194	199	1061	1081	1066.40
3 AM	200	260	197	201	197	1005-	1041	1066.40
4 AM	196	260	197	196	200	1000	1032	1055-
5 AM	201	259	196	203	200	1012	1027	1079
6 AM	200	260	204	196	200	1011	586	1046
7 AM	199	256	199	200	200	1013	1060	1093
8 AM	200	257	199	196	200	1009	1044	1092
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

STEP	93-01-15-12
DATE	15 January 1993

WELL HEAD OPERATION							ABSORBENT OPERATING PARAMETERS				
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESSURE Flow GPM	BLOWER Air Flow CFM	AIR PRESSURE INCHES HG	EFFLUENT Flow MGD	SUPERVISOR OPERATOR INITIALS
7 AM	200	260	203	193	200	1008	1030	1085	10166.40	Not	500 Conzo
8 AM	200	259	196	203	201	1006	1025	1079	10166.40	400/1000	65 NIX
9 AM	195	257	197	203	201	1004	1073	1116	10166.40		i17
10 AM	201	258	201	196	198	1003	1051	1098	10166.40		184
11 AM	200	260	200	196	200	998	1038	1093	10166.40		248
12 PM	200	259	197	203	200	1007	1030	1085	10166.40		305
1 PM	201	260	195	204	200	1008	1025	1080	10166.40		380
2 PM	200	258	170	200	199	1010	1070	1095	10166.40		425
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

A/ST Pump Out for Repair
 Main unit for Repair

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-01-15-13
TIME	1-15-93

AFTERNOON OPERATING PARAMETERS							
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	BLOWER AIR FLOW	AIR PRESSURE INCHES HG
3PM	200	259	199	200	201	1004	1095
4PM	198	260	195	202	200	1002	1034
5PM	200	197	199	200	1004	1025	1076
6PM	200	199	200	200	1009	1024	1072
7PM	196	258	200	202	198	1003	1072
8PM	201	258	200	201	200	1004	1055
9PM	200	259	200	196	200	1002	1039
10PM	201	260	200	201	1003	1038	1090
11PM	NA	NA	NA	NA	NA	NA	NA

REMARKS

A.S.P.M's setting off timer. Same problem with P.F.P.M's
 #1 AS pump down

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	5/2 - 5/6 - 11
DATE	1-16-92

WELL PUMP OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING DATA METERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	BLOWN AIR FLOW GPM	EFFLUENT PRESSURE INCHES HG	EFFLUENT FLOW GALLONS MINUTES	SUPERVISOR OPERATOR INITIALS		
11 PM	200	260	192	1004	1024	1078	9813.40	1	503	SCHROEDER	
12 AM	196	260	203	1012	1023	1073	9813.40		60	FALCONO	
1 AM	199	254	197	1002	106A	1004	9813.40		112		
2 AM	145	260	201	1006	1047	1046	9389.80		175		
3 AM	200	260	204	1011	1036	1093	9107.40		239		
4 AM	201	260	196	1002	1028	1085	9813.40		309		
5 AM	201	262	203	1005	1024	1079	9813.40		366		
6 AM	200	257	198	1010	1070	1095	9813.40		421		
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

1 A.S. PUMP OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD DATE	93-01-16 - 12
END DATE	1-16-93

WELL 1 OPERATIONS

AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	AIR STRIPPER Flow
	gpm	gpm	gpm	gpm	gpm	gpm
7 AM	200	259	200	199	195	1048
8 AM	201	259	203	196	200	1009
9 AM	200	261	200	196	197	1007
10 AM	197	260	202	204	199	1010
11 AM	201	257	202	194	200	1008
12 PM	196	259	201	197	198	1005
1 PM	198	263	195	201	200	1004
2 PM	100	260	196	204	199	1009
3 PM						
VERIF.	NA	NA	NA	NA	NA	NA
REMARKS	# 1 A.S. PUMPS OUT FOR REPAIRS					

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

93-01-16-13	93-01-16-13
11-16-93	

AIR STRIPPER OPERATING PARAMETERS											
WEIGHTS PER MINUTE		WEIGHT FLOW		SYSTEM FLOW		STRIPPER FLOW		PRESSURE FLOW	BLOWER AIR FLOW	EFFLUENT FLOW	SUPERVISORY
TIME	WEIGHT	WEIGHT	FLOW	WEIGHT	FLOW	SPM	FLOW	PSI	CFM	INCHES WC	OPERATOR
3 PM	199	260	197	201	199	1012	1024	1078	10166.40	NA	Nix
4 PM	199	258	198	202	200	1004	1072	1095	9813.40	55	Capt
5 PM	200	258	196	203	200	1009	1048	1096	10166.40	123	
6 PM	197	259	198	204	200	1015	1037	1091	9813.40	184	
7 PM	199	160	196	204	200	1030	1029	1085	10166.40	249	
8 PM	196	261	196	204	201	1010	1023	1075	10166.40	314	
9 PM	199	256	200	204	199	1005	1012	1092	9813.40	367	
10 PM	200	260	196	199	200	1002	1051	1099	10166.40	430	
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 A. S. PUMP OUT REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

SHIFT	93-01-17-11
DATE	1-17-93

WELL STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	BLOWDOWN FLOW GPM	AIR PRESSURE PSI
11 PM	196	203	197	200	1008	1038	10166.40
12 AM	201	200	195	200	1008	1031	10166.40
1 AM	200	200	196	200	1007	1025	10166.40
2 AM	200	202	198	200	1009	1020	9813.40
3 AM	201	204	193	200	1005	1058	10166.40
4 AM	202	203	193	200	1007	1041	9813.40
5 AM	199	200	203	204	197	1010	1032
6 AM	198	202	196	202	200	1007	1027
7 AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S Pump Down
 WITH A.S Pumps SHUTTING OFF Together SAME problem with P.F.Pumps

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD DATE	93-07-17-12
ENTRY DATE	1-17-93

WATER TREATMENT							AIR STRIPPER OPERATING PARAMETERS						
TIME	WATER FLOW	WATER FLOW	VENT FLOW	VENT FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	AIR FLOW	AIR FLOW	EFFLUENT FLOW	EFFLUENT FLOW	NOTES	
	gpm	gpm	gpm	gpm	gpm	gpm	psi	scfm	scfm	scfm	scfm		
7 AM	199	261	196	204	200	1011	1022	1074	10166.46	Not Working	565	N/A	
8 AM	199	259	202	201	200	0997	1000	1097	10590.00		63	Circuit	
9 AM	200	256	200	204	200	1006	1048	1092	10590.00		115		
10 AM	196	262	203	202	200	1017	1035	1090	10590.00		181	"	
11 AM	200	261	200	198	197	1013	1027	1084	10590.00		246	"	
12 PM	200	262	204	194	200	1010	1022	1078	10166.46		113		
1 PM	196	257	202	198	201	1007	1070	1093	10590.00		364		
2 PM	195	261	198	196	200	1009	1049	1094	10166.46		426		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

/ A 5 Pump is Down

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-01-17-13
TIME	1-17-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW SPM	BLOWER AIR FLOW CFM	EFFLUENT PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR INITIALS
5:30	199	259	195	204	200	1013	1038	1089	10590 ^a W.C.B. 99	493	Nix
6:00	200	260	196	199	200	1007	1028	1080	10590 ^a C.R.P.C.Y.	64	
6:30	200	260	195	201	199	1011	1022	1076	9913.40	127	
7:00	200	259	197	196	200	1004	1038	1089	9913.40	186	
7:30	196	259	203	195	200	1011	1055	1093	9913.40	245	
8:00	201	260	199	196	201	1009	1039	1088	9813.40	311	
8:30	200	260	202	196	199	1008	1030	1085	10166.40	373	
9:00	198	260	193	204	198	1005	1024	1073	10166.40	442	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

/ A. S. Parrot is down

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

NIGHT SHIFT

92-01-18-11
1-18-q2

REMARKS

#1 A/S PUMP CUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	92-01-18 - 12
TIME	1 - 8 - 93

**WELL TO OPERATION
 DAY SHIFT UNIT**

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESS FIL LOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW WEBS	SUPERVISOR INITIALS
7 AM	200	260	197	204	200	1004	1037	1089	10166.40	490	Nix
8 AM	200	260	198	197	199	1003	1027	1081	10166.40	63	Capek
9 AM	196	260	197	200	201	1007	1022	1075	10166.40	127	
10 AM	199	261	205	205	201	1012	1018	1020	10596.40	191	
11 AM	200	260	198	198	200	1004	1055	1092	10166.40	250	
12 PM	200	260	199	203	200	1009	1042	1088	9993.40	308	
1 PM	201	260	199	200	197	1008	1038	1086	10166.40	271	
2 PM	196	261	203	196	201	1007	1025	1080	9813.40	438	
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

1 H.S. Pump is down

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

TIME	9:30 - 01 - 18 - 13
	1-18 - 9:3

WELL SYSTEM OPERATION
 WELL 1, 2 & 3, 4, 5, 6, 7, 8, 9, 10

TIME	WELL SYSTEM OPERATION								AIR STRIPPER OPERATING PARAMETERS			
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow gpm	PRESSURE Flow gpm	RECOVERED AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGD	SUPERVISOR INITIALS	
2 PM	201	260	202	200	200	1003	1020	1073	9813.40	501	LCOYO	
1 PM	200	258	192	201	200	1007	1069	1085	9318.40		52	CRAEK
5 PM	200	259	195	202	200	1003	1048	1097	9813.40			
6 PM	196	260	204	199	200	1011	1030	1091	9389.50			
7 PM	192	260	201	199	197	1005	1028	1084	9813.40			
8 PM	196	260	204	197	200	1003	1021	1072	1016.40			
9 PM	198	260	200	196	200	1011	1019	1073	9813.40			
10 PM	198	260	203	199	200	1010	1070	1093	9813.40			
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

/ A.S. Pump is down

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

THE DATE	9.3.01-19-11
PAGE	7-19-93

WELL FLOW OPERATIONS							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR INITIALS
11 PM	200	260	204	198	200	1008	1045	1992	9813 20	486	LLOID
12 AM	198	261	194	196	199	1001	1034	1855	9813 40	70	DOUGLASS
1 AM	200	263	196	204	200	1023	1026	1076	9813 40	135	
2 AM	192	214	197	202	200	1004	1020	1020	9813 40	197	
3 AM	200	260	199	198	200	1007	990	1001	10166 40	253	
4 AM	197	259	201	196	197	998	1056	1023	10164 00	310	
5 AM	200	260	201	196	199	1008	1039	1089	10166 00	375	
6 AM	200	262	200	198	200	1007	1029	1083	10166 00	440	
7 AM											
EFFLUENT	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	13-01-19-12
TIME	1-19-93

WELL FIELD OPERATION				AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FIL FLOW GPM	BLOWER AIR FLOW CM/H	AIR PRESSURE INCHES WG	EFFECTIVE FLOW MEALS	SUPERVISOR OPERATOR INITIALS
7 AM	200	261	196	204	197	1007	1021	1076	438980	NOT	500
8 AM	200	262	200	199	201	1008	1020	1070	481340	WORKING	EB
9 AM	199	260	203	196	200	1004	1068	1082	1016640		CONZO
10 AM	200	197	200	196	201	956	1031	1068	1016640		
11 AM	198	203	204	197	199	956	1067	865	1016640		
12 PM	201	205	198	205	201	964	1022	1081	481340		
1 PM	196	203	194	202	200	953	1050	1093	481340		
2 PM	200	200	203	192	200	954	1023	1087	1016640		
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 A/S PUMP OUT FOR REPAIRS
 L.K.B., BRWOC RESET WELL #2 AT 10:30 hrs.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILED	93-01-19-13
DATE	1-19-93

WELL FIELD OPERATION DATA SHEET				AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE HEAD CM	AIR FLOW INCFN
3 PM	202	206	196	200	956	1047	10166.40
4 PM	200	200	197	200	955	1020	10166.40
5 PM	201	205	200	199	201	955	1048
6 PM	201	207	195	200	200	955	1017
7 PM	201	207	196	203	199	960	1040
8 PM	199	199	196	202	200	953	1070
9 PM	196	202	193	203	200	950	1034
10 PM	199	206	203	196	200	960	1064
11 PM	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S Pump Down
 BOTH A.S PUMPS SHUTTING OFF TOGETHER. SAME PROBLEM WITH PUMP'S

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OFF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 NIGHT SHIFT

20
 93-01-~~11~~-11
 JAN 1993
 10

WELL STRIPPER OPERATING PARAMETERS						
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	EFFLUENT FLOW
	GALLONS PER MINUTE	GALLONS PER MINUTE	GALLONS PER MINUTE	GPM	GPM	GPM
11 PM	200	204	196	204	200	960
12 AM	199	201	199	204	200	955
1 AM	199	204	196	205	200	958
2 AM	203	203	196	203	197	956
3 AM	196	203	204	192	200	953
4 AM	196	200	202	201	199	942
5 AM	200	201	204	199	198	951
6 AM	204	206	192	196	199	953
7 AM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE ID	93-01-30-62
DATE	1-20-93

TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	AIR STRIPPER OPERATING PARAMETERS		EFFECTIVE FLOW MINUTES
					STRIPPER FLOW GPM	STRIpper Flow GPM	
7 AM	201	200	196	200	955	1065	1107
8 AM	195	205	199	204	957	1028	1090
9 AM	197	200	201	201	198	1056	1092
10 AM	200	201	202	195	200	950	1021
11 AM	200	201	196	201	200	954	1040
12 PM	200	202	192	201	200	948	1014
1 PM	200	201	207	194	194	957	1022
2 PM	200	204	200	196	200	951	579
3 PM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A's pump out for repair &
 #Well 5-CV-52 " open - close right - wrong - 140cm³

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

SHIFT	9.3 - 01 - 20 - 13
DATE	1-20-93

WELL SYSTEM OPERATION										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	BLOWER AIR FLOW CFM	EFFLUENT PRESSURE INCHES WC	STRIKER WORKING	EFFLUENT FLOW INCHES WC	SUPERVISOR INITIALS			
3 PM	198	205	202	215	200	962	1038	1092	1016.40	NOT WORKING	475	SeHADLK			
4 PM	201	212	196	212	200	968	1019	1083	9813.40			CAVALLACO			
5 PM	195	214	203	204	199	962	1030	1040	9813.40						
6 PM	200	218	198	212	201	974	1026	1087	9813.40						
7 PM	197	220	196	208	200	970	1061	1092	9389.80						
8 PM	196	224	202	211	198	983	1033	1090	9389.80						
9 PM	199	228	197	211	200	984	1020	1084	9389.80						
10 PM	196	228	202	208	201	984	1053	1093	9389.80						
11 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 H.S. Pump Down
 BOTH HS PUMPS SHUTTING OFF AT SAME TIME, SAME PROBLEM WITH
 P.F. UNITS.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD	93-21-21 - 11
DATE	1-21-93

WELL SYSTEM OPERATION

TIME	WELL FLOW			WELL FLOW			SYSTEM FLOW			STRIPPER FLOW			PRESSURE FLOW			BLOWER AIR FLOW			AIR PRESSURE			EFFLUENT FLOW			SUPERVISOR NOTES				
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	WELL 5 Flow	WELL 6 Flow	WELL 7 Flow	WELL 8 Flow	WELL 9 Flow	WELL 10 Flow	WELL 11 Flow	WELL 12 Flow	WELL 13 Flow	WELL 14 Flow	WELL 15 Flow	WELL 16 Flow	WELL 17 Flow	WELL 18 Flow	WELL 19 Flow	WELL 20 Flow	WELL 21 Flow	WELL 22 Flow	WELL 23 Flow	WELL 24 Flow	WELL 25 Flow	WELL 26 Flow			
11 PM	196	232	204	209	200	993	1033	1088	9389.80	NET working	486	Lloyd																	
12 AM	198	233	196	209	200	989	1021	1082	9389.80																		6.2	Cavallaro	
1 AM	198	234	199	208	198	993	1059	1092	98/3.40																			1/8	
2 AM	197	234	199	208	199	991	1038	1089	9389.80																			182	
3 AM	197	239	194	209	200	990	1022	1078	98/3.40																			245	
4 AM	200	236	196	208	200	993	1057	1092	98/3.40																			305	
5 AM	197	239	201	208	200	998	1044	1095	98/3.40																			365	
6 AM	200	240	195	209	200	995	1030	1087	98/3.40																			428	
7 AM																													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA											

REMARKS

#1 A.S. Pump Down
 #2 A.S. Pumps shutting off at same time. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	5.3-01-21-12
DATE	1-31-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	RECOVER AIR FLOW CFM	EFFLUENT PRESSURE INCHES W.C.	EFFLUENT FLOW GPM
7 AM	196	240	198	201	992	1020	1081	981.3	40	490	CENTER
8 AM	200	238	201	208	200	992	1061	981.3	40	54	COMBINE
9 AM	200	240	185	208	200	994	1058	1050	9107.40	119	M.A
10 AM	197	241	196	208	201	1000	1025	1082	3472.00	183	
11 AM	197	240	201	208	200	993	1015	1077	9102.40	250	
12 PM	200	238	199	208	200	998	1053	1083	4101.40	303	
1 PM	200	239	197	208	200	999	1034	1082	3472.00	370	
2 PM	197	240	203	208	196	996	1022	1079	9393.40	435	
AVERAGE	NA	NA	NA	NA	NA						

REMARKS

A/S #1 Pump out for repair
 never out for repair

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-01-21 - 13
	1-21-93

TIME	WELL SYSTEM		WELL STRIPPER		AIR STRIPPER		OPERATING PARAMETERS		SUPERVISOR Operator Initials
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER Flow GPM	PRESS FIL FLOW GPM	BLOWER Air Flow CFM	
3 PM	200	240	196	208	200	993	1066	1115	9389.80
4 PM	200	238	195	209	201	993	1048	1096	9813.40
5 PM	200	239	202	208	198	1002	1032	1083	9813.40
6 PM	200	241	203	209	200	1004	1019	1082	9813.40
7 PM	199	240	199	208	201	993	1066	1090	9389.80
8 PM	200	240	200	208	199	996	1042	1089	9389.80
9 PM	198	240	204	208	201	998	1026	1085	9813.40
10 PM	201	240	202	208	200	998	1018	1077	9813.40
11 PM	NA	NA	NA	NA	NA	NA	NA	NA	NA
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1A Sump Down
 Both A's pump shutting off together. Same problem with P.F. Pump

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 NIGHT SHIFT

FIELD ID	193-01-22-97
DATE	JAN 22, 1993

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	BLOWN AIR FLOW CFM	AIR PRESSURE INCHES WC
11 PM	198	240	196	208	200	995	1062
12 AM	190	240	198	208	200	995	1036
1 AM	199	244	195	209	200	997	1026
2 AM	199	243	195	209	200	1001	1018
3 AM	199	241	199	208	200	988	1058
4 AM	200	242	197	208	201	997	1037
5 AM	198	244	201	208	198	1003	1023
6 AM	201	242	201	209	196	1002	1018
7 AM	NA	NA	NA	NA	NA	NA	NA
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TEP Date	9/3 - 01-3.2 - 12
	/ - 22 - 9.3

WELL 1 OPERATIONS					AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESS FIL LOW CM	BLOWER FLOW CM	AIR PRESSURE INCH HG
7 AM	198	241	196	205	999	1051	1092	107.40	NA
8 AM	201	241	208	193	993	1034	1084	106.40	498
9 AM	196	243	204	208	1000	1021	1082	9389.80	NA
10 AM	190	242	200	207	1095	1059	1001	9389.80	62
11 AM	180	241	204	208	1000	1052	1089	9389.80	124
12 PM	190	241	194	208	200	999	1034	1087	19.5
1 PM	197	242	201	208	200	998	1023	1081	NA
2 PM	200	242	194	209	200	1001	580	9813.40	368
3 PM									436
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A. S. Pump Dot working

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

93-01-22-13
1-22-93

WATER TREATMENT

WATER TREATMENT OPERATING PARAMETERS

TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow cm	BLOWDOWN Flow cm	AIR PRESSURE INCHES HG	EFFLUENT Flow AFC	SUPERVISOR Signature
1 PM	200	240	194	208	200	994	1049	1095	1016.40	237 working	490
2 PM	200	240	200	208	200	1004	1032	1090	9813.40		63
3 PM	200	241	203	209	199	1003	1024	1081	9813.40		Se HADLER
4 PM	200	241	196	209	200	992	1059	1111	9813.40		CAVALLARO
5 PM	196	242	197	208	201	995	1047	1098	9389.80		/26
6 PM	200	240	200	208	199	1002	1032	1084	9813.40		/86
7 PM	199	244	197	209	200	1006	1023	1079	9813.40		245
8 PM	200	242	199	208	200	1004	1057	1097	9813.40		310
9 PM											374
10 PM											435
11 PM											
AFTER	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 A.S Pump Down
 BOTH A S Pumps SHUTTING OFF TOGETHER. SAME problem with A.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 NIGHT SHIFT

TIMEID	93-01-23-11
DATE	1-23-93

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FILTER FLOW GPM
1 PM	196	243	196	207	201	997	1048
2 AM	202	245	193	208	201	1000	1033
3 AM	196	246	196	208	201	1004	1033
4 AM	200	244	198	210	200	998	1017
5 AM	200	246	196	210	200	1003	1047
6 AM	200	246	200	207	198	1005	1040
7 AM	201	246	202	208	199	995	1026
8 AM	198	248	194	208	200	1005	1020
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

DAY SHIFT

FILED 9.3-01-233-12
DATE 1-23-93

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILED
DATE

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

THE ID:	93-01-24-11
DATE:	1-24-93

WELL SYSTEM OPERATION GALLONS PER MINUTE								AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER Flow gpm	PRESSURE FIL FLOW gpm	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
11 PM	200	250	148	207	200	1016	1027	1083	9813.40	NOT	496	SCHADER	
12 AM	196	256	142	200	188	914	0001	10166.40	10166.40	WORKING	58	FACIANS	
1 AM	202	248	146	206	202	1009	1039	1043	10166.40		101		
2 AM	201	253	147	210	200	1015	1029	1087	9813.40		164		
3 AM	202	258	146	213	206	1024	1025	1075	9813.40		224		
4 AM	196	257	203	214	205	1031	1022	1075	9813.40		293		
5 AM	200	257	203	212	206	1026	1024	1070	9813.40		360		
6 AM	197	256	201	215	199	1032	1023	1084	9813.40	Y	419		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA							

REMARKS

#1 A/S PUMP OUT FOR REPAIR

NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-01-24
TIME	1 - 24 - 93

WEIGHTED AVERAGE
 DURING 5 MINUTE

TIME	WEIGHT FLOW		WEIGHT FLOW		WEIGHT FLOW		SYSTEM FLOW		STRIPPER FLOW		PRESSURE FLOW		BLOWER AIR FLOW		AIR PRESSURE INCHES HG		EFFLUENT FLOW INCHES HG		SUPERVISOR INITIALS	
	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW	WEIGHT FLOW								
7 AM	200	260	198	210	199	1027	1023	1028	9813.40	9813.40	1003.40	1003.40	1003.40	1003.40	1003.40	1003.40	1003.40	1003.40	1003.40	48.2 N.J.
8 AM	197	260	199	216	200	1024	1023	1022	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	64 Cape 15
9 AM	200	260	196	216	200	1030	1024	1024	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	126
10 AM	199	258	197	216	199	1033	1024	1024	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	190
11 AM	196	260	201	215	200	1029	1025	1025	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	251
12 PM	201	259	199	215	200	1024	1025	1025	1004.90	1004.90	1004.90	1004.90	1004.90	1004.90	1004.90	1004.90	1004.90	1004.90	1004.90	314
1 PM	200	260	196	216	200	1032	1026	1026	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	377
2 PM	200	259	197	215	199	1030	1024	1024	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	1006.40	477
3 PM																				
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA								

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-01-24-13
	/ - 24 - 93

WEIR FLOW ESTIMATION
 GALLONS PER MINUTE

AIRSTRIPPER OPERATING PARAMETERS							
TIME	WEIR FLOW	WEIR FLOW	SYSTEM FLOW	STRIPPER FLOW	EFFLUENT FLOW	EFFLUENT PRESSURE INCHES HG	EFFLUENT FLOW RATE GALLONS
	(GPM)	(LPM)	(GPM)	(LPM)	(GPM)	(INCHES HG)	(GPM)
3 PM	183	259	194	216	200	1030	1025
4 PM	180	259	195	215	200	1035	1024
5 PM	195	260	199	215	200	1032	1026
6 PM	200	260	200	197	192	1038	1026
7 PM	200	259	201	212	198	1036	1055
8 PM	201	259	199	213	202	1034	1044
9 PM	199	260	194	215	201	1034	1037
10 PM	198	260	202	216	200	1023	1058
11 PM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

NIGHT SHIFT

FIELD ID	Q3-01-05-11
DATE	JAN 25, 1993

WEELITE II OPERATION

STATIONS PER MINUTE

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW cPM	PRESSURE PSI	AIR FLOW cm ³ /sec	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGD	EFFLUENT MEAS.	SUPERVISOR INITIALS
11 AM	200	257	196	216	200	10.33	1057	10.91	10166.40	NO	4.87	10410
12 AM	197	259	204	214	201	1035	1042	10.89	10166.40	1	6.3	Dawkins
1 AM	201	261	203	213	200	1034	1037	1082	10166.40		1.22	
2 AM	204	261	196	215	201	10.35	10.31	1822	10166.40		1.88	
3 AM	200	260	200	216	200	10.35	10.30	10.78	10166.40		2.53	
4 PM	198	263	192	216	203	1030	10.29	10.73	10166.40		310.	
5 PM	200	260	200	214	200	10.31	10.28	1029	10166.40		384	
6 PM	195	260	204	216	200	1038	10.27	10.69	10166.40		447	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-01-25
TIME	1-25-93

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	EFFLUENT FLOW GPM	AIR PRESSURE INCHES HG CM	AIR FLOW CFM	EFFECTIVE OPERATION TIME	EFFLUENT FLOW GALLS
7 AM	200	200	200	216	144	1040	1028	1065	1066.40		511
8 AM	200	260	202	216	196	1039	1027	1065	11296.00		63
9 AM	200	260	202	214	200	1040	1027	1065	10813.20		125
10 AM	203	196	206	220	196	975	1019	681	9389.80		184
11 AM	148	206	200	218	197	984	0023	0002	10166.40		248
12 PM	195	197	202	220	201	985	1034	1064	10166.40		308
1 PM	201	206	201	219	197	978	1017	1085	10590.00		370
2 PM	203	197	200	216	200	986	1047	1092	87172.00		424
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S PUMP OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

ENTERED	93-01-25 - 13
BY	1-25-93

TIME	WELL FIELD OPERATION			AIR STRIPPER OPERATING PARAMETERS		
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW CFM
3 PM	200	205	195	220	200	987
4 PM	196	201	200	218	200	984
5 PM	199	204	200	219	200	987
6 PM	200	201	202	218	201	990
7 PM	196	200	203	219	200	984
8 PM	200	201	194	220	199	979
9 PM	200	208	200	217	200	987
10 PM	196	212	197	220	200	990
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

#1 H.S. Pump Down
 BOTH H.S.Pumps shutting off together. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD DATE 93-01-26-11
J-26-93

AIR STRIPPER OPERATING PARAMETERS							
WELL 1 GALLONS PER MINUTE	WELL 2 GALLONS PER MINUTE	WELL 3 GALLONS PER MINUTE	WELL 4 GALLONS PER MINUTE	SYSTEM FLOW GPM	STRIPPER FLOW GPM	BLOWER PRESSURE PSI	EFFLUENT FLOW GPM
TIME	FLOW	FLOW	FLOW	FLOW	FLOW	FLOW	FLOW
11 PM	200	213	203	218	200	989	1017
12 AM	194	216	203	217	200	994	1010
1 AM	200	217	195	218	200	999	1022
2 AM	196	220	204	219	200	985	1015
3 AM	199	220	200	216	200	976	1023
4 AM	199	224	203	218	199	1003	1030
5 AM	200	223	196	216	200	1003	1072
6 AM	197	225	195	216	202	1005	1060
7 AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.**

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

THE 15
 9.3 - 01-26-12
 1-26-93

WELL SYSTEM OPERATION

TIME	WELL SYSTEM OPERATION						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGD	SUPERVISOR OPERATOR INITIALS	
7 AM	199	228	200	216	199	1009	1034	1087	10166.40	491	FALCIANO	
8 AM	200	232	203	216	200	1012	1018	1081	1013.40	0069	ABRAMS	
9 AM	201	232	201	217	200	1016	1015	1075	0389.82	129		
10 AM	196	232	198	215	200	1013	1057	1042	02472.00	178		
11 AM	196	232	196	214	201	1004	1034	1088	01389.80	246		
12 PM	198	234	193	216	201	1008	1023	1082	01813.40	307		
1 PM	200	235	204	212	201	1012	1015	1075	01813.40	376		
2 PM	199	232	204	213	199	1011	1056	1001	01813.40	428		
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

X1 A/S DUMP OUT COR REPAIRS

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FIELD DATE	93-01-26 - 13
	1-26-93

WELL SYSTEM OPERATION DATA

TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PUMP FL. GPM	BLOWER AIR FLOW CFM	EFFLUENT PRESSURE INCHES WG	SUPERVISOR INITIALS	AIR STRIPPER OPERATING PARAMETERS			
										WELL 1	WELL 2	WELL 3	WELL 4
3 PM	202	237	196	216	200	1011	1038	1091	LLOYD	10166	40	Not working	790
4 PM	201	236	201	216	198	1011	1027	1086	CAVALLARO	10166	40		62
5 PM	200	240	203	216	198	1015	1019	1078		9813.40			125
6 PM	196	240	204	216	200	1016	1016	1071		9813.40			191
7 PM	200	237	196	213	200	1009	1066	1107		9813.40			245
8 PM	202	239	197	216	198	1016	1045	1090		9813.40			307
9 PM	198	239	195	217	200	1012	1032	1087		10166.40			371
10 PM	199	241	197	217	200	1016	1026	1082		9813.40			435
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA					

REMARKS

#1 A.S Pump down
 Both A.S Pumps shutting off together, same problem with P.F. Pumps
 B.LL TLLMAY from CANTERA DESIGN WORKED on overhead HEATERS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	93-01-27-11
DATE	1-27-93

AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL FLOW	WELL FLOW	WELL FLOW	STRIPPER FLOW	STRIPPER FLOW	EFFLUENT FLOW	EFFLUENT FLOW	STRIPPER PRESSURE	STRIPPER PRESSURE
	gpm	gpm	gpm	gpm	gpm	gpm	gpm	PSI	PSI
1 PM	201	241	194	216	200	1015	1020	1075	10166.40
12 AM	201	242	195	217	200	1016	1017	1069	10166.40
1 AM	200	239	200	215	200	1016	582	673	9813.40
2 AM	200	240	202	216	200	1017	1048	1085	9813.40
3 AM	201	240	199	216	197	1013	1036	1087	9813.40
4 AM	200	240	196	217	200	1019	1025	1081	9813.40
5 AM	196	240	195	216	198	1015	1019	1075	9813.40
6 AM	200	240	196	218	200	1016	1017	1068	9813.40
7 AM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 A.S. PUMP OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE ID:	93-01-27-11
DATE:	1-27-93

TIME	WELL PUMP OPERATION GALLONS PER MINUTE			AIR STRIPPER OPERATING PARAMETERS							
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WET WELL LEVEL	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW CM ³ /SEC.	BLOWER AIR FLOW CM ³ /SEC.	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGD	SUPERVISOR OPERATOR INITIALS
7 AM	200	241	196	217	260	1014	565	675	9813.40	NOT	496
8 AM	201	240	199	216	198	1012	1047	1044	9813.40	Working	55
9 AM	196	240	200	216	200	1010	1033	1040	9389.80		ABRAMS
10 AM	196	240	198	217	200	1012	1024	1079	9389.80		
11 AM	198	240	199	217	198	1010	1018	1075	4813.40		
12 PM	197	200	202	220	200	977	579	670	10166.40		
1 PM	196	200	197	218	203	981	1040	1090	9813.40		
2 PM	196	199	202	220	200	983	1016	1078	10166.40		
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S PUMP OUT FOR REPAIRS
 2nd set well 2 11:AM
 set AH-2 AT 75° AND U.H. 1.213 AT 60°

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-01-27-13
DATE	1-27-93

TIME	WELL FLOW			WELL SYSTEM FLOW			STRIPPER FLOW			STRIPPER AIR FLOW			STRIPPER PRESSURE			AIR STRIPPER OPERATING PARAMETERS		
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	STRIPPER FLOW GPM	STRIPPER FLOW CFM	AIR FLOW CFM	STRIPPER PRESSURE INCHES WC	AIR FLOW CFM	STRIPPER PRESSURE INCHES WC	AIR FLOW CFM	STRIPPER PRESSURE INCHES WC	AIR FLOW CFM	STRIPPER PRESSURE INCHES WC	AIR FLOW CFM	
3 PM	196	204	198	219	198	985	1053	1087	10166.40	10590.00	1087	10590.00	1087	10590.00	1087	10590.00	1087	
4 PM	200	202	202	218	198	984	1025	1086	10166.40	10590.00	1086	10590.00	1086	10590.00	1086	10590.00	1086	
5 PM	195	208	195	217	200	982	1062	1097	10590.00	10590.00	1097	10590.00	1097	10590.00	1097	10590.00	1097	
6 PM	201	202	204	217	200	985	1032	1092	10590.00	10590.00	1092	10590.00	1092	10590.00	1092	10590.00	1092	
7 PM	200	204	196	220	200	982	1017	1084	10590.00	10590.00	1084	10590.00	1084	10590.00	1084	10590.00	1084	
8 PM	196	207	196	218	200	985	1049	1089	10590.00	10590.00	1089	10590.00	1089	10590.00	1089	10590.00	1089	
9 PM	199	203	204	217	198	989	1020	1085	10590.00	10590.00	1085	10590.00	1085	10590.00	1085	10590.00	1085	
10 PM	199	200	204	218	200	985	1057	1088	10590.00	10590.00	1088	10590.00	1088	10590.00	1088	10590.00	1088	
11 PM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 A.S Pump Down
 BOTH A.S Pumps shutting off together. Same problem with P.F.Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

TIME	93-01-28-11
DATE	-28-93

WELL SYSTEM OPERATION

AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM Flow	STRIPPER Flow	BLOWDOWN Flow
	gpm	gpm	gpm	gpm	gpm	gpm
11PM	200	200	203	217	200	987
12AM	201	204	219	200	987	562
1AM	199	204	218	200	983	1044
2AM	197	208	196	218	200	989
3AM	202	208	195	218	200	985
4AM	200	211	202	218	200	992
5AM	199	213	202	220	200	986
6AM	200	212	197	218	200	988
7AM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-01-28-11
TIME	1-24-93

WELL SYSTEM DATA							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW cm ³	PRESSURE FLOW cm ³ /sec	BLOWDOWN FLOW cm ³ /sec	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGD	SUPERVISOR OPERATOR INITIALS			
7 AM	260	215	196	219	200	099-	1027	1025	10590.00	480	Dean		
8 AM	200	244	192	215	200	965	1069	1065	9615.40	64	Mark.		
9 AM	202	216	202	217	200	983	1042	1052	10613.40	121			
10 AM	197	214	195	219	200	988	1022	1086	10166.40	188			
11 AM	198	212	197	219	200	990	986	685	10165.40	241			
12 PM	199	216	196	218	198	945	1037	1089	9389.80	310			
1 PM	195	219	202	217	200	993	1020	1019	9389.80	371			
2 PM	196	220	194	217	200	991	588	673	9813.40	427			
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

END TIME	93-01-28-13
BEGIN TIME	1-28-93

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE
	GPM	GPM	GPM	GPM	GPM	GPM	PSI
3 PM	20.2	224	198	218	200	1002	1040
4 PM	194	226	199	218	200	1008	1030
5 PM	20.2	227	197	219	200	1002	1016
6 PM	198	228	200	217	200	1003	1055
7 PM	20.0	232	203	216	199	1001	1035
8 PM	20.0	234	196	218	198	1004	1022
9 PM	20.0	236	198	218	200	1013	1016
10 PM	148	234	198	216	201	1001	587
11 PM							
12 AM							

REMARKS

#1 A.S. Pump Down
 BOTH A.S. PUMPS SHUTTING OFF TOGETHER. SAME PROBLEM WITH P.F. PUMPS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE#	93-01-28-11
DATE	7-29-93

WELL SYSTEMS OPERATION
GALLONS PER MINUTE

TIME	WELL SYSTEMS			AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM Flow	STRIPPER Flow GPM	BLOWER Air Flow CFM	AIR PRESSURE INCHES WC	EFFLUENT Flow GPM	SUPERVISOR OPERATION NOTES
11 PM	201	235	199	216	200	1011	1047	1089	9813.40
12 AM	196	237	196	218	200	1007	1028	1085	9107.40
1 AM	200	238	200	217	200	1007	1019	1075	9107.40
2 AM	200	236	200	216	199	1011	1015	1068	9389.80
3 AM	197	240	196	218	201	1010	1013	1068	9389.80
4 AM	201	237	197	215	200	1008	1019	1090	9389.80
5 AM	197	240	202	216	199	1017	1034	1085	9107.40
6 AM	200	239	194	217	200	1012	1027	1083	9107.40
7 AM									442
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-01-29-12
DATE	1-29-93

WELL SYSTEM OPERATION					AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW cpsi	PRESSURE FLOW psi	BLOWDOWN FLOW psi	AIR PRESSURE INCH WC	EFFLUENT FLOW MGD	SUPERVISORY OPERATOR INITIALS
7 AM	199	240	196	217	201	1014	1016	1074	9107.40	508	KL
8 AM	199	241	202	217	200	1016	1015	1068	9389.80	62	Cheet
9 AM	201	243	197	210	201	1012	1011	1062	9388.80	126	ABRams
10 AM	195	200	199	220	196	969	1054	1092	9813.40	176	
11 AM	199	211	196	220	200	991	1027	1090	9813.40	241	
12 PM	200	212	198	220	200	997	1014	1080	9813.40	304	
1 PM	199	216	200	218	200	986	1045	1090	9813.40	358	
2 PM	196	219	202	219	200	991	1023	1085	9389.80	425	
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

10:00 Reset well #2

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

EVENING SHIFT

93-01-29-13
1-29-93

REMARKS

REMARKS #1 A.S. Pump Down BOTH A.S. Pumps SHUTTING OFF TOGETHER Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE #	93-01-30
DATE	1-30-93

AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	BLOWER FLOW	AIR FLOW	EFFLUENT PRESSURE	EFFLUENT CONC.
	gpm	gpm	gpm	gpm	gpm	gpm	CFM	PSI	PPM
11 PM	201	238	198	216	199	1013	1017	9389.80	NA
12 AM	196	240	200	217	200	1007	1013	9813.40	Working
1 AM	196	236	196	215	200	1009	1057	9389.80	NA
2 AM	198	237	197	216	200	1014	1038	1089	9389.80
3 AM	196	239	203	217	199	1009	1026	1084	9813.40
4 AM	201	240	198	217	200	1004	1019	1077	9813.40
5 AM	197	240	195	217	199	1011	1014	1067	9813.40
6 AM	199	240	196	219	200	1012	1012	1062	9813.40
7 AM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 A/S PUMP OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-01-30-12
TIME	1 - 30 - 93

WELL 11 OPERATION						AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 11 FLOW	WELL 12 FLOW	WELL 13 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	EFFLUENT FLOW	AIR PRESSURE	EFFLUENT FLOW	AIR PRESSURE	SUPERVISOR INITIALS
	gpm	gpm	gpm	gpm	gpm	gpm	gpm	psi	gpm	psi	
7 AM	196	240	262	216	198	1006	1050	1090	8472.00	No Working	487 N : x
8 AM	201	240	196	217	200	1013	1034	1087	9107.40		64 Cap e 9
9 AM	202	243	196	218	200	1008	1024	1081	9389.80		129
10 AM	200	244	195	217	200	1010	1019	1074	10590.00		192
11 AM	196	244	202	217	201	1010	1016	1069	9813.40		255
12 PM	200	244	202	217	200	1010	1013	1065	9813.40		322
1PM	200	243	202	217	196	1017	1012	1092	10943.00		379
2PM	200	241	197	215	200	1011	1061	1080	10943.00		433
3PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE#	93-01-30-13
DATE	1-30-93

TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW CMH	BLOWDOWN AIR FLOW CMH	EFFLUENT FLOW CMH	PRESSURE INCHES WC	AIR FLOW CMH	SUPERVISOR INITIALS
3 PM	196	241	197	216	200	1007	1043	1090	9813.40	No. 1	N. x
4 PM	196	242	202	216	201	1010	1032	1086	1058.00	..	64
5 PM	196	243	195	217	200	1015	1022	1087	1059.00	..	Caser
6 PM	200	242	197	216	200	1019	1018	1073	10166.40	..	130
7 PM	201	241	198	217	200	1012	1016	1065	10166.40	..	257
8 PM	201	243	197	216	199	1013	1013	1064	10166.40	..	319
9 PM	200	241	200	216	200	1008	1011	1078	9813.40	..	381
10 PM	201	244	200	217	199	1014	563	1029	10166.40	..	444
	AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE#	92-01-31-13
DATE	1-31-92

AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWDOWN AIR FLOW	EFFLUENT PRESSURE	SUPERVISOR OPERATION NOTES
	GPM	GPM	GPM	GPM	GPM	GPM	GPM	PSI	MILES
11:30M	200	241	196	215	199	101A	104C	10540.00	NOT WORKING
12AM	200	242	196	216	200	1013	1032	10166.40	WORKING
1AM	196	241	203	216	199	101A	1024	10166.40	
2AM	196	241	203	216	200	1012	1018	10166.40	
3AM	197	242	202	216	200	1010	1015	10166.40	
4AM	201	243	199	216	200	1010	1013	667 10166.40	
5AM	200	244	195	217	200	1015	1008	1078 10166.40	
6AM	200	244	200	217	199	1018	1011	10590.00	
7AM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 A/S PUMP OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD ID	93-01-31-12
DATE	7-31-93

WELL SYSTEM OPERATION DATA							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESSURE Flow GPM	AIR Flow SCFM	EFFECTIVE FLOW INCHES MC M.GAL	SUPERVISOR INITIALS	
7 AM	200	244	201	216	200	1019	1010	1064	10590.00	507	Dir
8 AM	199	243	196	216	200	1020	1010	1078	10590.00	61	Cape 15
9 AM	196	243	204	218	200	1015	0562	1067	10590.00	124	..
10 AM	200	243	197	215	200	1017	1048	1092	10690.00	177	..
11 AM	199	242	195	216	200	1017	1032	1087	10943.00	239	..
12 PM	200	244	199	217	201	1021	1026	1083	10590.00	304	..
1 PM	198	244	195	217	202	1014	1019	1077	10590.00	371	..
2 PM	200	244	203	217	197	1017	1016	1070	10943.00	433	..
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

EVENING SHIFT

FIELD
DATE
1-31-93

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF EPPING
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	93-02-01-11
DATE	1-23-93

WELL SYSTEM OPERATION						AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FPM	BLOWER AIR FLOW	AIR PRESSURE PSI	EFFLUENT FLOW GPM	SUPERVISION OPERATOR NOTES
11 PM	197	247	201	218	200	1018	1012	1080	1053000	197	Lloyd
12 AM	197	245	203	217	200	1014	1011	1074	1094300	1	Dowless
1 AM	200	245	204	216	201	1020	1011	1067	1059000	125	
2 AM	198	244	197	217	200	1020	1012	1113	1016640	186	
3 AM	198	248	195	217	200	1019	1012	1123	1016640	245	
4 AM	199	245	203	217	202	1020	1011	1128	1016640	312	
5 AM	200	247	196	216	200	1016	1011	1105	1057000	374	
6 AM	200	247	196	216	200	1016	1010	1111	1057000	437	
7 AM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
8 AM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TDWNT-OP-3A
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
DAY SHIFT

FILE # 13-02-01 12
125.1.1993

WELL SYSTEM OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIpper FLOW	PRESSURE FROM CM	EFFLUENT FLOW CM/H	AIR PRESSURE INPSIG	NOTES	SUPERVISOR SIGNATURE		
7 AM	196	246	196	216	200	1020	1010	1114	10943.00	Not	497	FALCON	
8 AM	199	244	200	217	200	1011	1012	1120	12003.00	Working	61	ABRAMS	
9 AM	200	244	201	217	200	1020	1011	1105	10590.00				125
10 AM	148	245	200	216	200	1021	1012	1114	1054.00				181
11 AM	198	245	199	216	200	1018	1011	1122	9389.80				248
12 PM	200	245	197	216	201	1013	1010	687	10166.40				316
1 PM	200	244	200	216	200	1011	1011	1114	10043.00				372
2 PM	198	245	199	216	200	1019	1010	1117	9813.40	Y			438
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN C. OWNER, 3A
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-02-01 - 13
	2-1-93

WELL SYSTEM OPERATION

WELL SYSTEM OPERATION

AFTER STRIPPER OPERATING PARAMETERS

TIME	WELL SYSTEM OPERATION			WELL SYSTEM OPERATION			STRIPPER OPERATION			AFTER STRIPPER OPERATING PARAMETERS		
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	PRESSURE FLOW	BLOWER FLOW	AIR FLOW	EFFLUENT PRESSURE	AIR PRESSURE	EFFLUENT FLOW
	gpm	gpm	gpm	gpm	gpm	gpm	gpm	gpm	cfm	psi	psi	gpm
3:01	201	244	200	216	200	1016	1011	1122	10590.00	49.6	49.6	SCHADLER
4:21	201	245	193	217	202	1016	1012	1102	10166.40			CARVALLARO
5:01	197	244	197	217	200	1011	1011	1118	10590.00			
6:01	196	244	200	216	199	1014	1011	1108	10590.00			
7:21	200	244	202	216	199	1019	1010	1086	10590.00			
8:01	200	243	200	213	200	1008	1047	1109	10166.40			
9:21	198	248	199	215	200	1010	1034	1102	10590.00			
10:01	199	248	204	216	200	1020	1028	1094	10590.00			
AVERAGES	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 A.S. Pump Down
 BOTH A.S. Pumps shutting off together. Same problem with P.F. Pump/s

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

DOVER TAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	93-02-02 - 11
DATE	2-2-93

WELL INFLUENT CONCENTRATION GALLONS PER MINUTE							AFTER TREATMENT CONCENTRATION GALLONS PER MINUTE				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWDOWN FLOW	AIR PRESSURE	EFFLUENT FLOW	SUPERVISION OPERATOR
11 PM	196	195	232	200	815	562	677	10590.00	/	499	160YD
12 AM	202	193	232	200	823	1025	1117	10570.00	/	40	Deveeis
1 AM	201	194	232	200	817	563	1096	10582.00		85	
2 AM	195	202	229	200	807	0000	0000	1254000		127	
3 AM	199	198	232	203	808	1026	1110	10590.00		180	
4 AM	199	197	195	232	805	1033	1113	10590.00		220	
5 AM	196	208	231	197	797	1043	1111	10166.40	/	276	
6 AM	196	205	231	198	811	1039	1115	10166.40		320	
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#2 WELL SHUT DOWN 10:30 WOULD NOT START

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.


DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
DAY SHIFT

B/E/P DATE	2-3-02-12
	2-2-93

WELL SYSTEM MONITORING							A/S STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR NOTES		
7 AM	192	197	208	232	200	807	1045	1124	10666.40	14	368	FALCON	
8 AM	197	197	230	207	795	1053	1115	9813.40	10700.00	50	ABRAMS		
9 AM	200	196	213	197	1014	1058	685	9813.40		103			
10 AM	202		200	228	201	815	566	136	9813.40		164		
11 AM	200	192	232	198	806	560	1092	9107.40		217			
12 PM	198	191	232	198	817	1011	1105	10166.40		262			
1 PM	196	192	232	203	799	1013	1113	10943.00		313			
2 PM	201	205	232	194	808	564	1091	9389.80	V	367			
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

- * 1 A/S pump out for repairs
- * 2 Well off 0900 BRUNO from L, K. B. working on Well #2 - unable to start well due to faulty high pressure shut off

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TQ''N F'' OY^THE '3A'
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 EVENING SHIFT

FIELD	93-02-02-13
REC'D.	2-2-93

AVERAGE OPERATING DATA						
TIME		WELL OPERATION		SYSTEM		SUPERVISOR
		WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	OPERATOR
		GPM	GPM	GPM	GPM	
5 PM	201	OFF	196	232	200	815
6 PM	192		208	232	200	807
5 PM	201		194	232	200	802
6 PM	200		198	230	202	805
7 PM	196		202	230	200	802
8 PM	192		205	228	200	800
9 PM	202		197	231	200	803
10 PM	201		205	230	200	807
AVERAGE		NA	NA	NA	NA	NA

WELL OPERATION						
TIME		WELL 1 Flow		WELL 2 Flow		SUPERVISOR
		WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	OPERATOR
		GPM	GPM	GPM	GPM	
5 PM	201	196	232	200	815	SHADLER
6 PM	192	208	232	200	807	CARVALHO
7 PM	194	194	232	200	802	106
8 PM	201	198	230	202	805	146
9 PM	196	202	230	200	802	194
10 PM	202	205	228	200	800	241
AVERAGE		NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pumps Down
 BOTH A.S. Pumps Shutting off together. Same problem with P.F. pumps
 15:00. #2 Well off

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

WATER TREATMENT
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE#:	93-02-03-11
DATE:	2-3-93

WELL SYSTEM OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	BLOWER FLOW	AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW	SUPERVISOR OPERATION
11 PM	196	205	232	200	801	572	0000	9813.40	1	400	Lloyd
12 AM	198	196	232	200	799	565	1090	9813.40		50	Douwellis
1 AM	196	205	229	200	807	569	687	9389.80		102	
2 AM	200	201	232	198	808	563	1000	9389.80		151	
3 AM	198	199	231	201	804	1014	1109	9389.80		200	
4 AM	192	204	232	200	798	1016	1087	9389.80		245	
5 AM	195	207	232	200	803	1015	1112	9389.80		299	
6 AM	194	204	233	200	807	559	1108	9389.80	V	356	
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

93-2-3-12
2-3-93

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	BLOWER FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGDS	SUPERVISOR INITIALS
7 AM	199	OFF	206	232	200	808	1026	1111	9389.80	111	396 FALCIANO
8 AM	203	OFF	197	228	199	811	1031	1115	9813.40	111	56 ABRAMS
9 AM	202	OFF	205	230	198	801	1039	1112	9389.80	111	104
10 AM	200	OFF	202	216	201	972	1048	1111	9389.80	111	158
11 AM	201	OFF	192	332	200	805	580	684	4107.40	111	215
12 PM	197	OFF	207	228	201	804	576	685	4813.40	111	265
1 PM	196	OFF	194	232	197	815	574	6001	9813.40	111	317
2 PM	200	OFF	193	232	201	805	570	6001	9389.80	111	369
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

* 1 A/S PUMP OUT FOR REPAIRS.
 ELECTRICAL FROM DELTA ON SITE 0930
 AT WELL #2 WITH BRUNO

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TENNESSEE STATE BOARD
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

REPORT DATE	93-02-03
TIME	2-3-93

AFTER STRIPPER OPERATING PARAMETERS							
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow	BLOWDOWN Flow
HRS	GPM	GPM	GPM	GPM	GPM	GPM	GPM
3 PM	202	0FF	190	232	200	808	1057
4 PM	196		194	232	200	805	1052
5 PM	202		192	231	200	810	1012
6 PM	195		207	232	201	816	1017
7 PM	196		203	232	201	810	1022
8 PM	197		196	231	198	802	1026
9 PM	193		191	231	201	799	1039
10 PM	193		203	232	198	805	1038
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A S. Pump Down
Both A S Pumps Shutting off Together. Same Problem with P.F. Pumps
#2 will down

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

WATER DAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

DATE	93-02-04
TIME	2:40 AM

WELL SYSTEMS

GALLONS PER MINUTE

WELL STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW RATE	WELL 2 FLOW RATE	WELL 3 FLOW RATE	SYSTEM FLOW	STRIPPER FLOW RATE	BLOWER AIR FLOW RATE
11 PM	203	203	232	200	804	1028
12 AM	192	209	228	200	805	1054
1 AM	196	200	228	197	807	1037
2 AM	196	203	231	200	802	1050
3 AM	196	207	230	201	801	1056
4 AM	200	192	232	199	802	571
5 AM	196	205	228	200	810	583
6 AM	201	192	231	201	805	561
7 AM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

- # 1 A1 is pump out for repairs
- # 2 well down
- # 1 P/F pump not coming on - run idle on
- # 2 # 3 only as of 2:30 hrs.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TODAY'S DATE
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-2-4-12
TIME	2-4-93

TIME	WELL 1		WELL 2		WELL 3		SYSTEM FLOW		STRIPPER FLOW		PRESSURE FILTER FLOW		AIR STRIPPER OPERATING PARAMETERS		
	WELL 1 FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 3 FLOW	SCFM	SCFM	SCFM	SCFM	PSI	PSI	PSI	PSI	EFFLUENT FLOW RATE
7 AM	203	04	97	232	200	807	560	1103	1	9389.60	402	102	102	102	102
8 AM	194	0FF	196	232	200	796	563	1103	1	10540.00	54	104	104	104	104
9 AM	203	0FF	203	228	200	798	1038	1323	1	10166.40	100	100	100	100	100
10 AM	200	04	195	230	200	813	1065	671	1	10166.40	104	104	104	104	104
11 AM	195	04	200	228	101	847	1053	0002	1	10166.40	199.	199.	199.	199.	199.
12 PM	202	0FF	198	228	200	813	995	201	1	10943.00	251	251	251	251	251
1 PM	194	04	204	231	200	800	578	659	1	10943.00	293	293	293	293	293
2 PM	203	04	192	230	200	796	577	661	1	10943.00	349.	349.	349.	349.	349.
3 PM	NA	NA	1	NA	NA	NA	NA	NA	NA						
4 PM	NA	NA	1	NA	NA	NA	NA	NA	NA						

REMARKS

<p>NOTES</p> <p>1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.</p> <p>2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.</p>

TUES., NOV. 1, 1988

DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	9-3-02-04 -13
TIME	2-4-93

WELL FIELD OPERATION DATA SHEET							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW CMH	PRESSURE HEAD CM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW CMH	SUPERVISOR INITIALS		
3 PM	193	OFF	202	228	196	809	1052	1058	10590.00	working	397	SCHLICK	
4 PM	197		208	228	196	814	1027	1039	10590.00		47	CAVALLARO	
5 PM	197		196	231	197	799	1032	1050	10166.40			95	
6 PM	200		192	232	200	803	1008	1060	10166.40				
7 PM	201		197	232	200	805	1022	1045	9813.40			142	
8 PM	194		200	232	199	798	1011	1063	10166.40			194	
9 PM	200		192	231	200	797	1017	1064	10166.40			242	
10 PM	195		205	232	200	807	1025	1042	10166.40			290	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

- # 1 A.S. Pump Down
- # 2 WELL OFF
- Both A.S. pump's SHUTTING OFF TOGETHER. SAME PROBLEM WITH P.F.Pump
- # 1 P.F. Pump not coming on in AUTO OR HAND.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF YEGEY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED:	93-02-05-11
DATE:	7-23-5-1993

WELL SYSTEM OPERATION

GALLONS PER MINUTE

TIME	WELL SYSTEM OPERATION			STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR OPERATION DETAILS
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow						
11 PM	193	NA	228	200	808	1025	1063	9389.80	NOT WORKING
12 AM	202	weekly	206	288	200	815	1035	1048	9385.80
1 AM	202	192	232	199	798	539	1056	10166.40	1
2 AM	203	198	232	202	810	1059	678	9813.40	99
3 AM	200	203	232	201	804	527	1041	9813.40	14/5
4 AM	200	202	229	199	814	1043	1042	9813.40	198
5 AM	200	200	228	201	794	576	1652	9813.40	250
6 AM	196	207	232	197	806	5655	1047	9813.40	298
7 AM									352
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OTERBA
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-CB-05-12
BATCH	2-5-93

WELL INFORMATION

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	AIR STRIPPER OPERATING PARAMETERS		SUPERVISOR OPERATOR	
					STRIPPER FLOW GPM	PRESSURE INCHES WC		
7AM	194	WELL 6	202	229	201	796	577	Craig
8AM	200		191	230	200	808	574	
9AM	195		208	232	200	801	002	Mark
10AM	203		193	232	200	801	1009	Rick
11AM	197		203	218	197	786	1037	
12PM	202		205	221	200	799	1026	
1PM.	197		192	222	200	0790	1039	
2PM	198		201	220	200	795	1044	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#2 PUMPATION WELL IS OFF

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TODAY'S OPERATOR: JAI
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILED	93-C2-C5-19
	2 - 5' - 43

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATION INITIALS			
3 PM	200	OFF	203'	224	200	0800	1048	1111	10166.40	No 1/14.44	380	Schadler		
4 PM	196	OFF	201	214	201	0792	1056	1112	10166.40		50	Capeit		
5 PM	203	OFF	194	224	199	0793	1055	1106	10166.40		102	.		
6 PM	199	OFF	203	225	202	0799	1055	1111	10166.40		153	.		
7 PM	199	OFF	204	225	198	0794	1032	1112	10590.00		203	.		
8 PM	195	OFF	207	227	200	0749	1053	1099	10590.00		252	.		
9 PM	199	OFF	206	227	199	0788	1048	1082	10590.00		304	.		
10 PM	197	OFF	196	228	198	0806	1054	1106	10166.40		357	.		
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

#2 connection well is off

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF YONTER 1Y
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID	93-02-06-11
DATE	FE 13, 6/923

WELL SYSTEM FLOW RATE							EFFLUENT OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIpper Flow GPM	PRESSURE Flow GPM	BLOWER AIR FLOW CFM	ATM PRESSURE PSI	EFFLUENT FLOW GPM	SUPERVISOR OPERATOR NAME		
11 PM	194	no ^r working	196	229	201	800	3557	1127	1016640	1107	Rodgers		
12 AM	196	1	206	228	200	796	1014	1120	1016640	115	Dowellis		
1 AM	196	1	203	228	201	794	1014	1118	1016640	95			
2 AM	202	1	204	227	199	806	1030	1114	1039200	142			
3 AM	199	1	204	228	200	805	1015	1119	1039000	195			
4 AM	201	1	196	229	201	795	1033	1115	1037000	240			
5 AM	197	1	205	227	197	810	1019	1110	1016640	292			
6 AM	192	1	204	228	200	799	1039	1123	1016640	339			
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

THE D	93-02-06-12
DATE	2-C-69

WELL FIELD OPERATIONS

TIME	WELL FIELD OPERATIONS				AIR STRIPPER OPERATING PARAMETERS							
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow gpm	PRESS FIL Flow gpm	BLOWER Air Flow CFM	EFFLUENT Flow gpm	EFFLUENT Pressure PSI	MEAS Meters	SUPERVISOR OPERATION INITIALS
7 AM	196	011	205	228	400	0793	1050	0691	10166.40	385	NA	X
8 AM	196	051	204	228	200	0798	1052	1118	10166.40	53	C	P = 5
9 AM	197	011	197	227	200	0798	1052	1112	10166.40	105		
10 AM	201	011	196	226	199	0801	1050	1111	10166.40	156		
11 AM	198	011	205	228	200	0801	1044	1114	10590.00	209		
12 PM	202	011	192	228	200	0805	1053	1076	10166.40	263		
1 PM	196	011	203	227	198	0792	0999	1079	10166.40	306		
2 PM	201	011	196	229	200	0798	1009	1112	10390.00	351		
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FIELD ID	98-02-06-19
DATE	2 - 6 - 93

WELL BY WELL INFORMATION

TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	AIR STRIPPER OPERATING PARAMETERS						
						STRIPPER Flow SCFM	PRESSURE Flow SCFM	BLOWDOWN Air Flow SCFM				
3 PM	203	OFF	192	229	201	0798'	1025	1105	105%	Not in use	40G	Nix
4 PM	193	OFF	193	228	200	0791	1024	1122	105%	10590.00	1	39 CeeK
5 PM	200	OFF	203	229	200	0800'	1030	1125	10943.00		90	.
6 PM	202	OFF	192	229	201	0804	1030	1119	10590.00		145'	.
7 PM	201	OFF	204	229	201	0807	1040	1132	10590.00		192	.
8 PM	200	CFF	208	228	201	0800'	1055	1127	10590.00		23G	.
9 PM	194	OFF	204	227	198	0795	1056	1117	10590.00		290	.
10 PM	196	OFF	200	228	199	0793	1050	1125	1066.40		347	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
11 PM												

REMARKS

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

NOTES

TOWN OF YESTERDAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 NIGHT SHIFT

FILED:	93-2-7-11
DATE:	3-7-93

WATER TREATMENT

AIR STRIPPER OPERATING PARAMETERS

TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow	BLOWDOWN Air Flow	AIR PRESSURE	EFFLUENT FLOW	SUPERVISOR ON DUTY
11 PM	193	OFF	200	228	201	790	1041	0002	1016640	NOT
12 AM	202		197	228	198	807	1043	1119	1016640	Working
1 AM	196		207	228	200	795	1044	897	1016640	
2 AM	202		192	228	200	800	581	694	1016640	
3 AM	195		204	226	200	795	589	1118	1016640	
4 AM	197		204	228	200	797	585	685	1016640	
5 AM	204		192	228	200	797	581	0002	1016640	
6 AM	192	↓	205	228	200	798	577	674	1016640	Y
7 AM										
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

5-1 A/S PUMP OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE#	93-C2-07-72
DATE	2-7-93

WELL FIELD OPERATION

GALLONS PER MINUTE

TIME	WELL FLOW			WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FILTER FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	EFFLUENT PRESSURE INCHES HG	SUPERVISOR INITIALS
	WELL 1	WELL 2	WELL 3												
7AM	196	0155	204	228	202	0796	1032	1126	10166.40	0.0	396	N;K			
8AM	194	OFF	203	227	199	0805	1058	1088	10166.40	0.0	46	Cape/K			
9 AM	200	OFF	199	228	200	0800	1058	107	9813.40	0.0	99				
10 AM	203	OFF	191	228	200	0798	1032	1120	10166.40	0.0	146				
11 AM	199	OFF	206	228	200	0803	1032	1125	10166.40	0.0	195				
12 PM	202	OFF	192	228	200	0805	1038	1115	10166.40	0.0	251				
1 PM	198	OFF	204	228	200	0805	1054	1095	10590.00	0.0	303				
2 PM	198	OFF	204	228	197	0803	1046	1121	10166.40	0.0	349				
3 PM															
4 PM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF STEAM
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-02-07-13
TIME	d - 7 - 93

WELL FEED OPERATION

AIR STRIPPER OPERATING PARAMETERS

TIME	WELL FEED OPERATION			AIR STRIPPER OPERATING PARAMETERS		
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW GPM	STRIPPER FLOW GPM	PRESSURE FLOW GPM
3 PM	199	OFF	208	229	202	290C
4 PM	196	OFF	204	228	200	2802
5 PM	201	OFF	194	230	200	2801
6 PM	193	OFF	207	227	200	2805
7 PM	198	OFF	203	227	200	2797
8 PM	201	OFF	192	227	200	2807
9 PM	198	OFF	192	228	199	2801
10 PM	200	OFF	197	228	200	2795
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

**WINSTON-SALEM
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY**

**DAILY OPERATIONS WORKSHEET
NIGHT SHIFT**

FIELD DATE	93-02-08-11
SECURITY	EE23

AFTER TREATMENT							AFTER STRIPPING & FILTERING			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW GPM	SUPERVISOR OPERATOR HANDS
11 PM	201	No Flow	200	228	200	808	567	1064	10166.40	Lloyd
12 AM	196	201	203	229	812	569	1063	10166.40		
1 AM	200	192	229	200	806	567	1058	10166.40		
2 AM	198	196	228	201	804	1012	1085	10166.40		
3 AM	196	204	231	197	805	1016	1088	9813.40		
4 AM	201	202	228	200	806	1011	1081	9813.40		
5 AM	197	195	228	200	808	1049	675	10166.40		
6 AM	198	204	228	197	802	1010	1082	10166.40		
7 AM										
	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TUNISIA, STATE, BA.
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-02-08-12
TIME	2-8-93

WELL SYSTEM OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	BLOWER FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR OPERATOR INITIALS		
7 AM	143	203	228	199	807	1043	1080	10166.90		395	FALCON		
8 AM	145	204	228	198	791	1031	1082	10540.00		54	ABRAMS		
9 AM	198	228	198	802	1033	1085	10540.00		105				
10 AM	146	205	228	200	806	1039	691	10540.00		150			
11 AM	196	230	199	809	577	0001	10540.00		208				
12 PM	197	229	200	802	575	1061	10043.00			258			
1 PM	197	207	231	200	797	568	1083	4389.80		304			
2 PM	200	196	230	197	802	1012	1080	10590.00		353			
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

- #1 A/S DUMP OUT FOR REPAIRS
- #1 P/F Pump does not come on

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

WINSTON-SALEM
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-02-08-13
PUMP	2 -08 -93

WEATHER INFORMATION

AIR STRIPPER OPERATING PARAMETERS

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE PUMP INCHES HG	BLOWER FLOW SCFM	AB PRESSURE INCHES HG	EFFLUENT FLOW GALLONS/MIN	SUPERVISOR OPERATOR NAME
3 PM	200	OFF	194	229	200	804	1027	1087	10166.40	NOT WORKING	401	SCHADLER
4 PM	192		206	228	200	805	1031	1088	10590.00		47	CAVALLARO
5 PM	196		195	228	200	797	1040	1080	10590.00		96	
6 PM	195		204	227	201	804	1053	1088	10590.00		143	
7 PM	198		199	228	200	805	1030	1087	10166.40		196	
8 PM	200		200	227	198	806	1053	1086	10166.40		247	
9 PM	202		198	227	201	804	1031	1080	10590.00		299	
10 PM	200		194	228	199	799	1050	1086	10590.00		350	
11 PM												
AVERAGE	NA	NA	NA	NA	NA							

REMARKS

#1 A.S. Pump Down
#1 P.F. Pump Down. (Will not work in Auto or manual)
BOTH A.S. Pumps shutting off together. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF EPHESUS
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED:	93-02-09-11
DATE:	FEB 13, 1993

VEHICLES PER MINUTE

AIR STRIPPER OPERATING DATA						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	AIR FLOW CFM
11 PM	197	ND	203	228	197	796
12 AM	200	1	202	229	196	805
1 AM	200	1	203	232	196	803
2 AM	200	1	192	226	200	800
3 AM	206	1	206	228	199	807
4 AM	200	1	192	228	201	801
5 AM	201	1	191	228	200	800
6 AM	197	1	207	228	199	798
7 AM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF THE BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-02-09-12
TIME	9-9-93

TIME	WELL OPERATIONS				AIR STRIPPER OPERATING PARAMETERS			
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESS FIL FLOW	BLOWER AIR FLOW
7AM	200	147	228	200	800	1051	681	16166.40
8AM	145	206	227	198	806	1056	8002	10166.40
9AM	196	205	227	201	803	590	663	10166.40
10AM	201	193	228	200	794	586	586	981340
11AM	200	193	228	201	799	588	667	8472.00
12PM	196	202	229	200	801	576	923	10540.00
1PM	192	202	229	201	792	571	1063	9107.20
2PM	200	193	229	200	800	566	1083	10166.40
AVERAGE	NA	NA	NA	NA	NA	NA	NA	351

REMARKS

- ✗ 1 A/s pump out for repairs
- ✗ 1 P/F pump not working

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

**TOWN OF WATER, SAN
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY**

**DAILY OPERATIONS WORKSHEET
EVENING SHIFT**

FILE #	93-02-09-13
DATE	2-9-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS						
TIME		WELL 1 FLOW	WELL 2 FLOW	WELL 1 FLOW	WELL 2 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWER AIR FLOW	AIR PRESSURE	EFFLUENT FLOW	EFLUENT FLOW	SUPERVISOR/ OPERATOR INITIALS
AM	PM	GPM	GPM	GPM	GPM	GPM	GPM	GPM	CFM	INCHES WC	CFM	CFM	
	3 PM	201	OFF	194	228	200	809	1033	1088	9389.80	107 King	399	SCHADLER
	4 PM	201		196	230	199	810	1021	1082	9813.10		48	CAVALLARO
	5 PM	198		204	228	200	812	1033	1086	9813.10		94	
	6 PM	196		205	227	200	810	1045	1079	10166.40		141	
	7 PM	200		197	227	200	809	1049	1072	10166.40		192	
	8 PM	197		201	227	200	810	1055	1087	10166.40		243	
	9 PM	201		191	227	200	799	1032	1086	10590.00		296	
	10 PM	202		191	228	200	802	1053	1082	10166.40		347	
	11 PM												
	AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 A.S. Pump Down
#1 P.F. Pump Down
BOTH A.S. PUMPS SHUTTING OFF TOGETHER. SAME PROBLEM WITH P.F. PUMPS.

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

**DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY**

**DAILY OPERATIONS WORKSHEET
NIGHT SHIFT**

FILED	93-02-10-11
DATE	FEB 01 1993

AIR STRIPPING OPERATING DATA METERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	BLOWER AIR FLOW CFM
11 PM	202	not working	202	227	200	726	1058
12 AM	198	1	204	228	149	800	571
1 AM	200		192	230	200	801	566
2 AM	196		203	230	200	792	1015
3 AM	193		207	228	200	797	1013
4 AM	203		195	230	201	797	1014
5 AM	203		192	229	201	805	1012
6 AM	200		194	229	200	795	1021
7 AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-02-10-12
DATE	2-10-93

WELL OPERATIONS										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM FLOW	STRIPPER Flow gpm	PRESSURE Flow psi	BLOWER Flow cfm	AIR PRESSURE inches w.c.	EFFLUENT Flow gpm	NOTES	SUPERVISOR OPERATOR		INITIALS	
												WELLINGS PER MINUTE	NOTES	INITIALS	
7 AM	191	OFF	204	228	200	792	1040	1087	10166.45	NOT	390	Participate			
8 AM	202	OFF	194	226	201	800	1048	1075	10166.40	Working	49	Abrams			
9 AM	195	OFF	200	228	201	788	544	677	10540.00		99				
10 AM	196	OFF	193	228	200	802	590	665	10590.00		153				
11 AM	197	OFF	194	228	200	800	586	667	1066.40		204				
12 PM	196	OFF	206	229	200	805	580	600	10166.40		251				
1 PM	199	OFF	190	228	200	802	579	664	10166.40		305				
2 PM	193	OFF	200	229	199	793	569	1074	10166.40	✓	352				
3 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

- #1 A/C pump out for repairs
- #2 P/F pump not working

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

JOV. 10 CYL. T-AY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

END TIME	9:30	02-10	-13
BEGIN TIME	02-10	-93	

WATER TREATMENT OPERATION

AIR STRIPPER OPERATING PARAMETERS

TIME	GALLONS PER MINUTE				STRIPPER FLOW GPM	SYSTEM FLOW GPM	PRESSURE FLOW PSI	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW GAL/S	SUPERVISOR OPERATOR INITIALS
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW							
3 PM	195	0FF	197	228	201	791	1032	1074	9813.40	1007	403
4 PM	196	204	228	200	799	1015	1070	9813.40	1007	403	SCHADLER
5 PM	199	192	229	200	807	1025	1084	10166.40	10166.40	91	CAVALLARO
6 PM	202	194	228	200	809	1031	1082	10166.40	10166.40	91	
7 PM	204	193	228	200	807	1031	1087	9813.40	9813.40	190	
8 PM	196	206	225	200	810	1055	1088	10166.40	10166.40	235	
9 PM	202	192	227	198	802	1032	1076	10166.40	10166.40	288	
10 PM	200	192	228	200	801	1052	1082	10166.40	10166.40	236	
11 PM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 A.S. Pump out for Repair
#1 P.F. Pump not working
Both A.S. Pumps shutting off together. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

**DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY**

**DAILY OPERATIONS WORKSHEET
NIGHT SHIFT**

FILED	93-02-11-11
DATE	FEB 11, 1993

WELL INFORMATION

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOTTED FLOW GPM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	AIR PRESSURE INCHES HG	SUPERVISOR OPERATOR NOTES
11 PM	202	No working	192	228	200	803	576	670	1016.40	392	1101D	
12 AM	200	A	205	228	198	792	584	666	1016.40		51	
1 AM	202		196	228	200	811	578	669	1016.40		100	
2 AM	201		190	230	197	794	567	1079	1016.90		147	
3 AM	198		195	228	200	800	570	1067	9107.40		199	
4 AM	200		190	228	201	798	1024	1074	9813.40		245-	
5 AM	199	V	196	231	200	794	1019	1084	9381.80		191	
6 AM	200		196	228	200	797	1048	1082	9813.40		342	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OTERBA
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD ID:	93-02-11-12
DATE:	FEB 11 / 993

WELL LINE OPERATION

AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW
	gpm	gpm	gpm	gpm	gpm	gpm
7 AM	201	NA	197	235	199	1050
8 AM	196	A	204	246	177	1050
9 AM	197	A	203	202	197	1065
10 AM	196	A	193	226	200	190
11 AM	200		196	228	201	588
12 PM	196		204	228	199	796
1 PM	197		203	227	200	805
2 PM	196		197	225	200	791
3 PM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN CENTER 3A
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 EVENING SHIFT

FIELD ID	93-C2-1113
Date	Feb 2 - 1993

AIR STRIPPER OPERATING PARAMETERS

		WELL SYSTEM OPERATION						AIR STRIPPER OPERATING PARAMETERS					
		WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWER AIR FLOW	AIR PRESSURE	EFFLUENT FLOW	NOTES	REASONS
TIME	DATE	GPM	GPM	GPM	GPM	GPM	GPM	CFM	PSI	CFM	INCHES HG	REASONS	REASONS
3 PM	197	OFF	201	228	201	0793	0574	1064	9813.40	No air	0400	Stabilizer	
4 PM	194	OFF	205	230	199	0807	0569	1078	10166.40		47	Cycle	
5 PM	192	OFF	206	228	200	0800	1012	1081	10166.40		97		
6 PM	192	OFF	204	228	200	0798	1019	1087	10166.40		145		
7 PM	201	OFF	194	228	201	0799	1022	1087	10590.00		192		
8 PM	197	OFF	193	228	201	0798	1038	1080	10590.00		239		
9 PM	203	OFF	190	227	200	0796	1051	1080	10166.40		285		
10 PM	196	OFF	204	227	199	0810	1055	0682	10598.0		337		
AVERAGES		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

- # 2 WELL OFF FOR REPAIRS
- # 1 A/S PUMP OUT FOR REPAIRS
- # 1 P/F PUMP WILL NOT COME ON P/F PUMPS OUT OF SEQUENCE

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

FIELD ID	93-02-14-11
DATE	FEB 12, 1992

WELL INJECTION

TIME	WELL FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWER AIRFLOW	EFFLUENT FLOW	SUPPLY FLOW	NOTES	SUPERVISOR COMMENTS
11 PM	204	not working	194	228	200	797	583	668	9107 ¹	107 ²	394	Lloyd
12 AM	199	A	192	228	200	807	578	677	9813.40	107	48	Daniels
1 AM	194		201	229	200	800	570	1089	9813.40	107	102	
2 AM	198		204	228	199	802	581	1074	9389.00	107	1.51	
3 AM	200		206	227	200	803	1054	638	10166.40	104		
4 AM	193		208	229	199	800	569	1075	10166.40	1050		
5 AM	200	V	200	228	198	808	1016	1087	10166.40	1050	292	
6 AM	203		191	228	200	803	583	667	9107.40	319		
7 AM												
OVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF THE BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
DAY SHIFT

HEP	93 - 02 - 12 - 12
DATE	2 - 12 - 93

WELL TREATMENT

CUBIC FEET PER MINUTE

TIME	WELL 1		WELL 2		WELL 3		SYSTEM FLOW		STRIPPER FLOW		PRESSURE FLOW		EFFLUENT FLOW		AIR PRESSURE		EFFECTIVE FLOW		NOTES		
	WELL 1 FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 3 FLOW	SYSTEM FLOW	SYSTEM FLOW	STRIPPER FLOW	STRIPPER FLOW	PRESSURE FLOW	PRESSURE FLOW	EFLUENT FLOW	EFLUENT FLOW	AIR PRESSURE	AIR PRESSURE	EFFECTIVE FLOW	EFFECTIVE FLOW	NOTES	REMARKS	
7 AM	201	OFF	200	227	200	811	1015	1086	9107.40	Not in use	398	NA	NA	NA	NA	NA	NA	NA	NA	NA	
8 AM	202	OFF	198	227	199	804	1030	1084	10949.00		43	CADET									
9 AM	199	OFF	193	226	200	806	1035	1074	10590.00		9.5	ABRAMS									
10 AM	200	OFF	192	227	201	801	1044	1086	10590.00		14.0										
11 AM	200	OFF	204	224	194	807	1036	1061	10166.40		19.1										
12 PM	200	OFF	192	229	200	820	1036	1083	10166.40		25.3										
1 PM	195	OFF	206	226	200	801	1055	1085	10590.00		28.8										
2 PM	199	OFF	199	224	200	808	1057	1080	10590.00		34.2										
3 PM																					
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA								

REMARKS

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%. 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

NOTES

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-02-12-12
BAT	2-12-93

WELL HEAD FLOW						AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW Flow	WELL 2 FLOW Flow	WELL 3 FLOW Flow	WELL 4 FLOW Flow	SYSTEM FLOW	STRIPPER FLOW Flow	PRESSURE Flow PSI	BLOWER A/F A/F	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR NAME
3 PM	201	OFF	192	227	202	797	584	665	10166.40	NOT	394
4 PM	192		201	228	202	792	578	677	10943.00	WORKING	45
5 PM	202		204	225	197	803	518	668	10590.00		96
6 PM	195		206	224	198	798	568	1058	10590.00		1A8
7 PM	196		207	228	200	802	565	1064	10943.00		198
8 PM	200		198	228	197	805	561	1074	10590.00		245
9 PM	202		199	229	201	808	1010	1086	10943.00		295
10 PM	196	↓	203	223	200	795	1010	1081	10943.**	↓	348
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

- * 2 Well off
- * 1 A/S pump out for repairs
- * 1 P/F pump does not come on.

NOTES

- 1-The system flow, stripper flow and pressure filter flow must be equal within 5%.
- 2-Effluent flow measures the total flow through the facility. Operator shall reset the gauge to zero at the beginning of each shift.

TOWN OF JEWELL
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 NIGHT SHIFT

FILED DATE	93-02-13-13
	2-13-93

WELL SYSTEM LOG

TIME	WELL SYSTEM LOG			AIR STRIPPING OPERATING PARAMETERS		
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow
	SCFM	SCFM	SCFM	SCFM	SCFM	SCFM
11 PM	195	OFF	196	228	200	796
12 AM	200		197	229	199	806
1 AM	197	195	229	199	802	563
2 AM	199	203	226	198	802	1046
3 AM	201	194	228	200	799	560
4 AM	200	197	225	201	803	1048
5 AM	196	204	226	198	800	1048
6 AM	194	205	227	200	797	1049
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

- 2 Well OFF, #1 A/S Pump out for Repairs
- 1 P/F Pump Not Coming On.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

SHIFT	93-03-13 - 12
DATE	2-19-93

WELL OPERATIONS

AIR STRIPPER OPERATING PARAMETERS

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	AIR FLOW SCFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GALLONS MINUTES	SUPERVISORY OPERATOR INITIALS
7 AM	103 OFF	200	228	200	802	584	663	10166.40	NOT DOLY.	399	
8 AM	197 OFF	202	229	200	797	580	676	10166.40		49	NiX
9 AM	194 OFF	201	229	199	807	572	1075	10166.40		93	Caper
10 AM	198 OFF	195	229	201	803	562	1078	10166.40		145	
11 AM	202 OFF	195	228	200	804	1016	1080	10390.00		190	
12 PM	201 OFF	204	223	200	809	1012	1087	10166.40		244	
1 PM	198 OFF	194	228	198	798	1026	1088	10166.40		287	
2 PM	198 OFF	206	227	200	806	1025	1081	9107.40		343	
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

TIME	93-03-13 - 63
DATE	2 - 19 - 93

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	AIR STRIPPER OPERATING PARAMETERS		SUPERVISOR COMMENTS
					STRIPPER PRESSURE	AIR FLOW	
3 PM	194 OFF	207	228	200	807	1034	10/66.40 Not working, 388 N/A
4 PM	198 OFF	206	228	201	809	590	10/66.40 56 Cape 15
5 PM	199 OFF	196	229	199	800	1002	10/66.40 105
6 PM	195 OFF	204	229	199	802	1029	10/66.40 151
7 PM	201 OFF	199	229	198	799	1019	10/66.40 200
8 PM	199 OFF	195	231	200	805	1004	10/59.00 252
9 PM	198 OFF	200	228	200	803	1003	10/59.00 301
10 PM	199 OFF	205	228	200	808	1000	10/59.00 350
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD DATE	92-02-14-11
	Z-1A-Q2

WELL OPERATIONS

AIR STRIPPER OPERATING PARAMETERS

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR OPERATOR NAME
11 PM	196	OFF	202	227	200	798	574	668	10943.00	NOT WORKING	400
12 AM	196		207	230	198	801	563	1075	10943.00	NOT WORKING	48
1 AM	200		204	228	200	803	710	1071	10590.00		97
2 AM	200		194	228	197	798	1019	1087	10943.00		144
3 AM	199		198	227	200	814	1020	1088	10166.40		192
4 AM	200		204	227	199	802	1030	1082	10166.40		241
5 AM	195		203	228	197	808	1034	1088	10590.00		289
6 AM	196	Y	198	228	200	801	1042	1086	10943.00	Y	338
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

- #2 WELL OFF, #1 A/S Pump out for Repairs.
- #1 P/F Pump NOT Working.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	93-03-14-12
DATE	2-14-93

WATERFALL OPERATION						AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLAOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGD	SUPERVISOR INITIALS
7 AM	200	OFF	200	228	200	799	1045	1025	1066.40	0.071,	Nix
8 AM	195	OFF	200	228	200	795	1050	1025	10943.00		45
9 AM	201	OFF	204	226	199	793	1056	1023	10590.00		Craig
10 AM	200	OFF	195	228	198	810	1051	1070	10943.00		99
11 AM	201	OFF	201	225	200	804	585	676	10590.00		153
12 PM	198	OFF	195	228	200	812	575	665	10590.00		197
1 PM	198	OFF	204	225	200	810	593	1080	10590.00		251
2 PM	200	OFF	200	228	199	807	588	677	1066.40		304
3 PM											347
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-02-14-13
DATE	2-14-93

TIME	WELL FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW CM	BLOWER AIR FLOW CM	AIR STRIPPER OPERATING PARAMETERS	
									EFFLUENT FLOW INCHES/SEC	EFFLUENT FLOW GALLONS/SEC
1 PM	203 OFF	192	228	200	804	1045	668	10/66, 40	NOT WORKING	40/
1 PM	200 OFF	205	228	196	910	1050	1071	10/66, 40		47 Cap 15
1 PM	194 OFF	198	230	200	801	1045	1080	10/66, 40		96
6 PM	202 OFF	194	229	200	803	1008	1082	10/66, 40		148
7 PM	201 OFF	193	229	200	798	1008	1084	10/66, 40		198
8 PM	199 OFF	200	227	199	803	1031	1082	10/66, 40		240
9 PM	202 OFF	196	228	202	803	1041	1087	10/66, 40		287
10 PM	199 OFF	204	225	200	791	1055	1071	10/66, 40		335
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	93-02-15-11
DATE	2-15-93

WELL SYSTEM OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWERS IN USE	AIR PRESSURE INCHES HG	EFLUENT FLOW GPM	SUPERVISOR INITIALS	
11 PM	201	OFF	204	228	198	803	782	0001	10166.40	NOT	390 ROGERS
12 AM	200		191	227	200	803	591	677	1813.40	WORKING	46 FRANCIAO
1 AM	203		192	228	201	801	585	668	1813.40		100
2 AM	200		193	227	197	803	582	665	1813.40		150
3 AM	203		194	228	201	806	585	677	10166.40		201
4 AM	193		204	228	202	806	573	1065	10540.00		249
5 AM	193		204	229	197	803	567	1074	10540.00		298
6 AM	196		206	228	200	800	1015	1078	10540.00	✓	345
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

- #2 WELL OFF
- #1 A/S Pump out for repairs
- #1 P/F Pump not coming on.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	9:30 AM	9:30 - 02 - 15-12
DATE		2 - 15 - 93

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW CPM	BLOWER AIR FLOW CFM	AIR STRIPPER OPERATING PARAMETERS		
									AIR PRESSURE INCHES WC	EFFLUENT FLOW RATE GPM	SUPERVISOR INITIALS
7 AM	195	OFF	201	228	200	204	1024	1088	1066.40	NA	N.J.
8 AM	193	OFF	205	228	201	200	1029	1087	1066.40	1	52 Capes
9 AM	196	OFF	203	228	197	806	1043	1666	1066.40	1	97 Markt
10 AM	195	OFF	206	228	199	808	1034	1087	1059.00	1	148
11 AM	192	OFF	200	227	201	907	1027	1086	1059.00	1	197
12 PM	201	OFF	200	227	200	808	1038	1081	10943.00	1	245
1 PM	198	OFF	206	228	201	809	1038	1075	10943.00	1	296
2 PM	200	OFF	200	228	200	801	1055	1081	10943.00	1	345
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-02-15 - 13
TIME	2-15-93

WELL FIELD OPERATION CALL LOG							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 Flow	WELL 1 Flow	WELL 2 Flow	WELL 2 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE FT	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW	SUPERVISOR INITIALS
3 PM	202	OFF	192	230	196	806	1011	1068	10166.40	WORKING	Lloyd
4 PM	202		192	226	199	803	1055	1088	10166.40		Carvalho
5 PM	197		204	225	200	810	1045	1075	10166.40		
6 PM	201		196	225	200	804	1054	1082	10166.40		
7 PM	200		198	226	201	806	1044	1078	10596.00		
8 PM	196		206	228	200	807	1054	1084	10590.00		
9 PM	202		197	228	200	803	1047	1079	10590.00		
10 PM	200		193	227	200	802	1092	1079	10590.00		
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

- #1 WELL Down
- #1 A.S. Pump Down
- #1 P.F. Pump NOT working on Auto or manual
- Both A.S. pumps SHUTTING OFF together.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID	93-02-16-11
DATE	02-16-93

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	AIR STRIPPER OPERATING PARAMETERS		SUPERVISOR	OPERATOR	NOTES
							STRIPPER FLOW	PRESSURE	EFFLUENT PRESSURE	EFFLUENT PRESSURE	
11 PM	194	207	226	200	802	1057	676	10590.00	399	399	LLoyd
12 AM	201	192	227	201	801	1023	-	1086	1016	48	Downey/S
1 AM	200	199	227	200	805	1041	1050	10590.00	96		
2 AM	203	191	229	200	795	1029	1087	10390.00		143	
3 AM	203	206	229	200	807	371	665	10590.00		183	
4 AM	201	193	228	201	803	592	667	10590.00		245	
5 AM	196	201	226	200	805	595	676	10590.00		292	
6 AM	199	200	228	197	797	573	1065	10590.00		346	
AVERAGE	NA	NA	NA	NA							

REMARKS

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-02-16-12
Date	02-16-93

**WELL TO OPERATION
GAL PER MINUTE**

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	EFLUEVER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGD	SUPERVISOR OPERATION INITIALS
7 AM	196	198	228	198	794	586	665	10590.00	395	EDD
8 AM	195	205	228	200	800	581	600	8472.00	51	Falciano
9 AM	202	195	228	194	807	573	605	10166.40	101	ABRAMS
10 AM	200	194	227	201	811	573	607	7977.80	153	
11 AM	202	205	228	200	816	761	1080	9107.40	199	
12 PM	200	201	228	200	806	1010	1086	9389.80	247	
1 PM	194	205	228	200	802	1021	1087	9107.40	295	
2 PM	195	193	228	201	801	1030	1077	9107.40	344	
3 PM										
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

- * Well 2 off, +1 A/S pump out for repairs
- * 1 P/F Pump not coming on.

NOTES

- 1- THE SYSTEM FLOW STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-04-16 13
TIME	2-16 53

WELL OPERATION

TIME	WELL OPERATION				AIR STRIPPER OPERATING PARAMETERS							
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW SPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	EFFLUENT Gauge INCHES	SUPERVISOR INITIALS
3 PM	198	0FF	204	236	200	801	1046	1084	9389.80	NA	390	SC HADLER
4 PM	198		207	224	200	803	1054	1088	10166.40		48	CAVALLARO
5 PM	199		196	225	201	800	1055	1087	10166.40		100	
6 PM	202		190	228	199	798	1057	1084	10166.40		147	
7 PM	203		195	228	201	803	1043	1085	10166.40		202	
8 PM	202		193	228	200	801	1032	1080	10166.40		253	
9 PM	202		194	228	200	803	1020	1065	9813.40		303	
10 PM	200		195	228	200	800	1024	1072	10166.40		353	
11 PM												
12 AM	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#2 WELL Down
 #1 A.S Pump out for repair
 #1 P.F. Pump not working
 Both A.S. Pumps shuttling off together. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	93-02-17-11
DATE	2-17-1993

WELL SYSTEM OPERATION DATA							AIR STRIPPER OPERATING DATA - 10' TIER						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	EFFLUENT PRESSURE INCHES HG	EFFLUENT FLOW GPM	SUPERVISORY OPERATOR NOTES		
11 PM	196	197	194	227	199	803	1037	1085	981.3 40	401	11081		
12 AM	198	196	229	200	808	1016	1079	981.3 40	X	46	Down 15		
1 AM	196	206	228	198	808	1017	1083	981.3 40		97			
2 AM	199	193	226	201	797	1049	682	981.3 40		142			
3 AM	201	199	227	198	795	1051	708	981.3 40		192			
4 AM	203	196	228	200	810	571	1075	981.3 40		238			
5 AM	197	207	228	200	804	570	1078	981.3 40	X	288			
6 AM	200	192	225	200	808	570	665	10943 ⁰⁰		344			
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-02-17-12
DATE	2-17-93

WELL SYSTEM OPERATION
 GALLONS PER MINUTE

TIME	WELL #1 Flow	WELL #2 Flow	WELL #3 Flow	WELL #4 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESSURE Flow GPM	FLOWER Air Flow GPM	AIR PRESSURE INCHES HG	EFFLUENT Flow GPM	SUPERVISOR INITIALS
7 AM	201	OFF	196	227	200	808	591	677	10943.00	NOT	391
8 AM	202		192	227	200	801	594	600	9389.80	WORKING	51
9 AM	201		194	227	200	804	580	668	11649.00		ABRAMS
10 AM	200		204	227	200	805	572	1063	10540.00		
11 AM	203		192	228	200	806	568	1078	11649.00		153
12 PM	200		200	228	200	793	1010	1086	10166.40		
1 PM	198		193	228	198	806	1016	1077	10166.40		
2 PM	196	↓	206	228	199	807	1020	1086	10166.40	↓	
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#2 Well OFF, #1 A/s Pump out for Repairs
 #1 P/F Pump not coming on.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-02-17-13
DATE	2-17-93

WELL FIELD OPERATION
 DATA - YESTERDAY

TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	WELL 5 Flow	SYSTEM Flow
3 PM	201	OFF	200	227	196	804
4 PM	194		201	226	200	803
5 PM	201	194	227	200	803	1036
6 PM	201	192	227	198	298	1047
7 PM	201	194	225	200	802	1085
8 PM	203	192	225	200	800	1057
9 PM	198	202	228	198	808	1020
10 PM	200	198	227	200	805	1017
11 PM						
AVERAGE	NA	NA	NA	NA	NA	NA

AIR STRIPPER OPERATING PARAMETERS

TIME	BLOWER F/C GPM	PRESSURE INCHES HG	BLOWER AIR FLOW GPM	ATM PRESSURE INCHES HG	EFFLUENT FLOW GALLS/MIN	NOTES	SUPERVISOR OPERATOR INITIALS
3 PM	1045	1087	10590.00	392	Working	392	SC HADLER
4 PM	1081	1066.40	10590.00	46		46	C AVALLARO
5 PM	1085	10590.00	10590.00	90		90	
6 PM	1067	10590.00	10590.00	143		143	
7 PM	1070	10590.00	10590.00	93		93	
8 PM	1087	1066.40	10590.00	240		240	
9 PM	1065	1066.40	10590.00	292		292	
10 PM	1063	1066.40	10590.00	340		340	
11 PM							
AVERAGE	NA	NA	NA	NA	NA	NA	

REMARKS

#2 WELL Down
 #1 AS pump out for repair
 #1 P.F. Pump not working
 BOTH AS pumps shutting off together. Same problem with P.F. Pumps

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID:	93-02-18-11
DATE:	02-18-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. Flow GPM	BLOWER Flow CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW WEAUS	SUPERVISOR OPERATOR INITIALS
11 PM	200	205	228	200	748	588	678	10166.10		390	LLYD
12 AM	203	192	229	200	810	1008	1086	10166.40		35	DOUNELIS
1 AM	200	192	228	199	794	571	1068	10166.90		95	
2 AM	194	206	229	199	805	1033	1081	10166.90		130	
3 AM	201	193	226	201	804	878	676	10166.90		189	
4 AM	196	194	225	200	806	1056	0000.2	10166.40		227	
5 AM	200	199	221	200	798	1030	1082	10166.40		277	
6 AM	198	194	225	201	807	1060	672	10166.40		329	
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	93-02-18-12
DATE	22-18-93

WELL 1 OPERATION
 GALLONS PER MINUTE

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPER FLOW GPM	PRESSURE FALL CM	AIR FLOW CM	EFFLUENT FLOW INCHES MC MEALS	SUPERVISORY OPERATOR INITIALS
7 AM	197		196	226	200	798	587	667	10116.40	381	Dean. <i>Morris</i>
8 AM	195		196	228	200	807	578	669	10166.40	30	
9 AM	192		197	227	193	809	576	160	10166.40	99	
10 AM	197		205	228	201	807	576	851	10166.40	150	
11 AM	200		192	228	194	807	570	1076	10590.00	198	
12 PM	202		196	228	200	809	571	1061	10590.00	256	
1 PM	202		192	229	200	806	568	1081	10166.40	303	
2 PM	202		204	224	200	192	1459	678	10590.00	257	
3 PM											
AVERAGE	NA	NA	NA	NA							

REMARKS

- # 2 well out for repairs
- # P/S 1 not working
- §/F 1 out for repairs

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILED	93-02-18-13
B/E	2-18-93

AEROSTRIPPER OPERATING PARAMETERS						
TIME	WELL FLOW LPM	WELL FLOW LPM	WELL FLOW LPM	SYSTEM FLOW LPM	STRIPPER FLOW GPM	PRESSURE FILTER FLOW GPM
3 PM	199	OFF	203	217	200	794
4 PM	197		203	218	200	794
5 PM	200		202	221	198	800
6 PM	196		205	224	200	805
7 PM	198		197	224	198	797
8 PM	200		205	224	200	811
9 PM	196		203	225	200	808
10 PM	199		192	227	199	797
11 PM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

#2 Well Down
 #1 A.S. Pump out for Repair
 #1 P.F. Pump not working
 BOTH A.S. PUMPS SHUTTING OFF TOGETHER. SAME PROBLEM WITH P.F. PUMPS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	43-02-19-11
DATE	FEB 1993

WELL FIELD OPERATION				AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL FLOW	WELL 1 FLOW	WELL 2 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWER AIR FLOW
	GALLONS PER MINUTE	GALLONS PER MINUTE	GALLONS PER MINUTE	GALLONS PER MINUTE	GALLONS PER MINUTE	GALLONS PER MINUTE	CFM
11 PM	203	195	224	300	808	1054	681
12 AM	196	200	228	202	801	1022	680
1 AM	198	196	237	200	800	580	667
2 AM	203	200	226	201	812	539	667
3 AM	200	196	224	201	805	1055	680
4 AM	202	192	237	200	802	581	667
5 AM	200	193	225	202	792	569	672
6 AM	203	199	223	193	811	567	682
7 AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE ID	93-02-19-12
DATE	2-19-93

WELL FIELD OPERATION GAL/SEC/MINUTE							AFFF STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW CM	EFFLUENT FLOW CM	AIR PRESSURE INCHES HG	SUPERVISOR INITIALS	
7 AM	201	OFF	204	227	200	809	566	1085	1066.40	501	
8 AM	200	0	201	225	200	814	1008	1080	9107.40	54	
9 AM	197	0	207	228	200	824	1019	1088	10943.00	97	
10 AM	201	168	228	201	815	1025	1088	11216.00	147		
11 AM	196	204	225	200	805	1036	1020	10166.40	195		
12 PM	200	205	225	200	803	1046	684	16943.00	243		
1PM	204	192	225	200	807	1054	1027	9813.00	294		
2 PM	200	197	228	200	795	596	660	9513.40	348		
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

7:55 PM	93 - C6 - 19 - 13
8:00 PM	2 - 19 - 93

TIME	WELL SYSTEM OPERATION			AIR STRIPPER OPERATING PARAMETERS						
	WELL FLOW	WELL 1 PUMP	WELL 2 PUMP	WELL SYSTEM FLOW	STRIPPER FLOW	SUGGS FIL. FLUM	AIR ACTUATION	AIR PRESSURE INCHES WC	EFFLUENT FLOW INALIS	SUPERVISOR OPERATOR INITIALS
	gpm	gpm	gpm	gpm	gpm	gpm	cm	gpm	gpm	
3:01 PM	201	0.1%	191	228	200	807	10417	678	10919..	Nothing
4:01 PM	195	OFF	203	227	201	794	582	668	10943cc	54
5:01 PM	199	OFF	199	228	200	798	577	673	1059cc	104
6:01 PM	197	OFF	194	228	200	806	572	10641	10943cc	154
7:01 PM	196	OFF	206	226	199	807	1040	1086	10943cc	199
8:01 PM	197	OFF	197	227	200	810	1014	1088	1066.40	246
9:01 PM	194	OFF	201	227	200	807	1024	1082	9107.00	295
10:01 PM	200	OFF	198	228	200	806	1035	1087	9107.00	340
11:PM										
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

- # 2 well off for repairs
- # 1 1/2 pump out for repairs
- # 1 P/F pump not coming on , running only on 2 pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID	9.3-42-20
DATE	2-20-93

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL FLOW	WELL FLOW	WELL SYSTEM FLOW	STRIPPER FLOW	BLOWER AIR FLOW	EFFLUENT FLOW	SUPERIOR OPERATOR NOTES
	GPM	GPM	GPM	GPM	CFM	GPM	
11 PM	196	0 P/F	201	228	200	809	1034
12 AM	197		200	218	201	810	1034
1 AM	202		193	226	201	807	1036
2 AM	197		205	224	198	813	591 *
3 AM	196		200	225	200	800	585 *
4 AM	197		196	228	200	801	5831 *
5 AM	201		204	227	200	808	576 *
6 AM	196		197	228	201	798	573 *
7 AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

- * 2 WELL OFF FOR REPAIRS
- # 1 A/S PUMP OUT FOR REPAIRS
- # 1 P/F PUMP NOT COMING ON, RUNNING ON ONLY 2 PUMPS.
- * - ONE PUMP ON ONLY - SYSTEM RECYCLING.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD DATE	93-02-20-12
	2-20-93

TIME	WELL SITE OPERATION			AIR STRIPPER OPERATING PARAMETERS			
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	AIR FLOW CM	EFFLUENT FLOW INCHES WG MEAS.
7 AM	196 OFF	194	230	200	80.9	564	1077 ^{Wet 11.5} 401 Nix
8 AM	196 OFF	191	228	197	80.4	1013	10166.4c 45 Capex
9 AM	198 OFF	206	228	200	810	1018	10166.4c 91
10 AM	200 OFF	203	228	200	814	1026	10590.00 1644
11 AM	204 OFF	201	230	197	817	1003	1086 10166.4c 194
12 PM	198 OFF	196	228	201	812	1024	1081 10166.4c 240
1 PM	195 OFF	207	229	200	809	1011	1085 - 10590.00 296
2 PM	194 OFF	203	227	199	807	1019	1079 9813.40 343
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-02-20-13
DATE	2-20-93

TIME	WELL FIELD OPERATION			AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW CFM	BLOWER PRESSURE INCHES WC	EFFLUENT FLOW INCHES WC	SUPERSTRIPER OPERATOR INITIALS
3 PM	198	045	203	328	201	812	1038	1085	1016.40 working
4 PM	200	055	206	328	200	813	1034	1085	10590.00
5 PM	198	065	197	225	199	798	1049	1090	10166.40 Capacit
6 PM	201	075	202	227	200	812	1049	1079	10590.00
7 PM	196	075	205	227	199	805	577	666	10590.00
8 PM	195	075	198	229	200	810	579	1070	10590.00
9 PM	202	075	194	228	199	803	1012	1078	10590.00
10 PM	195	075	207	228	201	815	1009	1085	10590.00
11 PM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID:	93-02-21-11
DATE:	2-21-93

WELL PUMPATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWERS AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW GPM	NOTES	SUPERVISOR NAME	OPERATOR NAME	
11 PM	195	OFF	196	235	146	795	1010	1087	10540	88	NOT	395	RODGERS		
12 AM	198		204	227	200	811	1027	1081	10166	40	WORKING	48	FALCIANO		
1 AM	198		193	228	201	811	1032	1085	9813	40		96			
2 AM	196		206	228	200	807	1041	1085	9813	40		144			
3 AM	197		204	226	200	810	1047	1067	9813	40		194			
4 AM	202		198	226	200	791	594	675	1066	40		244			
5 AM	200		196	225	200	808	589	664	9813	40		248			
6 AM	198	✓	204	228	200	802	585	666	9813	40	✓	340			
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA							

REMARKS

- *2 Well off, #1 Al's Pump out for repairs
- *1 P/F Pump not coming on.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	93-03-31-12
TYPE	2-21-93

AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	S T R I P P E R F L O W	E F F L U E N T A P P E A R A N C H O R
	GPM	GPM	GPM	GPM	CM	INCHES/M
7 AM	196	OFF	199	228	200	803
8 AM	199	OFF	196	227	200	804
9 AM	198	OFF	206	228	200	813
10 AM	195	OFF	201	229	199	804
11 AM	200	OFF	193	227	201	804
12 PM	198	OFF	202	228	200	810
1 PM	200	OFF	193	228	200	815
2 PM	197	OFF	193	228	200	805
3 PM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-02-761-1
DATE	2-21-93

AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW gpm
3 PM	195	OFF	203	225	200	813
4 PM	196	OFF	208	227	197	803
5 PM	199	OFF	192	225	201	806
6 PM	196	OFF	196	227	200	811
7 PM	199	OFF	194	228	202	802
8 PM	200	OFF	199	228	199	802
9 PM	194	OFF	201	228	200	810
10 PM	OFF	OFF	OFF	OFF	OFF	017
AVERAGE	NA	NA	NA	NA	NA	NA
11 PM						

REMARKS

Z1 30% PRODUCTION WELLS SHUT DOWN.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID:	93-02-22-11
DATE:	2-22-93

WELL SYSTEM OPERATION GATE OPENING MINUTE								AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW GPM	BLOWOFF AIR FLOW GPM	AIR PRESSURE INCHES WC	EFFECTIVE FLOW GPM	SUPERVISORY OPERATOR NAME		
11 PM											LLOYD		
12 AM											CARULLARO		
1 AM													
2 AM	196	OFF	204	212	192	770	0000	0000	10166.40	NOT WORKING	0		
3 AM	197		199	211	201	778	1058	1092	9813.40		30		
4 AM	194		203	212	199	780	1054	1080	10166.40		79		
5 AM	202		204	212	200	789	572	665	10166.40		129		
6 AM	202		193	216	200	784	562	1073	10166.40		180		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

#3:00 - PLANT Down. LOST WELLS.
 0200 PLANT ON LINE
 #2 Well Down
 #1 AS pump out for repair
 #1 P.F. Pump not working

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD DATE	93-02-22-12
DATE	2-22-93

WELL FIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	EFFLUENT PRESSURE PSI	AIR FLOW CFM	EFFECTIVE FLOW GAL/SEC	SUPERVISOR NOTES
7 AM	176		202	216	200	767	565	1062	10166.40		227	Mark H.A. DTHW.
8 AM	154		204	216	200	790	568	1058	10166.40		51	
9 AM	203		204	218	200	800	1014	1083	10166.40		819	
10 AM	197		204	220	200	797	1013	1076	10166.40		175	
11 AM	176		221	221	204	792	1022	1086	10166.40		190	
12 PM	202		200	220	200	800	1031	1086	10166.40		237	
1 PM	201		199	220	200	803	1036	1073	10159.40		289	
2 PM	201		201	220	201	803	1053	677	10180.00		330	
AVERAGE	NA	NA	NA	NA	NA							

REMARKS

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

SHIFT ID	93-022-22-13
DATE	2-22-93

TIME	WELL FIELD OPERATION					AIR STRIPPER OPERATING PARAMETERS					NOTES
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FT. OF C.M.	BLOWDOWN FLOW GPM	AIR PRESSURE INCHES WC	
3 PM	200	0 FF	200	221	200	798	1048	1074	98/3.40	working	384 Schadler
4 PM	196		207	221	201	804	1052	1075	98/3.40		53 Cavallaro
5 PM	196		201	223	198	800	1030	1061	98/3.40		101
6 PM	202		195	225	200	800	1042	1070	98/3.40		154
7 PM	196		200	224	200	798	1027	1068	98/3.40		203
8 PM	199		196	227	200	796	1039	1080	9389.80		254
9 PM	199		191	229	200	795	1017	1079	9389.80		302
10 PM	196		193	229	201	805	1060	1082	9389.80		351
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#2 WELL Down
 #1 A.S. Pump cut for repair
 #1 P.F. pump not working
 BOTH A.S. pumps shutting off together. Same problem with P.F. pump.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID	93-O2-23-11
DATE	FE/13/23/1923

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW gpm	BLOWDOWN FLOW gpm	AIR PRESSURE INCHES WS INHG	EFFLUENT FLOW gpm	AIR FLOW cfm	NOTES
11 PM	197 working	205	226	200	796	1080	1016.40	NOT working	400	1100	
12 AM	200	196	228	200	803	1044	1016.10	1	45-	1200	
1 AM	300	198	226	200	800	1036	1016.12		93		
2 AM	200	205	227	200	805	1057	1016.40		144		
3 AM	196	195	227	200	803	1052	1016.40		192		
4 AM	197	200	228	200	800	1009	1082	9389.80		245	
5 AM	201	202	224	199	802	585	665	9389.80	✓	244	
6 AM	198	206	227	200	801	580	677	9472.02		343	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE ID:	9.3 - 02-03-12
DATE:	2-23-93

WELL SYSTEM OPERATION
 COLUMNS 3 & 4 ONLY

AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	AIR FLOW	AIR FLOW	EFFLUENT FLOW
	GPM	GPM	GPM	GPM	GPM	PSI	SCFM	SCFM	SCFM
7AM	193		203	227	200	809	581	664	3412.50
8AM	200		204	227	200	808	572	667	3384.50
9AM	200		196	227	200	806	513	802	3107.40
10AM	202		193	227	198	803	572	672	3389.80
11AM	202		197	229	200	805	561	1071	3107.40
12PM	OFF		OFF	OFF	OFF	000	000	000	000
1PM	OFF		OFF	OFF	OFF	000	000	000	000
2PM	OFF		OFF	OFF	OFF	000	000	000	000
3PM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

- #2 Well OFF, #1 Air Pump Out per request
- #1 P/F Pump not running on site.
- 1045 has Fred from P.C.I. on site. Support for wells CFE to make repairs

NOTES

- 1-The system flow, stripper flow and pressure filter flow must be equal within 5%.
- 2-Effluent flow measures the total flow through the facility. Operator shall reset the gauge to zero at the beginning of each shift.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-02-23-13
TIME	2-23-93

WELL 1 & 2 OPERATIONS							ABE STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 1 FLOW	WELL 2 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	STRIPPER PRESSURE PSI	EFFLUENT FLOW GPM	EFFLUENT PRESSURE PSI	EFFLUENT FLOW GPM	STRIPPER PRESSURE PSI	SUPERVISOR NAME	OPERATOR NAME
3 PM													SCHADLER
4 PM													C AVALLARO
5 PM													
6 PM													
7 PM	200	0FF	200	207	201	787	1050	1083	9389.80	NOT WORKING	9		
8 PM	196		204	208	200	785	1032	1078	9813.40		57		
9 PM	195		205	212	200	788	1054	1080	9813.40		111		
10 PM	196		200	214	200	785	1037	1079	9813.40		161		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

1500 PLANT DOWN. P.C.I. PERSONNEL WORKING ON PANEL & WELLS
 LKB

1830 PLANT ON LINE.
 #2 WELL OFF

#1 A.S. PUMP OUT FOR REPAIR
 #1 P.F. PUMP NOT WORKING

BOTH A.S. PUMPS SHUTTING OFF TOGETHER SAME PROBLEM WITH P.F. PUMPS
 P.C.I. & L.K.B. OFF SITE AT 19.00

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

NIGHT SHIFT

FILE ID: 93-02-24-11
DATE: 2/24/93

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-C2-2A-12
DATE	2-24-93

TIME	WELL FIELD OPERATION			AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR INITIALS
7 AM	200	OFF	205	222	200	806	1054	9613 .40	NOT	386 FALCONI
8 AM	OFF	OFF	OFF	OFF	0029	567	6001	1066 .40	Working	53 ABRAMS
9 AM	OFF	OFF	OFF	OFF	000	000	000	—	—	—
10 AM	OFF	OFF	OFF	OFF	000	000	664	—	—	82
11 AM	OFF	OFF	OFF	OFF	000	000	000	—	—	EE
12 PM	OFF	OFF	OFF	OFF	000	000	0001	—	—	88
1 PM	OFF	OFF	OFF	OFF	000	000	000	—	—	EE
2 PM	OFF	OFF	OFF	OFF	000	000	000	—	—	NO
3 PM	OFF	OFF	OFF	OFF	000	000	000	—	—	—
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

- *2 Well OFF, #1 A/S Pump out for repairs
- *1 P/F Pump not running
- 0745 hrs. Fired from PC-I on site. 0750hrs PC-I shut off wells 1330hrs. Well 1-5 on 1400 hrs Wells OFF.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE ID:	93-02-24-13
DATE:	2-24-93

TIME	WELL FIELD OPERATION				AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW (GPM)	PRESSURE FL. FLOW (GPM)	BLOWER AIR FLOW (CFM)	AIR PRESSURE INCHES WC	EFFLUENT FLOW METALS	SUPERVISOR OPERATOR INITIALS
3PM	200	240	196	205	200	990	1018	1079	9813.40	NOT WORKING	1535 SCHADLER
4PM	200	247	202	208	200	1004	1013	1012	10166.40	NOT WORKING	62 CAVALLARO
5PM	199	250	204	212	200	1012	1010	1064	10166.40		125
6PM	201	251	202	213	201	1014	1013	1061	10166.40		187
7PM	197	253	200	214	200	1012	1014	1057	9813.40		248
8PM	200	252	199	216	200	1014	1017	1056	10166.40		313
9PM	197	251	202	216	200	1015	1014	1083	10166.40		370
10PM	200	251	202	216	200	1018	1019	1075	10166.40		435
11PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. pump out for repair.
 #1 P.F. pump not working.
 BOTH A.S. pumps shutting off together. Same problem with P.F. pumps.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID:	13-02-35-11
DATE:	02-25-93

WELL PUMPING INFORMATION GALLONS PER MINUTE								AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AMPS CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR NOTES
11 PM	200	252	202	202	1020	1018'	1063	10166 40	10166 40	500	LLCYD
12 AM	196	253	198	214	200	1013	1014"	10166 40	10166 40	57	Down 15
1 AM	200	251	202	214	200	1017	1019	10166 40	10166 40	57	
2 AM	200	252	200	216	200	1016	1020	10166 40	10166 40	180	
3 AM	201	252	199	214	200	1018	1020	10166 40	10166 40	240	
4 AM	200	262	201	216	200	1021	1020	10166 40	10166 40	25	
5 AM	200	252	197	216	200	1015	1019	10166 40	10166 40	353	
6 AM	200	252	202	214	200	1022	1020	10166 40	10166 40	32	
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE ID	93-022-1512
DATE	02-26-93

WELL FIELD OPERATIONS				AIR STRIPPER OPERATING PARAMETERS			
WELL ID		WELL FLOW RATE GALLONS PER MINUTE		WELL 1 FLOW		WELL 2 FLOW	
TIME	WELL FLOW	WELL 1 FLOW	WELL 2 FLOW	SYSTEM FLOW	STRIPPER FLOW	EFFLUENT FLOW	AIR PRESSURE INCHES HG
7 AM	139	202	216	200	1020	1018	10166.40
8 AM	188	203	216	200	1021	1060	10166.40
9 AM	220	208	216	200	1005	1019	10166.40
10 AM	176	212	202	205	1025	1023	10166.40
11 AM	164	217	141	196	1000	1050	10166.40
12 PM	203	255	198	216	200	1015	1070
1 PM	200	255	197	216	200	1020	1066.40
2 PM	200	259	197	215	200	1019	1062
3 PM							10166.40
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FIELD DATE	93-02-25-13
	2-25-93

TIME	WELL FIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS				
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW SPM	PRESSURE FLOW SPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
3 PM	197	256	198	215	200	1013	1019	1061	1016.40	110+	SCHADLER
4 PM	200	254	201	215	200	1018	1020	1060	9813.40	Working	60
5 PM	200	253	199	212	200	1017	1022	1086	1016.40		CIVALLARO
6 PM	200	252	201	216	200	1020	1022	1075	9813.40		121
7 PM	200	254	200	216	200	1019	1020	1072	9813.40		183
8 PM	200	252	203	215	200	1018	1020	1068	9389.80		245
9 PM	200	253	203	216	200	1018	1019	1064	9813.40		306
10 PM	200	250	197	216	198	1010	1020	1061	9813.40		374
11 PM											437
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump out for repair
 #1 P.F. pump not working
 BOTH A.S. Pumps shutting off together. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE ID:	93-C2-26-11
DATE:	2-26-93

WELL SYSTEM OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW gpm	PRESSURE FIL FLOW gpm	BLOWER FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MOLES	SUPERVISOR INITIALS				
11 PM	202	255	200	216	200	1011	1019	1058	9813 40	501	LLOYD				
12 AM	197	256	200	216	200	1016	1021	1085	9813 40	52	DOANE/CIS				
1 AM	198	253	196	216	199	1021	1020	1070	9389 80	105					
2 AM	196	255	200	214	200	1018	1019	1068	9107 40	180					
3 AM	200	252	200	216	200	1016	1021	1064	9107 40	248					
4 AM	201	256	199	216	200	1020	1059	1059	9389 80	312					
5 AM	196	255	203	216	200	1016	1021	1061	9389 80	372					
6 AM	196	256	198	215	199	1017	1020	1060	9389 80	438					
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

REMARKS

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

THE ID	93-C2-46-12
DATE	3-26-93

TIME	WELL FIELD OPERATION						AIR STRIPPER OPERATING PARAMETERS				
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW gpm	PRESS FIL LOW cm	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW GAL/S	SUPERVISOR INITIALS
7 AM	197	255	200	216	200	1015	1022	1055	9389.85	494	Nix
8 AM	200	256	197	215	200	1020	1023	9389.80	62	Cape & S	
9 AM	198	252	167	216	200	1015	1019	1071	10590.00	127	Abra
10 AM	200	256	198	215	201	1020	1020	1068	10590.00	191	-
11 AM	200	256	201	216	200	1014	1020	1063	10590.00	257	-
12 PM	201	256	197	216	201	1017	1020	1062	10590.00	316	-
1 PM	200	254	199	215	200	1021	1021	1056	10940.00	381	-
2 PM	201	256	195	215	201	1015	1019	673	10943.00	443	-
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 EVENING SHIFT

7 PM	93-02-26-13
8 PM	2-26-93

WELL SYSTEM OPERATION								AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE AT AIR FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
3 PM	199	254	200	216	199	1017	1021	1081	10590.00	NOT	500	Rodgers
4 PM	200	256	200	216	200	1018	1021	1073	10590.00	working	63	CAVALLARO
5 PM	200	255	202	215	201	1018	1020	1068	10590.00		126	LLOYD
6 PM	200	256	201	216	199	1015	1020	1063	10166.40		191	
7 PM	197	255	200	216	200	1013	1021	1061	10590.00		255	
8 PM	200	254	199	216	200	1015	1020	1060	10166.40		317	
9 PM	199	255	199	216	198	1014	1021	1057	10590.00		380	
10 PM	199	256	199	216	200	1016	1020	1079	10590.00		443	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump out for repair
 #1 P.F. Pump not working
 BOTH A.S. pumps shutting off together. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD ID	93 - 02-27-11
DATE	2-27-923

WELL 1 FLOW				WELL 2 FLOW				WELL 3 FLOW				WELL 4 FLOW				AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 1 SYSTEM FLOW	WELL 2 SYSTEM FLOW	WELL 3 SYSTEM FLOW	WELL 4 SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW GALLONS/MIN	SUPERVISOR INITIALS					
11 PM	201	256	199	216	200	1013	1021	1074	1021	1074	10590.00	10590.00	500	L L C Y D					
12 AM	200	254	199	216	200	1013	1020	1054	1020	1054	10590.00	10590.00	51	F A L C I A N O					
1 AM	197	256	198	216	200	1015	1020	1056	1020	1056	10590.00	10590.00	124						
2 AM	199	254	200	216	200	1016	1021	1055	1021	1055	10166.40	10166.40	188						
3 AM	199	256	200	216	200	1015	1021	1055	1021	1055	10166.40	10166.40	250						
4 AM	200	256	198	216	200	1020	1020	1055	1020	1055	10166.40	10166.40	316						
5 AM	196	256	200	215	200	1021	1021	1055	1021	1055	10166.40	10166.40	374						
6 AM	200	255	200	216	200	1017	1021	1055	1021	1055	10166.40	10166.40	436						
7 AM																			
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD ID	93-02-27-12
DATE	2-27-93

TIME	WELL HEAD OPERATION					AIR STRIPPER OPERATING PARAMETERS				
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	AIR FLOW CFM	EFFECTIVE PRESSURE INCHES W.C.	EFFLUENT FLOW GAL/S	SUPERVISOR INITIALS
7 AM	200	256	196	216	200	1015	1022	9813.40	502	Nix
8 AM	198	256	196	216	201	1019	1020	9813.40	62	Capek
9 AM	196	256	201	216	200	1020	1021	10166.40	124	
10 AM	198	256	201	216	200	1015	1022	1054	10166.40	
11 AM	199	257	195	216	200	1016	1021	1053	10166.40	159
12 PM	200	256	202	216	200	1017	1020	1054	10590.00	253
1 PM	199	254	202	216	200	1020	1022	1055	10590.00	315
2 PM	199	253	197	216	200	1020	1021	1053	10166.40	380
3 PM									440	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILED:	93-02-27-13
DATE:	2-27-93

TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM FLOW	AIR STRIPPER OPERATING PARAMETERS		
						STRIPPER Flow GPM	PRESSURE FILTER Flow SPM	BLOWER Air Flow CFM
3 PM	199	256	198	216	198	1022	1054	10166.40
4 PM	198	254	198	216	200	1015	1052	10590.00
5 PM	201	252	198	216	200	1014	1051	10590.00
6 PM	200	253	203	216	200	1013	1050	98913.40
7 PM	200	255	197	216	201	1016	1053	10590.00
8 PM	201	256	195	216	199	1015	1051	10166.40
9 PM	197	256	200	216	200	1018	1021	1053
10 PM	199	256	197	216	200	1017	1020	1051
11 PM								
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

ITEM ID	Q33-02-28-11
DATE	1-13-28/1993

WELL FLOW & DRACTION WELL 1, 2, 3, 4, 5, 6, 7, 8, 9, 10							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW cm	PRESSURE FLOW cm	BLOWER CFM	AIR FLOW CFM	EFFLUENT PRESSURE INCHES HG	AIR FLOW MGD	SUPERVISOR OPERATOR INITIALS
11 PM	198	252	197	216	196	1017	1019	1052	1016.43	100.70	501	Rockey's	
12 AM	201	252	196	244	200	1014	1022	1052	1016.52	100.70	57	Danielle's	
1 AM	197	252	202	214	200	1018	1022	1053	1016.45	100.70	114		
2 AM	195	252	202	216	202	1021	1021	1054	1016.40	100.70	183		
3 AM	197	252	202	216	200	1017	1021	1052	1016.40	100.70	846		
4 AM	200	252	191	214	200	1017	1021	1054	1016.40	100.70	311		
5 AM	196	256	200	216	200	1015	1022	1054	1016.40	100.70	374		
6 AM	200	252	198	216	201	1017	1021	1053	1016.40	100.70	438		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA						

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE#	93-02-28-12
DATE	2-28-93

WELL SYSTEM OPERATION						AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	AIR FLOW	AIR PRESSURE	EFFLUENT FLOW	SUPERVISOR COMMENTS
	CMH	CMH	CMH	CMH	CMH	CMH	CMH	CMH	INCHES HG	INCHES HG	INCHES HG
7 AM	200	250	198	216	200	1020	1022	1054	10590.00	498	N/A
8 AM	200	250	198	216	200	1017	1020	1055	10590.00	65	Caren 1
9 AM	201	256	198	216	200	1015	1022	1054	9819.40	123	
10 AM	196	256	202	216	200	1015	1021	1054	9813.40	183	
11 AM	197	256	202	216	200	1017	1022	1054	10590.00	251	
12 PM	196	256	202	215	200	1017	1021	1054	10590.00	313	
1 PM	200	256	196	216	200	1018	1021	1209	9813.40	380	
2 PM	200	256	202	216	201	1017	1021	1061	10590.00	435	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 Pressure Fall
 PF-1 is on at 1300 hrs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

THE ID	93-02-25-13
DATE	2-28-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWER AIR FLOW	AIR PRESSURE	EFFLUENT FLOW	SUPERVISOR INITIALS
	GPM	GPM	GPM	GPM	GPM	GPM	PSI	CFM	INCH WC	INCH WC	
12 PM	200	257	196	216	200	1016	1021	1056	105%	497	Nix
1 PM	199	257	200	214	200	1021	1017	1050	105%	46	Capey
5 PM	201	256	196	215	200	1015	1017	1052	105%	130	..
6 PM	201	256	196	214	200	1016	1017	1070	105%	191	..
7 PM	201	256	202	216	200	1016	1020	1063	105%	255	..
8 PM	197	253	204	214	200	1017	1041	1105	105%	310	..
9 PM	200	253	202	216	200	1019	1033	1094	105%	374	..
10 PM	200	256	200	215	200	1019	1028	1086	106%	440	..
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

PF #2 is working from 1300hrs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD ID:	93-03-01-11
DATE:	Mar 1, 1993

TIME	WELL FLOW						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW gpm	PRESSURE FLOW gpm	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGD	SUPERVISOR INITIALS	
11 PM	200	256	196	215	200	1015	1036	1106	10590 cc	4.95	LJD-YD	
12 AM	200	256	197	216	199	1017	1030	11570 cc	10590 cc	4.95	Col. Downey	
1 AM	200	256	202	216	200	1022	1038	1086	10590 cc	4.95		
2 AM	200	256	200	216	200	1022	1026	1080	10590 cc	4.95		
3 AM	200	257	196	216	200	1016	1023	1093	10590 cc	4.95		
4 AM	200	256	196	216	200	1016	1021	1077	10590 cc	4.95		
5 AM	200	257	200	216	200	1018	1022	1104	9813 cc	3.70		
6 AM	200	256	198	216	202	1020	1021	1095	9813 cc	3.70		
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TEP#	93-03-01-12
DATE	3-1-93

TIME	WELL PUMP OPERATION		AIR STRIPPER OPERATING PARAMETERS		SUPERVISOR						
	WELL FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESS. FIL. FLOW	BLOWER AIR FLOW CMH	AIR PRESSURE INCHES WC	EFFLUENT FLOW CMH	FLUID LEVEL IN FEET MARS	
7 AM	200	256	197	216	200	1020	1083	10943.00	NOT	510	FALCINO
8 AM	201	256	203	216	200	1017	1020	1093	10940.00	WORKING	059 Abrams
9 AM	200	256	201	216	200	1016	1021	1084	11246.00		121
10 AM	196	256	202	214	200	1022	1022	1043	11649.00		182
11 AM	197	256	201	216	200	1017	1021	1086	10666.40		247
12 PM	201	256	202	216	197	1010	1023	1108	11296.00		302
1 PM	201	256	196	216	200	1015	1036	1044	1054.00		365
2 PM	201	256	196	214	200	1016	1029	1090	10943.00	✓	433
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

✓ 1 A/S Pump out for Repairs
 ✓ 1 If pump not complete.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

EVENING SHIFT

FIRE ID 93-03-01-13
FARE 3-1-93

REMARKS

#1A.S Pump out FOR REPAIR
BOTH A.S Pumps SHUTTING OFF TOGETHER. Same problem with PF Pump

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	93-03-02-11
DATE	MAR 2 1993

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow gpm	BLOWERS Air Flow gpm	EFFLUENT Flow gpm
11 PM	200	256	159	216	200	1020	1019
12 AM	202	257	198	216	200	1018	1021
1 AM	200	256	196	216	200	1015	1022
2 AM	199	256	200	216	199	1017	1022
3 AM	200	257	204	216	200	1020	1022
4 AM	200	256	197	216	200	1013	1023
5 AM	201	256	201	216	200	1013	1021
6 AM	201	256	196	216	200	1016	1021
7 AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

THE D	93-03-02-12
DATE	3-2-93

WELLER OPERATION
 SALT SPRINGS UNITE

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL FLOW	WELL HEAD FLOW	WELL SYSTEM FLOW	STRIPPER FLOW	OVER AIR FLOW	AIR PRESSURE	EFFLUENT FLOW
	GPM	GPM	GPM	GPM	GPM	PSI	GPM
7AM	200	256	202	216	200	1016	102-2
8AM	197	257	195	216	200	1016	1021
9AM	199	256	201	216	200	1018	1014
10AM	OFF	OFF	OFF	OFF	OFF	OFF	10590.0
11AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF
1PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2PM	198	248	198	208	200	996	1016
3PM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S Dump out for Repairs
 Oacobas shut down system, plant for acid wash,
 Acid wash complete. Back on line at 1340

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

THE DATES	93-03-02-13
DATE	3-2-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	BLOWER FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW GAL/MIN	SUPERVISOR INITIALS
3 PM	198	253	200	211	200	1006	1031	1100	10166.40	224
4 PM	201	255	201	213	200	1016	1025	1088	10166.40	C2
5 PM	201	256	200	214	200	1020	1025	1100	9389.80	CAVALLARO
6 PM	197	257	202	216	200	1019	1024	1095	9813.40	124
7 PM	196	256	202	214	200	1016	1022	1083	9813.40	186
8 PM	200	256	201	216	198	1019	1023	1095	9813.40	254
9 PM	198	257	198	214	200	1016	1023	1081	9389.80	310
10 PM	198	257	198	217	200	1019	1023	1106	9813.40	377
11 PM										438
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump out for repair
 BOTH A.S. Pumps shutting off together. Same problem with P.F. 10m/s

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

NIGHT SHIFT

FIELD 93-03-03-11
DATE MAR 15 1993

REMARKS

NOTES

- THE SYSTEM FLOW, SHIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE#:	93-03-03-12
DATE:	3-3-93

WELL RATE & OPERATION							AIR STRIPPER OPERATING PARAMETERS				
Time	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESSURE FLOW GPM	BLOWER Air Flow CFM	AIR PRESSURE inches w.c.	EFFLUENT Flow GPM	Flow Meters	Supervision Initials
7 AM	198	256	145	216	200	1015	1023	1085	4813.40	NOT	507 FALCIANO
8 AM	200	256	202	216	200	1018	1021	1095	4813.40	WORKING	61 ABAGNIS
9 AM	200	259	148	216	200	1013	1022	1086	4107.40		124
10 AM	200	256	146	217	200	1016	1021	1091	41389.80		185
11 AM	200	257	149	217	200	1020	1022	1087	41389.80		249
12 PM	198	256	200	216	200	1017	1024	1082	43389.80		311
1 PM	201	257	146	216	200	1013	1025	1091	41813.40		375
2 PM	200	257	145	216	200	1018	1023	1085	44813.40	✓	441
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

✓ 1 A/S OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-03-03
TIME	13:30
	3-93

TIME	WATER TREATMENT			AIR STRIPPER OPERATING PARAMETERS		
	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM HEAD	STRIPPER FLOW	PRESSURE HEAD
	gpm	gpm	gpm	psi	gpm	psi
3 PM	200	256	200	200	1019	1024
4 PM	196	257	198	216	1015	1024
5 PM	199	256	202	216	198	1025
6 PM	200	256	197	216	200	1017
7 PM	200	256	204	216	199	1021
8 PM	200	256	200	216	200	1015
9 PM	198	256	202	216	201	1017
10 PM	197	257	198	216	200	1015
11 PM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. pump out for repair
 BOTH A.S. PUMP'S SHUTTING OFF TOGETHER. SAME PROBLEM WITH PUMP'S

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE #	93-03-04-11
PAGE	03-4-23

TIME	WELL SYSTEM OPERATIONS						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	STRIPPER PRESSURE	BLOWDOWN AIR FLOW	EFFLUENT AIR FLOW	EFFLUENT FLOW METERS	SUPERVISOR INITIALS	OPERATOR INITIALS
	gpm	gpm	gpm	gpm	gpm	gpm	cfm	cfm	cfm	inches w.c.		
11 PM	201	258	199	216	200	1019	1023	1090	9813.40	500	LLOPD	
12 AM	200	257	199	217	200	1022	1024	686	9813.40	58	DCLVCE13	
1 AM	200	256	200	216	198	1015	1024	1093	9813.40	125		
2 AM	200	257	202	217	200	1019	1025	1083	9813.40	190		
3 AM	199	259	201	216	200	1016	1025	1103	9813.40	248		
4 AM	197	257	203	216	200	1019	1024	1085	9813.40	315		
5 AM	201	256	202	216	205	1015	1022	1075	9102.80	378		
6 AM	200	256	201	216	200	1014	1024	1083	9107.50	441		
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD ID:	93-A3-4-1B
Date:	3-4-93

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	WELL'S FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG W.C.	NOTES
7AM	201	258	198	216	200	1017	1022	1102	9389.80	500	ABRAMS
8AM	194	252	202	216	200	1017	1024	1023	9385.80	64	DARJEUS
9AM	200	253	201	216	203	1018	1022	1076	9388.80	128	
10AM	197	259	196	216	200	1019	1022	1105	9107.42	187	
11AM	199	252	200	216	203	1020	1023	1088	9107.40	260	
12PM	197	258	203	216	200	1015	1023	1103	1101.40	311	
1PM	200	252	201	216	200	1012	1023	1091	9107.40	377	
2PM	200	254	196	216	199	1018	1022	1101	9107.40	442	
3PM											
AVERAGE	NA	NA	NA	NA							

REMARKS

1 H/S pump out for repairs
 Both A/s pumps shutting off together
 Some problem with P1=P2 pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE#	93-03-04-13
DATE	3-4-93

TIME	WELL FLOW INFORMATION						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FIL LOW PSI	BLOWED AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW GALLONS MINUTES	SUPERVISOR OPERATOR INITIALS	
3 PM	200	257	200	216	200	1020	1023	1087	10166.40	501	SCHADLER	
4 PM	194	258	202	216	200	1018	1023	1083	9389.80	63	CAVALLACO	
5 PM	198	257	199	216	200	1015	1022	1101	9813.40		125	
6 PM	201	257	199	216	200	1020	1023	1090	10166.40		188	
7 PM	200	258	201	216	200	1022	1024	1102	9389.80		249	
8 PM	201	258	200	216	197	1018	1024	1091	9389.80		313	
9 PM	201	257	199	216	199	1018	1024	1101	9389.80		376	
10 PM	200	257	196	216	201	1016	1023	1091	9389.80		439	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 A.S. Pump out for repair
 Both A.S. Pumps shutting off together. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD DATE	9/3-03-05-11
	3 - 3 - 9/3

WELL 1 & 2 DRAWDOWN GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR OPERATOR NAME		
11 PM	197	258	202	216	200	1022	1023	1081	9813.40	No 1 working	SC HADLEE		
12 AM	193	250	196	216	201	1019	1024	1100	9813.40	A	b1 DOWNEY		
1 AM	198	257	203	217	200	1017	1025	1091	9813.40		116		
2 AM	198	258	202	217	200	1017	1024	1104	7813.40		177		
3 AM	200	258	201	217	200	1014	1025	1093	9813.40		242		
4 AM	201	257	196	216	200	1020	1024	1102	9813.40		201		
5 AM	198	257	196	216	201	1019	1023	1092	10166.40	V	368		
6 AM	200	258	198	217	200	1016	1023	1081	10570.62		435		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

1 A/C PUMP OUT FOR REPAIRS
 A/S & P/F PUMPS SHUT DOWN OFF TO GAUGE

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	9-3-03-05-12
TIME	3-5-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW cm³	PRESSURE FLOW cm³	AIR FLOW cm³	EFFLUENT PRESSURE INCHES WC	EFFECTIVE MEASUREMENTS	SUPERVISOR INITIALS
7 AM	200	258	200	216	200	1016	1024	1102	10943.00	496	Casper
8 AM	200	250	198	216	200	1020	1023	1089	1059.00	65	Abra
9 AM	200	252	200	217	200	1016	1025	1105	1059.00	121	-
10 AM	119	259	196	216	200	1016	1023	1093	1059.00	189	-
11 AM	198	257	198	217	198	1018	1023	1086	10943.00	249	-
12 PM	200	258	199	217	201	1022	1024	1089	10166.40	316	-
1 PM	200	257	198	216	200	1020	1023	1080	10166.40	380	-
2 PM	100	259	200	217	200	1023	1024	1087	10166.40	437	-
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 120 #3 well Shut Down
 14 10 #3 well Back on

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

TIME	93-03-05	~13
DATE	3-5-93	

WELL SYSTEM PERMANENT							A.I.F. STRIPPER OPERATING PARAMETERS			
TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	AIR FLOW	PRESSURE	EFFLUENT	SUPERVISER
	GPM	GPM	GPM	GPM	GPM	GFM	CFM	PSI	FLOW	OPERATOR
3 PM	200	260	200	217	200	1019	1013	1093	10166.40	LLOYD
4 PM	200	258	201	216	199	1018	1015	1109	10166.40	61 CAVALARO
5 PM	196	258	200	216	199	1015	1019	1094	10590.00	123
6 PM	199	256	201	216	200	1019	1020	1109	10590.00	180
7 PM	196	257	200	217	200	1018	1021	1087	10166.40	243
8 PM	199	257	200	216	200	1019	1022	1080	10166.40	308
9 PM	200	258	195	216	200	1018	1022	1074	10590.00	373
10 PM	198	257	201	216	200	1021	1023	1089	10590.00	425
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. PUMP OUT FOR REPAIR
 BOTH A.S. PUMPS SHUTTING OFF TOGETHER. SAME PROBLEM WITH P.F. PUMPS.

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

NIGHT SHIFT

~~93-03-06-11~~
~~93-6-93~~

REMARKS

~~FAJS~~ DUMP IT OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILED	93-03-06-12
DATE	03-6-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. PSI	FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGDS	SUPERVISION OPERATOR INITIALS
7 AM	201	260	197	217	200	1010	1024	1088	10590.00	500	N/R
8 AM	201	257	201	216	199	1015	1023	1081	10590.00	60	CAPEX
9 AM	201	257	196	216	200	1015	1023	1073	9813.10	119	
10 AM	198	257	198	216	200	1015	1023	1065	10166.40	186	
11 AM	200	257	195	216	199	1016	1024	1067	10943.00	252	
12 PM	196	258	201	217	198	1016	1024	1091	10166.90	308	
1 PM	201	260	196	216	200	1016	1023	1079	10590.00	372	
2 PM	200	257	200	216	200	1019	1022	1076	10590.00	435	
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-03-06-13
TIME	03-06-93

TIME	WELL SYSTEM OPERATION			AIR STRIPPER OPERATING PARAMETERS		
	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW
	gpm	gpm	gpm	gpm	gpm	inches wc
3PM	200	260	196	319	200	1016
4PM	100	259	195	217	200	1018
5PM	201	255	202	216	200	1013
6PM	200	249	200	209	200	999
7PM	200	252	201	212	200	1008
8PM	200	249	201	213	200	1011
9PM	200	256	200	213	200	1018
10PM	195	255	201	216	200	1017
11PM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE #	93-03-07-11
DATE	3-7-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW dpm	BLOWERS FLOW dpm	AIR FLOW cm ³ /min	AIR PRESSURE inches wc	EFFLUENT FLOW MEAS.	SUPERVISOR NAME	OPERATOR NAME	MATERIALS
11 PM	200	257	197	215	200	1015	1022	1069	10166.40	NOT	496	SCHADLER	
12 AM	200	256	199	215	200	1015	1021	1063	10540. ^a	WORKING	62	FALCIANO	
1 AM	201	256	201	216	199	1013	1021	1083	10540.00		124		
2 AM	200	256	206	216	201	1017	1021	1076	10166.40		185		
3 AM	200	256	194	216	200	1019	1021	1069	10166.40		249		
4 AM	196	257	198	216	201	1018	1020	1067	10166.40		315		
5 AM	197	256	201	215	200	1018	1020	1066	10166.40		379		
6 AM	201	256	196	216	200	1012	1020	1062	10166.40	✓	440		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

X 1 A/S Pump out for Repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

SHIFT	93-03-07-12
DATE	3 - 7 - 93

DAILY OPERATIONS										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESSURE FLOW CFM	EFFLUENT FLOW CFM	AIR FLOW CFM	EFFLUENT FLOW INCHES W.C.	SUPERVISOR OPERATOR INITIALS		
7AM	202	258	198	216	201	1019	1021	1081	10590.00	↑	500	N. ~	
8AM	202	256	198	215	200	1019	1021	1070	10590.00		65	Caper	
9AM	201	256	200	216	200	1012	1019	1065	10166.40		125	~	
10AM	200	256	198	216	200	1017	1020	1065	101590.00		193	~	
11AM	196	256	199	216	200	1017	1049	1083	10390.00		244	~	
12PM	200	256	199	216	201	1015	1039	1076	10166.40		300	~	
1PM	197	257	200	216	199	1012	1032	1078	10166.40		375	~	
2PM	197	257	200	216	200	1016	1028	1074	10590.00		440	~	
3PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

TIME	9:55 - 10:15
DATE	3-7-93

TIME	WELL FIELD OPERATION			AIR STRIPPER OPERATING PARAMETERS			SUPERVISOR NAME								
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	AIR FLOW									
3 PM	198	235	199	214	200	1015	1045	1090	10590. ^a	1035	1086	10590. ^a	495	Mike	
4 PM	199	254	200	216	200	1017	1046	1023	1077	1022	1022	10390.	65	Capo H	
5 PM	199	254	195	213	200	1617	1023	1025	1075	1025	1025	1066. ^b	144	..	
6 PM	199	256	195	215	200	1019	1047	1023	1075	1025	1025	1066. ^b	201	..	
7 PM	201	256	201	209	200	1016	1048	1023	1075	1023	1023	10590. ^c	257	..	
8 PM	200	257	196	212	201	1016	1046	1021	1066	1021	1021	10590. ^c	321	..	
9 PM	200	256	197	216	200	1019	1047	1021	1061	1021	1021	10943. ^c	382	..	
10 PM	200	257	200	215	200	1018	1048	1022	1061	1022	1022	10590. ^c	442	..	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD	9.3 - 03 - 08 - 11
DATE	3 - 8 - 93

TIME	WELL FIELD OPERATION		WELL FIELD UNITE		WELL FIELD		WELL FIELD		STRIPPER		PRESSURE		BLOWDOWN		EFFLUENT		AIR STRIPPER OPERATING PARAMETERS	
	WELL FLOW	GALLONS PER MINUTE	WELL FLOW	GALLONS PER MINUTE	WELL FLOW	GALLONS PER MINUTE	WELL FLOW	GALLONS PER MINUTE	FLOW	CFM	FLOW	CFM	PRESSURE	INCHES MCWHS	FLOW	CFM	MONITORING	NOTES
11 PM	195	256	200	215	200	1015	1021	1073	10590.00	OFF	503	11010	11010	11010	11010	11010	11010	
12 AM	201	257	200	215	199	1018	1021	1070	10590.00	OFF	64	11015	11015	11015	11015	11015	11015	
1 AM	200	258	200	216	200	1020	1020	1065	10590.00	OFF	127	11015	11015	11015	11015	11015	11015	
2 AM	200	256	200	216	200	1020	1021	1082	10590.00	OFF	189	11015	11015	11015	11015	11015	11015	
3 AM	199	256	199	215	200	1020	1020	1072	10590.00	OFF	253	11015	11015	11015	11015	11015	11015	
4 AM	196	257	198	216	200	1014	1020	1068	10590.00	OFF	319	11015	11015	11015	11015	11015	11015	
5 AM	200	257	200	215	200	1015	1019	1062	10590.00	OFF	380	11015	11015	11015	11015	11015	11015	
6 AM	200	257	202	216	200	1017	1020	1064	10590.00	OFF	441	11015	11015	11015	11015	11015	11015	
7 AM	AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE ID	43-3-8-12
DATE	3-8-93

TIME	WELL SYSTEM OPERATION		AIR STRIPPER OPERATING PARAMETERS		SUPERVISOR INITIALS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW cm ³ /min	PRESSURE LOW cm	BLOWER PRESSURE INCHES HG	AIR FLOW CM ³ /min	EFFLUENT FLOW INCHES HG	
7 AM	199	256	199	214	200	1017	1020	1085	10166.40	Not Working
8 AM	200	256	148	214	200	1018	1019	1075	10166.40	Working
9 AM	198	256	201	216	200	1018	1020	1068	10166.40	
10 AM	201	256	200	214	200	1014	1020	1065	10166.40	
11 AM	197	256	200	216	198	1017	1020	1084	10166.40	
12 PM	197	256	200	216	201	1020	1014	1072	10540.00	
1 PM	200	256	202	216	200	1016	1014	1064	10540.00	
2 PM	201	257	198	216	200	1016	1019	1066	10166.40	✓
3 PM										
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

*1 A/S Pump out for repairs

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

REF ID:	93-03-08-13
DATE:	3-8-93

TIME	WELL SYSTEM OPERATION					AIR STRIPPER OPERATING PARAMETERS				
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	EFFLOW AIR FLOW INCHES WC	AIR PRESSURE INCHES WC	EFFLUENT FLOW INCHES WC
3:00 AM	200	255	200	216	200	1014	1019	1088	10590.00	502
4:00 AM	197	256	201	216	198	1013	1018	1076	10166.40	60
5:00 AM	201	256	202	211	200	1016	1020	1070	10590.00	CAYALLACO
6:00 AM	200	256	201	216	200	1017	1019	1067	10590.00	121
7:00 PM	197	256	198	216	199	1011	1019	1061	10590.00	183
8:00 PM	200	256	200	216	200	1016	1019	1061	10166.40	
9:00 PM	200	257	201	216	200	1016	1018	1081	10590.00	371
10:00 PM	200	256	200	216	200	1014	1019	1070	10590.00	435
11:00 PM										
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump out for repair
 BOTH A.S. Pumps shutting off together. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	93-03-09-11
DATE	3-9-93

TIME	WELL 1 OPERATION			WELL 3 OPERATION			AIR STRIPPER OPERATION			NOTES					
	WELL 1 Flow	WELL 1 Flow	GALLONS PER MINUTE	WELL 3 Flow	WELL 3 Flow	GALLONS PER MINUTE	STRIPPER Flow	STRIPPER Flow	CFM	BLOWDOWN Air Flow	INCHES W.C.	EFFECTIVE Flow	INCHES W.C.	EFFLUENT Flow	INCHES W.C.
11 PM	201	256	197	216	200	1013	1018	1067	10166.40	NOT	499	Lloyd			
12 AM	200	256	202	211	194	1016	1019	1065	10166.40	WORKING	63	Falcon			
1 AM	197	259	196	215	200	1017	1018	1080	10166.40						
2 AM	200	256	200	216	200	1014	1020	1072	10166.40						
3 AM	200	256	200	215	200	1013	1019	1065	10166.40						
4 AM	196	257	200	216	200	1014	1020	1064	10166.40						
5 AM	198	257	200	216	200	1016	1014	1078	10166.40						
6 AM	200	256	196	216	200	1016	1010	1071	10166.40	✓	435				
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 A/S Pump out for repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILED	93-03-09-12
DATE	3-9-93

TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW CMH	FLOW CMH	AIR PRESSURE CMH	AIR STRIPPER OPERATING PARAMETERS	
										SUPERVISOR	SUPERVISOR
1 PM	199	256	201	212	200	1012	1018	1067	10166.40	NOT	500
4 AM	199	256	196	214	200	1016	1019	1063	10166.40	WORKING	62
9 AM	197	258	200	213	200	1014	1018	675	10943.00		121
10 AM	200	255	201	215	200	1016	1018	1075	10166.40		104
11 AM	200	257	197	210	201	1012	1018	1072	10166.40		245
12 PM	198	256	198	216	199	1017	1019	1066	10590.00		302
1 PM	200	256	196	216	200	1013	1019	676	10590.00		368
2 PM	197	257	200	216	200	1014	1018	1074	10166.40	✓	431
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S Pump out for Repairs

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-03-09-13
DATE	3-9-93

WELL PUMP OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWER AIR FLOW	EFFLUENT PRESSURE	EFFLUENT FLOW	SUPERVISOR INITIALS
	gpm	gpm	gpm	gpm	gpm	gpm	cm	cm	incheshg	gpm	
3 PM	200	256	199	212	200	1014	1019	1072	10590.00		SC HADLER
4 PM	195	257	201	216	200	1015	1019	1067	10166.40		62 CAVALLARO
5 PM	198	256	200	216	200	1018	1019	1065	10166.40		122
6 PM	197	258	198	216	199	1014	1019	1077	9813.40		184
7 PM	200	256	195	209	198	1008	1018	1070	9813.40		245
8 PM	197	256	203	216	200	1018	1019	1065	10166.40		310
9 PM	200	258	200	210	200	1017	1018	1058	9813.40		375
10 PM	199	256	197	215	199	1014	1018	1085	9813.40		435
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 A.S. Pump out for repair
 BOTH A.S. PUMPS SHUTTING OFF TOGETHER. SAME PROBLEM WITH P.F. PUMPS.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILTERS	93-03 10-11
DATE	3-10-93

WELL OPERATIONS							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWDOWN FLOW	AIR FLOW	PRESSURE INCHES WC	EFFLUENT FLOW	SUPERVISOR NAME
11 PM	200	257	200	216	196	1013	1017	1073	9813.40	498	LLO/D
12 AM	197	258	200	215	200	1013	1017	1067	9389.80	62	CAVALLIRO
1 AM	200	258	201	216	200	1015	1018	1061	9389.80	125	
2 AM	196	256	201	216	200	1011	1018	1083	9389.80	185	
3 AM	200	257	200	216	200	1017	1018	1073	9813.40	247	
4 AM	200	257	198	216	201	1015	1019	1071	9813.40	310	
5 AM	200	257	202	214	200	1017	1019	1064	9813.40	376	
6 AM	199	257	199	216	200	1015	1017	1080	9813.40	436	
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1A5 Runout for Repair

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

Shift:	93-03-10-12
Date:	3-10-93

TIME	WELL 1			WELL 2			WELL 3			SYSTEM			STRIPPER			PRESSURE			FLOW			EFFLUENT			AIR			STRIPPER			OPERATING			SUPERVISOR		
	WELL 1 FLOW	WELL 1 FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 2 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 3 FLOW	WELL 3 FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 1 PRESSURE	WELL 2 PRESSURE	WELL 3 PRESSURE	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 1 MEAS.	WELL 2 MEAS.	WELL 3 MEAS.	WELL 1 MEAS.	WELL 2 MEAS.	WELL 3 MEAS.	WELL 1 MEAS.	WELL 2 MEAS.	WELL 3 MEAS.	WELL 1 MEAS.	WELL 2 MEAS.	WELL 3 MEAS.			
7 AM	200	257	200	216	200	1016	1019	1019	1019	1072	9389.80	100	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	500	Falcianno					
8 AM	200	256	202	216	198	1015	1016	1016	1016	1066	9101.40	100	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	61	Abrams			
9 AM	200	257	198	216	200	1018	1017	1017	1017	1063	9101.40	100	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124	124		
10 AM	200	256	200	216	200	1018	1017	1017	1017	674	9101.40	100	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185	185		
11 AM	200	259	199	216	200	1018	1018	1018	1018	1081	9101.40	100	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247	247		
12 PM	200	000	198	233	200	813	574	574	574	675	9389.80	100	294	294	294	294	294	294	294	294	294	294	294	294	294	294	294	294	294	294	294	294	294	294		
1 PM	202	283	191	000	201	825	1010	1010	1010	1090	1389.80	100	337	337	337	337	337	337	337	337	337	337	337	337	337	337	337	337	337	337	337	337	337	337		
2 PM	195	280	000	223	200	855	1018	1018	1018	9389.20	9389.20	100	392	392	392	392	392	392	392	392	392	392	392	392	392	392	392	392	392	392	392	392	392	392		
3 PM												100																								
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA																

REMARKS

#2 A/S pump out for repairs
 100hrs "Delta wells" on site with Brooks at wells
 10 Park will be switching down wells where needed

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

TIME	93-03-10 - 13
DATE	3-10-93

WELL FIELD OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE HEAD CM.	BLOWER AIR FLOW CM.	AIR PRESSURE INCHES HG	EFFLUENT FLOW M3/H	SUPERVISOR / OPERATOR / ANIMALS
3 PM	201	279	0FF	228	198	853	1026	1090	98/3.40	44.2	SCHADLER
4 PM	200	280	198	0FF	202	820	1024	1088	9389.80	21	CAVALLARO
5 PM	199	256	202	211	194	1010	1057	1096	9389.80	74	
6 PM	200	255	197	212	199	1007	1044	1083	10166.40	13.5	
7 PM	200	256	197	214	200	1012	1035	1083	10166.40	200	
8 PM	197	256	200	215	200	1012	1028	1075	10590.00	264	
9 PM	199	256	200	216	201	1015	1014	1071	98/3.40	324	
10 PM	200	258	196	215	200	1014	1022	1070	10166.40	391	
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

L.A.S. Delta working on wells
#1 A.S. pump out for repair
BOTH A.S. units shutting off together. Same problem with P.F. Pumps
1530 Military Power failure. Flow Totalizer zeroed out from 0.030,
17:00 Delta wells personnel off site, will be back to normal.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE #	93-03-11-11
DATE	3-11-93

WELL PUMP OPERATION
GALLONS PER MINUTE

TIME	AIR STRIPPER OPERATING PARAMETERS					
	WELL FLOW	WELL FLOW	WELL FLOW	STRIPPER FLOW	BLOWDOWN AIR FLOW	EFFLUENT FLOW M.G.P.H.
	GPM	CFM	CFM	CFM	CFM	M.G.P.H.
11 PM	196	256	202	216	199	1018
12 AM	198	258	201	216	200	1015
1 AM	199	257	203	216	200	1017
2 AM	200	256	196	216	201	1018
3 AM	200	259	198	213	200	1020
4 AM	201	257	198	216	200	1020
5 AM	198	258	198	215	200	1018
6 AM	200	254	197	216	200	1015
7 AM	AVERAGE	NA	NA	NA	NA	NA

REMARKS

#1 A/S Pump out for REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	93-03-11-93
DATE	3-11-93

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	AIR STRIPPER OPERATING PARAMETERS		NOTES		
							STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWED AIR FLOW CFM	AIR PRESSURE INCHES HG	SUPERVISOR INITIALS
7 AM	100	256	202	216	221	1015	1017	1070	10166.40	119.7	Mark R. (initials)
8 AM	136	218	200	215	200	1015	1019	1066	10166.46	105	Mark R. (initials)
9 AM	193	257	208	215	200	1017	1019	1063	10166.40	127	
10 AM	200	277	200	236	200	845	565	1067	10166.40	127	
11 AM	193	256	200	211	200	1016	1026	1085	10166.40	234	
12 PM	000	280	195	228	200	864	1037	1088	10166.40	285	
1 PM	005	276	199	227	200	867	581	602	10166.40	342	
2 PM	167	216	201	214	200	1014	1036	1086	10166.40	102	
3 PM											
AVERAGE	NA	NA	NA	NA							

REMARKS

- #1 P/S pump cut for repairs
- #3 well water low level
- De Ha working on wells, shutting down when needed

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

EVENING SHIFT

$$\begin{array}{r} \text{STORY PROBLEMS} \\ \hline \text{PRACTICE} \\ \hline \end{array}$$

REMARKS

#1 A.S. PUMP OUT FOR REPAIR

WITH A S PUMPS SHUTTING OFF TEGEETER. SAME PROBLEM WITH P.F.PUMPS

1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD ID	93-03-12-11
DATE	03-12-93

TIME	WELL SYSTEM FLOW				AIR STRIPPER OPERATING PARAMETERS			
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM
11 PM	199	257	199	216	200	1016	1019	10168
12 AM	201	257	196	216	200	1017	1018	10162
1 AM	198	256	201	216	200	1016	1016	10166
2 AM	199	257	201	209	200	1013	1017	10177
3 AM	201	257	200	216	200	1019	1018	10167
4 AM	200	256	199	216	201	1019	1017	10165
5 AM	200	257	198	216	200	1015	1018	10162
6 AM	196	257	202	215	200	1018	1019	10173
7 AM								
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-09-12-12
DATE	3-12-93

WELL FIELD OPERATION

24 HOURS PER DAY

AIR STRIPPER OPERATING PARAMETERS

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESS FIL. FLOW	BLOWER FLOW	NP INCHES SVC	EFFLUENT FLOW MEASUREMENTS	PRESSURE INCHES SVCS	OPERATOR INITIALS
7 AM	198	256	200	213	261	1020	1017	9107.40	✓	485	Nix
8 AM	200	258	202	216	220	1014	1016	9107.40	✓	66	Carter
9 AM	200	257	198	214	200	1013	1034	9813.40	✓	121	Browns
10 AM	199	259	199	213	200	1014	1030	1083.40	✓	184	✓
11 AM	199	258	198	213	201	1014	1025	10590.00	✓	247	✓
12 PM	196	258	200	216	198	1015	1022	10943.00	✓	314	✓
1 PM	198	258	198	213	201	1016	1020	1068	✓	375	✓
2 PM	200	258	196	216	200	1015	1019	1064	✓	437	✓
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-03-12 - 13
TIME	3-12-93

WELL SYSTEM OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FILT. FLOW	AIR FLOW	PRESSURE INCHES WC	EFLUENT FLOW MALS	SUPERVISOR OPERATOR INITIALS
3 PM	200	256	201	213	199	1015	1043	1085	10166.40	491	SCHADLER
4 PM	200	256	198	215	200	1014	1034	1084	10166.40	6.2	C AVALLARO
5 PM	200	256	198	212	200	1012	1028	1080	9389.80		
6 PM	200	258	199	216	200	1015	1023	1075	9389.80	124	
7 PM	201	256	202	214	201	1014	1020	1070	9389.80	189	
8 PM	201	257	197	214	200	1014	1020	1067	9813.40	253	
9 PM	201	258	201	212	200	1015	1019	1062	9389.80	316	
10 PM	200	258	200	216	200	1012	1018	1079	9813.40	380	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	440	

REMARKS

#1 A S Pump out for repair
 Both A.S. Pumps shutting off together. Same problem with 1st pump.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

NIGHT SHIFT

FRIENDS
DATE
93-03-13-11
3-13-93

REMARKS

- 1 A/S PUMP OFF FOR REPAIRS

NOTES

- 1 - THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2 - EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	9.3-03-13-12
DATA	3 - 13 - 2.3

WELL FIELD OPERATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIpper FLOW	PRESSURE FLOW	AIR INFLOW	AIR PRESSURE	EFFLUENT FLOW	SUPERVISOR COMMENTS
	gpm	gpm	gpm	gpm	gpm	gpm	gpm	CFM	inches wc	MGD	INITIALS
7 AM	196	257	201	216	200	1012	1017	1075	78/134°	1	499 N i x
8 AM	200	257	197	216	199	1015	1010	1068	9107. 4°	6.5	Caret
9 AM	197	258	202	212	200	1015	1015	1064	98/19. 4°	12.9	.
10 AM	200	257	200	208	198	1019	1016	1092	10590. 0°	184	.
11 AM	200	258	200	216	200	1018	1019	1081	98/13. 4°	252	.
12 PM	200	257	196	216	201	1016	1017	1074	10166. 4°	311	.
1 PM	200	258	198	214	200	1013	1017	10673	10590. 0°	375	.
2 PM	199	257	201	214	200	1017	1017	1061	10166. 4°	442	.
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE#:	93-03-13-13
DATE:	3-13-93

TIME	WELL FLOW	AIR STRIPPER OPERATING PARAMETERS		EFFLUENT FLOW RATE IN GPM	EFFLUENT FLOW RATE IN CM/H	EFFLUENT FLOW RATE IN INCHES WC	EFFLUENT FLOW RATE IN MM/H					
							STRIPPER FLOW GPM	SURFACE AIR FLOW CM/H				
3 PM	196	257	200	216	200	1013	1016	1040	10590.00	1	505	N/A
4 PM	197	252	197	208	192	993	1057	1067	10590.00	52	CHECK	
5 PM	200	253	200	209	199	1003	1041	1088	9803.42	108		
6 PM	200	252	200	215	200	1013	1029	1079	9813.40	189		
7 PM	196	260	201	217	199	1019	1027	1075	10590.00	237		
8 PM	200	260	201	217	200	1017	1040	1093	10590.00	301		
9 PM	200	259	201	216	200	1022	1040	1069	10943.00	368		
10 PM	200	260	195	218	200	1019	1040	1064	10943.00	428		
AVERAGE	NA	NA	NA	NA	NA	NA						

REMARKS

At 1405 hrs, triadertion wells shut down 1234 and 5
 High water level
 At 1405 hrs, all wells on line

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

TEMP	93.03.4A-11
DATE	3-A-93

TIME	WELL 1 PUMPING RATE		WELL 2 PUMPING RATE		WELL 3 PUMPING RATE		AIR STRIPPER OPERATING PARAMETERS	
	WELL FLOW	GPM	WELL FLOW	GPM	WELL FLOW	GPM	PRESSURE	EFFLUENT
	PSI	PSI	PSI	PSI	PSI	PSI	PSI	PSI
11 PM	200	261	146	217	200	1016	1037	1062
12 AM	200	260	147	217	201	1020	1038	673
1 AM	194	260	200	217	200	1016	1038	10943.00
2 AM	196	260	198	218	200	1023	1038	1077
3 AM	200	260	148	216	200	1015	1038	1068
4 AM	196	260	202	219	200	1019	1038	1071
5 AM	200	260	200	217	200	1022	1038	1062
6 AM	200	260	202	216	200	1014	1037	1060
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

*1 A/S pump out for repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

THE ID	93-03-14-12
DATE	3-14-93

**WELL FIELD OPERATION
 GALLONS PER MINUTE**

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	AIR STRIPPER OPERATING PARAMETERS		
					STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM
7AM	200	260	197	217	200	1039	1050cc
8AM	198	261	202	216	200	1039	1066.40
9AM	201	260	197	217	200	1038	1067
10AM	201	260	201	216	200	1038	10943.00
11AM	198	260	200	216	200	1039	1064
12PM	260	261	198	218	201	1019	1038
1PM	200	262	202	217	200	1034	1038
2PM	198	259	200	217	198	1036	1038
3PM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

BBP	93-03-14 13
B1	3-14-93

AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL FLOW GPM	WELL FLOW GPM	WELL FLOW GPM	WELL FLOW GPM	SYSTEM FLOW GPM	STRIPPER FLOW GPM
3 PM	199	360	203	216	200	1017
4 PM	201	239	197	216	200	1013
5 PM	197	260	197	217	200	1015
6 PM	201	260	201	217	200	1016
7 PM	200	261	197	218	200	1021
8 PM	202	260	197	217	200	1013
9 PM	200	261	200	217	197	1019
10 PM	197	260	200	218	200	1019
11 PM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE #	93-03-13-11
DATE	3-15--1993

TIME	WELL SYSTEM FLOW						AIR STRIPPER OPERATING PARAMETERS			
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	BLOWER AIR FLOW CFM	EFFLUENT FLOW CMH	PRESSURE GAUGE INCHES WC	SUPERVISOR INITIALS
11 PM	200	261	200	216	200	1011	1037	1078	1340.00	WORKING 4/97
12 AM	196	261	196	217	201	1015	1037	1070	10590.00	A 66 DOWNEWS
1 AM	201	261	200	217	199	1014	1037	1068	1813.42	125
2 AM	200	260	198	216	200	1019	1038	1063	10166.40	19
3 AM	200	259	203	216	200	1019	1039	1083	10166.40	248
4 AM	197	260	200	216	200	1017	1036	1073	10166.40	311
5 AM	197	261	200	217	200	1016	1038	1068	10166.40	375
6 AM	197	260	203	216	200	1011	1038	1065	10166.40	444
7 AM										
REVERSE	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-03-15-12
DATE	3-15-93

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESSURE Flow GPM	AIR FLOW CFM	EFFECTIVE PRESSURE INCHES HG	EFFLUENT LEVEL IN FEET	SUPERVISION NOTES
7AM	197	260	195	218	200	1018	1038	1063	9813.40	/	503 CAREK
8AM	200	260	200	216	196	1014	1036	1072	10590.00	/	67 Abram
9AM	200	260	197	216	205	1013	1034	1070	9813.40	/	129
10AM	200	260	198	216	200	1015	1037	1062	10590.00	/	193 ..
11AM	201	260	195	216	200	1015	1038	1059	10943.00	/	256 ..
12PM	197	260	196	217	200	1018	1037	1060	10943.00	/	319 ..
1PM	200	258	200	216	200	1013	1036	1083	10590.00	/	376 ..
2PM	199	260	200	216	200	1012	1037	1075	9813.40	/	440
3PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 EVENING SHIFT

FILED	93-03-15-13
DATE	3-15-93

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW CM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW GAL/SEC	SUPERVISOR INITIALS
3 PM	200	260	202	216	200	1014	1036	1065	10590.00		J C HADLER
4 PM	200	260	200	216	199	1013	1036	1064	10166.40		63
5 PM	200	259	202	216	200	1016	1037	1087	10166.40		121
6 PM	200	259	200	216	199	1014	1037	1073	9813.40		185
7 PM	199	260	202	216	200	1016	1034	1066	9813.40		248
8 PM	200	259	200	216	200	1014	1036	1064	9813.40		312
9 PM	196	260	197	216	200	1010	1037	1060	9813.40		375
10 PM	200	260	197	217	200	1016	1037	1077	9813.40		437
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump out for repair
 Both A.S. pumps shut off together. Same problem with P.F. Pumps.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD ID	Q3-Q3-16-11
DATE	MAR 14, 1993

WELL 1 & 2 INJECTION GALLONS PER MINUTE								A/F STRIPPER OPERATING DATA METERS							
TIME	WELL 1 FLOW GPM	WELL 2 FLOW GPM	WELL 3 FLOW GPM	WELL 4 FLOW GPM	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWDOWN FLOW GPM	EFFLUENT FLOW GPM	EFFLUENT PRESSURE INCHES HG	STRIPPER PRESSURE INCHES HG	EFLUENT FLOW INCHES HG	STRIPPER PRESSURE INCHES HG	EFFLUENT FLOW INCHES HG	STRIPPER PRESSURE INCHES HG	
11 PM	197	261	196	216	200	1016	1038	1072	9813 40	9813 40	9813 40	9813 40	9813 40	9813 40	
12 AM	197	260	200	216	200	1016	1036	1065	9813 40	9813 40	9813 40	9813 40	9813 40	9813 40	
1 AM	196	260	197	216	200	1014	1037	1062	9813 40	9813 40	9813 40	9813 40	9813 40	9813 40	
2 AM	198	260	199	216	201	1013	1031	1051	9813 40	9813 40	9813 40	9813 40	9813 40	9813 40	
3 AM	196	260	197	216	200	1019	1037	1057	9813 40	9813 40	9813 40	9813 40	9813 40	9813 40	
4 AM	260	260	201	217	199	1019	1038	1075	9813 40	9813 40	9813 40	9813 40	9813 40	9813 40	
5 AM	200	260	196	217	260	1017	1037	1070	9813 40	9813 40	9813 40	9813 40	9813 40	9813 40	
6 AM	201	261	196	216	280	1015	1036	1066	9813 40	9813 40	9813 40	9813 40	9813 40	9813 40	
7 AM	AVERAGE								NA	NA	NA	NA	NA	NA	

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	43-03-16-12
DATE	3-16-93

WELL SYSTEM OPERATION GAL/SEC/MINUTE		AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW cm	PRESSURE FLOW cm	AIR FLOW cm	EFFLUENT FLOW INCHES/MIN	SUPERVISOR OPERATOR INITIALS
7 AM	261	259	199	216	200	1012	1036	10166.40	A
8 AM	200	261	197	216	200	1017	1036	10166.40	
9 AM	198	260	199	216	199	1017	1037	10166.40	
10 AM	200	257	197	210	198	1011	648	002	
11 AM	200	256	199	213	200	1012	1034	10166.40	
12 PM	200	260	199	216	200	1016	1028	10166.40	
1 PM	198	254	200	216	20	1015	1025	10166.40	
2 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
3 PM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S Pump out for REPAIRS
 1010 hrs power went off
 1325 hrs power out, well off

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FIELD ID	93-03-16-13
DATE	3-16-93

AFTER STRIPPER OPERATING PARAMETERS									
TIME	WELL 1 Flow	WELL 2 Flow	WELL 4 Flow	WELL 5 Flow	SYSTEM Flow	STRIPPER Flow GPM	AIR PRESSURE PSI	AIR FLOW CFM	EFFLUENT FLOW GPM
3 PM									
4 PM									
5 PM									
6 PM									
7 PM									
8 PM									
9 PM									
10 PM									
11 PM									
AVERAGES	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

15:00 - PLANT Down DUE TO INTERRUPTION OF Power By L.L.C.


NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE #	93-03-17-11
DATE	MAP 17, 1993



REMARKS PLANT DOWN DUE TO INTERFUSION OF PUMP

OF PUMP BY LILCO

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD ID	93-03-13-13
DATE	3-17-93

TIME	WELL 1 OPERATION		WELL 2 OPERATION		STRIPPER SYSTEM		AIR STRIPPER		OPERATING PARAMETERS		
	WELL 1 FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 2 FLOW	STRIPPER SYSTEM FLOW	STRIPPER SYSTEM FLOW	PRESSURE LOW	FLOW LOW CMH	FLOW HIGH CMH	EFFLUENT PRESSURE INCHES WC	FLOW MEAS
7 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
8 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
9 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
10 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
11 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
12 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
1 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
2 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
3 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

Plant down due to power interruption by LCCC

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

REF ID:	93-03-17-13
DATE:	3-17-93

AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE	EFFLUENT FLOW	SUPERVISOR COMMENTS
	(GPM)	(GPM)	(GPM)	(GPM)	(GPM)	(GPM)	(PSI)	(GPM)	OPERATOR INITIALS
3 PM									SCHADLER
4 PM									C AVALLARO
5 PM									
6 PM									
7 PM									
8 PM									
9 PM									
10 PM									
11 PM									
DAVIS/REED	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

Plant down due to power interruption by LECO.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

THE 10	93 - 03 - 18-11
DAY	3 - 18 - 93

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW gpm	PRESSURE FLOW gpm	BLOWER PRESSURE INCHES HG
1 AM							
2 AM							
3 AM							
4 AM							
5 AM							
6 AM							
7 AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

Plant down due to pump motor burnout 3/12/00

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE#	93-18-93-12
DATE	3-18-93

AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER PRESSURE	EFFLUENT AIR FLOW	EFFLUENT PRESSURE
	gpm	gpm	gpm	psi	cfm	inches w.c.
7 AM						
8 AM						
9 AM						
10 AM						
11 AM						
12 PM						
1 PM						
2 PM						
3 PM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

Plant down due to power interruption by LCO

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE ID:	93-03-18-13
DATE:	3-18-93

TIME	WELL FLOW					WELL FLOW					WELL FLOW					AIR STRIPPER OPERATING PARAMETERS						
	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWER FLOW	AIR FLOW	PRESSURE FLOW	EFFLUENT FLOW	NOTES	INCHES W.C.	FEET W.C.	PRESSURE FLOW	EFFLUENT FLOW	NOTES	INCHES W.C.	FEET W.C.	PRESSURE FLOW	EFFLUENT FLOW				
3 PM	0 FF																					
4 PM	199	244	200	202	199	986	1040	1091	9813.40													
5 PM	202	256	200	209	198	999	1029	1087	9813.40													
6 PM	200	250	200	208	201	1001	1016	1080	9813.40													
7 PM	200	254	201	212	200	1009	1010	1071	10166.40													
8 PM	200	256	197	216	200	1014	1014	1065	10166.40													
9 PM	200	256	200	216	200	1019	1018	1057	9813.40													
10 PM	201	256	201	214	200	1019	1019	1075	9813.40													
11 PM																						
	AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

15:00: PLANT DOWN. P.C.I. WORKING ON WELLS.

15:20 PLANT ON LINE

#1 A.S. PLUMBED FOR REPAIR

16:30 PLANT DOWN WHILE P.C.I. WORKS ON PANEL

17:00 PLANT BACK ON LINE

18:00 P.C.I. SERVICED OFF SITE

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE#	93-03-19-11
DATE	3-14-93

DAILY OPERATIONS WORKSHEET									
WELL STRIPPER OPERATING PARAMETERS									
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow gpm	BLOWERS Air flow cfm	EFFLUENT PRESSURE Gauge Inc.
11:30	201	258	199	215	200	1019	1068	10166.40	4/34
12 AM	200	257	199	216	200	1022	1067	10166.40	64
1 AM	196	257	202	216	200	1023	1065	10166.40	Doc. #615
2 AM	200	258	196	216	200	1019	1084	10166.40	135
3 AM	200	257	197	216	200	1022	1016	10166.40	186
4 AM	202	258	198	216	200	1019	1068	9389.80	251
5 AM	200	259	198	216	200	1023	1016	10166.40	318
6 AM	200	257	201	215	200	1020	1015	9389.80	379
7 AM									4/39
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	93-03-19-12
	3 - 19 - 93

WELL 11 OPERATION DATA FOR MINUTE			AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 11 FLOW	WELL 3 FLOW	WELL 3 SYSTEM FLOW	STRIPPER FLOW CMH	PRESSURE FLOW CMH	EFFLUENT FLOW CMH	SUPERVISOR INITIALS	
7 AM	200	258	201	215	200	1015	1077	499
8 AM	200	256	201	216	200	1022	1068	67 Capet
9 AM	200	258	200	214	200	1018	1065	129
10 AM	200	257	204	214	199	1017	1060	193
11 AM	200	258	198	214	200	1022	1015	250
12 PM	200	258	196	212	200	1016	1041	1089
1 PM	196	257	196	211	200	1015	1033	1086
2 PM	199	258	202	216	200	1018	1027	9813.40
3 PM								434
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

Plant Shut down @ 1410 hrs on Power to Compressor plant.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-03-19-13
DATE	3-19-93

TIME	WELL FIELD OPERATION DATA'S PER MINUTE			AIR STRIPPER OPERATING PARAMETERS		
	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE AIR FLOW
	GPM	LPM	MLM	GPM	CFM	PSI
3 PM	OFF					
4 PM	200	248	200	204	200	10390.00
5 PM	200	253	200	212	200	10390.00
6 PM	200	256	198	216	201	10390.00
7 PM	200	259	198	216	201	10390.00
8 PM	200	257	201	216	200	10390.00
9 PM	200	258	197	216	200	10390.00
10 PM	196	259	199	216	200	10390.00
11 PM						
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

15:00 PLANT Down. Line working on power lines,
 15:30 - PLANT ON LINE
 #1 A.S. Pump out for repair
 BOTH A.S. Pumps shutting off together. SAME PROBLEM WITH P.F. PUMPS.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	93-03-20-11
DATE	3-20-93

TIME	WELL SYSTEM OPERATION			AIR STRIPPER OPERATING PARAMETERS		
	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	AIR FLOW	EFFLUENT FLOW
	GPM	GPM	GPM	GPM	CFM	GPM
1 PM	200	260	197	216	199	1017
2 AM	201	260	201	216	200	1016
3 AM	200	258	200	216	200	1017
4 AM	200	260	200	216	200	1017
5 AM	198	260	199	216	200	1015
6 AM	200	260	202	216	200	1019
7 AM	201	260	195	216	200	1013
AVERAGE	NA	NA	NA	NA	NA	NA

REMARKS

1 A S. PUMP OUT FOR REPAIRS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	9:30 - 03 - 2012
DATE	3 - 20 - 93

WELL 1 & 2 OPERATION
 ACTIVATION

ABR STRIPPER OPERATING PARAMETERS

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 1 FLOW	WELL 2 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW PSI	EFFLUENT PRESSURE INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR OPERATOR INITIALS
7 AM	200	160	208	217	200	1012	1019	1075	10166.40	A
8 AM	196	260	195	217	200	1021	1018	1065	10166.40	CAC/5
9 AM	200	240	202	216	196	1016	1018	1064	10166.40	128
10 AM	200	260	198	216	200	1019	1018	1063	10590.00	
11 AM	200	200	203	216	200	1020	1018	1082	10166.40	190
12 PM	200	200	201	217	199	1018	1020	1076	10166.40	313
1 PM	200	200	195	217	199	1017	1020	1071	10590.00	377
2 PM	200	260	198	216	200	1015	1019	1074	10590.00	Y
3 PM										
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-03-20-13
TIME	3 - 20 - 93

WELL PUMP OPERATION DATA						AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow GPM	PRESSURE FLOW CFM	BLOWER Air Flow CFM	AIR PRESSURE INCHES HG	EFFLUENT Flow GPM	SUPERVISOR Operator Initials
3 PM	201	260	202	217	200	1015	1019	1063	98/3.40	↑	503 NJ; x
4 PM	196	222	200	217	200	1021	1019	1062	98/3.40		63 Cap. F
5 PM	202	262	198	218	200	1018	1019	1082	10166.40		121 ,
6 PM	199	260	201	217	201	1014	1018	1075	98/3.40		187 ,
7 PM	199	260	200	217	201	1019	1019	1070	10596.00		249 ,
8 PM	200	260	196	217	200	1015	1018	1060	98/3.40		313 ,
9 PM	197	261	199	216	200	1015	1018	1059	1059.00		377 ,
10 PM	199	258	198	216	199	1016	1018	1060	1059.00	↓	438 ,
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD ID	93-03-21-11
DATE	3-21-93

WELL STRIPPER OPERATING PARAMETERS									
TIME	WELL FLOW GPM	WELL FLOW GPM	SYSTEM FLOW GPM	STRIPPER FLOW GPM	PRESSURE IN PSI	EFFLUENT FLOW GPM	EFFLUENT PRESSURE IN PSI	STRIpper OPEN VALVE	STRIpper OPEN VALVE
11 PM	196	260	199	216	200	1020	1060	10540.00	No
12 AM	197	260	200	218	200	1020	1019	10166.40	Working
1 AM	199	260	200	216	200	1018	1020	10166.40	
2 AM	200	260	200	216	200	1023	1020	10177	
3 AM	198	260	195	217	200	1017	1017	10166.40	
4 AM	196	261	202	217	200	1020	1019	10166.7	
5 AM	200	260	197	216	200	1019	1019	10166.40	
6 AM	198	261	201	216	200	1021	1019	10166.40	
7 AM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

- ☒ 1 A/s Pump out for Repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD DATE	93-3-21-12
	3 - 21 - 93

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	AIR STRIPPER OPERATING PARAMETERS		EFFLUENT FLOW INCHES MC MILS
					PRESSURE FLOW cm	AIR FLOW cm	
7 AM	200	260	200	1017	1018	1019	1016.40
8 AM	200	260	200	1017	1018	1019	1016.40
9 AM	201	260	200	216	1014	1018	1016.40
10 AM	201	260	196	216	200	1018	1016.40
11 AM	198	260	201	216	200	1016	1016.40
12 PM	196	261	201	216	200	1021	1020
1 PM	199	261	198	217	200	1022	1019
2 PM	200	260	199	218	201	1024	1020
3 PM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILE #	93-09-21-13
BAL.	3 - 21 - 93

TIME	WELL FLOW			WELL FLOW			WELL FLOW			WELL FLOW			WELL FLOW			AIR STRIPPER OPERATING PARAMETERS			WELL FLOW			AIR STRIPPER OPERATING PARAMETERS			
	WELL 1	WELL 2	WELL 3	WELL 4	WELL 5	WELL 6	WELL 7	WELL 8	WELL 9	WELL 10	WELL 11	WELL 12	WELL 13	WELL 14	EFFLUENT FLOW INCHES WG	SUPPLY AIR PRESSURE INCHES WG	AIR FLOW CFM	STRIPPER FLOW CFM	SUPPLY AIR PRESSURE INCHES WG	STRIPPER FLOW CFM	SUPPLY AIR PRESSURE INCHES WG	STRIPPER FLOW CFM	SUPPLY AIR PRESSURE INCHES WG	STRIPPER FLOW CFM	SUPPLY AIR PRESSURE INCHES WG
3 PM	199	260	201	216	200	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020
4 PM	199	260	201	217	201	1016	1019	1065	1065	1065	1065	1065	1065	1065	1065	1065	1065	1065	1065	1065	1065	1065	1065	1065	1065
5 PM	202	201	197	216	200	1017	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020
6 PM	199	260	197	216	200	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019	1019
7 PM	200	260	200	216	200	1020	1018	1059	1059	1059	1059	1059	1059	1059	1059	1059	1059	1059	1059	1059	1059	1059	1059	1059	1059
8 PM	198	260	200	216	201	1023	1018	1055	1055	1055	1055	1055	1055	1055	1055	1055	1055	1055	1055	1055	1055	1055	1055	1055	1055
9 PM	200	260	201	216	198	1021	1018	1084	1084	1084	1084	1084	1084	1084	1084	1084	1084	1084	1084	1084	1084	1084	1084	1084	1084
10 PM	198	260	202	216	200	1019	1019	1092	1092	1092	1092	1092	1092	1092	1092	1092	1092	1092	1092	1092	1092	1092	1092	1092	1092
11 PM																									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 NIGHT SHIFT

FILED	93-03-32-11
DATE	3-22-93

TIME	WELL PUMP DATA				AIR STRIPPER OPERATING PARAMETERS				SUPERVISOR OPEN FOR NOTES
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWDOWN AIR FLOW CFM	AIR PRESSURE INCHES WC	
11 PM	201	260	202	216	200	1022	1019	1070	98/3.40
12 AM	199	262	197	216	200	1019	1018	1066	9389.80
1 AM	199	261	200	218	200	1022	1018	1060	9389.80
2 AM	200	261	199	216	200	1016	1018	1061	9389.80
3 AM	201	261	197	217	200	1019	1016	1077	98/3.40
4 AM	200	260	200	216	200	1017	1018	1071	9389.80
5 AM	200	261	200	216	200	1019	1018	1066	98/3.40
6 AM	197	261	202	216	260	1023	1017	1063	98/3.40
7 AM									44/4
	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump out for Repair.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	93-03-22-12
DATE	3-22-93

TIME	WELL FLOW	WELL FLOW	WELL FLOW	AIR STRIPPER OPERATING PARAMETERS		EFFLUENT FLOW	EFFLUENT FLOW	SUPERVISION
				STRIPPER FLOW	PRESSURE FLOW			
7 AM	199	259	203	216	194	1022	1018	1061
8 AM	199	261	200	216	200	1017	1018	1066
9 AM	200	260	194	216	200	1020	1017	1066
10 AM	200	260	199	216	200	1024	1017	1066
11 AM	198	260	197	216	201	1021	1018	1063
12 PM	200	260	199	216	201	1023	1019	1063
1 PM	196	259	198	212	200	1017	1050	1091
2 PM	196	259	202	212	200	1019	1037	1089
3 PM								
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 H/s pump out for repairs
 RTP Arrived at 1100 to set up equipment for
 Air Stack testing
 1230 power surge again

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

TIME	93-03-22-	13
DATE	3-22-93	

TIME	WELL SYSTEM OPERATION		AIR STRIPPER OPERATING PARAMETERS		SUPERVISOR OPERATOR NOTES				
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	STRIPPER Flow GPM	PRESSURE FLOW GPM	BLOWER Air Flow CFM	EFFLUENT Flow inches WC	
3 PM	200	259	201	216	199	1023	1084	9813.40	Dales
4 PM	200	260	202	216	200	1024	1026	9813.40	Acott
5 PM	201	260	200	216	200	1023	1022	10166.40	Work
6 PM	199	260	201	215	199	1021	1021	9813.40	
7 PM	197	260	200	217	200	1023	1020	1067	9813.40
8 PM	200	260	201	216	200	1024	1021	1065	9389.80
9 PM	198	260	201	216	199	1023	1020	1080	9813.40
10 PM	200	260	200	216	200	1024	1019	1079	9813.40
11 PM									440
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. pump out for repair
 BOTH A.S. PUMPS SHUTTING OFF TOGETHER. SAME PROBLEM WITH P.F. PUMPS
 R.T.P. SETTING UP EQUIPMENT FOR AIR STACK TESTING

NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND
 PRESSURE FILTER FLOW MUST BE EQUAL WITHIN
 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW
 THROUGH THE FACILITY. OPERATOR SHALL
 RESET THE GAUGE TO ZERO AT THE BEGINNING
 OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

THEID	93-03-23-11
DATE	MAR 23, 1993

DAILY OPERATING PARAMETERS							
TIME	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	STRIPPER Flow GPM	PRESSURE Flow GPM	BLOWDOWN Flow GPM	EFFLUENT Flow GPM
11 PM	199	260	202	216	200	1020	1013
12 AM	200	262	202	217	200	1021	1015
1 AM	200	262	197	216	200	1020	1019
2 AM	200	262	196	216	200	1020	1019
3 AM	199	261	199	218	200	1022	1018
4 AM	200	261	200	217	200	1025	1016
5 AM	200	260	202	216	201	1026	1018
6 AM	201	260	200	216	200	1026	1017
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	93-3-23-12
DATE	3-23-93

TIME	WELL & STRIPPER OPERATION							AIR STRIPPER OPERATING PARAMETERS			
	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	STRIPPER FLOW	STRIPPER FLOW	AIR FLOW	EFFECTIVE AIR FLOW	PRESSURE	EFFLUENT FLOW	SUPERVISOR
	GPM	GPM	GPM	GPM	GPM	GPM	GPM	INCHES WC	INCHES WC	NOTES	
7 AM	200	260	203	216	200	1025	1017	1062	9384.80	NOT	503
8 AM	199	260	198	217	198	1023	1017	1050	9833.90	WORKING	62
9 AM	200	261	201	217	200	1020	1017	1053	9813.40		126
10 AM	200	261	197	216	200	1023	1016	1079	9107.40		185
11 AM	201	261	196	216	200	1023	1012	1070	8472.00		248
12 PM	196	262	195	217	200	1021	1018	1066	9813.40		314
1 PM	199	260	201	216	200	1027	1017	1065	9813.40		374
2 PM	201	260	202	216	200	1019	1017	1062	9813.40	Y	439
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

* 1 A/s Pump out for Repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

FILED	93-03-23-13
DATE	3-23-93

AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE F.L. CM	EFFLUENT F.L. INCHES WC	SUPERVISOR OPERATOR INITIALS
3 PM	201	260	200	216	198	1031	1017	1083	981340 NOT WORKING
4 PM	201	261	200	216	199	1021	1017	1075	10166.40
5 PM	198	261	196	214	200	1017	1017	1069	981340
6 PM	199	260	200	216	200	1022	1017	1066	9389.80
7 PM	198	260	198	217	200	1020	1017	1063	9389.80
8 PM	197	262	196	217	200	1019	1017	1081	9389.80
9 PM	200	260	200	216	196	1021	1017	1074	981340
10 PM	201	261	196	216	200	1024	1017	1068	9389.80
11 PM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump out for repair
 BOTH A.S. Pumps shutting off together. Same problem with P.F. Pump.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED	93-03-24-11
DATE	3-24-93

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL FLOW	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	AIR FLOW
	GPM	GPM	GPM	GPM	GPM	GPM	CFM
1 PM	200	263	200	216	200	1016	1017
12 AM	199	260	201	217	200	1024	1017
1 AM	201	261	200	217	200	1025	1018
2 AM	200	260	200	217	198	1026	1019
3 AM	200	261	200	217	200	1022	1018
4 AM	201	261	200	216	200	1023	1018
5 AM	198	266	198	218	200	1019	1018
6 AM	200	260	198	216	194	1023	1019
7 AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-03-2A-12
BILL	3-2A-93

TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	AIR STRIPPER OPERATING PARAMETERS				SUPERVISOR INITIALS
					SYSTEM FLOW	STRIPPER FLOW	PRESSURE	AIR FLOW	
7 AM	200	200	200	200	1024	1018	1062	9813.40	NOT 505
8 AM	197	200	200	200	1020	1017	1010	10166.40	WORKING 60
9 AM	197	200	204	216	1022	1017	1013	10166.40	ABRAMS
10 AM	200	200	216	200	1020	1016	1010	9813.40	104
11 AM	199	200	200	216	1023	1017	1064	9813.40	248
12 PM	200	200	196	216	200	1024	1016	1062	9813.40
1 PM	196	200	200	216	201	1018	1016	1061	9813.40
2 PM	201	200	200	216	200	1021	1017	1075	9813.40
3 PM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

* 1 a/s pump out for repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-03-24-13
	3-24-93

WELL FIELD DROPPED FLOW PER MINUTE

TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	EFFLUENT FLOW CFM	EFFECTIVE FLOW CFM	NOTES	SUPERVISOR	OPERATOR	NOTES	
3 PM	200	260	196	216	800	1022	1016	1073	9813.40	1007	496	SCHADLER			
4 PM	196	261	198	217	800	1024	1017	1065	9813.40	1007	496	CIVALLARO	63		
5 PM	196	261	197	216	800	1021	1017	1064	9389.80	1007	496			/26	
6 PM	193	260	199	216	800	1019	1014	1061	9384.80	1007	496			188	
7 PM	200	260	199	216	800	1022	1024	1017	1060	10166.40	1007	496			254
8 PM	200	260	200	216	800	1021	1016	1017	1056	10166.40	1007	496			315
9 PM	200	262	197	216	800	1022	1017	1080	10166.40	1007	496				375
10 PM	200	261	198	216	800	1022	1017	1072	10166.40	1007	496				438
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump out for REPAIR
 BOTH A.S. pumps shutting off together. Same problem with P.F. Pumps

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

3/25/93

93-03-25-11	93-03-25-93
-------------	-------------

TIME	AIR STRIPPER OPERATING PARAMETERS						SUPERVISOR OPERATOR NOTES
	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW gpm	EFFLUENT FLOW gpm	
11:30	201	261	199	216	200	1025	1016
12:AM	200	261	197	216	200	1023	1018
1:AM	200	264	200	217	200	1021	1018
2:AM	194	269	199	216	200	1025	1019
3:AM	200	260	196	216	196	1026	1017
4:AM	201	262	202	217	201	1021	1017
5:AM	200	261	200	216	201	1016	1018
6:AM	196	264	200	217	200	1018	1016
7:AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-03-25-1
DATE	3-25-93

WELL 1, 2 & 3 TREATMENT

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	AIR FLOW CM ³ /SEC	PRESSURE INCHES HG
7 AM	200	264	198	214	200	1017	1016
8 AM	200	261	197	216	200	1025	1015
9 AM	200	260	201	216	200	1022	1017
10 AM	197	261	201	216	200	1023	1016
11 AM	200	269	198	216	197	1024	1016
12 PM	200	263	196	217	201	1023	1016
1 PM	199	264	196	216	198	1014	1017
2 PM	199	259	200	216	199	1023	1017
3 PM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

R.T.P. / people testing on air stack.
 R.T.P. starting testing at 10:15.
 Meter reading every 10 min

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 EVENING SHIFT

FIELD	93-03-25-18
DATE	03-25-93

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW	BLOWER FLOW CFM	AIR FLOW CFM	PRESSURE Gauge INCHES HG	EFFLUENT FLOW GPM	SUPERVISOR/ OPERATOR INITIALS
3 PM	197	260	198	217	261	1022	1017	1076	10166.40	0	507
4 PM	200	260	196	217	209	1020	1018	1066	9813.40	0	58
5 PM	201	260	202	217	199	1017	1016	1066	9813.40	0	120
6 PM	196	262	202	216	200	1024	1018	1059	9813.40	0	
7 PM	201	261	196	216	200	1019	1016	1079	9813.40	0	180
8 PM	200	261	200	216	200	1023	1016	1072	9813.40	0	244
9 PM	197	261	200	216	200	1021	1016	1070	10166.40	0	367
10 PM	200	264	196	216	202	1025	1019	1067	10166.40	0	431
11 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FUELS	93-03-26-61
SEAL	3-26-73

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW gpm	EFFLUENT AIR FLOW cfm	PRESSURE INCHES HG
11 PM	260	198	216	202	1028	1018	10166.40 working
12 AM	260	198	216	203	1023	1017	9389.80
1 AM	199	264	202	217	200	1024	1074
2 AM	201	264	198	218	201	1018	10166.40
3 AM	200	259	199	219	200	1020	1018
4 AM	200	262	204	217	200	1024	1017
5 AM	199	262	201	217	200	1026	1018
6 AM	201	258	199	216	200	1025	1017
7 AM							
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S PUMP OUT FOR REPAIRS

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FILE #	93-03-26-12
DATE	3-26-93

WELL FLOW INFORMATION							AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	BLOWER FLOW	AIR FLOW	PRESSURE GAUGE	EFFLUENT FLOW	NOTES
	gpm	gpm	gpm	gpm	gpm	psi	cfm	scfm	psi	gpm	
7 AM	263	264	199	216	200	1022	1017	1080	10166.40	NEW Gauge	496
8 AM	200	261	200	217	201	1020	1017	1072	10166.40		65
9 AM	196	264	198	216	201	1018	1016	1068	10166.40		128
10 AM	202	261	196	216	200	1020	1016	1065	10526.00		191
11 AM	201	263	198	216	199	1023	1017	103	10526.00		249
12 PM	201	263	196	216	194	1021	1017	1072	10166.40		315
1 PM	200	264	197	216	196	1022	1017	1071	1013.40		376
2 PM	200	262	202	216	200	1021	1016	1067	9813.40		
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

REMARKS

#1 A/S pump out for repairs
 R.T.P on site at 1330 to clean-up

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 EVENING SHIFT

DATE	93-03-26-13
	3-26-93

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL FIELD OPERATION						AIR STRIPPER OPERATING PARAMETERS				
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW (GPM)	PRESSURE FILTER FLOW (GPM)	BLOWDOWN AIR FLOW (CFM)	INLET PRESSURE (INCHES HG)	EFFLUENT FLOW (MGD)	SUPERVISOR/OPERATOR INITIALS
3 PM	198	264	196	216	200	1020	1016	106A	9813.40	NOT	503 SCHADLER
4 PM	200	264	196	216	200	1023	1018	682	9813.40	WORKING	60 FAUCIANDO
5 PM	200	254	198	216	200	1023	1018	1077	10166.40		
6 PM	200	258	197	216	197	1023	1015	1067	9813.40		122
7 PM	201	262	200	216	199	1017	1017	1067	9813.40		
8 PM	201	261	196	216	198	1022	1017	1063	9813.40		186
9 PM	198	264	196	217	197	1021	1017	1061	9813.40		249
10 PM	197	264	198	216	200	1024	1016	1059	9389.80	Y	316
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

* 1 A/s pump out for repairs

Fauciando due est has O.T.

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

NIGHT SHIFT

93-03-27-11
3-27-43

REMARKS

REMARKS *1 A/s Pump out for Repairs

NOTES

- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.**

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

DATE	93-03-27-12
TIME	3 - 27 - 93

TIME	WELL SYSTEM OPERATION					AIR STRIPPER OPERATING PARAMETERS					NOTES 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%. 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.
	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	WELL 5 Flow	STRIPPER flow gpm	SYSTEM flow gpm	STRIpper flow gpm	AIR flow gpm	PRESSURE inches w.c.	
7 AM	200	244	198	217	200	1022	1016	1061	1061	10590.00	Not Working
8 AM	199	244	202	216	200	1021	1018	1062	1062	10590.00	66 Capek
9 AM	196	259	200	216	198	1025	1019	1078	1078	1066.40	121
10 AM	200	240	201	216	201	1022	1017	1072	1072	10590.00	184
11 AM	197	259	199	214	200	1015	1016	1067	1067	1066.40	253
12 PM	202	259	199	217	200	1018	1018	1065	1065	1066.40	314
1 PM	195	261	200	216	201	1019	1030	1088	1088	10590.00	320
2 PM	200	264	196	216	200	1023	1027	1080	1080	1066.40	434
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

ITEM #	93-03-27-18
ITEM #	93 - 22 - 93

WELL FIELD OPERATION
 GALLONS PER MINUTE

TIME	WELL FLOW	WELL FLOW	WELL 3 FLOW	WELL 2 FLOW	WELL 1 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FILTER FLOW GPM	AIR FLOW CFM	AIR PRESSURE PSIG	EFFLUENT FLOW GPM	EFFLUENT PRESSURE PSIG	SUPERVISOR SIGNATURE	OPERATOR SIGNATURE
3 PM	200	261	200	216	200	1025	1022	1074	NA	NA	10166.40	500	Nix	
4 PM	200	258	197	217	200	1022	1020	1071	NA	NA	10590.00	63	Capek	
5 PM	200	259	197	216	200	1025	1018	1067	NA	NA	1059.00	126		
6 PM	198	259	196	216	199	1026	1017	1066	NA	NA	1066.40	188		
7 PM	200	261	199	214	200	1019	1017	1062	NA	NA	10590.00	250		
8 PM	196	264	197	216	202	1019	1017	1025	NA	NA	10166.40	311		
9 PM	201	260	201	216	200	1025	1018	1073	NA	NA	9813.40	376		
10 PM	198	261	200	216	199	1025	1017	1068	NA	NA	10166.40	442		
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FIELD DATA	93-03-28-13
	3-28-93

TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	EFFLUENT AIR FLOW	EFFLUENT PRESSURE GAUGE	EFFLUENT FLOW GAUGE	AFTER STRIPPER FILTER RATES		
									MINUTES	CAL/SEC	
1 PM	199	263	200	216	200	1022	1018	1065	10166.40	NOT	501
2 AM	201	264	200	216	200	1019	1017	1062	9813.40	WORKING	62
1 AM	200	264	200	216	200	1026	1017	1078	9813.40		124
2 AM	201	264	200	216	201	1024	1018	1074	10166.40		186
3 AM	200	262	196	216	200	1025	1018	1068	9813.40		250
4 AM	200	264	201	217	200	1021	1018	1067	9813.40		215
5 AM	201	261	195	217	200	1023	1018	1064	11649.00		376
6 AM	200	259	197	216	196	1028	1018	1062	10843.00	✓	441
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

* 1 A/S PUMP OUT FOR REPAIRS
 1150 hrs "DAVE" from E.T. (alled) - OPEN GATE FOR him.
 1330 hrs E.T. OFF SITE

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

Effluent	93 - 03 - 28	12
Flow	3 - 28 - 93	
Total		

WELL FIELD OPERATION

GALLONS PER MINUTE

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW CM	BLOWDOWN FLOW CM	AIR PRESSURE INCHES WC	EFFLUENT FLOW GAL/min	STRIPPER OPERATOR INITIALS
7 AM	201	360	197	216	201	1025	1017	1060	10943.0	40700.00	503 AJ, Y
8 AM	197	260	200	217	199	1030	1017	1077	10166.40	1	57 Capet
9 AM	197	264	203	216	201	1024	1015	1070	10166.40		123 ..
10 AM	200	264	197	216	200	1027	1016	1068	10590.00		186 ..
11 AM	198	261	201	216	200	1020	1017	1062	10590.00		252 ..
12 PM	201	260	201	216	197	1022	1017	10670	10166.40		314 ..
1 PM	200	262	200	216	200	1019	1018	1080	10166.40		373 ..
2 PM	200	262	197	216	200	1025	1019	1074	10590.00		432 ..
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 EVENING SHIFT

DATE	93-03-28-13
BHR	3 - 28 - 93

WELL HEAD OPERATION

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FL. PSI	PUMP HEAD INCHES WC	EFFLUENT PRESSURE PSI	SUPERVISOR INITIALS
3 PM	196	264	200	216	201	1026	1018	1069	10590.00	Not Working.	500 Nit
4 PM	199	258	198	216	200	1025	1017	1066	10166.40	↑	61 Capet
5 PM	199	264	196	216	200	1029	1018	1062	10590.00	↓	128 .
6 PM	199	264	202	216	200	1025	1018	1080	10590.00	↓	188 .
7 PM	199	260	201	216	198	1028	1018	1074	10590.00	↓	250 .
8 PM	200	262	196	216	198	1025	1017	1068	10166.40	↓	315 .
9 PM	199	264	200	214	200	1025	1016	1066	10590.00	↓	377 .
10 PM	201	264	196	217	200	1023	1018	1064	10590.00	↓	438 .
AVERAGE	NA	NA	NA	NA	NA						

REMARKS

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

NOTES

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILED:	93-03-29-11
DATE:	3-29-93

TIME	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	PRESSURE FLOW	EFFLUENT FLOW	FILTER PRESSURE	OPERATING FILTERS	SUPERVISOR SIGNATURE	SUPERVISOR DATE
11 PM	200	264	202	216	200	1026	1017	1060	10340.00	LL OYP
12 AM	197	264	202	216	200	1022	1016	1071	10541.00	L1 FLACCIA
1 AM	200	264	199	216	201	1026	1018	1080	10443.00	.122
2 AM	200	264	198	216	200	1027	1018	1073	10590.00	107
3 AM	199	264	198	216	201	1026	1018	1066	10540.00	250
4 AM	199	263	200	217	200	1024	1018	1065	10166.40	309
5 AM	200	264	202	217	200	1023	1018	1066	10166.40	372
6 AM	198	264	198	217	201	1021	1017	1079	10166.40	438
7 AM										
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

FIELD ID	93-03-29-13
DATE	3-29-93

TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	AIR STRIPPER OPERATING PARAMETERS				SUPERVISOR INITIALS
					SYSTEM FLOW	STRIPPER FLOW	PRESSURE	EFFLUENT FLOW	
7 AM	200	260	202	216	200	1024	1015	1073	ACIADO
8 AM	201	263	196	214	199	1021	1017	1061	EMBRALE
9 AM	200	254	196	216	200	1021	1016	1062	
10 AM	201	261	201	216	200	1021	1017	1073	
11 AM	197	264	200	216	200	1024	1016	1072	
12 PM	200	261	196	216	200	1025	1017	1073	
1 PM	199	264	176	214	200	1020	1016	1066	
2 PM	198	257	198	215	200	1026	1017	1065	
3 PM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A/S pump out for repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 EVENING SHIFT

DATE	93-03-29-13
	3-29-93

WELL SYSTEM OPERATION DATA

AIR STRIPPER OPERATING PARAMETERS							
	WELL FLOW RATE	WELL FLOW RATE	WELL FLOW RATE	SYSTEM FLOW	STRIPPER FLOW	AIR FLOW	EFFLUENT FLOW
	GPM	CFM	LPM	CFM	CFM	CFM	INCHES W.C.
3 PM	198	264	196	216	200	1022	1017
4 PM	200	262	200	217	199	1024	1017
5 PM	200	262	197	216	200	1022	1017
6 PM	200	262	196	216	200	1020	1015
7 PM	201	260	201	216	200	1024	1016
8 PM	199	263	201	216	199	1024	1015
9 PM	201	261	200	215	199	1022	1016
10 PM	201	264	196	216	200	1021	1017
AVERAGE	NA	NA	NA	NA	NA	NA	NA
11 PM	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S.Pump out for repair
 BOTH A.S.Pumps shutting off together. Same problem with P.F. Pump

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FILE #	93-03-30-11
DATE	3-30-93

WELL FLOW AND WATER NITRATE

	WELL 1 Flow	WELL 2 Flow	WELL 3 Flow	WELL 4 Flow	SYSTEM Flow	STRIPPER Flow	PRESSURE Flow cmHg	EFFLUENT Flow cmHg	AIR PRESSURE INCHES HG	SUPERVISOR 6-22	SUPERVISOR 6-23
11 PM	200	260	201	216	200	1023	1018	1074	10166.40	497	LLOYD
12 AM	200	260	198	216	200	1020	1016	1069	981.340	64	C AVALLARO
1 AM	200	264	197	216	200	1023	1017	1065	10166.40	127	
2 AM	198	264	200	216	198	1021	1017	1084	10166.40	188	
3 AM	200	262	199	216	200	1022	1017	1077	10166.40	250	
4 AM	198	264	203	216	200	1026	1018	1073	10166.40	313	
5 AM	198	262	201	215	200	1023	1018	1068	10590.00	376	
6 AM	200	262	200	216	202	1028	1016	1064	10590.00	443	
7 AM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

#1 A.S. pump out for repair

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
 DAY SHIFT

TIME	3/30/93
DATE	

TIME	WELL FLOW & OPERATION DATA (GALLONS PER MINUTE)						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	SYSTEM FLOW	STRIPPER FLOW LPM	PRESSURE FLOW PSI	AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW LPM	EFFECTIVE FACILITY CAPACITY LPM	SUPERVISOR INITIALS
7 AM	201	258	200	215	200	1021	1017	1062	10166.40	500	500	FALLAWO
8 AM	200	262	202	215	201	1025	1017	1084	10166.40	61	61	CENBRAE
9 AM	201	260	203	216	200	1026	1016	1075	10166.40	126	126	
10 AM	200	260	196	216	200	1027	1015	1070	10540.00	187	187	
11 AM	200	261	202	210	200	1026	1016	1065	10590.00	205	205	
12 PM	200	261	200	214	201	1024	1015	676	10166.40	314	314	
1 PM	200	261	201	214	196	1029	1017	1059	10166.40	375	375	
2 PM	196	263	200	216	197	1021	1017	1071	10166.40	440	440	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

* 1 A/S Pump out for repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
EVENING SHIFT

DATE	93-03-30 - 13
TIME	3-30-93

AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL FLOW		SYSTEM FLOW		STRIPPER FLOW		EFFLUENT PRESSURE INCHES HG
	WELL	WELL	WELL	WELL	STRIPPER	BLLOWED	
	GPM	GPM	GPM	GPM	GPM	GPM	
3 PM	201	261	196	215	199	1022	1016
4 PM	201	261	196	215	200	1024	1016
5 PM	196	264	200	216	201	1026	1018
6 PM	201	259	200	216	200	1026	1016
7 PM	200	261	197	215	200	1024	1016
8 PM	199	262	201	215	198	1025	1015
9 PM	201	262	200	216	199	1026	1017
10 PM	199	260	198	214	201	1024	1017
AVERAGE	NA	NA	NA	NA	NA	NA	NA

REMARKS

#1 A.S. Pump out for REPAIR
 BOTH A.S. PUMPS SHUTTING OFF TOGETHER. SAME PROBLEM WITH PUMP

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
 DEPARTMENT OF PUBLIC WORKS
 GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET
NIGHT SHIFT

FUEL ID	93-03-31-11
DATE	Mar. 31, 1993

AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL FLOW	WELL FLOW	WELL FLOW	SYSTEM FLOW	STRIPPER FLOW	EFFLUENT AIR FLOW	EFFLUENT PRESSURE INCHES WC	EFFLUENT FLOW TO TOP MISTS	SUPERVISOR INITIALS
	GALLONS PER MINUTE	GALLONS PER MINUTE	GALLONS PER MINUTE	gpm	gpm	gpm	INCHES WC	LITER PER MINUTE	
11 PM	198	260	200	216	1023	1017	1082	1016, 4°	WEEKEND 500 Schaefer
12 AM	200	262	200	216	1027	1019	1075	1016, 4°	A 62 Dausell
1 AM	201	260	201	214	1020	1016	1074	1016, 4°	
2 AM	198	260	196	216	1026	1017	1067	1016, 4°	
3 AM	200	263	200	216	1021	1027	1087	1016, 4°	
4 AM	198	258	200	216	1028	1017	1080	1016, 4°	
5 AM	200	264	198	216	201	1022	1018	1073	1016, 4°
6 AM	195	264	203	216	200	1027	1017	1067	1016, 4°
7 AM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

1 A/S out for Repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET

DAY SHIFT

THE ID DATE 3/31/93

REMARKS

#1 A/S TUMPS OUT QOR REPAIRS
1125 hrs. (Wells #1 to 5 SHOT OFF

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

TOWN OF OYSTER BAY
DEPARTMENT OF PUBLIC WORKS
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILED 93-03 - 31 - 13
APR 12 1993
3-31-93

REMARKS

PLANT down. Wilks will not go on.
P.C.I. has been notified

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
 - 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.