

# SIXTH QUARTERLY REPORT

## SECOND YEAR OF GROUNDWATER TREATMENT FACILITY OPERATION

VOLUME 1 OF 2



## TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS

Prepared By:  
The Town of Oyster Bay  
Division of Environmental Control

April 1994

**SIXTH QUARTERLY REPORT**

**SECOND YEAR**


**OF**

**GROUNDWATER TREATMENT FACILITY OPERATION**

**TOWN OF OYSTER BAY**  
**DEPARTMENT OF PUBLIC WORKS**

**Prepared By:**  
**Town of Oyster Bay**  
**Division of Environmental Control**

**April 1994**



## **TABLE OF CONTENTS**

	<b><u>Page No.</u></b>
<b>SECTION 1.0 - INTRODUCTION</b>	
1.1 Purpose of this Document	1
1.2 Scope of this Document	1
<b>SECTION 2.0 - BACKGROUND INFORMATION</b>	
2.1 Site History	2
2.2 Consent Decree Requirements Pertaining to Plume Remediation	3
2.2.1 Requirements for Groundwater Monitoring	3
2.2.2 Treatment Facility Discharge Limitations and Monitoring Requirements	4
<b>SECTION 3.0 - GROUNDWATER TREATMENT FACILITY OPERATIONS</b>	
3.1 Theory of Operation	10
3.2 Physical Plant	10
3.3 Initial Operating Conditions	11
3.4 Monitoring Functions	11
3.4.1 Daily Operations Reports	11
3.4.2 Organic Analyses Reports	12
3.4.3 Inorganic Analyses Reports	12
3.4.4 State Pollution Discharge Elimination System (SPDES) Reports	14
3.4.5 Air Stripper Emissions Testing	14
<b>SECTION 4.0 - GROUNDWATER MONITORING PROGRAM</b>	
4.1 General	15
4.1.1 Field Sampling Protocols	15
4.1.2 Well Construction Details	16
4.2 Hydraulic Monitoring	17
4.2.1 Monthly Water Level Measurements - July, August and September 1993	18
4.3 Groundwater Quality and Quarterly Monitoring	22
4.3.1 Analyses of Volatile Organic Compound (VOC) Data - July 1993	24
4.3.2 Delineation of the VOC Plume	26
4.3.3 Analyses of Inorganic Compound Data - July 1993	26
4.4 Hydraulic Evaluation of the Groundwater Remediation System	27
4.4.1 Effective Capture Zone	27
4.4.2 Effects of Mounding Due to Recharge	28
4.4.3 Evaluation of System Pumpage	29

## **TABLE OF CONTENTS** (Cont'd)

	<b><u>Page No.</u></b>
<b>SECTION 5.0 - FINDINGS AND RECOMENDATIONS</b>	
5.1 Discussion	32
5.1.1 Facility Operations	32
5.1.2 Hydraulic Control of the VOC Plume	41
5.1.3 Remediation of Potential Groundwater Plumes from Other Sources	42
5.2 Recommendations	51
5.2.1 Groundwater Treatment Facility	51
5.2.2 Groundwater Monitoring Program	51



## LIST OF TABLES

	PAGE NO.
1. Effluent Limitations/Volatile Organic Compounds (VOC's)	5
2. Effluent Limitations/Inorganics	6
3. Applicable Air Discharge Requirements for Air Stripping Treatment System	8
4. Analytical Methods	13

## LIST OF FIGURES

1. Temporal Variation in Facility Influent	33
2. Temporal Comparison of Influent/Effluent Total VOC Concentrations	34
3. Temporal Variation in Facility Influent VOC Concentrations	36
4. Temporal Variation in Wellfield VOC Concentrations	37
5. Temporal Variation in Treatment Efficiency	38
6. Temporal Variation in VOC Concentrations at Recovery Well No. 1	43
7. Temporal Variation in VOC Concentrations at Recovery Well No. 2	44
8. Temporal Variation in VOC Concentrations at Recovery Well No. 3	45
9. Temporal Variation in VOC Concentrations at Recovery Well No. 4	46
10. Temporal Variation in VOC Concentrations at Recovery Well No. 5	47
11. Temporal Variation In Wellfield Tetrachloroethene Concentrations	49

## LIST OF APPENDICES

- A. Location Plan
- B. Daily Operations Reports,  
July 1 through September 30, 1993
- C. Self-Monitoring Organic Analyses
- D. Self-Monitoring Inorganic Analyses
- E. SPDES Reports
- F. "Air Stripper Stack Emissions Test Program"  
Second Year of Operation  
1993 - 1994 Second Quarterly Report  
February 1994
- G. "Quarterly Monitoring Report Sixth Quarter Results,"  
February 1994

## **SECTION 1.0**

### **INTRODUCTION**

#### **1.1 Purpose of this Document**

The initial operation of the Groundwater Treatment Facility (GTF) located at the Oyster Bay Solid Waste Disposal Complex (OBSWDC) in Old Bethpage commenced on April 1, 1992. Pursuant to the terms of the Town of Oyster Bay's Consent Decree (83 CIV 5357) with the State of New York, the Town is required to submit quarterly operating reports to the NYSDEC. These reports contain sufficient operating data to demonstrate compliance with the terms of the Consent Decree. This document is the sixth quarterly report (the second quarter of the second operational year) and was prepared in satisfaction of this requirement, and covers the period from July 1, through September 30, 1993.

#### **1.2 Scope of this Document**

This document provides a review of the various monitoring programs that have been undertaken at OBSWDC in satisfaction of the Town's responsibilities outlined on Pages 22-23 in Appendix A of the Consent Decree. This document is divided into five sections and seven appendices.

The sections are informational in nature and discuss the observations noted in the facility's performance and data collected in the reporting period. The appendices contain the raw data or reports collected from various sources relating to the facility's operations during the reporting period.

## SECTION 2.0

### BACKGROUND INFORMATION

#### 2.1 Site History

The OBSWDC is located in eastern Nassau County on Long Island, N.Y. The complex, which had been in operation since 1958, was used for the processing and disposal of all non-hazardous waste generated in the Town of Oyster Bay. Those wastes were burned in two on-site incinerators, and excess materials were compacted and baled for disposal in the adjacent landfill. The landfill also accepted incinerator ash and residue, as well as raw MSW bypassed around the incinerators during periods of maintenance downtime. In April, 1986 all landfilling activities ceased, and the Town began to ship, off site, all solid wastes collected and not recycled. The Town's incinerator ceased operation in December 1986. Presently, the site operations largely consist of operating the Town's scalehouse, solid waste transfer station, recycling program, clean fill disposal site, gas control system, power generating facility, leachate and groundwater treatment systems, and a vehicle maintenance garage.

In June 1988, the Town entered into a Consent Decree (83 CIV 5357) with the State of New York. That document required the Town to perform the following actions:

- \* Design, construct and operate a groundwater treatment facility in order to contain, recover and remediate the off-site groundwater plume associated with the OBSWDC.
- \* Design and construct an acceptable landfill cap.
- \* Continue to operate the leachate treatment facility.

- \* Continue to operate the landfill gas migration control system.
- \* Perform various monitoring functions designed to assess the adequacy of the remediation efforts.

This document concerns the operations of the Groundwater Treatment Facility (GTF), which is located in the northeast corner of the site off Winding Road. The GTF began normal operations on April 1, 1992. In early 1992, the final capping activities at the top of the closed landfill were initiated. The Town is also continuing to maintain the operation of its leachate treatment and landfill gas collection facilities.

## **2.2 Consent Decree Requirements Pertaining to Plume Remediation**

### **2.2.1 Requirements for Groundwater Monitoring**

The nature and extent of the area to be remediated (the 'plume') under the terms and conditions of the Consent Decree was defined in the report "OB SWDC Offsite Groundwater Monitoring Program, Old Bethpage, Long Island, New York", Geraghty & Miller, Inc., September 1986.

In order to verify hydraulic containment of the plume by the recovery well system, and to assess the progress of the cleanup, a Groundwater Monitoring Program has been implemented by the Town according to the requirements as set forth in the Consent Decree. Accordingly, the Groundwater Monitoring Program must consist of the following elements:

Hydraulic Monitoring Monthly - (operational) rounds of water level measurements in the required monitoring wells until equilibrium and appropriate drawdown has been established; and quarterly water level monitoring thereafter so long as hydraulic control of the plume is maintained.

Groundwater Quality Monitoring - A baseline comprehensive First Round monitoring in the required wells prior to start up of the treatment system; followed by Quarterly Monitoring of groundwater quality until the Termination Criteria, as defined in the Consent Decree, has been attained; and Termination Monitoring thereafter for a minimum of five full years (20 quarters).

To fulfill the requirements of the Consent Decree, the following hydraulic monitoring and groundwater quality sampling was accomplished during the sixth operational quarter at the OBSWDC: 1) three rounds of monthly water level measurements during July, August and September, 1993; and 2) one round of groundwater quality sampling performed during July 1993.

Analytical protocols for the above quarterly sampling round consisted of Volatile Organic Compound (VOC) analyses (EPA Method 601 and 602), dissolved metals and other parameters (EPA-40 CFR Part 136.3 for Individual Analyses), plus additional parameters, as per Table 6 of the Consent Decree. As required by the Consent Decree, a total of 16 monitoring wells were sampled, including one landfill well (LF-1) sampled for leachate parameters only, according to the above required EPA protocol.

#### 2.2.2 Treatment Facility Discharge Limitations and Monitoring Requirements

The Town's Consent Decree placed certain limitations on the water discharges from the GTF, and are tabulated in that document. Some water effluent discharge VOC limitations were modified in a letter to the Town from the New York State Department of Law. That modified list

TABLE 1

**TOWN OF OYSTER BAY**  
**DEPARTMENT OF PUBLIC WORKS**  
**GROUNDWATER TREATMENT FACILITY**

**EFFLUENT LIMITATIONS\***  
**VOLATILE ORGANIC COMPOUNDS**

CHEMICAL CONSTITUENT	ALLOWABLE EFFLUENT CONCENTRATION (ug/l)
TOTAL VOCs	100
BENZENE	ND
BROMODICHLOROMETHANE	50 **
BROMOFORM	50 **
CARBON TETRACHLORIDE	5
CHLOROBENZENE	5
CHLORODIBROMOMETHANE	50 **
CHLOROETHANE	5
CHLOROFORM	100 **
DICHLOROBENZENE o&p	4.7
DICHLOROBENZENE o,m&p	50
1,1 DICHLOROETHANE	5
1,2 DICHLOROETHANE	5
1,1 DICHLOROETHENE	0.07
1,2 DICHLOROETHENE cis	5
1,2 DICHLOROETHENE trans	5
1,2 DICHLOROPROPANE	5
ETHYLBENZENE	50
METHYLENE CHLORIDE	5
TETRACHLOROETHENE	0.7
TOLUENE	5
1,1,1 TRICHLOROETHANE	5
TRICHLOROETHYLENE	5
VINYL CHLORIDE	2
XYLENE o	5
XYLENE m	5
XYLENE p	5
XYLENE o,m&p	50

- \* REGULATORY EFFLUENT DISCHARGE STANDARDS AS SPECIFIED IN THE CONSENT DECREE AND AS MODIFIED BY 11/10/88 LETTER TO THE TOWN.
- \*\* TOTAL CONCENTRATION OF THESE FOUR TRIHALOMETHANES SHALL NOT EXCEED 100 ug/l.

TABLE 2

**TOWN OF OYSTER BAY**  
**DEPARTMENT OF PUBLIC WORKS**  
**GROUNDWATER TREATMENT FACILITY**

**EFFLUENT LIMITATIONS\***  
**INORGANICS**

<b>CHEMICAL CONSTITUENT</b>	<b>ALLOWABLE EFFLUENT CONCENTRATION (mg/l)</b>
<b>BARIUM</b>	<b>1</b>
<b>CADMIUM</b>	<b>0.01</b>
<b>CHLORIDE</b>	<b>250</b>
<b>CHROMIUM (hex)</b>	<b>0.05</b>
<b>COPPER</b>	<b>1</b>
<b>CYANIDE</b>	<b>0.2</b>
<b>IRON</b>	<b>0.3</b>
<b>LEAD</b>	<b>0.025</b>
<b>MAGNESIUM</b>	<b>35</b>
<b>MANGANESE</b>	<b>0.3</b>
<b>MERCURY</b>	<b>0.002</b>
<b>SILVER</b>	<b>0.05</b>
<b>ZINC</b>	<b>5</b>
<b>TOTAL DISSOLVED SOLIDS</b>	<b>500</b>
<b>NITRATE</b>	<b>10</b>
<b>SULFATE</b>	<b>250</b>
<b>PHENOLS (total)</b>	<b>0.001</b>

- \* REGULATORY EFFLUENT DISCHARGE STANDARDS AS  
SPECIFIED IN THE CONSENT DECREE AND AS MODIFIED BY  
11/10/88 LETTER TO THE TOWN.



is reproduced here as Table 1. Effluent discharge limitations pertaining to this facility concerning inorganic and other physical parameters are listed in Table 2. The Town began monthly SPDES monitoring of the air stripper effluent in April, 1992 for the parameters in Tables 1 and 2 and continued during this reporting period. This testing is performed by a New York State certified laboratory. The Consent Decree also placed limitations on the air stripper discharges from the GTF. That list, as it appears in the Consent Decree, is reproduced here as Table 3.

The Town began quarterly monitoring of the air stripper stack emissions on May 28, 1992. The sixth quarterly emissions monitoring took place on September 24, 1993. Analyses are performed by a New York State certified laboratory, and the results compared to the limitations stipulated in the Consent Decree and the most recent revision of NYSDEC Air Guide No. 1, effective June 1991.

In April 1993, after numerous discussions between the Town and NYSDEC, the Town was advised that the ambient air guideline for tetrachloroethane (PCE), published in the 1991 edition of NYSDEC Air Guide No. 1, was in error. The Town was further advised that the correct guideline was some fifteen times higher than the previously published number. Lastly, the Town was advised that NYSDEC will apply the ambient air guidelines at the OBSWDC property line to determine if the air stripper stack discharge is acceptable.

In addition to the above requirements, the Town is also required to perform certain self-monitoring functions, relating to recording comprehensive flow measurements through the plant and maintaining a record of downtime. The Town has enhanced its self-monitoring abilities with the installation of an onsite laboratory. This laboratory monitors the groundwater in the vicinity of each recovery well on a weekly basis, as well as the day-to-day treatment system performance, allowing plant personnel to make process adjustments when necessary. Daily monitoring may also warn the operator of equipment malfunction or the need for maintenance. Weekly

TABLE 3

APPLICABLE AIR DISCHARGE  
REQUIREMENTS FOR AIR STRIPPING  
TREATMENT SYSTEM\*

Constituent	-Ambient Air Concentrations-
	NYSDEC Annual Guideline (ug/m3)
Vinyl Chloride	4.00E-01
Freon 13	3.00E-02
Methylene Chloride	1.17E+03
1,1-Dichloroethane	2.70E+03
1,2-Dichloroethene	2.63E+03
Chloroform	1.67E+02
1,1,1,-Trichloroethane	3.80E+04
Carbon Tetrachloride	1.00E+02
1,2-Dichloroethane	2.00E+01
Trichloroethylene	9.00E+02
1,2,-Dichloropropane	1.17E+03
Bromodichloromethane	3.00E-02
Tetrachloroethene	1.12E+03
Chlorodibromomethane	3.00E-02
Bromoform	1.67E+01
Benzene	1.00E+02
Toluene	7.50E+03
Ethyl Benzene	1.43E+03
(m) Xylene	1.43E+03
(o;p) Xylene	1.43E+03
(m) Dichlorobenzene	3.00E-02
(o) Dichlorobenzene	1.00E+03
(p) Dichlorobenzene	1.50E+03
Chloroethane	5.20E+04
1,1,-Dichloroethylene	6.67E+01
Chlorobenzene	1.17E+03
Ammonia	3.60E+02

\* Established per New York State Department of Environmental Conservation Air Guide No. 1 for Toxic Air Contaminants. If any federal National Ambient Air Quality Standards or National Emission Standards for Hazardous Air Pollutants are promulgated which are more stringent than these State guidelines, the more stringent standard shall apply.

monitoring of the recovery wellfield will assist the Town in establishing the initiation of Termination Monitoring as proscribed in the Consent Decree.

## **SECTION 3.0**

### **GROUNDWATER TREATMENT FACILITY OPERATIONS**

#### **3.1     Theory of Operation**

A system of five (5) groundwater recovery wells was installed by the Town at the leading edge of the volatile organic compounds (VOC) plume, located in the Bethpage State Park. The location of the recovery wells/recharge basin are shown in Appendix A of this report.

The combined flow from all wells is directed through common transmission piping to the air stripper wet well. A triplex pump arrangement delivers the collected groundwater to the top of the air stripper containing proprietary packing media. As the groundwater passes through and wets the packing, it is contacted with air directed into the bottom of the air stripper. Dissolved VOC's pass from the liquid phase (groundwater) into the gas phase (air) and exit the stripper through a stack. The treated groundwater is directed into a receiving wet well where another triplex pump arrangement delivers it to a combination of eight (8) diffusion wells in a recharge basin (Recharge Basin No.1), located hydraulically upgradient of the landfill on the west perimeter of the site.

#### **3.2     Physical Plant**

The Groundwater Treatment Facility (GTF) consists of the following major components:

- \* five (5) recovery wells to deliver a combined maximum design flow of approximately 1.5 MGD.

- \* treatment plant building housing the control room, laboratory, wet wells, pumps, acid rinse system, and chemical holding tanks.
- \* air stripper and proprietary media.
- \* recharge basin/diffusion wells
- \* transmission piping.

### **3.3 Initial Operating Conditions**

On April 1, 1992, the facility pumped approximately 1.5 MGD of groundwater from the five (5) recovery wells located in the Bethpage State Park. This flow was processed through an air stripper operating at a nominal 1050 GPM forward hydraulic flow and approximately 10,400 SCFM of atmospheric air. The treatment plant design and the initial operating conditions are based on continuous twenty-four hours, seven days per week operation. Some adjustments to water and air flows were made during this reporting period.

### **3.4 Monitoring Functions**

#### **3.4.1 Daily Operations Reports**

The control console located at the GTF provides continuous readouts to the operating personnel of pumpage rates from each production well through the plant. Hourly, the operating personnel transfer these readings onto a "Daily Operations Report". One report is completed each shift. A box is provided on the form for the written observations made by those personnel concerning

plant operations. These reports for the sixth quarter (second quarter of the second operating year), from July 1 through September 30, 1993, are reproduced in Appendix B.

#### 3.4.2 Organic Analyses Reports

The Town installed a gas chromatograph at the facility laboratory to self-monitor the day to day treatment efficiency of the facility. During the operating quarter, to assure compliance, influent and effluent samples were taken regularly at the facility and analyzed for VOC's. Originally the sampling and analysis schedule operated daily, Monday through Friday, but was adjusted to three days per week near the end of the second quarter, as it became apparent that treatment efficiency remained high under varying inlet conditions. This procedure was continued during this quarter. In addition, weekly samples from the recovery wellfield are also analyzed for VOC's. All VOC self-monitoring data is reproduced in Appendix C.

#### 3.4.3 Inorganic Analyses Reports

The Town also installed at the facility laboratory, equipment to self-monitor other water quality parameters. These measurements are generally taken to forewarn the operating personnel of changes in the influent or effluent signaling potential equipment problems requiring maintenance. Therefore, soluble iron is occasionally monitored through the air stripper to quantify the potential for iron fouling of the packing media. Dissolved oxygen is measured in the effluent to assure proper blower operation and that the influent has been thoroughly aerated. All inorganic self-monitoring data is reproduced in Appendix D.

TABLE 4

<u>Analytical Methods</u>			
<u>Parameter</u>	<u>Analytical Method</u>	<u>Sample Preservation</u>	<u>Holding Time</u>
Chloride	SM 407 A	None	28 Days
Ammonia	SM 417B, EPA 350.2	Cool to 4°C pH 2 w/H <sub>2</sub> SO <sub>4</sub>	28 Days
Iron SM 303B, EPA 236.1		Field filter, Cool to 4°C, pH 2 w/HNO <sub>3</sub>	6 Months
Hardness	SM 314B, EPA 130.2	Cool to 4°C	6 Months
Alkalinity	SM 403, EPA 310.1	Cool to 4°C	14 Days
pH (measured in field)	SM 423	None	Analyze Immediately
Specific Conductance (measured in field)	SM 205	Cool to 4°C	28 Days
VOCs	EPA 601 and 602	Cool to 4°C	14 Days
Metals and others*	EPA 40 CFR 136.3 (Individual Analyses)	As per Individual method	As per Individual method

\*Aluminum, Copper, Lead, Manganese, Nickel, Sodium, Zinc, Chromium (VI), Chromium, Mercury, Potassium, Magnesium, Calcium, Total Dissolved Solids, Nitrate, Sulfate, Carbonate, Total Kjeldahl Nitrogen, Bicarbonate Alkalinity, Cyanide, Phenols and Barium

#### 3.4.4 State Pollution Discharge Elimination System (SPDES) Reports

In addition to self-monitoring, the Town sends monthly facility effluent samples to a New York State certified laboratory for organic and inorganic analyses. The analyses performed are those required by the Consent Decree, reproduced here as Table 4 as it appears in that document. The monthly SPDES reports from the certified laboratory are reproduced in this document as Appendix E.

#### 3.4.5 Air Stripper Emissions Testing

The sixth quarterly emissions test of the air stripper was performed on September 24, 1993. The testing procedure involves obtaining twelve gas samples from the air stripper stack, and to obtain meaningful results, the test is performed during normal facility operations. Hydraulic data is collected in the normal manner (See Section 3.4.1). The data contained in the "Daily Operations Report" spanning the test period is used to establish the mass quantities of materials emitted by the treatment process per unit of time. The report is reproduced in Appendix F.



## SECTION 4.0

### GROUNDWATER MONITORING PROGRAM

#### 4.1 General

In compliance with the Consent Decree for the Old Bethpage Landfill, the following groundwater monitoring related activities were performed during the sixth operational quarter (from July 1 through September 30, 1993) of the Groundwater Treatment Facility (GTF):

- 1) One round of quarterly groundwater quality samples collected from July 7 through July 9, 1993; and
- 2) Three rounds of monthly (operational) water level measurements collected on July 6, August 3 and September 13, 1993.

Geraghty & Miller, Inc. (G&M), Plainview, Long Island, as a subconsultant to Lockwood, Kessler & Bartlett, Inc. (LKB), performed all of the hydraulic and groundwater quality monitoring at the site.

The data collected are summarized and evaluated in a document entitled, "Quarterly Monitoring Report, Sixth Quarter Results, Old Bethpage Landfill", February, 1994 and are presented in their entirety in Appendix G.

##### 4.1.1 Field Sampling Protocols

Except as noted in the subconsultant's report (see Appendix G), field sampling procedures used during the July, 1993 Sampling Round were those that were previously submitted to the

NYSDEC in July, 1991 by the Town of Oyster Bay, entitled "Protocols for Sampling Groundwater Under the Old Bethpage Solid Waste Disposal Complex Remedial Action Plan". A copy of those field sampling protocols is contained in Appendix G. Evacuation data and sampling data/field parameters for each well sampled are included on the Water-Sampling Logs in Appendix G. Field Quality Assurance/Quality Control samples utilized during this sixth quarterly sampling round consisted of two field blanks and a total of four trip blanks analyzed for VOC's only. The field/trip blanks were used to gauge the level of background (VOC) contamination, if any, from sources other than the well. In addition, the duplicate sample was taken from an anonymous well (6C-Rep) and analyzed for the full list of parameters to determine the laboratory precision of the analytical results. The field QA/QC procedures utilized were in conformance with Sections IV.A, IV.B, and IV.C of the Consent Decree.

A tephlon bailer was used for the evacuation and sampling of Well 30B, , since this well is not fitted with dedicated submersible pump. All downhole equipment utilized for sampling which was not dedicated (i.e. used in other wells) was thoroughly sanitized prior to use in a particular well.

The Town coordinates its groundwater monitoring schedule, as much as possible, with the Nassau County Firemen's Training Center so that a more comprehensive groundwater picture is determined.

#### 4.1.2 Elevation of Recovery Well Screens

Elevations of the monitoring well screen intervals (in feet above and below Mean Sea Level) (MSL) were assigned to the following zones for data correlation and water level mapping purposes:

- \* Water Table Zone - 76 to 43 above MSL
- \* Shallow Potentiometric Zone - 30 above to 30 below MSL

- \* Deep Potentiometric Zone - 65 to 157 below MSL

The five recovery well screen intervals are included in both the shallow and deep potentiometric zones.

#### **4.2     Hydraulic Monitoring**

The purpose of the hydraulic monitoring is twofold: 1) to delineate the effective capture zone of the groundwater recovery wells so that hydraulic containment of the VOC plume can be demonstrated; and 2) to determine the extent of mounding in the recharge basin area, and the effect of the mounding, if any, on local groundwater flow patterns.

Static water levels were measured to the nearest .01 foot with an electronic water level meter (SLOPE INDICATOR) instead of with the chalk and tape method as referenced in the Consent Decree. In situ dedicated sampling equipment prevented the use of a chalk and tape. The electronic tape is generally considered to be more accurate than a chalk and tape.

Water level measurements collected during the monthly (hydraulic) monitoring rounds were converted to elevations relative to MSL and plotted on a Site Location Map. (See Appendix A, Location Plan). The data points (water level elevations) in each aquifer zone were then contoured to produce the water table, shallow potentiometric, and deep potentiometric surface maps shown in Figures 1 through 9 of Appendix G. The approximate extent of the VOC plume (based upon the July 1993 sampling data) and the limiting flow lines of the effective capture zone were also drawn on the maps. Contour lines are dashed where the data points are less than optimum; the limiting flow lines drawn through these areas are approximate.

#### 4.2.1 Monthly Water Level Measurements - July, August and September 1993

The monthly (operational) water level data were collected on July 6, August 3 and September 13, 1993 and are summarized in Tables 1, 2 and 3 of Appendix G. The data are contoured in Figures 1 through 9 for the water table, shallow potentiometric, and deep potentiometric zones of the aquifer. The following wells were incorporated into the hydraulic monitoring:

- \* all 23 off-site wells (i.e. 5A, 5B, 6A, 6B, etc.)
- \* existing Phase I, II, and III wells (LF-1 through LF 4 & TW1 through TW3 )
- \* the well at Melville Road (N9980)
- \* Farmingdale Public Supply Wells 1-3, 2-2 and 2-3
- \* Pump Test Observation Well OBS-2
- \* Groundwater Remediation Wells RW-1 through RW-5
- \* Wells upgradient of the recharge basin (29A, B and 30A, B)

Observation Well OBS-1 was damaged and, therefore could not be monitored for water levels during the sixth quarter.

Water level measurements in Farmingdale Public Supply Well Nos. 1-3 and 2-2 were obtained by water district personnel to the nearest 0.5 foot. Water levels were obtained in upgradient Well 9-A are suspect because it has been previously reported that gravel pack has entered the well.

#### July 6, 1993 Water Level Elevations

Contour maps depicting the elevations of the water table, shallow potentiometric, and deep potentiometric surfaces on July 6, 1993 are shown in Figures 1 through 3 in Appendix G. In general, compared to earlier rounds conducted during the fifth operating quarter, water level

elevations from this round decreased by approximately 0.5 feet but revealed similar groundwater flow directions. As shown in Figure 1, groundwater flow directions on the water table surface are to the southeast across the project area and are compatible with the regional (southerly) flow direction, as reported by the United States Geological Survey. Referring to Figures 2 and 3, groundwater flow in the shallow and deep potentiometric zones is radially inward from the south, east and western parts of the capture zone toward the recovery wells.

Groundwater elevations observed for the July 6, 1993 round for the water table surface ranged from approximately 71.0 feet above MSL in the recharge basin area (north of the landfill) to 56.5 feet MSL (south of the landfill site) in Well No. N9980 just south of Melville Road. Localized mounding of the water table was observed immediately adjacent to the groundwater remediation system recharge basin, at an elevation approximately equal to that observed during the fifth operational quarter of the system.

Groundwater elevations of the shallow and deep potentiometric zones of the aquifer during the July monitoring round ranged from approximately 69.6 feet above MSL upgradient of the site to 50.6 feet MSL in remediation Well RW-3 downgradient of the site in the capture zone area. Groundwater elevations south of approximate location of the stagnation point (which delineates the southern boundary of the capture zone), ranged from about 62 feet above MSL near the stagnation point to 56.5 feet MSL in the area along Melville Road (see Figures 2 and 3 in Appendix G)

Analysis of Figures 2 and 3 of Appendix G indicates that hydraulic control over the VOC plume was maintained during the July Hydraulic monitoring round, with an estimated system pumpage of approximately 1053 gpm (1.43 mgd).

#### **August 3, 1993 Water Level Elevations**

Contour maps depicting elevations of the water table, the shallow potentiometric surface, and deep potentiometric surface during August 3, 1993 are shown in Figure 4 through 6 in Appendix G. In general, compared to the July 6, 1993 round, water level elevation data from this round revealed similar groundwater flow directions across the site. Compared to the July 6, 1993 round, water level elevations from the August round generally decreased by .6 ft. across the site. Water level elevations for the water table ranged from approximately 70.0 feet above MSL (north of the landfill) to 55.6 feet MSL (south of the landfill site). Localized mounding, immediately adjacent to the groundwater remediation system recharge basin, was also observed during this round.

Groundwater elevations in the shallow and deep potentiometric zones ranged from approximately 68.8 feet above MSL in the recharge basin area to 50.6 feet MSL in Well RW-3 in the capture zone. South of the stagnation point, groundwater elevations ranged from approximately 60 feet MSL near the south edge of the capture zone to 55.6 feet MSL in Well N9980 near Melville Road.

Hydraulic control over the VOC plume was maintained during this hydraulic monitoring round with an estimated average system pumpage of 1103 gpm (1.49 mgd).

#### **September 13, 1993 Water Level Elevations**

Contour maps depicting elevations of the water table, shallow and deep potentiometric surfaces on September 13, 1993 are shown in Figures 7 through 9 in Appendix G. . A comparison of the September 13, 1993 water elevation data with that of the 1991 baseline monitoring round reveals

an average decline in water levels of approximately four feet across the study area (Geraghty & Miller, Inc. 1992a).

Water level elevations for the water table ranged from approximately 68.8 ft. above MSL (north of the landfill) to 54.5 ft. above MSL (south of the landfill site, near Melville Road). Localized mounding was also observed in the upgradient remediation recharge basin area, similar to that reported for the previous monitoring rounds. Except for the localized radial flow patterns resulting from this mounding, groundwater flow directions in the shallow aquifer during this round were to the southeast and, were compatible with the regional flow direction.

Groundwater elevations in the shallow and deep potentiometric zones ranged from approximately 68.1 ft. above MSL in the recharge basin area to 49.6 ft. above MSL in Well RW-3 in the capture zone. South of the stagnation point, groundwater elevations ranged from approximately 58 ft. above MSL near the south edge of the capture zone to 54.5 ft. above MSL in Well N9980 near Melville Road.

As shown in Figures 8 and 9, as a result of RW-1 being off-line for servicing, the effective capture zone estimated from the September round is smaller than those estimated from the July and August rounds. Nevertheless, analysis of the limiting flow lines indicates that the VOC plume was being captured at an estimated system pumpage of 898 gpm (1.22 mgd). Based upon the method of analysis used, it appears that the limiting flow lines west of the VOC plume were at or near a minimum during this round to demonstrate hydraulic containment of the plume. In response to this situation, the Town increased the pumpage (to full capacity) in Recovery Well No. 2 to compensate for the temporary loss of flow.

#### 4.3 Groundwater Quality and Quarterly Monitoring

In accordance with the requirements of the Consent Decree, a quarterly round of groundwater quality sampling was conducted at the Old Bethpage landfill site between July 7 and July 9, 1993. Wells sampled as part of the quarterly groundwater monitoring program, as specified in Section II.B.3 of the Consent Decree, are as follows:

Offsite Wells: 5B

6A, 6B, 6C, 6E, 6F

7B

8A, 8B

9B, 9C

11A, 11B

Observation Well: OBS-2

Upgradient Well: M-30B

Landfill Well: LF-1

Well OBS-1 was damaged and, therefore, a sample could not be collected from this well. Well OBS-2 was sampled in place of OBS-1 since it is screened in the same aquifer zone and is located within the southwest part of the plume.

Except for Landfill Well LF-1 which was analyzed for leachate parameters only (as per Table 6 in the Consent Decree), all groundwater samples collected were analyzed for Volatile Organic Compounds (VOC's); dissolved (filtered) Metals; total (unfiltered) Metals; and leachate parameters, as required by Table 6.



The results of the quarterly monitoring are summarized in Tables 5, 6 and 7 of Appendix G; the certified laboratory data reports are also presented in Appendix G of this Report. According to the data reports, VOC's were not found in any of the two trip blanks or four field blanks that were analyzed, and duplicate sampling results (i.e. 6C-Rep) were found to be within acceptable limits for all analyses. Artifact compounds currently recognized by the Consent Decree were not detected in any of the samples analyzed.

Plume maps showing the approximate distribution of the three important groupings of VOC's (i.e. volatile halogenated, aromatics, and tetrachloroethene), detected during the July 1993 sampling round, are presented in Figures 10, 11 and 12 in Appendix G. It should be noted that the individual plumelines represent the total VOC concentrations greater than 5 ppb (for VHO's and tetrachloroethene) or 1 ppb (for benzene/aromatics). These values represent the lowest standard value or detection limit for a constituent in a group. Previously, any total concentration > 0 ppb in a group was mapped as part of the plume. These new plume lines will help demonstrate when the Termination Criteria of the Consent Decree have been met.

In addition to the above proceedured charge, weekly VOC sampling data from the five remediation wells have been incorporated into the plume maps. At this stage in the remediation process, the integration of all data from the Town's monitoring programs will give the most accurate representation of the plume boundaries.

In general, because the groundwater recovery system was designed to capture and treat the VOC portion of the landfill plume, the data analyses focuses on VOC contamination. Analysis of the leachate (inorganic) portion of the landfill plume is limited to a comparison of inorganic data/plume dimensions as previously reported. For reference, all data collected during the July 1993 round are compared to the fifth quarter data (LKB, July 1993), as well as to the 1991 baseline data (LKB, September 1992).

#### 4.3.1 Analyses of Volatile Organic Compound (VOC) Data - July 1993

The July 1993 testing and analysis exhibit the same groupings of compounds but reveal a slightly different pattern of groundwater contamination than that observed in all prior operational quarters and the 1991 Baseline sampling round. The sampling rounds consistently demonstrate three groupings of VOC's. These groupings are as follows: 1) volatile halogenated organics (VHOs) except tetrachloroethene; 2) volatile aromatic hydrocarbons; and 3) tetrachloroethene. An analysis of the VOC grouping is given below and in the groundwater sampling discussion in Appendix G.

The most dominant compounds detected in the first grouping, in terms of occurrence and concentration, were: 1,2-dichloroethene and trichloroethene, at concentrations of 0-32 ug/l and 0-14 ug/l, respectively. Other VHOs were also detected in groundwater samples but typically in concentrations of less than 10 micrograms. Well 8A had the highest concentrations of VHOs detected, followed by Wells 7B, OBS-2, 8B and 5B. In general, concentrations of VHO's were lower in the July 1993 round than those detected in the April 1993 round and in the baseline round.

Figure 10 in Appendix G illustrates the approximate lateral extent of VHO's during the July 1993 sampling round. Based upon the groundwater sampling data, it appears that the lateral extent of VHO's during this round differs considerably from that reported during the July/August 1991 baseline sampling round. The most significant change in the configuration of the plume was apparently the result of a reduction in VHO concentrations in well clusters # 6 and # 9 over previous quarters. The lateral extent of the plume was also influenced by inclusion of sampling data from OBS-2 (not previously sampled) and by adjustment of the plumeline from > 0 ppb to 5 ppb as previously described.

The second VOC grouping, aromatic hydrocarbons, which consist of benzene, ethylbenzene, chlorobenzene, p-dichlorobenzene and o-dichlorobenzene, is shown in Figure 11. The highest concentrations of aromatic hydrocarbons were detected in Well 6B (15 ug/l), Well 6E (15 ug/l), Well 9C (13 ug/l) and Well 5B (5 ug/l). P-dichlorobenzene was the dominant aromatic compound detected. In general, total concentrations of aromatic hydrocarbons detected in the July 1993 round were approximately the same as those detecting in the April 1993 round and less than those detected in the July/August baseline round. The approximate lateral extent of aromatic hydrocarbons in groundwater in July 1993 is similar to the lateral extent based on April 1993 data and has decreased compared to the lateral extent in July/August 1991 baseline round (Geraghty & Miller, Inc. 1992a). However, as indicated in Figure 11, the eastern extent of the aromatics plume was shown to increase over previous sampling rounds, after weekly sampling data from the remediation wells was utilized in the mapping process.

The third VOC grouping, tetrachloroethene, presumably exhibits a distribution similar to the two separate plumes (east and west) evident from the historic data at the site. Figure 12, in Appendix G, illustrates the approximate lateral extent of tetrachloroethene in July 1993 based upon the groundwater sample data. The westernmost plume is not shown because Well OBS-1 was damaged and was not sampled during this round, data from OBS-1 is critical for determining the presense of the westernmost plume. The highest concentration of tetrachloroethene was detected in Well 8A (270 ug/l), followed by Well 7B (75 ug/l); (which are downgradient of the former Claremont Polychemical site). Concentrations of tetrachloroethene detected in the July 1993 round are less than those detected in the April 1993. For example, the concentration of tetrachloroethene detected in the July 1993 round decreased in Wells 7B and 8A when compared with the July/August 1991 baseline data and the April 1993 data. The concentrations of tetrachloroethene detected in Well 7B decreased from 140 ug/L and 130 ug/L in the July/August 1991 baseline round and April 1993 round to 75 ug/L in the July 1993 round. The

concentrations of tetrachloroethene detected in Well 8A decreased from 440 ug/L and 380 ug/L in the July/August 1991 baseline round and April 1993 round to 270 ug/L in the July 1993 round.

#### 4.3.2 Delineation of the VOC Plume

The position of the total Volatile Organic Compound (VOC) plume, which includes a composite of the three groupings as described above, has been delineated on Figures 1 through 6 in Appendix G. The position of the plume is based solely upon sampling data obtained from the Town's groundwater monitoring wells as required by the Consent Decree. The outline (hatched area) represents the approximate maximum horizontal extent of the plume within the aquifer at the time of the July 1993 Quarterly Sampling Round. A review of VOC plume outlines in Appendix G suggests that the approximate length of the plume downgradient of the landfill is 4,000 feet and the maximum width of the plume is about 3,000 feet. A comparison of the current lateral extent of the composite VOC plume with previous fifth quarter and baseline mapping efforts appears to indicate no significant change in the position of the plume.

However, since groundwater has been captured by the recovery wells for approximately one year, theoretically, the southernmost extent of the VOC plume should have been reduced. This apparent discrepancy may be accounted for by realizing that the southern boundary of the plume line(s) was estimated by using a less than ideal resolution of monitoring well sampling points.

#### 4.3.3 Analysis of Inorganic Compound Data - July 1993

Inorganic data collected during the July 1993 groundwater quality sampling round are summarized in Tables 6 and 7 in Appendix G. In general, leachate indicators detected in total (unfiltered) samples from the July 1993 round depict a distribution similar to the data from the

April 1993 round. Specifically, the landfill leachate plume exhibits its greatest approximate lateral extent in the middle zone (the approximate elevation of the "B" and "C" wells, which is roughly equivalent to the shallow potentiometric zone) and its greatest approximate thickness (approximately 200 ft) in Well Cluster 6. The highest concentrations of ammonia and chloride detected in the July 1993 round were found in Wells 5B, 6B and 9C. Iron was detected at its highest levels in Wells M-30, 6B and 6C. The highest concentrations of hardness were detected in Wells 5B, 6B, 6C, 6E, 8B and LF-1. Alkalinity was detected at its highest levels in Wells 5B, 6C, 9C and LF-1. Manganese was detected at its highest level in Well LF-1. Compared with the April 1993 round, the concentration of leachate indicators detected in the July 1993 round are similar.

#### **4.4 Hydraulic Evaluation of the Groundwater Remediation System**

##### **4.4.1 Effective Capture Zone**

Figures 1 through 9 show the configuration of the water table, the shallow potentiometric and deep potentiometric surfaces, relative to the position of the VOC plume, for the July 3, August 6 and September 13, 1993 water level monitoring rounds. In addition, limiting flow lines depicting the effective capture zone are shown on the shallow and deep potentiometric maps.

Average water level elevations across the study area have decreased approximately four feet since the 1991 (pre-pumping) baseline water level rounds, and drawdown in the capture zone has ranged from approximately 10 to 12 feet since the start of pumping in April 1992. Mean water level elevations in the capture zone, as measured in the five recovery wells, have shown a steady decline over the first and second operational quarters (from 55.4 to 53.7 feet MSL), and have shown a fluctuating but generally increasing trend during the third and fourth quarters. The third and fourth quarter fluctuations (from 54.0 to 55.8 feet MSL) are mostly due to Wells RW-1 and RW-2 being off-line during the January and February, 1993 monitoring round, respectively.

The fifth quarter and six quarter water level monitoring results illustrated a return to a decreasing trend within the capture zone, with the fifth and six quarters showing average water elevations of 54.28 and 53.82 feet above MSL, respectively, in the remediation wells. This general increasing/decreasing trend in water levels appears to be the result of seasonal recharge of the groundwater which results in rising water levels in winter and spring, and falling levels in summer and fall.

Water elevation data and limiting flow lines of the capture zones, as presented in Appendix G, indicate that the total system pumpage which averaged approximately 1.41 and 1.48 mgd during the July and August monitoring rounds, respectively, was sufficient to create and maintain a hydraulic control over the VOC plume, both horizontally and vertically. Although, the effective capture zone estimated from the September 13 round and shown on Figures 8 and 9 is smaller than that shown on Figures 2,3,5 and 6, it appears that hydraulic control over the VOC plume was maintained with an estimated average system flow of 898 gpm or 1.22 mgd during the hydraulic monitoring round. This reduction in system pumpage and the decrease in the effective capture zone was the result of Recovery Well No. 1 being incapacitated by flooding on August 9, 1993.

#### 4.4.2 Effects of Mounding Due to Recharge

Figures 1, 4 and 7 in Appendix G show the configuration of the water table and mounding in the area of Recharge Basin No. 1 during the July, August and September 1993 hydraulic monitoring rounds. Data presented in these Figures indicate localized mounding of the water table immediately adjacent to the recharge basin, resulting in a radially outward flow pattern. The elevation of the top of the mound is estimated to range from approximately 68-71 feet above MSL during the sixth operating quarter, which is a minor decrease from that reported for the

previous quarter (ECD, November 1993). The modification of the local groundwater flow pattern resulting from the mounding is largely restricted to the northwest corner of the landfill property.

During the sixth quarter, standing water was measured at 123 to 124 feet above MSL in the recharge basin. The standing water in the basin is the equilibrium water level for the recharge basin system, and is interpreted to be the result of slow seepage of effluent (and runoff water) through the leaching wells/recharge basin and soil. Hydraulic monitoring at the landfill indicates that the standing water in the basin does not significantly add to the elevation of the mounding that was observed and, consequently, does not adversely affect groundwater flow conditions in the area.

#### 4.4.3 Evaluation of System Pumpage

Wellfield operation (see Daily Operating Reports - Appendix B) was reviewed for the period July 1 through September 30, 1993 to estimate: 1) total system flow and system pumpage; and 2) well flow for the individual recovery wells. During the sixth quarter, the actual average system flow, as determined by air stripper operating parameters, was approximately 1.13 MGD.

The groundwater recovery system was fully operational for approximately 10 of the 92 day reporting period. Recovery Well No. 1 was damaged by flooding on August 9, 1993, and was inactive for the rest of the sixth quarter. This accounts for 53 of the 82 days when the facility was not fully operational. A summary of the daily pumpage records and estimated average system flows, in GPM, is presented in Table 4, Appendix G.

The minimum, maximum and mean average daily pumpage rates (gallons per minute) for each recovery well during July, August and September of the sixth operating quarter are summarized below:

**July 1993**

**Gallons Per Minute**

	<u>Minimum</u>	<u>Maximum</u>	<u>Mean</u>
RW-1	0	252	181
RW-2	0	285	165
RW-3	0	235	155
RW-4	0	237	179
RW-5	0	262	<u>199</u>

**Average Total System Pumpage = 879**

**August 1993**

**Gallons Per Minute**

	<u>Minimum</u>	<u>Maximum</u>	<u>Mean</u>
RW-1	0	230	45
RW-2	0	284	235
RW-3	0	204	177
RW-4	0	201	167
RW-5	0	255	<u>194</u>

**Average Total System Pumpage = 818**



**September 1993**

**Gallons Per Minute**

	<u>Minimum</u>	<u>Maximum</u>	<u>Mean</u>
RW-1	0	0	0
RW-2	135	291	264
RW-3	49	203	186
RW-4	0	201	144
RW-5	107	229	<u>213</u>

**Average Total System Pumpage = 807**

The average sixth quarter total system pumpage calculated from this data is 835 gallons per minute (1.20 MGD continuous system flow), which is about six percent greater than that determined from the air stripper effluent flows (1.13 MGD). This discrepancy is the result of normal intermittent operation of the recovery well pumps which are designed to maintain a relatively constant system flow.

## SECTION 5.0

### FINDINGS AND RECOMMENDATIONS

#### 5.1 Discussion

##### 5.1.1 Facility Operations


A review of the "Daily Operations Reports" (Appendix B) for the period reported shows that the facility maintained an on-line performance of 74.5 percent (figure represents the percentage of total hours in which Recovery Wells 1 through 5 were in operation), and when operating, processed an average of 1.18 MGD (figure does not include days when the facility was not in operation). Over this 92-day period, nearly 104 million gallons of groundwater were pumped, treated and recharged at an actual average flow of 1.13 MGD (Figure 1).

The on-line performance record of the facility during this quarter was affected primarily by downtime due to damage to Recovery Well No. 1 caused by flooding. Recovery Well No. 1 , which was not operating from August 9, 1993 through the end of the quarter, accounted for 42.9 % of the total downtime.


The policy of emergency shutdown during thunderstorm activity was initiated by the Town during the summer of 1992, has been reported previously, and is now a permanent feature of the facility operating procedures. In the sixth quarter, thunderstorm related downtime accounted for 7.3 % of the total downtime.

Based on self-monitoring data (Appendix C), total influent VOC's during the sixth quarter averaged 248 ppb, and total effluent VOC's for the same period averaged 6.35 ppb (Figure 2).

# TEMPORAL VARIATION IN FACILITY INFLUENT FLOW



# TEMPORAL COMPARISON OF INFLUENT/EFFLUENT TOTAL VOC CONCENTRATIONS



SIXTH OPERATIONAL QUARTER, 1993  
TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

Figure 3 visually depicts the contribution of the six most prevalent VOC's towards total influent VOC concentrations. The trend of tetrachloroethene concentrations being the major component of total VOC's is similar to that demonstrated in all previous operating quarters. Figure 4 illustrates the concentrations of total VOC's found to be contributed by the five Recovery Wells.

The average total VOC influent loading increased by about five percent over the previous quarter and overall average treatment efficiency decreased by two percent down to 97.4 percent (Figure 5). On the basis of four SPDES effluent analytical reports by a certified laboratory, and thirty seven self-monitoring reports, fourteen parameters were found to be above guideline concentrations at least once during this period.

The July 2, 1993 self-monitoring test revealed an effluent tetrachloroethene level of .94 ug/l which is more than the allowable level of 0.7 ug/l. The reason for this exceedance of the standard has not been determined.

On September 10th, 15th and 17th, self-monitoring revealed nine parameters to be above guideline concentrations. Each of these analyses revealed high levels of tetrachloroethene, and cis-1,2, dichloroethene. The September 10th analysis also indicated a concentration of 1,1 dichloroethene higher than the allowable standard. The September 17th tests revealed unacceptable concentrations of 1,1 dichloroethene and trichloroethylene. The September 15th, 1993 SPDES tests also revealed an unacceptable level of tetrachloroethene. At the time of these high readings, later investigation of the daily logs revealed that air flow to the air stripper had been decreased apparently due to a loosened locking nut. The air flow was readjusted to normal levels and the concentrations decreased in subsequent tests. Tetrachloroethene concentrations decreased from greater than 30 ppb to less than 1 ppb but were still found to be above the guideline concentration of 0.7 ppb in the tests conducted on September 24th and 27th. Similar tetrachloroethene results continued to be demonstrated throughout the months of

# TEMPORAL VARIATION IN FACILITY INFLUENT VOC CONCENTRATIONS

TOTAL VOC's    BENZENE    VINYL CHLORIDE    TETRACHLOROETHENE  
 1,1 DICHLOROETHENE    TRICHLOROETHENE    cis-1,2 DICHLOROETHENE





FIGURE 3

SIXTH OPERATIONAL QUARTER, 1993  
 TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY


# TEMPORAL VARIATION IN WELLFIELD TOTAL VOC CONCENTRATIONS



**SIXTH OPERATIONAL QUARTER, 1993**

**TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY**

# TEMPORAL VARIATION IN TREATMENT EFFICIENCY



SIXTH OPERATIONAL QUARTER, 1993  
TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY



October and November. In December, it was discovered that samples taken directly from the air stripper revealed acceptable levels of tetrachloroethene while those samples taken from the effluent pipe leading out of the treatment plant (via a sampling tap) still showed unacceptable levels of tetrachloroethene. This apparent contradiction led to the hypothesis that the tubing leading from the sample tap may have become contaminated and could therefore be causing falsely high readings of tetrachloroethene concentrations. The tubing was replaced and the tetrachloroethene concentrations returned to levels below the allowable limits.

In the sixth operational quarter, thirteen of the fourteen incidents of effluent concentrations of organics in excess of the allowable guidelines occurred on or following the period when air flow through the air stripper had been accidentally restricted.

Figure 2 depicts the Effluent Average of 6.35 ppb as well as an "Adjusted Effluent Average", which is the average of all test results except those that occurred during the three September days when the air stripper was not adjusted correctly, for comparison. This "Adjusted Effluent Average" illustrates that the sixth quarter's increase in effluent VOC concentration average was mainly due to the high readings that were observed on September 10, 15 and 17, 1993. In fact, this "Adjusted Effluent Average" of 1.05 ppb showed that a significant decrease in facility effluent VOC concentration was demonstrated over the majority of the quarter.

Excepting that period in September when airflow was restricted, the air/water ratio has been maintained higher than 60/1 called for in the manufacturer's design literature. Higher air/water ratios typically will improve to a degree air stripper efficiency to a degree simply by contacting greater volumes of air with the stripper influent. Occasionally, additional efficiency can be gained as greater air volumes force the downward flow more evenly across the diameter of the vessel, thus minimizing channeling and "dead" spots in the packing. Some evidence of channeling was evident during an inspection made in February 1993.

Also, a high awareness exists among operating personnel regarding maintenance of the stripper internals through observation of the tower packing, where iron deposit fouling can cause a drop in process efficiency. The initial acid washing of the tower internals was performed on March 14, 1992 and removed all visible signs of deposits. In the sixth quarter, the fourth "acid wash" took place on August 25, 1993. Additional "acid washes" will be performed as required.

On the basis of four analytical reports from a certified laboratory (Appendix E) and monitoring performed at the Town laboratory (Appendix D), no inorganic parameters were found to be above guideline concentrations. Air flow to the stripper tower had been increased during the second quarter in anticipation of oxidizing additional soluble iron to a precipitate form on the packing media. Iron deposits on the packing are removed during scheduled acid washing of the stripper tower as described previously.

Therefore, on the basis of the analytical work performed, no additional treatment units are currently required to remove iron or other trace inorganic constituents, since all applicable guideline values are consistently satisfied.

A review of the sixth quarterly air stripper emissions data (Appendix F) indicates that the air stripper continues to operate as designed. Tests results, from samples taken at the stack, indicate that there is one compound, tetrachloroethene, that exceeds the specified discharge concentration limit based on the Consent Decree. Since the Consent Decree has been signed and construction began on the Groundwater Treatment Facility, the applicable air discharge limitations were revised, effective June 1991. More recently, the Town has been advised by NYSDEC of certain clarifications to Air Guide No. 1 pertaining to tetrachloroethene (PCE). In April 1993, the Town was advised that NYSDEC will apply the ambient air guidelines at the

OBSWDC property line to determine if the air stripper stack discharge is acceptable. The quarterly test of model validity was conducted, although the background concentrations adjoining the site were too high to allow verification. However, the measured stack discharge rates during the second quarter were below those monitored during the previous quarter tests, and based on those test results, the facility continues to operate within the NYSDEC ambient guidelines at the property line. An annual summary utilizing all four quarterly tests will be prepared at the end of the second year of monitoring to verify the facility operated within the NYSDEC ambient air guidelines at the property boundary.

#### 5.1.2 Hydraulic Control of the VOC Plume

As discussed in Section 4.4.1 hydraulic control of the VOC plume had been demonstrated during the July and August 1993 hydraulic monitoring rounds. Furthermore, although the capture zone was smaller during the September round, the known extent of the VOC plume was also captured during this round. The capture zone was smaller in September because the pump in Remediation Well No. 1 was electrically shorted by flooding on August 9, 1993 and remained down through the rest of the sixth quarter. Since the limiting flow lines were found to be at or near their limit to demonstrate capture of the plume during September with one well down (see Figures 8 and 9 in Appendix G), two remediation wells off-line simultaneously would imply that the plume was not being captured. This criteria was used to evaluate whether or not effective hydraulic containment of the VOC plume was maintained during the sixth operating quarter.

A review of the pumpage records for the individual recovery wells revealed that during the sixth operating quarter, there were four occasions where two or more wells were down simultaneously for a period of more than 24 hours; wells RW-1 and RW-3 from July 10th to July 12th, wells RW-1 and RW-5 from July 30th to August 2nd, all wells off from August 28th to August 30th, and wells RW-1 and RW-4 August 28th to September 8th, 1993. Since approximately 90% of

drawdown recovery at the site occurs within 24 hours after a pump is turned on or off, shut down time less than 24 hours will not have a significant effect on hydraulic control of the VOC plume. In the cases where one well (in addition to RW-1) was off-line for two or three days most groundwater would move away from that well for approximately one or two days, but would be recaptured in one or two days after the well was turned back on. After the 11 day period where wells RW-1 and RW-4 were off-line simultaneously, it would take approximately 10 days (i.e. 10 feet of linear flow at 1 ft/day) to recapture the plume water and reestablish equilibrium pumping conditions in the aquifer.

The above analysis indicates that hydraulic containment of the full extent of the plume was questionable on several occasions, for short durations of time, during the sixth operating quarter. However hydraulic control of the VOC plume was re-established within a short period of time after the well or wells were turned back on, with no significant effect on the plume boundaries. Under these circumstances, the major consequence of shutting down a well or wells is that plume remediation would be slowed down, ultimately increasing the operating costs and delaying attainment of the zero slope condition.

#### 5.1.3 Remediation of Potential Groundwater Plumes from Other Sources

In addition to monitoring influent and effluent conditions at the facility, the Town regularly monitors VOC concentrations at each recovery well. This analytical data collected during the sixth quarter (Appendix C) indicates that a general trend in total VOC concentrations at recovery wells RW-1, RW-2 and RW-3 was not apparent, for the entire sixth quarter. However, total VOC's showed a slight increasing and decreasing trend in wells RW-4 and RW-5 respectively (see Figures 9 and 10).

The analysis also indicated that recovery wells RW-1, RW-2, RW-3 AND RW-5 showed their highest concentrations of total VOC's during period between the last week in July and the first week in August, as shown in Figures 6,7,8 and 10. Recovery Well No. 4 also showed a peak in Total VOC concentrations during this period. However this well demonstrated its highest total VOC concentration later on in the quarter, as shown in Figure 9. Consistant with sampling data from the first operating year, the general trend in total VOC's for the recovery system and more specifically, VOC trends in wells RW-4 and RW-5, could be correlated to the variation in concentrations of tetrachloroethene. Tetrachloroethene has been linked to contamination of groundwater near the former Claremont Polychemical site, northeast of the OBSWDC site.


Excluding results from wells OBS-1 and OBS-2, a comparison of the fifth and sixth quarterly rounds revealed an approximate decrease of 25% in total VOC's. This significant decrease in total VOC's is largely the result of a decreases in total VOC concentrations in Wells 7B and 8A. Monitoring wells 7B and 8A are located hydraulically downgradient of the former Claremont Polychemical Facility and showed a decrease in tetrachloroethene concentrations from 168 ug/l and 441 ug/l to 91 ug/l and 323 ug/l, respectively, since the fifth quarter. The decrease in tetrachloroethene concentrations in monitoring well 7B, located within the immediate area of capture around RW-3, may be the result of the groundwater remediation which has taken place for the last five quarters; the decrease in tetrachloroethene in well 8A apparently indicates a decrease in the source concentration. Well 8A is a shallow well located adjacent to the southern boundary of the former Claremont Polychemical site.

A groundwater flow rate of approximately two feet per day has been estimated for the area within the capture zone (based upon groundwater flow model data and hydraulic gradients during pumping). With continued pumping, as the tetrachloroethene-concentrated plume in the vicinity of well cluster 8 (located near the south side of the Claremont Polychemical facility) moves

\* Data for the entire quarter was not available because Recovery Well No. 1 was incapacitated on August 9, 1993 by flooding.

## TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No. 1


—●— TOTAL VOC\*      —■— BENZENE      —□— VINYL CHLORIDE      —◆— TETRACHLOROETHENE  
 —◇— 1,1 DICHLOROETHANE      —▲— TRICHLOROETHENE      —△— cis-1,2 DICHLOROETHENE



SIXTH OPERATIONAL QUARTER, 1993  
TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

FIGURE 6

# TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No. 2



SIXTH OPERATIONAL QUARTER, 1993  
TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

FIGURE 7

# TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No.3





FIGURE 8

SIXTH OPERATIONAL QUARTER, 1993  
TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY



# TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No. 4




SIXTH OPERATIONAL QUARTER, 1993  
TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

FIGURE 9

# TEMPORAL VARIATION IN VOC CONCENTRATIONS AT RECOVERY WELL No. 5

TOTAL VOC's    BENZENE    VINYL CHLORIDE    TETRACHLOROETHENE  
 1,1 DICHLOROETHANE    TRICHLOROETHENE    cis-1,2 DICHLOROETHENE



SIXTH OPERATIONAL QUARTER, 1993  
 TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY


closer to Recovery Wells, RW-4 and RW-5, concentrations of VOCs should begin to show an increasing trend in those wells at some time in the future.

Close inspection of Figures 6 through 10 indicates that the groundwater composition around each production well exhibits a unique chemical "signature" defined both by chemical species and concentration. Recovery wells RW-1, RW-2 and RW-3 are heavily influenced by VOC's known to be in the plume from OBSWDC, whereas the VOC's in wells RW-4 and RW-5 are almost entirely composed of tetrachloroethene, a compound previously noted only in trace amounts on and around the OBSWDC.

A known Superfund site, the Claremont Polychemical manufacturing and storage facility, is located near the northernmost part of what has been identified as the tetrachloroethene plume (see Appendix G, Fig. 12). Tetrachloroethene is a major contaminant historically associated with that site. Furthermore, groundwater and contaminant flow patterns have been shown to travel southeastward or downgradient from the Claremont Polychemical site and is intercepted by Recovery Wells, RW-4 and 5. Geographically, the Claremont Polychemical facility is closest to Recovery Well No. 5, the distance increasing to Recovery Well No. 4, No. 3, etc., and the recorded concentration levels of tetrachloroethene decline with increasing distance from the site. This relationship is illustrated in Figure 11.

Representatives of the various regulatory agencies and other interested parties have been alerted to this phenomenon. However, additional hydrogeological study is required to better establish the link which apparently exists between elevated VOC levels in certain recovery wells and the Claremont Polychemical facility.

# TEMPORAL VARIATION IN WELLFIELD TETRACHLOROETHENE CONCENTRATIONS



SIXTH OPERATIONAL QUARTER, 1993

TOWN OF OYSTER BAY GROUNDWATER TREATMENT FACILITY

FIGURE 11

## 5.2 Recommendations

### 5.2.1 Groundwater Treatment Facility

Certain enhancements performed to the facility control system during the preceding quarter helped to increase on-line performance significantly. Continued quantitative maintenance and facility improvements will be implemented as required.

Under the current operating conditions, the analytical results compiled during this quarter do not support the need for additional groundwater or air stripper exhaust treatment units at this time.

In addition to maintaining and enhancing the facility operation as previously discussed, the Town will continue the GTF monitoring programs put into place since startup. This data, collected from a variety of sources, will form the basis for future facility improvements or adjustments, as required.

### 5.2.2 Groundwater Monitoring Program

The sixth quarterly monitoring data that was evaluated in this report indicates that with the possible exception of short periods of time when two or more remediation wells were down simultaneously for repairs or maintenance, effective hydraulic control was maintained and as a result, hydraulic monitoring can be reduced from monthly to quarterly without significant concern. The NYSDEC should be notified with regards to this proposed change in the monitoring program.


However, to ensure that the largest possible capture zone is created and effective control of the VOC plume maintained, the pumpage in recovery well RW-2 should be kept at a maximum capacity while repairs are completed on RW-1.

The groundwater sampling program should be continued without change. As the upcoming October 1993 sampling round, the proposed hydraulic (water level) monitoring should be timed to coincide with the quarterly groundwater sampling round.

Wells 9A and OBS-1 should be repaired or replaced so that water levels can be measured year-round and groundwater samples collected in those wells.

## APPENDIX A

### Location Plan





## **APPENDIX B**

**Daily Operations Reports  
July 1 through September 30, 1993**

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-01-11
DATE:	7-1-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	219	241	216	205	232	1072	1054	1095	1066 40	NOT	524	LLOYD
12 AM	218	243	216	204	236	1074	1058	1098	1016 40	WORKING	66	DOUGLIS
1 AM	218	241	215	203	235	1074	1061	1256	10943 20		135	
2 AM	219	241	216	203	236	1072	1062	1078	10943 20		204	
3 AM	218	241	214	204	236	1073	1063	1083	10943 20		270	
4 AM	218	242	214	203	236	1072	1063	1093	10943 20		334	
5 AM	217	240	214	203	235	1072	1065	1095	10943 20		401	
6 AM	217	241	214	204	234	1072	1064	1250	10943 20		469	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-01-13
DATE:	7-1-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	220	244	216	206	209	1055	1053	1090	10590.00	NOT	520	LLOYD	
4 PM	220	244	216	207	212	1059	1052	1088	9813.40	WORKING	66	CAVALLARO	
5 PM	230	242	216	205	216	1062	1053	1076	9813.40		132		
6 PM	218	242	215	203	224	1066	1053	1086	10166.40		198		
7 PM	217	240	216	204	235	1074	1055	1083	10166.40		262		
8 PM	217	242	213	204	236	1073	1060	1093	9813.40		327		
9 PM	219	242	214	203	236	1072	1061	1088	9813.40		396		
10 PM	219	241	213	202	232	1072	1062	1095	10166.40		461		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE ID:	93-07-02-11
DATE:	7-2-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	217	242	214	203	232	1071	1073	1101	10943.00	28.1	5.20	S. HADLER		
12 AM	218	241	213	204	236	1072	1065	1123	10943.00	28.1	6.4	D. QUINN		
1 AM	217	240	214	203	236	1071	1064	1077	10943.00	28.1	1.30			
2 AM	218	240	214	203	236	1071	1064	1085	10943.00	28.1	1.92			
3 AM	217	242	214	204	235	1071	1065	1092	10943.00	28.1	2.57			
4 AM	216	240	215	204	232	1071	1065	1099	10943.00	28.1	3.23			
5 AM	216	240	212	203	232	1071	1063	1074	10943.00	28.1	3.89			
6 AM	217	241	214	203	236	1071	1063	1077	10943.00	28.1	4.61			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

REMARKS

NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-07-02-12
DATE:	07-02-93

WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	214	242	214	202	232	1071	1064	1085	10943.00	not	523	ABR/AMS
8 AM	217	242	213	202	232	1071	1065	1092	10543.00	working	62	CAUSA
9 AM	217	242	214	204	235	1070	1065	1086	7977.10		128	
10 AM	218	241	215	204	232	1071	1065	1100	7977.10		195	
11 AM	216	240	213	203	235	1070	1065	1072	8472.00		266	
12 PM	219	242	214	204	232	1071	1065	1083	9107.40		330	
1 PM	217	241	213	203	235	1071	1065	1090	9389.20		394	
2 PM	218	241	215	204	232	1071	1064	1096	9389.80		461	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-03-11
DATE:	7-3-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	216	241	214	203	234	1070	1063	1090	10543	Down	532	K. Walters		
12 AM	219	242	214	203	232	1071	1064	1095	10590	}	65	H. Han		
1 AM	217	241	213	203	235	1070	1064	1100	10590		132			
2 AM	217	241	215	202	232	1070	1064	1071	10943		203			
3 AM	217	241	214	203	236	1071	1065	1083	10590		266			
4 AM	216	243	213	203	235	1071	1065	1091	10590		330			
5 AM	216	240	214	203	236	1070	1064	1097	10943	V	337			
6 AM	217	242	216	203	236	1070	1065	1264	11296		462			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### DAY SHIFT

FILE ID:	93-07-03-12
DATE:	7-3-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISORY OPERATOR INITIALS		
7 AM	216	242	214	204	236	1070	1066	1025	10590 <sup>00</sup>	OFF	534	Nix		
8 AM	216	240	212	203	235	1070	1065	1084	10162 <sup>40</sup>	✓	62	Cape		
9 AM	218	242	212	203	232	1071	1064	1091	10590 <sup>00</sup>		127	"		
10 AM	216	240	212	204	233	1070	1065	1097	10590 <sup>00</sup>		192	"		
11 AM	217	241	214	204	236	1069	1064	1251	9813 <sup>40</sup>		259	"		
12 PM	217	241	213	204	233	1070	1064	1076	9813 <sup>40</sup>		328	"		
1 PM	216	240	213	202	232	1091	1064	1086	10166 <sup>40</sup>		392	"		
2 PM	216	240	212	203	236	1070	1065	1092	10166 <sup>40</sup>	✓	457	"		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	98-07-3-13
DATE:	7-3-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	218	240	212	202	236	1070	1064	1097	10590.0	0.5"	5.23	Nix		
4 PM	216	240	213	204	236	1071	1065	1241	10166.4	↑	6.8	Capeh		
5 PM	218	241	212	203	236	1070	1065	1078	10590.0		13.4	"		
6 PM	217	240	212	202	234	1070	1065	1083	10943.00		14.9	"		
7 PM	217	242	214	202	236	1070	1066	1093	10590.0		26.4	"		
8 PM	219	243	215	203	236	1071	1066	1098	10590.0		33.0	"		
9 PM	218	242	215	203	235	1070	1065	1070	9389.0		40.1	"		
10 PM	216	240	215	203	236	1070	1065	1080	9513.0	↑	46.4	"		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-04-11
DATE:	7-4-93

WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	218	241	214	203	236	1070	1065	1087	983	40	Down	528	SCHADLER
12 AM	217	241	214	203	236	1070	1065	1093	1016	40		65	Hilton
1 AM	216	241	214	204	236	1071	1066	1256	1016	40		130	
2 AM	216	243	214	204	236	1071	1066	1071	10943			201	
3 AM	217	241	212	202	236	1072	1066	1078	10943			266	
4 AM	216	242	212	204	234	1071	1067	1090	10943			330	
5 AM	217	242	214	203	236	1071	1066	1096	10943			396	
6 AM	218	241	213	204	232	1071	1067	1240	10943			467	
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### DAY SHIFT

FILE ID:	93-07-04-12
DATE:	7-4-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	218	243	215	202	232	1071	1065	1075	12002.00	OFF	533	Dir
8 AM	216	241	214	204	232	1071	1066	1082	11649.00	↓	62	Carey
9 AM	218	241	214	203	236	1071	1064	1091	10590.00		127	"
10 AM	218	242	214	204	232	1073	1065	1095	10590.00		192	"
11 AM	219	243	212	203	236	1073	1065	1068	10166.00		263	"
12 PM	216	241	213	203	235	1073	1065	1078	9813.00		326	"
1 PM	219	242	215	204	236	1073	1065	1084	10166.00		393	"
2 PM	219	242	214	203	233	1073	1066	1088	10166.00	↓	456	"
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-04-13
DATE:	7-4-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	218	241	214	203	236	1093	1066	1250	1066.40	0.75	525	Nix
4 PM	216	242	216	202	235	1073	1065	1072	9813.40	↑	67	Caper
5 PM	219	241	212	203	235	1073	1066	1082	10166.40		130	..
6 PM	217	241	213	204	236	1075	1065	1098	9813.40		197	..
7 PM	218	241	214	203	236	1074	1066	1096	9813.40		262	..
8 PM	217	242	214	204	232	1094	1065	1228	10166.40		331	..
9 PM	216	242	214	202	235	1074	1066	1079	10590.00		398	..
10 PM	217	241	215	204	236	1094	1067	1088	10943.00	↓	460	..
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### NIGHT SHIFT

FILE ID:	93-07-05-11
DATE:	7-5-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
11 PM	217	240	212	202	232	1074	1066	1090	12002	DOWN	526	Rodgers			
12 AM	217	241	213	203	236	1074	1067	1256	12002		67	Al Hume			
1 AM	218	241	214	204	236	1074	1066	1072	11649		137				
2 AM	218	241	214	203	236	1073	1066	1083	10943		199				
3 AM	218	242	212	202	232	1073	1066	1090	10166		264				
4 AM	217	243	214	204	236	1074	1066	1095	10590		329				
5 AM	218	241	214	204	232	1073	1067	1235	9813		400				
6 AM	218	242	213	204	236	1074	1067	1078	10590		465				
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-05-12
DATE:	7-5-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	218	243	214	201	236	1073	1065	1088	9813.40	0.8	528	Aix		
8 AM	216	241	213	202	234	1073	1065	1088	11649.00	1	64	Cape13		
9 AM	217	242	214	203	236	1073	1065	1239	11649.00	1	130	Abrams		
10 AM	216	241	214	204	235	1073	1065	1072	11296.00	1	199	11		
11 AM	217	241	214	203	236	1073	1064	1078	10943.00	1	264	11		
12 PM	219	242	214	203	236	1074	1064	1040	10943.00	1	329	11		
1 PM	218	242	214	204	234	1073	1065	1214	9813.40	1	394	11		
2 PM	216	242	213	203	234	1074	1066	1068	10943.40	1	466	11		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-05-13
DATE:	7-5-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3PM	217	243	214	203	235	1075	1062	1077	9389.80	NOT WORKING	528	SCHADLER	
4PM	216	241	213	204	234	1074	1061	1085	9813.40		62	CAVALIERO	
5PM	216	241	213	203	235	1075	1065	1095	9813.40		126		
6PM	218	243	214	204	236	1075	1065	1092	9813.40		195		
7PM	217	242	216	203	236	1075	1067	1077	9813.40		260		
8PM	218	242	214	202	232	1074	1065	1085	9389.80		325		
9PM	216	241	213	204	232	1074	1063	1092	9813.40		389		
10PM	217	242	216	204	236	1075	1066	1237	9813.40		462		
11PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE ID:	93-27-06-11
DATE:	7-6-93

WELLFIELD OPERATION											AIR STRIPPER OPERATING PARAMETERS			
GALLONS PER MINUTE														
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	219	242	214	202	234	1073	1065	1075	9813.4°	working	527	SCADLER		
12 AM	220	240	214	202	234	1073	1065	1085	9813.4°		64	DOUWELS		
1 AM	217	242	213	204	233	1074	1065	1087	9813.4°		187			
2 AM	218	242	214	203	234	1074	1067	1083	9813.4°		198			
3 AM	216	242	215	203	233	1073	1066	1034	10116.4°		263			
4 AM	216	240	213	202	232	1073	1066	1079	10166.4°		330			
5 AM	216	240	213	204	232	1073	1065	1088	10166.4°		396			
6 AM	218	242	213	202	236	1074	1065	1247	10590.0°		459			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-06-12
DATE:	7-6-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	218	241	214	202	233	1073	1065	1062	11649	DOWN	527	ABE/MS		
8 AM	216	241	214	204	233	1073	1065	1075	11296		66	14/10/93		
9 AM	216	242	212	204	234	1073	1065	1088	10166.40		128			
10 AM	217	241	213	204	234	1072	1065	1239	10166.40		196			
11 AM	217	243	214	204	233	1073	1064	1067	10590		265			
12 PM	217	241	215	201	233	1073	1066	1080	10590		329			
1 PM	217	242	213	204	235	1073	1066	1089	10166.40		394			
2 PM	216	242	215	201	234	1072	1064	1241	10166.40		461			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.





# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-06-13
DATE:	7-6-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	217	243	314	202	232	1075	1058	1075	9813.40	Not	526	Schadler	
4 PM		266	235	226	250	945	1025	1079	9813.40	working	63	Cavallaro	
5 PM		268	235	220	251	943	1017	1087	9813.40		120		
6 PM		267	234	221	252	941	1012	1085	9389.80		178		
7 PM		266	236	220	252	945	1025	1093	9389.80		235		
8 PM		266	234	219	234	940	1050	1097	9389.80		290		
9 PM		264	234	220	249	940	1021	1089	9389.80		348		
10 PM		268	235	221	229	922	1047	1094	9389.80		408		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

15 15 #1 WELL OFF FOR REPAIR

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-07-11
DATE:	7-7-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	OFF	270	239	223	208	910	566	1070	9813 <sup>40</sup>	NOT	471	LEOYD	
12 AM		268	240	224	263	905	1039	1097	9813 <sup>40</sup>	WORKING	57	DOUGLASS	
1 AM		264	234	220	251	943	1015	1090	10166 <sup>40</sup>		112		
2 AM		265	233	219	251	938	1060	1078	9813 <sup>40</sup>		165		
3 AM		264	232	220	251	944	1023	1093	9813 <sup>40</sup>		226		
4 AM		264	236	221	234	925	1037	1074	10166 <sup>40</sup>		288		
5 AM		266	236	221	251	944	1006	1085	9813 <sup>40</sup>		345		
6 AM	✓	265	232	226	257	945	575	1080	9813 <sup>40</sup>	✓	398		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 Well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FIELD:	93-07-07-12
DATE:	07-07-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISORY OPERATOR INITIALS	
7 AM	000	264	236	222	224	920	1059	686	10590.00	Not	454	Hilton	
8 AM	000	265	235	220	227	918	1037	681	11649	working	58	ABRAMS	
9 AM	231	000	237	224	232	912	576	1067	11649		120		
10 AM	240	000	238	224	215	900	568	1072	11649		181		
11 AM	241	—	236	224	227	916	1021	1095	12002.00		230		
12 PM	243	000	237	224	226	917	1002	1086	9107.40		286		
1 PM	242	—	236	224	204	894	1030	1089	9389.80		339		
2 PM	242	000	238	224	211	899	1036	1097	9389	✓	395		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

Well #1 Down  
Well #1 Back on line at 0900  
Well #2 Down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-07-13
DATE:	7-7-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	240	OFF	236	224	219	905	1014	1090	9389.80	Not	449	Schadler		
4 PM	240		234	220	244	927	1049	1083	9813.40	Working	54	Cavallaro		
5 PM	238		233	220	252	930	1040	1076	9813.40		115			
6 PM	240		235	222	251	934	1051	1080	9389.80		175			
7 PM	239		237	219	250	935	1009	1089	9813.40		230			
8 PM	238		234	220	250	932	1044	1097	10166.40		283			
9 PM	238		233	220	250	929	1059	1082	9813.40		339			
10 PM	240		237	222	230	915	1040	1078	9813.40		397			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#2 WELL OFF For Repair

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FIELD:	93-07-08-11
DATE:	7-8-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	237	064	234	219	249	930	1057	715	9813 1/2	107	460	LLOYD
12 AM	240		236	220	252	936	1021	1095	9389 80	102K106	51	DOUGLIS
1 AM	240		235	220	251	929	1062	1082	9389 84		107	
2 AM	240		232	220	250	930	1032	1070	9813 40		163	
3 AM	240		235	220	252	928	1060	1080	9813 40		221	
4 AM	240		233	218	252	931	1045	1120	9813 40		278	
5 AM	240		236	221	251	934	557	1036	9813 40		340	
6 AM	240		236	219	251	931	1006	1087	9813 40		398	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#2 OFF FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-08-07-12
DATE:	07-08-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	236	OFF	233	220	244	923	1045	1056	9813.40		450	ABP/MS		
8 AM	237		232	216	250	925	1053	1079	12294.40		57			
9 AM	236		233	218	250	924	1037	0002	11649.00		116	Capoek		
10 AM	237	260	OFF	219	249	931	997	1084	11296.00		178	" "		
11 AM	234	260	OFF	219	248	928	1026	1092	11296.00		230	" "		
12 PM	Plant 1	15	260	219	248	928	1026	1092	11296.00		270	" "		
1 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF		—	" "		
2 PM	OFF	279	OFF	232	217	0697	0551	0001	11637.40			" "		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

WELL #2 SHUT DOWN FOR REPAIRS  
 920 AM # 2nd ON LINE - FLOW 360  
 920 AM # 3rd ON LINE  
 Plant went down 11:50

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-08 - 13
DATE:	7-8-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS				
3 PM	227	252	OFF	213	242	896	992	1086	9813.40	NOT	16	LLOYD				
4 PM	227	252		212	240	895	1046	1073	9813.40	WORKING	53	CAVALLO				
5 PM	229	252		214	244	902	1052	1072	10166.40		106					
6 PM	232	256		216	248	914	1022	1096	10166.40		166					
7 PM	234	260		219	248	925	995	1082	9813.40		225					
8 PM	236	260		221	252	932	1019	1086	10166.40		282					
9 PM	236	260		222	252	932	1034	1094	10166.40		337					
10 PM	236	261		220	249	927	1050	1078	10166.40		395					
11 PM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						

#### REMARKS

#3 WELL OFF FOR REPAIR

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	23-07-09-11
DATE:	JULY 9, 1983

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	238	260	OFF	221	248	832	586	2002	10166 <sup>40</sup> / <sub>40</sub>	Not Watering	459	SCHROEDER	
12 AM	237	261	✓	221	249	832	576	1076	10166 <sup>40</sup> / <sub>40</sub>	✓	57	Dawney	
1 AM	237	260	✓	220	252	834	1026	1026	10166 <sup>40</sup> / <sub>40</sub>	✓	112		
2 AM	236	262	✓	220	251	830	1018	1054	9813 <sup>40</sup> / <sub>40</sub>	✓	168		
3 AM	236	261	✓	221	250	834	1001	1085	9389 <sup>40</sup> / <sub>40</sub>	✓	224		
4 AM	235	261	✓	220	249	929	572	1065	9813 <sup>40</sup> / <sub>40</sub>	✓	293		
5 AM	237	260	✓	220	250	932	1026	1093	10166 <sup>40</sup> / <sub>40</sub>	✓	342		
6 AM	236	262	✓	219	250	931	1014	1094	10166 <sup>40</sup> / <sub>40</sub>	✓	399		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#3 WELL OFF FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-09-12
DATE:	9 July 1993

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	234	259	OFF	219	249	926	864	1684	10939	NOI	453	ABRANS
8 AM	236	257	OFF	219	248	923	0002	0002	11649	WORKING	069	CADEN
9 AM	233	258	OFF	219	249	925	1028	1082	11649.00	1	116	NIX
10 AM	236	262	OFF	220	249	932	571	1082	11296.00		180	"
11 AM	236	261	OFF	220	249	930	1020	1087	10943.00		233	"
12 PM	234	260	OFF	220	249	928	1035	1092	10943.00		289	"
1 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF		303	"
2 PM	OFF	278	OFF	233	244	724	1028	1242	10590.00	V	337	"
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS #3 Well is off for repairs

PLANT is down @ 12:15  
POWER DET.  
PLANT is on line @ 1320 hrs  
#2 Well is off

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-09-13
DATE:	7-9-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE NOTES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	228	256	227	0 FT	248	915	1038	1097	9813.40	NOT	383		
4 PM	232	255	228		246	917	1027	1092	10166.40	WORKING	53		
5 PM	233	259	231		250	927	1062	1084	10166.40		110		
6 PM	237	260	232		251	939	1024	1091	10590.00		168		
7 PM	236	261	233		252	943	1032	1099	10166.40		227		
8 PM	236	260	233		251	942	1023	1092	9813.40		282		
9 PM	237	262	236		236	930	1017	1080	9813.40		340		
10 PM	238	264	236		232	930	1038	1089	9813.40		400		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#4 WELL OFF FOR REPAIR

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-08-90-11
DATE:	7-10-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
11 PM	238	260	234	R	253	946	1028	1092	10590	Down	46.2	Rodgers			
12 AM	236	261	233	E	252	943	1016	1089	10943		62	H. Hon			
1 AM	238	261	234	P D	252	945	580	1072	1291989		119				
2 AM	237	261	233	A O	252	945	1026	1094	11649		176				
3 AM	236	261	233	I W	252	943	1043	1098	10943		231				
4 AM	240	264	236	R N	216	926	1034	1069	938980		287				
5 AM	236	262	234	S	252	947	998	1083	938980		356				
6 AM	237	262	233		253	945	1030	1092	938980		407				
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### DAY SHIFT

FILE ID:	93-07-18-12
DATE:	7-10-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	236	261	234	0FF	252	942	1041	1098	11296.00	0FF	465	Nix		
8 AM	235	259	283	0FF	252	941	1033	1085	11649.00	↑	54	Capelet		
9 AM	234	262	234	0FF	252	946	1000	1080	11296.00		119	..		
10 AM	236	260	233	0FF	252	943	1030	1093	10590.00		173	..		
11 AM	236	260	232	0FF	252	942	1050	1098	10590.00		229	..		
12 PM	236	260	233	0FF	252	940	578	0001	10590.00		293	..		
1 PM	237	262	235	0FF	252	947	1008	1087	10166.00		351	..		
2 PM	236	262	233	0FF	252	943	1043	1096	10590.00	✓	406	..		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#4 Well is OFF

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-07-10 13
DATE:	7-10-93

WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	236	261	232	OFF	251	940	1024	1079	10166.4%	OFF	465	Nix
4 PM	238	263	232	OFF	253	948	561	1095	10590.0%	↓	61	Caret
5 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF		86	..
6 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF		95	..
7 PM	OFF	391	OFF	OFF	228	486	567	6674	9107.4%		112	..
8 PM	OFF	279	OFF	229	259	735	572	675	10166.4%		143	..
9 PM	OFF	276	OFF	228	258	739	569	678	9389.8%		184	..
10 PM	OFF	280	OFF	232	259	742	586	685	9813.4%		230	..
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS 01640 Hrs

Shut down Plant due to lightning storm.

Plant on line @ 1835 Hrs

# 1000

# 3000

# 4000

on line # 4000 see 4000 Hrs.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07.11-11
DATE:	7.11.93

WELLFIELD OPERATION												AIR STRIPPER OPERATING PARAMETERS			
GALLONS PER MINUTE															
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WVC	EFFLUENT FLOW MGALS	SUPERVISOR'S OPERATOR INITIALS			
11 PM		281		233	241	744	573	683	10164.40		275	RODEAS			
12 AM		280		233	260	746	573	678	10590.00		0.048	SCHADLER			
1 AM		280		235	260	749	588	685	10590.00		0.091				
2 AM		282		236	262	747	579	683	10943.00		0.139				
3 AM		283		235	264	751	573	679	10943.00		0.183				
4 AM		282		236	262	751	595	684	10166.40		0.233				
5 AM		284		237	264	757	557	1086	10166.40		0.283				
6 AM		285		237	264	757	1038	682			0.322				
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

#### REMARKS

#1 & #3 WELLS OFF DUE TO WATERING  
SYSTEM

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-11-12
DATE:	7-11-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	OFF	284	OFF	236	265	759	1050	1048	1052.0	OFF	369	Nix
8 AM	OFF	288	OFF	240	264	762	1042	1080	1016.0	1	50	Cape15
9 AM	OFF	287	OFF	240	266	763	1012	1095	9389.80		46	
10 AM	OFF	288	OFF	240	265	765	1026	1099	9107.0		144	
11 AM	OFF	287	OFF	236	267	762	1023	1093	1016.0		192	
12 PM	OFF	286	OFF	234	265	761	574	1086	1129.0		239	
1 PM	OFF	285	OFF	236	264	752	603	675	9807.0		296	
2 PM	OFF	283	OFF	236	264	759	1006	1090	1016.0	1	331	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

# 1 Well 1 is OFF  
# 3 Well 1 is OFF

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.  
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	2307-11-18
DATE:	7-11-23

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	387	OFF	237	264	758	1042	1098	1066.40	OFF	378	NIX		
4 PM	OFF	285	OFF	236	264	758	574	1083	10596.00	✓	48	2005		
5 PM	OFF	288	OFF	237	264	757	569	1074	10530.00		95	"		
6 PM	OFF	284	OFF	238	264	757	563	1070	10166.10		144	"		
7 PM	OFF	288	OFF	235	246	742	567	1074	9813.10		189	"		
8 PM	OFF	284	OFF	236	265	757	573	0002	10166.40		236	"		
9 PM	OFF	284	OFF	237	264	757	565	1073	10166.10		280	"		
10 PM	OFF	287	OFF	240	245	741	573	0001	10943.00	✓	325	"		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 Well 11 is OFF

#3 Well 11 is OFF

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### NIGHT SHIFT

FILED:	93.07.12.11
DATE:	7.12.93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	077	284	077	237	264	757	576	683	10943.00	Not working	370	SchADLER	
12 AM	✓	284	✓	237	265	756	577	682	10166.40		50	Deunelis	
1 AM		284		236	264	757	1039	680	10166.40		98		
2 AM		283		236	264	757	581	684	10943.00		137		
3 AM		285		236	263	757	681	681	10943.00		185		
4 AM		284		238	264	760	566	1063	10943.00		231		
5 AM		286		247	263	758	1047	685	10943.00		278		
6 AM	✓	283	✓	236	264	761	1012	1092	10943.00	✓	328		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 & #3 wells off due to lightning storm

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FIELD:	93-0712-12
DATE:	7-12-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISORY OPERATOR INITIALS		
7 AM	000	288	000	236	264	759	1020	1083	1263740		373	ABGMS		
8 AM	000	283	000	236	264	758	1046	687	10590	D	45	14 km		
9 AM	000	286	000	238	264	758	1033	686	10943	0	94			
10 AM	000	284	000	240	265	762	1015	1094	1016640	N	141			
11 AM	000	288	000	239	264	763	556	1688	628340	N	190			
12 PM	000	287	000	239	265	763	1001	1091	11649		238			
1 PM	000	286	000	240	265	762	565	1084	12002	V	286			
2 PM	233	259	219	222	000	903	572	1094	10943		333			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

Wells #1 & #3 Down for repairs  
WELL #1 ON AT 1:30  
WELL #3 ON AT 1:30  
WELL #5 Down for REPAIR AT 1:30

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-12-13
DATE:	7-12-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
3 PM	233	258	232	220	OFF	914	1006	1088	10590.00	NOT	388	Schadler			
4 PM	233	258	232	219		913	1017	1092	10166.40	working	54	Cavallo			
5 PM	232	258	232	218		911	1034	1098	10166.40		108				
6 PM	232	256	231	219		910	1030	1092	10166.40		164				
7 PM	232	259	228	220		909	1019	1084	9813.40		219				
8 PM	233	259	232	220		915	1032	1086	10166.40		277				
9 PM	234	259	231	220		915	1011	1093	10166.40		334				
10 PM	233	259	232	219		914	1006	1087	10166.40		393				
11 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

#### REMARKS

#5 WELL OFF FOR REPAIR

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-13-11
DATE:	7-13-93

WELLFIELD OPERATION										AIR STRIPPER OPERATING PARAMETERS				
GALLONS PER MINUTE														
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	232	258	232	220		912	1032	1094	10943	DOWN	449	LEOYD		
12 AM	232	257	232	219	DR	911	1040	1097	12002		53	141KWO		
1 AM	234	260	232	220	DE	910	574	002	1263740		108			
2 AM	232	259	232	220	WP	909	1046	673	11296		167			
3 AM	234	260	232	220	NA	916	1005	1088	106640		228			
4 AM	235	256	232	219	TI	912	568	1069	106640		286			
5 AM	233	259	231	220	R	915	562	1085	1016640		340			
6 AM	233	260	232	220	S	916	1010	1091	1016640		400			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-13-13
DATE:	7-13-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	234	259	226	219	OFF	910	1011	1069	10590.00	20.5	450	SCHADLER		
4 PM	233	259	232	220		913	1032	1070	10166.40	20.6	58	CAVALLARO		
5 PM	234	261	231	221		915	1008	1087	10166.40		115			
6 PM	233	260	232	219		913	1030	1095	10590.00		168			
7 PM	234	260	232	219		913	1022	1091	10590.00		223			
8 PM	232	259	229	219		910	1047	1084	10590.00		280			
9 PM	234	258	229	219		909	1052	1080	10590.00		336			
10 PM	232	259	232	219		912	1041	1078	10590.00		396			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#5 WELL OFF FOR REPAIR

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-14-11
DATE:	7-14-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	236	260	232	220	OFF	917	1002	1084	10590.00	NOT	454	KL0YD
12 AM	235	261	231	220		915	1014	1090	10590.00	working	55	CAVALLARO
1 AM	232	257	232	220		910	1044	1092	10590.00		109	
2 AM	233	257	232	220		912	1007	1087	10590.00		166	
3 AM	232	260	231	220		912	1049	1092	10166.40		220	
4 AM	234	260	232	220		913	1024	1090	10166.40		283	
5 AM	232	257	232	219		910	1009	1084	10590.00		340	
6 AM	233	258	231	219		913	1017	1089	10590.00		380	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#5 WELL OFF FOR REPAIR

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-14-12
DATE:	07-14-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	234	260	231	220	000	915	1013	1039	11246.00	Not	451	ABP/mm		
8 AM	233	259	228	219	000	913	1032	1095	12002	working	54	H.H.		
9 AM	232	260	228	220	000	910	1034	1084	10943		107			
10 AM	233	259	229	219	000	910	1038	1081	10590		165			
11 AM	234	263	232	000	024	913	1020	1094	10590		226			
12 PM	236	264	235	000	007	896	1028	1088	10590		280			
1 PM	236	260	232	000	231	913	1020	1094	10590		334			
2 PM	235	260	232	000	240	931	570	1075	9389	✓	397			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

Well #5 Down for repairs  
Well #5 out at 10:30 AM  
Well #4 off for 2 hours 10:53 AM

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-14-13
DATE:	7-14-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	235	260	232	OFF	251	939	1007	1094	9813.40	NOT	455	SCHADLER	
4 PM	234	261	232		249	937	1025	1099	9389.82	WORKING	56	Cavalier	
5 PM	234	260	232		248	935	1031	1092	9813.40		110		
6 PM	236	262	233		250	940	1017	1091	9813.40		170		
7 PM	234	260	232		249	938	1013	1096	10166.40		229		
8 PM	235	261	231		248	937	1035	1102	10166.40		285		
9 PM	233	260	232		248	933	1040	1097	9813.40		344		
10 PM	235	264	232		248	941	1000	1092	9813.40		404		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#4 WELL OFF FOR REPAIR

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-15-11
DATE:	7-15-93

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	234	260	232	OFF	249	938	1021	1090	748360	1205	460	LLOYD		
12 AM	235	260	232	1	249	935	1041	1098	84732	1202106	59	Hickson		
1 AM	236	263	232	1	249	941	560	1088	938980	1	115			
2 AM	234	261	232	1	250	940	1009	1083	10943	1	178			
3 AM	236	260	232		250	937	1030	1093	10943		234			
4 AM	233	260	231		249	934	586	0001	11619		289			
5 AM	235	261	232	1	249	940	1015	1090	12002	1	352			
6 AM	234	261	232	1	248	938	1018	1089	112960	1	408			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#4 Well Down For Repair

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-15-12
DATE:	07-15-93

WELLFIELD OPERATION											AIR STRIPPER OPERATING PARAMETERS				
GALLONS PER MINUTE															
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
7 AM	242	260	232	000	244	936	1042	1089	1200.00	105+	465	Dennis			
8 AM	234	260	229	000	244	933	1037	1081	126374000	105	53	10/24/93			
9 AM	235	262	232	000	245	946	1012	1087	1263740		115				
10 AM	236	261	231	000	249	937	1020	1087	107000		1108				
11 AM	235	260	230	000	248	935	1031	1042	1059000		224				
12 PM	231	260	232	000	250	939	510	1066	1064300		289				
1 PM	235	264	232	000	253	940	1017	1090	1074500		395				
2 PM	240	265	000	202	251	930	1086	1088	1074300		400				
3 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

#### REMARKS

Well #4 down for repairs  
 Well #3 down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-15-13
DATE:	7-15-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	240	267	OFF	193	252	924	1009	1073	10590.00	NOT	454	Schadler
4 PM	239	268		193	252	923	1002	1070	10166.40	working	62	Cavallaro
5 PM	239	268		203	252	925	1012	1089	10166.40		119	
6 PM	240	267		195	251	923	1016	1085	10166.40		174	
7 PM	236	264		210	249	930	1036	1092	9813.40		230	
8 PM	238	264		207	250	928	1052	1087	9813.40		283	
9 PM	240	266		212	250	929	1040	1080	9813.40		343	
10 PM	240	268		192	253	923	1003	1085	9813.40		402	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#3 Wkl Down For Repair

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-16-11
DATE:	7-16-95

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS				
11 PM	233	266	000	200	252	910	1026	1087	1066 40	DOWN	459	KLGD				
12 AM	240	268	000	194	252	915	1033	1074	9107 40		54	HLN				
1 AM	234	267	000	196	251	911	1034	1076	9813 40		118					
2 AM	240	267	000	203	252	912	576	677	1016 40		120					
3 AM	238	267	000	201	252	926	565	1085	10596		229					
4 AM	240	268	000	195	252	923	1021	1091	1016 40		284					
5 AM	240	267	000	196	252	923	1031	1083	9813 40		338					
6 AM	240	268	000	191	252	923	1002	1084	9389 30		392					
7 AM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						

#### REMARKS

#3 well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	43	07-16-12
DATE:	07-16-93	

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	239	265	000	196	249	907	587	000	12637.40	Net	44.1			
8 AM	212	268	055	191	352	919	1012	1044	12637.40	working	56	ABR/pms		
9 AM	240	269	000	192	262	924	997	1081	12637.40		12.1	A. R.		
10 AM	258	268	000	164	362	923	1011	1037	12637.40		17.5			
11 AM	239	269	035	198	250	925	1128	1091	12637.40		23.5			
12 PM	240	267	000	202	250	923	1033	1030	12637.40		28.3			
1 PM	239	267	000	197	250	907	1028	1091	12637.40		33.3			
2 PM	240	268	000	204	251	925	565	1081	12637.40		40.2			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

Well #3 Down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-16-13
DATE:	7-16-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS				
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	240	267	OFF	192	251	915	1024	1080	10590.00	NOT	462	SCHADLER
4 PM	240	268	1	198	252	926	1011	1085	10590.00	working	52	(Avallaro)
5 PM	239	267	1	194	252	914	1029	1091	10590.00		101	
6 PM	240	268		191	252	918	1007	1092	10166.40		157	
7 PM	240	268		206	251	925	1010	1089	10166.40		215	
8 PM	240	268		195	252	923	1003	1083	9813.40		273	
9 PM	240	267		200	252	927	1018	1088	9813.40		328	
10 PM	239	267	1	196	251	922	1033	1094	10166.40		385	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#3 Well Down For Repair

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-17-11
DATE:	7-17-93

WELLFIELD OPERATION							AIR STRIPPER OPERATING PARAMETERS						
GALLONS PER MINUTE													
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW M.GALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	239	265	000	198	250	908	10388	1064	10943	Down	445	P. Lucas	
12 AM	239	267	000	194	252	914	565	10722	10943		56	Whit	
1 AM	240	267	000	196	252	924	1013	10872	10166 45		114		
2 AM	240	268	000	194	252	923	1021	1091	9813 40		169		
3 AM	237	267	000	204	251	927	1028	1086	10166 40		229		
4 AM	237	265	000	193	250	911	1041	1066	10590 00		280		
5 AM	240	266	000	201	251	921	1040	0002	10166 40		323		
6 AM	239	268	000	200	251	912	561	1087	10166 40		398		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FIELD:	93 07-17-12
DATE:	7-17-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	240	268	OFF	196	253	915	1009	1090	10590.00	4.07	456	Nix
8 AM	240	268	1	197	253	920	1010	1084	10943.00	working	54	Phyllis
9 AM	238	266	1	196	251	922	1034	1087	10590.00	1	105	
10 AM	240	267	1	198	249	923	1034	1071	10590.00	1	157	
11 AM	240	266	1	195	249	914	1019	1070	10590.00	1	217	
12 PM	239	269	1	192	253	916	1003	1082	10943.00	1	276	
1 PM	240	267	1	192	252	912	1019	1087	10943.00	1	232	
2 PM	240	268	1	196	252	919	1011	1090	10966.40		290	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#3 Well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-17-13
DATE:	7-17-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	236	268	000	201	252	904	582	001	981340	Down	442	A.V.	
4 PM	240	267	000	196	252	905	584	001	10590		56	H.H.	
5 PM	240	268	055	206	252	923	000	1090	116640		147		
6 PM	237	265	000	204	249	918	1031	1087	10943		169		
7 PM	240	266	000	197	253	921	1040	1021	981340		229		
8 PM	240	268	000	196	252	911	1006	1085	938980		288		
9 PM	240	267	000	205	252	928	1015	1090	938980		343		
10 PM	240	267	000	201	252	915	1014	1086	938980		398		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

# 3 Well Down For Repairs

Hi Heri Stiles + 1 OT

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### NIGHT SHIFT

FILED:	23-07-18-11
DATE:	7-18-23

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	240	266	044	196	251	912	1033	1091	1066 <sup>40</sup> / <sub>2</sub>	Not	450	LLORD SS
12 AM	240	268		194	252	913	568	1076	10166 <sup>40</sup> / <sub>2</sub>	Working	56	W. J. T. C.
1 AM	240	268		203	253	918	1011	1089	12637 <sup>40</sup> / <sub>2</sub>		117	
2 AM	240	268		192	252	917	1009	1085	12637 <sup>40</sup> / <sub>2</sub>		174	
3 AM	235	267		202	251	923	1039	1084	12627 <sup>40</sup> / <sub>2</sub>		229	
4 AM	240	267		196	252	914	1026	1092	12002 <sup>40</sup> / <sub>2</sub>		288	
5 AM	240	268		194	250	910	1029	1086	11649 <sup>40</sup> / <sub>2</sub>		341	
6 AM	237	264		199	248	920	1045	1074	11649 <sup>40</sup> / <sub>2</sub>		396	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#3 Well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### DAY SHIFT

FILE ID:	93-07-18-12
DATE:	7-18-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	240	268	OFF	202	251	913	1007	1067	10590.00	NST	460	Nix
8 AM	240	267	1	198	251	920	1018	1091	10943.00	working	56	Cavallaro
9 AM	236	268		200	251	913	1010	1084	10166.40		110	
10 AM	240	266		203	252	916	1025	1087	10590.00		163	
11 AM	236	267		197	251	905	1042	1092	10590.00		219	
12 PM	240	266		205	249	916	1007	1067	10590.00		277	
1 PM	240	268		193	252	916	1002	1081	10943.00		334	
2 PM	240	267		203	251	922	1013	1087	10943.00		392	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#3 Well Down For Repair

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-18-13
DATE:	7-18-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	238	267	OFF	196	252	912	1026	1092	1016.40	NOT	447	NIX
4 PM	240	268	1	197	252	917	1040	1087	1016.40	Working	55	Cavalier
5 PM	238	268	1	200	251	920	1022	1058	1016.40	1	109	
6 PM	239	265	1	202	251	918	1011	1062	9813.40	1	169	
7 PM	240	268	1	203	252	921	1010	1088	9813.40	1	227	
8 PM	240	269	1	192	251	912	1009	1084	9813.40	1	284	
9 PM	240	267	1	199	252	915	1035	1087	10166.40	1	339	
10 PM	240	266	1	204	250	920	1046	1070	10166.40	1	393	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#3 WELL Down For Repair

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-19-11
DATE:	7-19-93

WELL FIELD OPERATION												AIR STRIPPER OPERATING PARAMETERS											
GALLONS PER MINUTE																							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW M.GALS	SUPERVISOR/ OPERATOR INITIALS											
11 PM	240	269	055	198	252	920	578	682	10943 <sup>00</sup>	NOT	451	LLOYD											
12 AM	240	268		199	252	925	1006	1080	10943 <sup>02</sup>	WORKING	58	DOUGLAS											
1 AM	239	267		200	252	926	1015	1083	10943 <sup>04</sup>		116												
2 AM	238	268		197	249	921	1039	1093	10166 <sup>06</sup>		170												
3 AM	240	268		194	252	924	558	1087	10166 <sup>08</sup>		257												
4 AM	240	265		203	250	917	1044	1060	10166 <sup>10</sup>		280												
5 AM	237	268	✓	193	252	915	574	1065	10166 <sup>12</sup>	✓	344												
6 AM	240	266	✓	197	257	912	560	1065	9389 <sup>14</sup>	✓	401												
7 AM																							
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA													

#### REMARKS

#3 Well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-19-12
DATE:	7-19-83

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	240	268	000	192	252	911	1013	1082	11296	Down	454	M. J. Jones		
8 AM	240	267	000	204	252	922	1027	1088	11296		54	M. J. Jones		
9 AM	240	268	000	192	251	917	1048	1074	11649		109			
10 AM	240	268	000	205	250	922	567	1068	11296		165			
11 AM	218	244	200	201	234	1058	1028	1080	9813 40		229			
12 PM	244	000	208	192	256	882	570	675	9107 40		287			
1 PM	245	000	207	140	254	884	581	0001	6918 30		344			
2 PM	244	000	200	200	253	883	574	0001	7977 30		400			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#3 Well Down For Repair 11:28  
#3 Well On At 10:25 AM  
#2 Well Down For Repair 11:08

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-19-13
DATE:	7-19-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS				
3PM	245	OFF	192	263	255	881	1009	1067	9359.82	NOT	455	SCHADLER				
4PM	244		196	197	256	879	1047	1065	9389.82	working	55	CHALLARE				
5PM	248		199	205	256	886	1010	1082	10166.40		109					
6PM	245		206	191	255	883	1007	1078	10166.40		162					
7PM	248		192	205	256	887	1011	1084	10166.40		214					
8PM	241		196	203	256	883	1018	1091	10590.00		268					
9PM	245		205	198	254	881	1024	1057	10590.00		320					
10PM	246		208	194	256	883	1014	1087	10590.00		377					
11PM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						

#### REMARKS

#2 Well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-20-11
DATE:	7-20-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	245	OFF	208	193	255	885	1032	1084	12002.00	NOT	432	22010
12 AM	245		193	203	254	890	1018	1087	12002.00	WORKING	53	Dave
1 AM	266		206	OFF	232	674	1011	674	12002.00		97	
2 AM	267		193		204	631	580	678	10943.00		141	
3 AM	270		187		224	661	1037	682	10943.00		182	
4 AM	269		201		243	667	1028	0001	10943.00		227	
5 AM	268		192		254	681	1032	673	10943.00		268	
6 AM	270	V	198	V	243	664	584	676	1016.00	V	307	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#2 well off for repairs  
#4 shut down at 12:30 AM, Hansen checked

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-01-20-12
DATE:	7-20-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	269	000	213	000	204	702	569	680	8472	DOWN	349	HCH/MS		
8 AM	268	000	211	000	217	701	575	673	9107 1/2		45	HCH/MS		
9 AM	265	000	200	000	246	707	1035	676	9813 1/2		85			
10 AM	268	000	194	000	195	674	582	676	13837 1/2		121			
11 AM	245	000	204	204	219	855	573	678	7977 80		164			
12 PM	248	000	197	200	219	857	580	0001	12002 00		219			
1 PM	247	000	206	195	216	848	1038	1077	7977 80		268			
2 PM	249	000	204	189	222	857	1023	1087	11296		322			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#2 well down for repairs  
#4 well down at 12:30 am  
#4 well on at 10:49 am

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-20-13
DATE:	7-20-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS				
3 PM	248	OFF	204	194	213	850	1018	1088	10943.00	NOT WORKING	376	SCHADLER				
4 PM	248		205	200	208	847	1028	1088	10943.00		373	CATHLINE				
5 PM	248		198	199	223	853	1019	1086	10943.00		105					
6 PM	248		200	204	213	848	1019	1088	10590.00		158					
7 PM	251		206	196	217	863	1015	1092	10166.40		212					
8 PM	251		195	207	207	860	1008	1086	9813.40		264					
9 PM	249		191	207	218	857	1003	1085	NOT WORKING		318					
10 PM	248		205	193	223	863	1021	1089	8020.00		370					
11 PM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						

#### REMARKS

#2 WELL DOWN FOR REPAIRS  
AIR FLOW GAUGE NOT REGISTERING. IS AT ZERO.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILED: 93-07-21-11  
DATE: 7-21-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS				
11 PM	248	055	206	190	237	871	561	1081	7977 <sup>90</sup>	NOT	430	LECID				
12 AM	248		191	207	239	874	1023	1088	9813 <sup>40</sup>	WEEK 16	58	DOUGLAS				
1 AM	246		193	205	256	893	1014	1087	9813 <sup>40</sup>		114					
2 AM	245		201	196	256	883	564	1084	14120 <sup>00</sup>		166					
3 AM	244		204	194	252	887	525	1063	1200 <sup>00</sup>		218					
4 AM	244		197	204	253	835	1044	1090	11649 <sup>00</sup>		229					
5 AM	243		203	196	255	878	1022	1087	9385 <sup>00</sup>		330					
6 AM	256	V	204	192	246	886	1019	1086	9387 <sup>00</sup>	V	383					
7 AM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93 07-21-12
DATE:	07-21-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	244	000	195	205	256	887	1623	1090	11296.02	100t	438	H.L. Ton
8 AM	248	000	204	191	254	888	1008	1085	12002.02	working	54	ABRAMS
9 AM	246	000	204	193	256	892	1027	1088	12002.02		105	
10 AM	245	000	201	194	256	883	1033	1091	11296.02		162	
11 AM	246	000	203	193	256	888	1005	1083	11296.02		217	
12 PM	243	000	201	200	254	887	1032	1087	10943.02		269	
1 PM	245	000	204	193	252	888	1032	1090	11649.02		324	
2 PM	243	000	197	203	252	884	1038	1066	11649.02	✓	376	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Well #2 Down for repairs

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-21 - 13
DATE:	7-21-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	245	OFF	192	200	253	874	1048	1092	10943.00	Not	430	Schadler
4 PM	244	1	193	205	254	890	1039	1093	10943.00	Well King	55	Cavallaro
5 PM	243	1	202	201	252	887	1027	1086	11296.00		110	
6 PM	244	1	204	204	252	884	1044	1072	10943.00		164	
7 PM	245		204	193	253	883	1027	1070	10590.00		218	
8 PM	243		204	194	254	884	1043	1075	10166.40		271	
9 PM	244		196	204	256	885	1032	1072	10166.40		327	
10 PM	244		206	195	253	884	1048	1089	10590.00		385	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#2 Well Down For Repairs

#### NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### NIGHT SHIFT

FILED:	93-07-22-11
DATE:	9-22-83

WELLFIELD OPERATION GALLONS PER MINUTE											AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
11 PM	245	6FF	202	194	253	882-	1011	1088	10943 <sup>00</sup>	NOT WORKING	438	LEWIS			
12 AM	246	✓	192	207	255	887	1003	1080	10943 <sup>00</sup>	✓	56	DEWELLS			
1 AM	244		200	192	256	890	580	10943	10943 <sup>00</sup>		113				
2 AM	247		196	203	256	889	573	1089	10943 <sup>00</sup>		166				
3 AM	244		192	204	254	890	1023	1100	9813 <sup>40</sup>		223				
4 AM	246		191	201	256	887	1024	1023	9813 <sup>40</sup>		282				
5 AM	244	✓	195	204	252	882	1043	668	9813 <sup>40</sup>		333				
6 AM	245	✓	202	200	253	899	524	1083	1016 <sup>40</sup>	✓	384				
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

#### REMARKS

WELL #2 Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-22-12
DATE:	07-22-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	245	000	205	192	256	890	1009	1090	12002.00	not	437	Lebrake
8 AM	245	000	207	192	256	888	1013	1034	12002.00	working	53	ABRAMS
9 AM	246	000	194	204	254	888	1000	1091	12002.00		100	
10 AM	248	000	200	191	255	894	1011	1093	10413.00		160	
11 AM	246	000	195	204	255	885	1013	1093	10943.00		244	
12 PM	246	000	195	200	256	890	1008	1093	11649.00		269	
1 PM	244	00	204	190	286	887	1017	1093	11645.00		321	
2 PM	245	000	202	197	253	883	1019	1093	11645.00	✓	378	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Well # 2 Down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-22-13
DATE:	7-22-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	244	OFF	204	196	255	883	1018	1089	10943.00	NOT	431	Rodgers		
4 PM	244		196	194	256	888	1021	1092	10590.00	Working	54	Cavallaro		
5 PM	245		206	196	256	885	1024	1094	10166.40		107	Lloyd		
6 PM	244		194	206	252	887	1025	1090	10166.40		162			
7 PM	244		205	199	256	887	1030	1089	9813.40		213			
8 PM	244		205	192	256	884	1030	1086	9813.40		269			
9 PM	246		194	204	251	893	1015	1086	9813.40		327			
10 PM	242		205	204	252	885	1035	1090	6918.80		378			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#2 Will Down For Repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-23-11
DATE:	7-23-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS				
11 PM	244	OFF	203	191	254	888	1044	1083	7483.60	NOT	4/29	LLOYD				
12 AM	243	1	195	204	252	883	1040	1083	9387.10	WECKING	57	DOUGLAS				
1 AM	240	1	204	202	253	883	1044	1064	9384.80	1	109					
2 AM	244		200	197	253	878	585	685	9107.40	1	166					
3 AM	241		198	205	253	886	1044	683	9389.20		220					
4 AM	244		196	205	254	886	574	676	9384.80	1	281					
5 AM	244		204	190	254	883	585	685	9389.50		334					
6 AM	244	✓	206	190	255	888	567	1071	9166.90	✓	387					
7 AM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						

#### REMARKS

# 2 Wells Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FIELD:	93-07-23-12
DATE:	07-23-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	244	000	192	203	256	888	575	0002	12002.00	not	439	CAPEK		
8 AM	244	000	203	193	251	875	585	0001	12637.00	working	55	ABRAMS		
9 AM	244	000	202	200	252	879	577	0001	12637.00		111			
10 AM	244	000	193	206	252	887	575	0001	10592.00		168			
11 AM	244	000	197	196	256	882	576	675	11296		223			
12 PM	244	000	197	203	252	885	569	670	12384		279			
1 PM	246	000	203	191	256	889	565	1666	12002.00		331			
2 PM	244	000	194	201	256	884	567	1075	11649.00	✓	385			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

Well #2 Down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-23-13
DATE:	7-23-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	244	OFF	204	204	253	894	1042	1086	10943.00	NOT	440	SCHADLER
4 PM	247	1	203	201	256	889	1004	1082	10943.00	working	54	CAVALARO
5 PM	245	1	199	195	255	885	1010	1085	10590.00	1	107	
6 PM	244	1	194	203	255	882	1016	1089	10590.00	1	160	
7 PM	245	1	201	199	256	885	1014	1081	10166.40	1	212	
8 PM	245	1	198	198	256	883	1030	1086	10590.00	1	266	
9 PM	245	1	198	197	254	883	1023	1085	10590.00	1	322	
10 PM	246	1	196	205	255	881	560	1081	10590.00	1	380	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#2 Well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-24-11
DATE:	7-24-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	248	1	196	196	235	888	1014	1085	10983.00	Not working	433	SCHADLER
12 AM	244		193	203	253	889	1045	1070	11649.00		44	Drumelis
1 AM	247		196	195	251	885	561	1079	10166.00		110	
2 AM	243		198	203	256	887	1041	1080	10943.04		268	
3 AM	244		199	196	252	879	1034	1034	10943.00		203	
4 AM	246		200	193	254	888	1038	1074	10943		258	
5 AM	244		202	200	254	883	1034	1088	10943.00		318	
6 AM	244	1	197	203	253	886	1041	1083	10166.40		374	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

# 2 well off for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

## DAILY OPERATIONS WORKSHEET

### DAY SHIFT

FILED:	93-67-24-12
DATE:	7-24-93

[illegible]

## REMARKS

H. Leitch Dean Ferrell's.

## NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93--07-24-13
DATE:	7-24-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	244	015	199	205	254	880	581	1001	1016.4	not blank	437	Nix		
4 PM	246	015	196	197	256	887	575	1001	1059.5	✓	54	Capet		
5 PM	244	015	200	193	255	885	573	1057	1059.7		111	"		
6 PM	244	015	200	200	256	885	576	1041	1016.4		165	"		
7 PM	244	015	206	200	252	889	569	1064	1016.4		220	"		
8 PM	245	015	205	191	251	886	566	1064	1016.4		273	"		
9 PM	244	015	197	196	256	887	568	1072	1059.5		327	"		
10 PM	245	015	203	190	254	888	561	1079	9813.40	✓	382	"		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 well is down for repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-25-11
DATE:	July 25, 1993

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	244	OFF	191	204	254	883	562	1069	9823 <sup>40</sup>	No. 1 Wetdry	437	Rodgers
12 AM	247		203	193	256	891	1007	1082	10166 <sup>42</sup>		52	Donnelis
1 AM	244		195	204	252	886	1027	1092	10743 <sup>40</sup>		104	
2 AM	244		201	200	254	888	1009	1083	9813 <sup>40</sup>		159	
3 AM	245		191	203	256	885	1006	1084	10166 <sup>40</sup>		213	
4 AM	246		196	204	256	883	1024	1090	10580 <sup>40</sup>		45	
5 AM	243		200	207	252	887	1028	1086	9813 <sup>40</sup>		320	
6 AM	243		195	204	255	885	1021	1085	9813 <sup>40</sup>		375	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Well #2 Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-07-25-12
DATE:	7-25-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISORY OPERATOR INITIALS
7 AM	244	CFE	197	203	253	885	1026	1090	1202.00	1072.00	428	Nix
8 AM	241	CFE	196	198	256	894	1016	1085	1094.00	1	54	Capet
9 AM	245	CFE	192	205	252	886	1020	1083	1129.00		109	"
10 AM	244	CFE	204	195	252	885	1027	1090	1129.00		163	"
11 AM	243	CFE	204	193	256	884	1019	1086	1094.00		215	"
12 PM	245	CFE	192	206	256	880	1023	1085	1094.00		270	"
1 PM	211	CFE	200	204	254	886	1034	1096	1094.00		326	"
2 PM	244	CFE	198	196	254	883	1030	1083	1016.00		376	"
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Well 1 is down for repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-C7-25 13
DATE:	7-25-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	244	111	204	192	253	887	1034	1081	9813.4	20.2	4.32	Nix		
4 PM	244	075	199	204	252	882	1042	1077	10162.4	1	54	Cape		
5 PM	244	115	204	194	252	880	1035	1063	9813.4	1	107	..		
6 PM	244	111	205	203	248	881	1038	1069	10166.4	1	164	..		
7 PM	248	115	204	188	232	859	1050	1063	10166.4	1	214	..		
8 PM	248	115	204	195	235	861	1034	1067	9384.8	1	268	..		
9 PM	248	115	192	205	219	860	1035	1067	9127.4	1	298	..		
10 PM		OK	TO	Shut	down	M.R.	2015:	Hrs	—	↓	—	..		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

At 2:00 PM is down for repairs.  
 4:15 PM is down @ 9:15 PM  
 See log 3-11

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE ID:	93-07-26-11
DATE:	7-26-93

WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM										NOT		LLBYD
12 AM										WORKING		DEWELLIS
1 AM												
2 AM												
3 AM												
4 AM												
5 AM												
6 AM												
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

PUMP SEVERED

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



TOWN OF OYSTER BAY  
DEPARTMENT OF PUBLIC WORKS  
GROUNDWATER TREATMENT FACILITY

DAILY OPERATIONS WORKSHEET  
DAY SHIFT

FILE ID: 95-07-26-12  
DATE: 7-26-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS				
7 AM		Down								Down		H. Hor				
8 AM		Foil										Pharmas				
9 AM		Repaired														
10 AM	240	000	203	195	202	826	1026	1088	1327280		36					
11 AM	240	000	202	193	205	828	1024	1086	1383740		88					
12 PM	243	000	199	194	204	830	583	445	14120		132					
1 PM	245	000	200	199	204	851	1015	1088	1355530		193					
2 PM	248	000	197	204	209	844	1062	1079	1327280		248					
3 PM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						

REMARKS

Plants down for repairs  
#3 + #4 + #5 closed 5/7/93 AT 9:15 AM  
#1 well situated AT 9:32 AM  
#2 well down for repairs

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-26-13
DATE:	7-26-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	247	215	197	204	222	856	1004	1067	11296.00	1.05	3.00	SCHADLER		
4 PM	249	1	205	201	209	846	1027	1084	10590.00	working	50	Cavallaro		
5 PM	250	1	195	196	201	832	1011	1069	10590.00	1	98			
6 PM	252	1	197	204	214	844	1003	1064	10943.00	1	147			
7 PM	248	1	203	200	202	838	1041	1081	10590.00	1	199			
8 PM		1												
9 PM	215	1	190	199	218	583	1033	1092	10943.00	1	224			
10 PM	1	1	206	198	239	637	1027	1075	10590.00	1	262			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#2 Well Down for Repairs  
 2000 Gallons Secured. Flow gauges not working.  
 2100 Gallons Secured. #1 & #2 Wells off

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	23-07-27-11
DATE:	July 27, 1993

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	OFF	OFF	200	158	227	608	564	676	9813 <sup>40</sup>	40 <sup>1</sup> 1/2	302	LLOYD
12 AM	X	X	198	202	222	618	574	672	9823 <sup>40</sup>	X	357	DAVE
1 AM			201	188	220	614	580	665	10166 <sup>40</sup>		68	
2 AM			190	203	218	615	572	673	10378 <sup>40</sup>		108	
3 AM			190	203	236	619	582	674	10166 <sup>40</sup>		147	
4 AM			192	208	228	618	586	675	10166 <sup>40</sup>		183	
5 AM			208	196	220	621	558	674	10166 <sup>40</sup>		198	
6 AM	X	X	200	208	205	618	567	670	10166 <sup>40</sup>	X	264	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Wells #1-5 OFF

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	43-07-27-12
DATE:	07-27-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	000	000	197	208	241	636	575	670	12002.00	202	296	Lilston		
8 AM	000	000	000	000	000	000	000	000	000	working	000	ABRAMS		
9 AM	000	000	000	000	000	000	000	000	000		000			
10 AM	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF		0FF			
11 AM	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF		0FF			
12 PM	232	000	195	204	226	810	582	673	12002		20			
1 PM	236	0FF	202	205	223	857	585	679	14120.00		72			
2 PM	240	0FF	201	196	281	857	579	674	12002.00	✓	125			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

11/15 to 2.22 Down for repairs  
 11.23 Down Due to LIGHTNING 7.00 AM  
 11.23 DUES 344 BACK ON AND S  
 11.55 A1 with BACK ON

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-07-13
DATE:	7-07-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	240	OFF	204	196	247	875	1043	1072	10590.00	Not	178	SCHADLER		
4 PM	242	1	195	204	253	887	1044	1077	10943.00	Working	54	CAVALLARO		
5 PM	244	1	196	200	253	883	1032	1074	10943.00	1	108			
6 PM	242	1	196	202	256	881	1046	1075	10590.00	1	159			
7 PM	244	1	195	201	256	883	1049	1078	10590.00	1	214			
8 PM	245	1	205	201	251	889	1042	1075	10590.00	1	269			
9 PM	248	1	195	198	256	890	1036	1072	10166.40	1	326			
10 PM	248	1	196	201	254	891	1027	1070	10166.40	1	383			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#2 Well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-28-11
DATE:	July 28, 1993

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	248	051	201	194	235	888	1023	1022	10943 <sup>00</sup>	Not Working	438	LLOV1
12 AM	249	1	204	189	252	893	565	1079	10943 <sup>00</sup>	✓	54	10/2/93
1 AM	249	1	200	199	227	859	571	1066	10943 <sup>00</sup>	✓	109	
2 AM	251	1	195	198	224	869	563	1061	10943 <sup>00</sup>	✓	157	
3 AM	252	1	198	202	204	871	573	1061	9107 <sup>40</sup>	✓	208	
4 AM	252	1	193	204	228	862	1028	1064	9813	✓	262	
5 AM	257	1	191	201	222	863	1036	1067	6283 <sup>42</sup>	✓	312	
6 AM	250	1	204	190	226	865	1010	1084	7483 <sup>00</sup>	✓	365	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	43-01-28-12
DATE:	07-28-93

WELLFIELD OPERATION												AIR STRIPPER OPERATING PARAMETERS			
GALLONS PER MINUTE															
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW M.GALS	SUPERVISOR/ OPERATOR INITIALS			
7 AM	248	000	205	202	232	859	1048	1071	9389, 80	Not	363	Hilton			
8 AM	251	000	193	202	216	865	1027	1080	12637 40	working	52	ABRAMS			
9 AM	252	000	205	192	199	865	1045	684	7483, 60		105				
10 AM	251	000	206	192	222	862	1040	1072	12002		159				
11 AM	252	000	200	195	225	869	1018	1086	13555, 20		212				
12 PM	252	000	196	193	204	832	1028	1088	1107, 40		264				
1 PM	249	000	195	207	229	868	1035	1084	9813 40		318				
2 PM	252	000	196	205	211	851	1000	1080	10166, 40	✓	375				
3 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

#### REMARKS

Well #2 down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-07-28-13
DATE:	7-28-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	250	OFF	207	190	203	870	1007	1087	10590.00	NOT WORKING	424	SCHADLER		
4 PM	252		206	194	212	850	1011	1084	10166.40		54	Cavallaro		
5 PM	250		200	192	223	865	1003	1085	10166.40		105			
6 PM	251		199	200	213	862	1012	1089	10166.40		158			
7 PM	248		197	198	234	868	1004	1083	9813.40		213			
8 PM	251		196	200	228	864	1005	1087	10166.40		264			
9 PM	248		200	200	202	838	1054	1089	9813.40		315			
10 PM	252		203	194	229	869	577	1087	9813.40		365			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

#2 Well Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-29-11
DATE:	7-29-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	250	CE	192	207	214	853	581	680	11649 <sup>SC</sup>	NOT	417	LEOYD
12 AM	247		205	204	233	873	581	682	11649 <sup>SC</sup>	WORKING	51	DOUGLAS
1 AM	248		202	197	228	864	576	680	11649 <sup>SC</sup>		102	
2 AM	250		196	206	213	864	1035	1080	11649 <sup>SC</sup>		158	
3 AM	252		200	200	220	873	569	1073	12284 <sup>SC</sup>		210	
4 AM	248		192	206	228	871	1040	1068	12237 <sup>SC</sup>		265	
5 AM	Down		Due To	Lightning							269	
6 AM												
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

#### REMARKS

#2 Well Down For Repairs  
1-3-4-5 wells off due to lightning at 4:05

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FIELD:	13-07-29-12
DATE:	7-29-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISORY OPERATOR INITIALS		
7 AM	000	000	000	209	000	192	000	0001	842.00	Not	278	Cembrak E		
8 AM	000	000	000	000	000	0000	000	000	1066.40	working	000	ABRAMS		
9 AM	000	232	181	170	000	586	1036	682	1016.40		25			
10 AM	000	272	192	204	000	646	567	681	1066.40		34			
11 AM	000	280	202	193	000	651	564	1060	1016.40		120			
12 PM	000	280	193	200	000	652	582	612	1263.40		158			
1 PM	000	277	202	208	000	657	567	522	1263.40		199			
2 PM	000	280	200	186	000	657	1039	676	1263.40					
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

Well #1 1,3,5 down due to lighting  
Well #2 down for repairs  
Well #4 shut down as per M. Rogers  
Well #1 1,3,5 well not restart 8715  
Well #2 back on at 0850 Well #4 back on at 0905  
Well #3 back on at 0900

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID: 93-07-29-13  
DATE: 7-29-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	281	201	204	OFF	655	572	670	12284.40	0612.11	240	Schadler		
4 PM	OFF	281	197	194	OFF	655	568	0001	12002.05	1	42	Capey		
5 PM	OFF	280	207	188	OFF	653	585	692	10166.00		81	..		
6 PM	OFF	282	196	203	OFF	656	575	676	10166.40		120	..		
7 PM	OFF	282	200	208	OFF	664	558	1074	9389.80		164	..		
8 PM	OFF	281	201	192	OFF	653	576	668	9389.80		199	..		
9 PM	OFF	282	192	208	OFF	660	572	678	9803.40		241	..		
10 PM	OFF	285	207	188	OFF	660	1013	1016	10943.00		280	..		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

Wells #1 and #5 Down for Repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-07-30-11
DATE:	July 30, 1993

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	OFF	280	203	201	OFF	662	580	672	11649.00	NOT	321	
12 AM		284	194	204		657	581	672	12884.40	WORKING	39	
1 AM		284	192	200		665	565	1065	11649.00		79	
2 AM		285	194	193		648	577	677	9977.80		115	
3 AM		284	200	206		665	567	681	7977.80		162	
4 AM		283	194	203		661	583	672	7977.80		201	
5 AM		284	196	204		662	568	673	9389.80		240	
6 AM	✓	285	202	198	✓	661	1015	680	9389.80	✓	288	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FIELD:	93-07-30-12
DATE:	07-30-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	000	284	191	207	000	661	586	671	9389.22	not	323	LAPEK
8 AM	000	286	198	207	000	664	677	674	9389.00	working	41	ABRAMS
9 AM	000	282	208	191	000	663	561	0001	16943.00		85	NIX
10 AM	000	284	199	198	000	664	1028	671	11296.00		122	"
11 AM	000	283	200	188	000	656	598	676	11296.00		163	"
12 PM	000	284	200	208	000	663	567	0002	10166.00		207	"
1 PM	000	285	199	196	000	666	1051	672	10166.00		242	"
2 PM	000	284	195	190	000	650	571	671	10166.00	✓	284	"
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Well # 125 closed for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-30-13
DATE:	7-30-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	284	195	208	OFF	665	1049	1089	9813.40	NOT	329	Schubler	
4 PM		284	191	190		650	1032	1087	9389.80	working	34	Cavalero	
5 PM		287	192	209		667	1019	1092	9813.40		73		
6 PM		283	204	189		654	1007	1087	9389.80		117		
7 PM		284	204	192		662	1045	1084	9389.80		157		
8 PM		285	198	208		668	1032	1082	10166.40		198		
9 PM		283	194	210		667	1024	1080	9813.40		240		
10 PM		286	208	188		666	1019	1068	9813.40		279		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 & #5 Wells Down for Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93.07.31-11
DATE:	7.31-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM		284	192	195		653	578	675	106640		318	Schadler		
12 AM		284	200	207		667	568	680	105900		40	Huron		
1 AM		286	209	188		661	1024	684	109430		82			
2 AM		283	204	205		667	574	669	105900		122			
3 AM		283	206	188		656	568	677	109430		162			
4 AM		285	204	188		658	1023	684	10943		202			
5 AM		284	208	190		658	580	675	10943		243			
6 AM		285	196	208		666	563	676	10590		283			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

# 1 & 5 WELLS OFF FOR REPAIRS

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OJETER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	98-07-31-12
DATE:	2-31-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	0515	284	204	188	055	659	1205	1069	10590.00	207 20.4 in.	324	Nix
8 AM	0515	284	206	192	055	659	580	1016.00	10580.00	207 20.4 in.	40	Cape
9 AM	0515	284	196	208	055	669	1042	1062	10586.00		76	
10 AM	0515	285	205	187	055	656	572	669	10943.00		121	
11 AM	055	284	194	209	055	656	569	680	10943.00		162	
12 PM	055	284	188	210	055	662	1027	681	11296.00		201	
1 PM	055	284	192	211	055	661	578	674	11296.00		243	
2 PM	055	284	196	191	055	651	567	674	10943.00		282	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

# 1 and 45 wells off repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-07-31	13
DATE:	7-31-93	

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	OFF	286	190	210	OFF	666	1009	932	10943.00	not working	324	Dix
4 PM	OFF	284	206	192	OFF	661	580	675	11296.00		40	Caper
5 PM	OFF	284	205	195	OFF	665	570	679	11296.00		81	"
6 PM	OFF	284	198	208	OFF	668	1031	681	10943.00		121	"
7 PM	OFF	284	191	210	OFF	662	573	677	10359.00		161	"
8 PM	OFF	284	197	203	OFF	653	570	685	10396.00		202	"
9 PM	OFF	284	207	200	OFF	668	1020	686	9813.00		243	"
10 PM	OFF	282	205	198	OFF	665	579	678	10166.00		283	"
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 and #5 wells off repairs

#### NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# Daily Operations Report



TOWN OF OYSTER BAY  
DEPARTMENT OF PUBLIC WORKS  
GROUNDWATER TREATMENT FACILITY  
DAILY OPERATIONS REPORT

EVENING  
SHIFT

Jul 31 1993

## Well Field Operation (GPM)

Well 1 Well 2 Well 3 Well 4 Well 5 System Flow Stripper Pressure Flow Filter Flow Air Flow Blower Air Flow Pres Air Effluent Op

3 PM:	0	286	190	210	0	666	1009	932	10943	0	0.324	KN
4 PM:	0	284	206	192	0	661	580	675	11296	0	0.04	FC
5 PM:	0	284	205	195	0	665	570	679	11296	0	0.081	KN
6 PM:	0	284	198	208	0	668	1031	681	10943	0	0.121	FC
7 PM:	0	284	191	210	0	662	573	677	10590	0	0.161	KN
8 PM:	0	284	197	203	0	653	570	685	10590	0	0.202	FC
9 PM:	0	284	207	200	0	668	1020	686	9813.4	0	0.243	KN
10 PM:	0	282	205	198	0	665	579	678	10166.4	0	0.283	FC

AVG.:	0	284	200	202	0	663.5	741.5	711.63	10705	0		
-------	---	-----	-----	-----	---	-------	-------	--------	-------	---	--	--

Note: All flows are in GPM except Blower (CFM) and Effluent (Millions of gallons).  
Cumulative Effluent flow is periodically reset; other flows are instantaneous rates.

Operator remarks



Town of Oyster Bay Department of Public Works  
Groundwater Treatment Facility - Daily Operations Report

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE ID:	83-08-01-11
DATE:	8-1-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
11 PM	OFF	286	203	190	OFF	665	559	690	9813 49	107	325	LLOYD	
12 AM	↓	284	209	186	↓	658	575	673	9813 49	WORKING	39	HILTON	
1 AM	↓	284	205	199	↓	663	574	680	10590	↓	82		
2 AM	↓	286	193	188	↓	646	564	690	10590	↓	119		
3 AM	↓	284	196	194	↓	652	581	675	10943	↓	161		
4 AM		284	204	203		663	561	686	10590		200		
5 AM		284	200	207		657	1010	686	10590		241		
6 AM	✓	284	192	208	✓	666	1027	682	10590	✓	284		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

WELLS #1 and 5 DOWN FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF Oyster Bay DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-08-01-14
DATE:	8-1-93

TIME	WELTFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATION INITIALS
7 AM	OFF	283	211	187	OFF	661	579	677	10943.00	wt. 0.44	324	Nix
8 AM	OFF	283	188	206	OFF	656	562	685	10943.00		40	Cape
9 AM	OFF	284	208	188	OFF	664	1019	682	10943.00		80	"
10 AM	OFF	284	208	194	OFF	670	579	675	11296.00		120	"
11 AM	OFF	285	189	202	OFF	651	568	684	11649.00		161	"
12 PM	OFF	282	192	208	OFF	664	1040	678	11296.00		201	"
1 PM	OFF	283	204	193	OFF	670	572	676	10943.00		242	"
2 PM	OFF	285	199	198	OFF	661	569	684	10590.00		282	"
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 and #5 Wells Down for Repairs.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-01-13
DATE:	8-1-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	OFF	284	196	205	OFF	664	1019	685	1016.4	NT 26.4"	324	N i s
4 PM	OFF	284	195	201	OFF	664	578	676	1012.4	1	38	Cape A
5 PM	OFF	284	189	207	OFF	660	562	684	9813.4		79	..
6 PM	OFF	284	197	206	OFF	670	1015	683	1016.4		119	..
7 PM	OFF	284	205	190	OFF	660	580	676	1016.4		160	..
8 PM	OFF	284	196	187	OFF	654	1052	676	1039.0		199	..
9 PM	OFF	284	193	209	OFF	663	571	679	1059.0		241	..
10 PM	OFF	284	191	201	OFF	660	567	687	1059.0	✓	281	..
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 and #5 Wells Down for Repairs.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FIELD #	93-08-02-11
DATE	8-2-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	WESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW GALLS	SUPERVISOR OPERATOR INITIALS	
11 PM	Down	283	192	207	Down	662	584	675	10943 <sup>00</sup>	Down	324	LL0YD	
12 AM		284	206	191		660	558	1077	10443 <sup>00</sup>		40	HH10N	
1 AM		284	196	189		652	575	673	9813 <sup>40</sup>		81		
2 AM		284	208	193		665	573	682	9389 <sup>30</sup>		118		
3 AM		284	192	205		659	565	690	9389 <sup>30</sup>		160		
4 AM		282	208	207		673	1053	676	7977 <sup>80</sup>		200		
5 AM	✓	286	208	192	✓	663	561	687	7977 <sup>85</sup>	✓	241		
6 AM	✓	284	204	188		659	1029	680	7977 <sup>80</sup>		281		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 and #5 wells Down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

84107



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-08-02-12
DATE:	8-2-93

WELTFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
7 AM	Down	284	205	188	Down	657	580	677	7483 <sup>40</sup>	Down	322	ASZ/AMS	
8 AM		284	194	207		665	570	684	12002		41	HH/HL	
9 AM		283	209	195		668	1025	686	9813 <sup>40</sup>		81		
10 AM		284	192	200		661	577	672	12637 <sup>40</sup>		122		
11 AM		284	210	187		661	572	683	14120		163		
12 PM		285	208	190		664	981	690	11296		201		
1 PM	✓	284	193	209	✓	664	582	675	12637 <sup>40</sup>	✓	242		
2 PM	✓	284	192	208	✓	663	561	685	13272 <sup>40</sup>		284		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

WELLS #1 AND #5 DOWN FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-02-13
DATE:	8-2-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	285	208	194	OFF	663	581 <sup>1/2</sup>	675 <sup>1/2</sup>	10166.40	NOT	323	Rodgers	
4 PM		285	191	209		661	1047	1089	10166.40	Working	40	Caballero	
5 PM		284	198	190		660	574	672	9813.40		80		
6 PM		284	208	200		665	559	1065	10590.00		123		
7 PM		283	197	196		658	557	675	9107.40		161		
8 PM		283	196	209		667	572	680	9813.40		203		
9 PM		284	191	209		664	564	672	10590.00		245		
10 PM		284	208	186		658	580	671	10590.00		282		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 & #5 WELLS Down for REPAIRS.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-08-03-11
DATE:	8-3-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	MESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	OFF	284	209	186	OFF	661	562	680	1043.00	NOT	320	LLOYD
12 AM		283	207	192		665	580	1082	1200.28	WORKING	46	Downe
1 AM		284	194	197		668	583	672	1200.2		84	
2 AM		284	210	209		662	565	1067	1200.28		12.5	
3 AM		284	207	195		667	1048	671	1129.00		16.7	
4 AM		284	191	207		659	576	674	938.95		204	
5 AM		284	202	194		662	571	680	938.98		243	
6 AM	✓	282	206	187	✓	659	585	672	938.92	✓	286	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Well's 1 + 5 Down for Repair's

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-08-03-12
DATE:	8-3-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
7 AM	Down	285	188	207	Down	660	579	670	8472	Down	326	Ascomms	
8 AM		283	210	196		671	566	679	14120		42	Alfon	
9 AM		284	198	192		661	1025	679	39728		81		
10 AM		283	210	187		657	579	675	12419.34		121		
11 AM		285	189	208	234	662	579	675	10590		163		
12 PM	✓	268	197	204	219	857	576	6001	11296		215		
1 PM		230	241	198	199	1049	1011	1082	12432.44		278		
2 PM		238	232	198	201	1072	1630	1076	12637.32		340		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

Wells #1 & #5 Down For Repair  
Well #5 Repaired and on at 10:50 am  
Well #1 Repaired and on at 12:37 pm \*

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-03 - 13
DATE:	8-3-93

WELLFIELD OPERATION										AIR STRIPPER OPERATING PARAMETERS				
GALLONS PER MINUTE														
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW K.GALS	SUPERVISOR OPERATOR INITIALS		
3 PM	227	237	200	200	232	1074	1042	1075	10590.00	Not	403	Rodgers		
4 PM	226	240	198	200	235	1071	1048	1077	10590.00	working	63	Cavallaro		
5 PM	227	238	200	198	234	1071	1053	1080	9813.40		127	Lloyd		
6 PM	227	236	201	200	234	1074	1056	1083	9389.80		190			
7 PM	229	240	197	200	233	1076	1057	1088	10590.00		258			
8 PM	227	236	200	200	232	1070	1059	1090	10590.00		322			
9 PM	227	238	200	200	232	1070	1058	1089	10166.40		386			
10 PM	228	238	202	197	233	1070	1059	1094	9107.40		453			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FIELD:	93-08-04-11
DATE:	8-4-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	227	239	200	199	234	1070	1060	1091	8472.00	NOT	516	LLOYD
12 AM	228	237	201	198	234	1072	1059	1233	8472.00	WORKING	68	DOONELIS
1 AM	228	240	198	200	234	1073	1060	1072	7918.80		132	
2 AM	228	240	198	200	235	1073	1048	1124	6283.80		200	
3 AM	227	240	200	200	234	1076	1051	1117	6918.80		268	
4 AM	231	239	199	198	235	1074	1029	1132	6918.80		334	
5 AM	228	240	200	197	235	1072	1035	1119	7483.60		402	
6 AM	229	240	197	200	235	1074	1043	1116	8472.00	✓	465	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FILE ID:	Y3-08-04-12
DATE:	8-4-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
7 AM	229	239	197	197	234	1076	1052	1117	9813.52	Down	531	ABG/MS		
8 AM	228	239	199	199	235	1074	1055	1115	12002		65	H/Hen		
9 AM	227	240	200	200	234	1072	1057	1109	12002		132			
10 AM	229	240	200	198	234	1070	1058	1135	6283.42		192			
11 AM	228	239	200	196	235	1071	1069	1126	12919.22		258			
12 PM	228	239	200	200	235	1070	1061	1124	8472		324			
1 PM	229	240	199	197	234	1075	1368	1131	4389.80		393			
2 PM	229	240	200	201	236	1080	1027	1129	13555.20		460			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-04-13
DATE:	8-4-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 3 FLOW	WELL 2 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	229	240	201	200	236	1077	1037	1112	10590.00	NOT	529	RODGERS
4 PM	228	239	199	201	235	1077	1046	1094	10590.00	WORKING	58	Cavalero
5 PM	229	240	197	201	235	1074	1044	1093	9813.40	1	119	
6 PM	229	240	201	198	235	1074	1053	1088	9813.40	1	183	
7 PM	228	238	200	200	236	1076	1058	1093	10590.00		246	
8 PM	228	240	197	200	236	1073	1059	1089	10166.40		311	
9 PM	228	240	200	201	233	1075	1059	1095	10166.40		377	
10 PM	228	239	200	195	234	1071	1060	1095	10166.40		446	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### NIGHT SHIFT

FILE ID:	93-08-05-11
DATE:	8-5-93

TIME	WELL/FEED OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW GALLONS	SUPERVISOR/ OPERATOR INITIALS
11 PM	229	239	201	201	235	1069	1060	1097	6283.40	NOT	509	LLOYD
12 AM	230	241	201	198	235	1079	1347	1374	6283.40	WORKING	70	DOUGLIS
1 AM	231	244	200	195	235	1077	1032	1127	6283.40	1	142	
2 AM	250	240	200	199	236	1075	1044	1111	6283.40		206	
3 AM	228	240	200	201	235	1071	1049	1095	6283.40		273	
4 AM	228	239	200	197	232	1073	1055	1085	6283.40		336	
5 AM	229	240	201	198	234	1075	1050	1099	7977.80	✓	406	
6 AM	228	240	200	198	233	1073	1052	1096	9107.40	✓	468	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	43-03-05-42
DATE:	08-05-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS					EFFLUENT FLOW MGALS	SUPERVISOR OPERATION INITIALS
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC		
7 AM	230	240	250	200	236	1672	1008	1094		122440	527	MHC Adams
8 AM	230	240	280	200	234	1075	1608	1096		122880	601	(Carroll)
9 AM	228	240	198	200	230	1073	1061	1052		157780	136	
10 AM	232	240	199	200	237	1681	1010	1323		197280	198	
11 AM	231	240	198	200	236	1080	1029	1086		11649.00	268	
12 PM	228	240	200	197	236	1074	1042	1108		11649.00	324	
1 PM	230	240	200	202	233	1075	1049	1097		11649.00	327	
2 PM	228	240	200	200	232	1612	1056	1098		11649.00	410	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-08-05-13
DATE:	8-05-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW GALLS	SUPERVISOR/ OPERATOR INITIALS
3 PM	229	240	200	200	232	1071	1056	1097	9813.40	NOT	526	Rodgers
4 PM	228	239	199	200	232	1069	1059	1098	9389.80	working	65	Cavallaro
5 PM	228	242	201	201	234	1077	1062	1120	9389.80		130	
6 PM	232	240	199	200	235	1074	1024	1092	9107.40		199	
7 PM	228	240	196	201	234	1074	1041	1098	9813.40		261	
8 PM	229	241	196	200	232	1071	1049	1100	9813.40		326	
9 PM	230	240	197	200	232	1069	1054	1097	1016.40		394	
10 PM	230	240	200	200	232	1071	1059	1096	6233.40		458	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE ID:	93-08-06-11
DATE:	8-6-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	228	239	200	159	236	1070	1058	1097	10166	NOT	520	LLOYD
12 AM	228	239	201	201	235	1069	1060	1088	9107	DOUGLAS	65	DOUGLAS
1 AM	228	240	195	201	228	1070	1061	1097	9813		136	
2 AM	231	241	200	198	236	1075	1081	1091	7997		205	
3 AM	232	240	199	200	236	1073	1030	1087	6918		268	
4 AM	229	241	202	196	235	1071	1042	1104	6918		333	
5 AM	228	240	200	201	235	1068	1050	1098	7483		397	
6 AM	228	240	200	201	236	1068	1055	1096	7977		463	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FIELD #	43-08-06-12
DATE	08-06-93

WELLSFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
7 AM	228	239	200	198	235	1072	1057	1094	9107.50	Not	529	Nix		
8 AM	130	240	201	201	234	1070	1061	1096	9389.80	Working	65	CHPEK		
9 AM	229	289	201	201	234	1071	1060	1096	10943.00		131	ARRHNS		
10 AM	232	243	200	198	236	1075	1021	1091	10945.00		202	..		
11 AM	232	241	200	200	236	1072	1035	1108	11296.00		262	..		
12 PM	230	241	200	199	235	1068	1046	1104	11296.00		327	..		
1 PM	228	240	199	201	235	1071	1053	1100	10943.00		393	..		
2 PM	229	241	200	199	236	1069	1057	1098	10590.00	✓	460	..		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-06-13
DATE:	8-6-93

WELL FLOW DATA										AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PREST FL FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE PSIG	EFFLUENT FLOW GPM	SUPERVISOR							
3 PM	229	240	198	198	236	1070	1058	1096	9813.40	N/T	523	Rodgers							
4 PM	228	240	200	197	236	1070	1061	1094	9389.80	Working	64	Cavallaro							
5 PM	231	244	200	201	236	1078	1018	1284	10590.00	0	138								
6 PM	232	241	200	201	236	1072	1033	1099	9813.40		200								
7 PM	229	240	200	201	235	1070	1044	1102	9389.80		264								
8 PM	230	241	200	200	235	1068	1049	1097	9389.80		327								
9 PM	229	240	200	200	236	1070	1055	1095	10166.40		390								
10 PM	229	241	200	200	234	1071	1056	1091	10966.40		455								
11 PM																			
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA								

REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FIELD ID:	93-08-07-11
DATE:	8-7-93

WELL HEAD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	PRESS. FL. FLOW	PRESS. FL. FLOW	BLOWER AIR FLOW	AIR PRESSURE	EFFLUENT FLOW	EFFLUENT FLOW	EFFLUENT FLOW	EFFLUENT FLOW	EFFLUENT FLOW	EFFLUENT FLOW
11 PM	229	242	199	198	233	1068	1060	1055	11296 <sup>00</sup>	NOT	WORKING	69	DOUGLAS						
12 AM	230	243	201	199	234	1068	1348	1117	11296 <sup>00</sup>	WORKING	69	DOUGLAS							
1 AM	232	240	197	199	234	1072	1032	683	10943 <sup>00</sup>			140							
2 AM	230	242	199	200	236	1071	1040	1102	10943 <sup>00</sup>			211							
3 AM	230	240	206	197	235	1072	1044	1096	10943 <sup>00</sup>			267							
4 AM	228	240	200	197	236	1070	1054	1091	10943 <sup>00</sup>			331							
5 AM	229	248	200	196	232	1071	1058	10955	9107 <sup>40</sup>			396							
6 AM	230	240	198	196	235	1068	1058	1094	9107 <sup>40</sup>			462							
7 AM																			
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-08-07-12
DATE:	8-7-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPED OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	REFILL FLOW GPM	BLOWER AIR FLOW CFM	AIR TEMPERATURE IN/OUT DEG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATION INITIALS	
7 AM	232	244	199	200	237	1073	1339	1317	9388.0	407.4	529	N.Y.	
8 AM	231	244	201	196	236	1073	1025	1078	9813.40	1	70	Cact	
9 AM	228	242	200	200	235	1073	1039	1104	10590.00		131	..	
10 AM	228	240	199	197	235	1072	1048	1100	10590.00		195	..	
11 AM	229	240	198	200	235	1072	1054	1095	10943.00		262	..	
12 PM	230	240	201	201	236	1067	1057	1094	10943.00		325	..	
1 PM	230	241	199	195	234	1070	1060	1096	11276.00		392	..	
2 PM	232	243	203	200	238	1078	1012	1304	11296.00		461	..	
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILED:	93-08-07-13
DATE:	8-7-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW GALLS	SUPERVISOR/ OPERATOR INITIALS
3 PM	230	244	201	198	236	1072	1029	0676	1016.4%	Not Op.	526	Niv
4 PM	228	240	200	200	236	1071	1042	1100	1016.4%	*	62	Caper
5 PM	230	240	201	199	236	1070	1049	1096	9813.4%		129	..
6 PM	229	242	202	196	236	1067	1055	1095	9813.4%		195	..
7 PM	230	241	200	198	235	1069	1057	1095	9813.4%		258	..
8 PM	228	240	202	200	232	1069	1059	1095	1016.4%		325	..
9 PM	231	241	201	200	236	1078	1018	1277	1016.4%		396	..
10 PM	230	240	198	200	235	1073	1034	1090	1094.5%	*	455	..
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FIELD:	93-08-08-11
DATE:	Aug 8, 1993

RELEASED OPERATION GALLONS PER MINUTE													AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS			
11 PM	232	243	197	197	236	1072	1042	1101	10934	10984	12002.8	518	Padgett			
12 AM	229	240	200	201	236	1072	1053	1094	12002.8	10166.40	132	12002.8	Padgett			
1 AM	230	240	200	199	236	1072	1056	1095	10166.40		132					
2 AM	229	241	200	196	236	1071	1059	1096	10590.00		198					
3 AM	232	244	197	200	235	1077	1011	1305	10570.00		266					
4 AM	231	241	197	201	236	1075	1032	1084	10166.40		333					
5 AM	232	242	200	200	236	1073	1041	1106	10590.00		395					
6 AM	227	240	199	199	236	1068	1047	1050	10590.00		461					
7 AM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID: 93-08-08-12  
DATE: 8-8-93

WELL/FEED OPERATION GALLONS PER MINUTE										AIR STRIPPED OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR TEMPERATURE INLET NO.	EFFLUENT FLOW MGALS	SOLVENT/ACID OPERATION INITIALS			
7 AM	230	242	200	200	235	1071	1054	1097	93898	526	Nix					
8 AM	228	240	200	196	235	1068	1057	1096	93898	64	Cape					
9 AM	229	241	197	196	235	1070	1388	1098	1058	130						
10 AM	232	244	197	200	236	1095	1022	1086	1059	206						
11 AM	225	242	201	198	236	1074	1036	1100	1062	268						
12 PM	232	242	199	198	236	1070	1046	1098	1059	327						
1 PM	229	241	200	201	234	1071	1053	1093	1059	393						
2 PM	229	240	200	201	235	1071	1065	1095	1058	456						
3 PM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-08 - 13
DATE:	8-8-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW GPM	SUPERVISOR/ OPERATOR INITIALS	
3 PM	928	244	198	197	236	1073	1368	1108	1016	NOT RECORDED	524	Nix	
4 PM	280	242	201	200	237	1076	1024	1087	1016	NOT RECORDED	74	Cape H	
5 PM	230	241	200	200	236	1075	1038	1104	981	130	130	..	
6 PM	230	242	201	200	235	1072	1048	1098	981	197	197	..	
7 PM	227	241	200	200	235	1073	1054	1096	981	261	261	..	
8 PM	231	241	196	199	234	1074	1056	1096	981	326	326	..	
9 PM	232	242	199	196	236	1076	1343	1117	1016	394	394	..	
10 PM	281	242	200	200	238	1075	1024	1086	1016	464	464	..	
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FIELD:	93-08-09-11
DATE:	8-9-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	229	241	200	198	236	1075	1040	1110	7483 <sup>20</sup>	NOT	524	LLOYD
12 AM	232	244	200	200	235	1072	1047	1100	7483 <sup>19</sup>	WORKING	67	DOONELIS
1 AM	231	243	200	200	235	1074	1053	1099	7977 <sup>80</sup>	1	130	
2 AM	228	240	202	198	235	1071	1056	1093	7977 <sup>82</sup>		199	
3 AM	231	244	200	196	236	1072	1377	1105	7977 <sup>82</sup>		264	
4 AM	232	244	198	197	236	1074	1028	1089	9107 <sup>40</sup>		335	
5 AM	232	244	199	200	236	1073	1042	1103	9385 <sup>80</sup>		395	
6 AM	228	242	200	241	228	1070	1050	1097	9385 <sup>82</sup>	✓	460	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	43-08-04-43
DATE:	08-04-43

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS				
7 AM	230	240	200	197	236	1072	1053	1096	10590.00	Not	525	Cembrade				
8 AM	225	242	198	200	235	1068	1005	1093	10550.00	working	64	ARRAMS				
9 AM	232	244	201	201	236	1070	1008	1316	10090.00		153					
10 AM	232	243	201	200	236	1076	1027	1084	104640		200					
11 AM	228	241	200	199	236	1073	1040	1101	11296.00		265					
12 PM	232	243	201	196	236	1067	1050	1097	9813.40		327					
1 PM	227	241	199	199	234	1073	1054	1095	9813.40		392					
2 PM	000	000	000	000	000	000	000	000	000	✓	431					
3 PM																
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA						

### REMARKS

Start plant Down at 1:25

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-09-13
DATE:	8-9-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS					EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC		
3 PM	OFF										431	Schadler
4 PM										NOT working		Cavallaro
5 PM		268	205	198	252	762	1038	1105	10166.40		40	
6 PM		272	196	204	253	761	1047	1107	9389.80		83	
7 PM		275	196	192	248	754	1040	1098	9389.80		130	
8 PM		278	194	196	200	721	1047	1105	10166.40		177	
9 PM		280	192	202	216	730	1040	1108	9813.40		222	
10 PM		280	204	198	212	738	1049	1103	9389.80		269	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Plant shut down at 11:25 DUE TO LIGHTNING  
1600 PLANT ON LINE. #1 WELL OFF. NOT WORKING PROPERLY.  
HIGHEST READING 88.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### NIGHT SHIFT

FILE ID:	93-08-10-11
DATE:	Aug 10, 1983

WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	OFF	279	194	200	208	737	1036	1099	6283 <sup>40</sup>	207 <sup>100</sup>	314	LLOYD
12 AM	✓	280	201	201	224	743	597	677	6283 <sup>40</sup>	✓	45	DUBOIS
1 AM		280	208	198	204	738	1048	684	6283 <sup>40</sup>		94	
2 AM		280	205	197	222	749	1050	682	6283 <sup>40</sup>		137	
3 AM		280	197	189	224	741	575	678	6283 <sup>40</sup>		181	
4 AM		283	206	194	206	738	1036	1114	6389 <sup>32</sup>		229	
5 AM		282	208	204	227	760	1037	691	6389 <sup>32</sup>		272	
6 AM	✓	282	208	192	234	757	577	1123	10166 <sup>40</sup>	✓	325	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 WELL OFF NOT WORKING PROPERLY  
Highest Reading 88

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-08-10-12
DATE:	8-10-93

WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	Down	284	208	192	199	737	1014	1113	12002	Down	371	ABEANS
8 AM		283	206	184	224	752	529	672	12637	40	48	H. H. H.
9 AM		284	210	194	228	764	998	1116	12002		92	
10 AM		284	195	190	235	757	563	1097	14120		141	
11 AM		283	202	193	204	736	555	1110	14120		189	
12 PM		287	204	192	210	739	567	670	12002		232	
1 PM		284	207	192	205	737	577	683	13555	29	279	
2 PM		285	208	189	200	734	565	671	13272	60	323	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Well #1 Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-10-13
DATE:	8-10-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	OFF	284	208	200	201	745	1035	1105	10590.00	NOT	368	LLOYD
4 PM		284	196	208	210	751	1044	1109	10590.00	WORKING	41	CAVALLA
5 PM		286	197	205	222	764	1040	1105	10943.00		89	
6 PM		287	200	192	214	747	1011	1111	10166.40		135	
7 PM		284	208	192	232	762	1045	1104	9389.80		180	
8 PM		287	207	190	205	739	1029	1097	9389.80		224	
9 PM		284	202	208	232	770	1018	1115	9389.80		275	
10 PM		285	204	202	216	752	1010	1106	9389.80		319	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 WELL DOWN FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-08-11-11
DATE:	8-11-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	1	284	193	206	218	750	1013	1111	10590.00		366	SCHADUE		
12 AM		285	192	208	224	766	1014	1115	10590.00		48	Dowdellis		
1 AM		288	208	188	214	744	1017	1109	10166.40		93			
2 AM		285	195	207	229	762	563	1103	9813.40		143			
3 AM		287	206	197	202	739	563	1105	9813.40		187			
4 AM		284	208	191	220	756	571	1106	9813.40		237			
5 AM		288	191	207	209	742	572	675	9107.00		284			
6 AM		286	192	205	219	755	562	1110	9107.00		328			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 WELL DOWN FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FIELD ID:	93-08-11-12
DATE:	8-11-93

WELTFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
7 AM	Down	287	196	208	224	762	562	1092	797780	Down	374	ASG/MS		
8 AM		285	192	208	213	749	1036	1112	797780		44	H/low		
9 AM		283	196	206	<del>203</del>	759	578	683	1016640		87			
10 AM		288	208	188	216	752	558	1104	14120-		131			
11 AM		285	207	194	218	750	584	685	14120-		179			
12 PM	✓	284	192	207	240	769	1046	686	14120-		227			
1 PM		284	195	204	214	739	1034	1095	14120-		269			
2 PM		285	206	193	224	753	1031	1167	14120-	✓	317			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 well Down For Repairing  
Brown Air Flow meter out of whack  
.25 on ABOVE PUT IN REMOINIS .25 (14120)

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **EVENING SHIFT**

FILE ID:	93-08-11-13
DATE:	8-11-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
3 PM	OFF	272	206	193	256	896	1036	1115	10590.00	No +	369	Schadler		
4 PM	1	270	200	202	256	892	1032	1111	10166.40	working	52	Cavallaro		
5 PM		272	194	204	255	891	1042	1106	10590.00		108			
6 PM		272	194	204	255	892	1036	1113	10943.00		164			
7 PM		272	205	196	256	896	1038	1102	10166.40		220			
8 PM		270	204	194	256	894	1017	1087	10590.00		280			
9 PM		272	200	202	257	895	1030	1097	10590.00		335			
10 PM	1	273	194	204	256	893	1015	1103	10166.40		392			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

#1 Well Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF CYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### NIGHT SHIFT

FILE ID:	93-08-12-11
DATE:	8-12-93

WELLFIELD OPERATION												AIR STRIPPER OPERATING PARAMETERS			
GALLONS PER MINUTE															
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
11 PM	OFF	272	195	203	257	886	1002	1102	7483 <sup>60</sup>	207	445	LLORD			
12 AM	1	273	204	195	256	895	567	1104	7483 <sup>60</sup>	WORKING	59	DOUGLAS			
1 AM	1	272	200	198	255	890	1037	1110	6283 <sup>40</sup>	1	105				
2 AM	1	272	200	191	256	896	1028	1110	6283 <sup>40</sup>	1	168				
3 AM	1	272	193	203	255	890	1037	1116	10590 <sup>00</sup>	1	216				
4 AM	1	272	204	194	255	891	1046	1111	10590 <sup>00</sup>	1	270				
5 AM	1	272	207	194	256	896	573	1116	9389 <sup>80</sup>	1	325				
6 AM	1	272	203	196	256	895	572	1104	9107 <sup>40</sup>	1	389				
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

#### REMARKS

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FIELD:	93-08-12-12
DATE:	08-12-93

WELFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	04	272	203	201	256	834	571	6674		9107.40	440	Thomas
8 AM	04	271	204	197	256	831	1084	1113		9107.46	54	Conrad
9 AM	04	272	192	203	257	834	572	677		9107.40	115	
10 AM	04	273	196	195	256	834	1008	1107		6283.16	165	
11 AM	04	272	204	197	256	903	538	1093		6283.16	228	
12 PM	OFF	273	194	207	257	900	1006	1104		9813.40	277	
1 PM	04	—	—	—	—	—	—	—		—	—	—
2 PM	Down	—	—	—	—	—	—	—		—	—	—
3 PM	Down	—	—	—	—	—	—	—		—	—	—
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

#### REMARKS

# Well Down for repairs  
Plant shut-down due to lighting at 12:30

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **EVENING SHIFT**

FILE ID:	93-08-12-13
DATE:	8-12-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW GALLS	SUPERVISOR/ OPERATOR INITIALS
3 PM	OFF										313	LLOYD
4 PM												Cavallaro
5 PM												
6 PM		259	202	197	221	850	1045	1107	9813.40	NOT	18	
7 PM		264	197	196	236	866	1016	1109	9107.40	WORKING	69	
8 PM		264	196	203	250	885	1027	1113	9107.40		122	
9 PM		268	200	191	252	883	1029	1110	9813.40		179	
10 PM		267	197	197	253	884	1040	680	9813.40		231	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

15:00 PLANT IS SHUT DOWN DUE TO LIGHTNING STORM  
 17:30 PLANT BACK ON LINE.  
 #1 WELL DOWN FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FIELD:	93-08-13-11
DATE:	AUG 13/1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	OFF	270	204	203	253	898	1031	1115	9107 <sup>40</sup>	NO <sup>1</sup>	282	SCHADLER	
12 AM	✓	271	196	204	256	895	1054	686	9107 <sup>40</sup>	✓	576	DANIELS	
1 AM	✓	272	206	196	253	895	1020	1109	9107 <sup>40</sup>	✓	109		
2 AM	✓	276	207	190	236	885	575	1106	9387 <sup>80</sup>	✓	163		
3 AM	✓	278	207	197	208	859	1018	1110	10943 <sup>00</sup>	✓	215		
4 AM	✓	276	204	194	200	857	1035	1093	9813 <sup>50</sup>	✓	269		
5 AM	✓												
6 AM	✓	256	196	201	244	871	1033	1114	10590 <sup>00</sup>	✓	306		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 WELL DOWN FOR REPAIRS  
SECURED WELLS AT 4:10 DUE TO  
LIGHTNING BACK ON LINE AT 0530 HRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-08-13-12
DATE:	8-13-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATION INITIALS		
7 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	10943.00	12.5 d.a.h.	354	Nix		
8 AM	OFF	260	202	200	240	868	1042	1122	10943.00	✓	0008	Grech		
9 AM	OFF	264	196	204	228	860	1026	1116	10166.4		62	Abraham		
10 AM	OFF	265	196	197	225	855	1031	1122	13272.8		114	..		
11 AM	OFF	268	196	204	207	844	1035	0689	13272.8		167	..		
12 PM	OFF	268	200	196	244	896	1017	1109	10943.00		219	..		
1 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF		248	..		
2 PM	OFF	263	196	195	224	851	1030	1114	10166.4	✓	262	..		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

ALL wells OFF Due to Lighting @ 6:35:  
 #1 Well is down for repairs.  
 on line @ 0740:  
 All wells off due to lighting @ 12:16  
 on line @ 1330..

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.  
 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	Y3-08-13-13
DATE:	8-13-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 2 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FILT FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	264	197	193	218	844	1033	1112	10166.40	NOT	314	SCHADLER		
4 PM		260	205	200	229	861	1022	1110	10590.00	WORKING	52	CAVALLARO		
5 PM		264	203	199	239	872	1032	1116	10590.00		105			
6 PM		268	199	192	251	881	1036	1112	10943.00		160			
7 PM		268	204	204	252	894	1027	1111	10590.00		212			
8 PM		268	208	192	253	888	1035	1115	10943.00		267			
9 PM		267	200	203	254	890	1042	1111	10943.00		319			
10 PM		271	204	194	255	893	1010	1107	10943.00		381			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

#1 Well Down for Repairs

### NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE ID:	93.08.14.11
DATE:	8.14.93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	1	270	193	204	254	893	1040	1117	9107.40	1	435	SCHADLER	
12 AM		270	195	204	256	887	1050	1106	9389.80		52	HILTON	
1 AM		272	205	195	254	898	561	1092	9813.40		106		
2 AM		269	203	197	254	892	1013	1107	9813.40		166		
3 AM		271	205	196	256	887	1021	1112	10590		221		
4 AM		272	193	204	255	900	557	1105	10580		224		
5 AM		272	204	190	256	896	1002	1103	10943		330		
6 AM	1	272	204	201	255	883	1015	1108	10943		383		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

WELL 1 WELL OFF FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-08-14-15
DATE:	8-14-93

WELTFIELD OPERATION										AIR STRIPPER OPERATING PARAMETERS			
GALLONS PER MINUTE													
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
7 AM	055	272	199	197	256	900	1020	1104	10943.1	No. 400	441	Nix	
8 AM	055	272	199	203	256	893	1017	1110	10943.00	A	48	Capelet	
9 AM	055	271	196	204	256	896	1021	1108	10166.10		105	..	
10 AM	055	272	205	192	254	893	1033	1109	10166.10		100	..	
11 AM	055	272	199	196	254	897	1025	1108	10943.10		213	..	
12 PM	055	272	195	205	256	891	1039	1116	10166.10		267	..	
1 PM	055	272	200	198	256	891	1051	1198	10166.10		223	..	
2 PM	055	271	199	192	250	894	1041	1104	10166.10		376	..	
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 & #2 down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-09-14-13
DATE:	8-14-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	272	205	194	256	891	579	0001	10945.00	NO. 20.44	4.36	W.R.	
4 PM	OFF	272	199	198	200	894	574	1092	10166.40		59	Capeh	
5 PM	OFF	272	204	194	256	892	561	1090	10948.00		112	..	
6 PM	OFF	273	196	201	257	898	1000	1100	10166.40		167	..	
7 PM	OFF	271	195	204	256	901	1012	1109	10166.40		221	..	
8 PM	OFF	272	195	196	256	892	1019	1108	10943.00		275	..	
9 PM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF		301	..	
10 PM	OFF	264	200	198	216	843	565	1287	10945.00		322	..	
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 Well Down for Repairs  
2016 hrs  
Plant is down due to lightning.  
2115 hrs Back on line.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE ID:	93-08-15-11
DATE:	8-15-93

WELLED OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
11 PM	OFF	265	201	194	220	851	568	1094	9107.40	NOT WORKING	374	CL0YD	
12 AM	1	268	202	201	203	844	1040	1111	9813.40	WORKING	51	CAVALCRO	
1 AM	1	266	201	202	220	855	1027	1105	9813.40	1	101		
2 AM	1	271	195	203	219	856	1019	1088	9389.80	1	151		
3 AM	1	272	201	198	202	837	1047	1115	10166.40	1	202		
4 AM	1	272	206	195	205	851	1008	1106	10166.40		255		
5 AM	1	273	200	199	218	862	1053	1114	9813.40		306		
6 AM	1	276	148	195	222	866	1042	683	9813.40	1	359		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-08-15-12
DATE:	8-15-99

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
7 AM	OFF	275	203	195	208	846	1035	1115	10166.4	106.7 working	414	Nix		
8 AM	OFF	274	196	205	232	883	1038	1112	10166.4	1	53	Capek		
9 AM	OFF	280	196	196	204	862	1025	1112	10943.7		106	..		
10 AM	OFF	276	195	204	210	856	1031	1116	10166.4		158	..		
11 AM	OFF	276	199	200	214	860	1035	1122	10943.7		211	..		
12 PM	OFF	276	199	201	206	859	1037	1135	10166.4		265	..		
1 PM	OFF	275	192	204	225	871	1039	686	10166.4		319	..		
2 PM	OFF	276	204	201	213	860	1027	689	10166.4		320	..		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#2 Well is Down for Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-15 13
DATE:	8-15-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	279	205	204	200	864	1029	694	10166.10	0.0244	425	Nix	
4 PM	OFF	279	206	195	215	883	1035	1105	10590.00		52	Caper	
5 PM	OFF	280	196	198	202	848	1019	1109	9389.80		104	..	
6 PM	OFF	276	199	193	224	872	1021	1120	10590.00		158	..	
7 PM	OFF	277	204	198	222	863	1023	1122	9389.80		213	..	
8 PM	OFF	278	192	196	221	860	1011	1122	9389.80		263	..	
9 PM	OFF	276	195	207	228	874	1016	1121	9813.00		319	..	
10 PM	OFF	280	200	197	215	858	1021	1122	9813.00		371	..	
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#2 Well is Down for Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILED:	93-08-16-11
DATE:	8-16-93

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	AIR STRIPPER OPERATING PARAMETERS					EFFLUENT FLOW (GALLONS)	SUPERVISOR OPERATOR INITIALS
							STRIPPER FLOW (GPM)	PRESS. FIL. FLOW (GPM)	BLOWER AIR FLOW (CFM)	AIR PRESSURE (PSI)	INCHES WG		
11 PM	Down	236	206	193	226	871	1038	678	1016 40	Down		425	SCHADLER
12 AM	1	238	206	196	213	857	1027	695	9389 80	1		54	H/16N
1 AM	1	237	204	196	220	865	1017	1120	9389 80			108	
2 AM	1	277	193	206	228	871	1007	1120	9389 80			162	
3 AM	1	280	207	193	203	851	567	1119	9813 40	1		213	
4 AM		278	200	203	212	876	1013	1120	9813 40			265	
5 AM	✓	280	194	205	203	869	650	1117	9813 40			317	
6 AM		279	205	194	198	837	543	1282	9389 80	✓		378	
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 well Down For repaired

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

8-10T

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-08-16-12
DATE:	8-16-93

WELTFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	Down	277	203	196	211	855	1022	1114	8472	Down	432	Agams		
8 AM	1	277	204	200	224	869	564	1098	8472	1	51	Hhkm		
9 AM	1	276	194	204	232	884	1010	1106	11296		103			
10 AM	1	276	195	202	232	873	564	1090	13555		159			
11 AM	1	278	204	194	220	873	566	1094	13272	1	211			
12 PM	1	276	206	190	220	876	569	1092	13272	1	262			
1 PM	✓	277	193	205	202	851	559	1101	12919	✓	316			
2 PM	✓	276	202	190	231	873	1617	1169	12919	✓	360			
4 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 well Down for Repair

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE NO:	93-08-16-13
DATE:	8-16-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI/INCH H2O	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	276	206	195	232	878	1012	1108	10166.40	Not	420	Rodgers	
4 PM	1	274	195	204	256	901	1004	1096	10166.40	working	54	Cavallaro	
5 PM	1	276	203	192	259	901	1000	1103	9389.80	1	110		
6 PM	1	275	199	198	257	900	1008	1106	9107.40	1	166		
7 PM		272	204	195	258	903	1022	1113	9107.40	1	218		
8 PM		274	192	206	258	902	1010	1108	9107.40	1	273		
9 PM		272	204	192	256	898	1022	1110	9813.40	1	328		
10 PM		275	196	204	259	903	1023	1113	9813.40	1	388		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 WELL Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE NO.	93-08-17-11
DATE	Aug 17, 1993

WELLS OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
11 PM	OFF	272	198	200	232	892	1037	1115	7463.40	NO	437	Schadler			
12 AM	✓	272	205	192	255	898	1039	1115	8472.80	✓	50	Downes			
1 AM		272	204	194	256	899	1043	1115	8472.80		107				
2 AM		272	196	204	255	903	1035	1115	9385.80		162				
3 AM		OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF		191				
4 AM			262	202	204	212	847	1020	1112		213				
5 AM			261	200	197	249	878	1026	1112	✓	263				
6 AM	✓	264	202	195	249	880	1013	1109	1016.40		320				
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

#### REMARKS

ALL WELLS OF AT 3:03 - DUE TO LIGHTNING  
BACK ON LINE AT 3:30  
1 WELL DOWN FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FIELD:	93-08-17-12
DATE:	8-13-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW GALLS	STRIPPER OPERATION INITIALS		
7 AM	Down	261	201	200	248	874	1038	1115	101640	Down	373	ABRAMS.		
8 AM		264	200	198	249	881	1047	1118	101640		49	H. H. H.		
9 AM		265	204	192	252	881	578	685	12002		108			
10 AM		268	204	195	252	888	1035	1113	13555.20		158			
11 AM		268	197	204	252	896	1045	1118	13555.20		218			
12 PM		270	196	197	256	881	1032	1113	13555.20		267			
1 PM	✓	269	194	205	253	891	1043	1115	14120.00	✓	320			
2 PM		268	193	204	256	895	580	0001	14120.00		375			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 Well Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-17-13
DATE:	8-17-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	FRESH FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI/PSI WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	270	205	192	254	891	1042	1107	9813.40	NOT	430	Rodgers	
4 PM		272	201	200	255	893	1007	1098	9813.40	WORKING	58	Cavallaro	
5 PM		269	204	191	256	884	1000	1087	9813.40		115		
6 PM		272	194	204	255	896	1004	1108	9107.40		169		
7 PM		272	195	204	252	895	1044	1107	10166.40		222		
8 PM		270	196	204	253	898	1029	1109	9107.40		275		
9 PM		272	204	195	256	897	1015	1102	9389.80		333		
10 PM		271	205	192	256	890	1008	1106	9389.80		390		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 WELL DOWN FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILED:	93-08-18-11
DATE:	Aug 18, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	OFF	272	196	204	252	891	1090	1111	9863.40	NOT	4140	Schadler	
12 AM	A	272	200	199	252	898	1067	1106	10943.00	WORKING	56	Douglas	
1 AM		267	197	200	254	892	1015	1108	10166.40		112		
2 AM		269	196	203	253	889	1047	1085	10166.40		165		
3 AM		271	197	203	257	891	1016	1109	10166.40		210		
4 AM		271	195	204	256	891	1030	1114	10166.40		274		
5 AM		268	195	201	254	886	1042	1110	10166.40		326		
6 AM	V	270	202	200	251	890	1049	1119	10166.40		380		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

# WELL 1 OFF BE REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FRE ID:	43-08-18-12
DATE:	08-18-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	OFF	268	204	196	256	887	568	0002	9107.50	Not	434	Hilton		
8 AM		268	200	203	252	896	1038	1114	8472	working	58	ARRAMS		
9 AM		272	193	204	255	893	564	1101	9107.40		115			
10 AM		272	200	198	254	888	1015	1110	9107.40		173			
11 AM		272	201	195	256	890	563	1100	8472		229			
12 PM		268	204	196	252	898	1019	1108	6918.80		282			
1 PM		271	196	197	253	887	575	0001	10943		337			
2 PM	✓	271	201	204	255	899	1013	1107	13272.80	✓	389			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

#2 Well Down for repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-18-13
DATE:	8-18-93

TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
3 PM	OFF	272	196	202	254	884	1025	1109	9389.80	Not	443	Rodgers
4 PM	1	272	196	200	256	890	1025	1113	9389.80	working	54	Cavallaro
5 PM	1	272	200	202	256	891	1021	1105	9813.40	1	106	
6 PM	1	269	196	204	253	888	1039	1113	9107.40	1	160	
7 PM		270	199	204	254	892	1038	1117	10166.40	1	216	
8 PM		268	199	195	254	885	1037	1103	9813.40	1	268	
9 PM		269	204	200	253	895	1044	1104	9389.80	1	322	
10 PM		271	194	204	252	893	1049	1109	9389.80	1	381	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 Well Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FIELD: 93-08-19-11  
DATE: Aug 19 1993

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	OFF	272	197	197	253	891	538	1109	12850	NO	432	SCHADLER
12 AM	↑	272	194	206	252	854	1012	1106	12660	NO	57	DANIEL
1 AM	↑	272	207	196	252	857	1005	1104	12580	NO	145	
2 AM	↑	272	204	183	253	852	1043	1117	12590	NO	173	
3 AM	↑	270	196	202	256	893	1016	1105	9813	40	228	
4 AM	↑	271	204	196	256	893	565	1099	9813	40	281	
5 AM	↑	271	198	202	256	893	1014	1109	9813	40	336	
6 AM	OFF	272	202	195	256	893	1007	1106	10166	40	390	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

#### REMARKS

#1 WELL DOWN FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-08-17-13
DATE:	05-19-93

WELLFIELD OPERATION										AIR STRIPPER OPERATING PARAMETERS				
GALLONS PER MINUTE														
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	000	268	201	204	234	890	1030	1112	9389.80		443	ComBMC		
8 AM	000	272	196	202	251	895	1045	1109	9383.80		57	ABGMS		
9 AM	000	271	199	200	248	891	1017	1104	9387.80		106			
10 AM	000	271	206	196	254	895	1029	1112	12437.00		169			
11 AM	000	272	196	204	253	890	1038	1115	14120.00		220			
12 PM	000	272	199	204	253	895	1023	1111	9813.40		276			
1 PM	000	270	206	194	253	893	1039	1114	10166.00		323			
2 PM	000	268	204	196	252	890	1023	1090	10166.40		378			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 well Down for repairs

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-08-19-13
DATE:	8-19-93

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	268	198	200	254	890	1038	1095	10590.00	20.2	434	Rodgers		
4 PM	OFF	269	198	194	254	896	1049	1096	10166.00	11	54	Capel		
5 PM	OFF	272	196	194	250	891	580	0001	10166.00		113	"		
6 PM	OFF	272	196	199	252	889	598	694	10166.00		167	"		
7 PM	OFF	271	204	193	255	893	570	1088	9813.40		227	"		
8 PM	OFF	272	200	193	255	889	566	1097	10590.00		383	"		
9 PM	OFF	272	204	196	255	894	1015	1110	10590.00		334	"		
10 PM	OFF	271	197	201	254	895	1006	1106	10590.00		387	"		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#2 Well is down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FIELD:	93-08-80-11
DATE:	AUG 20 1983

TIME	WELL/FEB OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	AERATOR FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	OFF	272	193	198	255	850	1012	1100	9107 <sup>40</sup>	NOT WORKING	447	Schadler
12 AM	A	272	193	205	254	891	1022	1105	9107 <sup>40</sup>	A	51	DOUGLIS
1 AM		272	205	193	256	892	1023	1111	9107 <sup>40</sup>		102	
2 AM		268	204	194	254	891	1029	1112	9389 <sup>40</sup>		156	
3 AM		272	205	192	252	886	580	1117	9813 <sup>40</sup>		210	
4 AM		268	198	196	253	893	1024	1112	9813 <sup>40</sup>		267	
5 AM	V	268	195	198	253	885	1043	1105	9813 <sup>40</sup>		315	
6 AM	OFF	270	198	202	253	888	1052	1100		V	372	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 WELL OFF FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FIELD: 93-08-20-12  
DATE: 8-20-93

WELL-FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
7 AM	055	268	203	200	252	889	1040	1102	10943.0	25.2	427	Nix	
8 AM	055	268	196	204	252	883	585	680	10590.0	1	55	Capet	
9 AM	055	269	203	195	254	885	580	0001	10590.0		112	Abrams	
10 AM	055	270	199	202	253	892	570	1102	10166.0		169	..	
11 AM	055	292	196	204	252	890	570	1076	10166.0		228	..	
12 PM	055	270	205	197	249	891	1014	1107	11296.0		280	..	
1 PM	055	272	197	193	257	887	1012	1109	10166.0		335	..	
2 PM	055	272	195	202	256	895	0005	1109	10166.0	1	390	..	
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-20-13
DATE:	8-20-93

WELLFIELD OPERATION										AIR STRIPPER OPERATING PARAMETERS									
GALLONS PER MINUTE																			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS							
3 PM	OFF	271	202	198	256	900	1017	1108	9389.80	NOT	441	SCHADLER							
4 PM		272	196	198	256	893	1021	1112	9107.40	WORKING	55	CAVALARO							
5 PM		270	193	205	251	895	1015	1109	9107.40		110								
6 PM		272	200	195	256	886	1038	1111	9389.80		162								
7 PM		268	201	196	253	887	1050	1115	9389.80		216								
8 PM		271	206	194	254	893	1029	1112	9389.80		270								
9 PM		268	204	194	254	887	1042	1105	9813.40		325								
10 PM		OFF									342								
11 PM																			
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA									

#### REMARKS

#1 WELL Down For Repairs  
21:15 - SHUT PLANT Down. Lightning Storm.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILED:	93-08-21-13
DATE:	8-21-93

WELLFIELD OPERATION GALLONS PER MINUTE											AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
11 PM	Down	—	—	—	—	—	—	—	—	—	342	Rodgers			
12 AM	Down	—	—	—	—	—	—	—	—	Down	—	Hilton			
1 AM	1	264	204	203	208	845	1016	1112	10590	1	31				
2 AM	1	264	197	200	210	845	1003	1108	11296	1	70				
3 AM	1	264	199	198	251	000	000	000	10943	1	78				
4 AM	Down	—	—	—	—	—	—	—	—	—	—				
5 AM	✓	264	201	200	208	558	1007	1017	628340	✓	792				
6 AM	✓	264	193	196	214	843	1004	1109	10166.46	✓	130				
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

### REMARKS

WELLS DOWN AT 11:00 PM DUE TO LIGHTNING  
12:15 WELLS ON  
# WELLS DOWN FOR REPAIR  
2:45 E/F/T STOPPED SAME GOES RUN S/F - S/F - P/F  
3:10 SHUT DOWN TO TRY TO GET READINGS BACK  
4:10 SYSTEM ON - NO READINGS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FILE ID:	93-08-21-12
DATE:	8-21-93

WELTFIELD OPERATION										AIR STRIPPER OPERATING PARAMETERS				
GALLONS PER MINUTE														
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	OFF	284	196	202	248	884	1010	1107	10943.00	25.2	184	Nix		
8 AM	OFF	264	204	194	249	885	1014	1110	10162.40	1	53	Capeles		
9 AM	OFF	268	202	195	252	885	1004	1104	10162.40		107			
10 AM	OFF	269	193	202	254	891	1012	1105	10943.00		101			
11 AM	OFF	270	196	200	255	892	1020	1110	10590.00		215			
12 PM	OFF	272	196	200	256	896	1012	1107	10590.00		268			
1 PM	OFF	270	200	201	256	898	1024	1107	10943.00		323			
2 PM	OFF	272	196	202	255	899	1034	1115	10590.00	1	377			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

#1 Well is down for repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-2113
DATE:	8-21-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	272	204	193	256	896	1025	1111	10590.00	NOT RECD	43.1	Nix	
4 PM	OFF	368	201	194	256	895	1039	1109	10166.00	NA	51	Capel	
5 PM	OFF	270	195	204	253	893	1047	1111	10166.00		197	..	
6 PM	OFF	272	200	196	256	892	1038	1106	10943.00		162	..	
7 PM	OFF	270	206	194	256	894	584	680	10943.00		215	..	
8 PM	OFF	268	195	203	256	895	1050	1098	9389.00		273	..	
9 PM	OFF	269	204	192	254	891	1038	1110	10943.00		333	..	
10 PM	OFF	272	204	200	255	897	571	1088	10943.00		388	..	
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

### REMARKS

#1 Well is down for repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILED:	93-08-22-11
DATE:	AUG 22, 1993

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	075	265	206	194	254	855	582	688	9107 40	NO 7 WAKING	443	LODGEES
12 AM	✓	272	152	204	259	838	564	1108	9107 40	✓	51	DOUGLIS
1 AM	✓	272	144	205	252	836	563	1038	9107 40		108	
2 AM	✓	271	200	204	256	901	103	1105	9813 40		162	
3 AM	✓	272	197	204	256	897	1022	1112	9813 40		215	
4 AM	✓	272	202	200	256	887	1006	1105	9813 40		270	
5 AM	✓	268	194	201	255	901	1010	1103			321	
6 AM	✓	270	201	154	255	891	1029	1113		✓	379	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

### REMARKS

1 WELL OFF DUE TO REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FIELD ID:	93-08-22-14
DATE:	8-22-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISORY OPERATOR INITIALS		
7 AM	OFF	272	202	196	234	895	1027	1108	10166.40	NOT WORKING	430	Alix		
8 AM	OFF	272	194	206	256	895	1038	1112	10166.40		54	Capers		
9 AM	OFF	267	206	192	256	892	1042	1115	10590.00		108	..		
10 AM	OFF	268	204	199	254	897	1034	1112	10590.00		161	..		
11 AM	OFF	268	191	204	251	893	1048	6823	10166.40		215	..		
12 PM	OFF	268	204	195	254	894	1053	1098	9813.40		273	..		
1 PM	OFF	269	192	201	253	887	1038	1105	9813.40		326	..		
2 PM	OFF	272	204	193	255	895	1048	1098	10166.40		388	..		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

#1 Well is down for repairs.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-2213
DATE:	

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	272	194	199	256	891	569	1087	10166.10	10.725 psi	440	Nix	
4 PM	OFF	272	196	204	255	895	561	1095	10166.10	10.725 psi	57	Capes	
5 PM	OFF	272	198	203	256	897	1004	1100	10390.00		109	..	
6 PM	OFF	272	202	195	256	893	1010	1105	10390.00		165	..	
7 PM	OFF	272	206	192	252	893	1017	1110	10166.10		220	..	
8 PM	OFF	271	196	203	256	902	1011	1106	10166.10		272	..	
9 PM	OFF	272	198	200	256	900	1021	1108	10166.10		327	..	
10 PM	OFF	271	204	194	256	896	1030	1113	10166.10		382	..	
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 Well is Down for Repair's

### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.  
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FIELD NO.	23-08-23-93
DATE	8-23-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	OFF	272	199	201	252	898	1024	1111	8772 <sup>20</sup>	NOT	431	LEOYD		
12 AM	1	270	195	201	256	891	1042	1103	9107 <sup>40</sup>	WORKING	57	DOONELLY		
1 AM		268	200	198	253	895	1054	686	9107 <sup>40</sup>		108			
2 AM		269	200	199	256	892	575	685	7977 <sup>80</sup>		164			
3 AM		269	203	193	252	895	576	680	7977 <sup>80</sup>		221			
4 AM		268	200	203	256	894	1045	1115	7977 <sup>80</sup>		275			
5 AM		272	204	192	256	898	1025	1105	7483.60		330			
6 AM	V	268	196	198	252	891	1031	1104	7483.40	V	388			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	03-08-23-12
DATE:	8-23-93

WELTFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
7 AM	Down	232	195	201	256	897	1009	1100	6918 <sup>80</sup>	Down	446	AS/AMMS	
8 AM	1	232	201	193	256	902	522	1093	10943	1	53	H/Hen	
9 AM	1	232	195	200	256	897	522	1098	9107 <sup>40</sup>	1	107		
10 AM	1	232	205	196	256	902	1009	1103	9107 <sup>40</sup>	1	160		
11 AM	1	270	196	204	256	904	1019	1109	13272 <sup>80</sup>	1	215		
12 PM	1	271	197	198	255	893	1015	1099	14120 <sup>40</sup>	1	269		
1 PM	1	269	193	206	256	892	1020	1107	10166 <sup>40</sup>	1	324		
2 PM	1	272	204	193	256	892	1026	1110	10166 <sup>40</sup>	1	580		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 well down for repair

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-23-1B
DATE:	MAY 23, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	271	194	200	256	891	1022	1108	11649.00	40.5	432	LLOYD		
4 PM	A	268	199	201	256	897	1029	1109	10943.00	40.5	54	DANIELS		
5 PM		269	203	196	257	901	1035	1113	11649.00	40.5	103			
6 PM		264	194	204	256	883	1034	1112	9823.40	40.5	161			
7 PM		271	193	200	256	898	1020	1105	7483.60	40.5	216			
8 PM		265	206	194	254	896	1053	1106	10166.40	40.5	271			
9 PM	V	271	201	193	256	897	558	1101	6283.40	40.5	330			
10 PM		272	192	204	256	900	1000	1102	6283.40	40.5	389			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

1 WELL OFF DUE TO REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILED:	93-08-24-11
DATE:	AUG 24, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	OFF	272	194	205	256	904	1006	1102	6283 <sup>36</sup> / <sub>32</sub>	NOT WORKING	442	LLOVD		
12 AM	↗	272	199	204	256	896	560	1107	6283 <sup>14</sup> / <sub>32</sub>	↗	53	DAVID		
1 AM		272	200	196	256	897	1012	1106	6283 <sup>14</sup> / <sub>32</sub>		108			
2 AM		272	193	204	256	898	1025	1106	6283 <sup>14</sup> / <sub>32</sub>		160			
3 AM		271	194	203	256	895	1028	1110	6283 <sup>40</sup> / <sub>32</sub>		212			
4 AM		272	201	200	256	903	1005	1104	6283 <sup>10</sup> / <sub>32</sub>		270			
5 AM		272	205	192	256	894	1017	1107	6283 <sup>42</sup> / <sub>32</sub>		327			
6 AM	↘	268	201	200	256	900	1028	1107			380			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

1 WELL OFF DUE TO Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FILE ID:	93-08-24-12
DATE:	8-24-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCREASING	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	Down	248	200	204	250	892	1016	1108	6918 <sup>82</sup>	Down	435	MS/AMS		
8 AM		249	198	206	256	892	1033	1110	9389 <sup>80</sup>		49	HL/BN		
9 AM		270	200	203	256	894	1039	1114	11649		106			
10 AM		270	202	197	256	896	1005	1101	12002		155			
11 AM		269	197	197	254	895	1048	680	12919 <sup>80</sup>		218			
12 PM		269	192	205	252	893	1053	688	10943		268			
1 PM	✓	268	200	194	256	894	572	001	10743	✓	324			
2 PM		270	206	192	255	893	581	001	11296		382			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

#1 Well Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-34-13
DATE:	8-24-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	055	269	193	204	256	895	575	0001	10166.40	Not Working	448	Schadler	
4 PM	055	272	205	194	256	892	565	1079	10166.40	1	56	Capek	
5 PM	055	271	193	194	256	893	565	1092	10590.00	1	109		
6 PM	055	273	193	192	256	905	1010	1098	10166.40	1	163		
7 PM	055	272	202	194	256	902	1017	1110	9389.80	1	219		
8 PM	055	271	206	192	256	897	1009	1111	9389.80	1	270		
9 PM	055	272	197	195	256	893	1020	1121	9813.40	1	323		
10 PM	055	268	201	201	256	894	1027	1300	9813.40	1	379		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 Well is Down for Repairs.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-08-25-11
DATE:	Aug 25, 1993

TIME	WELL/EB OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	OFF	272	197	202	255	893	1025	1111	9813 1/2	NOT WORKING	438	LEARD
12 AM	↗	269	200	204	254	900	1037	1116	9813 1/2	↗	56	Downeys
1 AM	↗	270	196	201	256	896	1047	1109	9813 1/2		113	
2 AM		264	200	193	256	898	1032	1113	10166 1/2		163	
3 AM		272	195	201	256	894	565	1095	10166 1/2		220	
4 AM		271	200	183	256	889	581	1106	10166 1/2		274	
5 AM		OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF		282	
6 AM	Y	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	Y	—	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

# WELL 1 OFF DUE TO Repairs  
ALL WELLS OFF DUE TO LIGHTNING  
Time 4:05

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-08-25-12
DATE:	8-25-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	Down										138	ASL/MS		
8 AM	Down											H/L/MS		
9 AM	Down													
10 AM	Down													
11 AM	Down													
12 PM	Down													
1 PM	Down													
2 PM	Down													
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

Wells Down Due to lightning  
Wells Down Due to Acid Rinse  
Wells ON AT 2:45

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-25-13
DATE:	8-25-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	0515	259	204	195	230	864	1018	681	10943.00	NOT DOWN	0000	Schadler		
4 PM	0515	250	201	201	241	871	1048	688	9818.00	✓	51	Capers		
5 PM	0515	260	200	196	245	875	1057	1110	10943.00		105	..		
6 PM	0515	260	204	195	248	879	1047	1097	10166.00		157	..		
7 PM	0515	264	195	200	248	888	1047	1095	10166.00		213	..		
8 PM	0515	264	198	203	249	887	1035	688	10166.00		260	..		
9 PM	0515	268	201	199	251	887	1051	682	10390.00		321	..		
10 PM	0515	269	193	192	252	888	1049	688	10390.00	✓	376	..		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 Well is Down for Repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FIELD:	83-08-26-11
DATE:	8-26-83

WELLFIELD OPERATION												AIR STRIPPER OPERATING PARAMETERS											
GALLONS PER MINUTE																							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS										
11 PM	OFF	269	204	196	245	886		1059	685	6283 <sup>40</sup>	NOT	435	LLOYD										
12 AM		274	192	204	201	849		572	1104	6283 <sup>40</sup>	DOORING	50	DOONELIS										
1 AM		269	205	196	252	904		1006	1107	6283 <sup>40</sup>		107											
2 AM		272	195	197	256	890		1009	1110	6918 <sup>30</sup>		163											
3 AM		270	204	197	255	900		1017	1107	6918 <sup>30</sup>		217											
4 AM		272	205	199	254	893		562	1103	1016 <sup>40</sup>		271											
5 AM		272	193	204	256	892		567	1107	1016 <sup>40</sup>		325											
6 AM	✓	270	199	200	256	894		1025	1108	9381 <sup>80</sup>	✓	379											
7 AM																							
AVERAGE	NA	NA	NA	NA	NA	NA		NA	NA	NA	NA												

### REMARKS

#1 well Down for Repair

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FIELD:	93-08-26-12
DATE:	8-26-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	0000	272	196	200	215	900	1608	1105		9389.80	435	ABRAMS
8 AM	000	270	196	194	286	890	1010	1109		9387.10	53	LEMIGNON
9 AM	000	270	205	196	256	832	1024	1110		9389.80	105	
10 AM	000	271	204	193	256	900	1010	1107		1016.40	164	
11 AM	000	268	205	191	257	900	1016	1113		1016.40	216	
12 PM	000	269	193	204	256	900	1027	1112		10590.00	289	
1 PM	000	269	206	198	253	893	1022	1111		10580.00	323	
2 PM	000	271	202	192	253	897	1017	1112		12037.00	375	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 Well down for repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-26-13
DATE:	8-26-93

WELLFIELD OPERATION										AIR STRIPPER OPERATING PARAMETERS			
GALLONS PER MINUTE													
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	268	245	192	255	892	1038	1113	1066.40	not working	430	Lloyd	
4 PM	OFF	270	200	195	255	895	1032	1113	1066.40		53	Caret	
5 PM	OFF	267	194	204	256	894	1033	1117	10590.00		112	..	
6 PM	OFF	268	204	196	254	899	1045	1114	10590.00		165	..	
7 PM	OFF	268	202	196	252	899	1043	1107	1066.40		217	..	
8 PM	OFF	268	201	200	252	891	1047	689	1066.40		272	..	
9 PM	OFF	269	197	202	253	894	586	685	9813.40		327	..	
10 PM	OFF	268	200	202	252	893	1046	1110	9813.40		383	..	
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 Well is Down for Repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE ID:	93-08-27-11
DATE:	AUG 27, 1993

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	OFF	268	205	185	233	896	578	0000	10570	NOT WORKING	441	SCHAUER
12 AM	A	272	203	185	254	898	570	1099	11296.00	A	54	DOANEUS
1 AM		272	194	202	254	892	566	1079			112	
2 AM				F	F						167	
3 AM												
4 AM		259	204	201	234				9389.40			
5 AM		261	197	202	204				9389.40			
6 AM	V	264	204	201	232				9107.40	V		
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

### REMARKS

# WELL 1 DOWN DUE TO REPAIRS  
ALL WELLS OFF AT 0200 HRS GAUGES  
NOT WORKING, WELLS BACK ON AT 0400 HRS  
GAUGES STILL NOT WORKING

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-08-27-12
DATE:	08-27-93

WELFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISORY OPERATOR INITIALS		
7 AM	000	000	000	000	000	000	000	000	4389.80		000	N.X		
8 AM	000	000	000	000	000	000	000	000	4389.20		000	ABRAMS		
9 AM	000	000	000	000	000	000	000	000	12637.40		000			
10 AM	000	264	204	201	231	000	000	000	12637.40		000			
11 AM	000	260	198	196	221	341	1044	0001	14120.00		21			
12 PM	000	258	203	197	216	846	1055	6882	12919.80		68			
1 PM	000	260	196	203	238	867	1036	1113	12919.80		121			
2 PM	000	259	200	204	248	879	1036	1114	14120.00	✓	168			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 well Down for repairs  
M. Rogers shut down system at 0700  
wells back on at 0925 Gauges not working  
A/S, P/F, S/F, E/F.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-08-27-13
DATE:	8-27-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FILT FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	Down	264	203	197	248	882	1056	682	13272	Down	225	SCHMIDT
4 PM		264	196	193	252	882	1040	1115	11296		55	Altman
5 PM		267	200	198	252	888	1050	688	9389		111	
6 PM		269	193	196	248	892	579	0002	7488		167	
7 PM		269	200	202	256	888	570	0001	6283		221	
8 PM		272	193	204	252	902	573	0001	6283		279	
9 PM		269	203	199	255	895	1014	1100	6283		337	
10 PM		269	193	198	256	907	562	1096	6918		391	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

8410T

#### REMARKS

#1 Well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FIELD	93-08-28-11
DATE	8-28-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	Down	271	200	202	256	899	1011	1106	9107 <del>40</del>	Down	445	SCHADLER
12 AM		271	206	196	255	902	1017	1109	9107 <del>40</del>		53	H16N
1 AM		272	194	200	256	898	1025	1110	9107 <del>40</del>		107	
2 AM		269	198	200	256	893	1022	1115	9389 <del>80</del>		164	
3 AM		268	196	202	255	896	1037	1115	9389 <del>80</del>		218	
4 AM		272	196	201	253	900	1023	1109	9389 <del>80</del>		271	
5 AM		270	192	199	256	897	1023	1109	9389 <del>80</del>		323	
6 AM	✓	272	195	204	256	898	1029	1111	10590.00	✓	379	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 well Down for Repairing

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FIELD:	93-08-3813
DATE:	8-38-93

WELTFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	OFF	271	203	195	254	895	1035	1107	1012.40	Not Above	433	Nix		
8 AM	OFF	269	202	201	256	0000	0000	0000	1012.40	A	19	Carpels		
9 AM	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF		OFF	"		
10 AM	OFF											"		
11 AM	OFF											"		
12 PM	OFF											"		
1 PM	OFF											"		
2 PM	OFF											"		
3 PM												"		
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

\*Well 1 is down for repairs  
0800 hrs system flow cut off + Air Stripper flow  
and pressure filter flow.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-08-28-13
DATE:	8-28-93

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM												Nix		
4 PM												Capeh		
5 PM														
6 PM														
7 PM														
8 PM														
9 PM														
10 PM														
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

0800 hrs SYSTEM flow cut off in Air Stripper

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE ID:	93-08-29-11
DATE:	8-29-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
11 PM	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	LLOV/D			
12 AM												H4 Hov			
1 AM															
2 AM															
3 AM															
4 AM															
5 AM															
6 AM															
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

846507



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILED	93-08-29-13
DATE	8-29-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	AVERGEL FLOW	STRIPPER FLOW GPM	FRESH FL. FLOW GPM	BLOWERS AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
3 PM												NLS Capeh			
4 PM															
5 PM															
6 PM															
7 PM															
8 PM															
9 PM															
10 PM															
11 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

1500 hrs The Plant is Down for Repairs.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE #	23-08-30-11
DATE	8-30-23

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM												LLOYD		
12 AM												HILTON -		
1 AM														
2 AM														
3 AM														
4 AM														
5 AM														
6 AM														
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

ALMNT SECURED  
 Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

81101

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FIELD NO.	43-08-30-12
DATE	8-30-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	Down											AS/MS		
8 AM	Down											H/H		
9 AM	Down													
10 AM	Down													
11 AM	Down													
12 PM	Down													
1 PM	Down	280	198	Down	222	Down	Down	Down	1378	Down	Down			
2 PM	Down	277	203	Down	209	Down	Down	Down	1383	Down	Down			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

Plant secured Down for repairs 0700 hrs  
wells #2 #3 back on at 12:15 pm  
wells #5 on at 12:25  
wells #1 and #4 down for repairs  
5/5 = P/F/E = E/F/T means not working

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 6%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILED:	93-08-30-13
DATE:	8-30-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW
3 PM	OFF	272	200	OFF	204	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING	NOT WORKING
4 PM		278	196		211														
5 PM		278	192		234														
6 PM		276	193		232														
7 PM		276	192		229														
8 PM		278	200		217														
9 PM		281	192		215														
10 PM		280	202		233														
11 PM																			
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

### REMARKS

#1 & #4 WELLS DOWN FOR REPAIRS  
15:00 - Sys. Flow - Strip. Flow - Press Flow & Flow To Thicker NOT WORKING  
Flow Readings 16:00 - 761434.000  
22:00 - 761673.000

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE NO.	93-08-31-11
DATE	8-31-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
11 PM	OFF	282	200	0000	240	OFF	OFF	10166 1/2	NOT	X	LLOYD		
12 AM	✓	282	208	0000	199	✓	✓	10166 1/2	100816	X	DOUGLIS		
1 AM		280	194	0000	216			10166 1/2		X			
2 AM		281	191	0000	221			10166 1/2		X			
3 AM		281	207	0000	226			10166 1/2		X			
4 AM		283	203	0	228			10166 1/2		X			
5 AM		284	207	0	240			8472 00		X			
6 AM	✓	283	204	0	238	✓	✓	7483 69		✓	761990		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FIELD ID:	93-08-31-12
DATE:	08-31-93

WELLS/OPERATION CALLING PER MINUTE										AIR STRIPPER OPERATING PARAMETERS							
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	WELL 7 FLOW	WELL 8 FLOW	WELL 9 FLOW	STRIPPER FLOW GPM	STRIPPER FLOW GPM	PRESSURE FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	OFF	284	206	OFF	220	Not working			—	3472.00	Not	—	—	Not	—	Not	Combrake
8 AM	OH	286	201	OH	203	—			—	8472.00	Working	Working	Working	Working	Working	Working	ABRAMS
9 AM	OH	288	198	OH	202	—			—	8472.00	—	—	—	—	—	—	—
10 AM	OH	284	196	OH	240	—			—	8472.00	—	—	—	—	—	—	—
11 AM	OFF	000	000	OFF	000	—			—	9389.80	—	—	—	—	—	—	—
12 PM	OFF	277	194	OFF	242	—			—	12002.00	—	—	—	—	—	—	—
1 PM	OFF	276	205	OFF	238	635	—	—	—	1015	635	—	—	12002.00	—	14	—
2 PM	OFF	277	206	OFF	208	—	—	—	—	—	—	—	—	12884.00	—	52V	—
3 PM																	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

### REMARKS

#1 & #4 Wells Down for repairs  
 System Flow - Stripper Flow. Pressure Flow & Flow  
 Totalizer not working. Shut Plant Down at 10:30  
 761550  
 1208 2+3+5, pumps back up

gauges working at 12:45

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **EVENING SHIFT**

FIELD NO.	93-08-31-13
DATE	8-31-93

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
3 PM	OFF	280	205	OFF	229	667	1025	1112	10590.00	NOT	93	SCHNIDER			
4 PM		283	200		235	670	1012	1099	10590.00	WORKING	43	Cavallaro			
5 PM		280	208		242	683	1027	1113	10166.40		81				
6 PM		281	196		229	671	1006	1114	9813.40		122				
7 PM		284	195		230	672	1017	1105	9389.80		164				
8 PM		281	190		224	670	1045	1115	9389.80		207				
9 PM		284	191		239	681	1029	1104	9813.40		243				
10 PM															
11 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

### REMARKS

#1 & #4 WELLS Down For Repairs.  
 21:05 Flow gauges NOT working  
 Flow Readings - 15:00 - 762318.00  
 22:00 - 762615.00

### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.  
 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-09-01-12
DATE:	9-1-93

WELTFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
7 AM	Down	284	198	Down	246	Down	Down	Down	9389 80	Down	Down	AR/CHMS	
8 AM		286	211	1	208	Down	Down	Down	11649		Down	H/fox	
9 AM		287	193	1	224	Down	Down	Down	11649		Down		
10 AM		287	190		245	Down	Down	Down	13837, 30		Down		
11 AM		284	195	1	240	Down	Down	Down	14120		Down		
12 PM		286	192		242	Down	Down	Down	9813 40		Down		
1 PM	✓	285	202	✓	208	Down	Down	Down	9389 80		Down		
2 PM		287	191		201	Down	Down	Down	13837 40	✓	Down		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 & #4 wells Down for repairs  
S/F = N/S/F = P/F/F = E/F/F = meters not working  
Flow start 762941000  
Flow finish 763266000  
Total 325

### NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-09-01-13
DATE:	9-1-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	288	195	OFF	186	—	—	—	10166.40	NOT	—	SCHADLER	
4 PM	1	283	206	1	244	—	—	—	10166.40	working	—	Cavallaro	
5 PM	1	254	207	1	236	—	—	—	10530.00	1	—		
6 PM	1	288	191	1	241	—	—	—	10943.00	1	—		
7 PM	1	287	202	1	233	—	—	—	12166.40	1	—		
8 PM	1	286	192	1	240	—	—	—	11134.0	1	—		
9 PM	1	284	200	1	233	—	—	—	11074.0	1	—		
10 PM	1	288	198	1	226	—	—	—	1107.40	1	—		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

# 1 & # 4 WELLS DOWN FOR REPAIR

Flow Readings Start - 763266.00

Finish - 763573.00

763266.00 327

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-03-11
DATE:	SEPTEMBER 2, 1993

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	OFF	288	194	OFF	244	DOWN	DOWN	WORKING	10166 40	NOT	DOWN	DAVID
12 AM		288	211		196				10166 40			DAVID
1 AM		285	196		241				6283 40			
2 AM		286	206		239				6283 40			
3 AM		286	203		208				6918 30			
4 AM		288	193		232				7979 80			
5 AM		288	189		232				9107 40			
6 AM	✓	286	209	✓	288	✓	✓	✓	9107 40	✓	✓	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

#### REMARKS

1 AM 4 OFF DUE TO REPAIRS

METER NO WORKING

FLOW READING START 763593000

FINISH 763922000

#### NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### DAY SHIFT

FILE ID:	93-09-02-12
DATE:	9-2-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	000	289	211	000	132	000	000	000	9107.16	NO T working	Down	Certified		
8 AM	000	290	210	000	130	000	000	000	9107.40	1	1	ABG/MS		
9 AM	000	288	191	000	237	000	000	000	9133.64	1	1			
10 AM	000	288	154	000	130	000	000	000	9133.40	1	1			
11 AM	000	294	203	000	240	000	000	000	9133.60	1	1			
12 PM	000	284	204	000	240	000	000	000	10590	1	1			
1 PM	000	288	208	000	247	000	000	000	12002	1	1			
2 PM	000	288	197	000	246	000	000	000	12284.10	1	1			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

1 AND 4 Down Due To Repairs  
Flow reading - start - 763922.000  
764 245  
323

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.  
2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-09-02-13
DATE:	9-2-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	208	203	OFF	241	0000	0000	0000	10943.00	106.13	0000	Schadler		
4 PM	OFF	288	206	OFF	199	0000	0000	0000	10943.00	1	0000	Byers		
5 PM	OFF	288	205	OFF	241	0000	0000	0000	10943.00		0000	..		
6 PM	OFF	289	190	OFF	242	0000	0000	0000	10590.00		0000	..		
7 PM	OFF	284	192	OFF	241	0000	0000	0000	10590.00		0000	..		
8 PM	OFF	288	200	OFF	199	0000	0000	0000	10590.00		0000	..		
9 PM	OFF	289	194	OFF	207	0000	0000	0000	10590.00		0000	..		
10 PM	OFF	289	204	OFF	247	0000	0000	0000	10590.00	1	0000	..		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

Flow Reading START 764245000  
End 764566000  
321  
1 and 4 Wells Down for Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-03.11
DATE:	4-3-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	OFF	285	191	OFF	247	NOT	NOT	NOT	11286 00	NOT	NOT	LLOYD		
12 AM		285	203		241	WORKING	WORKING	WORKING	11284 40	WORKING	WORKING	DOUGLIS		
1 AM		286	207		218				11284 10					
2 AM		285	195		230				10590 00					
3 AM		285	199		245				10590 00					
4 AM		286	202		243				10590 00					
5 AM		285	208		242				11649 00					
6 AM	✓	288	205	✓	220	✓	✓	✓	112637 40	✓	✓			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

Flow Reading      START 764566.000  
 END 764894.000  
 1+4 wells off      TOTAL 328,000  
 Fee Repair

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### DAY SHIFT

FILE ID:	93-09-03-12
DATE:	09-03-93

WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISORY OPERATOR INITIALS
7 AM	OFF	284	192	OFF	246	OFF	OFF	OFF	12637.40	not	000	DiX
8 AM		288	196		193				12637.40	working	000	CAPEK
9 AM		000	185		225				14120		000	ABRAMS
10 AM		282	206		214				13555.20		000	..
11 AM		283	196		187				13837.40		000	..
12 PM		283	208		212				13837.40		000	..
1 PM		281	193		193				4813.40		000	..
2 PM		284	195		231				10166.40		000	..
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Flow reading - Start 764894.000 Well #2 off at 09:00  
 Finish 765204.000 Well #2 Back on 09:30  
 #1 & #4 Down for repairs Total .310  
 Gauges not working  
 Fire Alarm System 073044e trouble  
 Reset System 081044e

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

A.C. is down 073044e  
 A.C. on line 103044e



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-09-03-13
DATE:	9-3-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	OFF	284	193	OFF	200	650	1041	1107	9813.40	NOT	27	SCHADLER
4 PM		282	208		228	692	1047	1109	10166.40	working	33	Cavallaro
5 PM		286	192		193	642	1027	1098	10166.40		74	
6 PM		286	192		226	672	1018	1097	10166.40		116	
7 PM		285	207		246	702	1037	1105	9813.40		162	
8 PM		284	208		239	700	1032	1100	9389.80		200	
9 PM		286	192		212	658	1027	1094	9389.80		241	
10 PM		284	197		242	697	575	683	9389.80		283	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 & #4 WELLS DOWN FOR REPAIRS

Flow - Start 765204000 - 3PM READING  
 END 765527000 10PM READING  
 TOTAL 321,000

### NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-04-11
DATE:	9-4-93

WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	OFF	Down	Down	OFF	Down	Down	Down	Down	Down	Not	322	SCHADLER
12 AM	1	Down	Down	1	Down	Down	Down	Down	Down	WEK46	Down	HILTON
1 AM		Down	Down		Down	Down	Down	Down	Down		Down	
2 AM	1	280	194	1	234	670	561	001	628342		329	
3 AM	1	280	207	1	213	671	560	1114	10943		74	
4 AM		278	197		227	672	581	678	11649		113	
5 AM		280	200		218	663	572	683	11649		156	
6 AM	1	282	196	1	237	682	559	1091	11649		200	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

\* 1 & 4 wells off for repairs  
 Flow start - 765,558.000 11 PM  
 End - 765,757.000 6 AM  
 Total - 199,000  
 Secured 2-3-5 wells at 22:45 hrs due to

lightning  
 back on line close eff not working

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-09-04-12
DATE:	9-4-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	OFF	0000	0000	OFF	0000	0000	0000	0000	10943.2	26.20 in. Hg	236	Nix
8 AM	OFF	0000	0000	OFF	0000	0000	0000	0000	10943.2	26.20 in. Hg	0000	Caper
9 AM	OFF	275	196	OFF	208	652	579	0001	10166.40	26.20 in. Hg	0007	..
10 AM	OFF	276	203	OFF	212	669	575	681	10166.40	26.20 in. Hg	46	..
11 AM	OFF	279	199	OFF	233	681	555	1109	10166.40	26.20 in. Hg	88	..
12 PM	OFF	279	196	OFF	236	678	577	679	10166.40	26.20 in. Hg	127	..
1 PM	OFF	279	205	OFF	239	685	573	683	10590.2	26.20 in. Hg	168	..
2 PM	OFF	281	195	OFF	225	675	569	0001	10590.2	26.20 in. Hg	213	..
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

#### REMARKS

#1 Well is Down for Repairs  
The Plant is Down Due to Lighting 0700 hrs.  
Plant on line @ 0850 hrs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

Flow START 765,757.000 0600 Hrs.  
END 766,003.000 1400 Hrs.  
Total 236

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-c9-04	13
DATE:	9-4-93	

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	075	280	196	075	238	690	1041	0681	1016.40	NOT WORKING	250	Nix
4 PM	077	282	206	077	243	691	574	683	1016.40	A	41	CapeH
5 PM	011	284	202	011	195	655	570	685	1016.40		80	" "
6 PM	005	284	195	015	243	679	667	1093	10943.00		129	" "
7 PM	015	284	208	015	201	660	653	678	10943.00		165	" "
8 PM	055	284	208	055	243	692	572	684	10943.00		206	" "
9 PM	055	285	200	055	210	0000	0000	0000	10943.00		226	" "
10 PM	055	286	186	055	246	0000	0000	0000	10943.00		0000	" "
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

1200 START 766,003.000

END 766,323.000

TOTAL 320

1800 Hrs 3200 Hrs

#1 and #4 Wells Down for Repairs.

Readings Shut down 2100 Hrs.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE ID:	93-09-05-11
DATE:	9-5-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
11 PM	Down	285	202	Down	225	Down	Down	Down	6918.80	Down	Down	LLOYD			
12 AM		284	208		238				6918.82			HHON			
1 AM		288	192		236				6283 3/4						
2 AM		288	208		237				6283 1/2						
3 AM		284	193		244				6283 10						
4 AM		284	193		248				6919 80						
5 AM		289	207		248				6283 1/2						
6 AM	✓	290	208	✓	190	✓	✓	✓	6918.86	✓	✓				
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

$S/F = A/S/F = P/F/F = E/F/T$  meters Down  
 wells #1444 Down for repairs  
 START 766323  
 END 766650  
 Total 337 Flow Reading

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-09-05-12
DATE:	9-5-93

WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	OFF	291	198	055	196	0	0	0	10166.4	Not Reckd	0	Nix
8 AM	OFF	289	204	055	234	0	0	0	10166.4	1	0	Capets
9 AM	OFF	288	201	055	249	710	575	683	10943.0		66	..
10 AM	OFF	288	208	055	188	651	574	675	10943.0		120	..
11 AM	OFF	288	209	055	235	697	557	1109	10166.4		162	..
12 PM	OFF	288	194	055	207	645	1018	1119	10166.4		201	..
1 PM	OFF	287	193	055	243	697	581	680	10943.0		244	..
2 PM		290	195		218	697	579	680	10943.0	1	289	..
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 Well is Down for Repairs / SE 195 / PF / OFF LINE 0704H  
 #4 Well is Down for Repairs / SE 195 / PF / OFF LINE 0900H  
 Flow - START 766, 680  
 End 766, 976  
 Total 326

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.  
 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-09-05-13
DATE:	9-5-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS.FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	0FF	288	204	0FF	236	683	560	0001	10943.0	NOT WORKING	331	Nix		
4 PM	0FF	292	192	0FF	244	696	561	1114	10943.0	1	40	Caper		
5 PM	0FF	289	195	0FF	234	680	1036	685	10166.0		79	..		
6 PM	0FF	287	207	0FF	247	707	582	678	10943.0		121	-		
7 PM	0FF	289	202	0FF	210	672	567	688	10943.0		164	-		
8 PM	0FF	293	192	0FF	199	659	564	1091	10166.0		210	-		
9 PM	0FF	288	210	0FF	223	685	0001	1105	10166.0		253	-		
10 PM	0FF	290	209	0FF	248	711	565	688	10166.0	1	289	..		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

#1 and #4 closed Down for Repairs.

New - Start 766,976  
End 767,304  
Total 328

### NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID	93-04-06-11
DATE	SEPT 6, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	OFF	288	203	OFF	236	702	692	522	1004 <sup>16</sup>	Not working	335	Schadler		
12 AM	1	292	191	1	185	644	1030	685	983 <sup>80</sup>	✓	37	Dobinski		
1 AM	1	288	192	1	244	695	585	677	983 <sup>80</sup>	✓	75			
2 AM		293	192		151	633	529	684	983 <sup>80</sup>		121			
3 AM		290	190		237	682	527	0000	983 <sup>80</sup>		165			
4 AM		289	204		248	702	568	1094	983 <sup>80</sup>	✓	207			
5 AM		291	193	✓	208	667	569	686	983 <sup>80</sup>	✓	248			
6 AM	✓	292	203		196	663	565	0000	983 <sup>80</sup>	✓	281			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

WELLS 1 AND 4 OFF DUE TO REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-09-06-12
DATE:	09-06-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM		292	200		203	660	568	1115	10590	Not Down	333	Nix		
8 AM		289	201		235	698	1052	629	10590	✓	40	Capets		
9 AM		288	204		231	695	573	684	10166.40		80	Abraham		
10 AM		290	208		234	697	571	684	10166.40		123	"		
11 AM		293	190		248	698	568	0001	10943		169	"		
12 PM		290	209		227	693	1024	1099	10943		207	"		
1 PM		292	197		192	640	1028	688	10943		252	"		
2 PM		288	208		248	714	577	681	10943	✓	290	"		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

767672 - start  
767957 - finish  
285 - total only 7 hrs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-09-06 13
DATE:	9-6-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	272	211	OFF	242	698	1041	1113	10570.00	40.5"	330	LLOYD		
4 PM		270	209		230	694	1033	1108	10570.00	working	44	CAVALLO		
5 PM		289	210		224	700	1040	1103	9813.40		87			
6 PM		289	199		231	697	1048	1115	9289.80		126			
7 PM		281	195		210	684	1037	1102	9107.40		166			
8 PM		231	192		220	690	1018	1115	10166.40		209			
9 PM		289	201		231	—	—	—	9387.80		227			
10 PM		291	206		189	—	—	—	6293.40		—			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 & #4 WELLS DOWN FOR REPAIRS

Flow meter 767 457  
768 283  
326  
30 6.000 gauges still working

#### NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE ID:	23-09-07-11
DATE:	9-7-93

WELL FIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	Down	292	198	Down	241	Down	Down	Down	6283 <sup>40</sup> / <sub>2</sub>	Down	Down	LLOYD
12 AM		291	205		244				9107 <sup>40</sup> / <sub>2</sub>			DOWNEY
1 AM		292	193		211				10166 <sup>40</sup> / <sub>2</sub>			
2 AM		292	182		240				9107 <sup>40</sup> / <sub>2</sub>			
3 AM		289	190		246				10166 <sup>40</sup> / <sub>2</sub>			
4 AM		292	196		195				10166 <sup>40</sup> / <sub>2</sub>			
5 AM		292	208		196				7483 <sup>60</sup> / <sub>2</sub>			
6 AM	V	292	199	V	196	V	V	V	7483 <sup>60</sup> / <sub>2</sub>	V	V	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

### REMARKS

1-4 Well's Down for Repair  
Flow Start 768283  
End 768608  
Total 325

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FRE ID:	43-04-07-12
DATE:	09-07-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	Down	292	208	Down	189	Down	Down	Down	6918 <del>80</del>	Down	Down	Hilton		
8 AM	Down	292	196	Down	192	Down	Down	Down	6918 <del>80</del>	Down	Down	ABRAMS		
9 AM	1	289	204	1	244	Down	Down	Down	13555 <del>20</del>	1	Down			
10 AM		292	204		240	709	575	682	6918 <del>80</del>		89			
11 AM		292	203		192	630	560	002	11649 <del>80</del>		136			
12 PM	1	291	210	1	203	690	570	685	14120 <del>80</del>	1	187			
1 PM		291	189		206	645	1027	688	12002		219			
2 PM	✓	292	200	✓	209	681	583	672	14120	✓	259			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

1 + 4 Wells Down For Repair 5/ft + 1/5/ft + 0/ft + 0/ft  
 Water Flow START 76,8608 NOT WORKING  
 END 768,936  
 Total 328000

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	13-07-07-13
DATE:	9-7-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	015	290	208	017	213	646	568	686	14120	207	302	SCHADLER
4 PM	1	270	192	1	249	692	1032	1017	10166.40	working	44	Cavalero
5 PM	1	292	203	1	236	704	1016	1109	9813.40	1	85	
6 PM	1	291	196	1	234	688	1041	1100	9813.40	1	124	
7 PM	1	230	206	1	212	684	1027	1097	10590.00	1	164	
8 PM	1	287	191	1	250	693	1020	1099	9813.40	1	207	
9 PM	1	292	206	1	249	708	1037	1111	9102.40	1	253	
10 PM	1	271	210	1	230	690	1018	1114	9813.40	1	295	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

11:00 - 12:00 Down for repairs

1:00 - Start - 768936000

2:00 - 769260000

3:00 - 324000

#### NOTES

1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.

2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE ID:	93-09-08-11
DATE:	SEP 8, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	OFF	289	200	OFF	245	707	879	681	9389 <sup>80</sup>	NOT WORKING	335	LOYD	
12 AM		291	206		196	655	578	682	9389 <sup>80</sup>		40	MUNNELIS	
1 AM		289	204		236	699	569	571	9813 <sup>42</sup>		80		
2 AM		292	194		199	649	558	1100	9813 <sup>42</sup>		131		
3 AM		289	207		223	635	1025	690	10166 <sup>40</sup>		168		
4 AM		292	212		181	657	1043	681	10166 <sup>40</sup>		210		
5 AM	✓	289	194	✓	216	670	579	691	9389 <sup>80</sup>		250		
6 AM		287	188		249	685	565	0000	9389 <sup>80</sup>	✓	290		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

11:52-12:00 OFF DUE TO REPAIRS  
 FLOW 76,9260 500  
 END 76,9588  
 Tota 328

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-09-08-12
DATE:	09-08-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS						
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	OFF	291	197	OFF	250	692	562	1104	9107.40	Not	340	Hilton
8 AM	OFF	283	211	OFF	235	707	1032	688	10166.40	working	37	ABRAMS
9 AM	OFF	292	189	OFF	251	698	563	676	10166.50		84	
10 AM	OFF	288	200	196	183	880	564	1094	11649.50		132	
11 AM	OFF	278	208	197	197	858	568	1111	12284.50		182	
12 PM	OFF	268	196	198	228	862	562	1106	11296		235	
1 PM	OFF	260	196	203	210	844	1032	698	11649		270	
2 PM	OFF	000	000	000	000	000	000	0001	11649	✓	304	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

Wells #1 & #4 Down for repairs  
Well #2 in at 9:15 am  
Well #4 out at 12:05  
Flow reading start 769528  
End 769922  
Total 664 334

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-07-08-13
DATE:	9-8-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	—	—	—	—	—	—	—	—	—	227	304	SCHAUER	
4 PM	off	259	195	201	223	848	1027	1117	10166.40	working	21	Cavallaro	
5 PM	—	260	200	189	236	850	1018	1104	9813.40	—	75	—	
6 PM	—	283	055	304	199	642	1019	1104	10592.00	—	108	—	
7 PM	—	284	—	192	196	—	—	—	10592.00	—	110	—	
8 PM	—	283	—	198	237	—	—	—	9813.40	—	—	—	
9 PM	—	285	—	196	214	—	—	—	9813.40	—	—	—	
10 PM	—	286	—	197	220	—	—	—	9813.40	—	—	—	
11 PM	—	—	—	—	—	—	—	—	—	—	—	—	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

#### REMARKS

18.00 Flow down P.C.I. working on well 105  
15.33 Flow on line, #1 well down for repair  
17.45 #3 well down for repairs  
18.05 Flow gauges not working  
1 flow strip 7673-000  
2.50 7713-000  
7.00 292.00

#### NOTES

- 1-THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2-EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-08-11
DATE:	9-19-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS			
11 PM	Down	288	Down	201	198	Down	Down	Down	9813 1/2	Down	Down	LLOYD			
12 AM		286		203	244				9813 1/2			Downells			
1 AM		283		204	244				11296 00						
2 AM		288		205	245				10943 00						
3 AM		285		196	201				10943 00						
4 AM		286		204	223				12284 40						
5 AM		246		202	238				10943 00						
6 AM	V	284	V	194	244	V	V	V	10943 00	V	V				
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

WELL'S 1 + 3 DOWN FOR REPAIRS

Flow START 77,020.2  
END 77,052.4  
Total 32.2

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BA** **DEPARTMENT OF PUBLIC WORK** **GROUNDWATER TREATMENT FACI**

## **DAILY OPERATIONS WORKSHE** **DAY SHIFT**

FILE ID:	83-09-09-12
DATE:	9-09-93

UD  
PNT not

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					STRIPPER		GPM	SUPERVISOR OPERATOR INITIALS
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	FLOW GPM		
7 AM	000	294	000	204	236	000	000	000	Adams
8 AM	000	288	000	182	237	000	000	000	Coburn
9 AM	000	298	000	195	201	000	000	000	
10 AM	000	288	000	203	242	000	000	000	
11 AM	000	288	000	201	234	000	000	000	
12 PM	000	288	000	207	145	000	000	000	
1 PM	000	284	000	196	240	000	000	000	
2 PM	000	284	000	147	242	000	000	000	
3 PM	000	284	000	147	242	000	000	000	
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

### REMARKS

Start 770524 PNT on site at 14:20  
Well #1, #3 Down for repairs  
Total 330,000

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-09-09-13
DATE:	9-9-93

WELLFIELD OPERATION										AIR STRIPPER	
GALLONS PER MINUTE											
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BL AIR		
3 PM	-	288	-	187	248	-	-	-	10590.00	Not working	
4 PM	-	288	-	195	236	-	-	-	10166.40	Cavallaro	
5 PM	-	OFF	-	205	192	-	-	-	10166.40		
6 PM	-	-	-	197	256	<del>4527</del>	Run P5 OFF 0000	Run P5 OFF 0000	10166.40	24	
7 PM	-	261	196	202	227	853	1034	1102	9813.40	63	
8 PM	-	266	194	195	230	852	1011	1112	9813.40	111	
9 PM	-	264	204	192	209	840	1044	1113	9813.40	161	
10 PM	-	268	198	204	211	859	1046	1110	9389.60	212	
11 PM	-	-	-	-	-	-	-	-	-		
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

### REMARKS

15 cc Flow gauges not working. P.C.I. on site (Fixed)  
17 of Flow gauges working. P.C.I. off site at 20:10  
#1 Well Down For Repairs.

Flow START: 770852.000  
END: 771186.000  
TOTAL: 334.000

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

PRI NT

FORM

NOT WORKING

CAVALLARO

24

63

111

161

212

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE ID:	93-09-10-11
DATE:	SEPT 10 1993

NO  
PRINT

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR		SUPERVISOR OPERATOR INITIALS
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	FREE FL G	
11 PM	OFF	267	196	200	230	870	1050	685	Working out 10/16/93 D. J. HADLEY
12 AM	✓	272	199	207	196	858	1043	1110	
1 AM		271	195	200	224	868	1045	687	10/16/93
2 AM		OFF	OFF	OFF	OFF	OFF	OFF	OFF	103
3 AM		OFF	OFF	OFF	OFF	OFF	OFF	OFF	
4 AM		OFF	OFF	OFF	OFF	OFF	OFF	OFF	
5 AM		OFF	OFF	OFF	OFF	OFF	OFF	OFF	
6 AM	✓	OFF	OFF	OFF	OFF	OFF	OFF	OFF	
7 AM									
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA

### REMARKS

WELL 1 DOWN FOR REPAIRS  
LIFTING - PLANT SECURED AT 12:50

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-04-10-12
DATE:	09-10-93

WELLFIELD OPERATION										AIR STRIPP	
GALLONS PER MINUTE											
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM			
7 AM	000	000	000	000	000	000	000	000	0		
8 AM	000	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF	working	
9 AM	000	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF		
10 AM	000	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF		
11 AM	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF		
12 PM	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF		
1 PM	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF	0FF		
2 PM	0FF	262	204	197	220	341	679	677	9389.20	✓	
3 PM											
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

### REMARKS

Well #1, ~~down~~ Down for repairs  
Plant Down due to lighting (Power Lines Down)  
Flow reaching start - 771334.000 - 5.000  
End - 771334.000 - 5.000  
Plant Back on line at 14:00

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

PRINT

20

working

ABRAMS

9389.20

V

004



# TOWN OF OYSTER

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT PLANT

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID: 93-02-10-13  
DATE: 9-10-93

WELLFIELD OPERATION GALLONS PER MINUTE												SUPERVISOR/ OPERATOR INITIALS
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	FLOW GPM	AIR FLOW CFM	INCHES WG	MGALS	
3 PM	OFF	263	204	200	216	858	1012	1092	1016.40	—	55	SCHADLER
4 PM		264	205	197	212	854	1040	1112	9813.40	—	50	CHALLACO
5 PM		266	201	197	224	857	1011	1097	9813.40	—	100	
6 PM		269	200	203	208	856	1007	1086	9813.40		157	
7 PM		273	201	193	192	837	1013	1089	9389.50		209	
8 PM		273	202	196	195	836	1007	1090	9107.40		260	
9 PM		276	207	197	203	870	1021	1099	9107.40		313	
10 PM		275	202	193	232	875	575	249	9107.40		360	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

4115.55 Treated Water Recycled

1700 FLOW TREATMENT PLANT NOTIFIED BY K. HANCOCK  
1833 TREATMENT PLANT BY C. M. HANCOCK

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

VO  
PRT/UT

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILED:	93.09.11.11.
DATE:	9.11.93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER		
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM
11 PM	OFF	276	206	300	309	876	577	1104
12 AM		275	206	189	236	878	574	677
1 AM		276	193	204	232	873	574	679
2 AM		274	193	198	237	872	573	678
3 AM		280	194	200	200	872	574	681
4 AM		276	196	204	217	861	577	1101
5 AM		275	197	202	234	878	575	1085
6 AM		276	205	201	208	849	573	682
7 AM								
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA

### REMARKS

# 1 WELL OFF FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

PRI/ST

100

WORKING 59 HILTON

107

156

207

259

319

368

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-09-11-12
DATE:	9-11-93

PRINT

NO

8 + 1455 01

TIME	WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIP	
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM			CHL IN	CHL OUT
7 AM	Down	276	196	200	235	880	574	683	9107.40	Down	419	Hilltop
8 AM		275	206	200	199	815	573	675	9107.40		53	<del>Hilltop</del>
9 AM		274	207	195	227	868	576	1094	9107.40		109	NIX
10 AM		277	204	191	237	879	575	1091	9107.40		162	
11 AM		276	206	193	236	861	576	1103	9107.40		224	
12 PM		268	202	204	200	860	308	1094	1327280		279	
1 PM	✓	280	196	198	232	881	001	0005	12002	✓	327	
2 PM		281	196	205	213	851	001	0001	12002		377	
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

### REMARKS

Well #1 Down For Repair

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-09-11-13
DATE:	SEPT 11 1993

2569

20

[illegible]

# WELL I DOWN FOR RETAIES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER B. DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FIELD ID: 93-09-12-11  
DATE: 4-12-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIRS		RISON RATOR TALS	
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FLOW GPM					
11 PM	David	277	203	193	235	880	576	677	797789	David	426	LLOYD	
12 AM		276	205	193	233	876	579	689	847208		48	H/HEN	
1 AM		280	205	189	209	873	579	686	9107 1/2		101		
2 AM		277	206	194	208	835	580	1101	9107 1/2		157		
3 AM		281	193	204	201	880	577	679	9107 1/2		210		
4 AM		280	204	204	208	875	577	677	9107 1/2		260		
5 AM	✓	277	191	203	237	887	577	684	9813 1/2	✓	316		
6 AM		280	204	200	192	854	577	1089	9813 1/2		364		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 well down for repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

NO

PRINT

8 hrs 07

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-09-12-13
DATE:	SEPT 12, 1993

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	276	197	202	224	857	583	1086	1016 <sup>uo</sup>	105 <sup>uo</sup>	422	Nix		
4 PM	1	277	196	205	231	865	581	678	1016 <sup>uo</sup>	105 <sup>uo</sup>	50	Downells		
5 PM		276	206	200	222	862	585	1101	10530 <sup>uo</sup>	105 <sup>uo</sup>	100			
6 PM		280	196	200	208	886	586	1059	10530 <sup>uo</sup>	105 <sup>uo</sup>	153			
7 PM		280	194	202	218	830	586	1096	10590 <sup>uo</sup>	105 <sup>uo</sup>	204			
8 PM		276	204	204	224	874	584	1039	10543 <sup>uo</sup>	105 <sup>uo</sup>	262			
9 PM		278	196	203	229	862	582	678	1016 <sup>uo</sup>	105 <sup>uo</sup>	313			
10 PM	✓	281	192	200	209	869	586	1104	10570 <sup>uo</sup>	105 <sup>uo</sup>	364			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

WELL #1 DOWN FOR REPAIRS -

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-13-11
DATE:	SEP 13 1993

WELLFIELD OPERATION GALLONS PER MINUTE											AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	OFF	276	202	208	194	836	586	1103	10590 <sup>02</sup>	NO <sup>1</sup> WEEKS	414	LLOYD		
12 AM		277	208	193	214	874	588	1105	10443 <sup>02</sup>		49	DOUGLAS		
1 AM		278	204	192	235	881	585	1085	10166 <sup>40</sup>		104			
2 AM		280	202	202	203	836	582	678	9813 <sup>40</sup>		156			
3 AM		278	202	197	238	880	582	672	9813 <sup>40</sup>		205			
4 AM		282	185	193	195	876	583	1106	10940 <sup>02</sup>		264			
5 AM		276	204	196	231	883	585	1096	9813 <sup>40</sup>		316			
6 AM	✓	281	196	194	214	878	582	1093	10902 <sup>02</sup>	✓	369			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

WELL 1 DOWN FOR REPAIRS

#### NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-09-18-13
DATE:	9-18-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW GALLS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	280	241	191	240	889	1018	1119	Down	Not Working	422	Schadler	
4 PM	OFF	280	205	202	235	881	1009	1113	Not Working	1	51	Caret	
5 PM	OFF	283	195	204	200	880	1006	1112	Not Working		107	" "	
6 PM	OFF	280	208	192	217	850	0559	1111	Not Working		162	" "	
7 PM	OFF	279	207	196	202	834	0563	1103	Not Working		212	Lloyd	
8 PM	OFF	281	192	203	233	878	573	1099	Not Working		268	" "	
9 PM	OFF	277	202	192	238	886	564	660	Not Working		321	" "	
10 PM	OFF	276	204	191	233	876	568	1010	Not Working		372	" "	
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#2 Well is down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILED:	93-08-19-11
DATE:	9-19-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	OFF	279	205	192	233	880	1010	1112	DOF	DOF	DOF	424	LLOYD
12 AM	1	280	197	196	201	820	576	684	NOT WORKING			419	HILTON
1 AM		280	206	193	224	861	564	1102	N.W.			102	
2 AM	1	278	201	204	214	845	581	1107	N.W.			154	
3 AM		280	196	204	203	879	560	1106	N.W.			206	
4 AM		282	206	192	198	879	571	685	N.W.			261	
5 AM		282	205	193	201	873	576	1112	N.W.			310	
6 AM	✓	280	193	191	236	880	573	685	N.W.			364	
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 Well Down for Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-09-19-12
DATE:	9-19-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS					EFFLUENT FLOW MGALS	SUPERVISOR OPERATION INITIALS
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES HG		
7 AM	055	276	206	196	234	878	1046	1105	N/A	26.0	414	Rodgers
8 AM	055	276	196	196	232	879	1051	1106	N.25	↑	52	Capey
9 AM	055	277	204	202	232	874	1034	1118	20		107	..
10 AM	055	279	199	203	203	835	1037	1118	20		156	..
11 AM	055	280	194	201	237	889	1045	1126	20		211	..
12 PM	055	275	192	204	232	874	1035	1114	20		261	..
1 PM	055	280	208	196	184	864	1030	1120	20		317	..
2 PM	055	280	205	191	225	879	1039	1124	20		368	..
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 well is down for repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-09-19 13
DATE:	9-19-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE PSI	EFFLUENT FLOW GALLS	SUPERVISOR/ OPERATOR INITIALS			
3 PM	OFF	276	196	199	228	863	1022	1116	Not Working	Not Working	424	LLOYD			
4 PM	OFF	279	196	200	231	890	1022	1118	Not Working	✓	53	Capeley			
5 PM	OFF	278	206	188	238	882	1029	1121	Not Working		106	..			
6 PM	OFF	279	194	204	232	880	1015	1114	Not Working		159	..			
7 PM	OFF	280	201	206	192	854	1014	1111	Not Working		213	..			
8 PM	OFF	282	191	191	239	862	1022	1120	Not Working		265	..			
9 PM	OFF	275	206	193	236	891	1010	1115	Not Working		320	..			
10 PM	OFF	283	194	201	203	880	1010	1112	Not Working		371	..			
11 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

#### REMARKS

#1 Well is down for repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-20-11
DATE:	9-20-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
11 PM	OFF	277	200	199	236		883	1025	1121	N.W.	DOT	420	LEOYD		
12 AM		280	192	204	229		880	1024	1118	N.W.	WORKING	54	DOUGLAS		
1 AM		277	206	192	236		876	581	1116	13272 <sup>89</sup>		109			
2 AM		279	204	203	225		866	1019	1119	13837 <sup>20</sup>		161			
3 AM		284	192	200	198		871	560	1107	13837 <sup>48</sup>		215			
4 AM		280	191	203	235		880	571	1112	13555 <sup>20</sup>		248			
5 AM		276	203	200	225		883	565	1095	13555 <sup>24</sup>		322			
6 AM	✓	268	196	196	195		838	1006	1106	13555 <sup>20</sup>	✓	361			
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 WELL DOWN FOR REPAIR

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FILE ID:	93-09-20-12
DATE:	9-20-93

WELFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
7 AM	Down	268	199	199	215	857	1018	1115	797780	Down	406	ABK/MS		
8 AM	1	272	199	202	192	842	1017	1120	12919, 30	1	52	HL/HL		
9 AM	1	273	204	204	212	867	1015	1115	Not working	1	104			
10 AM	1	272	194	204	231	877	574	1093	Not working		158			
11 AM	1	276	196	198	235	873	563	1097	Not working		209			
12 PM	1	276	207	195	196	841	571	0001	Not working		261			
1 PM	✓	276	197	195	235	875	579	0001	Not working	✓	312			
2 PM		279	195	203	190	822	573	0001	Not working		362			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

11 wells Down for repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-09-20-13
DATE:	SEPT 20, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	off	275	203	190	222	874	583	681	107 working	107 working	415	Schallert	
4 PM		275	196	200	235	875	586	687	111 w		51	Donnell	
5 PM		276	207	192	206	858	1036	1118	N/W		102		
6 PM		274	201	194	233	862	579	664	N-Y		156		
7 PM		280	205	194	186	878	1053	689	1243 <sup>10</sup>		206		
8 PM		276	200	200	220	866	1041	1054	1263 <sup>10</sup>		256		
9 PM		275	204	200	223	867	1038	1123	1263 <sup>40</sup>		312		
10 PM	✓	276	196	204	217	868	1038	1124	N/W	✓	307		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

WELL 1 DOWN FOR 123 PAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-21-11
DATE:	SEP 21, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES H <sub>2</sub> O	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	OFF	276	198	201	236	878	562	1103	N.W.	NOT WORKING	427	LLO'N'D	
12 AM		275	207	196	223	858	1040	1121	N.W.		45	DRIVEIS	
1 AM		276	194	202	227	855	1040	1124	N.W.		98		
2 AM		276	207	192	222	862	1029	1119	N.W.		150		
3 AM		280	208	194	205	851	1013	1115	N.W.		207		
4 AM		280	196	199	237	882	1017	1120	N.W.		258		
5 AM		278	203	192	235	880	1005	1111	N.W.		312		
6 AM	V	278	196	204	221	868	1014	1109	N.W.		366		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

WELL 1 DOWN FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### DAY SHIFT

FILE ID:	93-09-21-12
DATE:	9/21/93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
7 AM	Down	278	204	204	191	821	1020	1118	Not working	Down	412	Hilton	
8 AM		275	192	203	225	867	1016	1115	Not working		47	ABRAMS	
9 AM		278	192	204	228	869	573	1098	Not working		103		
10 AM		280	205	188	225	878	1072	1115	Not working		154		
11 AM		280	196	205	200	879	570	0002	Not working		207		
12 PM	✓	280	200	193	224	881	574	1096	12284.40		257		
1 PM	✓	277	200	199	230	868	570	0001	13272.80	✓	309		
2 PM		273	198	205	220	847	579	680	Not working		359		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

#1 well Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE D:	93-09-21-15
DATE:	9-21-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW GALLONS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	055	277	200	204	205	876	590	687	N.O.	No Work,	440	Schodick	
4 PM	055	278	207	199	193	822	1005	683	N.O.	✓	49	Capeis	
5 PM	055	279	202	195	217	876	577	681	N.O.		104	"	
6 PM	055	279	204	189	228	874	588	686	N.O.		156	"	
7 PM	055	276	208	196	215	834	1045	1096	N.O.		210	"	
8 PM	055	275	204	190	234	880	583	661	N.O.		259	"	
9 PM	055	277	204	191	234	877	1053	1112	N.O.		311	"	
10 PM	055	278	206	195	199	829	1043	1133	N.O.	✓	364	"	
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

# 2 Well is down for Repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-22-11
DATE:	SEPT 22, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	SPRINKLER FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
11 PM	OFF	279	196	201	208	872	1036	1114	N-W	WALKERS	416	LLOYD	
12 AM		276	196	204	217	856	1048	1125	N.W.		51	DAVIDS	
1 AM		281	200	202	192	874	572	1074	N.W.		104		
2 AM		276	204	201	232	874	1041	717	N.W.		158		
3 AM		000	000	000	000	000	0000	0000	N.W.		205		
4 AM		000	000	000	000	000	0000	0000	N.W.		205		
5 AM		267	195	201	204	838	558	1110	N.W.		247		
6 AM	✓	268	199	197	213	855	1012	1115	N.W.	✓	208		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

WELL 1 DOWN FOR REPAIRS  
Down Due To Leaking 2:40 AM  
Started Pumps 4 AM

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FIELD:	93-09-28-12
DATE:	09-28-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATION INITIALS		
7 AM	OFF	268	198	198	212	848	583	685	not working	not working	352	Hilton		
8 AM		271	200	196	190	828	1041	1107	working	working	47	ABRAMS		
9 AM		272	205	194	191	832	1037	1114	not working		103			
10 AM		272	192	194	232	863	1041	1110	not working		151			
11 AM		274	194	200	233	875	1028	1119	not working		206			
12 PM		279	197	199	195	842	1015	1118	not working		265			
1 PM		280	196	203	191	839	1020	1113	not working		312			
2 PM	V	275	192	204	236	882	1012	1112	not working	V	365			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 well down for repairs  
ATP on site at 11:30

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-09-22-13
DATE:	9-22-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE					AIR STRIPPER OPERATING PARAMETERS					EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE PSI		
3 PM	Down	281	196	198	192	860	1015	1113	Not working	Down	418	Schmoller
4 PM		276	200	194	203	819	1024	1115			51	Hilton
5 PM		276	192	204	228	875	564	1104			110	
6 PM		276	202	193	236	883	1013	1117			157	
7 PM		280	194	200	208	833	1013	1112			211	
8 PM		277	204	195	232	877	561	1106			262	
9 PM		276	208	193	201	837	586	685			317	
10 PM		276	205	206	195	828	572	681			367	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 well Down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

8/11/01



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FIELD:	93-09-23-11
DATE:	SEP 23/1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	WELL 7 FLOW	WELL 8 FLOW	WELL 9 FLOW	STRIPPER FLOW GPM	WHEEL FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	OFF	274	199	200	235			878		1032	1132	N-W	NO WHEELS	423	110712
12 AM	1	280	196	202	222			879		585	1107	N-W	1	45	DOWNED
1 AM	1	195	203	193	280			818		524	1054	N-W		95	
2 AM		276	197	204	234			886		572	1112	N.W.		149	
3 AM		276	198	195	234			879		587	683	N.W.		203	
4 AM	1	272	200	202	206			826		1047	682	N.W.		252	
5 AM		272	204	200	223			861		579	687	N.W.		309	
6 AM	V	279	197	202	188			825		577	688	N.W.	V	360	
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

### REMARKS

WELL 1 DOWN FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-09-23-12
DATE:	09-23-93

WELLS OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS			
7 AM	000	217	204	146	205	869	1056	1121	1051040	NOT	408	COOPER			
8 AM	000	215	204	134	230	862	1056	1124	12687.40	NOT	408	ABRAMS			
9 AM	000	215	208	202	186	819	1015	1113	12657.40		105				
10 AM	000	214	204	194	234	878	1026	1115	6213.40		155				
11 AM	000	225	133	202	229	886	1023	1121	12084.40		210				
12 PM	000	230	208	191	198	877	1019	1106	12284.40		265				
1 PM	000	274	46	204	285	889	1011	1111	6213.40		316				
2 PM	000	276	204	189	236	885	1008	1115	12002.40		321				
3 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

### REMARKS

#1 Well Down for repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE NO.	93-09-23-13
DATE:	9-23-93

WELL FLOW OVERLAP										AIR STRIPPER OPERATING PARAMETERS									
TIME	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	WELL FLOW	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM
3 PM	OFF	275	203	201	234	887	1023	1110	1016.40	NOT WORKING	421	LLOYD							
4 PM		281	191	200	225	870	1002	1113	10943.00	WORKING	53	CAWLLING							
5 PM		278	200	193	236	876	1004	1112	10943.00		105								
6 PM		280	193	195	220	868	1017	1113	11246.00		158								
7 PM		277	196	203	199	855	1017	1115	10590.00		210								
8 PM		277	190	191	237	873	576	523	10590.00		265								
9 PM		276	195	197	230	877	998	1120	NOT WORKING		315								
10 PM		278	194	205	217	859	967	1102	NOT WORKING		362								
11 PM																			
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA								

#### REMARKS

#1 WELL Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID: **93-09-24-11**  
 DATE: **SEPT 24, 1993**

WELL HEAD OPERATION CALLING PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
11 PM	OFF	283	185	198	184	875	1007	1114	N-W-W	WAKENS	422	Schadler		
12 AM		269	201	196	192	813	1042	1106	N-W		417	DOUGHERT		
1 AM		276	195	223	230	823	568	567	N-W		106			
2 AM		276	204	191	220	874	1048	1117	N-W		156			
3 AM		277	192	202	232	881	1024	1112	N-W		201			
4 AM		273	192	202	228	876	1043	1067	N/W		257			
5 AM		274	203	194	220	860	1044	1112	N/W		305			
6 AM	✓	280	202	194	202	1874	1025	1119	N/W	✓	365			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

WELL 1 DOWN FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-09-24-13
DATE:	9-24-93

TIME	WELFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
7 AM	OFF	278	196	192	227	869	1038	1121	13937.0	NOT WORKING	409	Wix
8 AM	OFF	277	201	196	218	876	1043	1118	NOT WORKING		33	Capey
9 AM	OFF	275	195	203	236	881	1029	1121	NOT WORKING		107	Abrams
10 AM	OFF	277	194	197	229	882	1017	1119	NOT WORKING		162	"
11 AM	OFF	280	195	204	199	875	1034	1117	NOT WORKING		211	"
12 PM	OFF	276	200	192	234	884	1022	1120	NOT WORKING		265	"
1 PM	OFF	280	201	198	205	876	1020	1116	NOT WORKING		319	"
2 PM	OFF	275	204	200	222	854	1025	1116	NOT WORKING		371	"
3 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 Cell #11 is down for repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-09-24-13
DATE:	9-24-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS
3 PM	OFF	276	189	203	236	881	1009	1114	NOT WORKING	NOT WORKING	424	Se Habler
4 PM		278	204	193	229	872	1019	1121	WORKING	WORKING	51	Cavallaro
5 PM		281	200	197	189	825	1025	1116			103	
6 PM		281	192	202	204	851	1009	1117			156	
7 PM		280	197	193	202	850	1012	1120			208	
8 PM		276	194	205	236	873	1004	1112			261	
9 PM		279	206	202	189	821	1003	1112			316	
10 PM		277	196	204	212	849	1046	1109			368	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 WELL DOWN FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET NIGHT SHIFT

FILE ID: 93-09-25-11  
DATE: 9-25-93

TIME	WELLFIELD OPERATION GALLONS PER MINUTE						AIR STRIPPER OPERATING PARAMETERS					
	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW GALS	SUPERVISOR/ OPERATOR INITIALS
11 PM	off	234	202	198	235	880	567	002	Not	Not	417	SCUARDER
12 AM		276	207	196	202	835	577	001	Working	Working	50	HILTON
1 AM		277	198	190	237	882	577	675			100	
2 AM		274	204	196	192	867	1056	684			151	
3 AM		276	205	198	202	805	1036	1122			204	
4 AM		274	192	204	232	875	1057	684			254	
5 AM		274	196	204	232	882	1038	1112			307	
6 AM		276	202	204	196	821	1037	1125			360	
7 AM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 WELL OFF FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FIELD ID:	93-09-25-12
DATE:	9-25-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
7 AM	OFF	278	203	196	224	871	1040	1120	N.C.	N.C.	415	W.R.	
8 AM	OFF	380	192	202	192	857	1035	1121	"	"	52	Capek	
9 AM	OFF	276	204	192	236	873	1028	1122	"	"	104	"	
10 AM	OFF	281	192	205	210	877	1027	1116	"	"	158	"	
11 AM	OFF	276	198	196	236	875	1013	1111	"	"	213	"	
12 PM	OFF	275	207	200	204	810	1010	1118	"	"	267	"	
1 PM	OFF	275	204	196	228	864	1017	1114	"	"	317	"	
2 PM	OFF	276	195	203	205	819	1007	1113	"	"	369	"	
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 Well is down for repairs.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-09-2513
DATE:	9-25-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	277	192	205	228	873	1017	1121	nd	nd	42.5	Nix		
4 PM	OFF	281	205	195	198	883	558	1106	nd	nd	50	Cape		
5 PM	OFF	278	192	204	237	890	564	1103	nd	nd	103	..		
6 PM	OFF	280	193	204	216	875	574	1099	nd	nd	156	..		
7 PM	OFF	276	207	191	228	866	1017	1103	nd	nd	207	..		
8 PM	OFF	279	196	193	227	877	572	1001	nd	nd	257	..		
9 PM	OFF	276	207	194	190	876	587	1083	nd	nd	309	..		
10 PM	OFF	280	194	205	196	879	1017	1105	nd	nd	358	..		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 Well is down for repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FIELD #	92-09-26-11
DATE	9-26-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGAL	SUPERVISOR OPERATOR INITIALS	
11 PM	Down	279	201	196	201	875	579	686	NOT	NOT	411	LLOYD	
12 AM		278	202	195	194	863	590	683	WORKING	WORKING	50	14 Hsu	
1 AM		273	199	204	233	873	576	681			102		
2 AM		276	193	205	229	871	1043	1107			154		
3 AM		274	202	200	233	877	1053	686			207		
4 AM		276	205	196	228	874	1039	1113			260		
5 AM		278	195	200	216	880	1043	717			314		
6 AM		276	206	197	195	818	1042	1118			365		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 Well Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-09-26-12
DATE:	9-24-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
7 AM	OFF	280	197	198	195	801	1015	1118	Not Mon.	Not Mon.	421	N. S.		
8 AM	OFF	278	198	197	220	853	1017	1120	..		53	Capels		
9 AM	OFF	276	201	200	233	879	1020	1110	..		106	..		
10 AM	OFF	280	192	204	216	880	1007	1114	..		159	..		
11 AM	OFF	277	202	198	193	803	1006	1116	..		213	..		
12 PM	OFF	284	196	201	190	881	0557	1108	..		267	..		
1 PM	OFF	278	203	195	195	870	0562	1104	..		319	..		
2 PM	OFF	283	192	203	192	864	0573	1099	..		372	..		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

# 16211-15 Down for Repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-09-2C-13
DATE:	9-20-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	272	197	199	232	0883	0527	0042	Not Data	Not Data	424	N. v		
4 PM	OFF	276	193	199	232	0881	0571	0001	Not Data		50	C. acet		
5 PM	OFF	279	195	206	189	0877	0580	0001	Not Data		100	..		
6 PM	OFF	279	206	196	211	0874	1020	1110	Not Data		149	..		
7 PM	OFF	276	204	192	235	0880	1047	0689	Not Data		202	..		
8 PM	OFF	276	198	202	239	0884	0589	0683	Not Data		253	..		
9 PM	OFF	276	190	202	232	0878	1044	1110	Not Data		306	..		
10 PM	OFF	276	203	201	194	0839	1045	1108	Not Data		356	..		
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

#1 Well is down for repairs.

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-21-11
DATE:	SEPT 27, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW
11 PM	OFF	276	194	201	232	879	1050	1106	1291	1327	1327	1327	1327	1327	1327
12 AM		276	193	197	233	874	1039	1112	1327	1327	1327	1327	1327	1327	1327
1 AM		0	0	0	0	0	0	0	0	0	0	0	0	0	0
2 AM		0	0	0	0	0	0	0	0	0	0	0	0	0	0
3 AM		276	197	203	188	835	1042	1107	1164	1164	1164	1164	1164	1164	1164
4 AM		267	194	200	200	840	1022	1111	1164	1164	1164	1164	1164	1164	1164
5 AM		268	204	196	206	857	563	1113	1164	1164	1164	1164	1164	1164	1164
6 AM		272	194	197	200	848	1017	1120	1164	1164	1164	1164	1164	1164	1164
7 AM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

#### REMARKS

#1 WELL OFF FOR REPAIR  
PLANT SHUT DOWN 12:30 AM DUE TO LIGHTNING  
ON LINE 2:30 AM

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-09-27-12
DATE:	9-27-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
7 AM	Down	272	193	196	226	862	1025	1117	NOT	NOT	318	AKKANS	
8 AM		274	202	198	191	861	1006	1115	WORKING	WORKING	46	AKKANS	
9 AM		275	203	192	234	874	581	1112			99		
10 AM		278	204	189	234	876	557	1110			153		
11 AM		276	204	196	236	870	569	0002			207		
12 PM		000	000	000	000	0024	0001	5601			253		
1 PM		000	000	000	000	0001	000	0001			253		
2 PM		272	205	198	227	784	1060	0001			253		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 well Down For Repairing  
Shut plant down due to lighting at 11:50 am  
STARTED Plant A 1:50 PM

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILED:	93-09-27-13
DATE:	9-27-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FILT FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	264	198	203	221	853	1045	1103	NOT	NOT	299	Schadler		
4 PM		268	194	204	194	828	1035	1116	working	working	53	Cavallaro		
5 PM		270	196	195	231	858	1041	1117			105			
6 PM		272	203	201	201	854	1024	1119			158			
7 PM		272	206	194	231	872	1027	1123			210			
8 PM		274	202	200	224	874	1029	1117			263			
9 PM		274	196	204	203	851	1014	1118			316			
10 PM		275	192	204	235	879	1011	1119			371			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 WELL Down For Repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE ID:	93-09-28-11
DATE:	9-28-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	FRESH FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS	
11 PM	off	282	199	197	192	879	539	1105	Not	Not	428	SCHADLER	
12 AM	1	274	204	200	220	870	561	1115	Working	Working	418	DOUGLASS	
1 AM	1	276	193	201	235	875	1011	1119	1	1	100		
2 AM	1	278	194	205	212	849	569	0000	1	1	150		
3 AM	1	280	192	202	218	857	1015	1115	1	1	202		
4 AM	1	274	198	202	213	837	1049	1104	1	1	255		
5 AM	1	274	203	190	234	875	571	0001	1	1	304		
6 AM	1	276	200	193	210	867	1046	687	1	1	358		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 WELL OFF FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-09-28-12
DATE:	09-28-93

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
7 AM	067	273	204	194	231	875	586	683	Not	Not	409	Hilton		
8 AM		277	208	194	195	864	1024	1121	working	working	50	ABRAMS		
9 AM		273	194	197	235	880	577	0001			100			
10 AM		273	202	196	232	871	1056	684			154			
11 AM		273	204	203	224	857	1045	682			207			
12 PM		274	197	203	223	852	1043	1110			260			
1 PM		279	196	198	192	869	1052	687			312			
2 PM		280	204	195	193	869	1021	1120			362			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 Well Down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **EVENING SHIFT**

FILE ID:	93-09-28-13
DATE:	9-28-93

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS																																																																																																																																																																																																																																																																																																																																																																				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	STRIPPER FLOW GPM	STRIPPER FL FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER FLOW GPM	STRIPPER 

### REMARKS

#1 WELL Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE ID:	83-09-29-11
DATE:	8-29-93-1

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
11 PM	OFF	277	196	200	206	874	725	687	14120 <sup>2</sup>	NOT	417	LLOYD		
12 AM	1	277	204	193	229	869	568	1108	N.W.	WORKING	51	DOONELIS		
1 AM	1	278	207	196	212	843	563	1099	N.W.	1	105			
2 AM	1	277	192	202	233	876	571	1110	N.W.	1	155			
3 AM		276	205	202	189	814	590	683	N.W.	1	202			
4 AM		273	200	199	224	857	574	687	N.W.		254			
5 AM		277	204	194	235	836	1032	1123	N.W.		307			
6 AM	✓	282	193	196	210	847	102	1107	N.W.	✓	364			
7 AM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

11 / Well Down for Repair

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET DAY SHIFT

FILE ID:	93-04-29-12
DATE:	09-29-93

WELFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FIL. FLOW GPM	DELIVERED AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATION INITIALS
7 AM	off	274	205	199	214	844	1041	1058	1105	working	working	411	H. H. on
8 AM		271	204	203	199	873	1043	1105	1122			52	ABRAMS
9 AM		279	191	203	219	873	1032	1122				106	
10 AM		277	200	192	208	868	1035	1110				163	
11 AM		278	206	196	199	866	1021	1119				211	
12 PM		277	200	195	233	883	1022	1119				264	
1 PM		281	197	205	184	859	1010	1111				316	
2 PM		276	196	204	232	881	1009	1115				369	
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

### REMARKS

#1 well down for repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-09-29-13
DATE:	9-29-93

WELL HEAD OPERATIONS CALCULATED PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
3 PM	OFF	280	196	192	232	865	1022	1120	NOT	NOT	421	SCHADLER		
4 PM		276	192	204	236	876	1001	1108	WORKING	WORKING	53	CAVALLARO		
5 PM		277	196	200	219	848	1010	1116			104			
6 PM		277	194	204	233	875	1007	1116			158			
7 PM		278	204	192	222	859	1041	1103			210			
8 PM		276	204	196	225	870	1027	1111			261			
9 PM		272	196	203	224	865	1007	1115			308			
10 PM		279	203	195	184	829	1040	1107			360			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE #	93-09-30 - 11
DATE	9-30-93

WELLFIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	STRIPPER FLOW GPM	FRESH FL. FLOW GPM	BUBBLER AIR FLOW GPM	AIR PRESSURE PSI	EFFLUENT FLOW MGAL	SHIPPER/WORK OPERATOR INITIALS	
11 PM	OFF	277	200	192	206	875	1049	1110	Not	Not	414	LLOYD	
12 AM		273	203	198	230	867	1043	1112	working	working	51	Cavallaro	
1 AM		277	194	194	233	864	1044	1103			103		
2 AM		274	206	204	217	859	1048	1120			157		
3 AM		274	205	196	229	860	1037	1117			208		
4 AM		280	208	195	198	855	1026	1120			261		
5 AM		279	204	195	199	871	1042	1115			315		
6 AM		275	203	201	228	881	1027	1117			369		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 WELL Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FILE ID:	93-09-30-12
DATE:	9-30-93

WELLFIELD OPERATION GALLONS PER MINUTE												AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES HG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS			
7 AM	800	274	143	202	234	876	1017	1117	not working	not working	425	Heenan			
8 AM	Down	275	204	192	236	876	560	1105	working	working	55	Hilton			
9 AM		273	207	196	208	837	1043	685			105				
10 AM		278	208	199	192	812	1013	1115			153				
11 AM		280	203	202	233	872	1027	1121			204				
12 PM		279	204	189	218	880	566	1094			259				
1 PM		281	196	204	193	878	1004	1113			312				
2 PM		276	203	198	234	873	559	1104			362				
3 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA					

### REMARKS

#1 well down for repaired

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

8466

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **EVENING SHIFT**

FILE #	93-09-30-13
DATE	9-30-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	WELL 7 FLOW	WELL 8 FLOW	WELL 9 FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR OPERATION NOTES
3 PM	OFF	276	204	198	229	868	1001	1099	NOT	411	LLOYD				
4 PM		276	203	205	235	876	1048	1107	WORKING	52	CAVALLA				
5 PM		273	195	193	236	862	1042	1110		103					
6 PM		279	196	206	201	866	1041	1116		153					
7 PM		278	194	207	197	862	1021	1097		204					
8 PM		275	204	203	217	868	1045	1107		255					
9 PM		275	198	205	225	870	1036	1110		307					
10 PM		278	207	195	217	850	1015	1117		360					
11 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

### REMARKS

#1 WELL Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FILE ID	93-09-13-12
DATE	SEPT 13, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATION INITIALS		
7 AM	OFF	278	202	204	217	884	582	678	11296 <sup>20</sup>	NOT WORKING	415	HILTON		
8 AM	1	278	206	198	195	835	586	1083	12637 <sup>10</sup>	1	58	ALBENS		
9 AM	1	281	196	203	214	878	586	1097	907 <sup>10</sup>	1	109			
10 AM	1	279	203	195	209	820	585	1106	1016 <sup>10</sup>	1	163			
11 AM	1	277	193	205	220	853	585	1086	10580 <sup>10</sup>	1	219			
12 PM	1	280	203	192	216	874	582	676	9107 <sup>10</sup>	1	270			
1 PM	1	281	204	193	184	865	585	1047	11649	1	321			
2 PM	V	280	206	192	216	872	584	1090	11649	V	382			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

WELL #1 DOWN FOR REPAIRS

### NOTES

1. THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
2. EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### EVENING SHIFT

FILE ID:	93-09-13-13
DATE:	9-13-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS		
3 PM	OFF	278	196	204	226	871	1027	1092	10590.00		428	SCHADLER		
4 PM		277	197	205	220	867	1027 1027	1092 679	10943.00		52	CAVALLARO		
5 PM		277	205	190	234	880	1045	1108	10943.00		103			
6 PM		276	203	193	239	884	1027	1115	10590.00		158			
7 PM		279	192	204	237	878	1047	1100	10166.40		207			
8 PM		276	195	204	238	881	1009	1113	9389.80		262			
9 PM		276	200	193	230	864	1027	1092	10590.00		316			
10 PM		276	201	199	238	877	578	687	10590.00		370			
11 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 Well Down For Repairs.

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### NIGHT SHIFT

FILE ID:	93-05-14-11
DATE:	SEPT 14, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	WELL 6 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	AIR PRESS. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS
11 PM	OFF	279	153	200	233	883	576	677	10116 <sup>40</sup> / <sub>100</sub>	NOT WORKING		416	LLOYD
12 AM		281	196	194	224	888	580	1100	10166 <sup>40</sup> / <sub>100</sub>			55	BOUNERS
1 AM		280	204	206	194	871	579	1090	9107 <sup>40</sup> / <sub>100</sub>			107	
2 AM		277	195	204	232	876	578	1088	9107 <sup>40</sup> / <sub>100</sub>			163	
3 AM		278	188	202	231	881	579	1101	9107 <sup>40</sup> / <sub>100</sub>			217	
4 AM		277	192	206	230	862	579	685	10943 <sup>40</sup> / <sub>100</sub>			264	
5 AM		275	205	200	230	874	580	1095	9913 <sup>40</sup> / <sub>100</sub>			317	
6 AM	✓	278	207	196	192	839	580	1100	10590 <sup>40</sup> / <sub>100</sub>		✓	376	
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

WELL #1 DOWN FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FIELD:	93-09-14-12
DATE:	09-14-93

WELTFIELD OPERATION										AIR STRIPPER OPERATING PARAMETERS									
GALLONS PER MINUTE																			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR/ OPERATOR INITIALS							
7 AM	OFF	278	203	191	230	880	577	679	6918.86	204	432	Hilton							
8 AM		278	197	191	238	880	577	684	7983.62	working	44	ABRAMS							
9 AM		280	206	194	200	878	576	675	1016.40		96								
10 AM		281	193	203	203	884	578	683	7977.80		150								
11 AM		275	204	204	233	871	577	1081	13272.82		206								
12 PM		276	204	205	192	795	578	1091	13837.62		257								
1 PM		276	196	205	235	875	575	683	14120		310								
2 PM		277	206	195	207	876	579	1112	11796	✓	361								
3 PM																			
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA									

#### REMARKS

Well #1 Down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-09-14-13
DATE:	9-14-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS					SUPERVISOR OPERATOR INITIALS
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	STRIPPER FLOW	
3 PM	OFF	280	206	194	193	849	1047	1105	9389.80					414	SCHADLER
4 PM		278	189	204	238	882	1012	1120	9813.40					54	CAVALLARO
5 PM		277	203	201	217	860	1040	1107	9813.40					106	
6 PM		277	206	204	228	876	1027	1113	9107.40					155	
7 PM		278	200	199	232	872	1047	1102	1016.40					210	
8 PM		—	200	204	233	632	1047	1102	9389.80					244	
9 PM		—	205	202	229	620	1042	1100	9107.40					285	
10 PM		—	207	193	237	633	1042	1100	9107.40					325	
11 PM															
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	

#### REMARKS

#1 WELL DOWN FOR REPAIRS  
19:02 #2-3-4-5 WELLS STOPPED RUNNING.  
19:05 #3-4-5 WELLS BACK ON LINE. #2 WILL NOT COME BACK

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FIELD:	93-09-15-11
DATE:	9-15-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
11 PM	OFF	OFF	198	192	238	628	572	693	9389 <sup>80</sup>	NOT	360	LLOYD	
12 AM			200	210	192	598	566	691	9389 <sup>80</sup>	WORKING	37	DOONELIS	
1 AM			194	208	192	598	558	687	7483 <sup>60</sup>		78		
2 AM			192	194	244	630	552	681	8472 <sup>80</sup>		119		
3 AM			194	208	200	597	572	689	8472 <sup>80</sup>		148		
4 AM			200	200	220	624	566	686	8472 <sup>80</sup>		190		
5 AM		✓	208	200	246	636	558	679	8472 <sup>80</sup>	✓	230		
6 AM	✓		202	209	245	624	558	681	9389 <sup>80</sup>		260		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

Well's 1 + 2 Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILE ID:	93-09-15-12
DATE:	09-15-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
7 AM	OFF	000	203	195	182	623	576	685	10590.00	201	303	Hilton		
8 AM		230	196	204	231	864	573	682	12637.40	working	38	AB44115		
9 AM		266	197	202	217	856	584	1098	14120		40			
10 AM		272	199	194	228	864	583	1112	9107.40		140			
11 AM		274	194	205	196	851	584	1104	14120		193			
12 PM		272	200	203	222	870	582	1098	12637.40		247			
1 PM		273	202	195	233	873	582	1095	14120		297			
2 PM	✓	235	132	204	236	879	571	678	14620	✓	300			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

Well #1 Down for repairs  
Well #2 will not start  
Well #3 on at 7:50 am

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **EVENING SHIFT**

FILE ID:	93-09-15-13
DATE:	9-15-93

WELL FIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI	EFFLUENT FLOW GALLS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	277	191	196	239	874	1037	1098	9813.40		399	SCHADLER	
4 PM		277	205	192	202	853	1047	1110	10166.40		53	CAVALLARO	
5 PM		278	204	190	219	872	1044	1116	9813.40		105		
6 PM		280	197	193	237	881	1044 582	1116 685	9107.40		161		
7 PM		278	202	204	195	859	1047	1120	9107.40		211		
8 PM		278	200	200	229	880	1018	1127	9813.40		266		
9 PM		275	192	195	231	872	1040	1107	9107.40		318		
10 PM		277	200	197	223	878	1032	1113	9107.40		371		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 WELL Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### NIGHT SHIFT

FILE ID:	93-09-16-11
DATE:	SEPT 16, 1993

WELLFIELD OPERATOR GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS. FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES H <sub>2</sub> O	EFFLUENT FLOW MGALS	SUPERFLOW OPERATOR INITIALS	
11 PM	OFF	276	205	194	233	880	576	680	10166	40	NOT WORKING	42.5	LLOYD
12 AM	1	278	207	198	190	840	575	677	9813	48	1	52	DOWNES
1 AM	1	278	197	205	223	861	576	679	9813	48	1	105	
2 AM	1	279	201	198	212	876	577	688	6283	48	1	153	
3 AM		275	204	204	237	886	580	1112	6283	48		208	
4 AM		280	200	198	228	864	575	683	6234	48		261	
5 AM		277	203	204	230	876	576	688	6283	48		314	
6 AM	✓	280	205	191	204	875	578	689	6283	48	✓	369	
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

REMARKS

NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

#### DAY SHIFT

FILE ID:	93-09-16-12
DATE:	09-16-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FIL FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATION INITIALS	
7 AM	OFF	277	204	192	232	878	579	1108	6918.20	not	429	Cembale	
8 AM		276	203	205	216	865	577	1101	6518.80	working	44	ABRAMS	
9 AM		278	203	204	210	871	576	686	6518.80		100		
10 AM		276	199	203	227	869	578	617	6918.80		149		
11 AM		281	198	204	193	878	579	1102	7443.60		261		
12 PM		279	195	205	216	857	579	1101	7977.80		251		
1 PM		277	205	199	212	842	577	673	10166.40		308		
2 PM	✓	271	195	195	198	829	577	686	10166.40	✓	357		
3 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

#### REMARKS

Use 1 #1 Down for repairs

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### EVENING SHIFT

FILE ID:	93-09-16-13
DATE:	9-16-93

WELL FIELD OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS					
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESS FL. FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES VAC	EFFLUENT FLOW GALLS	SUPERVISOR/ OPERATOR INITIALS
3 PM	OFF	276	196	199	236	877	1041	1100	10166.40		408	SCHADLER
4 PM		276	197	202	229	872	1027	1113	10166.40		56	CAYALLARD
5 PM		280	200	204	224	876	1019	1115	10590.00		111	
6 PM		282	196	195	229	870	1026 P 577	1140 P 681	10943.00		160	
7 PM		280	206	200	219	877	1031	1108	10943.00		215	
8 PM		276	204	196	232	879	1030 P 581	1120 P 687	10166.40		266	
9 PM		279	196	205	196	834	1045	1107	9107.40		320	
10 PM		278	195	204	222	862	1030	1094	9813.40		375	
11 PM												
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA		

#### REMARKS

#1 WELL DOWN FOR REPAIRS

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FILE ID:	93-09-17-11
DATE:	SEPT 17, 1993

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE PSI INCHES W.C.	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
11 PM	075	277	195	200	232	888	584	678	1066 <sup>40</sup>	No 1 WORKING	497	LLOYD	
12 AM	1	279	192	199	237	884	582	682	9813 <sup>40</sup>	1	54	DAWES	
1 AM		276	204	193	233	821	585	1111	9813 <sup>40</sup>	1	100		
2 AM		276	194	200	236	867	585	990	9813 <sup>40</sup>	1	153		
3 AM		277	194	204	223	865	583	681	12002 <sup>40</sup>	1	210		
4 AM		280	204	197	210	880	583	676	11649 <sup>40</sup>	1	261		
5 AM	V	276	191	205	224	864	585	689	11649 <sup>40</sup>	1	313		
6 AM		280	206	191	220	879	582	682	12919.80	V	365		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

Well 1 Down For Repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.



# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **DAY SHIFT**

FILE ID:	43-09-17-12
DATE:	09-17-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
7 AM	OFF	276	148	204	235	877	584	1093	1200.00	not	420	Cembak		
8 AM		280	145	200	206	825	583	681	1200.00	working	53	ABRAMS		
9 AM		277	206	196	235	884	586	1104	11256.00		100			
10 AM		277	192	204	236	881	586	1108	11296.00		154			
11 AM		275	147	201	238	883	586	1102	12284.00		208			
12 PM		276	143	202	236	878	583	684	10943.00		265			
1 PM		281	196	200	206	820	583	676	10943.00		314			
2 PM	✓	280	208	192	198	881	585	1102	10943.00	✓	364			
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

### REMARKS

Well #1 Down for repairs

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# TOWN OF OYSTER BAY DEPARTMENT OF PUBLIC WORKS GROUNDWATER TREATMENT FACILITY

## DAILY OPERATIONS WORKSHEET EVENING SHIFT

FILE ID:	93-09-17-13
DATE:	9-17-93

WELL/BIOT OPERATION GALLONS PER MINUTE							AIR STRIPPER OPERATING PARAMETERS						
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW CFM	AIR PRESSURE INCHES WG	EFFLUENT FLOW GALLS	SUPERVISOR/ OPERATOR INITIALS	
3 PM	OFF	276	202	204	233	888	1048	1102	10166.40	NOT	419	SCHADLER	
4 PM		277	191	203	236	884	1040	1112	10943.00	WORKING	52	CAVALLARO	
5 PM		276	205	190	238	880	1048	1106	10943.00		104		
6 PM		277	206	192	235	884	1024	1113	10943.00		157		
7 PM		281	191	203	209	861	1024 572	1113 673	9813.40		210		
8 PM		278	197	201	235	876	1019	1115	10590.00		262		
9 PM		280	204	200	197	860	1050	1112	10943.00		313		
10 PM		276	193	205	224	867	1032	1101	10943.00		366		
11 PM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 WELL DOWN FOR REPAIRS

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

# **TOWN OF OYSTER BAY** **DEPARTMENT OF PUBLIC WORKS** **GROUNDWATER TREATMENT FACILITY**

## **DAILY OPERATIONS WORKSHEET** **NIGHT SHIFT**

FIELD #	93-09-18-11
DATE	9-18-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS			
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	AIR FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE PSI	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS	
11 PM	Down	278	194	200	216	879	1041	1115	NOT WORKING	Down	422	4498	
12 AM	1	276	204	195	236	877	589	689	NOT WORKING	1	48	4462	
1 AM	1	277	200	200	236	881	570	1111	NOT WORKING	1	100		
2 AM	1	276	206	195	208	824	1048	682	NOT WORKING	1	152		
3 AM	1	279	193	200	236	882	1636	1123	NOT WORKING	1	215		
4 AM	1	277	208	193	210	838	1035	1112	NOT WORKING	1	259		
5 AM	1	281	194	200	199	874	1037	1115	NOT WORKING	1	313		
6 AM	1	280	199	196	188	807	1041	1123	NOT WORKING	1	366		
7 AM													
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			

### REMARKS

#1 Well Down For Repairs  
 3:30 Methane Down

### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.

3460

# TOWN OF OYSTER BAY

## DEPARTMENT OF PUBLIC WORKS

### GROUNDWATER TREATMENT FACILITY

#### DAILY OPERATIONS WORKSHEET

##### DAY SHIFT

FILED:	9309-18-12
DATE:	9-18-93

WELLFIELD OPERATION GALLONS PER MINUTE										AIR STRIPPER OPERATING PARAMETERS				
TIME	WELL 1 FLOW	WELL 2 FLOW	WELL 3 FLOW	WELL 4 FLOW	WELL 5 FLOW	SYSTEM FLOW	STRIPPER FLOW GPM	PRESSURE FLOW GPM	BLOWER AIR FLOW GPM	AIR PRESSURE INCHES WC	EFFLUENT FLOW MGALS	SUPERVISOR OPERATOR INITIALS		
7 AM	OFF	276	202	192	238	887	1022	1117	AWD	Not Working	491	Schadler		
8 AM	OFF	276	206	194	236	887	1025	1118	Not Working	✓	51	Capek		
9 AM	OFF	278	204	195	235	885	1029	1121	Not Working	✓	104	..		
10 AM	OFF	280	202	192	218	883	1015	1115	Not Working	✓	159	..		
11 AM	OFF	278	193	205	209	813	1015	1111	Not Working	✓	212	..		
12 PM	OFF	274	192	204	240	879	1013	1120	Not Working	✓	264	..		
1 PM	OFF	280	209	192	240	879	1011	1113	Not Working	✓	319	..		
2 PM	OFF	278	194	205	218	838	1012	1115	Not Working	✓	372	..		
3 PM														
AVERAGE	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA				

#### REMARKS

#1 Well is down for Repair

#### NOTES

- 1- THE SYSTEM FLOW, STRIPPER FLOW AND PRESSURE FILTER FLOW MUST BE EQUAL WITHIN 5%.
- 2- EFFLUENT FLOW MEASURES THE TOTAL FLOW THROUGH THE FACILITY. OPERATOR SHALL RESET THE GAUGE TO ZERO AT THE BEGINNING OF EACH SHIFT.