

Notification Form ⁽¹⁾

Operable Unit 3 Soil Gas IRM System
Northrop Grumman Systems Corporation
Bethpage, New York Facility

Incident Date/Time:	Thursday, May 27, 2010 03:30		
Prepared By/Affiliation:	Christine Esposito/ARCADIS of New York, Inc.		
Alarm Condition:	BL-300 Motor Fault		
Operating Blower(s) :	BL-300	Blower Runtime(s):	Not Measured
Description of Problem (based on present knowledge):	The OU-3 Soil Gas IRM shut down on Thursday, 5/27/10 at approximately 03:30. The shutdown was assumed to be caused by a power anomaly. ARCADIS personnel noted that the Groundwater IRM had also shut down at approximately the same time, and neither the SG IRM nor GW IRM building had power when they were physically inspected on Thursday, 5/27/10. NGC personnel contacted LIPA and LIPA troubleshot the electrical problem and restored power to each building. ARCADIS personnel physically inspected the system on the same day, cleared the motor fault alarm and restarted the system at approximately 12:00. The system operated as designed after being restarted.		
Current Status:	The system is operating as designed.		
Actions Taken:	LIPA troubleshot the power loss condition at the site and rectified the problem. The motor fault alarm was cleared and the system was restarted on Thursday, 5/27/10. The system has been operating as designed since being restarted.		
Actions Planned:	None.		

Persons Notified:	Bold Indicates Primary Person to Notify:	Telephone:	Cell Phone:	Notification Method:
ARCADIS	Carlo SanGiovanni	(631) 391-5259	(516) 903-6591	Phone Fax E-Mail
	David Stern	(631) 391-5284	(516) 369-7440	Phone Fax E-Mail
	Ken Zegel or	(631) 391-5219	(516) 805-0470	Phone Fax E-Mail
	Christina Tuohy	(631) 391-5213	(516) 779-8033	Phone Fax E-Mail
NGC	John Cofman	(516) 575-4680	N/A	Phone Fax E-Mail
	Ben Kenney	(516) 523-4261	N/A	Phone Fax E-Mail
NYSDEC	Steven Scharf	(518) 402-9620	N/A	Phone Fax E-Mail

<u>Firm:</u>	<u>Fax No:</u>	<u>E-Mail Address/Formula:</u>
ARCADIS	631-249-7610	first initial plus full last name@arcadis-us.com
NGC	516-575-6672	full first name "." full last name@ngc.com
NYSDEC	518-402-9627	sxscharf@gw.dec.state.ny.us

Note:

(1) Phone calls to report incidents will be made within 24 business hours of becoming aware of the problem.

This form will be faxed or e-mailed for documentation purposes.

