



RESOLUTION CONSULTANTS

To: Lora Fly, DON, NAVFAC MIDLANT

From: Brian Caldwell, P.G., Resolution Consultants

Subject: Week #1 Summary, Bethpage Water District Well 6-2 Pilot Test — NWIRP
Bethpage

Date: 30 March 2016

Week #1 Summary

The BWD Pilot Test began with groundwater pumping at well 6-2 on Monday, March 21; pumping times, interval flow rates, interval total gallons, and daily gallons pumped are provided in the following table.

Date	Well 6-2 Time on	Well 6-2 Time Off	Well 6-2 Hours Run	Flow Rate (gpm)	Interval Pumpage (K Gal)	Daily Pumpage (K Gal)
3/21/2016	6:30	24:00:00	17:30	1152	1209.60	1209.60
3/22/2016	0:01	24:00:00	23:59	1151	1656.29	1657.44
3/23/2016	0:01	24:00:00	23:59	1152	1657.73	1657.73
3/24/2016	0:01	24:00:00	23:59	1148	1651.97	1651.97
3/25/2016	0:00	10:45	10:45	1154	744.33	744.33
3/26/2016	off	--	--	--	--	--
3/27/2016	off	--	--	--	--	--
Sums =			4.175	1151.4	6919.919	6921.07
			days	ave. gpm	total gals	total gals

Well 6-1 located at Plant #6 was not operated during the above dates.

Preliminary rainfall data (daily inches) for the above dates is:

3/21/2016	0.07
3/22/2016	0
3/23/2016	0
3/24/2016	0
3/25/2016	0
3/26/2016	na
3/27/2016	na

Week #1 samples were collected on Friday, March 25. Chemicals detected in the raw water for wells 6-1 and 6-2, and the treated water used for distribution are summarized below:

Chemicals Detected 3/25/16	Well 6-1	Well 6-2	Treated Water	NYS limit
1,4-Dioxane	12	9.1	8.4	--
Carbon Tetrachloride	<0.50	1.75	<0.50	5
Chloroform	<0.50	1.39	<0.50	--
cis-1,2-Dichloroethene	<0.50	2.43	<0.50	5
Tetrachloroethene	3.54	1.99	<0.50	5
Trichloroethene	22.8	1280	<0.50	5

Exceed NYS Regulatory Limits

Laboratory reports were forwarded to Mr. Henry Wilkie of NYSDEC via email dated March 30, 2016.

Week #2

Week #2 of the Pilot Test began on Monday, March 28; pumping will be conducted at well 6-1 only for this weekly pumping cycle.



Sample Information:

Type : Potable Water
 Origin: Raw Well
 Special

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Bethpage Water District
25 Adams Ave.

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No N-03876

Received : 03/25/2016 11:09 AM Location: Well 6-1

Collected By : PS99

Lab No. : 1603K37-001

Client Sample ID. : N-03876

<u>Analytical Method:</u> E522 :	<u>Prep Method:</u> E522				<u>Prep Date:</u> 3/28/2016 6:59:28 AM	<u>Analyst:</u> SH	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane	12	D +	5	µg/L		03/29/2016 3:19 PM	Container-01 of 02
Surr: 1,4-Dioxane-D8	102		1	%Rec	Limit 70-130	03/29/2016 3:53 AM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.
 Date Reported : 3/29/2016

Stu Murrell
 Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
 Origin: Raw Well
 Special

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Bethpage Water District
25 Adams Ave.

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No N-03876

Received : 03/25/2016 11:09 AM Location: Well 6-1

Collected By : PS99

Lab No. : 1603K37-001

Client Sample ID. : N-03876

Analytical Method: E524.2 : POC

Analyst: KG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,1,1,2-Tetrachloroethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,1,1-Trichloroethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,1,2,2-Tetrachloroethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,1,2-Trichloroethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,1-Dichloroethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,1-Dichloroethene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,1-Dichloropropene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,2,3-Trichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,2,3-Trichloropropane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,2,4-Trichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,2,4-Trimethylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,2-Dichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,2-Dichloroethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,2-Dichloropropane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,3,5-Trimethylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,3-Dichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,3-Dichloropropane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
1,4-Dichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
2,2-Dichloropropane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
2/4-Chlorotoluene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
4-Isopropyltoluene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Benzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Bromobenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Bromochloromethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.
 Date Reported : 3/29/2016

Stu Murrell
 Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water

Origin: Raw Well

Special

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Bethpage Water District
25 Adams Ave.

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No N-03876

Received : 03/25/2016 11:09 AM Location: Well 6-1

Collected By : PS99

Lab No. : 1603K37-001

Client Sample ID. : N-03876

Analytical Method: E524.2 : POC

Analyst: KG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Bromodichloromethane	< 0.50		1	µg/L		03/28/2016 7:14 PM	Container-01 of 02
Bromoform	< 0.50		1	µg/L		03/28/2016 7:14 PM	Container-01 of 02
Bromomethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Carbon tetrachloride	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Chlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Chloroethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Chloroform	< 0.50		1	µg/L		03/28/2016 7:14 PM	Container-01 of 02
Chloromethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
cis-1,2-Dichloroethene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
cis-1,3-Dichloropropene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Dibromochloromethane	< 0.50		1	µg/L		03/28/2016 7:14 PM	Container-01 of 02
Dibromomethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Dichlorodifluoromethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Ethylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Hexachlorobutadiene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Isopropylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
m,p-Xylene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Methyl tert-butyl ether	< 0.50		1	µg/L	10	03/28/2016 7:14 PM	Container-01 of 02
Methylene chloride	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
n-Butylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
n-Propylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
o-Xylene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
sec-Butylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Styrene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.

Date Reported : 3/29/2016



Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
 Origin: Raw Well
 Special

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Bethpage Water District
25 Adams Ave.

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No N-03876

Received : 03/25/2016 11:09 AM Location: Well 6-1

Collected By : PS99

Lab No. : 1603K37-001

Client Sample ID. : N-03876

Analytical Method: E524.2 : POC

Analyst: KG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
tert-Butylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Tetrachloroethene	3.54		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Toluene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Total Trihalomethanes	< 2.00		1	µg/L	80	03/28/2016 7:14 PM	Container-01 of 02
trans-1,2-Dichloroethene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
trans-1,3-Dichloropropene	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Trichloroethene	* 22.8	*	1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Trichlorofluoromethane	< 0.50		1	µg/L	5	03/28/2016 7:14 PM	Container-01 of 02
Vinyl chloride	< 0.50		1	µg/L	2	03/28/2016 7:14 PM	Container-01 of 02
Surr: 1,2-Dichlorobenzene-d4	101		1	%Rec	Limit 70-130	03/28/2016 7:14 PM	Container-01 of 02
Surr: 4-Bromofluorobenzene	94.4		1	%Rec	Limit 70-130	03/28/2016 7:14 PM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.
 Date Reported : 3/29/2016

Stu Murrell
 Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
 Origin: Raw Well
 Special

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Bethpage Water District
 25 Adams Ave.**

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No N-08941

Received : 03/25/2016 11:09 AM Location: Well 6-2

Collected By : PS99

Lab No. : 1603K37-002

Client Sample ID. : N-08941

<u>Analytical Method:</u> E522 :	<u>Prep Method:</u> E522				<u>Prep Date:</u> 3/28/2016 6:59:28 AM	<u>Analyst:</u> SH	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane	9.1	D +	5	µg/L		03/29/2016 3:43 PM	Container-01 of 02
Surr: 1,4-Dioxane-D8	102		1	%Rec	Limit 70-130	03/29/2016 4:17 AM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.
 Date Reported : 3/29/2016

Stu Murrell
 Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Raw Well
 Special

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Bethpage Water District
25 Adams Ave.

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No N-08941

Received : 03/25/2016 11:09 AM Location: Well 6-2

Collected By : PS99

Lab No. : 1603K37-002

Client Sample ID. : N-08941

Analytical Method: E524.2 : POC

Analyst: KG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,1,1,2-Tetrachloroethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,1,1-Trichloroethane	0.59		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,1,2,2-Tetrachloroethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,1,2-Trichloroethane	0.65		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,1-Dichloroethane	1.53		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,1-Dichloroethene	3.34		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,1-Dichloropropene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,2,3-Trichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,2,3-Trichloropropane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,2,4-Trichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,2,4-Trimethylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,2-Dichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,2-Dichloroethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,2-Dichloropropane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,3,5-Trimethylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,3-Dichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,3-Dichloropropane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
1,4-Dichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
2,2-Dichloropropane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
2/4-Chlorotoluene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
4-Isopropyltoluene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Benzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Bromobenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Bromochloromethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.

Date Reported : 3/29/2016



Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Sample Information:

Type : Potable Water
 Origin: Raw Well
 Special

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Bethpage Water District
25 Adams Ave.

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No N-08941

Received : 03/25/2016 11:09 AM Location: Well 6-2

Collected By : PS99

Lab No. : 1603K37-002

Client Sample ID. : N-08941

Analytical Method: E524.2 : POC

Analyst: KG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Bromodichloromethane	< 0.50		1	µg/L		03/28/2016 7:39 PM	Container-01 of 02
Bromoform	< 0.50		1	µg/L		03/28/2016 7:39 PM	Container-01 of 02
Bromomethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Carbon tetrachloride	1.75		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Chlorobenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Chloroethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Chloroform	1.39		1	µg/L		03/28/2016 7:39 PM	Container-01 of 02
Chloromethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
cis-1,2-Dichloroethene	2.43		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
cis-1,3-Dichloropropene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Dibromochloromethane	< 0.50		1	µg/L		03/28/2016 7:39 PM	Container-01 of 02
Dibromomethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Dichlorodifluoromethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Ethylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Hexachlorobutadiene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Isopropylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
m,p-Xylene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Methyl tert-butyl ether	< 0.50		1	µg/L	10	03/28/2016 7:39 PM	Container-01 of 02
Methylene chloride	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
n-Butylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
n-Propylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
o-Xylene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
sec-Butylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Styrene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.

Date Reported : 3/29/2016



Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Information:

Type : Potable Water
 Origin: Raw Well
 Special

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Bethpage Water District
25 Adams Ave.

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No N-08941

Received : 03/25/2016 11:09 AM Location: Well 6-2

Collected By : PS99

Lab No. : 1603K37-002

Client Sample ID. : N-08941

Analytical Method: E524.2 : POC

Analyst: KG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
tert-Butylbenzene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Tetrachloroethene	1.99		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Toluene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Total Trihalomethanes	< 2.00		1	µg/L	80	03/28/2016 7:39 PM	Container-01 of 02
trans-1,2-Dichloroethene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
trans-1,3-Dichloropropene	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Trichloroethene	* 1,280	D*	50	µg/L	5	03/29/2016 8:31 AM	Container-01 of 02
Trichlorofluoromethane	< 0.50		1	µg/L	5	03/28/2016 7:39 PM	Container-01 of 02
Vinyl chloride	< 0.50		1	µg/L	2	03/28/2016 7:39 PM	Container-01 of 02
Surr: 1,2-Dichlorobenzene-d4	103		1	%Rec	Limit 70-130	03/28/2016 7:39 PM	Container-01 of 02
Surr: 4-Bromofluorobenzene	99.6		1	%Rec	Limit 70-130	03/28/2016 7:39 PM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.
 Date Reported : 3/29/2016

Stu Murrell
 Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sample Information:

Type : Potable Water
 Origin: Treated Well
 Special

Treatment

Treated-GAC

**Bethpage Water District
 25 Adams Ave.**

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No ASGAC-6-16-2

Received : 03/25/2016 11:09 AM Location: Plant 6 Airstripper/GAC

Collected By : PS99

Lab No. : 1603K37-003

Client Sample ID. : ASGAC-6-16-2

<u>Analytical Method:</u> E522 :	<u>Prep Method:</u> E522				<u>Prep Date:</u> 3/28/2016 6:59:28 AM	<u>Analyst:</u> SH	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,4-Dioxane	8.4	D	+	5	µg/L	03/29/2016 4:08 PM	Container-01 of 02
Surr: 1,4-Dioxane-D8	97.8			1	%Rec Limit 70-130	03/29/2016 4:41 AM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.
 Date Reported : 3/29/2016

Stu Murrell
 Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sample Information:

Type : Potable Water
 Origin: Treated Well
 Special

Treatment

Treated-GAC

**Bethpage Water District
 25 Adams Ave.**

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No ASGAC-6-16-2

Received : 03/25/2016 11:09 AM Location: Plant 6 Airstripper/GAC

Collected By : PS99

Lab No. : 1603K37-003

Client Sample ID. : ASGAC-6-16-2

Analytical Method: E524.2 : POC

Analyst: KG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
1,1,1,2-Tetrachloroethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,1,1-Trichloroethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,1,2,2-Tetrachloroethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,1,2-Trichloroethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,1-Dichloroethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,1-Dichloroethene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,1-Dichloropropene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,2,3-Trichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,2,3-Trichloropropane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,2,4-Trichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,2,4-Trimethylbenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,2-Dichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,2-Dichloroethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,2-Dichloropropane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,3,5-Trimethylbenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,3-Dichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,3-Dichloropropane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
1,4-Dichlorobenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
2,2-Dichloropropane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
2/4-Chlorotoluene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
4-Isopropyltoluene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Benzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Bromobenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Bromochloromethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.
 Date Reported : 3/29/2016

Stu Murrell
 Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sample Information:

Type : Potable Water
 Origin: Treated Well
 Special

Treatment

Treated-GAC

Bethpage Water District
 25 Adams Ave.

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No ASGAC-6-16-2

Received : 03/25/2016 11:09 AM Location: Plant 6 Airstripper/GAC

Collected By : PS99

Lab No. : 1603K37-003

Client Sample ID. : ASGAC-6-16-2

Analytical Method: E524.2 : POC

Analyst: KG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Bromodichloromethane	< 0.50		1	µg/L		03/28/2016 6:49 PM	Container-01 of 02
Bromoform	< 0.50		1	µg/L		03/28/2016 6:49 PM	Container-01 of 02
Bromomethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Carbon tetrachloride	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Chlorobenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Chloroethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Chloroform	< 0.50		1	µg/L		03/28/2016 6:49 PM	Container-01 of 02
Chloromethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
cis-1,2-Dichloroethene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
cis-1,3-Dichloropropene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Dibromochloromethane	< 0.50		1	µg/L		03/28/2016 6:49 PM	Container-01 of 02
Dibromomethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Dichlorodifluoromethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Ethylbenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Hexachlorobutadiene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Isopropylbenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
m,p-Xylene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Methyl tert-butyl ether	< 0.50		1	µg/L	10	03/28/2016 6:49 PM	Container-01 of 02
Methylene chloride	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
n-Butylbenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
n-Propylbenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
o-Xylene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
sec-Butylbenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Styrene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) NYS Regulatory Limit(s).

Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.

Date Reported : 3/29/2016



Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sample Information:

Type : Potable Water
 Origin: Treated Well
 Special

Treatment

Treated-GAC

Bethpage Water District
25 Adams Ave.

Bethpage, NY 11714

Attn To : Michael Boufis

Federal ID : 2902817

Collected : 03/25/2016 9:40 AM Point No ASGAC-6-16-2

Received : 03/25/2016 11:09 AM Location: Plant 6 Airstripper/GAC

Collected By : PS99

Lab No. : 1603K37-003

Client Sample ID. : ASGAC-6-16-2

Analytical Method: E524.2 : POC

Analyst: KG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
tert-Butylbenzene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Tetrachloroethene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Toluene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Total Trihalomethanes	< 2.00		1	µg/L	80	03/28/2016 6:49 PM	Container-01 of 02
trans-1,2-Dichloroethene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
trans-1,3-Dichloropropene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Trichloroethene	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Trichlorofluoromethane	< 0.50		1	µg/L	5	03/28/2016 6:49 PM	Container-01 of 02
Vinyl chloride	< 0.50		1	µg/L	2	03/28/2016 6:49 PM	Container-01 of 02
Surr: 1,2-Dichlorobenzene-d4	103		1	%Rec	Limit 70-130	03/28/2016 6:49 PM	Container-01 of 02
Surr: 4-Bromofluorobenzene	97.4		1	%Rec	Limit 70-130	03/28/2016 6:49 PM	Container-01 of 02

Qualifiers: E = Value above quantitation range, Value estimated.
 B = Found in Blank
 D.F. = Dilution Factor D = Results for Dilution
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated
 H = Received/analyzed outside of analytical holding time
 J = Estimated value - below calibration range
 M-, M+ = Matrix Spike recovery below / above control limit
 N = Indicates presumptive evidence of compound
 P = Duplicate RPD outside of control limit
 r = Reporting limit below calibration range. Value estimated.
 S = Recovery outside of control limits for this analyte
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method
 Result(s) reported meet(s) NYS Regulatory Limit(s).
 Result(s) flagged with * Exceed NYS Regulatory Limit(s). Limit noted.
 Date Reported : 3/29/2016

Stu Murrell
 Sr. Project Manager : Stu Murrell

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



Sample Receipt Checklist

Client Name **BWD**

Date and Time Received: **3/25/2016 11:09:00 AM**

Work Order Number: **1603K37**

RcptNo: **1**

Received by **Amanda De Pascale**

Completed by: *John State*

Reviewed by: *Stu Murrell*

Completed Date: 3/25/2016 12:37:28 PM

Reviewed Date: 3/25/2016 3:58:56 PM

Carrier name: Client

- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Are matrices correctly identified on Chain of custody? Yes No
- Is it clear what analyses were requested? Yes No
- Custody seals intact on sample bottles? Yes No Not Present
- Samples in proper container/bottle? Yes No
- Were correct preservatives used and noted? Yes No NA
- Preservative added to bottles:
- Sample Condition? Intact Broken Leaking
- Sufficient sample volume for indicated test? Yes No
- Were container labels complete (ID, Pres, Date)? Yes No
- All samples received within holding time? Yes No
- Was an attempt made to cool the samples? Yes No NA
- All samples received at a temp. of > 0° C to 6.0° C? Yes No NA
- Response when temperature is outside of range: Samples were collected the same day and chilled.
- Sample Temp. taken and recorded upon receipt? Yes No To 15.9 °
- Water - Were bubbles absent in VOC vials? Yes No No Vials
- Water - Was there Chlorine Present? Yes No NA
- Water - pH acceptable upon receipt? Yes No No Water
- Are Samples considered acceptable? Yes No
- Custody Seals present? Yes No
- Airbill or Sticker? Air Bil Sticker Not Present

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? Yes No NA Person Contacted:
 Contact Mode: Phone: Fax: Email: In Person:
 Client Instructions:
 Date Contacted: Contacted By:
 Regarding:
 Comments:
 CorrectiveAction:

WorkOrder :
1603K37

Certifications

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MAS S ACHUS E TTS	M-NY026
NE W HAMP S HIRE	2987
RHODE IS LAND	LAO00340
P E NNS YLVANIA	68-00350