

Mr. Henry Wilkie
Project Manager
New York State Department of Environmental Conservation
Remedial Bureau A
625 Broadway
Albany, New York 12233-7015

Arcadis of New York, Inc.
Two Huntington Quadrangle
Suite 1S10
Melville
New York 11747
Tel 631 249 7600
Fax 631 249 7610
www.arcadis.com

Mr. Steven Scharf, P.E.
Project Manager
New York State Department of Environmental Conservation
Remedial Bureau A
625 Broadway
Albany, New York 12233-7015

ENVIRONMENT

Date:
November 30, 2016

Subject:

2016 Third Quarter Operation Maintenance and Monitoring Report,
Operable Unit 2, Northrop Grumman Systems Corporation and Naval Weapons
Industrial Reserve Plant (NWIRP) Sites, Bethpage, New York.
(NYSDEC Site #s 1-30-003A and B)

Contact:
David E. Stern

Phone:
631.391.5284

Email:
david.stern@arcadis.com

Our ref:
NY001496.0216.RPT14

Dear Henry and Steve:

On behalf of Northrop Grumman Systems Corporation (Northrop Grumman), Arcadis is providing the NYSDEC with the 2016 Third Quarter Operation Maintenance and Monitoring Report (Report). This Report was prepared to document the operation, maintenance, and monitoring (OM&M) activities conducted for the on-site portion of the Operable Unit 2 (OU2) groundwater remedy and the results of ongoing volatile organic compound (VOC) and inorganic monitoring in groundwater to meet the remedial objectives set forth in the March 2001 OU2 Record of Decision (ROD).

Table 1 summarizes OU2 remedial system performance operational data and water balance. Tables 2 and 3 provide the analytical results for remedial system water and vapor samples for this period. Tables 4A and 4B provide the air modeling inputs and outputs and resulting analyses, based on vapor samples

Mr. Henry Wilkie
Mr. Steven Scharf, P.E.
November 30, 2016

collected from the Tower 96 and Tower 102 systems, respectively, for this period. Table 5 provides the validated analytical results of groundwater monitoring for this period. Figures 1 through 4 show the Locations of Wells and Onsite Groundwater Remedy, Locations of Treatment Systems and Discharges, ONCT Groundwater Extraction and Treatment System Site Plan, and the ONCT Groundwater Extraction and Treatment System Schematic, respectively.


Please contact us if you have any questions or comments.

Sincerely,

Arcadis of New York, Inc.



David E. Stern
Senior Hydrogeologist



Carlo San Giovanni
Project Manager

Copies:

Ed Hannon – Northrop Grumman
Fred Weber – Northrop Grumman
Walter Parish – NYSDEC Region 1
Steven Karpinski – New York State Department of Health
Joseph DeFranco – Nassau County Department of Health
Lora Fly – NAVFAC Midlant Environmental
David Brayack – TetraTech NUS, Inc.
Roger Smith – Glenn Springs Holdings, Inc.
Manfred Bohms – Steel Equities
Mike Negrelli – USEPA
Robert Alvey – USEPA
Carol Stein-USEPA
Matthew Russo – Town of Oyster Bay
Stan Carey – Massapequa Water District
Matthew Snyder – New York American Water
Frank Koch – South Farmingdale Water District
John Reinhardt – Town of Hempstead Water District
Michael Boufis – Bethpage Water District
Lois Lovisololo – Bethpage Public Library (Public Repository)
File

Table 1
Operational Summary for the On-Site Portion of the OU2 Groundwater Remedy, Third Quarter 2016 ⁽¹⁾
Operable Unit 2, Northrop Grumman Systems Corporation,
Bethpage, New York

	Quarterly Flow Rates (gpm)		Quarterly Flow Volumes (MG)			Quarterly VOC Concentrations (µg/L)		VOC Mass Removed (lbs) ⁽⁷⁾	
	Design ⁽²⁾	Average ^(3,4)	Design ⁽²⁾	Actual ^(3,4)	% of Design	TCE ⁽⁵⁾	TVOC ^(5,6)	Quarterly	Cumulative
Influent Groundwater									
Well 1 ^(11,13)	800	827	103.7	104.0	100%	838	880	765	42,920
Well 3R ^(11,13)	700	995	90.7	125.0	138%	579	630	644	88,570
Well 17 ⁽¹³⁾	1,000	1,047	129.6	129.0	100%	132	170	179	52,275
Well 18 ⁽¹³⁾	600	1,001	77.8	122.0	157%	55	79	79	6,091
Well 19 ^(12,13)	700	771	90.7	90.0	99%	150	180	133	7,834
Total ⁽¹⁴⁾	3,800	4,641	493	570	116%	--	--	1,800	197,690
Effluent Groundwater ⁽⁸⁾									
Calpine	100 - 400	589	--	78.0	--	--	--	--	--
OXY Biosparge ⁽¹⁰⁾	2 - 42	0	--	0	--	--	--	--	--
West Recharge Basins	1,112 - 1,455	1,574	--	204.0	--	--	3.0	--	--
South Recharge Basins	2,231	2,222	289.1	288.0	100%	--	2.1	--	--
Total ⁽¹⁴⁾	--	4,385	--	570	--	--	--	--	--
Additional Flow to South Recharge Basins									
Storm Water Runoff Contributing to South Recharge Basins Flow Volume ⁽¹⁵⁾	--	--	--	12.9	--	--	--	--	--
Total Flow Volume to South Recharge Basins ^(15,16)	--	--	289	301	104%	--	--	--	--
Treatment Efficiencies ⁽⁹⁾									
Tower 96 System:	99.5%								
Tower 102 System:	>99.9%								

Notes and abbreviations on last page.

Table 1
Operational Summary for the On-Site Portion of the OU2 Groundwater Remedy, Third Quarter 2016 ⁽¹⁾
Operable Unit 2, Northrop Grumman Systems Corporation,
Bethpage, New York

Notes and Abbreviations:

- (1) Quarterly reporting period: July 06, 2016 through October 04, 2016.
 - (2) "Design" flow rates were determined for the five remedial wells and for the South Recharge Basins based on computer modeling (ARCADIS G&M, Inc. 2003c, modified in April 2005). Flow rates for Calpine, OXY Biosparge and West Recharge Basins are typical flow rates and are provided for reader information. "Design" flow volumes represent the volume of water that should be pumped/discharged during the reporting period and is calculated by multiplying the design rate by the reporting period duration.
 - (3) "Average" flow rates for the remedial wells represent the average actual pumping rates when the pumps are operational and do not take into account the time that a well is not operational. During this quarterly reporting period, the remedial wells operated for the following percentage of the time: Well 1 (97%), Well 3R (97%), Well 17 (95%), Well 18 (94%), and Well 19 (90%). "Actual" volumes are determined via totalizing flow meters. Well 1 and 3R totalizing flow meters were replaced during 3Q 2016. Totalizers for those wells were estimated based on influent totalizing flow meter to Tower 96 air stripper.
 - (4) "Average" flow rates for the system discharges represent the average flow rate during the entire reporting period and are determined by dividing the total flow during the reporting period by the reporting period duration. The Calpine and South Recharge Basins flow volumes are determined via totalizing flow meters. The West Recharge Basin flow is calculated by subtracting the cumulative flow to the other discharges from the total influent flow. Actual flow to the recharge basins is greater, as shown, because storm water combines with the plant effluent prior to discharge to the recharge basins.
 - (5) The TCE and TVOC concentrations for the remedial wells are from the quarterly sampling event performed during this reporting period on August 17, 2016 (Table 2).
 - (6) The TVOC concentration for the two sets of recharge basins are their respective average monthly SPDES concentration for the current quarter.
 - (7) TVOC mass removed for the reporting period is calculated by multiplying the TVOC concentration from the quarterly sampling event and the quantity of water pumped during the reporting period.
 - (8) There are four discharges for the effluent groundwater: South Recharge Basins, West Recharge Basins, Calpine and OXY Biosparge system. Treated water is continuously discharged to the south and west recharge basins, and is available "on-demand" to both the Calpine Power Plant (Calpine) for use as make-up water, and the biosparge remediation system operated by Occidental Chemical (OXY Biosparge).
 - (9) Treatment System Efficiencies are calculated by dividing the difference between the remedial well flow weighted influent and effluent TVOC concentrations by the remedial well flow weighted influent concentration.
 - (10) Occidental Chemical reported in May 2016 that the OXY Biosparge system required no water usage in the 1st Quarter of 2016, and no planned usage for the remainder of 2016.
 - (11) Wells 1 and 3R were shut down on July 12 and 13, 2016 for Occidental blower repair, VPGAC inspection, and Occidental carbon changeout at Tower 96.
 - (12) Well 19 was shut down between July 12 and July 19 due to overheating of the VFD. The issue was remedied by replacing the VFD fan.
 - (13) The majority of downtime during Third Quarter 2016 was due to communication failures at both systems, repair of a treated water distribution pipeline that briefly affected both systems, and low compressed air at Tower 102. The low compressed air condition was remedied and a radiofrequency survey was completed for ONCT to investigate the cause of communication failures.
 - (14) Total pumpage/recharge rates are accurate to ±15% due to limitations in metering. Flow meter calibration was completed on September 29, 2016.
 - (15) Storm Water Runoff Volume is calculated by multiplying the adjusted tributary area and NOAA precipitation data for the reporting periods. The adjusted tributary area is tributary area that is adjusted by the runoff coefficient to exclude the infiltration volume from the total rainfall volume. The tributary area, runoff coefficient, and adjusted tributary area are from Dvirka and Bartilucci Consulting Engineers' Storm Water Permit Evaluation Report (January, 28, 2010). The NOAA precipitation data are calculated as a sum of NOAA daily precipitation data for the reporting period. NOAA precipitation data are retrieved from Station GHCND:USW00054787 - FARMINGDALE REPUBLIC AIRPORT, NY US.
 - (16) Total Flow Volume to South Recharge Basins is estimated as a sum of flow volumes contributed from the Effluent Groundwater to South Recharge Basins and from Storm Water Runoff to South Recharge Basins.
- | | | | |
|------|----------------------|-------|---|
| -- | not applicable | NOAA | National Oceanic and Atmospheric Administration |
| µg/L | micrograms per liter | SPDES | State Pollution Discharge Elimination System |
| gpm | gallons per minute | TCE | trichloroethene |
| lbs | pounds | TVOC | total volatile organic compounds |
| MG | million gallons | VOC | volatile organic compounds |

Table 2
Concentrations of Constituents in Remedial Wells and
Treatment System Effluents, Third Quarter 2016, Operable Unit 2,
Northrop Grumman Systems Corporation,
Bethpage, New York

Constituents (units in µg/L)	Location ID:	WELL 1	WELL 3R	96 EFFLUENT
	Sample ID:	WELL 1	WELL 3R	T96 EFFLUENT
	Sample Date:	8/17/2016	8/17/2016	9/26/2016
Volatile Organic Compounds (VOCs)^(1,2)				
1,1,1-Trichloroethane		0.39 J	0.85 J	<1.0
1,1,2,2-Tetrachloroethane		<1.0	<1.0	<1.0
1,1,2-Trichloroethane		<1.0	<1.0	<1.0
1,2-Dichloropropane		4.0	<1.0	<1.0
2-Butanone (MEK)		<10	<10	<10
2-Hexanone (MBK)		<5.0	<5.0	<5.0
4-methyl-2-pentanone (MIK)		<5.0	<5.0	<5.0
Acetone		<10	<10	<10
Benzene		<0.50	<0.50	<0.50
Bromodichloromethane		<1.0	<1.0	<1.0
Bromoform		<1.0	<1.0	<1.0
Bromomethane		<2.0	<2.0	<2.0
Carbon Disulfide		<2.0	<2.0	<2.0
Carbon tetrachloride		<1.0	<1.0	<1.0
Chlorobenzene		<1.0	<1.0	<1.0
Chloroethane		<1.0	<1.0	<1.0
Chloroform		0.25 J	<1.0	<1.0
Chloromethane		<1.0	<1.0	<1.0
cis-1,2-dichloroethene		4.5	4.9	<1.0
cis-1,3-dichloropropene		<1.0	<1.0	<1.0
Dibromochloromethane		<1.0	<1.0	<1.0
Ethylbenzene		<1.0	<1.0	<1.0
Methylene Chloride		<2.0	<2.0	<2.0
Styrene		<1.0	<1.0	<1.0
Tetrachloroethene		28.0	33.0	<1.0
Toluene		<1.0	<1.0	<1.0
trans-1,2-dichloroethene		<1.0	<1.0	<1.0
trans-1,3-dichloropropene		<1.0	<1.0	<1.0
Trichloroethylene		838 D	579 D	3.5
Trichlorotrifluoroethane (Freon 113)		3.8 J	4.1 J	<5.0
Vinyl Chloride		<1.0	5.0	<1.0
Xylene-o		<1.0	<1.0	<1.0
Xylenes - m,p		<1.0	<1.0	<1.0
Total VOCs⁽³⁾		880	630	3.5
1,4-Dioxane^(1,2)		3.99	5.33	NA

Notes and abbreviations on last page.

Table 2
Concentrations of Constituents in Remedial Wells and
Treatment System Effluents, Third Quarter 2016, Operable Unit 2,
Northrop Grumman Systems Corporation,
Bethpage, New York

Constituents (units in µg/L)	Location ID:	WELL 17	Well 18	WELL 18	WELL 19	102 EFFLUENT
	Sample ID:	WELL 17	Well 18	REP-081716-KD-1	WELL 19	T102 EFFLUENT
	Sample Date:	8/17/2016	8/17/2016	8/17/2016	8/17/2016	8/17/2016
Volatile Organic Compounds (VOCs)^(1,2)						
1,1,1-Trichloroethane		0.34 J	0.64 J	0.63 J	0.41 J	<1.0
1,1,2,2-Tetrachloroethane		<1.0	<1.0	<1.0	<1.0	<1.0
1,1,2-Trichloroethane		<1.0	<1.0	<1.0	<1.0	<1.0
1,2-Dichloropropane		<1.0	<1.0	<1.0	<1.0	<1.0
2-Butanone (MEK)		<10	<10	<10	<10	<10
2-Hexanone (MBK)		<5.0	<5.0	<5.0	<5.0	<5.0
4-methyl-2-pentanone (MIK)		<5.0	<5.0	<5.0	<5.0	<5.0
Acetone		<10	<10	<10	<10	<10
Benzene		<0.50	<0.50	<0.50	<0.50	<0.50
Bromodichloromethane		<1.0	<1.0	<1.0	<1.0	<1.0
Bromoform		<1.0	<1.0	<1.0	<1.0	<1.0
Bromomethane		<2.0	<2.0	<2.0	<2.0	<2.0
Carbon Disulfide		<2.0	<2.0	<2.0	<2.0	<2.0
Carbon tetrachloride		<1.0	<1.0	<1.0	<1.0	<1.0
Chlorobenzene		<1.0	<1.0	<1.0	<1.0	<1.0
Chloroethane		<1.0	<1.0	<1.0	<1.0	<1.0
Chloroform		0.34 J	0.25 J	0.23 J	0.43 J	<1.0
Chloromethane		<1.0	<1.0	<1.0	<1.0	<1.0
cis-1,2-dichloroethene		3.0	2.4	2.4	17	<1.0
cis-1,3-dichloropropene		<1.0	<1.0	<1.0	<1.0	<1.0
Dibromochloromethane		<1.0	<1.0	<1.0	<1.0	<1.0
Ethylbenzene		<1.0	<1.0	<1.0	<1.0	<1.0
Methylene Chloride		<2.0	<2.0	<2.0	<2.0	<2.0
Styrene		<1.0	<1.0	<1.0	<1.0	<1.0
Tetrachloroethene		25.4	14.5	14.4	6.9	<1.0
Toluene		<1.0	<1.0	<1.0	<1.0	<1.0
trans-1,2-dichloroethene		<1.0	<1.0	<1.0	<1.0	<1.0
trans-1,3-dichloropropene		<1.0	<1.0	<1.0	<1.0	<1.0
Trichloroethylene		132	54.7	54	150	<1.0
Trichlorotrifluoroethane (Freon 113)		4.1 J	1.8 J	1.9 J	<5.0	<5.0
Vinyl Chloride		<1.0	<1.0	<1.0	<1.0	<1.0
Xylene-o		<1.0	<1.0	<1.0	<1.0	<1.0
Xylenes - m,p		<1.0	<1.0	<1.0	<1.0	<1.0
Total VOCs⁽³⁾		170	79	79	180	0
1,4-Dioxane^(1,2)		4.40	2.75	3.51	3.67	4.25

Notes and abbreviations on last page.

Table 2
Concentrations of Constituents in Remedial Wells and Treatment System Effluents, Second Quarter 2016, Operable Unit 2, Northrop Grumman Systems Corporation, Bethpage, New York

Notes and Abbreviations:

- (1) VOC samples analyzed using USEPA Method 8260C. 1,4-Dioxane samples analyzed using USEPA Method 8270 SIM.
- (2) Results for the program are validated at 20% frequency, per protocols specified in OU2 Groundwater Monitoring Plan (Arcadis 2016).
- (3) Total VOC results rounded to two significant figures.
- NA Not Analyzed
- 2.4** Bold value indicates the constituent was detected at or above its reporting limit.
- < 5.0 Compound is not detected above its laboratory quantification limit.
- µg/L micrograms per liter
- D Concentration is based on a diluted sample analysis.
- J Constituent value is estimated.
- NYSDEC New York State Department of Conservation
- REP blind replicate sample
- SIM selective ion monitoring
- SPDES State Pollution Discharge Elimination System
- TCE Trichloroethylene
- VOC volatile organic compounds

Table 3
Vapor Sample Analytical Results for Treatment Systems,
Third Quarter 2016, Northrop Grumman Systems Corporation,
Operable Unit 2, Bethpage, New York

Constituents (Units in µg/m ³)	Location ID:	96 INFLUENT	96 MID-EFFLUENT	96 EFFLUENT	102 INFLUENT	102 EFFLUENT
	Sample ID:	T96 INFLUENT (AA)	T96 MIDTRAIN (AA)	T96 EFFLUENT (AA)	T102 INFLUENT (AA)	T102 EFFLUENT (AA)
	Date:	8/17/2016	8/17/2016	8/17/2016	8/17/2016	8/17/2016
<u>Volatile Organic Compounds (VOCs)⁽¹⁾</u>						
1,1,1-Trichloroethane		19	8.2	<0.55	98	0.65
1,1,2,2-Tetrachloroethane		<14	<5.5	<0.69	<8.9	<0.69
1,1,2-Trichloroethane		<11	<4.4	<0.55	<7.1	<0.55
1,1-Dichloroethane		38	39	2.0	121	10
1,1-Dichloroethylene		111	140	14	271	77
1,2-Dichloroethane		<16	<6.5	<0.81	7.3 J	<0.81
1,2-Dichloropropane		64	14	<0.92	6.9 J	<0.92
Benzene		<13	<5.1	<0.64	<8.0	0.42
Bromodichloromethane		<13	<5.4	<0.67	<8.7	<0.67
Bromoform		<8.3	<3.3	<0.41	<5.3	<0.41
Bromomethane		<16	<6.2	<0.78	<9.7	<0.78
Carbon disulfide		<12	<5.0	<0.62	<7.8	<0.62
Carbon tetrachloride		<5.0	<2.0	<0.25	9.4	<0.25
Chlorobenzene		<18	<7.4	<0.92	<12	<0.92
Chloroethane		<11	5.3	6.3	<6.6	<0.53
Chloroform		<20	6.8 J	<0.98	40	1.5
Chloromethane		<8.3	<3.3	5.0	<5.2	0.89
cis-1,3-Dichloropropene		<18	<7.3	<0.91	<11	<0.91
Dibromochloromethane		<17	<6.8	<0.85	<11	<0.85
Ethylbenzene		<17	<6.9	<0.87	<11	<0.87
Methylene chloride		8.7 J	5.2 J	1.1	<8.7	1.3
Styrene		<17	<6.8	<0.85	<11	<0.85
Tetrachloroethylene		936	37	<0.27	773	0.36
Toluene		<15	<6.0	<0.75	<9.4	<0.75
trans-1,3-Dichloropropene		<18	<7.3	<0.91	<11	<0.91
Trichloroethylene		23,400	3,770	1.6	8,550	13
Trichlorotrifluoroethane (Freon 113)		128	94	<0.77	251	16
Vinyl chloride		83	113	3.6	<1.3	0.54
Xylene-o		<17	<6.9	<0.87	<11	0.56
Xylenes - m,p		<17	<6.9	<0.87	<11	0.42
Total VOCs⁽²⁾		24,787	4,232	34	10,128	123

Notes and abbreviations on last page.

Table 3
Vapor Sample Analytical Results for Treatment Systems,
Third Quarter 2016, Northrop Grumman Systems Corporation,
Operable Unit 2, Bethpage, New York

Notes and Abbreviations:

- (1) Vapor samples collected by Arcadis on the dates shown and submitted to a NYSDOH ELAP certified laboratory for VOC analyses per Modified USEPA Method TO-15.
- (2) "Total VOCs" represents the sum of individual concentrations of compounds detected rounded to the nearest whole number.

19	Bold data indicates that the analyte was detected at or above its reporting limit.
ELAP	Environmental Laboratory Approval Program
J	Compound detected below its reporting limit; value is estimated.
NYSDOH	New York State Department of Health
USEPA	United States Environmental Protection Agency
VOC	volatile organic compound
$\mu\text{g}/\text{m}^3$	micrograms per cubic meter

Table 4A
 Summary of AERMOD Air Quality Impact Analysis
 Tower 96 Treatment System, Operable Unit 2,
 Northrop Grumman Systems Corporation,
 Bethpage, New York

Constituent	CAS#	T96 Effluent (ug/m ³)	Emission Rate ⁽¹⁾			Scaled Impact - Hourly ⁽²⁾ (ug/m ³)	Scaled Impact - Annual ⁽²⁾ (ug/m ³)	SGC ⁽³⁾ (ug/m ³)	AGC ⁽³⁾ (ug/m ³)	Modeled Impacts < SGC and AGC (Yes/No)
			8/17/2016	lb/yr	lb/hr					
1,1 - Dichloroethane	00075-34-3	2.0	0.31	3.56E-05	4.49E-06	8.48E-04	2.71E-05	--	6.30E-01	Yes
1,1 - Dichloroethene	00075-35-4	14	2.18	2.49E-04	3.14E-05	5.94E-03	1.90E-04	--	200	Yes
Trichloroethene	00079-01-6	1.6	0.25	2.85E-05	3.59E-06	6.79E-04	2.17E-05	20	2.00E-01	Yes
Vinyl Chloride	00075-01-4	3.6	0.56	6.41E-05	8.07E-06	1.53E-03	4.87E-05	180000	1.1E-01	Yes
Chloroethane	00075-00-3	6.3	0.98	1.12E-04	1.41E-05	2.67E-03	8.53E-05	--	10000	Yes
Chloromethane	00074-87-3	5.0	0.78	8.90E-05	1.12E-05	2.12E-03	6.77E-05	22000	90	Yes
Dichloromethane	00075-09-2	1.1	0.17	1.96E-05	2.47E-06	4.67E-04	1.49E-05	14000	60	Yes

Notes and abbreviations on last page.

Table 4A
Summary of AERMOD Air Quality Impact Analysis
Tower 96 Treatment System, Operable Unit 2,
Northrop Grumman Systems Corporation,
Bethpage, New York

Notes and Abbreviations:

(1) Emission rate calculated based on effluent concentration and a stack air flow rate of 4,720 cfm. The stack air flow rate (in acfm) is taken from the actual stack air flow rate on the day of sampling.

$$\text{Trichloroethene (lb/hr)} = (1.6 \text{ ug/m}^3) \times (4,720 \text{ ft}^3/\text{min}) \times (1 \text{ m}^3/35 \text{ ft}^3) \times (60 \text{ min/hr}) \times (0.000001 \text{ g/1 ug}) \times (0.0022 \text{ lb/g})$$

$$\text{lb/yr} = \text{lb/hr} \times 8,760 \text{ hrs/yr}$$

$$\text{g/s} = \text{lb/hr} \times 1 \text{ hr}/3,600 \text{ sec} \times 453.59 \text{ g/1 lb}$$

(2) Ambient impact based on AERMOD modeling using normalized rate of 1 g/s is scaled to the actual emission rate of the pollutant. Modeling was performed using the representative meteorological data from the nearest station (Farmingdale, NY) for the years 2011 through 2015, and a stack which is 55 feet high and 20 inches in diameter. The maximum impact from all the years was used for the calculations.

$$\text{Scaled hourly impact (ug/m}^3) = \text{AERMOD predicted hourly ambient impact at 1 g/s (ug/m}^3\text{/[g/s])} \times \text{Actual emission rate (g/s)}$$

$$\text{Scaled annual impact (ug/m}^3) = \text{AERMOD predicted annual ambient impact at 1 g/s (ug/m}^3\text{/[g/s])} \times \text{Actual emission rate (g/s)}$$

AERMOD Normalized Ambient Impact at 1 g/s	
Hourly ([ug/m ³]/[g/s])	Annual ([ug/m ³]/[g/s])
189.14	6.04

(3) Short-term and annual guideline concentrations for air toxic pollutants specified in the NYSDEC DAR-1 AGC/SGC tables revised August 10, 2016.

(4) The receptor height corresponds to the average inhalation level.

µg/m ³	micrograms per cubic meter
lb/yr	pounds per year
lb/hr	pounds per hour
g/s	grams per second
0.57	bold value indicates a detection
AGC	annual guideline concentration
SGC	short-term guideline concentration
acfm	actual cubic feet per minute
DAR-1	Division of Air Resources-1
NYSDEC	New York State Department of Environmental Conservation

Table 4B
 Summary of AERMOD Air Quality Impact Analysis
 Tower 102 Treatment System, Operable Unit 2,
 Northrop Grumman Systems Corporation,
 Bethpage, New York

Constituent	CAS#	T102 Effluent (ug/m ³)	Emission Rate ⁽¹⁾			Scaled Impact -Hourly ⁽²⁾ (ug/m ³)	Scaled Impact -Annual ⁽²⁾ (ug/m ³)	SGC ⁽³⁾ (ug/m ³)	AGC ⁽³⁾ (ug/m ³)	Modeled Impacts < SGC and AGC (Yes/No)
			8/17/2016	lb/yr	lb/hr					
1,1,1 - Trichloroethane	00071-55-6	0.65	0.17	1.91E-05	2.41E-06	2.71E-04	5.97E-06	9000	5000	Yes
1,1 - Dichloroethane	00075-34-3	10	2.57	2.94E-04	3.70E-05	4.17E-03	9.18E-05	--	6.30E-01	Yes
1,1 - Dichloroethene	00075-35-4	76.9	19.79	2.26E-03	2.85E-04	3.21E-02	7.06E-04	--	200	Yes
Tetrachloroethene	00127-18-4	0.36	0.09	1.06E-05	1.33E-06	1.50E-04	3.30E-06	300	4	Yes
Trichloroethene	00079-01-6	13	3.35	3.82E-04	4.81E-05	5.42E-03	1.19E-04	20	2.00E-01	Yes
Vinyl Chloride	00075-01-4	0.54	0.14	1.59E-05	2.00E-06	2.25E-04	4.96E-06	180000	1.1E-01	Yes
Benzene	00071-43-2	0.42	0.11	1.23E-05	1.55E-06	1.75E-04	3.86E-06	1300	1.30E-01	Yes
Total Xylene	01330-20-7	0.98	0.25	2.88E-05	3.63E-06	4.09E-04	9.00E-06	37000	5000	Yes
Chloroform	00067-66-3	1.5	0.39	4.41E-05	5.55E-06	6.25E-04	1.38E-05	150	14.7	Yes
Chloromethane	00074-87-3	0.89	0.23	2.61E-05	3.29E-06	3.71E-04	8.17E-06	22000	90	Yes
Dichloromethane	00075-09-2	1.3	0.33	3.82E-05	4.81E-06	5.42E-04	1.19E-05	14000	60	Yes
Trichlorotrifluoroethane (Freon 113)	00076-13-1	16	4.12	4.70E-04	5.92E-05	6.67E-03	1.47E-04	960000	180000	Yes

Notes and abbreviations on last page.

**Table 4B
Summary of AERMOD Air Quality Impact Analysis
Tower 102 Treatment System, Operable Unit 2,
Northrop Grumman Systems Corporation,
Bethpage, New York**

Notes and Abbreviations:

(1) Emission rate calculated based on effluent concentration and a stack air flow rate of 7,790 cfm. The stack air flow rate (in acfm) is taken from the actual stack air flow rate on the day of sampling.

$$\text{Trichloroethene (lb/hr)} = (13 \text{ ug/m}^3) \times (4,720 \text{ ft}^3/\text{min}) \times (1 \text{ m}^3/35 \text{ ft}^3) \times (60 \text{ min/hr}) \times (0.000001 \text{ g/1 ug}) \times (0.0022 \text{ lb/g})$$

$$\text{lb/yr} = \text{lb/hr} \times 8,760 \text{ hrs/yr}$$

$$\text{g/s} = \text{lb/hr} \times 1 \text{ hr}/3,600 \text{ sec} \times 453.59 \text{ g/1 lb}$$

(2) Ambient impact based on AERMOD modeling using normalized rate of 1 g/s is scaled to the actual emission rate of the pollutant. Modeling was performed using the representative meteorological data from the nearest station (Farmingdale, NY) for the years 2011 through 2015, and a stack which is 69.52 feet high and 24 inches in diameter. The maximum impact from all the years was used for the calculations.

$$\text{Scaled hourly impact (ug/m}^3) = \text{AERMOD predicted hourly ambient impact at 1 g/s (ug/m}^3)/[\text{g/s}] \times \text{Actual emission rate (g/s)}$$

$$\text{Scaled annual impact (ug/m}^3) = \text{AERMOD predicted annual ambient impact at 1 g/s (ug/m}^3)/[\text{g/s}] \times \text{Actual emission rate (g/s)}$$

AERMOD Normalized Ambient Impact at 1 g/s	
Hourly ([ug/m ³]/[g/s])	Annual ([ug/m ³]/[g/s])
112.65	2.48

(3) Short-term and annual guideline concentrations for air toxic pollutants specified in the NYSDEC DAR-1 AGC/SGC tables revised August 10, 2016.

(4) The receptor height corresponds to the average inhalation level.

µg/m ³	micrograms per cubic meter
lb/yr	pounds per year
lb/hr	pounds per hour
g/s	grams per second
0.57	bold value indicates a detection
AGC	annual guideline concentration
SGC	short-term guideline concentration
acfm	actual cubic feet per minute
DAR-1	Division of Air Resources-1
NYSDEC	New York State Department of Environmental Conservation

Table 5.
Concentrations of Volatile Organic Compounds
and 1,4-Dioxane in Monitoring Wells ⁽¹⁾
BPOW 2-1, BPOW 2-2 and BPOW 2-3, Third Quarter 2016
Operable Unit 2 (Groundwater),
Bethpage, New York


Well: Sample ID: Date:	BPOW 2-1 BPOW 2-1 8/12/2016	BPOW 2-2 BPOW 2-2 8/10/2016	BPOW 2-3 BPOW 2-3 8/30/2016
CONSTITUENT Units (ug/L)			
Volatile Organic Compounds (VOCs) ⁽²⁾⁽³⁾			
1,1,1-Trichloroethane	<0.50	<0.50	<0.50
1,1,2,2-Tetrachloroethane	<0.50	<0.50	<0.50
1,1,2-trichloro-1,2,2-trifluoroethane	<1.0	<1.0	<1.0
1,1,2-Trichloroethane	<0.50	<0.50	<0.50
1,1-Dichloroethane	<0.50	<0.50	<0.50
1,1-Dichloroethene	<0.50	<0.50	<0.50
1,2-Dichloroethane	<0.50	<0.50	<0.50
1,2-Dichloropropane	<0.50	<0.50	<0.50
2-Butanone (MEK)	<5.0	<5.0	<5.0
2-Hexanone	<2.0	<2.0	<2.0
4-methyl-2-pentanone (MIBK)	<2.0	<2.0	<2.0
Acetone	<5.0	<5.0	<5.0
Benzene	0.067 J	<0.50	<0.50
Bromodichloromethane	<0.50	<0.50	<0.50
Bromoform	<0.50	<0.50	<0.50
Bromomethane	<0.50	<0.50	<0.50
Carbon Disulfide	<0.50	<0.50	<0.50
Carbon tetrachloride	<0.50	<0.50	<0.50
Chlorobenzene	<0.50	<0.50	<0.50
Chloroethane	<0.50	<0.50	<0.50
Chloroform	<0.50	<0.50	<0.50
Chloromethane	<0.50	<0.50	<0.50
cis-1,2-dichloroethene	<0.50	<0.50	<0.50
cis-1,3-dichloropropene	<0.50	<0.50	<0.50
Dibromochloromethane	<0.50	<0.50	<0.50
Ethylbenzene	<0.50	<0.50	<0.50
Methylene Chloride	<0.50	<0.50	<0.50
Styrene	<0.50	<0.50	<0.50
Tetrachloroethene	<0.50	<0.50	<0.50
Toluene	<0.50	<0.50	<0.50
trans-1,2-dichloroethene	<0.50	<0.50	<0.50
trans-1,3-dichloropropene	<0.50	<0.50	<0.50
Trichloroethylene	<0.50	<0.50	<0.50
Vinyl Chloride	<0.50	<0.50	<0.50
Xylene-o	<0.50	<0.50	<0.50
Xylenes - m,p	<0.50	<0.50	<0.50
Total VOCs ⁽⁴⁾	0.07	0	0
1,4-Dioxane ⁽²⁾⁽³⁾	0.547	0.346	3.21

See last page for Notes and Abbreviations.

Table 5.
Concentrations of Volatile Organic Compounds
and 1,4-Dioxane in Monitoring Wells ⁽¹⁾
BPOW 2-1, BPOW 2-2 and BPOW 2-3, Third Quarter 2016
Operable Unit 2 (Groundwater),
Bethpage, New York

Notes and Abbreviations:


- (1) These outpost wells have been recently repurposed for use as plume monitoring wells per the June 2015 Groundwater Monitoring Plan Addendum (ARCADIS of New York, Inc., 2015) as conditionally approved by the NYSDEC (August 25, 2015). Therefore, TVOC trigger levels that may have been previously established are no longer shown
 - (2) Samples were analyzed for VOCs using USEPA Method 524.2; samples were analyzed for 1,4-Dioxane using USEPA Method 522
 - (3) Results for the program are validated at 20% frequency, per protocols specified in OU2 Groundwater Monitoring Plan (Arcadis 2016)
 - (4) Total VOCs are rounded to two significant figures
- 0.547** Bold value indicates constituent detected at or above its reporting limit.
- J Constituent value is estimated
- TVOCs Total Volatile Organic Compounds
- VOC Volatile Organic Compounds
- µg/L micrograms per liter
- <0.5 Compound not detected above its laboratory quantification limit.



EXPLANATION

- PROPERTY BOUNDARY OF THE FORMER GRUMMAN AEROSPACE SITE
- PROPERTY BOUNDARY OF THE FORMER NAVY SITE
- PROPERTY BOUNDARY OF THE FORMER OXY/RUCO SITE
- +++++ LONG ISLAND RAILROAD
- DENOTES NORTHROP GRUMMAN OWNED PROPERTY (AS OF 2009)
- DENOTES NAVY OWNED PROPERTY (AS OF 2014)
- ▨ DENOTES FORMER NAVY OWNED PROPERTY
- RECHARGE BASIN
- 10592 ● OBSERVATION/MONITORING/OUTPOST WELL (1)
- 9591 ● PUBLIC SUPPLY WELL (2)
- WELL-17 ● NORTHROP GRUMMAN REMEDIAL WELL
- PART OF ON-SITE REMEDY
- NWIRP NAVAL WEAPONS INDUSTRIAL RESERVE PLANT
- TOH (LWD) TOWN OF HEMPSTEAD LEVITOWN WATER DISTRICT
- HWD HICKSVILLE WATER DISTRICT
- SFWD SOUTH FARMINGDALE WATER DISTRICT
- BWD BETHPAGE WATER DISTRICT
- NYAW NEW YORK AMERICAN WATER


NOTE:
 (1) THIS FIGURE DEPICTS OBSERVATION/MONITORING/OUTPOST WELLS INCLUDED IN THE OU-2 GROUNDWATER MONITORING PROGRAM.
 (2) PUBLIC SUPPLY WELLS ARE NOT SAMPLED AS A PART OF THE OU2 GROUNDWATER MONITORING PROGRAM AND ARE ONLY FOR REFERENCE.



NORTHROP GRUMMAN SYSTEMS CORPORATION
 BETHPAGE, NEW YORK
OPERABLE UNIT 2

**LOCATIONS OF WELLS AND
 ON-SITE GROUNDWATER REMEDY**

FIGURE
1




EXPLANATION

- PROPERTY BOUNDARY OF THE FORMER GRUMMAN AEROSPACE SITE
- PROPERTY BOUNDARY OF THE FORMER NAVY SITE
- PROPERTY BOUNDARY OF THE FORMER OXY/RUCO SITE
- +++++ LONG ISLAND RAILROAD
- DENOTES NORTHROP GRUMMAN OWNED PROPERTY (AS OF 2009)
- DENOTES NAVY OWNED PROPERTY (AS OF 2014)
- ▨ DENOTES FORMER NAVY OWNED PROPERTY
- RECHARGE BASIN
- 10592 ◆ OBSERVATION/MONITORING/OUTPOST WELL (1)
- 9591 ● PUBLIC SUPPLY WELL (2)
- WELL-17 ◆ NORTHROP GRUMMAN REMEDIAL WELL
- PART OF ON-SITE REMEDY
- NWIRP NAVAL WEAPONS INDUSTRIAL RESERVE PLANT
- TOH (LWD) TOWN OF HEMPSTEAD LEVITOWN WATER DISTRICT
- HWD HICKSVILLE WATER DISTRICT
- SFWD SOUTH FARMINGDALE WATER DISTRICT
- BWD BETHPAGE WATER DISTRICT
- NYAW NEW YORK AMERICAN WATER

NOTE:

(1) THIS FIGURE DEPICTS OBSERVATION/MONITORING/OUTPOST WELLS INCLUDED IN THE OU-2 GROUNDWATER MONITORING PROGRAM.
 (2) PUBLIC SUPPLY WELLS ARE NOT SAMPLED AS A PART OF THE OU2 GROUNDWATER MONITORING PROGRAM AND ARE ONLY FOR REFERENCE.




NORTHROP GRUMMAN SYSTEMS CORPORATION
 BETHPAGE, NEW YORK
OPERABLE UNITS 2 AND 3

LOCATIONS OF TREATMENT SYSTEMS AND DISCHARGES

ARCADIS Design & Construction for natural and built assets

FIGURE
2

CITY:SYRACUSE,NY DIV:GROUPENV DB:A,SANCHEZ LD:ALS PIC:Opti PM:Recd TM:Opti LVR:OptiON="OFF=REF"
 \arcadis-us.com\office\data\Syracuse-NY\ENV\CAD\Syracuse\ACT\NY\001496315\G\MM41496315\F03.dwg LAYOUT: 3 SAVED: 3/18/2016 2:32 PM ACADVER: 19.1S (LMS TECH) PAGES: 3 PLOTSTYLETABLE: PLOTTED: 8/11/2016 3:16 PM BY: IAMICELI,KIMBERLY
 XREFS: IMAGES: PROJECTNAME:
 NO. GW PIPE
 XBD:BL



- LEGEND:**
- FORMER NORTHROP GRUMMAN PROPERTY LINE
 - INFLUENT LINE
 - - - BYPASS
 - - - STORM DRAIN (EFFLUENT)
 - - - NON POTABLE WATER DISTRIBUTION LINE (EFFLUENT)
 - ++++ RAILROAD TRACKS
 - - - FENCE
 - WELL 18 REMEDIAL WELL
 - BASIN
 - ONCT ON-SITE CONTAMINANT

NOTES:
 DRAWING IS NOT TO BE USED FOR DESIGN PURPOSES. LAYOUT OF PIPING IS FOR REPRESENTATION ONLY (LOCATIONS ARE APPROXIMATE).


NORTHROP GRUMMAN SYSTEMS CORPORATION
 BETHPAGE, NEW YORK
OPERABLE UNIT 2

**ONCT GROUNDWATER
 EXTRACTION AND TREATMENT
 SYSTEM SITE PLAN**


ARCADIS Design & Consultancy
for natural and built assets

FIGURE
3

TOWER 96 TREATMENT SYSTEM:



TOWER 102 TREATMENT SYSTEM:



LEGEND:

- PROCESS WATER
- PROCESS AIR
- STEAM
- SAMPLE LOCATION
- WATER SAMPLE
- VAPOR SAMPLE
- ON-SITE CONTAMINANT

NORTHROP GRUMMAN SYSTEMS CORPORATION
BETHPAGE, NEW YORK
OPERABLE UNIT 2

**ONCT GROUNDWATER
EXTRACTION AND TREATMENT
SYSTEM SCHEMATIC**

ARCADIS Design & Consultancy
for natural and
built assets

FIGURE
4

CITY: SYRACUSE, NY DIV: GROUP ENV DB: A SANCHEZ LD: ALS PIC: (Opt) PM: (Recd) TM: (Opt) LVR: (Opt) ON: -OFF-REF-
 \arcadis-us.com\office\data\Syracuse-NY\ENV\CA\AD\SYRACUSE\ACTN\001496315\GWM41496315\1514F04.dwg LAYOUT: 4 - SAVED: 3/15/2016 10:09 AM ACADVER: 19.1S (LMS TECH) PAGESETUP: --- PLOTSTYLETABLE: --- PLOTSTYLETABLE: --- PLOTTED: 8/11/2016 3:19 PM BY: IAMICELI, KIMBERLY
 XREFS: IMAGES: PROJECTNAME: ---