

# H2M LABS, INC.

575 Broad Hollow Road, Melville NY 11747  
(631) 694-3040 FAX: (631) 420-8436 NYSDOH ID# 10478

**Sample Information**  
Type : Potable Water  
Origin : Raw Well  
Routine

## LABORATORY RESULTS

Lab No. : **0808266-001A**

Client ID. : **WELL #6-1 (R)**


**Bethpage Water District**  
**25 Adams Ave.**  
**Bethpage, NY 11714**  
**Attn To :**

Federal ID : 2902817  
Collected : 7/15/2008 11:10:00 AM Point No : N-3876  
Received : 7/15/2008 11:24:00 AM Location : WELL #6-1  
Collected By : PS99  
**Copy : RWH**  
**CC : NCHD**

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Method Number	Analyzed
Total coliform	Negative		1		Negative	M9221DE	07/15/2008 3:15 PM
E_Coliform	Absent		1		Absent	M9221DE	07/15/2008 3:15 PM
Dichlorodifluoromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Chloromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Vinyl chloride	< 0.5		1	µg/L	2	E524.2	07/16/2008 5:58 PM
Bromomethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Chloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Trichlorofluoromethane	0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,1-Dichloroethene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Methylene chloride	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
trans-1,2-Dichloroethene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,1-Dichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
2,2-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
cis-1,2-Dichloroethene	1.6		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Bromochloromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Chloroform	< 0.5		1	µg/L	50	E524.2	07/16/2008 5:58 PM
1,1,1-Trichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Carbon tetrachloride	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,1-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,2-Dichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Benzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
* Trichloroethene	* 121	*D	5	µg/L	5	E524.2	07/17/2008 1:03 PM
1,2-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Dibromomethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Bromodichloromethane	< 0.5		1	µg/L	50	E524.2	07/16/2008 5:58 PM
cis-1,3-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Toluene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
trans-1,3-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,1,2-Trichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
* Tetrachloroethene	* 9.5	*	1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,3-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Dibromochloromethane	< 0.5		1	µg/L	50	E524.2	07/16/2008 5:58 PM
Chlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,1,1,2-Tetrachloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Ethylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
m,p-Xylene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
o-Xylene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Styrene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Bromoform	< 0.5		1	µg/L	50	E524.2	07/16/2008 5:58 PM

Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
D.F. = Dilution Factor

Date Reported : 7/23/2008



# H2M LABS, INC.

575 Broad Hollow Road, Melville NY 11747  
(631) 694-3040 . FAX: (631) 420-8436 NYSDOH ID# 10478

## Sample Information

Type : Potable Water  
Origin : Raw Well  
Routine

## LABORATORY RESULTS

Lab No. : **0808266-001A**

Client ID. : **WELL #6-1 (R)**


**Bethpage Water District**  
**25 Adams Ave.**  
**Bethpage, NY 11714**  
**Attn To :**

Federal ID : 2902817  
Collected : 7/15/2008 11:10:00 AM Point No : N-3876  
Received : 7/15/2008 11:24:00 AM Location : WELL #6-1  
Collected By : PS99  
**Copy : RWH**  
**CC : NCHD**

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Method Number</u>	<u>Analyzed</u>
Isopropylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Bromobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,1,2,2-Tetrachloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,2,3-Trichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
n-Propylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
2/4-Chlorotoluene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,3,5-Trimethylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
tert-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,2,4-Trimethylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
sec-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
n-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,3-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,4-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
4-Isopropyltoluene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,2-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,2,4-Trichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Hexachlorobutadiene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
1,2,3-Trichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 5:58 PM
Methyl tert-butyl ether	< 0.5		1	µg/L	10	E524.2	07/16/2008 5:58 PM
Total Trihalomethanes	< 0.5		1	µg/L	80	E524.2	07/16/2008 5:58 PM

Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
D.F. = Dilution Factor

Date Reported : 7/23/2008



# H2M LABS, INC.

575 Broad Hollow Road, Melville NY 11747  
(631) 694-3040. FAX: (631) 420-8436 NYSDOH ID# 10478

## Sample Information

Type : Potable Water  
Origin : Treated Well  
Routine

## Treatment

Treated- AirStripper

## LABORATORY RESULTS

Lab No. : 0808266-002A

Client ID. : WELL #6-1 (T)

Bethpage Water District  
25 Adams Ave.  
Bethpage, NY 11714  
Attn To :

Federal ID 2902817

Collected : 7/15/2008 10:45:00 AM Point No : N-3876

Received : 7/15/2008 11:24:00 AM Location : WELL #6-1

Collected By : PS99

Copy : RWH

CC : NCHD


Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Method Number	Analyzed
Dichlorodifluoromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Chloromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Vinyl chloride	< 0.5		1	µg/L	2	E524.2	07/16/2008 6:26 PM
Bromomethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Chloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Trichlorofluoromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,1-Dichloroethene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Methylene chloride	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
trans-1,2-Dichloroethene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,1-Dichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
2,2-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
cis-1,2-Dichloroethene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Bromochloromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Chloroform	< 0.5		1	µg/L	50	E524.2	07/16/2008 6:26 PM
1,1,1-Trichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Carbon tetrachloride	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,1-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,2-Dichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Benzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Trichloroethene	1.6		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,2-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Dibromomethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Bromodichloromethane	< 0.5		1	µg/L	50	E524.2	07/16/2008 6:26 PM
cis-1,3-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Toluene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
trans-1,3-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,1,2-Trichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Tetrachloroethene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,3-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Dibromochloromethane	< 0.5		1	µg/L	50	E524.2	07/16/2008 6:26 PM
Chlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,1,1,2-Tetrachloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Ethylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
m,p-Xylene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
o-Xylene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Styrene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Bromoform	< 0.5		1	µg/L	50	E524.2	07/16/2008 6:26 PM
Isopropylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Bromobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

D.F. = Dilution Factor

Date Reported : 7/23/2008



# H2M LABS, INC.

575 Broad Hollow Road, Melville NY 11747  
(631) 694-3040 . FAX: (631) 420-8436 NYSDOH ID# 10478

Bethpage Water District  
25 Adams Ave.  
Bethpage, NY 11714  
Attn To :

## LABORATORY RESULTS

Lab No. : **0808266-002A**

Client ID. : **WELL #6-1 (T)**

### Sample Information

Type : Potable Water  
Origin : Treated Well  
Routine

### Treatment


Treated- AirStripper

Federal ID : 2902817  
Collected : 7/15/2008 10:45:00 AM Point No : N-3876  
Received : 7/15/2008 11:24:00 AM Location : WELL #6-1  
Collected By : PS99  
Copy : **RWH**  
CC : NCHD

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Method Number</u>	<u>Analyzed</u>
1,1,2,2-Tetrachloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,2,3-Trichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
n-Propylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
2/4-Chlorotoluene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,3,5-Trimethylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
tert-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,2,4-Trimethylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
sec-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
n-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,3-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,4-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
4-Isopropyltoluene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,2-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,2,4-Trichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Hexachlorobutadiene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
1,2,3-Trichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:26 PM
Methyl tert-butyl ether	< 0.5		1	µg/L	10	E524.2	07/16/2008 6:26 PM
Total Trihalomethanes	< 0.5		1	µg/L	80	E524.2	07/16/2008 6:26 PM

Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
D.F. = Dilution Factor

Date Reported : 7/23/2008



# H2M LABS, INC.

575 Broad Hollow Road, Melville NY 11747  
(631) 694-3040. FAX: (631) 420-8436 NYSDOH ID# 10478

**Sample Information**  
Type : Potable Water  
Origin : Raw Well  
Routine

## LABORATORY RESULTS

Lab No. : **0808266-003A**

Client ID. : **WELL #6-2 (R)**


**Bethpage Water District**  
**25 Adams Ave.**  
**Bethpage, NY 11714**  
**Attn To :**

Federal ID : 2902817  
Collected : 7/15/2008 11:10:00 AM Point No : N-8941  
Received : 7/15/2008 11:24:00 AM Location : WELL #6-2  
Collected By : PS99  
**Copy : RWH**  
**CC : NCHD**

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Method Number	Analyzed
Total coliform	Negative		1		Negative	M9221DE	07/15/2008 3:15 PM
E_Coliform	Absent		1		Absent	M9221DE	07/15/2008 3:15 PM
Dichlorodifluoromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Chloromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Vinyl chloride	< 0.5		1	µg/L	2	E524.2	07/16/2008 6:53 PM
Bromomethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Chloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Trichlorofluoromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,1-Dichloroethene	2.2		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Methylene chloride	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
trans-1,2-Dichloroethene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,1-Dichloroethane	1.1		1	µg/L	5	E524.2	07/16/2008 6:53 PM
2,2-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
cis-1,2-Dichloroethene	1.0		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Bromochloromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Chloroform	0.7		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,1,1-Trichloroethane	0.7		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Carbon tetrachloride	1.9		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,1-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,2-Dichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Benzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
* Trichloroethene	* 390	*D	10	µg/L	5	E524.2	07/17/2008 1:30 PM
1,2-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Dibromomethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Bromodichloromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
cis-1,3-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Toluene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
trans-1,3-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,1,2-Trichloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Tetrachloroethene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,3-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Dibromochloromethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Chlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,1,1,2-Tetrachloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Ethylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
m,p-Xylene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
o-Xylene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Styrene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Bromoform	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM

Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
D.F. = Dilution Factor

Date Reported : 7/23/2008



# H2M LABS, INC.

575 Broad Hollow Road, Melville NY 11747  
(631) 694-3040 . FAX: (631) 420-8436 NYSDOH ID# 10478

## Sample Information

Type : Potable Water  
Origin : Raw Well  
Routine

## LABORATORY RESULTS

Lab No. : 0808266-003A

Client ID. : WELL #6-2 (R)


Bethpage Water District  
25 Adams Ave.  
Bethpage, NY 11714  
Attn To :

Federal ID : 2902817  
Collected : 7/15/2008 11:10:00 AM Point No : N-8941  
Received : 7/15/2008 11:24:00 AM Location : WELL #6-2  
Collected By : PS99  
Copy : RWH  
CC : NCHD

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Method Number	Analyzed
Isopropylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Bromobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,1,2,2-Tetrachloroethane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,2,3-Trichloropropane	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
n-Propylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
2/4-Chlorotoluene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,3,5-Trimethylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
tert-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,2,4-Trimethylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
sec-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
n-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,3-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,4-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
4-Isopropyltoluene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,2-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,2,4-Trichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Hexachlorobutadiene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
1,2,3-Trichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/16/2008 6:53 PM
Methyl tert-butyl ether	< 0.5		1	µg/L	10	E524.2	07/16/2008 6:53 PM
Total Trihalomethanes	< 2.0		1	µg/L	80	E524.2	07/16/2008 6:53 PM

Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
D.F. = Dilution Factor

Date Reported : 7/23/2008



# H2M LABS, INC.

575 Broad Hollow Road, Melville NY 11747  
(631) 694-3040. FAX: (631) 420-8436 NYSDOH ID# 10478

## Sample Information

Type : Potable Water  
Origin : Treated Well  
Routine

## Treatment

Treated- AirStripper

## LABORATORY RESULTS

Lab No. : 0808266-004A

Client ID. : WELL #6-2 (T)

Bethpage Water District  
25 Adams Ave.  
Bethpage, NY 11714  
Attn To :

Federal ID 2902817

Collected : 7/15/2008 10:45:00 AM Point No : N-8941

Received : 7/15/2008 11:24:00 AM Location : WELL #6-2

Collected By : PS99


Copy : RWH

CC : NCHD

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Method Number	Analyzed
Dichlorodifluoromethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Chloromethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Vinyl chloride	< 0.5		1	µg/L	2	E524.2	07/17/2008 12:07 PM
Bromomethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Chloroethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Trichlorofluoromethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,1-Dichloroethene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Methylene chloride	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
trans-1,2-Dichloroethene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,1-Dichloroethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
2,2-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
cis-1,2-Dichloroethene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Bromochloromethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Chloroform	< 0.5		1	µg/L		E524.2	07/17/2008 12:07 PM
1,1,1-Trichloroethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Carbon tetrachloride	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,1-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,2-Dichloroethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Benzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Trichloroethene	1.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,2-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Dibromomethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Bromodichloromethane	< 0.5		1	µg/L		E524.2	07/17/2008 12:07 PM
cis-1,3-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Toluene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
trans-1,3-Dichloropropene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,1,2-Trichloroethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Tetrachloroethene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,3-Dichloropropane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Dibromochloromethane	< 0.5		1	µg/L		E524.2	07/17/2008 12:07 PM
Chlorobenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,1,1,2-Tetrachloroethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Ethylbenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
m,p-Xylene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
o-Xylene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Styrene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Bromoform	< 0.5		1	µg/L		E524.2	07/17/2008 12:07 PM
Isopropylbenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Bromobenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM

Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
D.F. = Dilution Factor

Date Reported : 7/23/2008



# H2M LABS, INC.

575 Broad Hollow Road, Melville NY 11747  
(631) 694-3040 . FAX: (631) 420-8436 NYSDOH ID# 10478

Bethpage Water District  
25 Adams Ave.  
Bethpage, NY 11714  
Attn To :

## LABORATORY RESULTS

Lab No. : **0808266-004A**

Client ID. : **WELL #6-2 (T)**

### Sample Information

Type : Potable Water  
Origin : Treated Well  
Routine

### Treatment

Treated- AirStripper

Federal ID 2902817

Collected : 7/15/2008 10:45:00 AM Point No : N-8941

Received : 7/15/2008 11:24:00 AM Location : WELL #6-2

Collected By : PS99

Copy : **RWH**

CC ; NCHD

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Method Number</u>	<u>Analyzed</u>
1,1,2,2-Tetrachloroethane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,2,3-Trichloropropane	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
n-Propylbenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
2/4-Chlorotoluene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,3,5-Trimethylbenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
tert-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,2,4-Trimethylbenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
sec-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
n-Butylbenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,3-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,4-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
4-Isopropyltoluene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,2-Dichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,2,4-Trichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Hexachlorobutadiene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
1,2,3-Trichlorobenzene	< 0.5		1	µg/L	5	E524.2	07/17/2008 12:07 PM
Methyl tert-butyl ether	< 0.5		1	µg/L	10	E524.2	07/17/2008 12:07 PM
Total Trihalomethanes	< 2.0		1	µg/L	80	E524.2	07/17/2008 12:07 PM

Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
D.F. = Dilution Factor

Date Reported : 7/23/2008

