



21 April 2017

Mr. Jason Pelton
New York State Department of Environmental Conservation
Division of Solid & Hazardous Materials
625 Broadway
Albany, NY 12233-7252

**Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT
GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2
MARCH 2017 REPORTING PERIOD**

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2.

GWTP operational data from 1 March 2017 to 31 March 2017 are presented in Attachment A. There was no significant downtime for the GWTP during this reporting period. Minimal downtime occurred for various maintenance activities including the removal and cleaning of the two wye screens before the air stripper effluent pumps, which required shut down of the system to allow for the liquid gasket material to cure after reassembly.

As indicated in Attachment A, all permitted constituents were in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0622 or sroy@komangs.com with any questions or concerns you may have regarding this report.

Sincerely,
KOMAN Government Solutions, LLC

Stephane Roy
Project Manager

Attachment A: Groundwater and Air Sampling Results from February 2017

Cc: Donald Hesler - NYSDEC
Henry Wilkie - NYSDEC
Steven Scharf – NYSDEC
Jean Occidental - NYSDEC Division of Water
Jennifer Pilewski - NYSDEC – Region 1 Water Engineer
Gerard Ennis - Nassau County Department of Public Works
Linda Bianculli - Town of Oyster Bay
Lora Fly - NAVFAC Mid-Atlantic RPM
Greg Pearman – NWIRP Bethpage
GM-38 Copy

ATTACHMENT A
GROUNDWATER AND AIR SAMPLING RESULTS
MARCH 2017

**GM-38 Area Groundwater Remediation
Groundwater Treatment Plant
Naval Weapons Industrial Reserve Plant - Bethpage, NY
Discharge Monitoring Report
March 2017**

SPDES Parameters	March 2017					
	Daily Treated Effluent Maximum	Units	RW-1 ⁽¹⁾	RW-3 ⁽²⁾	Combined Influent ⁽¹⁾	Treated Effluent
Well Depth	N/A	ft	445	530	N/A	N/A
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	N/A	N/A
Sampling Date	N/A		3/7/17			
Effective Flowrate	1100	GPM	901	0.3	902	932
Total Flow	N/A	gallons	40,260,000	12,000	40,272,000	41,628,600
pH	5.5 - 8.5	SU	5.12	NS	5.12	6.24
Carbon Tetrachloride	NA	µg/L	ND (1.0)	NS	ND (1.0)	ND (1.0)
1,1-Dichloroethane	5	µg/L	2.0	NS	2.0	ND (1.0)
1,2-Dichloroethane	0.6	µg/L	0.38 J	NS	0.38 J	ND (1.0)
1,1-Dichloroethene	5	µg/L	1.4	NS	1.4	ND (1.0)
cis 1,2-Dichloroethene	5	µg/L	8.0	NS	8.0	0.35 J
trans 1,2-Dichloroethene	5	µg/L	ND (1.0)	NS	ND (1.0) J	ND (1.0)
Tetrachloroethene	5	µg/L	24	NS	24	ND (1.0)
1,1,1-Trichloroethene	5	µg/L	0.97 J	NS	1.0	ND (1.0)
Trichloroethene	5	µg/L	110	NS	110	ND (1.0)
Vinyl Chloride	2	µg/L	0.41 J	NS	0.41 J	ND (1.0)
Mercury	0.00025	mg/L	ND (0.00010)	NS	ND (0.00010)	ND (0.00010)
Total Suspended Solids (TSS)	N/A	mg/L	ND (1.0)	NS	ND (1.0)	ND (1.0)

Notes:

B - Method blank contamination

J - Estimated result between laboratory method detection limit and reporting limit

ND - Not detected above laboratory method detection limit. Reporting Limit (RL) given in parentheses.

NR - Not Recorded

NS - Not Sampled. RW-3 sampling frequency has been reduced from monthly to semi-annually.

N/A - Not Applicable

NS - Not Sampled

(1) On 1 July 2015, the RW-1 flowrate was increased from ~800 gpm to ~1,000 gpm and RW-3 was taken off-line, as approved by NYSDEC on 20 April 2015. Influent concentrations presented above are therefore equivalent to RW-1 concentrations only.

(2) To maintain the integrity of RW-3 for potential future use, approximately 200 gallons per minute of water are pumped for a 1-hour period from the well on a monthly basis. RW-3 is sampled semi-annually, consistent with the groundwater monitoring program.

**GM-38 Area Groundwater Remediation
Groundwater Treatment Plant
Naval Weapons Industrial Reserve Plant - Bethpage, NY
Air Sampling Results
March 2017**

DAR Parameters	March 2017	Discharge Goal ⁽¹⁾	March 2017	
			Influent	Effluent
Process Stream				
Sampling Date	N/A	N/A	3/7/17	
Average Flowrate	CFM	N/A	NR	7,943
Total Flow	ft ³	N/A	NR	354,575,520
Total Flow	m ³	N/A	NR	10,040,461
1,2-Dichloroethane	µg/m ³	N/A	4.4	ND
cis 1,2-Dichloroethene	µg/m ³	> 100,000 ⁽²⁾	130	170
trans 1,2-Dichloroethene	µg/m ³		2.5 J	2.2 J
1,2-Dichloroethene (total)	µg/m ³	>100,000	130	170
Toluene	µg/m ³	N/A	0.58 J	ND
Total Xylene	µg/m ³	N/A	ND	ND
1,1,2-Trichloroethane	µg/m ³	N/A	2.70 J	ND
Trichloroethene	µg/m ³	2,600	1700	2.2 J
Vinyl Chloride	µg/m ³	560	3.8	2.5
Tetrachloroethene	µg/m ³	5,100	400	1.2 J

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.

(2) Discharge goal is for total 1,2-Dichloroethene.

**GM-38 Area Groundwater Remediation
Groundwater Treatment Plant
Naval Weapons Industrial Reserve Plant - Bethpage, NY
Controlled Stack Emissions
March 2017**

DAR Parameters	Units	Discharge Goal ⁽¹⁾	March 2017
Sampling Date	N/A	N/A	3/7/17
Average Flowrate	CFM	N/A	7,943
Total Flow	ft ³	N/A	354,575,520
Total Flow	m ³	N/A	10,040,461
Trichloroethene	lb/hr	0.09	0.00007
Vinyl Chloride	lb/hr	0.02	0.00007
1,2 Dichloroethene	lb/hr	11	0.00506
1,2-Dichloroethane	lb/hr	N/A	0.00000
Toluene	lb/hr	N/A	0.00000
Total Xylene	lb/hr	N/A	0.00000
1,1,2-Trichloroethane	lb/hr	N/A	0.00000
Tetrachloroethene	lb/hr	0.18	0.00004

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.