

8 June 2018

Mr. Jason Pelton New York State Department of Environmental Conservation Division of Solid & Hazardous Materials 625 Broadway Albany, NY 12233-7252

Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT

GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2

**May 2018 REPORTING PERIOD** 

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 May to 31 May 2018 are presented in Attachment A. In the May reporting period, no downtime was recorded for the GM38. As indicated in Attachment A, all SPDES permitted constituents were in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0622 with any questions or concerns you may have regarding this report.

Sincerely,

KOMAN Government Solutions, LLC

Stephane Roy

Project Manager

Attachment A: Groundwater and Air Sampling Results from May 2018

Cc: S. Edwards, NYSDEC

D. Hesler, NYSDEC

C. Haas, NYSDEC Region 1 W. Parish, NYSDEC Region 1

R. Wither, NYSDEC Division of Water

J. Pilewski, NYSDEC – Region 1 Water Engineer

- S. Karpinski, NYSDOH
- J. Lovejoy, NCDH
- L. Thantu, USEPA Region 2
- G. Ennis, Nassau County Department of Public Works
- S. Urban, Nassau County Department of Public Works
- T. Licata, Town of Oyster Bay
- M. Russo, Town of Oyster Bay
- L. Fly, NAVFAC Mid-Atlantic
- B. Murray, NAVFAC Mid-Atlantic RPM
- G. Pearman, NWIRP Bethpage
- GM-38 Copy

# ATTACHMENT A GROUNDWATER AND AIR SAMPLING RESULTS MAY 2018

## GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Discharge Monitoring Report

Discharge Monitorir May 2018

SPDES Parameters	May 2018 <sup>(1)</sup>							
Process Stream	Daily Treated Effluent Maximum <sup>(1)</sup>	Units	RW-1	<b>RW-3</b> <sup>(2)</sup>	Combined Influent <sup>(3)</sup>	Treated Effluent		
Well Depth	N/A	ft	445	530	N/A	N/A		
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	N/A	N/A		
Sampling Date	N/A		5/1/18					
Effective Flowrate	1100	GPM	876	0.2	876	904		
Total Flow	N/A	gallons	39,098,400	10,700	39,109,100	40,357,700		
рН	5.5 - 8.5	SU	4.87	NS	4.87	5.97		
Chloroform	5	μg/L	0.347 J	NS	0.347 J	ND (1.0)		
1,1-Dichloroethane	5	μg/L	1.49	NS	1.49	ND (1.0)		
1,2-Dichloroethane	0.6	μg/L	0.246 J	NS	0.246 J	ND (1.0)		
1,1-Dichloroethene	5	μg/L	0.996 J	NS	0.996 J	ND (1.0)		
cis 1,2-Dichloroethene	5	μg/L	5.71	NS	5.71	ND (1.0)		
trans 1,2-Dichloroethene	5	μg/L	ND (1.0)	NS	ND (1.0)	ND (1.0)		
Tetrachloroethene	5	μg/L	21.4	NS	21.4	ND (1.0)		
1,1,1-Trichloroethane	5	μg/L	0.706 J	NS	0.706 J	ND (1.0)		
Trichloroethene	5	μg/L	85.0	NS	85.0	0.502 J		
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.0)	NS	ND (1.0)	ND (1.0)		
Vinyl Chloride	2	μg/L	0.215 J	NS	0.215 J	ND (1.0)		
1,4-Dioxane		μg/L	NS	NS	NS	2.4		
Mercury	0.00025	mg/L	ND (0.00010)	NS	ND (0.00010)	ND (0.00010)		
Total Suspended Solids (TSS)	N/A	mg/L	ND (1.0)	NS	ND (1.0)	ND (1.0)		

#### Notes:

 $\ensuremath{\mathsf{J}}$  - Estimated result between laboratory method detection limit and reporting limit

ND - Not detected above laboratory method detection limit. Reporting Limit (RL) given in parentheses.

NR - Not Recorded

N/A - Not Applicable

NS - Not Sampled

- (1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.
- (2) Well RW-3 was turned on for a total of approximately 1 hour this period.

## GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Air Sampling Results May 2018

DAR Parameters		Discharge Goal <sup>(1)</sup>	May 2018	
Process Stream			Influent	Effluent
Sampling Date			5/1/18	
Average Flowrate	CFM	N/A	NR	9,324
Total Flow	ft <sup>3</sup>	N/A	NR	416,201,040
Total Flow	m <sup>3</sup>	N/A	NR	11,785,501
1,2-Dichloroethane	μg/m³	N/A	2.7 J	ND
cis 1,2-Dichloroethene	μg/m³	. 400 000 (2)	71	ND
trans 1,2-Dichloroethene	μg/m³	> 100,000 (2)	1.7 J	ND
1,2-Dichloroethene (total)	μg/m³	>100,000	74	ND
Toluene	μg/m³	N/A	0.42 J	ND
Total Xylene	μg/m³	N/A	ND	ND
1,1,2-Trichloroethane	μg/m³	N/A	ND	ND
Trichloroethene	μg/m³	2,600	1200	2.7 J
Vinyl Chloride	μg/m³	560	2.0	1.6 J
Tetrachloroethene	μg/m³	5,100	260	1.3 J

#### Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

- (1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.
- (2) Discharge goal is for total 1,2-Dichloroethene.

# GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Controlled Stack Emissions May 2018

DAR Parameters	Units	Discharge Goal <sup>(1)</sup>	May 2018	
Sampling Date			5/1/18	
Average Flowrate	CFM	N/A	9,324	
Total Flow	ft <sup>3</sup>	N/A	416,201,040	
Total Flow	m <sup>3</sup>	N/A	11,785,501	
Trichloroethene	lb/hr	0.09	0.00009	
Vinyl Chloride	lb/hr	0.02	0.00006	
1,2 Dichloroethene	lb/hr	11	0.00000	
1,2-Dichloroethane	lb/hr	N/A	0.00000	
Toluene	lb/hr	N/A	0.00000	
Total Xylene	lb/hr	N/A	0.00000	
1,1,2-Trichloroethane	lb/hr	N/A	0.00000	
Tetrachloroethene	lb/hr	0.18	0.00005	

### Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.