



6 September 2018

Mr. Jason Pelton
New York State Department of Environmental Conservation
Division of Solid & Hazardous Materials
625 Broadway
Albany, NY 12233-7252

**Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT
GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2
AUGUST 2018 REPORTING PERIOD**

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 August to 31 August 2018 are presented in Attachment A. In the August reporting period, no significant downtime was recorded for the GM38.

As indicated in Attachment A, all SPDES permitted constituents were in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0622 with any questions or concerns you may have regarding this report.

Sincerely,

KOMAN Government Solutions, LLC

Stephane Roy
Project Manager

Attachment A: Groundwater and Air Sampling Results from August 2018

Cc: S. Edwards, NYSDEC
D. Hesler, NYSDEC
C. Haas, NYSDEC Region 1
W. Parish, NYSDEC Region 1
R. Wither, NYSDEC Division of Water

J. Pilewski, NYSDEC – Region 1 Water Engineer
S. Karpinski, NYSDOH
J. Lovejoy, NCDH
L. Thantu, USEPA Region 2
G. Ennis, Nassau County Department of Public Works
S. Urban, Nassau County Department of Public Works
T. Licata, Town of Oyster Bay
M. Russo, Town of Oyster Bay
L. Fly, NAVFAC Mid-Atlantic
B. Murray, NAVFAC Mid-Atlantic RPM
G. Pearman, NWIRP Bethpage
GM-38 Copy

ATTACHMENT A
GROUNDWATER AND AIR SAMPLING RESULTS
AUGUST 2018

**GM-38 Area Groundwater Remediation
Groundwater Treatment Plant
Naval Weapons Industrial Reserve Plant - Bethpage, NY
Discharge Monitoring Report
August 2018**

SPDES Parameters	August 2018 ⁽¹⁾					
	Daily Treated Effluent Maximum ⁽¹⁾	Units	RW-1	RW-3 ⁽²⁾	Combined Influent ⁽³⁾ (RW-1 + RW-3)	Treated Effluent
Well Depth	N/A	ft	445	530	N/A	N/A
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	N/A	N/A
Sampling Date	N/A		8/1/18			
Effective Flowrate	1100	GPM	689	190	879	923
Total Flow	N/A	gallons	30,840,500	8,499,700	39,340,200	41,282,200
pH	5.5 - 8.5	SU	4.89	5.06	4.88	6.02
Chloroform	5	µg/L	0.390 J	0.330 J	0.377 J	ND (1.0)
1,1-Dichloroethane	5	µg/L	1.59	1.88	1.65	ND (1.0)
1,2-Dichloroethane	0.6	µg/L	0.310 J	ND (1.0)	0.243 J	ND (1.0)
1,1-Dichloroethene	5	µg/L	1.02	1.30	1.08 J	ND (1.0)
cis 1,2-Dichloroethene	5	µg/L	5.24	1.63	4.46	0.220 J
trans 1,2-Dichloroethene	5	µg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Tetrachloroethene	5	µg/L	20.6	0.420 J	16.24	ND (1.0)
1,1,1-Trichloroethane	5	µg/L	0.620 J	0.730 J	0.644 J	ND (1.0)
Trichloroethene	5	µg/L	84.5	200 D	109.5	0.950 J
1,1,2-Trichlorotrifluoroethane	5	µg/L	ND (1.0)	1.03	0.22 J	ND (1.0)
Vinyl Chloride	2	µg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,4-Dioxane	--	µg/L	NS	NS	NS	3.2
Mercury	0.00025	mg/L	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)
Total Suspended Solids (TSS)	N/A	mg/L	ND (1.0)	2.8	0.6	ND (1.0)

Notes:

J - Estimated result between laboratory method detection limit and reporting limit

D - Concentration is a result of a dilution.

ND - Not detected above laboratory method detection limit. Reporting Limit (RL) given in parentheses.

NR - Not Recorded

N/A - Not Applicable

NS - Not Sampled

(1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.

(2) Well RW-3 was placed back in operation on 1 June, 2018.

(3) Influent concentrations presented are the weighted average concentrations of RW-1 and RW-3.

**GM-38 Area Groundwater Remediation
Groundwater Treatment Plant
Naval Weapons Industrial Reserve Plant - Bethpage, NY
Air Sampling Results
August 2018**

DAR Parameters		Discharge Goal ⁽¹⁾	August 2018	
			Influent	Effluent
Process Stream				
Sampling Date			8/1/18	
Average Flowrate	CFM	N/A	NR	9,068
Total Flow	ft ³	N/A	NR	404,812,260
Total Flow	m ³	N/A	NR	11,463,007
1,2-Dichloroethane	μg/m ³	N/A	3.2 J	ND
cis 1,2-Dichloroethene	μg/m ³	> 100,000 ⁽²⁾	48	ND
trans 1,2-Dichloroethene	μg/m ³		ND	ND
1,2-Dichloroethene (total)	μg/m ³	>100,000	48	ND
Toluene	μg/m ³	N/A	ND	ND
Total Xylene	μg/m ³	N/A	ND	ND
1,1,2-Trichloroethane	μg/m ³	N/A	ND	ND
Trichloroethene	μg/m ³	2,600	1500	2.9 J
Vinyl Chloride	μg/m ³	560	ND	1.3 J
Tetrachloroethene	μg/m ³	5,100	200	1.2 J

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.

(2) Discharge goal is for total 1,2-Dichloroethene.

**GM-38 Area Groundwater Remediation
Groundwater Treatment Plant
Naval Weapons Industrial Reserve Plant - Bethpage, NY
Controlled Stack Emissions
August 2018**

DAR Parameters	Units	Discharge Goal ⁽¹⁾	August 2018
Sampling Date			8/1/18
Average Flowrate	CFM	N/A	9,068
Total Flow	ft ³	N/A	404,812,260
Total Flow	m ³	N/A	11,463,007
Trichloroethene	lb/hr	0.09	0.00010
Vinyl Chloride	lb/hr	0.02	0.00004
1,2 Dichloroethene	lb/hr	11	0.00000
1,2-Dichloroethane	lb/hr	N/A	0.00000
Toluene	lb/hr	N/A	0.00000
Total Xylene	lb/hr	N/A	0.00000
1,1,2-Trichloroethane	lb/hr	N/A	0.00000
Tetrachloroethene	lb/hr	0.18	0.00004

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.