

9 August 2019

Mr. Jason Pelton New York State Department of Environmental Conservation Division of Solid & Hazardous Materials 625 Broadway Albany, NY 12233-7252

Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT

GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2

JULY 2019 REPORTING PERIOD

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 July to 31 July 2019 are presented in Attachment A. There was a power outage that resulted in the plant being offline from 22 July until the morning of 23 July; the plant was offline for a total of 12.6 hours during the July reporting period.

As indicated in Attachment A, all SPDES permitted constituents were in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0622 with any questions or concerns you may have regarding this report.

Sincerely,

KOMAN Government Solutions, LLC

Stephane Roy Project Manager

, c

Attachment A: Groundwater and Air Sampling Results from July 2019

Cc: S. Edwards, NYSDEC

D. Hesler, NYSDEC

C. Haas, NYSDEC Region 1

W. Parish, NYSDEC Region 1

- R. Wither, NYSDEC Division of Water
- J. Pilewski, NYSDEC Region 1 Water Engineer
- S. Karpinski, NYSDOH
- J. Lovejoy, NCDH
- C. Stein, USEPA Region 2
- G. Ennis, Nassau County Department of Public Works
- S. Urban, Nassau County Department of Public Works
- T. Licata, Town of Oyster Bay
- M. Russo, Town of Oyster Bay
- L. Fly, NAVFAC Mid-Atlantic
- B. Murray, NAVFAC Mid-Atlantic RPM
- G. Pearman, NWIRP Bethpage
- GM-38 Copy

ATTACHMENT A GROUNDWATER AND AIR SAMPLING RESULTS JULY 2019

GM-38 Area Groundwater Remediation Groundwater Treatment Plant

Naval Weapons Industrial Reserve Plant - Bethpage, NY Discharge Monitoring Report July 2019

SPDES Parameters			July 2019 ⁽¹⁾			
Process Stream	Daily Treated Effluent Maximum ⁽¹⁾	Units	RW-1	RW-3 ⁽²⁾	Combined Influent (3) (RW-1 + RW-3)	Treated Effluent
Well Depth	N/A	ft	445	530	N/A	N/A
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	N/A	N/A
Sampling Date	N/A		7/2/19			
Effective Flowrate	1100	GPM	630	160	790	853
Total Flow	N/A	gallons	28,289,295	7,163,450	35,452,746	38,303,667
рН	5.5 - 8.5	SU	5.29	4.99	5.23	6.03
Chloroform	5	μg/L	0.250 J	0.390 J	0.28 J	ND (1.0)
1,1-Dichloroethane	5	μg/L	1.41 J	2.18 J	1.57 J	ND (1.0)
1,2-Dichloroethane	0.6	μg/L	0.220 J	0.200 J	0.216 J	ND (1.0)
1,1-Dichloroethene	5	μg/L	0.900 J	1.05 J	0.930 J	ND (1.0)
cis 1,2-Dichloroethene	5	μg/L	4.86 J	1.29 J	4.14 J	ND (1.0)
trans 1,2-Dichloroethene	5	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Tetrachloroethene	5	μg/L	15.6	0.250 J	12.50	ND (1.0)
1,1,1-Trichloroethane	5	μg/L	0.620 J	0.720 J	0.640 J	ND (1.0)
Trichloroethene	5	μg/L	64.2	152	81.9	ND (1.0)
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.0)	0.870 J	0.18 J	ND (1.0)
Vinyl Chloride	2	μg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,4-Dioxane		μg/L	2.0	5.0	2.6	NS
Mercury	0.00025	mg/L	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)
Total Suspended Solids (TSS)	N/A	mg/L	ND (1.0)	6.3	1.3	ND (1.0)

Notes:

- J Estimated result between laboratory method detection limit and reporting limit
- D Concentration is a result of a dilution.
- ND Not detected above laboratory method detection limit. Reporting Limit (RL) given in parentheses.
- NR Not Recorded
- N/A Not Applicable
- NS Not Sampled
- (1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.
- (2) Well RW-3 was placed back in operation on 1 June, 2018.
- (3) Influent concentrations presented are the weighted average concentrations of RW-1 and RW-3.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Air Sampling Results July 2019

DAR Parameters	July 2019			
Process Stream	Units	Discharge Goal ⁽¹⁾	Influent	Effluent
Sampling Date			7/2/19	
Average Flowrate	CFM	N/A	NR	8,526
Total Flow	ft ³	N/A	NR	374,210,602
Total Flow	m ³	N/A	NR	10,596,464
1,2-Dichloroethane	μg/m³	N/A	2.3 J	ND
cis 1,2-Dichloroethene	μg/m³	≤ 100,000 ⁽²⁾	46	78
trans 1,2-Dichloroethene	μg/m³	≤ 100,000	ND	ND
1,2-Dichloroethene (total)	μg/m³	≤ 100,000	48	79
Toluene	μg/m³	N/A	ND	ND
Total Xylene	μg/m³	N/A	ND	ND
1,1,2-Trichloroethane	μg/m³	N/A	2.4 J	ND
Trichloroethene	μg/m³	≤ 2600	1200	1.8 J
Vinyl Chloride	μg/m³	≤ 560	ND	ND
Tetrachloroethene	μg/m³	≤ 5100	180	2.6 J

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

- (1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.
- (2) Discharge goal is for total 1,2-Dichloroethene.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Controlled Stack Emissions July 2019

DAR Parameters	Units	Discharge Goal ⁽¹⁾	July 2019
Sampling Date			7/2/19
Average Flowrate	CFM	N/A	8,526
Total Flow	ft ³	N/A	374,210,602
Total Flow	m ³	N/A	10,596,464
Trichloroethene	lb/hr	≤ 0.09	0.0006
Vinyl Chloride	lb/hr	≤ 0.02	0.00000
1,2 Dichloroethene	lb/hr	≤ 11	0.00248
1,2-Dichloroethane	lb/hr	N/A	0.00000
Toluene	lb/hr	N/A	0.00000
Total Xylene	lb/hr	N/A	0.00000
1,1,2-Trichloroethane	lb/hr	N/A	0.00000
Tetrachloroethene	lb/hr	≤ 0.18	0.00008

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.