

15 September 2020

Mr. Jason Pelton New York State Department of Environmental Conservation Division of Solid & Hazardous Materials 625 Broadway Albany, NY 12233-7252

Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT

GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2

AUGUST 2020 REPORTING PERIOD

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 August to 31 August 2020 are presented in Attachment A. Nine and a half hours of downtime were recorded during this period associated with a power outage.

As indicated in Attachment A, all SPDES permitted constituents are in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0636 with any questions or concerns you may have regarding this report.

Sincerely,

KOMAN Government Solutions, LLC

Kolut & Dryng

Robert Gregory Project Manager

Attachment A: Groundwater and Air Sampling Results from August 2020

Cc: S. Edwards, NYSDEC

D. Hesler, NYSDEC

C. Haas, NYSDEC Region 1

C. Engelhardt, NYSDEC Region 1

- J. Pilewski, NYSDEC Region 1 Water Engineer
- J. Sullivan, NYSDOH
- J. Lovejoy, NCDOH
- G. Ennis, Nassau County Department of Public Works
- T. Licata, Town of Oyster Bay
- M. Russo, Town of Oyster Bay
- S. Sokolowski, NAVFAC Mid-Atlantic
- B. Murray, NAVFAC Mid-Atlantic
- V. Varricchio, NWIRP Bethpage Facilities Management
- P. Schauble, KGS
- GM-38 Copy

ATTACHMENT A GROUNDWATER AND AIR SAMPLING RESULTS AUGUST 2020

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Weapons Industrial Reserve Plant - Rethnace

Naval Weapons Industrial Reserve Plant - Bethpage, NY Discharge Monitoring Report August 2020

| SPDES Parameters | | | August 2020 ⁽¹⁾ | | | |
|--------------------------------|--------------------------------------------------------|---------|----------------------------|---------------------|-------------------------------------|---------------------|
| Process Stream | Daily Treated Effluent Maximum ⁽¹⁾ | Units | RW-1 | RW-3 ⁽²⁾ | Combined Influent (3) (RW-1 + RW-3) | Treated Effluent |
| Well Depth | N/A | ft | 445 | 530 | N/A | N/A |
| Screened Interval | N/A | ft bgs | 335-395 410-430 | 392-412 442-504 | N/A | N/A |
| Sampling Date | N/A | | 8/3/20 | | | |
| Effective Flowrate | 1100 | GPM | 799 | 213 | 1,012 | 1,052 |
| Total Flow | N/A | gallons | 35,669,600 | 9,517,600 | 45,187,200 | 46,974,700 |
| рН | 5.5 - 8.5 | SU | 4.91 | 5.41 | 5.02 | 6.70 |
| Chloroform | 5 | μg/L | ND (1.0) | ND (1.0) | ND (1.0) | ND (1.0) |
| 1,1-Dichloroethane | 5 | μg/L | 0.905 J | 1.85 J | 1.10 J | ND (1.0) |
| 1,2-Dichloroethane | 0.6 | μg/L | ND (1.0) | ND (1.0) | ND (1.0) | ND (1.0) |
| 1,1-Dichloroethene | 5 | μg/L | 0.620 J | 1.23 J | 0.748 J | ND (1.0) |
| cis 1,2-Dichloroethene | 5 | μg/L | 3.23 J | 1.38 J | 2.84 J | ND (1.0) |
| trans 1,2-Dichloroethene | 5 | μg/L | ND (1.0) | ND (1.0) | ND (1.0) | ND (1.0) |
| Tetrachloroethene | 5 | μg/L | 16.7 | ND (1.0) | 13.18 | ND (1.0) |
| 1,1,1-Trichloroethane | 5 | μg/L | 0.375 J | 0.498 J | 0.401 J | ND (1.0) |
| Trichloroethene | 5 | μg/L | 60.1 | 131 | 75.0 | 0.470 J |
| 1,1,2-Trichlorotrifluoroethane | 5 | μg/L | ND (1.0) | 0.501 J | 0.11 J | ND (1.0) |
| Vinyl Chloride | 2 | μg/L | ND (1.0) | ND (1.0) | ND (1.0) | ND (1.0) |
| 1,4-Dioxane | | μg/L | 2.2 | 5.9 | 3.0 | NS |
| Mercury | 0.00025 | mg/L | ND (0.00010) | ND (0.00010) | ND (0.00010) | ND (0.00010) |
| Total Suspended Solids (TSS) | N/A | mg/L | ND (1.0) | 3.1 | 0.7 | ND (1.0) |

Notes:

- $\ensuremath{\mathsf{J}}$ Estimated result between laboratory method detection limit and reporting limit
- D Concentration is a result of a dilution.
- ND Not detected above laboratory method detection limit. Reporting Limit (RL) given in parentheses.
- NR Not Recorded
- N/A Not Applicable
- NS Not Sampled
- (1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.
- (2) Well RW-3 was placed back in operation on 1 June, 2018.
- (3) Influent concentrations presented are the weighted average concentrations of RW-1 and RW-3.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Air Sampling Results August 2020

| DAR Parameters | August 2020 | | | |
|----------------------------|-----------------|----------------------------------|----------|-------------|
| Process Stream | Units | Discharge Goal ⁽¹⁾ | Influent | Effluent |
| Sampling Date | | | 8/3/20 | |
| Average Flowrate | CFM | N/A | NR | 8,794 |
| Total Flow | ft ³ | N/A | NR | 387,564,171 |
| Total Flow | m ³ | N/A | NR | 10,974,595 |
| 1,2-Dichloroethane | μg/m³ | N/A | 2.9 J | ND |
| cis 1,2-Dichloroethene | μg/m³ | ≤ 100,000 ⁽²⁾ | 49 | ND |
| trans 1,2-Dichloroethene | μg/m³ | ≤ 100,000 ` ′ | 1.6 J | ND |
| 1,2-Dichloroethene (total) | μg/m³ | ≤ 100,000 | 51 | ND |
| Toluene | μg/m³ | N/A | 2.0 J | 0.77 J |
| Total Xylene | μg/m³ | N/A | ND | ND |
| 1,1,2-Trichloroethane | μg/m³ | N/A | 2.8 J | ND |
| Trichloroethene | μg/m³ | ≤ 2600 | 1200 | ND |
| Vinyl Chloride | μg/m³ | ≤ 560 | 1.9 J | 2.1 J |
| Tetrachloroethene | μg/m³ | ≤ 5100 | 220 | ND |

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

- (1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.
- (2) Discharge goal is for total 1,2-Dichloroethene.

GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Controlled Stack Emissions August 2020

| DAR Parameters | Units | Discharge Goal ⁽¹⁾ | August 2020 |
|-----------------------|-----------------|----------------------------------|-------------|
| Sampling Date | | | 8/3/20 |
| Average Flowrate | CFM | N/A | 8,794 |
| Total Flow | ft ³ | N/A | 387,564,171 |
| Total Flow | m ³ | N/A | 10,974,595 |
| Trichloroethene | lb/hr | ≤ 0.09 | 0.00000 |
| Vinyl Chloride | lb/hr | ≤ 0.02 | 0.00007 |
| 1,2 Dichloroethene | lb/hr | ≤ 11 | 0.00000 |
| 1,2-Dichloroethane | lb/hr | N/A | 0.00000 |
| Toluene | lb/hr | N/A | 0.00003 |
| Total Xylene | lb/hr | N/A | 0.00000 |
| 1,1,2-Trichloroethane | lb/hr | N/A | 0.00000 |
| Tetrachloroethene | lb/hr | ≤ 0.18 | 0.00000 |

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.