



11 October 2020

Mr. Jason Pelton  
New York State Department of Environmental Conservation  
Division of Solid & Hazardous Materials  
625 Broadway  
Albany, NY 12233-7252

**Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT  
GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2  
SEPTEMBER 2020 REPORTING PERIOD**

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 September to 30 September 2020 are presented in Attachment A. Four and a half hours of downtime were recorded during this period associated with multiple bag filter changeouts associated with non-routine clogging of the filters.

As indicated in Attachment A, all SPDES permitted constituents are in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0636 with any questions or concerns you may have regarding this report.

Sincerely,

***KOMAN Government Solutions, LLC***

Robert Gregory  
Project Manager

Attachment A: Groundwater and Air Sampling Results from September 2020

Cc: S. Edwards, NYSDEC  
D. Hesler, NYSDEC  
C. Haas, NYSDEC Region 1

C. Engelhardt, NYSDEC Region 1  
J. Pilewski, NYSDEC – Region 1 Water Engineer  
J. Sullivan, NYSDOH  
J. Lovejoy, NCDOH  
G. Ennis, Nassau County Department of Public Works  
T. Licata, Town of Oyster Bay  
M. Russo, Town of Oyster Bay  
S. Sokolowski, NAVFAC Mid-Atlantic  
B. Murray, NAVFAC Mid-Atlantic  
V. Varrichio, NWIRP Bethpage Facilities Management  
P. Schauble, KGS  
GM-38 Copy

**ATTACHMENT A**  
**GROUNDWATER AND AIR SAMPLING RESULTS**  
**SEPTEMBER 2020**

**GM-38 Area Groundwater Remediation  
Groundwater Treatment Plant  
Naval Weapons Industrial Reserve Plant - Bethpage, NY  
Discharge Monitoring Report  
September 2020**

SPDES Parameters			September 2020 <sup>(1)</sup>			
Process Stream	Daily Treated Effluent Maximum <sup>(1)</sup>	Units	RW-1	RW-3 <sup>(2)</sup>	Combined Influent <sup>(3)</sup> (RW-1 + RW-3)	Treated Effluent
Well Depth	N/A	ft	445	530	N/A	N/A
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	N/A	N/A
Sampling Date	N/A		9/1/20			
Effective Flowrate	1100	GPM	297	135	431	540
Total Flow	N/A	gallons	12,740,400	5,778,300	18,518,700	23,198,000
pH	5.5 - 8.5	SU	5.69	5.29	5.57	6.80
Chloroform	5	µg/L	0.309 J	0.367 J	0.327 J	ND (1.0)
1,1-Dichloroethane	5	µg/L	1.12 J	2.34 J	1.50 J	ND (1.0)
1,2-Dichloroethane	0.6	µg/L	0.202 J	ND (1.0)	0.14 J	ND (1.0)
1,1-Dichloroethene	5	µg/L	0.855 J	1.24 J	0.975 J	ND (1.0)
cis 1,2-Dichloroethene	5	µg/L	3.80 J	1.64 J	3.13 J	ND (1.0)
trans 1,2-Dichloroethene	5	µg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
Tetrachloroethene	5	µg/L	17.7	0.224 J	12.18	ND (1.0)
1,1,1-Trichloroethane	5	µg/L	0.505 J	0.607 J	0.537 J	ND (1.0)
Trichloroethene	5	µg/L	58.5	129	80.5	0.432 J
1,1,2-Trichlorotrifluoroethane	5	µg/L	ND (1.0)	0.575 J	0.18 J	ND (1.0)
Vinyl Chloride	2	µg/L	ND (1.0)	ND (1.0)	ND (1.0)	ND (1.0)
1,4-Dioxane	--	µg/L	2.2	5.8	1.81	NS
Mercury	0.00025	mg/L	ND (0.00010)	ND (0.00010)	ND (0.00010)	ND (0.00010)
Total Suspended Solids (TSS)	N/A	mg/L	ND (1.0)	4.9	1.5	ND (1.0)

**Notes:**

J - Estimated result between laboratory method detection limit and reporting limit

D - Concentration is a result of a dilution.

ND - Not detected above laboratory method detection limit. Reporting Limit (RL) given in parentheses.

NR - Not Recorded

N/A - Not Applicable

NS - Not Sampled

(1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.

(2) Well RW-3 was placed back in operation on 1 June, 2018.

(3) Influent concentrations presented are the weighted average concentrations of RW-1 and RW-3.

**GM-38 Area Groundwater Remediation  
Groundwater Treatment Plant  
Naval Weapons Industrial Reserve Plant - Bethpage, NY  
Air Sampling Results  
September 2020**

DAR Parameters			September 2020	
Process Stream	Units	Discharge Goal <sup>(1)</sup>	Influent	Effluent
Sampling Date			9/1/20	
Average Flowrate	CFM	N/A	NR	8,672
Total Flow	ft <sup>3</sup>	N/A	NR	372,274,650
Total Flow	m <sup>3</sup>	N/A	NR	10,541,644
1,2-Dichloroethane	µg/m <sup>3</sup>	N/A	2.1 J	ND
cis 1,2-Dichloroethene	µg/m <sup>3</sup>	≤ 100,000 <sup>(2)</sup>	49	ND
trans 1,2-Dichloroethene	µg/m <sup>3</sup>		ND	ND
1,2-Dichloroethene (total)	µg/m <sup>3</sup>	≤ 100,000	49	ND
Toluene	µg/m <sup>3</sup>	N/A	ND	ND
Total Xylene	µg/m <sup>3</sup>	N/A	ND	ND
1,1,2-Trichloroethane	µg/m <sup>3</sup>	N/A	1.5 J	ND
Trichloroethene	µg/m <sup>3</sup>	≤ 2600	1200	ND
Vinyl Chloride	µg/m <sup>3</sup>	≤ 560	ND	ND
Tetrachloroethene	µg/m <sup>3</sup>	≤ 5100	210	ND

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.

(2) Discharge goal is for total 1,2-Dichloroethene.

**GM-38 Area Groundwater Remediation  
Groundwater Treatment Plant  
Naval Weapons Industrial Reserve Plant - Bethpage, NY  
Controlled Stack Emissions  
September 2020**

<b>DAR Parameters</b>	<b>Units</b>	<b>Discharge Goal <sup>(1)</sup></b>	<b>September 2020</b>
Sampling Date			9/1/20
Average Flowrate	CFM	N/A	8,672
Total Flow	ft <sup>3</sup>	N/A	372,274,650
Total Flow	m <sup>3</sup>	N/A	10,541,644
Trichloroethene	lb/hr	≤ 0.09	0.00000
Vinyl Chloride	lb/hr	≤ 0.02	0.00000
1,2 Dichloroethene	lb/hr	≤ 11	0.00000
1,2-Dichloroethane	lb/hr	N/A	0.00000
Toluene	lb/hr	N/A	0.00000
Total Xylene	lb/hr	N/A	0.00000
1,1,2-Trichloroethane	lb/hr	N/A	0.00000
Tetrachloroethene	lb/hr	≤ 0.18	0.00000

Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.