

6 January 2022

Mr. Jason Pelton New York State Department of Environmental Conservation Division of Solid & Hazardous Materials 625 Broadway Albany, NY 12233-7252

Subject: GROUNDWATER DISCHARGE MONITORING/AIR EMISSION REPORT

GM-38 AREA, NWIRP BETHPAGE, NY; DER SITE # 1-30-003B-OU 2

**DECEMBER 2021 REPORTING PERIOD** 

Dear Mr. Pelton:

KOMAN Government Solutions, LLC (KGS) is submitting this monthly monitoring report of the groundwater discharge and air emission results for the Groundwater Treatment Plant (GWTP) located at the Former Naval Weapons Industrial Reserve Plant (NWIRP), Bethpage, NY, GM-38 Area. This report was prepared in accordance with GWTP operational requirements for DER Site # 1-30-003B-OU 2, and the SPDES Permit Equivalent # 13003B.

GWTP operational data from 1 December to 31 December 2021 are presented in Attachment A. The plant was down for approximately 63 hours during the reporting period as the result intermittent power outages throughout weekend of 10-13 December 2021.

As indicated in Attachment A, all SPDES permitted constituents are in compliance with regulatory guidelines during this reporting period.

Please contact me at 610-400-0636 with any questions or concerns you may have regarding this report.

Sincerely,

KOMAN Government Solutions, LLC

Robert G. Gregory

Robert & Dryng

Project Manager

Attachment A: Groundwater and Air Sampling Results for December 2021

- cc: C. Haas, NYSDEC Region 1
  - C. Engelhardt, NYSDEC Region 1
  - J. Pilewski, NYSDEC Region 1 Water Engineer
  - J. Sullivan, NYSDOH
  - G. Ennis, Nassau County Department of Public Works
  - T. Licata, Town of Oyster Bay
  - M. Russo, Town of Oyster Bay
  - S. Sokolowski, NAVFAC Mid-Atlantic
  - V. Varricchio, NWIRP Bethpage Facilities Management
  - P. Schauble, KGS
  - GM-38 Copy

# ATTACHMENT A GROUNDWATER AND AIR SAMPLING RESULTS DECEMBER 2021

## GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Discharge Monitoring Report December 2021

SPDES Parameters			December 2021 <sup>(1)</sup>				
Process Stream	Daily Treated Effluent Maximum <sup>(1)</sup>	Units	RW-1	RW-3	RW-4	Combined Influent (RW-1 + RW-3 + RW- 4)	Treated Effluent
Well Depth	N/A	ft	445	530	655*	N/A	N/A
Screened Interval	N/A	ft bgs	335-395 410-430	392-412 442-504	550-650*	N/A	N/A
Sampling Date	N/A		12/3/21				
Effective Flowrate	1100	GPM	628	0	169	797	838
Total Flow	N/A	gallons	25,652,634	0	6,922,821	32,575,456	34,260,555
рН	5.5 - 8.5	SU	5.61	NS	6.27	5.75	7.14
Chloroform	5	μg/L	ND (0.90)	NS	ND (4.5)		ND (0.90)
1,1-Dichloroethane	5	μg/L	1.3	NS	ND (4.5)	1.02	ND (0.90)
1,2-Dichloroethane	0.6	μg/L	ND (0.75)	NS	ND (3.8)		ND (0.75)
1,1-Dichloroethene	5	μg/L	ND (0.75)	NS	ND (3.8)		ND (0.75)
cis 1,2-Dichloroethene	5	μg/L	3.9	NS	ND (3.8)	3.07	ND (0.75)
trans 1,2-Dichloroethene	5	μg/L	ND (0.90)	NS	ND (4.5)		ND (0.90)
Tetrachloroethene	5	μg/L	16.9	NS	4.9 J	14.35	ND (0.90)
1,1,1-Trichloroethane	5	μg/L	ND (0.90)	NS	ND (4.5)		ND (0.90)
Trichloroethene	5	μg/L	61.5	NS	654	187.4	ND (0.90)
1,1,2-Trichlorotrifluoroethane	5	μg/L	ND (1.5)	NS	ND (7.5)		ND (1.5)
Vinyl Chloride	2	μg/L	ND (0.90)	NS	ND (4.5)		ND (0.90)
1,4-Dioxane		μg/L	0.323	NS	1.74	0.62	ND (0.15)
Mercury	0.00025	mg/L	ND (0.00015)	NS	ND (0.00015)	ND (0.00015)	ND (0.00015)
Total Suspended Solids (TSS)	N/A	mg/L	ND (2.0)	NS	ND (2.0)	ND (2.0)	ND (2.0)

### Notes

- J Estimated result between laboratory method detection limit and reporting limit
- ${\rm ND} \cdot {\rm Not\ detected\ above\ laboratory\ method\ detection\ limit.\ Limit\ of\ Detection\ (LOD)\ given\ in\ parentheses.}$
- NR Not Recorded
- N/A Not Applicable
- NS Not Sampled
- -- LOD for non-detect combined well influent not applicable; RW-4 sample required dilution.
- (1) Wastewater discharge equivalence permit renewed on 18 August 2017. Discharge limits established for 10 years. Chloroform, 1,4-dioxane and 1,1,2-trichlorotrifluoroethane are now monitored under the new permit.
- \* Design depths

# GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Air Sampling Results December 2021

DAR Parameters	December 2021				
Process Stream	Units	Discharge Goal <sup>(1)</sup>	Influent	Effluent	
Sampling Date			12/3/21		
Average Flowrate	CFM	N/A	NR	9,133	
Total Flow	ft <sup>3</sup>	N/A	NR	373,222,906	
Total Flow	m <sup>3</sup>	N/A	NR	10,568,496	
1,2-Dichloroethane	μg/m³	N/A	1.7 J	ND	
cis 1,2-Dichloroethene	μg/m³	≤ 100,000 <sup>(2)</sup>	35	39	
trans 1,2-Dichloroethene	μg/m³	≤ 100,000 ` ′	ND	ND	
1,2-Dichloroethene (total)	μg/m³	≤ 100,000	35	39	
Toluene	μg/m³	N/A	0.63 J	ND	
Total Xylene	μg/m³	N/A	ND	ND	
1,1,2-Trichloroethane	μg/m³	N/A	1.6 J	ND	
Trichloroethene	μg/m³	≤ 2600	1800	ND	
Vinyl Chloride	μg/m³	≤ 560	ND	ND	
Tetrachloroethene	μg/m³	≤ 5100	180	ND	

## Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

J - Estimated result between laboratory method detection limit and reporting limit

N/A - Not Applicable

NR - Not recorded

- (1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.
- (2) Discharge goal is for total 1,2-Dichloroethene.

# GM-38 Area Groundwater Remediation Groundwater Treatment Plant Naval Weapons Industrial Reserve Plant - Bethpage, NY Controlled Stack Emissions December 2021

DAR Parameters	Units	Discharge Goal <sup>(1)</sup>	December 2021	
Sampling Date			12/3/21	
Average Flowrate	CFM	N/A	9,133	
Total Flow	ft <sup>3</sup>	N/A	373,222,906	
Total Flow	m <sup>3</sup>	N/A	10,568,496	
Trichloroethene	lb/hr	≤ 0.09	0.00000	
Vinyl Chloride	lb/hr	≤ 0.02	0.00000	
1,2 Dichloroethene	lb/hr	≤ 11	0.00122	
1,2-Dichloroethane	lb/hr	N/A	0.00000	
Toluene	lb/hr	N/A	0.00000	
Total Xylene	lb/hr	N/A	0.00000	
1,1,2-Trichloroethane	lb/hr	N/A	0.00000	
Tetrachloroethene	lb/hr	≤ 0.18	0.00000	

# Notes:

CFM - cubic feet per minute

DAR - Division of Air Resources

N/A - Not Applicable

(1) Discharge goal as approved by NYSDEC's letter dated 31 October 2013.