



6 May 2022

Mr. Scott Sokolowski
Remedial Project Manager
Naval Facilities Engineering Systems Command, Mid-Atlantic
9324 Virginia Avenue, Building Z-144
Norfolk, VA 23511-3095

**Subject: April 2022 Monthly Operating Report
Full Scale Liquid-Phase Granular Activated Carbon Treatment System
Liberty New York Water, Seamans Neck Road Water Plant
NWIRP Bethpage, New York
Contract No. N40085-16-D-2288, Task Order N4008518F5125**

Dear Mr. Sokolowski,

The Full Scale Liquid-Phase Granulated Activated Carbon (GAC) Treatment System is located at the Liberty New York Water (LNYW), Seamans Neck Road Water Treatment Plant in Levittown, NY. The GAC System was installed at the effluent of the potable water treatment plant and consists of six GAC vessels operating in parallel to remove low levels of trichloroethene (TCE) from Well No. 3S and Well No. 4S. After processing through the GAC units, the water is treated with sodium hypochlorite and sodium tripolyphosphate before distribution. Startup of the GAC Treatment System occurred on 8 January 2015 by CH2MHill. KOMAN Government Solutions, LLC (KGS) began operation and maintenance (O&M) activities in March 2015.

In May 2018, production Well No. 3S was decommissioned and has been replaced with a new production well designated as Well No. 3A. Well No. 4S is normally in operation during the entire month, while well No. 3A is operated infrequently, typically during the periods of higher water demand.

This report documents the routine operation and maintenance of the GAC System performed during the month of April 2022. **Attachment 1** presents the field logs detailing system operating data as recorded during the month. These readings include flow rate and total flows of the overall GAC System and each GAC unit, pressures across the GAC System, effluent chlorine residual and pH values, chemical usage levels of sodium hypochlorite and sodium tripolyphosphate for each chemical tank, and chemical metering pump settings and pressures.

Electricity use is no longer monitored and recorded using the Leviton Series 2000 Multiple Meter Unit. Summary energy consumption reports will be provided separately to the Navy representative.

A summary of the system operating data recorded in April 2022 is presented below in **Table 1**.


Table 1 - System Operating Data for April 2022

| Date | Total Flow (Gallons) | Flow Rate (GPM) | Influent Pressure (PSI) | Effluent Pressure (PSI) | Differential Pressure (PSI) | Effluent Chlorine Residual (mg/L) ⁽¹⁾ | Effluent pH (SU) ⁽¹⁾ |
|-----------|-------------------------|--------------------|----------------------------|----------------------------|--------------------------------|---|------------------------------------|
| 4/1/2022 | 7,501,473,000 | 2,100 | 68 | 65 | 3.5 | 1.49 read 1.48 manual | 6.80 read |
| 4/4/2022 | 7,510,423,000 | 2,050 | 64 | 64 | 3.4 | 1.43 read 1.41 manual | 6.80 read |
| 4/5/2022 | 7,513,377,000 | 2,050 | 69 | 66 | 3.6 | 1.46 read 1.45 manual | 6.80 read |
| 4/6/2022 | 7,516,350,000 | 2,150 | 63 | 59 | 3.8 | 1.37 read 1.36 manual | 6.90 read |
| 4/7/2022 | 7,519,206,000 | 2,100 | 64 | 61 | 3.9 | 1.44 read 1.43 manual | 6.80 read |
| 4/8/2022 | 7,521,817,000 | 2,000 | 63 | 60 | 3.9 | 1.54 read 1.53 manual | 7.00 read |
| 4/11/2022 | 7,530,683,000 | 2,050 | 70 | 66 | 3.9 | 1.44 read 1.42 manual | 6.90 read |
| 4/12/2022 | 7,533,683,000 | 2,050 | 70 | 66 | 4.0 | 1.59 read 1.56 manual | 6.90 read |
| 4/13/2022 | 7,536,267,000 | 2,100 | 64 | 60 | 4.1 | 1.57 read 1.55 manual | 6.70 read |
| 4/14/2022 | 7,539,975,000 | 2,150 | 67 | 63 | 4.3 | 1.58 read 1.57 manual | 6.60 read |
| 4/18/2022 | 7,550,943,000 | 2,150 | 69 | 65 | 4.4 | 1.59 read 1.57 manual | 6.50 read |
| 4/19/2022 | 7,553,915,000 | 2,200 | 67 | 62 | 4.6 | 1.57 read 1.55 manual | 6.60 read |
| 4/20/2022 | 7,555,972,000 | 2,150 | 68 | 63 | 4.7 | 1.59 read 1.58 manual | 6.80 read |
| 4/21/2022 | 7,560,174,000 | 2,200 | 69 | 65 | 4.8 | 1.63 read 1.64 manual | 6.50 read |
| 4/22/2022 | 7,562,824,000 | 2,200 | 56 | 51 | 4.8 | 1.53 read 1.51 manual | 6.60 read |
| 4/25/2022 | 7,571,442,000 | 2,250 | 56 | 51 | 5.0 | 1.41 read 1.40 manual | 6.50 read |
| 4/26/2022 | 7,574,334,000 | 2,025 | 76 | 72 | 4.7 | 1.62 read 1.60 manual | 6.30 read |
| 4/27/2022 | 7,577,227,000 | 2,000 | 75 | 70 | 4.8 | 1.73 read 1.71 manual | 6.40 read |
| 4/28/2022 | 7,579,802,000 | 2,000 | 73 | 68 | 4.8 | 1.60 read 1.60 manual | 6.50 read |
| 4/29/2022 | 7,582,710,000 | 1,900 | 82 | 77 | 4.8 | 1.90 read 1.88 manual | 6.45 manual |

⁽¹⁾ Effluent pH and chlorine residual readings are recorded by the in-line pH meter and chlorine analyzer. Chlorine is also checked with a manual chlorine residual meter for comparison, while manual pH is only checked occasionally. Both in-line and manual readings are presented, if collected, as noted above.

Figure 1, below, illustrates the volume of water treated by the GAC System since system startup, with the increment for the month of April 2022. Over 84.0 million gallons of water were treated in April 2022, bringing the total cumulative volume of water treated since startup to over 7.58 billion gallons.

Figure 1 - Volume of Water Treated through Full Scale GAC System (April 2022)




In general, differential pressure increases as the system continues to operate, and decreases after a backwashing event. The increasing trend then continues until the next backwashing event is performed. Also, lower differential pressures are observed during times of low water demand (e.g., typically over the winter months). **Figure 2**, below, depicts the pressure loss across the GAC System and subsequent backwashing dates, from May 2021 through the current reporting period.

Backwashing events during the summer and fall are performed more often because of the higher demand during that time of year. The exchange of carbon in each of the six GAC vessels with virgin coconut shell carbon was completed in August 2020 and the Seamans Neck Road facility is able to operate at full capacity. In support of the 2020 Fourth Quarter bacteria sampling conducted in December 2020, it was identified that each vessel required additional backwashing and/or flushing prior to returning to service to address a colored water issue attributable to the remobilization of iron-impacted materials released when flow through the vessels was stopped

for a mandatory 12-hour period prior to bacteria sampling, per NCDOH requirements. The additional backwashing/flushing events have been incorporated into the standard process for bacteria sampling.

The facility is operating at full design capacity and pressure loss across the overall GAC System is monitored regularly, and it is expected that backwashing events will occur on a periodic basis as needed. In addition, it is expected that backwashing of each vessel will be conducted following each quarterly bacteria sampling event to address potential colored water issues and to ensure the timely return to service for each vessel.

Figure 2 - System Differential Pressure vs. Time



System Maintenance

Routine maintenance of the GAC System during this reporting period consisted of:

- General monitoring of the system flow rates, totalized flows, influent and effluent pressures, differential pressure, chlorine residual, and pH readings.
- Changing paper for the chlorine/pH chart recorder and flow/differential pressure chart recorder on a weekly basis.
- Calibration of the pH meter on a weekly basis.

- Periodic running of Well 3A in place of or concurrently with Well 4S had previously been initiated by NYAW; Well 3A did not operate in April 2022.


In addition, the following non-routine activities or operation issues occurred during the April 2022 reporting period:

- 29 April – Replaced interior light bulbs within the plant.

Please contact me at 610-400-0636 or rgregory@komangs.com with any questions or concerns regarding this report.

Sincerely,

KOMAN Government Solutions, LLC



Robert G. Gregory
Project Manager

Cc: C. Shukis - NAVFAC
V. Varricchio - NWIRP Bethpage Facilities Management
R. Kern - LNYW
N. Niola – LNYW
J. Palmer - LNYW
P. Schauble - KGS
R. Hoffmaster – KGS
D. Brayack - Tetra Tech
J. Pelton – NYSDEC
K. Granzen – NYSDEC
M. Travis – NYSDEC

ATTACHMENT 1
O&M LOGS – APRIL 2022

Daily Readings
Granular Activated Carbon Treatment System

| Description | Date | 3-25-2022 | 3-28-2022 | 3-29-2022 | 3-30-2022 | 3-31-2022 | 4-1-2022 |
|--|-----------|------------|------------|------------|------------|------------|------------|
| System Flow Rate | GPM | 2100 | 2150 | 2000 | 2200 | 2050 | 2100 |
| Total System Flow | Gallons | 7565008 | 7573925 | 7576772 | 7579022 | 7582595 | 7585345 |
| Well 3 Status | ON OR OFF | OFF | OFF | OFF | OFF | OFF | OFF |
| Well 4 Status | ON OR OFF | ON | ON | ON | ON | ON | ON |
| Tank 100 Flow Rate | GPM | 250 | 225 | 250 | 250 | 250 | 250 |
| Tank 200 Flow Rate | GPM | 250 | 225 | 225 | 300 | 225 | 225 |
| Tank 300 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 400 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 500 Flow Rate | GPM | 350 | 400 | 350 | 400 | 350 | 350 |
| Tank 600 Flow Rate | GPM | 380 | 350 | 250 | 300 | 250 | 250 |
| Tank 100 Total Flow | Gallons | 36,098,000 | 37,328,000 | 37,711,000 | 38,135,000 | 38,514,000 | 38,804,000 |
| Tank 200 Total Flow | Gallons | 77,964,000 | 79,169,000 | 79,551,000 | 79,963,000 | 80,377,000 | 80,610,000 |
| Tank 300 Total Flow | Gallons | 54,658,000 | 56,224,000 | 56,919,000 | 57,231,000 | 57,737,000 | 58,210,000 |
| Tank 400 Total Flow | Gallons | 45,646,000 | 47,163,000 | 47,642,000 | 48,135,000 | 48,622,000 | 49,004,000 |
| Tank 500 Total Flow | Gallons | 65,757,000 | 67,406,000 | 67,928,000 | 68,491,000 | 68,998,000 | 69,414,000 |
| Tank 600 Total Flow | Gallons | 41,104,000 | 42,384,000 | 42,788,000 | 43,226,000 | 43,621,000 | 43,906,000 |
| System Influent Pressure | PSI | 60 | 55 | 69 | 55 | 69 | 68 |
| System Effluent Pressure | PSI | 57 | 51 | 65 | 52 | 66 | 65 |
| System Differential Pressure | PSI | 3.1 | 3.5 | 3.4 | 3.4 | 3.4 | 3.5 |
| Chlorine Analyzer: Free Chlorine Residual - Inline | PPM | 1.67 | 1.64 | 1.67 | 1.41 | 1.45 | 1.49 |
| Effluent Water pH - Inline | Units | 6.80 | 6.75 | 6.60 | 6.80 | 6.80 | 6.80 |
| Manual Chlorine Reading (ex: Hach DR) | PPM | 1.65 | 1.64 | 1.66 | 1.41 | 1.44 | 1.48 |
| Manual pH check (ex: Hanna) | Units | | | | | | |

**Daily Readings
Granular Activated Carbon Treatment System**

| Description | Date | 3-25-2022 | 3-28-2022 | 3-29-2022 | 3-30-2022 | 3-31-2022 | 4-1-2022 |
|--|---------|-----------|-------------|-----------|-----------|-----------|----------|
| Tank 000A Hypochlorite Level | Gallons | 105 | 139 | 98 | 62 | 140 | 121 |
| Tank 000B Hypochlorite Level | Gallons | 145 | 80 | 86 | 90 | 145 | 140 |
| Tank 000C Hypochlorite Level | Gallons | 147 | 50 | 50 | 50 | 150 | 150 |
| Tank 000A Polyphosphate Level | Gallons | 60 | 130 | 99 | 78 | 61 | 43 |
| Tank 000B Polyphosphate Level | Gallons | 57 | 160 | 166 | 160 | 160 | 160 |
| Metering Pump 000A: Hypochlorite Output Pressure | PSI | | | | | | |
| Metering Pump 000B: Hypochlorite Output Pressure | PSI | | | | | | |
| Metering Pump 000A: Phosphate Output Pressure | PSI | | | | | | |
| Metering Pump 000B: Phosphate Output Pressure | PSI | | | | | | |
| Metering Pump 000A: Strokes/Speed | Units | | | | | | |
| Metering Pump 000B: Strokes/Speed | Units | | | | | | |
| Metering Pump 000A: Strokes/Speed | Units | | | | | | |
| Metering Pump 000B: Strokes/Speed | Units | | | | | | |
| Generator Operating Hours | Hours | 173.4 | 173.4 | 173.4 | 173.4 | 173.4 | 173.4 |
| Main Facility Electric Meter Reading | | | | | | | |
| Comments (additional tasks performed, maintenance needed, contractors on site, etc.) | | | Phos. D-lv. | | | | |
| | | | | | | | |

Daily Readings
Granular Activated Carbon Treatment System

| Description | Date | 4.4.2022 | 4.5.2022 | 4.6.2022 | 4.7.2022 | 4.8.2022 | 4.11.2022 |
|--|-----------|------------|------------|------------|------------|------------|------------|
| System Flow Rate | GPM | 2050 | 2050 | 2150 | 2100 | 2000 | 2050 |
| Total System Flow | Gallons | 7594295 | 7597249 | 7606222 | 7603078 | 7605689 | 7614555 |
| Well 3 Status | ON OR OFF | OFF | OFF | OFF | OFF | OFF | OFF |
| Well 4 Status | ON OR OFF | ON | ON | ON | ON | ON | ON |
| Tank 100 Flow Rate | GPM | 250 | 250 | 300 | 250 | 300 | 250 |
| Tank 200 Flow Rate | GPM | 250 | 250 | 300 | 300 | 250 | 250 |
| Tank 300 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 400 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 500 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 600 Flow Rate | GPM | 250 | 300 | 250 | 250 | 250 | 250 |
| Tank 100 Total Flow | Gallons | 46,187,000 | 40,534,000 | 40,931,000 | 41,271,000 | 41,675,000 | 42,904,000 |
| Tank 200 Total Flow | Gallons | 81,922,000 | 82,322,000 | 82,721,000 | 83,007,000 | 83,460,000 | 84,660,000 |
| Tank 300 Total Flow | Gallons | 59,794,000 | 60,213,000 | 60,830,000 | 61,409,000 | 61,780,000 | 63,357,000 |
| Tank 400 Total Flow | Gallons | 50,588,000 | 51,075,000 | 51,571,000 | 52,111,000 | 52,490,000 | 53,967,000 |
| Tank 500 Total Flow | Gallons | 71,158,000 | 71,694,000 | 72,249,000 | 72,781,000 | 73,244,000 | 74,879,000 |
| Tank 600 Total Flow | Gallons | 45,296,000 | 45,718,000 | 46,140,000 | 46,558,000 | 46,870,000 | 48,189,000 |
| System Influent Pressure | PSI | 64 | 69 | 63 | 64 | 63 | 70 |
| System Effluent Pressure | PSI | 64 | 66 | 59 | 61 | 60 | 66 |
| System Differential Pressure | PSI | 3.4 | 3.6 | 3.8 | 3.9 | 3.9 | 3.9 |
| Chlorine Analyzer: Free Chlorine Residual - inline | PPM | 1.43 | 1.46 | 1.37 | 1.44 | 1.54 | 1.44 |
| Effluent Water pH - inline | Units | 6.8 | 6.8 | 6.9 | 6.8 | 7.0 | 6.9 |
| Manual Chlorine Reading (ex: Hach Kit) | PPM | 1.41 | 1.45 | 1.36 | 1.43 | 1.53 | 1.42 |
| Manual pH check (ex: Hanna) | Units | | | | | | |

Daily Readings
Granular Activated Carbon Treatment System

| Description | Date | 4.4.2022 | 4.5.2022 | 4.6.2022 | 4.7.2022 | 4.8.2022 | 4.11.2022 |
|---|---------|----------|----------|-------------|----------|----------------------------------|-----------|
| Tank 008A Hypochlorite Level | Gallons | 20 | 15 | 15 | 145 | 135 | 20 |
| Tank 008B Hypochlorite Level | Gallons | 146 | 105 | 73 | 145 | 105 | 120 |
| Tank 008C Hypochlorite Level | Gallons | 150 | 150 | 143 | 143 | 145 | 140 |
| Tank 008A Phosphate Level | Gallons | 76 | 52 | 145 | 122 | 109 | 57 |
| Tank 008B Phosphate Level | Gallons | 160 | 160 | 160 | 160 | 160 | 160 |
| Metering Pump 008A: Hypochlorite Output Pressure | PSI | | | | | | |
| Metering Pump 008B: Hypochlorite Output Pressure | PSI | | | | | | |
| Metering Pump 008A: Phosphate Output Pressure | PSI | | | | | | |
| Metering Pump 008B: Phosphate Output Pressure | PSI | | | | | | |
| Metering Pump 008A: Stroke/Speed | Units | | | | | | |
| Metering Pump 008B: Stroke/Speed | Units | | | | | | |
| Metering Pump 008A: Stroke/Speed | Units | | | | | | |
| Metering Pump 008B: Stroke/Speed | Units | | | | | | |
| Generator Operating Hours | Hours | 173.8 | 173.8 | 173.8 | 173.8 | 174.2 | 174.2 |
| Main Facility Electric Meter Reading | | | | | | | |
| Comments (additional tasks performed, maintenance needed, contractors on site, etc.) | | | | Phos. Delu. | | Monthly 1,4 / POC Sampling | |
| | | | | | | | |

Daily Readings
Granular Activated Carbon Treatment System

| Description | Date | 4-12-2022 | 4-13-2022 | 4-14-2022 | 4-18-2022 | 4-19-2022 | 4-20-2022 |
|--|-----------|------------|------------|------------|------------|------------|------------|
| System Flow Rate | GPM | 2050 | 2100 | 2150 | 2150 | 2200 | 2150 |
| Total System Flow | Gallons | 7617555 | 7620139 | 7623847 | 7634815 | 7637787 | 7639844 |
| Well 3 Status | ON OR OFF | OFF | OFF | OFF | OFF | OFF | OFF |
| Well 4 Status | ON OR OFF | ON | ON | ON | ON | ON | ON |
| Tank 100 Flow Rate | GPM | 250 | 250 | 250 | 250 | 250 | 250 |
| Tank 200 Flow Rate | GPM | 250 | 250 | 300 | 300 | 300 | 300 |
| Tank 300 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 400 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 500 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 600 Flow Rate | GPM | 250 | 300 | 200 | 250 | 300 | 300 |
| Tank 100 Total Flow | Gallons | 43,324,000 | 43,691,000 | 44,171,000 | 51,748,000 | 55,071,000 | 55,311,000 |
| Tank 200 Total Flow | Gallons | 85,065,000 | 85,418,000 | 85,911,000 | 87,408,000 | 87,793,000 | 88,087,000 |
| Tank 300 Total Flow | Gallons | 83,885,000 | 64,351,000 | 64,721,000 | 66,939,000 | 67,428,000 | 67,809,000 |
| Tank 400 Total Flow | Gallons | 54,468,000 | 54,898,000 | 55,287,000 | 57,327,000 | 57,510,000 | 57,897,000 |
| Tank 500 Total Flow | Gallons | 75,430,000 | 75,910,000 | 76,410,000 | 78,618,000 | 79,148,000 | 79,501,000 |
| Tank 600 Total Flow | Gallons | 48,618,000 | 48,997,000 | 49,297,000 | 51,090,000 | 51,311,000 | 51,601,000 |
| System Influent Pressure | PSI | 70 | 64 | 67 | 69 | 67 | 68 |
| System Effluent Pressure | PSI | 66 | 60 | 63 | 65 | 62 | 63 |
| System Differential Pressure | PSI | 4.0 | 4.1 | 4.3 | 4.4 | 4.6 | 4.7 |
| Chlorine Analyzer: Free Chlorine Residual - Inline | PPM | 1.59 | 1.57 | 1.58 | 1.59 | 1.57 | 1.59 |
| Effluent Water pH - Inline | Units | 6.90 | 6.7 | 6.6 | 6.5 | 6.6 | 6.8 |
| Manual Chlorine Reading (ex: Hach Kit) | PPM | 1.56 | 1.55 | 1.57 | 1.57 | 1.55 | 1.58 |
| Manual pH check (ex: Hanna) | Units | | | | | | |

**Daily Readings
Granular Activated Carbon Treatment System**

| Description | Date | 4.12.2022 | 4.13.2022 | 4.14.2022 | 4.18.2022 | 4.19.2022 | 4.20.2022 |
|--|---------|-------------|-----------|-----------|-----------|-----------|-------------|
| Tank 800A Hypochlorite Level | Gallons | 120 | 92 | 145 | 71 | 53 | 31 |
| Tank 800B Hypochlorite Level | Gallons | 120 | 120 | 145 | 95 | 90 | 82 |
| Tank 800C Hypochlorite Level | Gallons | 10 | 10 | 145 | 145 | 145 | 140 |
| Tank 800A Polyphosphate Level | Gallons | 148 | 131 | 114 | 82 | 61 | 150 |
| Tank 800B Polyphosphate Level | Gallons | 160 | 160 | 160 | 142 | 142 | 142 |
| Metering Pump 800A: Hypochlorite Output Pressure | PSI | | | | | | |
| Metering Pump 800B: Hypochlorite Output Pressure | PSI | | | | | | |
| Metering Pump 800A: Phosphate Output Pressure | PSI | | | | | | |
| Metering Pump 800B: Phosphate Output Pressure | PSI | | | | | | |
| Metering Pump 800A: Stroke/Speed | Units | | | | | | |
| Metering Pump 800B: Stroke/Speed | Units | | | | | | |
| Metering Pump 800A: Stroke/Speed | Units | | | | | | |
| Metering Pump 800B: Stroke/Speed | Units | | | | | | |
| Generator Operating Hours | Hours | 174.2 | 174.2 | 174.5 | 174.5 | 174.5 | 174.5 |
| Main Facility Electric Meter Reading | | | | | | | |
| Comments (additional tests performed, maintenance needed, contractors on site, etc.) | | Phos. Delv. | | Cl Delv. | | | Phos. Delv. |
| | | | | | | | |

Daily Readings
Granular Activated Carbon Treatment System

| Description | Date | 4-21-2022 | 4-22-2022 | 4-25-2022 | 4-26-2022 | 4-27-2022 | 4-28-2022 |
|--|-----------|------------|------------|------------|------------|------------|------------|
| System Flow Rate | GPM | 2200 | 2200 | 2250 | 2025 | 2000 | 2000 |
| Total System Flow | Gallons | 7644046 | 7646696 | 7655314 | 7658206 | 7661099 | 7663674 |
| Well 3 Status | ON OR OFF | OFF | OFF | OFF | OFF | OFF | |
| Well 4 Status | ON OR OFF | ON | ON | ON | ON | ON | |
| Tank 100 Flow Rate | GPM | 300 | 300 | 300 | 300 | 300 | 250 |
| Tank 200 Flow Rate | GPM | 300 | 300 | 300 | 300 | 250 | 250 |
| Tank 300 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 400 Flow Rate | GPM | 350 | 350 | 350 | 350 | 350 | 350 |
| Tank 500 Flow Rate | GPM | 350 | 300 | 200 | 350 | 350 | 350 |
| Tank 600 Flow Rate | GPM | 300 | 300 | 300 | 250 | 250 | 250 |
| Tank 100 Total Flow | Gallons | 47,036,000 | 47,390,000 | 48,589,000 | 49,004,000 | 49,408,000 | 49,767,000 |
| Tank 200 Total Flow | Gallons | 58,561,000 | 59,004,000 | 60,180,000 | 60,584,000 | 60,891,000 | 61,333,000 |
| Tank 300 Total Flow | Gallons | 68,461,000 | 69,009,000 | 70,524,000 | 71,046,000 | 71,555,000 | 72,000,000 |
| Tank 400 Total Flow | Gallons | 58,621,000 | 59,276,000 | 60,690,000 | 61,181,000 | 61,668,000 | 62,098,000 |
| Tank 500 Total Flow | Gallons | 80,319,000 | 80,789,000 | 82,389,000 | 82,931,000 | 83,468,000 | 83,944,000 |
| Tank 600 Total Flow | Gallons | 51,908,000 | 52,774,000 | 54,011,000 | 54,436,000 | 54,858,000 | 55,221,000 |
| System Influent Pressure | PSI | 69 | 56 | 56 | 76 | 75 | 73 |
| System Effluent Pressure | PSI | 65 | 51 | 51 | 72 | 70 | 68 |
| System Differential Pressure | PSI | 4.8 | 4.8 | 5.0 | 4.7 | 4.8 | 4.8 |
| Chlorine Analyzer: Free Chlorine Residual - inline | PPM | 1.63 | 1.53 | 1.41 | 1.62 | 1.73 | 1.60 |
| Effluent Water pH - inline | Units | 6.5 | 6.6 | 6.50 | 6.30 | 6.4 | 6.5 |
| Manual Chlorine Reading (ex: Hach Kit) | PPM | 1.64 | 1.51 | 1.40 | 1.60 | 1.71 | 1.60 |
| Manual pH check (ex: Hanna) | Units | | | | | | |

Daily Readings
Granular Activated Carbon Treatment System

| Description | Date | 4-21-2022 | 4-22-2022 | 4-25-2022 | 4-26-2022 | 4-27-2022 | 4-28-2022 |
|---|---------|-----------|------------------------|-----------|-----------|-----------|-----------|
| Tank 800A Hypochlorite Level | Gallons | 145 | 138 | 140 | 100 | 61 | 143 |
| Tank 800B Hypochlorite Level | Gallons | 145 | 136 | 140 | 140 | 140 | 143 |
| Tank 800C Hypochlorite Level | Gallons | 145 | 145 | 30 | 30 | 30 | 145 |
| Tank 800A Polyphosphate Level | Gallons | 123 | 111 | 140 | 123 | 105 | 90 |
| Tank 800B Polyphosphate Level | Gallons | 142 | 142 | 142 | 142 | 142 | 142 |
| Metering Pump 800A: Hypochlorite Output Pressure | PSI | | | | | | |
| Metering Pump 800B: Hypochlorite Output Pressure | PSI | | | | | | |
| Metering Pump 800A: Phosphate Output Pressure | PSI | | | | | | |
| Metering Pump 800B: Phosphate Output Pressure | PSI | | | | | | |
| Metering Pump 800A: Strokes/Speed | Units | | | | | | |
| Metering Pump 800B: Strokes/Speed | Units | | | | | | |
| Metering Pump 800A: Strokes/Speed | Units | | | | | | |
| Metering Pump 800B: Strokes/Speed | Units | | | | | | |
| Generator Operating Hours | Hours | 174.2 | 175.6 | 174.6 | 174.6 | 174.6 | 174.6 |
| Main Facility Electric Meter Reading | | | | | | | |
| Comments (additional tasks performed, maintenance needed, contractors on site, etc.) | | Cl Delv. | Change flow/PIF charts | Phos Delv | | | |

Daily Readings
Granular Activated Carbon Treatment System

| Description | Date | | | | | |
|--|-----------|------------|--|--|--|--|
| | | 4.29.2022 | | | | |
| System Flow Rate | GPM | 1900 | | | | |
| Total System Flow | Gallons | 7666582 | | | | |
| Well 3 Status | ON OR OFF | OFF | | | | |
| Well 4 Status | ON OR OFF | ON | | | | |
| Tank 100 Flow Rate | GPM | 250 | | | | |
| Tank 200 Flow Rate | GPM | 250 | | | | |
| Tank 300 Flow Rate | GPM | 350 | | | | |
| Tank 400 Flow Rate | GPM | 350 | | | | |
| Tank 500 Flow Rate | GPM | 350 | | | | |
| Tank 600 Flow Rate | GPM | 250 | | | | |
| Tank 100 Total Flow | Gallons | 50,164,000 | | | | |
| Tank 200 Total Flow | Gallons | 91,725,000 | | | | |
| Tank 300 Total Flow | Gallons | 72,510,000 | | | | |
| Tank 400 Total Flow | Gallons | 62,568,000 | | | | |
| Tank 500 Total Flow | Gallons | 84,478,000 | | | | |
| Tank 600 Total Flow | Gallons | 55,675,000 | | | | |
| System Influent Pressure | PSI | 82 | | | | |
| System Effluent Pressure | PSI | 77 | | | | |
| System Differential Pressure | PSI | 4.8 | | | | |
| Chlorine Analyzer: Free Chlorine Residual - inline | PPM | 1.90 | | | | |
| Effluent Water pH - inline | Units | | | | | |
| Manual Chlorine Reading (ex: Hach DO) | PPM | 6.45 | | | | |
| Manual pH check (ex: Hanna) | Units | 1.88 | | | | |

**Daily Readings
Granular Activated Carbon Treatment System**

| Description | Date | | | | | |
|---|---------|--|--|--|--|--|
| | | 4/29/2022 | | | | |
| Tank 880A Hypochlorite Level | Gallons | 121 | | | | |
| Tank 880B Hypochlorite Level | Gallons | 143 | | | | |
| Tank 880C Hypochlorite Level | Gallons | 145 | | | | |
| Tank 880A Polyphosphate Level | Gallons | 72 | | | | |
| Tank 880B Polyphosphate Level | Gallons | 142 | | | | |
| Metering Pump 880A: Hypochlorite Output Pressure | PSI | | | | | |
| Metering Pump 880B: Hypochlorite Output Pressure | PSI | | | | | |
| Metering Pump 880A: Phosphate Output Pressure | PSI | | | | | |
| Metering Pump 880B: Phosphate Output Pressure | PSI | | | | | |
| Metering Pump 880A: Strokes/Speed | Units | | | | | |
| Metering Pump 880B: Strokes/Speed | Units | | | | | |
| Metering Pump 880A: Strokes/Speed | Units | | | | | |
| Metering Pump 880B: Strokes/Speed | Units | | | | | |
| Generator Operating Hours | Hours | 174.9 | | | | |
| Main Facility Electric Meter Reading | | | | | | |
| Comments (additional tests performed, maintenance needed, contractors on site, etc.) | | Change flow / PH charts change light bulbs | | | | |