




**COUNTY OF NASSAU
DEPARTMENT OF PUBLIC WORKS
1194 PROSPECT AVENUE
WESTBURY, NEW YORK 11590-2723**

May 21, 2008



New York State Department of
Environmental Conservation
Division of Environmental Remediation
Bureau of Hazardous Site Control
625 Broadway
Albany, New York 12233

Attn: Cynthia Whitfield, P.E.
Environmental Engineer II

Re: Monthly Effluent Monitoring Reports 2007
Nassau County Mitchel Field Remedial Action
(AKA Purex), Site #1-30-014

Gentlemen:

Attached are the 2007 Monthly Effluent Monitoring Reports for the groundwater remediation at the Purex Mitchel Field Remedial Action in Garden City, New York.

If you have any questions concerning the monthly monitoring reports, please contact Mr. Joseph Walker, Assistant Superintendent of Water Supply at (516) 571-6983.

Very truly yours,

A handwritten signature in cursive script, appearing to read "Kenneth G. Arnold".

Kenneth G. Arnold
Sanitary Engineer IV

KGA:JNW:
Attachments

c: Joseph L. Davenport, Deputy Commissioner
Kenneth G. Arnold, Sanitary Engineer IV
William Spitz, Region 1, NYSDEC

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

JANUARY 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMP'T MDL	WEEK 1 1/2/07	WEEK 2 01/09/07	WEEK 3 01/16/07	WEEK 4 01/23/07	WEEK 5 01/30/07
FLOW, DAILY MAX	MONITOR	GPD	NA					
pH	6.5-8.5	SU		5.72	6.53	7.32	7.08	6.69
TOTAL AGG CONC #1	4.7	µ g/l						
TOTAL AGG CONC #2	2	µ g/l						
TOTAL AGG CONC #3	50	µ g/l						
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	7.80	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	BDL	3.40	B 2.60	4.40	B 5.30
TETRACHLOROETHENE	0.5	µ g/l	1.2	BDL	1.50	6.20	BDL	BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	1.70	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	4.40	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	BDL	2.30	BDL	BDL	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0.0	7.80	7.20	B 14.90	4.40	B 5.30

B - Analyte detected in the associated Method Blank

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

FEBRUARY 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1 2/6/07	WEEK 2 02/13/07	WEEK 3 02/20/07	WEEK 4 02/27/07
FLOW, DAILY MAX	MONITOR	GPD	NA				
pH	6.5-8.5	SU		6.86	6.85	6.65	6.59
TOTAL AGG CONC #1	4.7	µ g/l					
TOTAL AGG CONC #2	2	µ g/l					
TOTAL AGG CONC #3	50	µ g/l					
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	5.7	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	3.8	7.8	5.4	6.3
TETRACHLOROETHENE	0.5	µ g/l	1.2	BDL	52.0	BDL	BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	2.5	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	20.0	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	BDL	46.0	BDL	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0.0	3.8	134.0	5.4	6.3

B - Analyte detected in the associated Method Blank

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

MARCH 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMP'T MDL	WEEK 1 3/6/07	WEEK 2 03/13/07	WEEK 3 03/20/07	WEEK 4 03/27/07
FLOW, DAILY MAX	MONITOR	GPD	NA				
pH	6.5-8.5	SU		6.92	6.69	7.04	7.00
TOTAL AGG CONC #1	4.7	µ g/l					
TOTAL AGG CONC #2	2	µ g/l					
TOTAL AGG CONC #3	50	µ g/l					
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
TETRACHLOROETHENE	0.5	µ g/l	1.2	BDL	BDL	BDL	BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	BDL	BDL	BDL	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0.0	0.00	0.00	0.00	0.00

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

APRIL 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMP'T MDL	WEEK 1 4/2/07	WEEK 2 04/10/07	WEEK 3 04/17/07	WEEK 4 04/24/07
FLOW, DAILY MAX	MONITOR	GPD	NA				
pH	6.5-8.5	SU		6.86	7.17	6.89	6.98
TOTAL AGG CONC #1	4.7	µ g/l					
TOTAL AGG CONC #2	2	µ g/l					
TOTAL AGG CONC #3	50	µ g/l					
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	1.2
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	BDL	BDL	4.9	4.7
TETRACHLOROETHENE	0.5	µ g/l	1.2	BDL	BDL		1.2
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	BDL	BDL	0.8	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0.0	0.0	0.0	5.7	7.1

B - Analyte detected in the associated Method Blank

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

MAY 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1 5/1/07	WEEK 2 05/08/07	WEEK 3 05/15/07	WEEK 4 05/22/07	WEEK 5 05/29/07
FLOW, DAILY MAX	MONITOR	GPD	NA					
pH	6.5-8.5	SU		7.10	6.63	7.59	6.78	6.68
TOTAL AGG CONC #1	4.7	µ g/l						
TOTAL AGG CONC #2	2	µ g/l						
TOTAL AGG CONC #3	50	µ g/l						
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	5.40	13.00	BDL	2.10	3.80
TETRACHLOROETHENE	0.5	µ g/l	1.2	0.91	0.97	BDL	BDL	BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	BDL	0.84	BDL	BDL	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0.0	6.31	14.81	0.00	2.10	3.80

B - Analyte detected in the associated Method Blank

J - Analyte detected below quantitaion limits

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

JUNE 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1 6/5/07	WEEK 2 06/12/07	WEEK 3 06/19/07	WEEK 4 06/26/07
FLOW, DAILY MAX	MONITOR	GPD	NA				
pH	6.5-8.5	SU		6.66	6.65	6.49	6.70
TOTAL AGG CONC #1	4.7	µ g/l					
TOTAL AGG CONC #2	2	µ g/l					
TOTAL AGG CONC #3	50	µ g/l					
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	6.50 B	11.00 B	BDL	7.10 B
TETRACHLOROETHENE	0.5	µ g/l	1.2	1.20	BDL	1.70	BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	1.10	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	0.77 J	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	0.81 J	BDL	2.10	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0.0	9.61 B	11.00 B	4.57	7.10 B

B - Analyte detected in the associated Method Blank

J - Analyte detected below quantitaion limits

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

JULY 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMP'T MDL	WEEK 1 7/3/07	WEEK 2 07/09/07	WEEK 3 07/16/07	WEEK 4 07/23/07	WEEK 5 07/30/07
FLOW, DAILY MAX	MONITOR	GPD	NA					
pH	6.5-8.5	SU		6.45	6.60	6.39	6.48	6.90
TOTAL AGG CONC #1	4.7	µ g/l						
TOTAL AGG CONC #2	2	µ g/l						
TOTAL AGG CONC #3	50	µ g/l						
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	4.70	20.00	14.00	3.30	6.60
TETRACHLOROETHENE	0.5	µ g/l	1.2	1.10	BDL	BDL	BDL	BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	1.40	BDL	BDL	BDL	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0.0	7.20	20.00	14.00	3.30	6.60

B - Analyte detected in the associated Method Blank

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

AUGUST 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1 8/6/07	WEEK 2 08/13/07	WEEK 3 08/20/07	WEEK 4 08/27/07
FLOW, DAILY MAX	MONITOR	GPD	NA				
pH	6.5-8.5	SU		7.30	6.76	7.00	6.83
TOTAL AGG CONC #1	4.7	µ g/l					
TOTAL AGG CONC #2	2	µ g/l					
TOTAL AGG CONC #3	50	µ g/l					
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	8.70	BDL	6.80	6.10
TETRACHLOROETHENE	0.5	µ g/l	1.2	0.98	BDL	0.60	BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	0.78	BDL	0.87	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0.0	10.46	0.00	8.27	6.10

B - Analyte detected in the associated Method Blank

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

SEPTEMBER 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMP'T MDL	WEEK 1 9/3/07	WEEK 2 09/10/07	WEEK 3 09/17/07	WEEK 4 09/24/07
FLOW, DAILY MAX	MONITOR	GPD	NA				
pH	6.5-8.5	SU		6.74	6.56	6.95	7.14
TOTAL AGG CONC #1	4.7	µ g/l					
TOTAL AGG CONC #2	2	µ g/l					
TOTAL AGG CONC #3	50	µ g/l					
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	7.80	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	7.50	BDL	8.50	BDL
TETRACHLOROETHENE	0.5	µ g/l	1.2	1.20	BDL	0.76	BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	1.20	BDL	0.74	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0.0	17.70	0.00	10.00	0.00

B - Analyte detected in the associated Method Blank

J - Analyte detected below quantitaion limits

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

OCTOBER 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMP'T MDL	WEEK 1 10/1/07	WEEK 2 10/08/07	WEEK 3 10/15/07	WEEK 4 10/22/07	WEEK 5 10/29/07				
FLOW, DAILY MAX	MONITOR	GPD	NA									
pH	6.5-8.5	SU		7.52	7.62	7.51	7.42	7.28				
TOTAL AGG CONC #1	4.7	µ g/l										
TOTAL AGG CONC #2	2	µ g/l										
TOTAL AGG CONC #3	50	µ g/l										
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL				
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL				
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL				
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL				
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL				
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL				
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL				
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL				
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL				
METHYLENE CHLORIDE	5	µ g/l	1.0	BDL	6.30	B	2.20	B	1.10	B		
TETRACHLOROETHENE	0.5	µ g/l	1.2	BDL	BDL	BDL	0.52	J	BDL			
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL	BDL			
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL	BDL			
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL	BDL			
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL	BDL	BDL			
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL	BDL			
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL	BDL			
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL	BDL	BDL			
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL	BDL			
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL	BDL			
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL	BDL			
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL	BDL			
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL	BDL			
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL	BDL			
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL	BDL			
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL	BDL			
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL	BDL			
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL	BDL			
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	BDL	BDL	BDL	BDL			
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	BDL	2.90	11.00	1.00	BDL	BDL			
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL	BDL	BDL			
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL	BDL			
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL	BDL	BDL			
TOTAL VOCs	100	µ g/l	0.0	0.00	9.20	B	13.20	B	1.52	B	1.10	B

B - Analyte detected in the associated Method Blank

J - Analyte detected below quantitaion limits

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

NOVEMBER 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMP'T MDL	WEEK 1 11/5/07	WEEK 2 11/12/07	WEEK 3 11/19/07	WEEK 4 11/26/07	WEEK 5
FLOW, DAILY MAX	MONITOR	GPD	NA					
pH	6.5-8.5	SU		7.45	7.48	7.26	7.35	
TOTAL AGG CONC #1	4.7	µ g/l						
TOTAL AGG CONC #2	2	µ g/l						
TOTAL AGG CONC #3	50	µ g/l						
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL	
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL	
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL	
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL	
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL	
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	
METHYLENE CHLORIDE	5	µ g/l	1.0	BDL	2.10	B 2.00	BDL	
TETRACHLOROETHENE	0.5	µ g/l	1.2	2.90	3.10	1.30	3.50	
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL	
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL	
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL	
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL	
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL	
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL	
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL	
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL	
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL	
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL	
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	
TRICHLOROETHENE	10	µ g/l	0.6	2.10	2.20	0.92	J 5.00	
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	15.00	18.00	8.70	55.00	
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL	
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL	
TOTAL VOCs	100	µ g/l	0.0	20.00	25.40	B 12.92	63.50	0.00

B - Analyte detected in the associated Method Blank

*STRIPPER TOWERS ARE DUE FOR ACID WASHING

J - Analyte detected below quantitaion limits

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
MONTHLY EFFLUENT MONITORING REPORT

DECEMBER 2007
OUTFALL 001G

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1* 12/3/07	WEEK 2 **	WEEK 3 **	WEEK 4 12/24/07
FLOW, DAILY MAX	MONITOR	GPD	NA				
pH	6.5-8.5	su		7.24			7.27
TOTAL AGG CONC #1	4.7	µ g/l					
TOTAL AGG CONC #2	2	µ g/l					
TOTAL AGG CONC #3	50	µ g/l					
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL			BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL			BDL
BROMOFORM	50	µ g/l	0.7	BDL			BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL			BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL			BDL
TOLUENE	5	µ g/l	1.2	BDL			BDL
BENZENE	0.7	µ g/l	0.7	BDL			BDL
CHLOROBENZENE	5	µ g/l	1.2	0.93 J			BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL			BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	BDL			2.10 B
TETRACHLOROETHENE	0.5	µ g/l	1.2	2.70			BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL			BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL			BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL			BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL			BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL			BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL			BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL			BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL			BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL			BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL			BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL			BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL			BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL			BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL			BDL
m,p-XYLENE	5	µ g/l	2.4	BDL			BDL
BROMOMETHANE	5	µ g/l	2.4	BDL			BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL			BDL
TRICHLOROETHENE	10	µ g/l	0.6	3.10			BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	19.00			2.20
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL			BDL
o-XYLENE	5	µ g/l	1.3	BDL			BDL
CHLOROETHANE	5	µ g/l	1.6	BDL			BDL
TOTAL VOCs	100	µ g/l	0.0	25.73	0.00	0.00	4.30 B

B - Analyte detected in the associated Method Blank

J - Analyte detected below quantitaion limits

*STRIPPER TOWERS ARE SCHEDULED FOR ACID WASHING

**PLANT SHUT DOWN FOR STRIPPER TOWER ACID WASHING