


EDWARD P. MANGANO
COUNTY EXECUTIVE



SHILA SHAH-GAVNOUDIAS, P.E.
COMMISSIONER

**COUNTY OF NASSAU
DEPARTMENT OF PUBLIC WORKS**
1194 PROSPECT AVENUE
WESTBURY, NEW YORK 11590-2723

September 10, 2010



New York State Department of
Environmental Conservation
Division of Environmental Remediation
Bureau of Hazardous Site Control
625 Broadway
Albany, New York 12233

Att: Cynthia Whitfield, P.E.
Environmental Engineer II

Re: Monthly Effluent Monitoring Reports 2010
Nassau County Mitchel Field Remedial Action
(AKA Purex), Site # 1-30-014

Ladies and Gentlemen:

Attached is the August 2010 Monthly Effluent Monitoring Report for the groundwater remediation at the Purex Mitchel Field Remedial Action in Garden City, New York.

If you have any questions concerning the monthly monitoring report, please contact Mr. Michael Flaherty, Hydrogeologist III, at (516) 571-7514.

Very truly yours,

Joseph L. Davenport, P.E.
Chief Sanitary Engineer
Unit Head, Water/Wastewater Engineering Unit

JLD:cs
Attachment

c: Kenneth G. Arnold, Assistant to Commissioner of Public Works
Joseph N. Walker, Assistant Superintendent of Water Supply
Michael Flaherty, Hydrogeologist III
William Spitz, Region 1, NYSDEC

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION
 MONTHLY EFFLUENT MONITORING REPORT

AUGUST 2010

OUTFALL 001G

| EFFLUENT PARAMETER | DISCHARGE LIMITATIONS | UNITS | COMPT MDL | WEEK 1 8/2/2010 | WEEK 2 8/9/2010 | WEEK 3 8/16/2010 | WEEK 4 8/23/2010 | WEEK 5 8/30/2010 |
|---------------------------------------|-----------------------|-------|-----------|-----------------|-----------------|------------------|------------------|------------------|
| FLOW, DAILY MAX | MONITOR | GPD | NA | 488,300 | 487,800 | 487,467 | 483,800 | 481,800 |
| pH | 6.5-8.5 | su | | 6.86 H | 7.20 H | 6.85 | 6.89 H | 7.13 H |
| TOTAL AGG CONC #1 | 4.7 | µ g/l | | | | | | |
| TOTAL AGG CONC #2 | 2 | µ g/l | | | | | | |
| TOTAL AGG CONC #3 | 50 | µ g/l | | | | | | |
| DICHLOROBROMOMETHANE | 50 | µ g/l | 0.9 | BDL | BDL | BDL | BDL | BDL |
| CARBON TETRACHLORIDE | 5 | µ g/l | 1.3 | BDL | BDL | BDL | BDL | BDL |
| BROMOFORM | 50 | µ g/l | 0.7 | BDL | BDL | BDL | BDL | BDL |
| DIBROMOCHLOROMETHANE | 50 | µ g/l | 0.7 | BDL | BDL | BDL | BDL | BDL |
| CHLOROFORM | 0.2 | µ g/l | 1.1 | BDL | BDL | BDL | BDL | BDL |
| TOLUENE | 5 | µ g/l | 1.2 | BDL | BDL | BDL | BDL | BDL |
| BENZENE | 0.7 | µ g/l | 0.7 | BDL | BDL | BDL | BDL | BDL |
| CHLOROBENZENE | 5 | µ g/l | 1.2 | BDL | BDL | BDL | BDL | BDL |
| ETHYLBENZENE | 5 | µ g/l | 1.2 | BDL | BDL | BDL | BDL | BDL |
| METHYLENE CHLORIDE | 5 | µ g/l | 1.0 | BDL | BDL | BDL | BDL | BDL |
| TETRACHLOROETHENE | 0.5 | µ g/l | 1.2 | BDL | BDL | BDL | BDL | BDL |
| TRICHLOROFLUOROMETHANE | 5 | µ g/l | 1.2 | BDL | BDL | BDL | BDL | BDL |
| 1,1-DICHLOROETHANE | 5 | µ g/l | 1.1 | BDL | BDL | BDL | BDL | BDL |
| 1,1-DICHLOROETHENE | 0.9 | µ g/l | 1.2 | BDL | BDL | BDL | BDL | BDL |
| 1,1,1-TRICHLOROETHANE | 5 | µ g/l | 1.4 | BDL | BDL | BDL | BDL | BDL |
| 1,1,2-TRICHLOROETHANE | 0.5 | µ g/l | 0.9 | BDL | BDL | BDL | BDL | BDL |
| 1,1,2,2 TETRACHLOROETHANE | 0.3 | µ g/l | 1.0 | BDL | BDL | BDL | BDL | BDL |
| 1,2-DICHLOROETHANE | 1 | µ g/l | 0.8 | BDL | BDL | BDL | BDL | BDL |
| 1,2 DICHLOROBENZENE | 4.7 | µ g/l | 0.9 | BDL | BDL | BDL | BDL | BDL |
| 1,2 DICHLOROPROPANE | 5 | µ g/l | 1.0 | BDL | BDL | BDL | BDL | BDL |
| 1,2(TRANS)-DICHLOROETHENE | 2 | µ g/l | 1.1 | BDL | BDL | BDL | 1.0 | BDL |
| 1,3 DICHLOROBENZENE | 5 | µ g/l | 1.1 | BDL | BDL | BDL | BDL | BDL |
| 1,4 DICHLOROBENZENE | 4.7 | µ g/l | 1.0 | BDL | BDL | BDL | BDL | BDL |
| TRANS 1,3 DICHLOROPROPENE | 2 | µ g/l | 0.9 | BDL | BDL | BDL | BDL | BDL |
| CIS 1,3 DICHLOROPROPENE | 2 | µ g/l | 0.9 | 2.0 | 2.6 | 2.4 | 0.40 J | BDL |
| m,p-XYLENE | 5 | µ g/l | 2.4 | BDL | BDL | BDL | BDL | BDL |
| BROMOMETHANE | 5 | µ g/l | 2.4 | BDL | BDL | BDL | BDL | BDL |
| VINYL CHLORIDE | 5 | µ g/l | 1.1 | BDL | BDL | BDL | BDL | BDL |
| TRICHLOROETHENE | 10 | µ g/l | 0.6 | BDL | BDL | BDL | BDL | BDL |
| 1,2(CIS)-DICHLOROETHENE | 5 | µ g/l | 0.7 | BDL | BDL | BDL | BDL | BDL |
| 1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE | 5 | µ g/l | | BDL | BDL | BDL | BDL | BDL |
| o-XYLENE | 5 | µ g/l | 1.3 | BDL | BDL | BDL | BDL | BDL |
| CHLOROETHANE | 5 | µ g/l | 1.6 | BDL | BDL | BDL | BDL | BDL |
| TOTAL VOCs | 100 | µ g/l | 0 | 2.0 | 2.6 | 2.4 | 1.4 | BDL |

B - Analyte detected in the associated Method Blank
 H - Sample received / analyzed outside method allowable holding time
 J - Analyte detected below quantitaion limits