

EDWARD P. MANGANO  
COUNTY EXECUTIVE



SHILA SHAH-GAVNOUDIAS, P.E.  
COMMISSIONER

**COUNTY OF NASSAU**  
**DEPARTMENT OF PUBLIC WORKS**  
1194 PROSPECT AVENUE  
WESTBURY, NEW YORK 11590-2723

February 4, 2011

New York State Department of  
Environmental Conservation  
Division of Environmental Remediation  
Remedial Bureau A, section B  
625 Broadway  
Albany, New York 12233 – 7015

Att: Cynthia Whitfield, P.E.  
Environmental Engineer II

Re: Monthly Effluent Monitoring Reports 2010  
Nassau County Mitchel Field Remedial Action  
(AKA Purex), Site # 1-30-014

Ladies and Gentlemen:

Attached is the September 2010 Monthly Effluent Monitoring Report for the groundwater remediation at the Purex Mitchel Field Remedial Action in Garden City, New York.

If you have any questions concerning the monthly monitoring reports, please contact Mr. Michael Flaherty, Hydrogeologist III, at (516) 571-7514.

Very truly yours,

Joseph L. Davenport, P.E.  
Chief Sanitary Engineer  
Unit Head, Water/Wastewater Engineering Unit

JLD:je  
Attachment

c: Kenneth G. Arnold, Assistant to Commissioner of Public Works  
Joseph N. Walker, Assistant Superintendent of Water Supply  
Michael Flaherty, Hydrogeologist III  
William Spitz, Region 1, NYSDEC

NASSAU COUNTY MITCHEL FIELD REMEDIAL ACTION  
MONTHLY EFFLUENT MONITORING REPORT

OUTFALL 001G  
SEPTEMBER 2010

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1	WEEK 2	WEEK 3	WEEK 4
				9/6/10	9/13/10	9/20/10	9/27/10
FLOW, DAILY MAX	MONITOR	GPD	NA	8/23/13	11/27/10	3/2/08	10/19/06
pH	6.5-8.5	su		6.74 H	7.28 H	7.06 H	6.96 H
TOTAL AGG CONC #1	4.7	µ g/l					
TOTAL AGG CONC #2	2	µ g/l					
TOTAL AGG CONC #3	50	µ g/l					
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL
CARBON TETRACHLORIDE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
BROMOFORM	50	µ g/l	0.7	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROFORM	0.2	µ g/l	1.1	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROBENZENE	5	µ g/l	1.2	BDL	BDL	0.89 J	BDL
ETHYLBENZENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
METHYLENE CHLORIDE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
TETRACHLOROETHENE	0.5	µ g/l	1.2	BDL	BDL	BDL	BDL
TRICHLOROFLUOROMETHANE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	0.9	µ g/l	1.2	BDL	BDL	BDL	BDL
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL
1,1,2-TRICHLOROETHANE	0.5	µ g/l	0.9	BDL	BDL	BDL	BDL
1,1,2,2 TETRACHLOROETHANE	0.3	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2-DICHLOROETHANE	1	µ g/l	0.8	BDL	BDL	BDL	BDL
1,2 DICHLOROBENZENE	4.7	µ g/l	0.9	BDL	BDL	BDL	BDL
1,2 DICHLOROPROPANE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	2	µ g/l	1.1	BDL	BDL	BDL	BDL
1,3 DICHLOROBENZENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,4 DICHLOROBENZENE	4.7	µ g/l	1.0	BDL	BDL	BDL	BDL
TRANS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	BDL	BDL	BDL	BDL
CIS 1,3 DICHLOROPROPENE	2	µ g/l	0.9	0.49 J	BDL	0.76 J	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
BROMOMETHANE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	0.6	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	0.7	BDL	BDL	BDL	BDL
1,1,2 TRICHLORO 1,2,2 TRIFLUOROETHANE	5	µ g/l		BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
CHLOROETHANE	5	µ g/l	1.6	BDL	BDL	BDL	BDL
TOTAL VOCs	100	µ g/l	0	0.49 J	BDL	1.65 J	BDL

B - Analyte detected in the associated Method Blank  
H - Sample received / analyzed outside method allowable holding time  
J - Analyte detected below quantitation limits