



**OCTOBER 2010 MONTHLY REPORT  
FOR GROUNDWATER TREATMENT  
O&M ACTIVITIES AT THE  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NASSAU COUNTY, NEW YORK**

**Prepared for:**

**United States Army Corps of Engineers  
Kansas City District**

**Contract No. W912 DQ-07-D-0044 Task 0001**

**Prepared by:**

**Science Applications International Corporation**

**6310 Allentown Boulevard  
Harrisburg, PA 17112  
(717) 901-8100**

**Prepared: November 4, 2010**

# TABLE OF CONTENTS

Page

<b>ACRONYMS AND ABBREVIATIONS .....</b>	<b>Preceding Text</b>
<b>1.0 OPERATION AND MAINTENANCE ACTIVITIES .....</b>	<b>1</b>
<b>2.0 OPERATION AND MAINTENANCE LOGS.....</b>	<b>1</b>
2.1 DAILY QUALITY CONTROL REPORTS .....	1
2.2 SUMMARY OF MAINTENANCE ACTIVITIES .....	2
2.3 OPERATOR’S LOGS.....	3
<b>3.0 TECHNICAL SUPPORT ACTIVITIES.....</b>	<b>3</b>
3.1 SAIC PERSONNEL.....	3
3.2 MANUFACTURING REPRESENTATIVES.....	3
3.3 SUBCONTRACTORS AND DELIVERIES .....	3
3.4 VISITORS.....	4
<b>4.0 HEALTH AND SAFETY .....</b>	<b>4</b>
<b>5.0 PLANNED ACTIVITIES AND SCHEDULES.....</b>	<b>4</b>
<b>6.0 MONITORING WELL WATER ELEVATIONS .....</b>	<b>4</b>
<b>7.0 TREATMENT SYSTEM FLOWS.....</b>	<b>4</b>
<b>8.0 CHEMICAL CONSUMPTION.....</b>	<b>5</b>
<b>9.0 CARBON USAGE .....</b>	<b>6</b>
9.1 AQUEOUS-PHASE CARBON .....	6
9.2 VAPOR-PHASE CARBON.....	6
<b>10.0 SLUDGE DISPOSAL.....</b>	<b>7</b>
<b>11.0 MONTHLY DISCHARGE MONITORING REPORT .....</b>	<b>7</b>
<b>12.0 SLUDGE QUALITY ASSURANCE REGULATIONS REPORT TO NYSDEC .....</b>	<b>7</b>
<b>13.0 OTHER OPERATIONS, MAINTENANCE, OR MANAGEMENT ISSUES.....</b>	<b>7</b>
<b>14.0 PROPOSED CHANGES TO STANDARD OPERATING PROCEDURES (SOP) .....</b>	<b>8</b>
<b>15.0 TREATMENT PLANT AND WELL FIELD MONITORING RESULTS .....</b>	<b>8</b>
15.1 OFF-SITE ANALYTICAL DATA RESULTS.....	8
15.2 FIELD DATA .....	9
<b>16.0 PROCESS ANALYSIS, INTERPRETATIONS, AND CONCLUSIONS.....</b>	<b>10</b>
16.1 INFLUENT PROCESS .....	10
16.2 METALS REMOVAL PROCESS .....	11
16.3 SETTLING FILTER PROCESS .....	11
16.4 AIR STRIPPING PROCESS .....	12
16.5 AQUEOUS-PHASE CARBON TREATMENT PROCESS .....	12
16.6 TREATED WATER INJECTION PROCESS .....	12

## **TABLE OF CONTENTS** (cont'd)

### **LIST OF FIGURES**

Figure 7-1, Actual Versus Contractual Quantity of Treated Water .....	Following Text
Figure 15-1, Injection Well Water Elevations and Daily Flow .....	Following Text
Figure 15-2, Injection Well Falling Head Test .....	Following Text
Figure 15-3, Comparison of Post-Redevelopment and March 2006 Falling Head Tests .....	Following Text

### **LIST OF TABLES**

Table 2-1, Monthly Plant Maintenance Record .....	Following Text
Table 6-1, Groundwater Elevation and Well Construction Data .....	Following Text
Table 7-1, Magnetic Flow Meter Daily Totalizer Readings .....	Following Text
Table 15-1, Injection Well Soundings .....	Following Text

### **LIST OF APPENDICES**

Appendix A, Project Status Reports .....	Following Text
Appendix B, Daily Quality Control Reports (DQCRs) .....	Following Text

## ACRONYMS AND ABBREVIATIONS

ALSI	Analytical Laboratory Services, Inc.
AS	air stripping
ASF	air stripper feed
ASR	Analytical Services Request
CA	carbon adsorber
CLP	contract laboratories program
DESA	Division of Environmental Science and Assessment
DQCRs	daily quality control reports
DTW	depth to water
EPA	United States Environmental Protection Agency
gpd	gallons per day
gpm	gallons per minute
GW	groundwater
GWTP	groundwater treatment plant
GWTS	groundwater extraction, treatment, and reinjection system
HCl	hydrochloric acid
HMI	human-machine interface
HVAC	heating, ventilation, and air conditioning
IG	infiltration gallery
IW	injection well
LGAC	liquid-phase granular-activated carbon
LTRA	Long Term Response Action
MCC	motor control cabinet
MCP	master (main) control panel
NYSDEC	New York State Department of Environmental Conservation
O&M	operation and maintenance
PD	plant discharge
PID	photoionization detector
PLC	programmable logic controller
PW	process water
SAIC	Science Applications International Corporation
SAP	sampling and analysis plan
SOP	standard operating procedure
SSHP	site safety and health plan
USACE	United States Army Corps of Engineers
VGAC	vapor-phase granular-activated carbon
VOCs	volatile organic compounds

## **1.0 OPERATION AND MAINTENANCE ACTIVITIES**

Science Applications International Corporation (SAIC) continued the operation and maintenance (O&M) of the Claremont Polychemical on-site groundwater extraction, treatment, and reinjection system (GWTS) for October 2010, the period defined as 0600 hours, October 1, 2010, through 0600 hours, November 1, 2010. All work was performed in accordance with SAIC Contract W912 DQ-07-D-0044 - Task 0001 under Option Year 3 of the contract. The facility operated for 31 days in the October reporting period with 270 minutes of downtime for the backwashing of the carbon adsorber (CA) vessels.

A copy of Project Status Report No. 40 is provided in Appendix A.

O&M conducted during this reporting period was performed in accordance with the site O&M Manual. Additional details of these activities are presented in Section 2.0 of this report.

Each workday morning, readings of key operational parameters are taken. These readings are used to monitor the plant's performance and determine if any problems or trends have developed. Copies of the daily readings are included in the Daily Quality Control Reports (DQCRs) found in Appendix B. The results and interpretations of these readings are discussed in Section 7.0 of this report.

## **2.0 OPERATION AND MAINTENANCE LOGS**

### **2.1 Daily Quality Control Reports**

The daily operations of the GWTS are documented in the DQCRs. The DQCRs include a summary of the daily operational activities, the Daily Operating Logs, the Daily Activities Summary Reports, the Daily Site Safety Inspection Forms, Weekly Air Monitoring Logs, the Sound Level Monitoring Worksheets, and the Employee and Subcontractor/Visitor Sign-in Sheets. Copies of these documents are also provided in Appendix B.

## **2.2 Summary of Maintenance Activities**

Maintenance of the treatment plant and equipment is performed in accordance with the O&M Manual, and the routine activities completed during this reporting period are summarized on Table 2-1. System maintenance incorporates the equipment manufacturers' recommendations, operations experience, and good engineering and maintenance practices. A detailed accounting of daily maintenance activities is provided in the plant operator's daily logbook, the site supervisor's daily logbook (both filed on-site), the operator's daily activities summary reports (Appendix B), and the plant supervisor's daily plant activity notes (filed on-site). Significant maintenance activities completed during this reporting period included the following:

- Monthly scheduled tasks included motor amp load readings, injection well (IW) depth soundings, IW falling head tests, valve function tests, comprehensive site inspections, infiltration gallery (IG) water level readings, and other function tasks.
- Landscaping and outdoor site maintenance were performed, as needed. Storm damage was cleaned up around plant.
- The process pumps were rotated (two on-line, one off) three times during this period as part of the preventive maintenance task.
- The process pH probes were cleaned, inspected, calibrated, and adjusted, as necessary.
- The check valve on air stripper feed (ASF) pump 3 was taken apart and examined for problems. The sealing disc stem is corroded, along with several other parts which require replacement.
- The pump-to-motor coupling for influent pump 3 was replaced and the motor aligned.
- Both CA vessels were air sparged and back washed through two cycles each.
- Preventive maintenance tasks were performed on the snowplow pump. The oil was changed.
- The outdoor tank level monitors were heat traced and insulated.
- Preventive maintenance tasks were completed on the heating, ventilation, and air conditioning (HVAC) unit.
- The filter press was filled and cleaned.

- The Aero-Tech M-8 pump was rebuilt and used to remove carbon from recycle tank and the floor sump.

## **2.3 Operator's Logs**

The following operating logbooks are currently in use:

- |  |       |
|--|-------|
| • Program/Project Manager's Field Activities Log | CL-26 |
| • Well Redevelopment Field Log                   | CL-28 |
| • Site Sampling and Technical Support Log        | CL-34 |
| • Site Supervisor's Daily Log                    | CL-36 |
| • Field Support Log                              | CL-37 |
| • Plant Operator's Daily Log                     | CL-38 |

All logbooks (in use and filed) are retained on-site and are available for detailed review. All of the logbooks are identified on a master logbook inventory control file and are routinely checked as part of the site quality control program.

## **3.0 TECHNICAL SUPPORT ACTIVITIES**

### **3.1 SAIC Personnel**

- No SAIC support was on-site this period.

### **3.2 Manufacturing Representatives**

- Richard Burke of Liger Energy was on-site to propose an alternative natural gas supplier. The proposal paperwork was forwarded to Harrisburg.

### **3.3 Subcontractors and Deliveries**

- Mail was delivered on six occasions.

- FedEx delivered the Analytical Laboratory Services, Inc. (ALSI) bottle order.
- FedEx returned sampling coolers twice.

### **3.4 Visitors**

- Din Weng of the Town of Oyster Bay laboratory was in to drop off sample bottles.

## **4.0 HEALTH AND SAFETY**

Work at the Claremont Polychemical groundwater treatment plant (GWTP) was conducted in accordance with the approved Site Safety and Health Plan (SSHP). Daily site safety inspections were performed and are presented in the DQCRs in Appendix B. In addition to the daily site inspections, comprehensive safety inspections are routinely performed.

No safety incidents or accidents occurred during October 2010.

## **5.0 PLANNED ACTIVITIES AND SCHEDULES**

The schedule of significant O&M activities is updated on a monthly basis, as presented in Table 2-1. Separate tentative schedules for equipment maintenance and sampling events are shown in the O&M Manual and the Sampling and Analysis Plan (SAP).

## **6.0 MONITORING WELL WATER ELEVATIONS**

Water level elevations for the monitoring wells were collected during October. Water quality data were not collected as the groundwater sampling event did not occur. The database has been updated, and the water elevation data are provided in Table 6-1.

## **7.0 TREATMENT SYSTEM FLOWS**

The volume of treated water discharged by the treatment plant to the injection well field is determined daily from readings of the magnetic flow meter on the plant effluent line. A



summary of these meter readings is provided in Table 7-1. The total treated water discharged for October 2010, as measured from 0600 hours on October 1, 2010, to 0600 hours on November 1, 2010, was 17,358,757 gallons. This volume is approximately 116 percent of the monthly targeted treatment goal. The cumulative amount of treated water for Option Year 3 (starting June 1, 2010) under the Long Term Response Action (LTRA) contract is 82,474,346 gallons. This is approximately 12 percent above the targeted goal for water to be treated. A graphic representation of total system flows is presented in Figure 7-1, and daily system flows are provided in Figure 15-1.

The average discharge flow for October was 389 gallons per minute (gpm) and 559,960 gallons per day (gpd).

The flow monitoring units for the individual IW systems are fully functioning. This allows for reading the flow rate and volume to each system. The relative flows for October are indicated below:

<b>Injection Well System</b>	<b>Flow Average (gpm)</b>	<b>Volume Discharged (Gallons)</b>
IW-1	95	4,241,430
IW-2	94	4,199,000
IW-3	112	5,005,810
IW-4	80	3,584,700
System	382	17,030,940

There is a discrepancy between the total of the individual flows with that of the plant discharge flowmeter of ~7 gpm. Much of this error is due to how the magnetic flow meter records flow.

## **8.0 CHEMICAL CONSUMPTION**

Currently, the four chemical feed systems are off-line, and their future use is not anticipated. All systems have been tested.

- The permanganate system is not operational. The programmable logic controller (PLC) is nonresponsive and needs to be replaced. An action plan is being devised.
- The sodium hydroxide system is operational.
- The hydrochloric acid (HCl) system is operational.
- The mixers on the polymer system are not functioning due to a wiring problem at the motor control cabinet (MCC) to the local control panel. An action plan is being devised.

Following is the inventory of the bulk chemicals at the plant:

Chemical	Inventory	
	No. of Containers	Container Type/Size
Caustic	7	55-gallon drums
Hydrochloric Acid (HCl)	1	55-gallon drum
Citric Acid	1	55-gallon drum (~200 lbs.)

## 9.0 CARBON USAGE

### 9.1 Aqueous-Phase Carbon

The presence of volatile organic compounds (VOCs) has not been detected in the effluent streams of the liquid-phase granular-activated carbon (LGAC) adsorber vessels. The influent and effluent streams of the vessels are monitored on a quarterly basis.

Rising differential pressure readings across each vessel indicated the need for backwashing. Both vessels were air sparged and then backwashed through two cycles each in October. Carbon was discharged to the floor sump during this task.

### 9.2 Vapor-Phase Carbon

Two vapor-phase granular-activated carbon (VGAC) beds are available for the off-gas treatment of the air stripping (AS) stream. Currently, VGAC-1 is on-line with VGAC-2 off-line and ready for service. Monitoring of VOCs in the influent and effluent air of the active vessel is performed

weekly with a photoionization detector (PID). VOCs have not been detected in the effluent during these weekly monitoring events. During this period, spent vapor-phase carbon was not generated, and no carbon was added to the vessels.

## **10.0 SLUDGE DISPOSAL**

- No water treatment sludge was collected or disposed of during this period.
- Nonhazardous carbon sludge from the backwash operation was collected in the floor drain sump in October.
- Five partially filled drums of nonhazardous carbon sludge/water are on-site.

## **11.0 MONTHLY DISCHARGE MONITORING REPORT**

The plant is currently operating under an equivalency permit from the New York State Department of Environmental Conservation (NYSDEC). While this permit requires periodic submittal of discharge monitoring results, monthly discharge monitoring reporting is not required. Monitoring data will be provided to the NYSDEC upon request.

A letter requesting an extension of the authorization to discharge treated groundwater to the groundwater aquifer was submitted to Mr. Brian Baker of the NYSDEC Division of Water. The response and permit extension are pending.

## **12.0 SLUDGE QUALITY ASSURANCE REGULATIONS REPORT TO NYSDEC**

During this period, no metal hydroxide sludge or hazardous waste was generated in the treatment process, and no hazardous waste was disposed of in October.

## **13.0 OTHER OPERATIONS, MAINTENANCE, OR MANAGEMENT ISSUES**

Responsibility for the GWTP operation is to be turned over to the NYSDEC. This includes the transfer of documents related to the operation of the plant to the NYSDEC project manager.

Several ongoing plant-wide issues include:

- Long-term plan for the compressed air system.
- Reliable remote access to the plant human-machine interface (HMI).
- Repair master control panel (MCP) grounding issues.
- Electrically connect injection pump #3 to the control system.
- Construct and install dedicated pump systems for selected monitoring wells.
- Repair leak in plant discharge (PD) manifold.
- Determine disposition of ASF pump 3.
- Fill in sinkhole at IW-4.

#### **14.0 PROPOSED CHANGES TO STANDARD OPERATING PROCEDURES (SOP)**

Procedures and standard forms are reviewed and revised as needed. In October, the following revisions were made:

- Horiba Calibration Log Sheet (CPS-Form-026) to revision level C.
- Horiba Calibration Procedure (CPS-GPO-008) to revision level B.
- Horiba Operation Procedure (CPS-GPO-009) to revision level B.
- Administrative tables for the SOP and Manual of Instruction were updated.

#### **15.0 TREATMENT PLANT AND WELL FIELD MONITORING RESULTS**

The Claremont Polychemical GWTS is monitored through the analysis of off-site laboratory analytical data and on-site field data.

##### **15.1 Off-Site Analytical Data Results**

Monthly PD samples are taken for organic analysis in compliance with the NYSDEC discharge permit and United States Army Corps of Engineers (USACE) contractual requirements.

Quarterly groundwater (GW) samples are taken for organic analysis, and quarterly process water (PW) samples are taken for organic, inorganic, and generic analysis. Samples are sent to facilities assigned by the United States Environmental Protection Agency (EPA) contract laboratories program (CLP). Significant sampling-related events for the month of October included:

- The PD was sampled on four occasions for pH and temperature.
- The quarterly PW sampling task was completed October 13. The organic and inorganic samples were shipped to the Division of Environmental Science and Assessment (DESA) laboratory for analysis. The generic samples were shipped to ALSI for analysis.
- An Analytical Services Request (ASR) was submitted for the November PD sampling task. The EPA assigned the DESA laboratory for the organic samples.
- The quarterly GW task normally scheduled for October was cancelled as per the revised and extended operational activities.

## 15.2 Field Data

Treatment plant effluent is monitored for pH and temperature on a weekly basis in order to obtain a monthly average in compliance with the NYSDEC discharge permit requirements. These readings are obtained from the discharge sample in a controlled area with calibrated portable meters. A summary of these data is as follows:

Date	pH	Temperature (°C)
October 4, 2010	6.48	15
October 12, 2010	5.37	15
October 18, 2010	5.42	14
October 25, 2010	6.49	14
<b>Monthly Average</b>	<b>5.94</b>	<b>14.5</b>

The NYSDEC discharge permit requires the PD to have an average monthly pH greater than 5.50. Although two sample readings are below this point, the treatment plant effluent met the monthly average pH discharge requirement.

Soundings to determine the depth to the bottom of the IWs were taken on October 14, 2010, and compared to previous readings. A summary of these data is included in Table 15-1. The data indicate that since the beginning of monitoring on June 17, 2004, there has been an accumulation of sediment in the four IWs. IW-1 is the most severe case, with the influx of sand accounting for more than 100 feet of sediment in the bottom of the well. Of this sediment, 75 feet were deposited between April 2008 and March 2009. In the last month, there was little change in the well sediment levels.

Water elevations in the IWs are recorded on a daily basis as is the daily total flow discharged to the well field. These are depicted in Figure 15-1. During October, the plant continued its stable operation, and the plant effluent and IW levels were steady. The transducer for IW-2 continues to read low.

A falling head test was performed on the IWs on October 21. A graphic representation of the time required to drop the water level to a static condition is presented in Figure 15-2. Comparisons of baseline data from March 2006 to that of recent tests (Figure 15-3) indicate that well #4 is operating near its baseline. Well #3 is stable, and IW-1 shows continued improvement. IW-2 appears stable (readings are interpolated up to 30 feet) and operating near its baseline.

Flow to infiltration galleries IG-1 and IG-3 is restricted so that flow to IW-1 and IW-3 is maximized. Both galleries are draining adequately. The plant's effluent discharge flow is maximized and is limited by injection pump capacity.

## **16.0 PROCESS ANALYSIS, INTERPRETATIONS, AND CONCLUSIONS**

### **16.1 Influent Process**

Currently, the three extraction well pumps are on-line and operational. The pump for well #1 failed in October, and the overload relay had to be manually reset. It is back on-line.

All three influent pumps are operational and are rotated into service two at a time:

- The motor-to-pump coupling on pump 3 was replaced and the motor realigned.
- October's influent flow was maintained to keep the treated water tanks at ~65 percent of capacity. This boosts the injection pump performance.
- Water was treated by both treatment trains throughout this period.

No other issues arose with the extraction/influent system. Routine maintenance continues.

## **16.2 Metals Removal Process**

The polymer, potassium permanganate, caustic, and HCl feed systems remain out of service as current water conditions make their use unnecessary. The flash and flocculation mixers at the clarifiers remain idle due to the discontinued use of the polymer and lack of solids generation.

The inclined plates on the clarifiers were brushed and cleaned. No sludge was removed from the clarifier cones.

## **16.3 Settling Filter Process**

The discharge nozzles and screens of the retention-settling filter tanks are subject to particulate fouling. As part of routine maintenance, the system is backwashed with pressurized air using a sparger. Periodically, the system needs to be shut down for cleaning using pressurized water, along with brushing.

The frequency of air sparging remains periodic; however, in October, the risers received minimal attention.

## **16.4 Air Stripping Process**

All three ASF pumps are operational with two rotated into service at a time.

The remote start-up of the ASF pumps remains troublesome as the check valves fail to operate as intended.

Pump #3 emits a high-pitched whine which will require future address. The check valve for pump #3 was disassembled and cleaned. The sealing disc has corroded and will require replacement. The valve operate as a flow through valve.

No other issues arose with the air stripping system. Routine maintenance continues.

## **16.5 Aqueous-Phase Carbon Treatment Process**

All three LGAC feed pumps are operational, with two pumps rotated into service at a time. The pressures through the vessels continue to be monitored. The differential pressures in both vessels were rising, resulting in the backwashing of each vessel.

Other routine maintenance tasks continued.

## **16.6 Treated Water Injection Process**

The IW system is on-line and fully operational. Valves to the four wells are currently fully open. Water levels in the wells are stable. Both injection pumps are on-line.

The plant's total discharge flow rate and volume are measured by a magnetic flow meter on the injection pump system's main discharge line. Flow sensors and transmitters installed in the discharge line to each injection well system are on-line and connected to the MCP and HMI.



The level transducer in IW-2 continues to read ~30 feet below the actual depth to water (DTW) level. This will be addressed when the electrician is on-site.

No issues were encountered with the injection system in October. Routine maintenance tasks continue.

## **FIGURES**

**Figure 7-1. Actual Versus Treated Water Goal**




Figure 15-1 Injection Well Elevations and Daily Flow









Figure 15-2 Injection Well Falling Head Test October 21, 2010



**Figure 15-3 Comparison of Post-Redevelopment and March 2006 Falling Head Tests**



# TABLES

**Table 2-1 Maintenance Log**  
**Claremont Polychemical Superfund Site**  
**Old Bethpage New York**  
 October 2010

SYSTEM	UNITS	EQUIPMENT	ACTION	FREQUENCY	4-Oct	11-Oct	18-Oct	25-Oct	COMMENTS
<b>EXTRACTION WELLS</b>									
new motor installed in #2 6/18/10	3	PUMPS	HOOR READINGS	DAILY	FF	FF	FF	FF	
new pump and motor in #1 on 7/22/10	3	MOTORS	AMP DRAW	MONTHLY	-	-	-	complete	Amp Draws taken 10/29
<b>EQUALIZATION TANK</b>	1	TANK	INSPECT	DAILY	FF	FF	FF	FF	Tanks are inspected daily. Some rust observed
jogged mixer 9/3/09	1	MIXER	exercise	AS NEEDED	-	-	-	-	mixer is off line
inspected and cleaned 8/09	1	INFLUENT STRAINER	INSPECT(last 10/06)	MONTHLY	-	-	-	-	
<b>INFLUENT PUMPS</b>	3	SUCTION VALVES	EXERCISE	MONTHLY	-	-	-	FF	Pump isolation valves are exercised monthly and during plant shutdowns
	3	DISCHARGE VALVES	EXERCISE	MONTHLY	-	-	-	FF	
	3	CHECK VALVES	LUBRICATE	AS NEEDED	-	-	-	-	Check valves are lubricated periodically
			INSPECT	MONTHLY	FF	-	-	-	
pumps and trays painted 4/10	3	PUMPS	INSPECT	WEEKLY	FF	FF	FF	FF	
new pump head installed P-3 10/08	3	PUMP MOTORS	INSPECT	MONTHLY	FF	-	-	-	pumps rotated 3 times in October
P#2 mech. seal installed 12/09			LUBRICATE	MONTHLY	FF	-	-	-	
			AMP DRAW	MONTHLY	-	-	-	complete	Amp Draws taken 10/29
	2	FLOW DIRECTION VALVES	EXERCISE	MONTHLY	FF	-	-	-	adjusted as needed during pump rotations
actuators removed 6/2/08	2	FLOW CONTROL VALVES	INSPECT	MONTHLY	FF	FF	FF	FF	Valves normally open
	2	MAGNETIC FLOW METERS	INSPECT	WEEKLY	FF	FF	FF	FF	
			CALIBRATE	AS NEEDED	FF	FF	FF	FF	not necessary
	6	PRESSURE GAUGE VALVES	EXERCISE	MONTHLY	FF	-	-	-	
<b>REACTION TANK # 1</b>	1	MAIN DRAIN VALVE	EXERCISE	MONTHLY	-	-	-	-	Tanks are filled with water, no leaks, drain valve not tested
mixer jogged 9/09	1	MIXER	INSPECT	MONTHLY	Chemical feeds are not in service, ppt not required				not in service
			LUBRICATE	AS NEEDED	-	-	-	-	
electrode replaced 10/08	1	pH PROBE	CHECK ACCURACY	WEEKLY	FF	FF	FF	FF	checked weekly vs lab meter
			INSPECT	MONTHLY	cleaned	cleaned	cleaned	cleaned	inspected and cleaned as needed
			CALIBRATE	MONTHLY	cal'd	cal'd	cal'd	cal'd	last calibrated 10/25
<b>REACTION TANK # 2</b>	1	MAIN DRAIN VALVE	EXERCISE	MONTHLY	-	-	-	-	Tanks are filled with water, no leaks, drain valve not tested
mixer jogged 9/09	1	MIXER	INSPECT	MONTHLY	Chemical feeds are not in service, ppt not required				not in service
			LUBRICATE	AS NEEDED	-	-	-	-	
probe replaced 12/08	1	pH PROBE	CHECK ACCURACY	WEEKLY	FF	FF	FF	FF	checked weekly vs lab meter
			INSPECT	MONTHLY	cleaned	cleaned	cleaned	cleaned	inspected and cleaned as necessary
			CALIBRATE	MONTHLY	cal'd	cal'd	cal'd	cal'd	Last calibrated 10/25
<b>CAUSTIC FEED</b>		Bulk Chemical - drums	INVENTORY	WEEKLY	7	7	7	7	ok
	1	POLY TANK	INSPECT	WEEKLY	-	-	-	-	System holds water but is off line
system last tested 05/10			CLEAN	AS NEEDED	-	-	-	-	not necessary
	1	MIXER	INSPECT	WEEKLY	-	-	-	-	
(pump 1 new 10/2/07)	2	PUMPS	INSPECT	WEEKLY	-	-	-	-	system all ok.
		PIPING / TUBING	INSPECT	WEEKLY	-	-	-	-	
			CLEAN	AS NEEDED	-	-	-	-	
<b>POLYMER FEED</b>		Bulk Chemicals -bags	INVENTORY	WEEKLY	0	0	0	0	The polymer feed system is currently offline. The system was tested 5/29/09. Water fill and level controls work. Neither mixer is getting power at LCP. An investigation revealed wiring inconsistencies and missing control parts. Pumps work in manual mode with variable speed. No leaks.
	2	POLY TANK	INSPECT	MONTHLY	-	-	-	-	
system last tested 05/09	2	MIXER	INSPECT/EXERCISE	MONTHLY	-	-	-	-	
			CLEAN	AS NEEDED	-	-	-	-	
	2	DRAIN VALVE	EXERCISE	MONTHLY	-	-	-	-	
	2	WATER SUPPLY VALVES	EXERCISE	MONTHLY	-	-	-	-	



## Table 2-1 Maintenance Log

### Claremont Polychemical Superfund Site

### Old Bethpage New York

SYSTEM	UNITS	EQUIPMENT	ACTION	FREQUENCY	4-Oct	11-Oct	18-Oct	25-Oct	COMMENTS
	1	WATER FILTER	INSPECT	MONTHLY	-	-	-	-	
	3	PERISTALTIC PUMPS	EXERCISE	MONTHLY	-	-	-	-	
	19	SYSTEM VALVES	EXERCISE	MONTHLY	-	-	-	-	
POTASSIUM PERMANGANATE FEED		Bulk Chemicals	INVENTORY	WEEKLY	0	0	0	0	The potassium permanganate feed system is currently off-line. The system requires replacement of PLC control system to be operational. Repair work is scheduled. Flange gasket on tank drain was replaced 8/24/10. System not retested for leaks.
	1	POLY TANK	INSPECT	MONTHLY	-	-	-	-	
	1	MIXER	INSPECT/EXERCISE	MONTHLY	-	-	-	-	
			CLEAN	AS NEEDED	-	-	-	-	
	1	DRAIN VALVE	EXERCISE	MONTHLY	-	-	-	-	
	2	METERING PUMPS	INSPECT	MONTHLY	-	-	-	-	
	7	SYSTEM VALVES	EXERCISE	MONTHLY	-	-	-	-	
FLASH/FLOC TANK # 1	1	SAMPLE PORT VALVE	EXERCISE	MONTHLY	-	-	-	-	The flash and flocculation tanks and associated equipment are currently offline. Due to lack of solids in the groundwater, metals precipitation is not required at this time.
	1	DRAIN VALVE	EXERCISE	MONTHLY	-	-	-	-	
	1	SLUDGE PUMP INF. VALVE	EXERCISE	MONTHLY	-	-	-	-	
mixer jogged 05/09	2	MIXER	EXERCISE	MONTHLY	-	-	-	-	
	1	SLUDGE PUMP EFF. VALVE	EXERCISE	MONTHLY	-	-	-	-	
	2	GAUGE VALVES	EXERCISE	MONTHLY	-	-	-	-	
FLASH/FLOC TANK # 2	1	SAMPLE PORT VALVE	EXERCISE	MONTHLY	-	-	-	-	
	1	DRAIN VALVE	EXERCISE	MONTHLY	-	-	-	-	
	1	SLUDGE PUMP INF. VALVE	EXERCISE	MONTHLY	-	-	-	-	
mixer jogged 05/09	2	MIXER	EXERCISE	MONTHLY	-	-	-	-	
	1	SLUDGE PUMP EFF. VALVE	EXERCISE	MONTHLY	-	-	-	-	
	2	GAUGE VALVES	EXERCISE	MONTHLY	-	-	-	-	
CLARIFIER # 1	1	BAFFLES	INSPECT	WEEKLY	FF	FF	FF	FF	last cleaned Sept. 2010
			CLEAN	WEEKLY	-	-	-	-	
Unit was emptied and cleaned 5/09	2	SLUDGE PUMPS	INSPECT	WEEKLY	-	-	-	-	idle, no sludge is being generated
baffels last cleaned 02/10			EXERCISE	MONTHLY	-	-	-	-	
Pumps tested 6/10	3	SAMPLE PORT VALVES	EXERCISE	WEEKLY	-	-	-	-	
	1	DRAIN VALVE	EXERCISE	MONTHLY	-	-	-	-	tank is full, valve not tested, no leaks
	1	WEIRS	INSPECT	WEEKLY	FF	FF	FF	FF	cleaned as needed
CLARIFIER # 2	1	BAFFLES	INSPECT	WEEKLY	FF	FF	FF	FF	last cleaned Sept. 2010
Unit was emptied and cleaned 5/09			CLEAN	WEEKLY	-	-	-	-	
baffels last cleaned 02/10	2	SLUDGE PUMPS	INSPECT	WEEKLY	-	-	-	-	idle, no sludge is being generated
Pumps tested 6/10			EXERCISE	MONTHLY	-	-	-	-	
	3	SAMPLE PORT VALVES	EXERCISE	WEEKLY	-	-	-	-	
	1	DRAIN VALVE	EXERCISE	MONTHLY	-	-	-	-	System holds water, no leaks
	1	WEIRS	INSPECT	WEEKLY	FF	FF	FF	FF	
SAND FILTER # 1	4	DRAIN VALVES	EXERCISE	MONTHLY	-	-	-	-	System holds water, no leaks
Unit was emptied and cleaned 5/09	8	RISERS	INSPECT	WEEKLY	FF	FF	FF	FF	air sparged and brushed as needed
SAND FILTER # 2	4	DRAIN VALVES	EXERCISE	MONTHLY	-	-	-	-	System holds water, no leaks
Unit was emptied and cleaned 5/09	8	RISERS	INSPECT	WEEKLY	FF	FF	FF	FF	air sparged and brushed as needed
PNEUMATIC SYSTEM	1	AIR COMPRESSOR MOTORS	CHECK OIL LEVEL	WEEKLY	FF	off	off	off	System is off line and is activated as needed. Oil and filters changed sept 2010
(off line 1/08)			CHANGE OIL / FILTER	QUARTERLY	FF	off	off	off	
last changed 1/06	2	COMPRESSOR AIR FILTER	INSPECT	WEEKLY	FF	off	off	off	
chamber rebuilt 3/20/09			CHANGE	QUARTERLY	FF	off	off	off	changed sept 2010

## Table 2-1 Maintenance Log

### Claremont Polychemical Superfund Site

### Old Bethpage New York

SYSTEM	UNITS	EQUIPMENT	ACTION	FREQUENCY	4-Oct	11-Oct	18-Oct	25-Oct	COMMENTS
#1 belts changed 11/21/07	2	COMPRESSOR BELTS	CHECK BELT TENSION	WEEKLY	FF	off	off	off	
			CHANGE	AS NEEDED	FF	off	off	off	as necessary
control panel circuit breaker replaced 3-17-09	1	AIR COMP. TANK	INSPECT	WEEKLY	FF	off	off	off	
			CHECK DRAIN / FILTER	DAILY	FF	off	off	off	auto valve is operational
	2	AIR COMP. TANK VALVES	EXERCISE	MONTHLY	FF	off	off	off	
	8	PRESSURE RELIEF VALVES	INSPECT	WEEKLY	FF	off	off	off	
	3	AFTER COOLER VALVES	EXERCISE	MONTHLY	FF	off	off	off	
	1	AFTER COOLER DRAIN	INSPECT	DAILY	FF	off	off	off	auto valve is operational
	4	AIR DRYER VALVES	EXERCISE	MONTHLY	FF	off	off	off	
repaired 2/7/07	1	AIR DRYER DRAIN	INSPECT	WEEKLY	FF	off	off	off	auto valve is operational
replaced 1/27/06	2	COALESCING FILTER	DRAIN	AS NECESSARY	FF	off	off	off	as necessary
			Cartridge	AS NECESSARY	FF	off	off	off	filter replaced Sept 2010
	4	COALESIG FILTER VALVES	EXERCISE	MONTHLY	FF	off	off	off	
	15	PLANT REGULATORS/TRAPS	DRAIN	AS NECESSARY	FF	off	off	off	as necessary
<b>AIR STRIPPER FEED</b>	2	TANK	INSPECT	WEEKLY	FF	FF	FF	FF	holding water with no leaks
probe replaced 7/08	1	pH PROBE	CHECK ACCURACY	WEEKLY	FF	FF	FF	FF	
removed and cleaned 5/28/10			CALIBRATE	AS NEEDED	-	-	-	-	electrode removed and cleaned, not taking cal.
pumps and trays painted 4/10	2	pH PROBE VALVES	EXERCISE	MONTHLY	FF	-	-	-	
	3	PUMPS	INSPECT	WEEKLY	FF	FF	FF	FF	inspected daily, pumps rotated 3 times in October
	3	PUMP MOTORS	INSPECT	WEEKLY	FF	FF	FF	FF	amp draws taken 10/29
			LUBRICATE	AS NEEDED	FF	FF	FF	FF	pump 3 exhibits high pitch whine
	3	CHECK VALVES	LUBRICATE	MONTHLY	OK	OK	OK	OK	valve 3 missing disc and arm
			INSPECT	QUARTERLY	-	-	-	-	continue to pose pump start-up problems
actuators removed 6/07	1	FLOW CONTROL VALVES	INSPECT	WEEKLY	FF	FF	FF	FF	valve is normally open
	2	TANK INFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	normally open
	2	TANK EFFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	No leaks
	2	TANK DRAIN	EXERCISE	MONTHLY	-	-	-	-	tank full - not tested, no leaks
	2	LEVEL INDICATOR	INSPECT	WEEKLY	FF	FF	FF	FF	
	2	LEVEL IND. ISOLATION VALVE	EXERCISE	MONTHLY	FF	-	-	-	
	5	PUMP INFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	
replaced 3/08	3	PUMP EFFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	
	1	SAMPLE PORT VALVE	EXERCISE	MONTHLY	FF	FF	FF	FF	exercised during pH probe checks
<b>HYDROCHLORIC FEED</b>		Bulk Chemistry - plastic drums	INVENTORY	WEEKLY	1	1	1	1	The hydrochloric acid feed system is currently offline and out of service. Equipment is checked as needed.
	1	MIXER	INSPECT	MONTHLY	NR	NR	NR	NR	
system tested 5/09			CLEAN	AS NEEDED	-	-	-	-	The system was operated for several days in June 2010. Fill system, mixer, level controls, and pumps operate. Pump 1 is a little weaker than #2.
pump2 replaced 7/07	2	PUMPS	INSPECT	MONTHLY	-	-	-	-	
calibration column valves replaced 11/09		PIPING / TUBING	INSPECT	MONTHLY	-	-	-	-	
			CLEAN	AS NEEDED	-	-	-	-	
<b>AIR STRIPPER TOWER</b>	1	FIBERGLASS TOWER (painted 5/08)	INSPECT	WEEKLY	FF	FF	FF	FF	
heater switched off Mar-2010	1	HEATER (painted 8/10)	INSPECT	WEEKLY	-	-	-	-	heater duct painted 8/10
Tower power washed and painted 5/08	1	GAUGES / TUBING	INSPECT	WEEKLY	FF	FF	FF	FF	drained of moisture, replaced as required
			DRAIN CONDENSATE	AS NEEDED	-	-	-	-	drained as required
Bx-80 belts replaced 10/28/09	1	BLOWER	INSPECT BELTS	WEEKLY	FF	FF	FF	FF	amp draws taken 10/29
last greased 8/31/10			GREASE BEARINGS	MONTHLY	FF	-	-	-	

**Table 2-1 Maintenance Log**  
**Claremont Polychemical Superfund Site**  
**Old Bethpage New York**

SYSTEM	UNITS	EQUIPMENT	ACTION	FREQUENCY	4-Oct	11-Oct	18-Oct	25-Oct	COMMENTS
	1	Blower Magnehelic	INSPECT	WEEKLY	FF	FF	FF	FF	
	1	SUMP	DRAIN	AS NEEDED	-	-	-	-	
		OFF GAS PIPING	INSPECT	WEEKLY	FF	FF	FF	FF	
	2	OFF GAS PIPING VALVES	EXERCISE	MONTHLY	FF	-	-	-	
<b>VAPOR GAC UNITS</b>	4	GAUGES	INSPECT	DAILY	FF	FF	FF	FF	part of daily data collection
			DRAIN CONDENSATE	AS NEEDED	-	-	-	-	periodically
	8	GAUGE VALVES	EXERCISE	MONTHLY	FF	-	-	-	
new tubing 10/29/09		TUBING	INSPECT	DAILY	FF	FF	FF	FF	
			REPLACE	AS NEEDED	-	-	-	-	
<b>AQUEOUS GAC FEED</b>	3	PUMP	INSPECT	WEEKLY	FF	FF	FF	FF	
pumps and trays painted 4/10	3	PUMP MOTORS	INSPECT/ROTATE	WEEKLY	FF	FF	FF	FF	inspected daily, rotated 3 times in October
New PG (P-2 out) 9/08			LUBRICATE	AS NEEDED	FF	-	-	-	
			AMP DRAW	MONTHLY	-	-	-	-	Amp Draws taken 10/29
	3	CHECK VALVES	LUBRICATE	MONTHLY	FF	-	-	-	last lubricated Sept 2010
P-2 glan repaired 1/08			INSPECT	QUARTERLY	-	-	-	-	
	2	POLY TANK	INSPECT	WEEKLY	FF	FF	FF	FF	daily inspection during data collection
	2	TANK INFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	
	2	TANK EFFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	
	2	TANK DRAIN	EXERCISE	MONTHLY	-	-	-	-	not exercised, tank full and on-line, no leaks
	2	LEVEL Monitor ISOLATION VALVES	EXERCISE	MONTHLY	FF	-	-	-	
new valves 10/07	3	PUMP SUCTION VALVE	EXERCISE	MONTHLY	FF	-	-	-	
new valves 11/07	3	PUMP DISCHARGE VALVE	EXERCISE	MONTHLY	FF	-	-	-	
actuators removed 6/07	2	FLOW CONTROL VALVES	INSPECT	WEEKLY	-	-	-	-	valves normally open
	2	AIR STRIP. BYPASS VALVE	EXERCISE	MONTHLY	NR	-	-	-	Blocked and out of service
	2	SAMPLE PORT VALVE	EXERCISE	MONTHLY	FF	-	-	-	
<b>AQUEOUS GAC VESSELS</b>	3	INFLUENT VALVES	EXERCISE	MONTHLY	FF	FF	FF	FF	exercised during backwash operations
	2	PRESSURE RELIEF VALVES	INSPECT	MONTHLY	FF	-	-	-	last backwashed 10/21/10
	3	BACKWASH VALVES	EXERCISE	MONTHLY	FF	FF	FF	FF	
weld repairs 5/28/10	2	EFFLUENT VALVES	EXERCISE	MONTHLY	FF	FF	FF	FF	
replaced #1 12/09, #2 3/10	2	SAMPLE PORT VALVE	EXERCISE	MONTHLY	FF	-	-	-	
	4	GAUGE ISOL. VALVES	EXERCISE	MONTHLY	FF	-	-	-	
<b>TREATED WATER</b>	2	TANK	INSPECT	DAILY	-	-	-	-	some rust present
<b>SYSTEM</b>	2	DRAIN VALVE	EXERCISE	AS NEEDED	NR	-	-	-	tanks are full and on-line, no leaks, valves do not properly seal
pump 3 installed 12/08 off line	3	Injection PUMPS	INSPECT	WEEKLY	FF	FF	FF	FF	electrical hook up of Pump #3 scheduled
pumps and trays painted 4/10	3	PUMP MOTORS	INSPECT	WEEKLY	FF	FF	FF	FF	
tanks cleaned 04/10			LUBRICATE	AS REQUIRED	-	-	-	-	
			AMP DRAW	MONTHLY	-	-	-	-	Amp Draws taken 10/29
IW-3 pipe repaired 1/10	4	Injection Wells	Inspect	AS NECESSARY	FF	FF	FF	FF	Falling head tests completed 10/21 no overflows
Infiltration Galleries installed 9/10	2	Infiltration Galleries	Valves	AS NECESSARY				FF	Currently IG-1 and IG-3 influent valves set at 1/2 open
	3	CHECK VALVES	LUBRICATE	AS NEEDED	FF	-	-	-	last lubricated Sept 2010
			INSPECT	QUARTERLY	-	-	-	-	
	3	PUMP INFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	
	5	PUMP EFFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	
	3	RECYCLE FLOW VALVES	EXERCISE	MONTHLY	FF	-	-	-	

## Table 2-1 Maintenance Log

### Claremont Polychemical Superfund Site

### Old Bethpage New York

SYSTEM	UNITS	EQUIPMENT	ACTION	FREQUENCY	4-Oct	11-Oct	18-Oct	25-Oct	COMMENTS
	1	BACKWASH FEED VALVE	EXERCISE	MONTHLY	FF	FF	FF	FF	exercised during backwash operations
insulated 10/10	2	Level Monitor	INSPECT	WEEKLY	FF	FF	FF	FF	
	2	level Monitor isolation valves	EXERCISE	MONTHLY	FF/FF	-	-	-	units insulated and heat traced 10/10
	1	Krohne Mag meter	Inspect	WEEKLY	FF	FF	FF	FF	leak at elbow
on-line 12/09	4	IW Flow Meters	INSPECT	WEEKLY	FF	FF	FF	FF	
	8	METER ISOL. VALVES	EXERCISE	MONTHLY	FF	FF	FF	FF	full open
<b>FLOOR DRAINS &amp; PIT</b>	1	SUMP PIT W/ PUMP	INSPECT	WEEKLY	FF	FF	FF	FF	
	12	FLOOR DRAINS	INSPECT	WEEKLY	FF	FF	FF	FF	clear
sump & Pre sump cleaned 9/10	2	FLOW CONTROL VALVES	EXERCISE	MONTHLY	FF	FF	FF	FF	exercised during backwash operations
<b>RECYCLE SYSTEM</b>	2	PUMPS	INSPECT	WEEKLY	FF	FF	FF	FF	
pumps and trays painted 4/10		PUMP MOTORS	INSPECT	WEEKLY	FF	FF	FF	FF	system spends most time in standby mode
			LUBRICATE	AS REQUIRED	-	-	-	-	carbon removed from tank 10/28
			AMP DRAW	MONTHLY	-	-	-	-	Amp Draws taken 10/29
	2	CHECK VALVES	LUBRICATE	AS NEEDED	-	-	-	-	last lubricated Sept 2010
			INSPECT	QUARTERLY	FF	-	-	-	
	2	PUMP INFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	
	3	PUMP EFFLUENT VALVES	EXERCISE	MONTHLY	FF	-	-	-	
<b>SLUDGE STORAGE</b>	1	TANK	INSPECT	WEEKLY	FF	FF	FF	FF	
cone drain valves replaced 11/05/09	2	CONE DRAIN VALVE	EXERCISE	MONTHLY	-	-	-	-	clog in system. Tank will not drain
	4	DECANT VALVES	EXERCISE	MONTHLY	FF	FF	FF	FF	exercised when emptying tank
	1	SAMPLE PORT VALVE	EXERCISE	MONTHLY	FF	-	-	-	
	1	SLUDGE PRESS PUMP	EXERCISE	MONTHLY	-	-	-	-	
	1	LEVEL INDICATOR	INSPECT	WEEKLY	FF	FF	FF	FF	
	2	LEVEL INDIC. VALVE	EXERCISE	MONTHLY	FF	-	-	-	
<b>SLUDGE PRESS</b>	1	SLUDGE PRESS	INSPECT	MONTHLY	NR	-	-	-	operated as necessary,
			EXERCISE	MONTHLY	NR	-	-	-	slight leak in hydraulic control panel
	1	INFLUENT VALVE	EXERCISE	MONTHLY	NR	-	FF	FF	
	4	EFFLUENT VALVES	EXERCISE	MONTHLY	NR	-	FF	FF	
<b>HVAC &amp;</b>	1	MOTOR	INSPECT	ANNUALLY	NR	-	-	-	last inspection 10/10
<b>AIR HANDLING UNIT</b>	3	BELTS	INSPECT	SEMI-ANNUALLY	NR	-	-	-	last inspection 10/10
	1	MOTOR BEARING	LUBRICATE	SEMI-ANNUALLY	NR	-	-	-	last lubbed 10/10
	1	BLOCK BEARING (SOUTH)	LUBRICATE	SEMI-ANNUALLY	NR	-	-	-	last Lubbed 10/10
		Filters	inspect/replace	AS NEEDED	NR	-	-	-	last changed 2/08
	1	BEARING (NORTH)	LUBRICATE	SEMI-ANNUALLY	NR	-	-	-	last lubbed 10/10
<b>CONTROL ROOM</b>	1	MCC UNIT	CHECK LIGHTBULBS	WEEKLY	-	-	-	-	several sockets need replacement
	20	Ceiling	CHECK LIGHTBULBS	WEEKLY	FF	FF	FF	FF	
<b>LABORATORY</b>	N/A	BOTTLES	INVENTORY	AS NEEDED	NR	-	-	-	
	N/A	CHEMICALS	INVENTORY	AS NEEDED	NR	-	-	-	
	N/A	COOLERS	INVENTORY	AS NEEDED	NR	-	-	-	
<b>PLANT AND SHOP</b>	20	Overhead (HP) lights	Check function	AS NEEDED					Bulbs are replaced as necessary
	5	exit lights	check function	AS NEEDED	FF			FF	Bulbs are replaced as necessary
	3	fluorescent lights	check function	AS NEEDED					Bulbs are replaced as necessary

**COMMENTS:**

FF - FULLY FUNCTIONAL	RR - REPAIRS REQUIRED
IOS - INTENTIONALLY OUT OF SERVICE	NR - NOT REQUIRED
NS - NEEDS SERVICE (NORMAL MAINTENANCE)	NA - NOT APPLICABLE

**Table 6-1**  
**Groundwater Elevation and Well Construction Data**  
**Claremont Polychemical Superfund Site**  
**Old Bethpage, NY**

Well ID	Northing (NAD27)	Easting (NAD27)	Well Diameter (inches)	Depth of Screened Interval (ft bgs)	Elev. of Screened Interval (ft AMSL)	Well Depth (ft bgs)	Elevation (NGVD29) to Top of				February 2002			April 2002			May 2002		
							Ground Surface (ft AMSL)	Steel Casing (ft AMSL)	PVC Casing (ft AMSL)	Pump Cap (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>a</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>a</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)
<b>Monitoring Wells</b>																			
EW-1A	193873.779	2154019.942	4	65.17 to 75.00	53.34 to 63.17	76.50	128.34	130.09	130.02	130.00	14-Feb-02	69.58	60.44	5-Apr-02	70.20	59.82	16-May-02	70.60	59.40
EW-1B	193883.104	2154024.450	4	90.17 to 100.00	28.75 to 38.58	102.40	128.75	130.65	130.56	130.53	14-Feb-02	70.17	60.39	5-Apr-02	70.77	59.79	16-May-02	71.13	59.40
EW-1C	193876.735	2154013.250	4	115.17 to 125.00	3.43 to 13.26	127.50	128.43	130.60	130.47	130.44	14-Feb-02	69.75	60.72	5-Apr-02	70.51	59.96	16-May-02	71.02	59.42
EW-2A	193955.252	2154621.992	4	92.17 to 102.00	65.19 to 55.36	108.50	157.36	157.54	157.14	157.36	12-Feb-02	97.67	59.47	5-Apr-02	98.35	58.79	17-May-02	98.89	58.47
EW-2B	193968.144	2154627.191	4	120.17 to 130.00	28.74 to 38.57	129.50	157.74	157.99	157.61	157.73	12-Feb-02	98.17	59.44	5-Apr-02	98.59	59.02	15-May-02	99.05	58.68
EW-2C	193965.658	2154619.710	4	140.17 to 150.00	7.60 to 17.43	149.50	157.60	157.93	157.54	157.66	12-Feb-02	98.33	59.21	5-Apr-02	98.60	58.94	15-May-02	99.19	58.47
EW-2D	194009.000	2154637.000	2.5	291.1 to 301.1	32.55 to -142.5	301.40	158.55	158.58	NA	158.24	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-3A	192803.360	2155737.476	4	95.17 to 105.00	52.28 to 62.11	106.00	157.28	159.24	158.92	158.95	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-3B	192823.359	2155736.476	4	125.17 to 135.00	22.32 to 32.15	136.86	157.32	159.36	159.06	159.09	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-3C	192822.360	2155742.476	4	154.17 to 164.00	2.99 to -6.84	165.85	157.16	159.25	158.92	158.95	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-4A	194255.578	2154569.281	4	100.17 to 115	44.86 to 59.69	116.60	159.86	161.81	161.89	161.78	13-Feb-02	102.58	59.31	5-Apr-02	101.68	60.21	16-May-02	102.90	58.88
EW-4B	194249.291	2154569.137	4	120.17 to 130.00	29.8 to 39.63	131.72	159.80	161.91	161.67	161.80	13-Feb-02	101.42	60.25	5-Apr-02	101.72	59.95	16-May-02	102.17	59.63
EW-4C	194242.950	2154569.108	4	145.17 to 155.00	4.59 to 14.42	157.00	159.59	161.68	161.41	161.54	13-Feb-02	101.17	60.24	5-Apr-02	101.47	59.94	16-May-02	101.91	59.63
EW-4D	194268.565	2154585.597	2.5	285 to 295	25.26 to -135.2	295.00	159.74	162.24	NA	161.77	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-5	194051.026	2154443.232	4	165.17 to 175.00	31.16 to -40.99	178.87	134.01	135.81	135.55	136.98	11-Feb-02	77.08	58.47	5-Apr-02	75.43	60.12	15-May-02	78.36	58.62
EW-6A	194695.522	2154111.047	4	63.17 to 73.00	57.66 to 67.49	75.00	130.72	130.76	130.32	/d	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-6B	Abandoned		4	110.17 to 120.00	10.79 to 20.62	NA	NA	130.86	130.61	NA	abandoned			abandoned			abandoned		
EW-6C	194691.623	2154118.917	4	160.67 to 170.50	29.60 to -39.43	168.00	130.79	131.53	130.40	/d	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-7C	194676.000	2154489.000	2.5	189.00 to 199.00	37.47 to -47.43	199.50	151.53	154.14	NA	153.79	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-7D	194677.613	2154479.434	2.5	273.00 to 283.00	21.47 to -131.2	283.50	151.53	153.92	NA	153.71	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-8D	194519.683	2153954.990	2.5	232.00 to 242.00	02.49 to -112.2	242.50	129.51	131.98	NA	131.54	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-9D	194596.601	2154263.993	2.5	244.00 to 254.00	108.6 to -118.6	254.50	135.40	138.07	NA	137.53	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-10C	194593.000	2154734.000	2.5	139.5 to 149.5	19.11 to 9.11	150.00	158.61	161.23	NA	160.94	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-11D	193993.198	2155316.978	2.5	270 to 280	06.75 to -116.3	280.00	163.25	165.75	NA	165.33	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-12D	194110.000	2154849.000	2.5	209.5 to 219.5	47.33 to -57.33	220.00	162.17	164.58	NA	164.42	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-13D	194557.000	2154979.000	2.5	340 to 350	77.28 to -187.2	350.30	162.72	165.01	NA	164.73	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-14D	191632.016	2156477.193	2.5	185 to 195	85.27 to -95.27	195.00	99.73	102.25	NA	102.13	NM	NM	NM	NM	NM	NM	NM	NM	NM
SW-2	194051.190	2154448.258	4	63 to 73	65.10 to 75.10	73.11		102.00	136.93	/d	dry			dry			dry		
DW-2	194063.355	2154430.872	4	95 to 100	37.35 to 42.35	100.79		137.61	136.42		11-Feb-02	86.00	51.61	5-Apr-02	77.45	60.16	15-May-02	78.24	58.18
SW-1	194071.311	2154123.654	4	65 to 70	61.50 to 66.50	70.99		131.31	131.49		11-Feb-07	70.67	60.64	5-Apr-02	70.99	60.32			
DF-1	194070.541	2154132.146	4	93.5 to 98.5	32.89 to 38.39	99.10		131.19	131.38		11-Feb-02	70.67	60.52	5-Apr-02	71.16	60.03	16-May-02	71.72	59.66
LF-02	193617.347	2153592.477	6	110 to 115	3 to 8	102.00	NA	118.70	NA		18-Feb-02	57.75	60.95	NM	NM	NM	NM	NM	NM
PPW-1	194341.106	2154124.530	12/10	300 to 330	66.15 to -196.1	330	133.85	NA	136.74	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
WT-01	194312.475	2154959.015	4	95.4 to 105.4	56.98 to 66.98	107.20	162.94	164.77	164.57	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-6D	192831.355	2154128.481	4	185 to 190	-26.1 to -31.1	190.00	158.90	NA	160.39	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-8A	193670.718	2154228.598	4	85 to 90	48.5 to 53.5	90.00	132.80	133.57	133.18	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-8B	193723.370	2154266.420	4	155 to 160	-22.2 to -27.2	160.00	132.80	NA	134.24	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-8C	193723.373	2154266.424	4	245 to 250	110.7 to -115.7	250.00	134.30	136.26	135.72	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-10B	193334.083	2155374.785	4	173 to 178	-13 to -18	178.00	160.00	162.24	161.12	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-10C	193355.184	2155308.330	4	273 to 278	113.1 to -118.1	278.00	159.90	161.16	160.27	NA	18-Feb-02	101.85	58.42	NM	NM	NM	NM	NM	NM
MW-10D	193341.537	2155310.126	4	346 to 351	186.2 to -191.2	351.00	159.80	161.85	161.17	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
BP-3A	190227.267	2155064.492	4	54 to 74	51 to 71	74.00		124.54	NA	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
BP-3B	190244.367	2155068.492	4	215 to 235	-91 to -111	235.00		123.57	NA	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
BP-3C	190276.367	2155078.492	4	280 to 300	-156 to -176	300.00		123.68	NA	NA	NM	NM	NM	NM	NM	NM	NM	NM	NM
RW-01	194259.860	2154065.580		Abandoned		157 - 170	NA	Abandoned			NM	NM	NM	NM	NM	NM	NM	NM	NM
<b>Extraction Wells</b>																			
EX-1	193746.762	2154315.864	10	5 to 110, 125 to 175		175		134.31	NA	NA	Feb-02	77.94	56.37	NM	NM	NM	29-May-02	80.00	54.31
EX-2	193853.944	2154407.808	10	95 -120, 135 -190		190		146.25	NA	NA	Feb-02	88.27	57.98	NM	NM	NM	29-May-02	NM	NM
EX-3	193997.321	2154530.799	10	94 -194		194		160.69	NA	NA	Feb-02	102.88	57.81	NM	NM	NM	29-May-02	105.00	55.69
<b>Injection Wells</b>																			
IW-1	194419.137	2155036.895	8	133 to 248	29.92 to -85.08	248	162.92	164.88	NA	NA	NM	NM	NM	4-Apr-02	16.40	148.48	15-May-02	4.90	159.98
IW-2	194434.129	2155148.931	8	100 to 250	63.64 to -86.36	250	163.64	165.61	NA	NA	NM	NM	NM	4-Apr-02	19.20	146.41	15-May-02	10.40	155.21
IW-3	194438.720	2155249.932	8	102 to 252	62.25 to -87.75	252	164.25	166.26	NA	NA	NM	NM	NM	4-Apr-02	3.50	162.76	15-May-02	24.10	142.16
IW-4	194315.518	2155244.734	8	100 to 250	63.84 to -86.16	250	163.84	166.09	NA	NA	NM	NM	NM	4-Apr-02	18.10	147.99	15-May-02	16.10	149.99
IG-1'	194391.807	2154916.695																	
IG-3'	194455.720	2155354.682																	

**Notes:**

- a) Well Transducer Reading at time of depth to water readings
- b)
- c)
- d) Pump not installed
- e) Unable to measure depth to water due to low conductivity
- f)
- g) Measured while pump was off
- h) Reference elevation data not available
- i) No access to well
- j) location of 4" cleanout

**Key:**

- ft bgs - feet below ground surface
- ft AMSL - feet above mean sea level
- Ref El - reference elevation
- NM - not measured
- NA - not applicable

**Table 6-1**  
**Groundwater Elevation and Well Construction Data**  
**Claremont Polychemical Superfund Site**  
**Old Bethpage, NY**

Well ID	August 2002			October 2002			November 2002			January 2003			April 2003			July 2003			October 2003		
	Sample Date	Depth to Water Below Ref El <sup>a</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)
EW-1A	6-Aug-02	72.00	58.00	21-Oct-02	72.76	57.24	21-Nov-02	76.62	53.38	22-Jan-03	71.24	58.76	16-Apr-03	69.68	60.32	28-Jul-03	68.94	61.06	22-Oct-03	67.99	62.01
EW-1B	6-Aug-02	73.13	57.40	21-Oct-02	73.99	56.54	21-Nov-02	73.10	57.43	22-Jan-03	71.20	59.33	16-Apr-03	70.15	60.38	28-Jul-03	68.45	62.08	22-Oct-03	69.31	61.22
EW-1C	6-Aug-02	72.52	57.92	21-Oct-02	73.07	57.37	21-Nov-02	72.80	57.64	22-Jan-03	71.54	58.90	16-Apr-03	69.80	60.64	28-Jul-03	68.50	61.94	22-Oct-03	68.11	62.33
EW-2A	7-Aug-02	101.17	56.19		dry		21-Nov-02	100.20	57.16	21-Jan-03	dry			dry			dry		23-Oct-03	95.93	61.43
EW-2B	7-Aug-02	100.42	57.31	23-Oct-02	100.80	56.93	21-Nov-02	100.35	57.38	21-Jan-03	99.38	58.35	15-Apr-03	97.85	59.88	28-Jul-03	96.12	61.61	21-Oct-03	96.15	61.58
EW-2C	7-Aug-02	100.25	57.41	23-Oct-02	100.74	56.92	21-Nov-02	100.30	57.36	21-Jan-03	99.20	58.46	15-Apr-03	97.60	60.06	28-Jul-03	95.90	61.76	21-Oct-03	95.92	61.74
EW-2D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-3A	NM	NM	NM		dry		22-Nov-02	103.90	55.02	NM	NM	NM		dry			dry			dry	
EW-3B	NM	NM	NM	24-Oct-02	104.09	55.00	22-Nov-02	103.96	55.13	NM	NM	NM	15-Apr-03	101.49	57.60	28-Jul-03	98.80	60.29	21-Oct-03	99.33	59.76
EW-3C	NM	NM	NM	24-Oct-02	104.02	54.93	22-Nov-02	103.85	55.10	NM	NM	NM	15-Apr-03	101.15	57.80	28-Jul-03	98.69	60.26	21-Oct-03	98.99	59.96
EW-4A	6-Aug-02	103.49	58.29	23-Oct-02	104.12	57.66	21-Nov-02	103.66	58.12	22-Jan-03	102.52	59.26	16-Apr-03	100.92	60.86	28-Jul-03	99.25	62.53	20-Oct-03	99.45	62.33
EW-4B	6-Aug-02	103.55	58.25	23-Oct-02	104.07	57.73	21-Nov-02	103.70	58.10	22-Jan-03	102.72	59.08	16-Apr-03	100.00	61.80	28-Jul-03	99.29	62.51	20-Oct-03	99.45	62.35
EW-4C	6-Aug-02	103.48	58.06	23-Oct-02	103.92	57.62	21-Nov-02	103.43	58.11	22-Jan-03	102.28	59.26	16-Apr-03	100.65	60.89	28-Jul-03	98.95	62.59	20-Oct-03	99.24	62.30
EW-4D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-5	5-Aug-02	78.75	58.23	22-Oct-02	79.16	57.82	22-Nov-02	78.64	58.34	21-Jan-03	77.43	59.55	15-Apr-03	76.26	60.72	28-Jul-03	74.23	62.75	22-Oct-03	82.70	54.28
EW-6A	NM	NM	NM		dry			dry		NM	NM	NM	16-Apr-03	67.66	62.66	NM	NM	NM		dry	
EW-6B		abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			abandoned	
EW-6C	NM	NM	NM	23-Oct-02	71 (+/-) 1	59.4 (+/-) 1	22-Nov-02	/e	/e	NM	NM	NM	16-Apr-03	68.50	61.90	28-Jul-03	66.90	63.50	23-Oct-03	65.64	64.76
EW-7C	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-7D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-8D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-9D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-10C	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-11D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-12D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-13D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-14D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
SW-2		dry			dry			dry			dry			dry			dry			dry	
DW-2	5-Aug-02	79.50	56.92	22-Oct-02	80.11	56.31	22-Nov-02	79.59	56.83	21-Jan-03	78.58	57.84	15-Apr-03	76.76	59.66	28-Jul-03	75.26	61.16	22-Oct-03	76.49	59.93
SW-1		dry			dry			dry			dry			dry			dry			dry	
DW-1	5-Aug-02	73.12	58.26	22-Oct-02	73.78	57.60	22-Nov-02	73.60	57.78	21-Jan-03	72.40	58.98	17-Apr-03	70.76	60.62	28-Jul-03	69.00	62.38	21-Oct-03	68.97	62.41
LF-02	NM	NM	NM	21-Oct-02	61.01	57.69	19-Nov-02	60.82	57.88	NM	NM	NM	15-Apr-03	57.94	60.76	28-Jul-03	56.18	62.52	23-Oct-03	56.12	62.58
PPW-1	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	23-Oct-03	71.15	62.70
WT-01	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	17-Apr-03	103.19	61.38	28-Jul-03	101.12	63.45	22-Oct-03	100.45	64.12
MW-6D	NM	NM	NM	24-Oct-02	104.20	56.19	NM	NM	NM	NM	NM	NM	16-Apr-03	101.12	59.27	31-Jul-03	99.59	60.80	22-Oct-03	99.39	61.00
MW-8A	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-8B	NM	NM	NM	21-Oct-02	77.49	56.75	NM	NM	NM	NM	NM	NM	16-Apr-03	74.77	59.47	NM	NM	NM	22-Oct-03	72.88	61.36
MW-8C	NM	NM	NM	23-Oct-02	68.55	67.17	NM	NM	NM	NM	NM	NM	16-Apr-03	75.08	60.64	29-Jul-03	73.58	62.14	22-Oct-03	73.55	62.17
MW-10B	NM	NM	NM	24-Oct-02	105.02	56.10	NM	NM	NM	NM	NM	NM	15-Apr-03	102.08	59.04	31-Jul-03	100.82	60.30	22-Oct-03	101.38	59.74
MW-10C	NM	NM	NM	24-Oct-02	104.20	56.07	NM	NM	NM	NM	NM	NM	15-Apr-03	101.20	59.07	30-Jul-03	99.96	60.31	21-Oct-03	99.28	60.99
MW-10D	NM	NM	NM	24-Oct-02	95.00	66.17	NM	NM	NM	NM	NM	NM	15-Apr-03	102.03	59.14	30-Jul-03	100.98	60.19	21-Oct-03	99.34	61.83
BP-3A	NM	NM	NM	21-Oct-02	73.83	50.71	NM	NM	NM	NM	NM	NM	14-Apr-03	70.45	54.09	30-Jul-03	65.48	59.06	NM	NM	NM
BP-3B	NM	NM	NM	25-Oct-02	72.94	50.63	NM	NM	NM	NM	NM	NM	14-Apr-03	69.81	53.76	29-Jul-03	67.29	56.28	20-Oct-03	68.27	55.30
BP-3C	NM	NM	NM	25-Oct-02	73.17	50.51	NM	NM	NM	NM	NM	NM	14-Apr-03	70.02	53.66	29-Jul-03	67.55	56.13	20-Oct-03	68.52	55.16
RW-01	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	17-Apr-03	73.80	/h	24-Jul-03	72.20	/h		abandoned	
EX-1		NM	NM	Oct-02	77.12	57.19	NM	NM	NM	28-Jan-03	76.04	58.27	Apr-03	75.28	59.03	28-Jul-03	73.48	60.83	7-Oct-03	73.30	61.01
EX-2		NM	NM	Oct-02	88.64	57.61	NM	NM	NM	28-Jan-03	88.12	58.13	Apr-03	86.82	59.43	28-Jul-03	85.23	61.02	7-Oct-03	85.12	61.13
EX-3		NM	NM	Oct-02	102.98	57.71	NM	NM	NM	28-Jan-03	102.12	58.57	Apr-03	101.34	59.35	28-Jul-03	99.25	61.44	7-Oct-03	99.01	61.68
IW-1	8-Aug-02	7.21	157.67	28-Oct-02	13.00	151.88	19-Nov-02	7.10	157.78	23-Jan-03	10.72	154.16	Apr-03 <sup>9</sup>	91.99	72.89	28-Jul-03	25.00	139.88	16-Oct-03	2.44	162.44
IW-2	8-Aug-02	15.61	150.00	28-Oct-02	17.93	147.68	19-Nov-02	12.59	153.02	23-Jan-03	22.30	143.31	Apr-03 <sup>9</sup>	101.30	64.31	28-Jul-03	23.30	142.31	16-Oct-03	5.75	159.86
IW-3	8-Aug-02	14.62	151.64	28-Oct-02	2.53	163.73	19-Nov-02	6.10	160.16	23-Jan-03	14.20	152.06	Apr-03 <sup>9</sup>	102.40	63.86	28-Jul-03	88.30	77.96	16-Oct-03	0.00	166.26
IW-4	8-Aug-02	28.78	137.31	28-Oct-02	40.32	125.77	19-Nov-02	56.00	110.09	23-Jan-03	46.31	119.78	Apr-03 <sup>8</sup>	103.30	62.79	28-Jul-03	54.25	111.84	16-Oct-03	29.70	136.39
IG-1 <sup>1</sup>																					
IG-3 <sup>1</sup>																					
Well Transducer Reading at time of depth to water readings																					

**Table 6-1**  
**Groundwater Elevation and Well Construction Data**  
**Claremont Polychemical Superfund Site**  
**Old Bethpage, NY**

Well ID	January 2004			April 2004			July 2004			October 2004			January 2005			April 2005			June 2005		
	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)
EW-1A	19-Jan-04	67.25	62.75	19-Apr-04	67.10	62.90	19-Jul-04	67.11	62.89	18-Oct-04	67.25	62.75	20-Jan-05	66.50	63.50	6-Apr-05	66.13	63.87	9-Jun-05	65.20	64.80
EW-1B	19-Jan-04	67.80	62.73	19-Apr-04	67.53	63.00	19-Jul-04	67.67	62.86	18-Oct-04	67.79	62.74	20-Jan-05	67.10	63.43	6-Apr-05	66.65	63.88	9-Jun-05	65.67	64.86
EW-1C	19-Jan-04	67.70	62.74	19-Apr-04	67.13	63.31	19-Jul-04	67.68	62.76	18-Oct-04	67.65	62.79	20-Jan-05	66.89	63.55	6-Apr-05	66.50	63.94	9-Jun-05	65.74	64.70
EW-2A	19-Jan-04	97.60	59.76	19-Apr-04	95.05	62.31	19-Jul-04	95.20	62.16	18-Oct-04	95.21	62.15	20-Jan-05	94.60	62.76	6-Apr-05	94.54	62.82	9-Jun-05	93.30	64.06
EW-2B	19-Jan-04	95.50	62.23	19-Apr-04	95.20	62.53	19-Jul-04	95.52	62.21	18-Oct-04	95.57	62.16	20-Jan-05	94.74	62.99	6-Apr-05	94.60	63.13	9-Jun-05	93.50	64.23
EW-2C	19-Jan-04	95.30	62.36	19-Apr-04	95.00	62.66	19-Jul-04	95.62	62.04	18-Oct-04	95.62	62.04	20-Jan-05	94.52	63.14	6-Apr-05	94.77	62.89	9-Jun-05	93.45	64.21
EW-2D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-3A	20-Jan-04	98.98	59.94	19-Apr-07	106.00	52.92	19-Jul-04	98.50	60.45	18-Oct-04	98.35	60.60	20-Jan-05	97.50	61.45	6-Apr-05	97.58	61.37	9-Jun-05	96.50	62.45
EW-3B	19-Jan-04	107.90	51.19	19-Apr-04	98.90	60.19	19-Jul-04	98.70	60.39	18-Oct-04	98.48	60.61	20-Jan-05	97.51	61.58	6-Apr-05	97.61	61.48	9-Jun-05	96.56	62.53
EW-3C	19-Jan-04	99.10	59.85	19-Apr-04	98.80	60.15	19-Jul-04	98.60	60.35	18-Oct-04	98.35	60.60	20-Jan-05	97.40	61.55	6-Apr-05	97.50	61.45	9-Jun-05	96.60	62.35
EW-4A	19-Jan-04	98.63	63.15	19-Apr-04	98.50	63.28	19-Jul-04	98.63	63.15	18-Oct-04	98.62	63.16	20-Jan-05	97.90	63.88	6-Apr-05	97.62	64.16	9-Jun-05	96.67	65.11
EW-4B	19-Jan-04	98.63	63.17	19-Apr-04	98.52	63.28	19-Jul-04	98.67	63.13	18-Oct-04	98.64	63.16	20-Jan-05	97.93	63.87	6-Apr-05	97.68	64.12	9-Jun-05	96.71	65.09
EW-4C	19-Jan-04	98.38	63.16	19-Apr-07	93.32	68.22	19-Jul-04	98.38	63.16	18-Oct-04	98.41	63.13	20-Jan-05	97.70	63.84	6-Apr-05	97.43	64.11	9-Jun-05	96.51	65.03
EW-4D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-5	19-Jan-04	74.56	62.42	19-Apr-04	73.70	63.28	19-Jul-04	73.90	63.08	18-Oct-04	74.70	62.28	20-Jan-05	73.89	63.09	6-Apr-05	73.40	63.58	9-Jun-05	72.66	64.32
EW-6A	22-Jan-04	65.49	64.83	19-Apr-07	65.20	65.12	19-Jul-04	65.45	64.87	18-Oct-04	65.37	64.95	20-Jan-05	65.00	65.32	6-Apr-05	64.40	65.92	9-Jun-05	63.33	66.99
EW-6B	abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			abandoned		
EW-6C	19-Jan-04	66.66	63.74	19-Apr-07	65.68	64.72	19-Jul-04	66.13	64.27	18-Oct-04	65.95	64.45	20-Jan-05	65.20	65.20	6-Apr-05	64.82	65.58	9-Jun-05	63.80	66.60
EW-7C	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	20-Jan-05	88.61	65.18	6-Apr-05	88.36	65.43	9-Jun-05	87.68	66.11
EW-7D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	20-Jan-05	88.60	65.11	6-Apr-05	88.35	65.36	9-Jun-05	87.70	66.01
EW-8D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	20-Jan-05	66.56	64.98	6-Apr-05	66.26	65.28	9-Jun-05	71.57	59.97
EW-9D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	20-Jan-05	72.45	65.08	6-Apr-05	72.24	65.29	9-Jun-05	65.69	71.84
EW-10C	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-11D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-12D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-13D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
EW-14D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
SW-2	dry			dry			dry			dry			dry			dry			dry		
DW-2	19-Jan-04	73.60	62.82	19-Apr-07	68.20	68.22	19-Jul-04	74.51	61.91	18-Oct-04	73.80	62.62	20-Jan-05	74.50	61.92	6-Apr-05	73.72	62.70	9-Jun-05	66.31	70.11
SW-1	19-Jan-04	68.40	63.09	19-Apr-04	68.20	63.29	19-Jul-04	68.32	63.17	18-Oct-04	68.36	63.13	20-Jan-05	67.72	63.77	6-Apr-05	67.30	64.19	9-Jun-05	NM	NM
DW-1	19-Jan-04	68.35	63.03	19-Apr-07	74.49	56.89	19-Jul-04	68.25	63.13	18-Oct-04	68.31	63.07	20-Jan-05	67.64	63.74	6-Apr-05	67.23	64.15	9-Jun-05	66.21	65.17
LF-02	22-Jan-04	55.60	63.10	19-Apr-04	55.25	63.45	19-Jul-04	55.55	63.15	18-Oct-04	55.59	63.11	20-Jan-05	54.69	64.01	6-Apr-05	54.29	64.41	10-Jun-05	53.55	65.15
PPW-1	21-Jan-04	69.57	64.28	21-Apr-04	70.33	63.52	20-Jul-04	70.77	63.08	20-Oct-04	70.30	63.55	20-Jan-05	72.32	64.42	6-Apr-05	71.90	64.84	9-Jun-05	71.5	65.24
WT-01	21-Jan-04	100.99	63.58	20-Apr-04	100.68	63.89	20-Jul-04	100.68	63.89	20-Oct-04	100.37	64.20	20-Jan-05	99.65	64.92	6-Apr-05	99.58	64.99	9-Jun-05	98.61	65.96
MW-6D	26-Jan-04	99.31	61.08	19-Apr-04	98.73	61.66	19-Jul-04	98.70	98.73	18-Oct-04	98.66	61.66	20-Jan-05	97.60	98.73	12-Apr-05	97.90	62.49	9-Jun-05	96.67	63.72
MW-8A	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-8B	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-8C	22-Jan-04	73.10	62.62	19-Apr-04	72.85	62.87	19-Jul-04	73.19	62.53	18-Oct-04	73.19	62.53	20-Jan-05	72.17	63.55	11-Apr-05	71.89	63.83	9-Jun-05	71.20	64.52
MW-10B	23-Jan-04	99.95	61.17	20-Apr-04	100.08	61.04	20-Jul-04	100.02	61.10	19-Oct-04	99.73	61.39	20-Jan-05	98.40	62.72	12-Apr-05	97.85	63.27	9-Jun-05	97.65	63.47
MW-10C	22-Jan-04	99.12	61.15	20-Apr-04	98.91	61.36	21-Jul-04	99.02	61.25	20-Oct-04	98.55	61.72	20-Jan-05	97.70	62.57	14-Apr-05	97.12	63.15	9-Jun-05	96.84	63.43
MW-10D	23-Jan-04	100.07	61.10	20-Apr-04	99.65	61.52	21-Jul-04	100.11	61.06	20-Oct-04	99.33	61.84	20-Jan-05	98.68	62.49	14-Apr-05	98.30	62.87	9-Jun-05	97.98	63.19
BP-3A	NM	NM	NM	21-Apr-04	67.32	57.22	21-Jul-04	65.87	58.67	21-Oct-04	65.48	59.06	20-Jan-05	NM	NM	14-Apr-05	64.60	59.94	NM	NM	NM
BP-3B	NM	NM	NM	21-Apr-04	67.77	55.80	21-Jul-04	67.97	55.60	21-Oct-04	66.87	56.70	20-Jan-05	NM	NM	14-Apr-05	65.92	57.65	NM	NM	NM
BP-3C	NM	NM	NM	21-Apr-04	67.97	55.71	21-Jul-04	67.71	55.97	21-Oct-04	67.09	56.59	20-Jan-05	NM	NM	14-Apr-05	66.12	57.56	NM	NM	NM
RW-01	abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			abandoned		
EX-1	NM	NM	NM	28-Apr-04	79.78	54.53	26-Jul-04	80.15	54.16	26-Oct-04 <sup>a</sup>	74.30	60.01	18-Jan-05	79.05	55.26	6-Apr-05	79.79	54.52	9-Jun-05	78.65	55.66
EX-2	NM	NM	NM	28-Apr-04	91.46	54.79	26-Jul-04	99.11	47.14	26-Oct-04	90.37	55.88	18-Jan-05	90.23	56.02	6-Apr-05	89.85	56.40	9-Jun-05	89.07	57.18
EX-3	27-Jan-04	66.40	94.29	28-Apr-04	105.25	55.44	26-Jul-04	105.95	54.74	26-Oct-04	106.01	54.68	18-Jan-05	106.00	54.69	6-Apr-05	97.50	63.19	9-Jun-05	104.68	56.01
IW-1	16-Jan-04	11.30	153.58	19-Apr-04	5.65	159.23	23-Jul-04	100.50	64.38	18-Oct-04	61.88	103.00	20-Jan-05	32.88	132.00	6-Apr-05	29.88	135.00	9-Jun-05	32.88	132.00
IW-2	16-Jan-04	23.97	141.64	19-Apr-04	12.32	153.29	23-Jul-04	40.10	125.51	18-Oct-04	15.61	150.00	20-Jan-05	10.61	155.00	6-Apr-05	18.61	147.00	9-Jun-05	11.61	154.00
IW-3	16-Jan-04	30.00	136.26	19-Apr-04	2.53	163.73	23-Jul-04	100.10	66.16	18-Oct-04	18.26	148.00	20-Jan-05	10.26	156.00	6-Apr-05	13.26	153.00	9-Jun-05	13.26	153.00
IW-4	16-Jan-04	61.62	104.47	19-Apr-04	21.90	144.19	23-Jul-04	81.20	84.89	18-Oct-04	42.09	124.00	20-Jan-05	26.09	140.00	6-Apr-05	16.09	150.00	9-Jun-05	19.09	147.00
IG-1 <sup>a</sup>																					
IG-3 <sup>a</sup>																					
Well Transducer Reading at time of depth to water readings																					

**Table 6-1**  
**Groundwater Elevation and Well Construction Data**  
**Claremont Polychemical Superfund Site**  
**Old Bethpage, NY**

	July 2005			September 2005			January 2006			March 2006			April 2006			May 2006			July 2006		
	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)
Well ID	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)
EW-1A	15-Jul-05	65.40	64.60	27-Sep-05	67.10	62.90	26-Jan-06	63.88	66.12	27-Mar-06	62.94	67.06	5-Apr-06	62.87	67.13	22-May-06	63.00	67.00	18-Jul-06	62.98	67.02
EW-1B	15-Jul-05	65.89	64.64	27-Sep-05	67.65	62.88	26-Jan-06	64.40	66.13	27-Mar-06	63.43	67.10	5-Apr-06	63.37	67.16	22-May-06	63.52	67.01	18-Jul-06	62.54	67.99
EW-1C	15-Jul-05	65.91	64.53	27-Sep-05	67.85	62.59	26-Jan-06	64.00	66.44	27-Mar-06	63.53	66.91	5-Apr-06	63.07	67.37	22-May-06	63.61	66.83	18-Jul-06	63.26	67.18
EW-2A	15-Jul-05	93.55	63.81	27-Sep-05	95.54	61.82	26-Jan-06	91.84	65.52	27-Mar-06	91.11	66.25	5-Apr-06	90.97	66.39	22-May-06	91.15	66.21	18-Jul-06	91.11	66.25
EW-2B	15-Jul-05	93.79	63.94	27-Sep-05	95.71	62.02	26-Jan-06	92.08	65.65	27-Mar-06	91.44	66.29	5-Apr-06	91.25	66.48	22-May-06	91.51	66.22	18-Jul-06	91.59	66.14
EW-2C	15-Jul-05	93.91	63.75	27-Sep-05	97.74	59.92	26-Jan-06	92.34	65.32	27-Mar-06	91.65	66.01	5-Apr-06	91.53	66.13	22-May-06	91.73	65.93	18-Jul-06	91.77	65.89
EW-2D	NM	NM	NM	NM	NM	NM	26-Jan-06	92.34	65.90	27-Mar-06	91.44	66.80	5-Apr-06	91.25	66.99	22-May-06	91.38	66.86	18-Jul-06	91.58	66.66
EW-3A	15-Jul-05	96.74	62.21	27-Sep-05	98.58	60.37	26-Jan-06	95.28	63.67	27-Mar-06	94.36	64.59	5-Apr-06	94.40	64.55	22-May-06	94.41	64.54	18-Jul-06	94.45	64.50
EW-3B	15-Jul-05	96.98	62.11	27-Sep-05	98.90	60.19	26-Jan-06	95.32	63.77	27-Mar-06	94.60	64.49	5-Apr-06	94.50	64.55	22-May-06	94.59	64.50	18-Jul-06	94.64	64.45
EW-3C	15-Jul-05	96.89	62.06	27-Sep-05	98.82	60.13	26-Jan-06	95.20	63.75	27-Mar-06	94.50	64.45	5-Apr-06	94.44	64.51	22-May-06	94.48	64.47	18-Jul-06	94.58	64.37
EW-4A	15-Jul-05	96.97	64.81	27-Sep-05	98.74	63.04	26-Jan-06	95.35	66.43	27-Mar-06	94.46	67.32	5-Apr-06	94.41	67.37	22-May-06	94.44	67.34	18-Jul-06	94.50	67.28
EW-4B	15-Jul-05	97.00	64.80	27-Sep-05	98.80	63.00	26-Jan-06	95.38	66.42	27-Mar-06	94.58	67.22	5-Apr-06	94.45	67.35	22-May-06	94.50	67.30	18-Jul-06	94.54	67.26
EW-4C	15-Jul-05	96.78	64.76	27-Sep-05	98.50	63.04	26-Jan-06	95.16	66.38	27-Mar-06	94.33	67.21	5-Apr-06	94.25	67.29	22-May-06	94.19	67.35	18-Jul-06	94.33	67.21
EW-4D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	18-Jul-06	94.44	67.33
EW-5	15-Jul-05	72.20	64.78	27-Sep-05	73.62	63.36	26-Jan-06	70.15	66.83	27-Mar-06	69.75	67.23	5-Apr-06	69.80	67.18	22-May-06	69.39	67.59	18-Jul-06	69.75	67.23
EW-6A	15-Jul-05	63.80	66.52	27-Sep-05	65.00	65.32	26-Jan-06	62.50	67.82	27-Mar-06	61.40	68.92	5-Apr-06	61.40	68.92	22-May-06	61.14	69.18	18-Jul-06	61.00	69.32
EW-6B	abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			abandoned		
EW-6C	15-Jul-05	64.20	66.20	27-Sep-05	65.49	64.91	26-Jan-06	62.28	68.12	27-Mar-06	61.49	68.91	5-Apr-06	61.81	68.59	22-May-06	61.19	69.21	18-Jul-06	61.80	68.60
EW-7C	15-Jul-05	88.10	65.69	27-Sep-05	89.61	64.18	26-Jan-06	86.18	67.61	27-Mar-06	85.40	68.39	5-Apr-06	85.43	68.36	22-May-06	85.28	68.51	18-Jul-06	85.50	68.29
EW-10B	15-Jul-05	88.10	65.61	27-Sep-05	89.87	63.84	26-Jan-06	86.18	67.53	27-Mar-06	85.40	68.31	5-Apr-06	85.44	68.27	22-May-06	85.30	68.41	18-Jul-06	85.50	68.21
EW-8D	15-Jul-05	66.05	65.49	27-Sep-05	67.80	63.74	26-Jan-06	64.10	67.44	27-Mar-06	63.30	68.24	5-Apr-06	63.32	68.23	22-May-06	63.39	68.15	18-Jul-06	63.52	68.02
EW-9D	15-Jul-05	71.94	65.59	3-Oct-05	73.49	64.04	26-Jan-06	70.03	67.50	27-Mar-06	69.25	68.28	5-Apr-06	69.30	68.22	22-May-06	69.20	68.33	18-Jul-06	69.40	68.13
EW-10C	NM	NM	NM	NM	NM	NM	26-Jan-06	93.44	67.50	27-Mar-06	92.60	68.34	5-Apr-06	92.57	68.37	22-May-06	92.35	68.59	18-Jul-06	92.62	68.32
EW-11D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	22-May-06	98.33	67.00	18-Jul-06	98.65	66.68
EW-12D	NM	NM	NM	NM	NM	NM	26-Jan-06	98.03	66.39	27-Mar-06	97.21	67.21	5-Apr-06	97.16	67.26	22-May-06	97.30	67.12	18-Jul-06	97.30	67.12
EW-13D	NM	NM	NM	NM	NM	NM	26-Jan-06	98.16	66.57	27-Mar-06	97.41	67.32	5-Apr-06	97.37	67.36	22-May-06	NM	NM	18-Jul-06	97.50	67.23
EW-14D	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	22-May-06	39.49	62.64	18-Jul-06	39.53	62.60
SW-2	dry			dry			dry			dry			dry			dry			dry		
DW-2	15-Jul-05	72.80	63.62	27-Sep-05	75.61	60.81	26-Jan-06	71.25	65.17	27-Mar-06	70.43	65.99	5-Apr-06	70.50	65.92	22-May-06	70.34	66.08	18-Jul-06	70.55	65.87
SW-1	15-Jul-05	66.60	64.89	27-Sep-05	68.35	63.14	26-Jan-06	65.10	66.39	27-Mar-06	64.13	67.36	5-Apr-06	64.10	67.39	22-May-06	64.18	67.31	18-Jul-06	64.20	67.29
DF-1	15-Jul-05	66.52	64.86	27-Sep-05	68.29	63.09	26-Jan-06	65.00	66.38	27-Mar-06	64.04	67.34	5-Apr-06	64.02	67.36	22-May-06	64.03	67.35	18-Jul-06	64.10	67.28
LF-02	15-Jul-05	53.81	64.89	28-Sep-05	55.46	63.24	26-Jan-06	52.20	66.50	27-Mar-06	51.35	67.35	5-Apr-06	51.59	67.11	22-May-06	51.41	67.29	18-Jul-06	51.50	67.20
PPW-1	15-Jul-05	71.87	64.87	27-Sep-05	73.50	63.24	26-Jan-06	69.70	67.04	27-Mar-06	69.06	67.68	5-Apr-06	69.06	67.68	22-May-06	69.03	67.71	18-Jul-06	69.37	67.37
WT-01	15-Jul-05	99.06	65.51	27-Sep-05	100.70	63.87	26-Jan-06	97.45	67.12	27-Mar-06	96.50	68.07	5-Apr-06	96.40	68.17	22-May-06	96.48	68.09	18-Jul-06	96.60	67.97
MW-6D	15-Jul-05	96.93	63.46	27-Sep-05	98.64	61.75	26-Jan-06	95.31	65.08	27-Mar-06	94.44	65.95	5-Apr-06	94.42	65.97	22-May-06	94.58	65.81	18-Jul-06	94.72	65.67
MW-8A	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
MW-8B	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	22-May-06	NM	NM	18-Jul-06	NM	NM
MW-8C	15-Jul-05	71.56	64.16	27-Sep-05	73.30	62.42	26-Jan-06	69.53	66.19	27-Mar-06	68.94	66.78	5-Apr-06	68.75	66.97	22-May-06	69.00	66.72	18-Jul-06	69.00	66.72
MW-10B	15-Jul-05	97.99	63.13	27-Sep-05	99.85	61.27	26-Jan-06	95.20	65.92	27-Mar-06	95.60	65.52	5-Apr-06	95.51	65.61	22-May-06	95.60	65.52	18-Jul-06	95.70	65.42
MW-10C	15-Jul-05	97.23	63.04	27-Sep-05	99.02	61.25	26-Jan-06	95.50	64.77	27-Mar-06	95.20	65.07	5-Apr-06	94.65	65.62	22-May-06	94.69	65.58	18-Jul-06	94.80	65.47
MW-10D	15-Jul-05	97.30	63.87	27-Sep-05	100.15	61.02	26-Jan-06	96.10	65.07	27-Mar-06	95.68	65.49	5-Apr-06	95.62	65.55	22-May-06	95.60	65.57	18-Jul-06	95.90	65.27
BP-3A	21-Jul-05	63.08	61.46	6-Oct-05	65.50	59.04	2-Feb-06	62.20	62.34	NM	NM	NM	13-Apr-06	61.45	63.09	22-May-06	NM	NM	27-Jul-06	60.99	63.55
BP-3B	21-Jul-05	66.04	57.53	6-Oct-05	68.18	55.39	NM	NM	NM	NM	NM	NM	13-Apr-06	63.89	59.68	22-May-06	NM	NM	27-Jul-06	NM	NM
BP-3C	21-Jul-05	66.29	57.39	6-Oct-05	68.42	55.26	NM	NM	NM	NM	NM	NM	13-Apr-06	64.10	59.58	22-May-06	NM	NM	27-Jul-06	NM	NM
RW-01	abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			abandoned		
EX-1	13-Jul-05	79.30	55.01	27-Sep-05	81.31	53.00	26-Jan-06	69.15	65.16	27-Mar-06	77.70	56.61	5-Apr-06	76.70	57.61	22-May-06	68.31	66.00	18-Jul-06	68.38	65.93
EX-2	21-Jul-05	89.61	56.64	27-Sep-05	91.90	54.35	26-Jan-06	81.23	65.02	27-Mar-06	87.93	58.32	5-Apr-06	87.90	58.35	22-May-06	80.35	65.90	18-Jul-06	87.95	58.30
EX-3	15-Jul-05	105.15	55.54	27-Sep-05	107.20	53.49	26-Jan-06	95.13	65.56	27-Mar-06	103.34	57.35	5-Apr-06	103.50	57.19	22-May-06	94.34	66.35	18-Jul-06	103.82	56.87
IW-1	15-Jul-05	34.88	130.00	27-Sep-05	29.88	135.00	26-Jan-06	20.88	144.00	27-Mar-06	33.88	131.00	5-Apr-06	18.88	146.00	22-May-06	19.88	145.00	18-Jul-06	22.88	142.00
IW-2	15-Jul-05	10.61	155.00	27-Sep-05	8.61	157.00	26-Jan-06	13.61	152.00	27-Mar-06	21.61	144.00	5-Apr-06	31.61	134.00	22-May-06	24.61	141.00	18-Jul-06	18.88	146.00
IW-3	15-Jul-05	12.26	154.00	27-Sep-05	14.26	152.00	26-Jan-06	11.26	155.00	27-Mar-06	17.26	149.00	5-Apr-06	26.26	140.00	22-May-06	21.26	145.00	18-Jul-06	13.88	151.00
IW-4	15-Jul-05	17.09	149.00	27-Sep-05	19.09	147.00	26-Jan-06	13.09	153.00	27-Mar-06	25.09	141.00	5-Apr-06	16.09	150.00	22-May-06	13.09	153.00	18-Jul-06	10.88	154.00
IG-1 <sup>a</sup>																					
IG-3 <sup>a</sup>																					
Well Transducer Reading at time of depth to water readings																					



**Table 6-1**  
**Groundwater Elevation and Well Construction Data**  
**Claremont Polychemical Superfund Site**  
**Old Bethpage, NY**

Well ID	October 2006			January 2007			May 2007			July 2007			October 2007			January 2008			April 2008			
	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)	
EW-1A	07-Oct-06	63.98	66.02	4-Jan-07	63.55	66.45	11-May-07	62.21	67.79	5-Jul-07	62.49	67.51	5-Oct-07	62.54	67.46	8-Jan-08	62.95	67.05	10-Apr-08	62.49	67.51	14-Jul-08
EW-1B	07-Oct-06	64.51	66.02	4-Jan-07	64.03	66.50	11-May-07	62.71	67.82	5-Jul-07	63.01	67.52	5-Oct-07	63.03	67.50	8-Jan-08	63.90	66.63	10-Apr-08	63.00	67.53	14-Jul-08
EW-1C	07-Oct-06	64.69	65.75	4-Jan-07	63.99	66.45	11-May-07	62.51	67.93	5-Jul-07	63.14	67.30	5-Oct-07	62.72	67.72	8-Jan-08	63.69	66.75	10-Apr-08	62.71	67.73	14-Jul-08
EW-2A	07-Oct-06	92.40	64.96	4-Jan-07	91.79	65.57	11-May-07	90.25	67.11	5-Jul-07	90.67	66.69	5-Oct-07	90.71	66.65	8-Jan-08	91.35	66.01	10-Apr-08	90.72	66.64	16-Jul-08
EW-2B	07-Oct-06	92.54	65.19	4-Jan-07	92.10	65.63	11-May-07	90.44	67.29	5-Jul-07	91.19	66.54	5-Oct-07	90.82	66.91	8-Jan-08	91.54	66.19	10-Apr-08	90.98	66.75	14-Jul-08
EW-2C	07-Oct-06	92.75	64.91	4-Jan-07	92.29	65.37	11-May-07	90.35	67.31	5-Jul-07	91.32	66.34	5-Oct-07	90.64	67.02	8-Jan-08	91.82	65.84	10-Apr-08	91.25	66.41	14-Jul-08
EW-2D	07-Oct-06	92.54	65.70	4-Jan-07	91.81	66.43	11-May-07	90.75	67.49	5-Jul-07	91.00	67.24	5-Oct-07	90.91	67.33	8-Jan-08	91.40	66.84	10-Apr-08	90.85	67.39	16-Jul-08
EW-3A	07-Oct-06	95.70	63.25	4-Jan-07	95.21	63.74	11-May-07	94.12	64.83	5-Jul-07	94.00	64.95	5-Oct-07	94.35	64.60	8-Jan-08	94.89	64.06	10-Apr-08	94.21	64.74	14-Jul-08
EW-3B	07-Oct-06	95.84	63.25	4-Jan-07	95.33	63.76	11-May-07	94.22	64.87	5-Jul-07	94.30	64.79	5-Oct-07	94.58	64.51	8-Jan-08	95.09	64.00	10-Apr-08	94.32	64.77	14-Jul-08
EW-3C	07-Oct-06	95.72	63.23	4-Jan-07	95.22	63.73	11-May-07	94.09	64.86	5-Jul-07	94.22	64.73	5-Oct-07	94.48	64.47	8-Jan-08	95.01	63.94	10-Apr-08	94.21	64.74	17-Jul-08
EW-4A	07-Oct-06	95.40	66.38	4-Jan-07	95.03	66.75	11-May-07	93.80	67.98	5-Jul-07	94.02	67.76	5-Oct-07	94.18	67.60	8-Jan-08	94.98	66.80	10-Apr-08	94.10	67.68	15-Jul-08
EW-4B	07-Oct-06	95.44	66.36	4-Jan-07	95.08	66.72	11-May-07	93.81	67.99	5-Jul-07	94.08	67.72	5-Oct-07	94.22	67.58	8-Jan-08	95.52	66.28	10-Apr-08	94.12	67.68	15-Jul-08
EW-4C	07-Oct-06	95.15	66.39	4-Jan-07	94.75	66.79	11-May-07	93.62	67.92	5-Jul-07	93.80	67.74	5-Oct-07	93.95	67.59	8-Jan-08	94.61	66.93	10-Apr-08	93.82	67.72	16-Jul-08
EW-4D	07-Oct-06	95.22	66.55	4-Jan-07	94.56	67.21	11-May-07	93.95	67.82	5-Jul-07	93.82	67.95	5-Oct-07	94.02	67.75	8-Jan-08	94.59	67.18	10-Apr-08	93.82	67.95	14-Jul-08
EW-5	07-Oct-06	70.57	66.41	4-Jan-07	69.83	67.15	11-May-07	69.24	67.74	5-Jul-07	68.83	68.15	5-Oct-07	69.04	67.94	8-Jan-08	70.00	66.98	10-Apr-08	69.03	67.95	15-Jul-08
EW-6A	07-Oct-06	61.75	68.57	4-Jan-07	61.72	68.60	11-May-07	60.43	69.89	5-Jul-07	60.80	69.52	5-Oct-07	61.01	69.31	8-Jan-08	61.69	68.63	10-Apr-08	61.28	69.04	17-Jul-08
EW-6B	abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			
EW-6C	07-Oct-06	62.75	67.65	4-Jan-07	62.28	68.12	11-May-07	61.00	69.40	5-Jul-07	61.80	68.60	5-Oct-07	61.30	69.10	8-Jan-08	62.00	68.40	10-Apr-08	61.30	69.10	17-Jul-08
EW-7C	07-Oct-06	86.34	67.45	4-Jan-07	85.68	68.11	11-May-07	84.96	68.83	5-Jul-07	85.02	68.77	5-Oct-07	85.11	68.68	8-Jan-08	85.58	68.21	10-Apr-08	85.20	68.59	14-Jul-08
EW-7D	07-Oct-06	86.35	67.36	4-Jan-07	85.68	68.03	11-May-07	84.75	68.96	5-Jul-07	85.03	68.68	5-Oct-07	85.14	68.57	8-Jan-08	85.52	68.19	10-Apr-08	85.10	68.61	14-Jul-08
EW-8D	07-Oct-06	64.38	67.16	4-Jan-07	63.64	67.90	11-May-07	62.66	68.88	5-Jul-07	62.95	68.59	5-Oct-07	63.02	68.52	8-Jan-08	63.42	68.12	10-Apr-08	62.95	68.59	14-Jul-08
EW-9D	07-Oct-06	70.25	67.28	4-Jan-07	69.62	67.91	11-May-07	68.70	68.83	5-Jul-07	68.90	68.63	5-Oct-07	69.00	68.53	8-Jan-08	69.49	68.04	10-Apr-08	68.80	68.73	14-Jul-08
EW-10C	07-Oct-06	93.49	67.45	4-Jan-07	93.00	67.94	11-May-07	92.22	68.72	5-Jul-07	92.00	68.94	5-Oct-07	92.26	68.68	8-Jan-08	92.88	68.06	10-Apr-08	92.33	68.61	14-Jul-08
EW-11D	07-Oct-06	99.62	65.71	4-Jan-07	98.88	66.45	11-May-07	98.35	66.98	5-Jul-07	98.22	67.11	5-Oct-07	98.30	67.03	8-Jan-08	98.95	66.38	10-Apr-08	96.25	69.08	14-Jul-08
EW-12D	07-Oct-06	98.27	66.15	4-Jan-07	97.77	66.65	11-May-07	97.10	67.32	5-Jul-07	96.87	67.55	5-Oct-07	97.10	67.32	8-Jan-08	97.54	66.88	10-Apr-08	97.10	67.32	14-Jul-08
EW-13D	07-Oct-06	98.48	66.25	4-Jan-07	97.49	67.24	11-May-07	96.76	67.97	5-Jul-07	97.01	67.72	5-Oct-07	97.10	67.63	8-Jan-08	97.54	67.19	10-Apr-08	97.86	66.87	14-Jul-08
EW-14D	07-Oct-06	41.02	61.11	4-Jan-07	43.50	58.63	15-May-06	39.09	63.04	5-Jul-07	39.50	62.63	gate locked			8-Jan-08	40.47	61.66	10-Apr-08	39.31	62.82	14-Jul-08
SW-2	dry			dry			dry			dry			dry			dry			dry			
DW-2	07-Oct-06	71.44	64.98	4-Jan-07	79.90	56.52	11-May-07	69.65	66.77	5-Jul-07	69.80	66.62	5-Oct-07	70.01	66.41	8-Jan-08	71.68	64.74	10-Apr-08	69.99	66.43	15-Jul-08
SW-1	07-Oct-06	65.03	66.46	4-Jan-07	64.73	66.76	11-May-07	63.40	68.09	5-Jul-07	63.70	67.79	5-Oct-07	63.80	67.69	8-Jan-08	64.59	66.90	10-Apr-08	63.74	67.75	15-Jul-08
DW-1	07-Oct-06	64.95	66.43	4-Jan-07	64.62	66.76	11-May-07	63.30	68.08	5-Jul-07	63.57	67.81	5-Oct-07	64.01	67.37	8-Jan-08	64.10	67.28	10-Apr-08	63.64	67.74	15-Jul-08
LF-02	11-Oct-06	40.02	78.68	4-Jan-07	51.65	67.05	11-May-07	50.89	67.81	5-Jul-07	50.80	67.90	5-Oct-07	50.70	68.00	8-Jan-08	51.20	67.50	10-Apr-08	50.70	68.00	16-Jul-08
PPW-1	07-Oct-06	70.23	66.51	4-Jan-07	69.34	67.40	11-May-07	68.66	68.08	5-Jul-07	68.20	68.54	5-Oct-07	68.88	67.86	8-Jan-08	69.14	67.60	10-Apr-08	68.62	68.12	16-Jul-08
WT-01	07-Oct-06	97.54	67.03	4-Jan-07	97.58	66.99	11-May-07	96.35	68.22	5-Jul-07	96.50	68.07	5-Oct-07	96.01	68.56	8-Jan-08	96.60	67.97	10-Apr-08	96.13	68.44	16-Jul-08
MW-6D	07-Oct-06	95.95	64.44	4-Jan-07	94.80	65.59	11-May-07	94.00	66.39	5-Jul-07	93.90	66.49	10-Oct-07	93.80	66.59	8-Jan-08	94.40	65.99	10-Apr-08	93.88	66.51	16-Jul-08
MW-8A	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
MW-8B	07-Oct-06	NM	NM	4-Jan-07	NM	NM	11-May-07	NM	NM	5-Jul-07	NM	NM	10-Oct-07	67.64	NM	8-Jan-08	67.41	56.27	10-Apr-08	67.80	66.44	15-Jul-08
MW-8C	07-Oct-06	70.20	65.52	4-Jan-07	69.38	66.34	11-May-07	68.20	67.52	5-Jul-07	68.65	67.07	10-Oct-07	68.53	67.19	8-Jan-08	69.19	66.53	10-Apr-08	68.50	67.22	16-Jul-08
MW-10B	07-Oct-06	96.79	64.33	4-Jan-07	96.20	64.92	11-May-07	95.20	65.92	5-Jul-07	95.25	65.87	10-Oct-07	95.52	65.60	8-Jan-08	95.84	65.28	10-Apr-08	95.28	65.84	15-Jul-08
MW-10C	07-Oct-06	95.56	64.71	4-Jan-07	95.23	65.04	11-May-07	95.10	65.17	5-Jul-07	94.30	65.97	10-Oct-07	94.48	65.79	8-Jan-08	94.90	65.37	10-Apr-08	94.32	65.95	15-Jul-08
MW-10D	07-Oct-06	97.05	64.12	4-Jan-07	96.00	65.17	11-May-07	94.22	66.95	5-Jul-07	95.40	65.77	10-Oct-07	95.52	65.65	8-Jan-08	95.78	65.39	10-Apr-08	95.18	65.99	15-Jul-08
BP-3A	12-Oct-06	62.27	62.27	18-Jan-07	62.87	61.67	16-May-07	61.47	63.07	12-Jul-07	61.29	63.25	5-Oct-07	61.15	63.39	8-Jan-08	62.91	61.63	10-Apr-08	62.18	62.36	16-Jul-08
BP-3B	12-Oct-06	65.27	58.30	18-Jan-07	64.57	59.00	16-May-07	63.35	NM	12-Jul-07	63.84	59.73	5-Oct-07	NM	NM	8-Jan-08	64.61	58.96	10-Apr-08	NM	NM	17-Jul-08
BP-3C	12-Oct-06	65.50	58.18	18-Jan-07	62.92	60.76	16-May-07	63.56	NM	12-Jul-07	NM	NM	5-Oct-07	NM	NM	8-Jan-08	64.83	58.85	10-Apr-08	NM	NM	17-Jul-08
RW-01	abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			
EX-1	07-Oct-06	79.75	54.56	4-Jan-07	72.27	62.04	10-May-07	NM	NM	5-Jul-07	NM	NM	5-Oct-07	NM	NM	NM	NM	NM	NM	NM	NM	NM
EX-2	07-Oct-06	89.35	56.90	4-Jan-07	88.86	57.39	11-May-07	87.90	58.35	5-Jul-07	80.30	65.95	5-Oct-07	88.31	57.94	NM	NM	NM	NM	NM	NM	NM
EX-3	07-Oct-06	102.96	57.73	4-Jan-07	104.88	55.81	11-May-07	85.57	75.12	5-Jul-07												

**Table 6-1**  
**Groundwater Elevation and Well Construction Data**  
**Claremont Polychemical Superfund Site**  
**Old Bethpage, NY**

July 2008			October 2008			January 2009			April 2009			July 2009			October 2009			Jan-10			Apr-10			
	Depth to Water Below Ref El <sup>b</sup>	Water Elevation (ft AMSL)		Depth to Water Below Ref El <sup>b</sup> (ft)	Water Elevation (ft AMSL)		Depth to Water Below Ref El <sup>b</sup> (ft)	Water Elevation (ft AMSL)		Depth to Water Below Ref El <sup>b</sup> (ft)	Water Elevation (ft AMSL)		Depth to Water Below Ref El <sup>b</sup> (ft)	Water Elevation (ft AMSL)		Depth to Water Below Ref El <sup>b</sup> (ft)	Water Elevation (ft AMSL)		Depth to Water Below Ref El <sup>b</sup> (ft)	Water Elevation (ft AMSL)		Depth to Water Below Ref El <sup>b</sup> (ft)	Water Elevation (ft AMSL)	
	Well ID		Sample Date			Sample Date			Sample Date			Sample Date			Sample Date			Sample Date			Sample Date			
EW-1A	62.97	67.03	7-Oct-08	63.58	66.42	12-Jan-09	63.22	66.78	6-Apr-09	62.54	67.46	13-Jul-09	62.85	67.15	19-Oct-09	64.00	66.00	14-Jan-10	64.85	65.15	1-Apr-10	63.30	66.70	8-Jul-10
EW-1B	63.86	66.67	7-Oct-08	64.38	66.15	12-Jan-09	63.82	66.71	6-Apr-09	63.22	67.31	13-Jul-09	63.63	66.90	19-Oct-09	64.50	66.03	14-Jan-10	64.50	66.03	1-Apr-10	63.87	66.66	8-Jul-10
EW-1C	63.72	66.72	7-Oct-08	64.30	66.14	12-Jan-09	63.84	66.60	6-Apr-09	63.07	67.37	13-Jul-09	63.79	66.65	19-Oct-09	64.90	65.54	14-Jan-10	64.20	66.24	1-Apr-10	63.73	66.71	8-Jul-10
EW-2A	91.53	65.83	9-Oct-08	91.59	65.77	12-Jan-09	91.90	65.46	7-Apr-09	90.45	66.91	13-Jul-09	90.93	66.43	20-Oct-09	92.41	64.95	14-Jan-10	92.65	64.71	1-Apr-10	91.28	66.08	8-Jul-10
EW-2B	91.80	65.93	10-Oct-08	92.65	65.08	12-Jan-09	91.40	66.33	7-Apr-09	11.38	146.36	13-Jul-09	91.56	66.17	20-Oct-09	92.56	65.17	14-Jan-10	92.65	65.08	1-Apr-10	91.58	66.15	13-Jul-10
EW-2C	91.35	66.31	9-Oct-08	92.40	65.26	12-Jan-09	91.79	65.87	7-Apr-09	91.20	66.46	14-Jul-09	91.73	65.93	21-Oct-09	92.57	65.09	14-Jan-10	93.12	64.54	1-Apr-10	91.50	66.16	14-Jul-10
EW-2D	91.79	66.45	7-Oct-08	92.18	66.06	13-Jan-09	91.62	66.62	7-Apr-09	91.28	66.96	14-Jul-09	91.81	66.43	20-Oct-09	92.64	65.60	19-Jan-10	92.33	65.91	6-Apr-10	90.65	67.59	13-Jul-10
EW-3A	94.64	64.31	8-Oct-08	95.15	63.80	13-Jan-09	94.83	64.12	8-Apr-09	94.60	64.35	14-Jul-09	94.78	64.17	19-Oct-09	95.65	63.30	15-Jan-10	95.50	63.45	5-Apr-10	94.28	64.67	9-Jul-10
EW-3B	94.96	64.13	8-Oct-08	95.48	63.61	13-Jan-09	94.75	64.34	8-Apr-09	94.93	64.16	14-Jul-09	94.93	64.16	19-Oct-09	95.96	63.13	15-Jan-10	95.86	63.23	5-Apr-10	94.13	64.96	9-Jul-10
EW-3C	94.85	64.10	8-Oct-08	95.24	63.71	13-Jan-09	94.69	64.26	7-Apr-09	94.84	64.11	14-Jul-09	94.75	64.20	19-Oct-09	95.83	63.12	15-Jan-10	96.75	62.20	5-Apr-10	94.10	64.85	9-Jul-10
EW-4A	95.20	66.58	7-Oct-08	95.50	66.28	13-Jan-09	94.90	66.88	6-Apr-09	94.68	67.10	14-Jul-09	95.10	66.68	20-Oct-09	97.20	64.58	15-Jan-10	95.64	66.14	5-Apr-10	94.55	67.23	9-Jul-10
EW-4B	94.76	67.04	7-Oct-08	95.68	66.12	13-Jan-09	95.00	66.80	7-Apr-09	94.62	67.18	14-Jul-09	95.32	66.48	20-Oct-09	97.00	64.80	15-Jan-10	96.35	65.45	5-Apr-10	94.84	66.96	9-Jul-10
EW-4C	94.77	66.77	7-Oct-08	95.15	66.39	13-Jan-09	94.20	67.34	7-Apr-09	94.25	67.29	14-Jul-09	94.57	66.97	20-Oct-09	95.92	65.62	15-Jan-10	96.10	65.44	5-Apr-10	94.12	67.42	9-Jul-10
EW-4D	94.85	66.92	6-Oct-08	95.33	66.44	12-Jan-09	94.48	67.29	6-Apr-09	94.20	67.57	13-Jul-09	94.56	67.21	19-Oct-09	95.65	66.12	18-Jan-10	95.42	66.35	5-Apr-10	94.07	67.70	12-Jul-10
EW-5	70.50	66.48	8-Oct-08	70.55	66.43	14-Jan-09	69.63	67.35	8-Apr-09	69.65	67.33	15-Jul-09	69.50	67.48	21-Oct-09	72.32	64.66	19-Jan-10	71.70	65.28	6-Apr-10	69.19	67.79	13-Jul-10
EW-6A	61.84	68.48	7-Oct-08	62.31	68.01	14-Jan-09	61.55	68.77	7-Apr-09	61.28	69.04	14-Jul-09	61.51	68.81	20-Oct-09	62.62	67.70	19-Jan-10	61.77	68.55	7-Apr-10	60.95	69.37	13-Jul-10
EW-6B	abandoned		abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			abandoned			
EW-6C	62.30	68.10	7-Oct-08	62.80	67.60	13-Jan-09	61.89	68.51	7-Apr-09	61.94	68.46	14-Jul-09	62.10	68.30	20-Oct-09	63.18	67.22	19-Jan-10	62.56	67.84	7-Apr-10	61.30	69.10	13-Jul-10
EW-7C	85.83	67.96	6-Oct-08	86.39	67.40	12-Jan-09	85.69	68.10	6-Apr-09	97.43	56.36	13-Jul-09	85.68	68.11	19-Oct-09	86.80	66.99	18-Jan-10	86.17	67.62	5-Apr-10	84.98	68.81	12-Jul-10
EW-7D	85.85	67.86	6-Oct-08	86.35	67.36	12-Jan-09	85.53	68.18	6-Apr-09	97.35	56.36	13-Jul-09	85.64	68.07	19-Oct-09	86.86	66.85	18-Jan-10	86.24	67.47	5-Apr-10	85.05	68.66	12-Jul-10
EW-8D	63.68	67.86	6-Oct-08	64.24	67.30	12-Jan-09	63.49	68.05	6-Apr-09	63.13	68.41	13-Jul-09	63.51	68.03	19-Oct-09	64.70	66.84	18-Jan-10	64.08	67.46	5-Apr-10	62.92	68.62	12-Jul-10
EW-9D	69.58	67.95	6-Oct-08	70.15	67.38	12-Jan-09	69.40	68.13	6-Apr-09	69.27	68.26	13-Jul-09	69.62	67.91	19-Oct-09	70.68	66.85	18-Jan-10	70.21	67.32	5-Apr-10	68.99	68.54	12-Jul-10
EW-10C	92.93	68.01	7-Oct-08	93.59	67.35	13-Jan-09	92.84	68.10	6-Apr-09	92.62	68.32	13-Jul-09	92.93	68.01	19-Oct-09	94.03	66.91	18-Jan-10	93.26	67.68	5-Apr-10	92.00	68.94	13-Jul-10
EW-11D	99.07	66.26	6-Oct-08	99.52	65.81	13-Jan-09	98.72	66.61	6-Apr-09	98.63	66.70	13-Jul-09	98.93	66.40	19-Oct-09	100.06	65.27	18-Jan-10	99.65	65.68	5-Apr-10	97.92	67.41	12-Jul-10
EW-12D	97.86	66.56	6-Oct-08	98.35	66.07	13-Jan-09	97.73	66.69	6-Apr-09	97.35	67.07	13-Jul-09	97.85	66.57	19-Oct-09	98.91	65.51	18-Jan-10	98.36	66.06	5-Apr-10	96.93	67.49	12-Jul-10
EW-13D	97.94	66.79	6-Oct-08	98.25	66.48	12-Jan-09	97.38	67.35	6-Apr-09	97.30	67.43	13-Jul-09	97.70	67.03	19-Oct-09	98.72	66.01	18-Jan-10	98.10	66.63	5-Apr-10	96.57	68.16	12-Jul-10
EW-14D	40.17	61.96	7-Oct-08	40.34	61.79	13-Jan-09	39.68	62.45	7-Apr-09	40.02	62.11	14-Jul-09	39.75	62.38	20-Oct-09	41.18	60.95	19-Jan-10	40.95	61.18	5-Apr-10	38.08	64.05	12-Jul-10
SW-2	dry		dry			dry			dry			dry			dry			dry			dry			
DW-2	70.60	65.82	8-Oct-08	70.96	65.46	14-Jan-09	70.80	65.62	6-Apr-09	69.95	66.47	13-Jul-09	70.17	66.25	21-Oct-09	71.85	64.57	19-Jan-10	70.20	66.22	6-Apr-10	70.32	66.10	13-Jul-10
SW-1	64.50	66.99	8-Oct-08	64.05	67.44	14-Jan-09	64.65	66.84	7-Apr-09	64.00	67.49	15-Jul-09	64.34	67.15	21-Oct-09	65.40	66.09	19-Jan-10	65.15	66.34	6-Apr-10	64.31	67.18	8-Jul-10
DF-1	64.20	67.18	8-Oct-08	64.64	66.74	14-Jan-09	64.20	67.18	7-Apr-09	63.37	68.01	15-Jul-09	64.00	67.38	21-Oct-09	65.23	66.15	19-Jan-10	65.81	65.57	6-Apr-10	63.85	67.53	8-Jul-10
LF-02	52.54	66.16	8-Oct-08	51.94	66.76	14-Jan-09	51.60	67.10	8-Apr-09	51.20	67.50	15-Jul-09	51.50	67.20	22-Oct-09	52.35	66.35	19-Jan-10	52.53	66.17	7-Apr-10	51.10	67.60	12-Jul-10
PPW-1	69.65	67.09	9-Oct-08	69.79	66.95	Permanently closed Oct. 2008			Permanently closed Oct. 2008			Permanently closed Oct. 2008			Permanently closed Oct. 2008			Permanently closed Oct. 2008			Permanently closed Oct. 2008			
WT-01	96.65	67.92	9-Oct-08	97.29	67.28	14-Jan-09	96.63	67.94	7-Apr-09	96.52	68.05	14-Jul-09	96.71	67.86	21-Oct-09	97.59	66.98	20-Jan-10	96.42	68.15	8-Apr-10	95.38	69.19	14-Jul-10
MW-6D	94.82	65.57	8-Oct-08	94.99	65.40	14-Jan-09	94.80	65.59	8-Apr-09	94.35	66.04	15-Jul-09	94.71	65.68	21-Oct-09	95.74	64.65	20-Jan-10	95.73	64.66	6-Apr-10	94.20	66.19	14-Jul-10
MW-8A	68.40	64.78	8-Oct-08	69.25	63.93	14-Jan-09	68.91	64.27	9-Apr-09	68.44	64.74	16-Jul-09	68.55	64.63	22-Oct-09	69.92	63.26	21-Jan-10	68.76	64.42	7-Apr-10	68.70	64.48	14-Jul-10
MW-8B	68.48	NM	8-Oct-08	70.14	64.10	15-Jan-09	68.40	65.84	9-Apr-09	67.58	66.66	16-Jul-09	65.70	68.54	22-Oct-09	69.55	64.69	21-Jan-10	69.44	64.80	7-Apr-10	67.05	67.19	14-Jul-10
MW-8C	69.21	66.51	8-Oct-08	70.30	65.42	14-Jan-09	68.90	66.82	9-Apr-09	69.00	66.72	16-Jul-09	69.00	66.72	22-Oct-09	70.26	65.46	21-Jan-10	70.08	65.64	7-Apr-10	68.40	67.32	15-Jul-10
MW-10B	95.66	65.46	8-Oct-08	96.30	64.82	14-Jan-09	95.82	65.30	8-Apr-09	95.72	65.40	15-Jul-09	95.81	65.31	21-Oct-09	96.84	64.28	20-Jan-10	96.68	64.44	6-Apr-10	95.07	66.05	13-Jul-10
MW-10C	95.95	64.32	9-Oct-08	95.34	64.93	15-Jan-09	94.80	65.47	8-Apr-09	94.74	65.53	15-Jul-09	94.99	65.28	21-Oct-09	95.83	64.44	20-Jan-10	95.75	64.52	6-Apr-10	94.00	66.27	14-Jul-10
MW-10D	96.12	65.05	9-Oct-08	96.15	65.02	15-Jan-09	95.47	65.70</																

**Table 6-1**  
**Groundwater Elevation and Well Construction Data**  
**Claremont Polychemical Superfund Site**  
**Old Bethpage, NY**

Well ID	Jul-10		Oct-10		
	Depth to Water Below Ref El <sup>a</sup> (ft)	Water Elevation (ft AMSL)	Sample Date	Depth to Water Below Ref El <sup>b</sup> (ft)	Water Elevation (ft AMSL)
EW-1A	62.00	68.00	12-Oct-10	63.10	66.90
EW-1B	61.90	68.63	12-Oct-10	63.00	67.53
EW-1C	61.75	68.69	12-Oct-10	63.48	66.96
EW-2A	90.20	67.16	12-Oct-10	91.52	65.84
EW-2B	90.20	67.53	12-Oct-10	91.70	66.03
EW-2C	90.05	67.61	12-Oct-10	91.85	65.81
EW-2D	89.91	68.33	12-Oct-10	91.74	66.50
EW-3A	92.68	66.27	12-Oct-10	94.61	64.34
EW-3B	93.03	66.06	12-Oct-10	94.84	64.25
EW-3C	93.00	65.95	12-Oct-10	94.81	64.14
EW-4A	93.40	68.38	12-Oct-10	94.78	67.00
EW-4B	93.63	68.17	12-Oct-10	94.83	66.97
EW-4C	92.95	68.59	12-Oct-10	94.61	66.93
EW-4D	93.01	68.76	12-Oct-10	94.93	66.84
EW-5	69.32	67.66	12-Oct-10	69.06	67.92
EW-6A	59.93	70.39	12-Oct-10	61.92	68.40
EW-6B	abandoned		abandoned		
EW-6C	60.48	69.92	12-Oct-10	62.00	68.40
EW-7C	84.13	69.66	12-Oct-10	85.93	67.86
EW-7D	84.10	69.61	12-Oct-10	85.83	67.88
EW-8D	61.83	69.71	12-Oct-10	60.73	70.81
EW-9D	67.89	69.64	12-Oct-10	60.73	76.80
EW-10C	93.82	67.12	12-Oct-10	97.71	63.23
EW-11D	97.24	68.09	12-Oct-10	99.01	66.32
EW-12D	96.03	68.39	12-Oct-10	97.72	66.70
EW-13D	96.27	68.46	12-Oct-10	92.71	72.02
EW-14D	38.25	63.88	12-Oct-10	nm	#VALUE!
SW-2	dry		dry		
DW-2	69.07	67.35	12-Oct-10	70.71	65.71
SW-1	62.69	68.80	12-Oct-10	64.47	67.02
DW-1	62.28	69.10	12-Oct-10	63.83	67.55
LF-02	46.64	72.06	12-Oct-10	51.60	67.10
PPW-1	ntly closed Oct. 2008		Permanently closed Oct. 2008		
WT-01	92.42	72.15	12-Oct-10	97.15	67.42
MW-6D	92.59	67.80	12-Oct-10	94.70	65.69
MW-8A	66.86	66.32	12-Oct-10		#VALUE!
MW-8B	66.10	68.14	12-Oct-10		#VALUE!
MW-8C	67.43	68.29	12-Oct-10	65.92	69.80
MW-10B	90.95	70.17	12-Oct-10	95.88	65.24
MW-10C	92.93	67.34	12-Oct-10	95.30	64.97
MW-10D	94.20	66.97	12-Oct-10	96.10	65.07
BP-3A	59.35	65.19	12-Oct-10		#VALUE!
BP-3B	62.21	61.36	12-Oct-10		#VALUE!
BP-3C	62.30	61.38	12-Oct-10		#VALUE!
RW-01	abandoned		abandoned		
EX-1	79.20	55.11	26-Jul-10		#VALUE!
EX-2	87.10	59.15	20-Jul-10		#VALUE!
EX-3	107.22	53.47	20-Jul-10		#VALUE!
IW-1	5.20	159.68	14-Oct-10	5.40	159.48
IW-2	11.98	153.63	14-Oct-10	13.78	151.83
IW-3	5.30	160.96	14-Oct-10	5.40	160.86
IW-4	8.98	157.11	14-Oct-10	12.83	153.26
IG-1 <sup>c</sup>					
IG-3 <sup>c</sup>					
Well Transducer Reading at time of depth to water readings		162.5	14-Oct-10		161.2
		147.0	14-Oct-10		124.4
		154.8	14-Oct-10		163.6
		155.2	14-Oct-10		154.1

TABLE 7-1  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
MAGNETIC FLOW METER DAILY TOTALIZER READINGS

**October 2010**

DATE	TOTALIZER READING	GALLONS PER DAY	GALLONS PER MINUTE
10/1/2010	233863850	1726150	400
10/4/2010	235590000	560000	389
10/5/2010	236150000	570000	396
10/6/2010	236720000	560000	389
10/7/2010	237280000	570000	396
10/8/2010	237850000	1650000	382
10/11/2010	239500000	600000	417
10/12/2010	240100000	570000	396
10/13/2010	240670000	560000	389
10/14/2010	241230000	560000	389
10/15/2010	241790000	1700000	394
10/18/2010	243490000	570000	396
10/19/2010	244060000	550000	382
10/20/2010	244610000	560000	389
10/21/2010	245170000	450000	313
10/22/2010	245620000	1690000	391
10/25/2010	247310000	560000	389
10/16/2010	247870000	560000	389
10/27/2010	248430000	560000	389
10/28/2010	248990000	570000	396
10/29/2010	249560000	1662607	385
11/1/2010	251222607		
<b>Oct. 2010 TOTAL TREATED WATER</b>		<b>17,358,757</b>	
<b>Oct. 2010 AVERAGE GALLONS PER MINUTE DISCHARGED</b>			<b>402</b>

**Table 15-1**  
**Injection Well Soundings**  
**Claremont Polychemical Superfund Site**

Date	Injection Well 1		Injection Well 2		Injection Well 3		Injection Well 4	
	Depth to Bottom (ft)	Difference	Depth to Bottom (ft)	Difference	Depth to Bottom (ft)	Difference	Depth to Bottom (ft)	Difference
6/17/2004	248.50	--	248.50	--	253.20	--	205.00	--
7/23/2004	247.97	0.53	248.19	0.31	251.20	2.00	203.50	1.50
8/16/2004	247.90	0.07	248.18	0.01	251.00	0.20	203.40	0.10
9/14/2004	247.95	-0.05	248.15	0.03	251.10	-0.10	203.95	-0.55
10/28/2004	247.79	0.16	248.20	-0.05	251.20	-0.10	203.15	0.80
11/15/2004	247.40	0.39	248.26	-0.06	251.03	0.17	204.03	-0.88
12/29/2004	247.87	-0.47	248.33	-0.07	250.82	0.21	204.40	-0.37
1/10/2005	247.83	0.04	248.12	0.21	250.54	0.28	204.70	-0.30
2/16/2005	247.50	0.33	248.25	-0.13	250.45	0.09	204.36	0.34
3/18/2005	247.82	-0.32	248.10	0.15	250.40	0.05	204.43	-0.07
4/5/2005	247.78	0.04	248.13	-0.03	250.47	-0.07	204.20	0.23
5/10/2005	247.81	-0.03	248.14	-0.01	250.45	0.02	204.22	-0.02
6/30/2005	247.62	0.19	247.25	0.89	250.36	0.09	204.04	0.18
7/26/2005	247.67	-0.05	246.82	0.43	249.93	0.43	204.11	-0.07
8/29/2005	247.71	-0.04	246.50	0.32	249.78	0.15	204.17	-0.06
9/27/2005	247.77	-0.06	246.29	0.21	249.77	0.01	203.90	0.27
10/24/2005	247.78	-0.01	246.00	0.29	249.44	0.33	203.84	0.06
11/14/2005	247.51	0.27	246.19	-0.19	249.10	0.34	203.57	0.27
12/27/2005	247.60	-0.09	245.70	0.49	249.32	-0.22	203.83	-0.26
1/27/2006	247.51	0.09	246.09	-0.39	249.21	0.11	203.98	-0.15
2/16/2006	247.50	0.01	245.69	0.40	249.19	0.02	203.98	0.00
3/23/2006*	247.59	-0.09	245.65	0.04	249.60	-0.41	203.75	0.23
4/28/2006	247.54	0.05	243.68	1.97	249.50	0.10	203.78	-0.03
5/24/2006	247.38	0.16	243.61	0.07	249.57	-0.07	203.90	-0.12
6/20/2006	247.47	-0.09	243.70	-0.09	249.46	0.11	203.14	0.76
7/28/2006	247.44	0.03	243.37	0.33	249.52	-0.06	203.33	-0.19
8/21/2006	247.34	0.10	243.19	0.18	249.42	0.10	202.88	0.45
9/22/2006	247.36	-0.02	242.70	0.49	249.27	0.15	203.05	-0.17
10/30/2006	247.16	0.20	242.64	0.06	249.48	-0.21	203.92	-0.87
11/29/2006	247.32	-0.16	242.50	0.14	249.22	0.26	203.19	0.73
12/29/2006	247.22	0.10	242.52	-0.02	249.29	-0.07	203.15	0.04
1/30/2007	247.44	-0.22	242.60	-0.08	249.47	-0.18	203.35	-0.20
2/21/2007	247.63	-0.19	242.56	0.04	249.42	0.05	203.32	0.03
3/29/2007	247.11	0.52	242.54	0.02	249.22	0.20	201.55	1.77
4/20/2007	247.17	-0.06	242.29	0.25	249.19	0.03	201.24	0.31
5/25/2007	246.85	0.32	242.86	-0.57	249.11	0.08	201.24	0.00
6/28/2007	246.63	0.22	242.15	0.71	248.80	0.31	200.96	0.28
7/26/2007	245.88	0.75	242.13	0.02	248.78	0.02	200.80	0.16
8/23/2007	245.96	-0.08	242.03	0.10	248.73	0.05	200.22	0.58
9/27/2007	245.79	0.17	241.96	0.07	246.80	1.93	200.29	-0.07
10/25/2007	244.69	1.10	242.08	-0.12	248.73	-1.93	200.14	0.15
11/19/2007	242.20	2.49	242.00	0.08	249.60	-0.87	201.05	-0.91
12/21/2007	235.02	7.18	241.56	0.44	249.62	-0.02	200.08	0.97
1/29/2008	232.46	2.56	241.98	-0.42	249.63	-0.01	200.03	0.05
2/29/2008	226.58	5.88	242.12	-0.14	249.82	-0.19	199.52	0.51
3/27/2008	220.50	6.08	241.90	0.22	249.50	0.32	199.30	0.22
4/29/2008	222.50	-2.00	242.02	-0.12	249.60	-0.10	198.98	0.32
5/30/2008	218.55	3.95	241.90	0.12	249.47	0.13	198.65	0.33
6/26/2008	218.60	-0.05	241.95	-0.05	249.50	-0.03	198.65	0.00
7/29/2008	214.98	3.62	242.20	-0.25	249.68	-0.18	198.68	-0.03
8/26/2008	207.03	7.95	241.90	0.30	249.72	-0.04	198.65	0.03
9/26/2008	202.40	4.63	241.93	-0.03	249.52	0.20	198.60	0.05
10/27/2008	200.68	1.72	241.88	0.05	249.50	0.02	198.59	0.01
11/20/2008	198.05	2.63	242.12	-0.24	249.54	-0.04	198.64	-0.05
12/29/2008	178.29	19.76	242.10	0.02	249.15	0.39	198.30	0.34
1/26/2009	167.50	10.79	241.90	0.20	248.87	0.28	198.28	0.02

**Table 15-1**  
**Injection Well Soundings**  
**Claremont Polychemical Superfund Site**

2/25/2009	151.20	16.30	242.00	-0.10	248.80	0.07	198.80	-0.52
3/13/2009	148.68	2.52	241.87	0.13	248.94	-0.14	198.28	0.52
4/17/2009	148.52	0.16	241.67	0.20	249.00	-0.06	198.10	0.18
5/15/2009	147.60	0.92	241.64	0.03	249.05	-0.05	198.10	0.00
6/8/2009	147.50	0.10	241.60	0.04	248.95	0.10	197.92	0.18
7/27/2009	147.20	0.30	242.40	-0.80	249.00	-0.05	197.90	0.02
8/13/2009	147.20	0.00	241.55	0.85	248.90	0.10	198.00	-0.10
9/16/2009	147.20	0.00	241.50	0.05	248.90	0.00	198.00	0.00
10/28/2009	147.20	0.00	241.44	0.06	248.50	0.40	197.95	0.05
11/19/2009	146.90	0.30	241.50	-0.06	248.53	-0.03	198.00	-0.05
12/10/2009	147.40	-0.50	242.50	-1.00	249.20	-0.67	198.10	-0.10
1/22/2010	147.20	0.20	241.80	0.70	248.50	0.70	198.00	0.10
3/4/2010	147.28	-0.08	241.20	0.60	245.45	3.05	198.00	0.00
3/24/2010	144.95	2.33	241.60	-0.40	248.30	-2.85	198.00	0.00
4/19/2010	147.25	-2.30	241.65	-0.05	247.70	0.60	198.00	0.00
5/26/2010	147.28	-0.03	241.80	-0.15	248.00	-0.30	198.00	0.00
6/24/2010	147.18	0.10	241.72	0.08	248.80	-0.80	198.00	0.00
7/27/2010	144.50	2.68	241.10	0.62	248.90	-0.10	198.00	0.00
8/19/2010	146.95	-2.45	241.70	-0.60	249.05	-0.15	198.00	0.00
9/14/2010	146.00	0.95	241.70	0.00	249.10	-0.05	198.00	0.00
10/14/2010	145.90	0.10	241.65	0.05	249.10	0.00	198.00	0.00

Change 6/17/04 to present      **102.60**                                      **6.85**                                      **4.10**                                      **7.00**

Change 6-04 through 2-06      1.00                                      2.81                                      4.01                                      1.02

\*Injection wells IW-2 and IW-3 redeveloped during week ending 3/17/2006

Change 3-06 thru 10/07      2.90                                      3.57                                      0.87                                      3.61

Injection wells IW-1 and IW-3 were redeveloped during week ending 11/9/07

Change 11-07 thru 3/08      21.70                                      0.10                                      0.10                                      1.75

Injection wells IW-1 and IW-3 were redeveloped during week ending 4/25/08

Change 4/08 to present      **76.60**                                      **0.37**                                      **0.50**                                      **0.98**

# **APPENDIX A**

## **Project Status Reports**

**Project Status Report No. 40**  
**Long Term Response Action (LTRA) Contract W912 DQ-07-D-0044-0001**  
**Science Applications International Corporation**  
**Date: October 25, 2010**

This status report is for activities associated with the operation and maintenance of the Claremont Polychemical Superfund Site Groundwater Treatment Plant (GWTP) during the period from October 1, 2010 through October 24, 2010. This represents the fortieth status report under SAIC's Long Term Response Action (LTRA) contract W912 DQ-07-D-0044-0001.

**Quantity of Water Treated**

Approximately 13.4 million gallons of groundwater were treated during this 24 day period. This equates to 560,256 gallons per day of continuous water treatment at an average treatment rate of ~389 gallons per minute. This is well above the current daily treatment goal of 482,400 gpd, with the plant running continuously at approximately 335 gpm. The plant was shut down for 270 minutes this month to complete the backwashing of the carbon adsorber vessels.

**General Activities and Events**

**This Reporting Period**

- Site activities involved normal GWTP operations, maintenance and inspections.
- This month the plant experienced severe wind and rain storms. There were several momentary power interruptions in which the plant automatically reset.

**Upcoming**

- Paperwork regarding the extension of the SPDES equivalency permit has been submitted to the NYSDEC. The renewal of the permit is pending.
- Collection and transfer of requested documents to the NYSDEC.

**Reporting and Documentation**

**This Reporting Period**

- The monthly report for September was completed and submitted with associated documents.

**Upcoming**

- Submit this October Progress Report with related documents.
- Submit October 2010 Monthly Operations Report, Maintenance Log and supplementary documents.
- Compile documents requested by NYSDEC



## **Operations and Maintenance Activities**

### **This Reporting Period**

- Daily, weekly and monthly O&M tasks on plant systems were performed.
- Comprehensive site safety inspections continue.
- Interior and exterior plant housekeeping continues.
- Acceptable water levels were maintained in the injection wells and galleries.
- The process pH electrodes were cleaned, calibrated and adjusted as needed.
- The process pumps were rotated three times during this period as part of the preventive maintenance (PM) task.
- The check-valve for ASF pump 3 was disassembled and inspected. The disk and lever arm have corroded and require replacement. The valve was closed up and returned to service with out the disk.
- On INF Pump 3 the motor to pump drive coupling was replaced and the pump was returned to service.
- The on-hand small parts supply was inventoried and labeled.
- The annual NYS Motor Vehicle inspection of the plant truck was completed.
- Both carbon adsorber vessels were air sparged and backwashed through two cycles each.
- The pH electrode for the ASF line was removed, cleaned, and manually calibrated with standard solutions. The system continues to show and E2 – asymmetry potential error.
- Influent pump 3 failed. After checking, the pump was started.

### **Upcoming**

- Ongoing routine operations and maintenance tasks. (high priority)
- Dedicated sampling equipment for selected monitoring wells. (low)
- Electrical repair tasks which include the following:
  - Configure the GWTP router and PLC to allow for remote access and control.
  - Connect the third treated water discharge pump to the power supply and to the GWTP control system. (high)
  - Investigate control system grounding sensitivity issues. (medium)
  - Evaluate the control panels on the polymer and potassium permanganate feed systems and determine any repairs that may be required to have all systems fully functional.
- Clean water storage tanks and flush process lines

## **Site Sampling and Analysis**

### **This Reporting Period**

- As part of the revised extended plant operations, the groundwater sampling task was not performed this month as would normally be scheduled. The next quarterly sampling event is scheduled for April 2011.

- The plant process water sampling task was completed on 10/13, with organic and inorganic samples shipped to DESA lab and generic samples sent to ALSI
- The plant discharge was sampled for temperature and pH on 3 occasions.
- An ASR for November's PD samples was submitted. The USEPA has designated DESA lab for the analysis.

#### **Upcoming**

- Complete the November PD sampling tasks including documentation.
- Submit ASR for the December PD tasks and set schedule.

### **Database Development and Modeling**

#### **This Reporting Period**

- No database development or modeling work was conducted this period.

#### **Upcoming**

- Finalize the groundwater modeling report.

### **Human Machine Interface (HMI) and Controls**

#### **This Reporting Period**

- No new HMI activities this period

#### **Upcoming**

- Connection of the third injection pump to the system.

### **Transition of Facility to NYSDEC**

#### **This Reporting Period**

- No activity this month, although a budget was proposed to continue operation of the plant through June 2011.

#### **Upcoming**

- Determine costs associated with equipment priority list.
- Submit documentation as requested by NYSDEC.
- Contact NYSDEC regarding their plans for staffing the plant O&M program.

### **Budget/ Finance Status**

- Extended budget was finalized and the WVN submitted and approved.

### **Miscellaneous Issues or Problems Encountered**

- No new issues to note

### **Upcoming**

- Continue with getting plant to baseline for operation transfer to NYSDEC.

### **General Activities Schedule**

Various activities involving predictive, preventive, and other types of work are in various states of planning and execution. These activities are summarized in Table 1, attached.

**APPENDIX B**

**Daily Quality Control Reports (DQCRs)**

# VISITOR/SUBCONTRACTOR LOG

OCT 2010

Doc. No.: CPS-Form-010  
July 1, 2008  
Rev.: D

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Friday  
**Date:** 10-1-10

**Weather Forecast (am):** Heavy rain with high winds. Temperatures are to range from 66-70-53°F. Winds are from the WNW-NNW at 10-18 mph. Relative humidity at 85%, clearing in afternoon.  
Saturday – Sunny, temps at 54-66-51°F, wind at 13-11 from N, RH at 55-65%, no rain.  
Sunday – Sunny, temps at 52-63-50°F, wind at 13-14 from NE, RH at 60%, afternoon rain.

**Volume Processed** for 3-day period (10/1 thru 10/4): 1,691,690 gallons

**Operating Hours:** 72:00 hrs

**Total Downtime:** 00:00 hrs.

**Reason for Downtime:**

No downtime required

**Significant Operational Problems:**

None

**Corrective Maintenance Performed:**

Check valve for ASF P3 was disassembled. The defective/worn parts were removed for evaluation.  
Changed light bulbs in shop

**Verbal/Written Instruction from Government Personnel:**

USACE approved the RFAs for the plant electrical work pending budgetary considerations

**Inspections Performed and Results:**

Site safety inspection was completed with no new issues found.

**Record of any tests performed, samples taken, and personnel involved:**

No tests were performed or samples taken

**Available Analytical Results**

No new data available

**Calibration Procedures Performed:**

No calibrations required

**General Remarks:**

Plant has been running steady and stable. Plant influent water is at 372 gpm, effluent water is at 391 gpm.

Upon examination of the ASF P3 check-valve, it was discovered that the valve disk arm was eroded and the disk was non-functional. Replacement parts will be required.

End of month documentation will be required.

James Jackson (JSJ) and Peter Takach (PET) were on site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 4, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J JACKSON

Day: FRI DAY

Date: 10-01-10

Time: 0501

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
391	0	23385

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS ( HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	326095	163860					63391
EW-2	264755	179320					57132
EW-3	241344	157400					61489

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.4	05	34034137	HEAVY RAINS AND GUSTY WINDS
IW-2	119.8	05	3689803	THIS MORNING, TEMP 73°F
IW-3	163.4	113	3832660	
IW-4	153.2	83	3555625	PLANT IS RUNNING FINE.

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74395	NM	1	11	
INF 2	73203		1	12	
INF 3	28430		SB	SB	STAND-BY
ASF 1	41452		0	31	
ASF 2	49201		0	30	
ASF 3	42533		SB	SB	STAND-BY
GAC 1	44754		2	16	
GAC 2	48270		2	15	
GAC 3	33433		SB	SB	STAND-BY
REC 1	21934		OFF	OFF	
REC 2	20142		OFF	OFF	
INJ 1	65170		6	27	
INJ 2	39128		8	27	
INJ 3	-		NIS	NIS	NOT IN SERVICE
SUMP					
BLOWER		✓			

	INLET	OUTLET
GAC #1 (PSI)	10	8
GAC #2 (PSI)	10	11
AIR DRIER (PSI)	0L	0L

AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	57°	57°
Water Temp (°F)		17°C
V-GAC #1 (H <sub>2</sub> O")	2.45	0.60
V-GAC #2 (H <sub>2</sub> O")	0L	0L

Additional comments:  
 CHECK VALVE AT AIR STRIPPER #3  
 HAD SHAFT, ARM, & DISK  
 REMOVED - NEW PARTS ORDERED


pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.34	
Reactor Tank 2	5.07	
AS. Feed	6.21	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/4"	

NM = Not Measured  
 OL = Off Line  
 SB = Standby

NIS = Not in service

Supervisors Signature:



Date

10-4-10



**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J JACKSON

DATE: 10-01-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • HEAVY RAINS AND GUSTY WINDS @ 55 mph	
2)	
3) • the daily operations was completed	
4)	
5) • the PLANT IS RUNNING FINE FOR NOW.	
6)	
7) • 3-T12 40 watt 48" Philips BULBS were installed	
8) IN CONTROL RM.	
9)	
10) • RAINS ARE COMING DOWN EXTREMELY HARD @ 720	
11)	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • Remove Check Valve shaft, ARMS, AND FLAP	
2) FROM Check Valve #3 - PART were ordered by	
3) Refe.	
4)	
5)	
6)	
7)	
8)	
9)	
10)	
11)	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS
1)

*Pittsford* 10-4-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-01-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT
			IN
			SERVICE

### Process Tanks

EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

### Process Systems

INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK - Check valve inspected
✓	✓	✓	OK
✓	✓		OK

### Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

#### General Conditions and Comments

WATER EVERYWHERE
NONE
NONE
NONE

### Air Compressor

TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

#### General Conditions and Comments

OFF
LINE

### Air Stripper

COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

#### General Conditions and Comments

OK
OK
OK

### Notes and Comments:


CHECK VALVE, AIR STRIPPER, COVER REMOVED, SHAFT REMOVED, DISK ARM REMOVED, NEW ARM, & DISK WILL BE ORDERED.

SIGNED: [Signature]

DATE: 10-4-10

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-01-10



**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Monday  
**Date:** 10-04-10

**Weather Forecast:** Raining and cold. Temps to range from 54-59-57°F. Wind at 20-18 mph from NNE. RH at 90-95% with scattered showers to continue.

**Total Volume Processed for Day:** 560,389 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 00:00 hrs.

**Reason for Downtime:**  
No downtime to report.

**Significant Operational Problems:**  
Plant experienced a momentary power interruption. System automatically restarted.

**Corrective Maintenance Performed:**  
Cleaned disassembled check valve  
Cleaned electrodes at reaction tanks  
Pulled and tested EW-2 pumps

**Verbal/Written Instruction from Government Personnel:**  
No new instructions received

**Inspections Performed and Results:**  
Site safety inspection was completed

**Record of any tests performed, samples taken, and personnel involved:**  
Plant pH and temperature readings were recorded  
Plant air monitoring was completed. No emissions  
Tested Horiba water quality multimeter was tested

**Available Analytical Results:**  
No new data was available.

**Calibration Procedures Performed:**  
Process pH meters were calibrated  
Lab pH meter was calibrated and logged in  
PID meter was calibrated and logged in  
Horiba multimeter

**General Remarks:**  
The plant continues to operate without and significant issues. Influent and effluent flows are high and steady. Injection well levels are steady.

End of the month documentation continues

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 5, 2010

Attachments:

Daily Operating Log

Daily Activities Summary Report

Daily site Safety Inspection

Employee Sign-in Sheet

AIR MONITORING LOG

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J JACKSON

Day: MONDAY

Date: 10-04-10

Time: 0520

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
391	0	23555

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS ( HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	326588	164640	161840	165520	163860		634410
EW-2	265294	180210	183720	181060	179320		57183
EW-3	241910	188200	191880	189030	187400		61539

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.3	95	4075495	Rainy morning, (COLD), TEMPO 58° PLANTS RUNNING FINE
IW-2	122.9	91	3730677	
IW-3	163.5	113	3881790	
IW-4	153.4	80	3390998	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74465	NM	1	11	
INF 2	73274		2	12	
INF 3	28430		SB	SB	STAND-BY
ASF 1	41522		1	33	
ASF 2	49272		1	30	
ASF 3	42533		NIS	NIS	NIS IN SERVICE
GAC 1	44824		2	16	
GAC 2	48341		2	15	
GAC 3	33433		SB	SB	STAND-BY
REC 1	21934		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	65240		6	27	
INJ 2	39199	39199	8	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP					
BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	13	13
AIR DRIER (PSI)	OL	OL

AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	56	56°
Water Temp (°F)		15°c
V-GAC #1 (H <sub>2</sub> O")	2.45	0.45
V-GAC #2 (H <sub>2</sub> O")	OL	OL

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.36	6.07/14°c
Reactor Tank 2	4.87	6.12/14°c
AS. Feed	6.21	6.34/14°c
PLANT DISCHARGE - pH		6.48
PLANT DISCHARGE - Temp.		15°c

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

Additional comments:  
Weekly Ph & TEMP TAKEN

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Supervisors Signature: [Signature]

Date: 10-5-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACKSON

DATE: 10-04-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • THIS MORNING IT RAINY AND DAMP, VERY COOL	
2) TEMP @ 58°F	
3)	
4) • THE PLANT RAN WELL OVER THE WEEK-END	
5)	
6) • THE WEEKLY PH & TEMPS WERE COMPLETED	
7)	
8) • PID WAS CALIBRATED, AIR MONITORING WAS	
9) DONE	
10)	
11) • THE DAILY OPERATOR LOG WAS COMPLETED	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • PULLED PUMPS FROM FW-2A & B - INSPECTED BOTH	
2) TOOK A LOOK AT BOTH BLADDERS, SEEM TO BE OK	
3)	
4) • TEST BOTH PUMPS IN THE DECON 55 gal Drum	
5) RAN FINE	
6)	
7) • ALSO TESTED BOTH PUMPS IN WELL SETTING, BOTH	
8) WORKED FINE	
9)	
10)	
11)	

**IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS**

1)	

*Patricia* 10-5-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-01-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			N/A
			IN
			SERVICE

Process Tanks  
 EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

Process Systems  
 INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

Floor and General Work Areas  
 SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

General Conditions and Comments
WATER IN VARIOUS LOCATION IN PLANT
NONE
NONE
NONE

Air Compressor  
 TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

General Conditions and Comments
OFF
LINE

Air Stripper  
 COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

General Conditions and Comments
OK
OK
OK

Notes and Comments:

CHECK VALVE @ AIR STRIPPER #3 - IS NOT IN SERVICE  
 IN THE PROCESS OF BEING REBUILT.

SIGNED:

Peter Wahl

DATE: 10-5-10



# AIR MONITORING LOG CLAREMONT POLYCHEMICAL SUPERFUND SITE

Sampler

G. Jackson

Date

10-04-10

Calibration Standard(s)

100 DDM / ISOLBUTLENE

Post-cal Readings

86.7 DDM / 100 DDM

Location		Reading (ppm)
CONTROL ROOM		
	Laboratory	0.0
	Bathroom	0.0
	Office	0.0
PLANT		
	Influent Area	0.0
	Sludge Storage Area	0.0
	Sand Filter Area	0.0
	Air Compressor Area	0.0
	Sludge Press Area	0.0
EXTERIOR		
	Storage Tanks	
	Upper (South West) Lot	0.0
	Lower (South East) Lot	0.0
	Air Stripper Area	0.0
	Back (North)	0.0
GAC VESSELS		
	#1 Influent	0.0
	#1 Effluent	0.0
	#2 Influent	OL
	#2 Effluent	OL

Comments:

PLANT DIO WAS CALIBRATED, NO AIR  
MONITORING ISSUES INSIDE OR OUTSIDE PLANT.

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-6-4-10

25

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Tuesday  
**Date:** 10-05-10

**Weather Forecast (am):** Raining and cool. Temperatures are expected to range from 56-62-55°F. Wind will be 13-8 mph from the NNE-E-SW with gusts to 18 mph. Relative humidity is 85-90% with continued scattered showers expected.

**Total Volume Processed for Day:** 569,604 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 00:00 hrs.

**Reason for Downtime:**  
No downtime required

**Significant Operational Problems:**  
None

**Corrective Maintenance Performed:**  
Cleaned check valve parts and cut gaskets

**Verbal/Written Instruction from Government Personnel:**  
No new instructions received

**Inspections Performed and Results:**  
Conducted site safety inspection, no new issues observed.  
Inspected well field and paths to remote monitoring wells

**Record of any tests performed, samples taken, and personnel involved:**  
No tests performed or samples taken

**Available Analytical Results:**  
No new data available.

**Calibration Procedures Performed:**  
No calibrations required

**General Remarks:**  
Plant continues to run in a steady fashion. Plant flows were 372 gpm in and 391 gpm out.

End of month documentation work continues

Peter Takach (PET) and James Jackson (JSJ) were on site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 6, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J JACKSON Day: Tuesday Date: 10-05-10 Time: 0840

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
3912	0	23612

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS ( HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	326753	165660					63486
EW-2	265474	181230					57197
EW-3	242000	189370					61553

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.2	96	4089455	misty, with light rain, temp at 57°F PLANT RAN FINE THRU OUT THE NIGHT
IW-2	122.4	94	3744205	
IW-3	163.5	112	3895349	
IW-4	153.4	80	3402896	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74489	NM	1	11	
INF 2	73297		2	12	
INF 3	28430		SB	SB	STAND-BY
ASF 1	41546		2	32	
ASF 2	49295		2	30	
ASF 3	42533		NIS	NIS	NOT IN SERVICE
GAC 1	44848		2	16	
GAC 2	48365		2	15	
GAC 3	33433		SB	SB	STAND-BY
REC 1	21934		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	65264		6	27	
INJ 2	39222		8	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP					
BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	11	12
AIR DRIER (PSI)	OL	OL

AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	56°	56°
Water Temp (°F)		15°c
V-GAC #1 (H <sub>2</sub> O")	260	0.40
V-GAC #2 (H <sub>2</sub> O")	OL	OL

Additional comments:

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.34	
Reactor Tank 2	5.28	
AS. Feed	6.19	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

NM = Not Measured

OL = Off Line

SB = Standby

NIS = Not in service

Supervisors Signature: [Signature]Date: 10-6-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACKSON

DATE: 10-05-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • MISTY, Cloudy, AND Light Rain this Morning	
2) The Temp WAS AT 56°F, COLD FOR this time	
3) OF the Year.	
4)	
5) • The PLANT RAN WELL LAST Night	
6)	
7) • the daily operators Log WAS Completed	
8)	
9) • Call made to Jim of GA Industries to order	
10) Part For Check Valve Rebuilt. Parts ARE:	
11) ① DISK WITH CENTER PIN	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
1) ② RENEWABLE SEAT / ③ SEAT & NUTS / ④ DISK NUT	
2) ⑤ DISK NUT WASHER / ⑥ BLANK Stud SET	
3)	
4) • WENT TO INSPECT the TRAIL LEADING to BP-3, A, B, C	
5) WELLS - Roads were getting close to being impassable	
6) Road has very deep RUTS & VALLYS. Need attention	
7) SOON.	
8)	
9)	
10)	
11)	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS
1)

*Patricia* 10-6-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-05-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			Not
			IN
			SERVICE

Process Tanks  
 EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

Process Systems  
 INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓		OK
✓	✓		OK
✓	✓		OK
✓	✓		OK
✓	✓		OK

Floor and General Work Areas  
 SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

### General Conditions and Comments

SOME WATER ON FLOOR
NONE
NONE
NONE

Air Compressor  
 TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

### General Conditions and Comments

OFF
LINE AT
this time

Air Stripper  
 COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

### General Conditions and Comments

OK
OK
OK

Notes and Comments:

Call made to QA Industries for the Price of Part that NEED TO ordered For Check VALVE.

SIGNED: \_\_\_\_\_

DATE: \_\_\_\_\_

*P. T. Atank* 10-6-10

**CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET**

TUE  
DATE: 10-05-10

178



**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Wednesday  
**Date:** 10-06-10

**Weather Forecast (am):** Mostly cloudy and mild. Temperatures are to range from 57-64-52°F. Wind at 3-10 mph from the SSW-SW. Relative humidity is 55-60%. Clearing.

**Total Volume Discharged for Day:** 560,779 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 0:00 hrs.

**Reason for Downtime:**  
No downtime to report

**Significant Operational Problems:**  
None

**Corrective Maintenance Performed:**  
Mowed grass around plant and at various wells

**Verbal/Written Instruction from Government Personnel:**  
No new instructions.

**Inspections Performed and Results:**  
Conducted site safety inspection, there were no new safety or equipment issues.

**Record of any tests performed, samples taken, and personnel involved:**  
No tests performed or samples taken

**Available Analytical Results:**  
No new results were available.

**Calibration Procedures Performed:**  
No calibrations required

**General Remarks:**  
The plant has been running in a very stable mode with steady influent and effluent flows. Plant effluent averaged 391 gpm.

Routine plant O&M continues

James Jackson (JSJ) and Peter Takach (PET) were on site today.

Plant Manager Signature:



Peter Takach, October 7, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J JACKSON

Day: Wednesday

Date: 10-06-10

Time: 0505

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
391	0	23667

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	326915	164150					63472
EW-2	265652	180200					57213
EW-3	242286	188020					4569

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.2	96	4102979	COOL MORNING, Temp 57°F PLANT RAN FINE though out the Nite.
IW-2	120.7	93	3757467	
IW-3	163.5	113	3914373	
IW-4	153.8	81	3414379	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74512	NM	2	12	
INF 2	73320		3	12	
INF 3	28430		SB	SB	STAND-BY
ASF 1	41569		1	31	
ASF 2	49318		1	31	
ASF 3	42533		NIS	NIS	NOT IN SERVICE
GAC 1	44871		2	16	
GAC 2	48388		3	15	
GAC 3	35433		SB	SB	STAND-BY
REC 1	21934		OFF	OFF	
REC 2	20142		OFF	OFF	
INJ 1	65287		6	27	
INJ 2	39245		8	27	
INJ 3	NIS		NIS	NIS	NOT IN SERVICE
SUMP BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	13	11
AIR DRIER (PSI)	OL	OL

AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	56°	56°
Water Temp (°F)		15°C
V-GAC #1 (H <sub>2</sub> O")	2.60	0.45
V-GAC #2 (H <sub>2</sub> O")	OL	OL

Additional comments:

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.33	
Reactor Tank 2	5.27	
AS Feed	6.19	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/4"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Supervisors Signature:



Date

10-7-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACKSON

DATE: 10-06-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
• COOL AND DAMP MORNING, TEMP @ 57°F	
• NO PROBLEMS WITH PLANT IT RAN FINE DURING THE NIGHT.	
• THE DAILY OPERATORS LOG WAS COMPLETED	
• PLANT GRASS ON THE HILL WAS CUT	
• GRASS WAS WEED WACKEN UNDER THE FENCE	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
• GRASS WAS CUT AROUND EXT-3	
• GRASS WAS CUT AT EW-4, 1, 2, 3 & 4 WELL	
• GRASS AT EW-10C WAS CUT / GRASS CUT @ EW-12D	
• GRASS WEED WACKEN AT EW-13D	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS

*Peter Akel*

10-7-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-06-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT
			IN
			SEE VICE

Process Tanks  
 EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

Process Systems  
 INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	#3 Check Valve NEED Repairs
✓	✓	✓	OK
✓	✓		OK

Floor and General Work Areas  
 SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

### General Conditions and Comments

LESS WATER ON FLOOR
NONE
NONE
NONE

Air Compressor  
 TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

### General Conditions and Comments

OFF
LINE

Air Stripper  
 COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

### General Conditions and Comments

OK
OK - hearing a slight NOISE -
OK

Notes and Comments:

• BLOWER BELTS - NEEDS TO BE TIGHTENED •

SIGNED: R. A. A. A.

DATE: 10-7-10

**CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET**

WED  
DATE: 10-06-10

[illegible]

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Thursday

**Date:** 10-07-10

**Weather Forecast (am):** Mostly cloudy, cool, and windy. Temperatures should range from 53-71-52°F. Wind will be 17-21-18 mph from the WSW-WNW. Relative humidity is 50%. Clearing is expected.

**Total Volume Discharged for Day:** 570,793 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 0:00 hrs.

**Reason for Downtime:**

No downtime to report

**Significant Operational Problems:**

None

**Corrective Maintenance Performed:**

pH electrodes at reaction tanks were cleaned

Landscaping tasks at injection wells

PM on HVAC unit

PM on ASF blower

**Verbal/Written Instruction from Government Personnel:**

No new instructions received

**Inspections Performed and Results:**

Conducted site safety inspection, there were no new safety or equipment issues.

**Record of any tests performed, samples taken, and personnel involved:**

No tests were performed or samples taken

**Available Analytical Results:**

No new results available.

**Calibration Procedures Performed:**

No calibrations required

**General Remarks:**

The plant has been stable and the flows were steady at ~372 gpm in and ~392 gpm out. Average plant discharge flow for the day was 392 gpm

Routine O&M tasks continue

James Jackson (JSJ) and Peter Takach were on site.

Plant Manager Signature:



Peter Takach, October 8, 2010

**Attachments:**

Daily Operating Log  
Daily Activities Summary report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File



Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J. JACKSON Day: Thursday Date: 10-07-10 Time: 0530

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
390	0	23724

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS ( HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	327081	163900					63488
EW-2	265834	179770					57229
EW-3	242417	187510					61586

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	112.3	97	4116881	ANOTHER COOL MORNING, TEMP. 55° PLANT RAN FINE LAST NIGHT
IW-2	121.9	99	3771128	
IW-3	163.6	114	3930842	
IW-4	184.0	80	3426123	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74536	NM	3	11	
INF 2	73344		3	12	
INF 3	28430		SB	SB	STAND-BY
ASF 1	41593		1	33	
ASF 2	49342		1	31	
ASF 3	42533		NIS	NIS	NOT IN SERVICE
GAC 1	44895		2	17	
GAC 2	48411		2	15	
GAC 3	33433		SB	SB	STAND-BY
REC 1	21934		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	65311		6	27	
INJ 2	39269		8	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	13	11
AIR DRIER (PSI)	01	01

AS Blower (H <sub>2</sub> O")	4.7	
Air Temp (°F)	56°	56°
Water Temp (°F)		
V-GAC #1 (H <sub>2</sub> O")	2.60	0.45
V-GAC #2 (H <sub>2</sub> O")	01	01

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.34	
Reactor Tank 2	4.97	
AS. Feed	6.20	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 1/2"	
Treat. Train 2	13 1/4"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:

AIR STRIPPED MOTOR OIL CHANGED  
WHEEL WAXED AROUND THE  
IW WELLS

Supervisors Signature: P. H. H. H.Date 10-8-10

DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK

OPERATOR: J. JACKSON

DATE: 10-07-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
• COLD MORNING - Temp @ 58°F	
• The PLANT RAN FINE thru out the night	
• the Daily operators Log WAS DONE	
• WEED WACKED AROUND IW-2	
• WEED WACKED AROUND IW-3	
• GRASS AT WT-01 WAS WEED WACKED	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
• GRASS AT IW-4 WAS WEED WACKED.	
• INSPECTED AND LUBRICATED the HVAC UNIT	
• BLOWER MOTOR WAS GREASED	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS

*Patricia* 10-8-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-07-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

### Chemical Feed Skids

POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT
			IN
			SERVICE

### Process Tanks

EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

### Process Systems

INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	CHECK VALVE BEING REPAIRED
✓	✓	✓	OK
✓	✓		OK

### Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

#### General Conditions and Comments

MUCH LESS WATER ON FLOOR
NONE
NONE
NONE

### Air Compressor

TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

#### General Conditions and Comments

OFF
LINE

### Air Stripper

COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

#### General Conditions and Comments

OK
OK - MOTOR (LUBRICATED)
OK

### Notes and Comments:

HVAC WAS INSPECTED & Lubricated

SIGNED: [Signature]

DATE: 10-8-10

**CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET**

THURS  
DATE: 10-07-10

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Friday  
**Date:** 10-08-10

**Weather Forecast (am):** Mostly sunny and cool. Temperatures are to range from 50-72-56°F. Winds are from the WNW-WSW at 7-14 mph. Relative humidity at 45-50%, no rain is expected.  
Saturday – Sunny, temps at 57-68-47°F, wind at 12 from NNW, RH at 55%, no rain.  
Sunday – Sunny, temps at 48-64-54°F, wind at 12-5 from W, RH at 50-70%, no rain.

**Total Volume Processed** for 3-day period (10/8 thru 10/11): 1,682,720 gallons

**Operating Hours:** 72:00 hrs

**Total Downtime:** 00:00 hrs.

**Reason for Downtime:**

No downtime required

**Significant Operational Problems:**

None

**Corrective Maintenance Performed:**

Cleaned and calibrated pH electrodes at reaction tanks  
HVAC PM and start up – all ok  
Miscellaneous housekeeping and plant clean up

**Verbal/Written Instruction from Government Personnel:**

No new instructions received

**Inspections Performed and Results:**

Site safety inspection was completed with no new issues found.  
Comprehensive site safety inspections completed – no new issues

**Record of any tests performed, samples taken, and personnel involved:**

Plant sound level monitoring

**Available Analytical Results**

No new data available

**Calibration Procedures Performed:**

Calibrated sound level meter  
Calibrated lab pH meter  
Calibrated process pH meters

**General Remarks:**

Plant has been running steady and stable. Plant influent water is at 372 gpm, effluent water is at 391 gpm.  
General clean up continues.

James Jackson (JSJ) and Peter Takach (PET) were on site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 12, 2010

Attachments:

- Daily Operating Log
- Daily Activities Summary Report
- Daily Site Safety Inspection Log
- Sound Level Monitoring Worksheet
- Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: V. JACKSON Day: FRIDAY Date: 10-08-10 Time: 0516

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
391	0	2.3780

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS ( HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	327241	163850					65504
EW-2	266010	179650					57246
EW-3	242661	157420					61602

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	1623	96	4130556	Temp @ 57°
IW-2	122.6	96	3784837	PLANT IS RUNNING FINE
IW-3	1635	114	3947044	
IW-4	154.1	81	3437674	OPERATORS LOG IS COMPLETED

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74559	NM	2	12	
INF 2	73367		2	13	
INF 3	28430		SB	SB	STANDBY
ASF 1	41616		2	33	
ASF 2	49365		2	31	
ASF 3	42533		NIS	NIS	NOT IN SERVICE
GAC 1	44918		2	16	
GAC 2	48435		2	15	
GAC 3	33433	20712	SB	SB	STANDBY
REC 1	21934		OFF	OFF	
REC 2	39292		OFF	OFF	
INJ 1	65334		6	27	
INJ 2	39292		6	27	
INJ 3	-		NIS	NIS	NOT IN SERVICE
SUMP BLOWER		V			

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	13	11
AIR DRIER (PSI)	OL	OL

AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	56°	56°
Water Temp (°F)		15°C
V-GAC #1 (H <sub>2</sub> O")	2.65	0.65
V-GAC #2 (H <sub>2</sub> O")	0.1	0.1

Additional comments:


pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.35	
Reactor Tank 2	5.18	
AS. Feed	6.20	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4	
Treat. Train 2	13 1/2"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Supervisors Signature: Pat SchaalDate: 10-12-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J JACKSON

DATE: 10-08-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • Another very cool morning, NO RAIN, but a slight	
2) Wind.	
3)	
1) • the PLANT FINE over the Night	
2)	
2) • the HVAC UNIT was PUT ON, to see how IT	
1) RAN, SEEM TO BE much Quieter.	
2)	
1) • the Daily operation Log was completed	
2)	
1) • Began the PLANT house Keeping - Tightened the	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
NOT IN the TOILET Bow?	
• Began Vacuuming the upper level - Vacuum be	
gan Releasing Particals or small pieces being	
Picked up - 8" long x 1" Piece was Remove, hosed	
OUT Carbon SLUDGE From the Top section - Problem	
still remains.	
• Finish Vacuuming the Lower Level of PLANT.	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS

*P. Bakal 10-12-10*



# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-08-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

### Chemical Feed Skids

POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NBT
			IN
			SERVICE

### Process Tanks

EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

### Process Systems

INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			OK
			OK
			OK
			#3 Check VALVE - N-I-S
			OK
			OK

### Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

#### General Conditions and Comments

LITTLE TO NO WATER ON FLOOR
NONE
NONE
NONE

### Air Compressor

TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

#### General Conditions and Comments

OFF
LINE

### Air Stripper

COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

#### General Conditions and Comments

OK
OK
OK

### Notes and Comments:

PLANT HOUSEKEEPING DONE BY VACUUMING - UPPER AND LOWER LEVELS.

SIGNED: Pat [Signature]

DATE: 10-12-10

Operations and Maintenance Document

SOUND MONITORING WORK SHEET

Day	FRIDAY
Date	OCT 8 2010
Instrument ID	GREENLEE 93-20 #310
Battery Check	OK
Calibration Check	OK
Inspector	TAKACH

Area	Reading (dB)	Conditions
Office	64-66	Doors OPEN
HVAC Mezzanine	68-72	
Clarifier Mezzanine	72-74	
Injection Pumps (at motors)	82-86	
AS Feed Pumps (at Motors)	80-92	Pumps 1 & 2
Air Compressor Station	90	#2 ON
Air Stripper Tower Area	72-78	
AST Blower	88-92	
Paved Area	64-68	
Shop	70-72	Doors OPEN

Comments and Observations:

NM - Not Measured

Document No.:	Date of Issue:	Revision Level:
CPS-Form-015	July 9, 2010	F

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-08-10

Doc. No.: CPS-Form-011  
March 3 2008

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Monday  
**Date:** 10-11-10

**Weather Forecast:** Sunny and warm with temps at 54-74-64°F, wind at 508 from the north. RH at 60-85%, heavy rain and t-storms overnight expected.

**Total Volume Processed for Day:** 555,985 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 00:00 hrs.

**Reason for Downtime:**  
No downtime to report.

**Significant Operational Problems:**  
Start quarterly PW sampling

**Corrective Maintenance Performed:**  
None

**Verbal/Written Instruction from Government Personnel:**  
No new instructions received

**Inspections Performed and Results:**  
Daily site safety inspection completed

**Record of any tests performed, samples taken, and personnel involved:**  
Plant discharge pH and temp readings  
Sampled extraction wells for organic, inorganic and generic parameters

**Available Analytical Results:**  
No new data was available.

**Calibration Procedures Performed:**  
Calibrated lab pH meter  
Calibrated process pH meters  
Calibrated PID meter  
Calibrated Horiba multi meter

**General Remarks:**  
Plant continues to run with out any significant problems.  
Start of PW sampling

JSJ onsite, PET was out.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October, 201 120

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection  
Air Monitoring Log  
Employee Sign-In Sheet

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J. JACKSON

Day: Monday

Date: 10-11-10

Time: 0622

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
391	0	239.50

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	327734	163920	167250	166200	163850		63553
EW-2	266549	179540	183190	182030	179650		51294
EW-3	243228	187390	191350	140250	157420		61650

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	112.3	95	4171994	Temp @ 58°F, will rise to 72°F
IW-2	122.3	96	3826377	Today
IW-3	163.6	114	3996098	
IW-4	154.2	81	3472571	PLANT RAN WELL OVER WEEKEND

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	746.29	NM	2	10	
INF 2	734.38		3	11	
INF 3	284.30		SB	SB	STAND-BY
ASF 1	416.87		1	32	
ASF 2	494.86		2	31	
ASF 3	425.33		NIS	NIS	NOT IN SERVICE
GAC 1	449.88		3	16	
GAC 2	485.05		2	16	
GAC 3	334.33		SB	SB	STAND-BY
REC 1	219.34		OFF	OFF	
REC 2	207.42		OFF	OFF	
INJ 1	654.04		6	27	
INJ 2	393.63		8	27	
INJ 3	-		NIS	NIS	NOT IN SERVICE
SUMP					
BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	13	11
AIR DRIER (PSI)	OL	OL
AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	57°	57°
Water Temp (°F)		16°
V-GAC #1 (H <sub>2</sub> O")	260	0.05
V-GAC #2 (H <sub>2</sub> O")	OL	OL

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.21	5.86 / 17°C
Reactor Tank 2	5.09	5.89 / 17°C
AS. Feed	6.19	6.21 / 16°C
PLANT DISCHARGE - pH		5.01
PLANT DISCHARGE - Temp.		22°C

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:

Supervisors Signature:

*Peter Akmal*

Date

10-12-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J JACKSON

DATE: 10-11-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • THE PLANT RAN FINE OVER THE WEEKEND	
2)	
1) • THE PH'S AND TEMP'S WERE COMPLETED	
2)	
1) • THE OPERATORS LOG WERE COMPLETED	
2)	
1) • THE OAKTON PH METER - WAS CALIBRATED	
2)	
1) • THE PID WAS CALIBRATED - THE WEEKLY AIR MONITORING	
2) OF INSIDE & OUTSIDE PLANT, WAS TAKEN	
1)	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
• THE TRIP BLANK WAS TAKEN	
• AT EXT-1 THE WELL WAS DUMPING WELL, NO PROBLEM SAMPLES WERE TAKEN - 4 METALS / 6 VOAS / 2 TSS	
• AT EXT-2 PUMP SHUT DOWN - WENT BACK TO PLANT TO PUT PUMP IN MANUAL MODE - WELL QUICKLY STABILIZE	
• AT EXT-3 - THE INITIAL FLOW WAS VERY CLOUDY, AND BROWN IN COLOR. PUMP SHUT DOWN - WENT BACK TO PLANT TO PUT SWITCH IN MANUAL MODE. SAMPLES TAKEN - 1 METAL /	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS
3 VOAS / 1 TSS

*Pat Walsh 10-12-10*

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-10-10

**Check all areas, process systems, and equipment for general unsafe conditions.  
This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
POLYMER  
CAUSTIC  
POTASSIUM PERMANGANATE  
HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NDT
			IN
			SERVICE

Process Tanks  
EQUALIZATION  
TREATED WATER  
REACTORS  
CLARIFIERS  
SAND FILTERS  
CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

Process Systems  
INFLUENT  
SLUDGE SETTLER  
RECYCLE  
AIR STRIPPER FEED  
CARBON FEED  
INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	VALUE NOT IN SERVICE
✓	✓	✓	OK
✓	✓		OK

Floor and General Work Areas  
SLIP, TRIP, & FALL HAZARDS  
SHARP EDGES  
PINCH POINTS  
OTHER HAZARDS

### General Conditions and Comments

NONE
NONE
NONE
NONE

Air Compressor  
TANK  
AFTER COOLER  
AIR DRIER  
MOTOR & COMPRESSOR

### General Conditions and Comments

OFF
LINE

Air Stripper


COLUMN  
BLOWER & BELTS  
CARBON VESSELS

### General Conditions and Comments

OK
OK
OK

Notes and Comments:

SIGNED:



DATE: 10-12-10



# AIR MONITORING LOG CLAREMONT POLYCHEMICAL SUPERFUND SITE

Sampler Q. Jackson

Date 10-11-10

Calibration Standard(s) 100 PPM 1 ISOLIBUTYLENE  
Post-cal Readings 72.6 PPM 1 100 PPM

Location		Reading (ppm)
CONTROL ROOM		
	Laboratory	0.0
	Bathroom	0.0
	Office	0.0
PLANT		
	Influent Area	0.0
	Sludge Storage Area	0.0
	Sand Filter Area	0.0
	Air Compressor Area	0.0
	Sludge Press Area	0.0
EXTERIOR		
	Storage Tanks	0.0
	Upper (South West) Lot	0.0
	Lower (South East) Lot	0.0
	Air Stripper Area	0.0
	Back (North)	0.0
GAC VESSELS		
	#1 Influent	0.0
	#1 Effluent	0.0
	#2 Influent	OL
	#2 Effluent	OL

Comments: DID WAS CALIBRATED - AIR MONITORING OF PLANT  
INSIDE & OUTSIDE.

(QJ)

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-11-10

Doc. No.: CPS-Form-011  
March 2000

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Tuesday  
**Date:** 10-12-10

**Weather Forecast (am):** Mostly cloudy and wet. Temperatures are to range from 61-66-47°F. Wind will be 8-4 mph from the NNE-N. Relative humidity is 85-60% with clearing in afternoon.

**Total Volume Processed for Day:** 569,209 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 00:00 hrs.

**Reason for Downtime:**  
No downtime required

**Significant Operational Problems:**  
Coupling on INF Pump #3 failed

**Corrective Maintenance Performed:**  
Rotated pumps from 1&2 to 1&3  
Cleaned electrodes at reaction tanks  
Installed gland flange on ASF P3 check-valve

**Verbal/Written Instruction from Government Personnel:**  
No new instructions received

**Inspections Performed and Results:**  
Conducted site safety inspection, no new issues observed.

**Record of any tests performed, samples taken, and personnel involved:**  
Monitoring well water levels recorded  
Re-measured pH and temperature from plant discharge

**Available Analytical Results:**  
No new data available.

**Calibration Procedures Performed:**  
Lab pH meter was calibrated and logged in  
PID meter was calibrated and logged in  
Process pH meters were calibrated

**General Remarks:**  
Plant continues to run in a steady fashion. Plant flows were 372gpm in and 391 gpm out.  
  
Quarterly sampling tasks are underway.

Peter Takach (PET) and James Jackson (JSJ) were on site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach", written in a cursive style.

Peter Takach, October 13, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J Jackson

Day: Tuesday

Date: 10-12-10

Time: 0556

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
392	0	24008

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	327873	151260					63566
EW-2	266710	175430					57308
EW-3	243489	207390					6671

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.8	96	4186341	56° Cloudy & cool
IW-2	122.8	95	3840578	the operator log completed
IW-3	163.6	113	4613067	
IW-4	154.0	81	34846670	
PLANT RAN FINE OVERNIGHT				

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74653	NM	3	11	
INF 2	73412		3	12	
INF 3	28430		SB	SB	STAND-BY
ASF 1	41711		2	34	
ASF 2	49460		2	31	
ASF 3	42533		NIS	NIS	NOT IN SERVICE
GAC 1	45012		3	17	
GAC 2	46529		3	16	
GAC 3	33433		SB	SB	STAND-BY
REC 1	21934		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	65428		6	27	
INJ 2	39367		8	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	13	11
AIR DRIER (PSI)	OL	OL
AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	56°	56°
Water Temp (°F)		16°
V-GAC #1 (H <sub>2</sub> O")	2.65	0.10
V-GAC #2 (H <sub>2</sub> O")	OL	OL

Additional comments:

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.12	
Reactor Tank 2	4.82	
AS. Feed	6.10	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

NM = Not Measured

OL = Off Line

SB = Standby

NIS = Not in service

Supervisors Signature:

*Peter Akal*

Date

10-13-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

PERATOR: J. JACKSON

DATE: 10-12-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
• Temp 25.8° Cloudy, and Cool this Morning	
• The Plant is Running Fine	
• The Daily operators Log was Completed	
• The Pid was Calibrated	
• The Quarterly WATER Level was Completed	
(1) AT THE EW-1A,B,C WELL	
(2) WATER LEVELS TAKEN AT EW-2A,B,C & D / EW-3A,B,C	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
(3) LEVELS TAKEN AT EW-4A,B,C & D / EW-5 AND DW-2	
(4) AT EW-9D / EW-10C / EW-11 / EW-13D	
(5) AT MW-10B / MW-10C / MW-10D	
Note: Branch Blocking Rd AT MW-6D	
(6) AT MW-6D 94.65 LEVEL TAKEN	
Note Branch HAD to be TRIMMED AND REMOVED FROM ROAD	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS

*Patricia* 10-13-10

# DAILY SITE SAFETY INSPECTION CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-12-10

**Check all areas, process systems, and equipment for general unsafe conditions.  
This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
POLYMER  
CAUSTIC  
POTASSIUM PERMANGANATE  
HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT
			IN
			SERVICE

Process Tanks  
EQUALIZATION  
TREATED WATER  
REACTORS  
CLARIFIERS  
SAND FILTERS  
CARBON VESSELS (liq)

Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK

Process Systems  
INFLUENT  
SLUDGE SETTLER  
RECYCLE  
AIR STRIPPER FEED  
CARBON FEED  
INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

Floor and General Work Areas  
SLIP, TRIP, & FALL HAZARDS  
SHARP EDGES  
PINCH POINTS  
OTHER HAZARDS

**General Conditions and Comments**

NONE
NONE
NONE
NONE

Air Compressor  
TANK  
AFTER COOLER  
AIR DRIER  
MOTOR & COMPRESSOR

**General Conditions and Comments**

OFF
LINE

Air Stripper  
COLUMN  
BLOWER & BELTS  
CARBON VESSELS

**General Conditions and Comments**

OK
OK
OK

Notes and Comments:

AIR STRIPPER Check VALVE IS NOT IN SERVICE  
IN THE PROCESS OF BEING REBUILT.

SIGNED: \_\_\_\_\_

DATE: 10-13-10

CLAREMONT POLYCHEMICAL SUPERFUND SITE

# EMPLOYEE SIGN IN SHEET

DATE: 10-12-10

Doc. No.: CPS-Form-011  
March 3 2008



**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Wednesday  
**Date:** 10-13-10

**Weather Forecast (am):** Mostly sunny and cool. Temperatures are to range from 48-63-56°F. Wind will be at 7-3 from the NNE - SSE. Relative humidity is 45-50% with no rain expected.

**Total Gallons Processed for the day:** 562,343 gallons

**Plant Operating Hours:** 24:00 hrs. **Plant Total Downtime:** 00:00 hrs.

**Reason for Downtime:**  
No downtime to report

**Significant Operational Problems:**  
None

**Corrective Maintenance Performed:**  
Shimmed motor of INF P3 and replaced motor to pump transmission coupling

**Verbal/Written Instruction from Government Personnel:**  
USACE requests costs associated with non-CLP analytical costs

**Inspections Performed and Results:**  
Site safety inspection was conducted with nothing new to report.

**Record of any tests performed, samples taken, and personnel involved:**  
Quarterly Process Water (PW) sampling was completed with organic and inorganic samples sent to DESA and generic samples to ALSI.

**Available Analytical Results:**  
No new data available.

**Calibration Procedures Performed:**  
No calibrations required

**General Remarks:**

The plant has been running well at current flow levels. The average discharge from the plant was 391 gpm for the day.

The PW sampling task was completed with out any remarkable events

James Jackson (JSJ) was out, Peter Takach was on site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach".

Peter Takach, October 14, 2010

Attachments:

Daily Operating Log  
Daily Activities summary report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J. JACKSON

Day: WEDNESDAY Date: 10-13-10

Time: 0515

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
390	0	24063

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	328078	142950					63581
EW-2	266879	156250					67323
EW-3	243679	242460					61688

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.4	95	4199722	PLANT IS RUNNING FINE the operator log was completed
IW-2	122.4	96	3854185	
IW-3	163.6	113	4078898	
IW-4	154.0	80	3495961	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74676	NM	3	8	
INF 2	73480		3	13	
INF 3	28435		SB	SB	STAND-BY
ASF 1	41733		3	32	
ASF 2	49464		SB	SB	STAND-BY
ASF 3	42551		0	3	
GAC 1	45035		4	17	
GAC 2	48533		SB	SB	STAND-BY
GAC 3	33452		4	18	
REC 1	21934		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	65451		6	27	
INJ 2	39409		8	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP BLOWER		✓			

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	13	12
AIR DRIER (PSI)	OL	OL

AS Blower (H <sub>2</sub> O")	4.8	
Air Temp (°F)	56.0	56.0
Water Temp (°F)		14°C
V-GAC #1 (H <sub>2</sub> O")	2.60	0.00
V-GAC #2 (H <sub>2</sub> O")	OL	OL

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	536	
Reactor Tank 2	534	
AS. Feed	621	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 3/4"	

Additional comments:

Supervisors Signature: *Peter Akad*

Date 10-14-10

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACKSON

DATE: 10-13-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
• PLANT PERFORMED WELL LAST NIGHT, NO MAJOR ISSUES	
• ONE Problem @ INFLUENT Pump #3, BAD COUPLIN	
• the Daily operator Log was Completed	
• Began Taking Samples For the Quarterly plant sampling EVENT.	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
• The Samples were taken From Sample Location:	
① 002	
② 07A	
③ 08A/08B	
④ AT 009- PLANT DISCH.	
• Samples were Sealed, Labeled, AND Packaged in Coolers. - Will TAKE TO FEI-EX FOR DELIVERY	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS

*Retrieved* 10-14-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-13-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOV
			IN
			SERVICE

### Process Tanks

EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

### Process Systems

INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

### Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

#### General Conditions and Comments

NONE
NONE
NONE
NONE

### Air Compressor

TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

#### General Conditions and Comments

OFF
LINE

### Air Stripper

COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

#### General Conditions and Comments

OK
OK
OK

### Notes and Comments:

SAMPLES TAKEN AT VARIOUS LOCATION

SIGNED: P. P. P.

DATE: 10-14-10

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-13-10

Doc. No.: CPS-Form-011  
March 3 2008

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Thursday  
**Date:** 10-14-10

**Weather Forecast (am):** Sunny, cool, and clear. Temperatures are to range 45-64-50°F. Wind is from the ESE-east at 4-13 mph. Relative humidity is 70-90% with rain expected in late afternoon, heavy at times.

**Total Gallons Processed for day:** 560,389 gallons

**Plant Operating Hours:** 24:00 hrs. **Plant Total Downtime:** 00:00 hrs.

**Reason for Downtime:**  
No downtime to report

**Significant Operational Problems:**  
None

**Corrective Maintenance Performed:**  
Re-installed motor guard on INF P3  
General plant clean up  
Truck clean up

**Verbal/Written Instruction from Government Personnel:**  
No new instructions received

**Inspections Performed and Results:**  
Site safety inspection was completed with no new issues to note.

**Record of any tests performed, samples taken, and personnel involved:**  
No tests were performed or samples taken

**Available Analytical Results:**  
No new data is available.

**Calibration Procedures Performed:**  
No calibrations required

**General Remarks:**  
Plant flows are stable. The treatment plant ran without problems through out the period. Plant influent flow averaged 372 gpm and effluent flow at 390 gpm.

JSJ spotted 3 men at the old Claremont plant. They were gone by the time I arrived there. The building east side doors were closed.

James Jackson and Peter Takach were on site for O&M.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 15, 2010

Attachments:

Daily Operating Log  
Daily Activities summary report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File



Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: JACKSON

Day: Thursday

Date: 10-14-10

Time: 0510

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALS
391	0	24119

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	328188	164100					63597
EW-2	267054	179300					57339
EW-3	243863	187400					61704

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.3	96	4213351	58°F THIS MORNING
IW-2	122.4	95	3861854	the operator's Log completed
IW-3	163.6	113	4045018	
IW-4	154.1	81	3567469	PLANT IS RUNNING FINE

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74700	NM	1	8	
INF 2	73487		SB	SB	STAND-BY
INF 3	28451		3	13	
ASF 1	41757		2	34	
ASF 2	49464		SB	SB	STAND-BY
ASF 3	42575		0	31	
GAC 1	45059		4	18	
GAC 2	48533		SB	SB	STAND-BY
GAC 3	33476		4	18	
REC 1	21934		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	65475		6	27	
INJ 2	39433		6	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	12	8
GAC #2 (PSI)	14	11
AIR DRIER (PSI)	OL	OL

AS Blower (H <sub>2</sub> O")	4.7	
Air Temp (°F)	56°	56°
Water Temp (°F)		14°C
V-GAC #1 (H <sub>2</sub> O")	2.60	0.01
V-GAC #2 (H <sub>2</sub> O")	OL	OL

Additional comments:  
SOUNDING AT INJECTION WELLS  
#1, 2, 3 & 4 = NO PROBLEM @  
WELL.

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.31	
Reactor Tank 2	5.34	
AS. Feed	6.21	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/4"	

NM = Not Measured

OL = Off Line

SB = Standby

NIS = Not in service

Supervisors Signature: Petrakal

Date 10-15-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACKSON

DATE: 10-14-10

LISTING OF OPERATIONS ACTIVITIES		EQUIPMENT/MATERIALS USED	
1)	• Temp @ 58°F this Morning	PLANT	RUNNING FINE
2)			
3)	• the operator Log was completed		
4)			
5)	• Sounding of TW-1, 2, 3 & 4 wells		
6)			
7)	① EW-1	5.40	145.90
8)	② EW-2	13.78	241.65
9)	③ EW-3	5.40	249.10
10)	④ EW-4	12.83	198.00
11)			

LISTING OF MAINTENANCE ACTIVITIES		EQUIPMENT/MATERIALS USED	
•	PLANT CLEAN-UP WAS completed - Work Bench		
	CLEANED OFF, PLANT TRUCK WAS CLEANED OUT		
•	PLANT TRUCK WAS WASHED		
•	Call made to Beth View Mobil @ 220 MANETTO Hill		
	Rd BAINVIEW, NY 11803 - For Truck Inspection.		

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS

*Peter W. Neal* 10-15-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-14-10

**Check all areas, process systems, and equipment for general unsafe conditions.  
This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
POLYMER  
CAUSTIC  
POTASSIUM PERMANGANATE  
HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT
			IN
			SERVICE

### Process Tanks

EQUALIZATION  
TREATED WATER  
REACTORS  
CLARIFIERS  
SAND FILTERS  
CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

### Process Systems

INFLUENT  
SLUDGE SETTLER  
RECYCLE  
AIR STRIPPER FEED  
CARBON FEED  
INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
#3	✓		ELEMENT installed on #3
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

### Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
SHARP EDGES  
PINCH POINTS  
OTHER HAZARDS

#### General Conditions and Comments

NONE
NONE
NONE
NONE

### Air Compressor

TANK  
AFTER COOLER  
AIR DRIER  
MOTOR & COMPRESSOR

#### General Conditions and Comments

OFF
LINE

### Air Stripper

COLUMN  
BLOWER & BELTS  
CARBON VESSELS

#### General Conditions and Comments

OK
OK
OK

### Notes and Comments:

NEW ELEMENT INSTALLED, BY PETER O #3 INFLUENT SHED

SIGNED: Peter O

DATE: 10-18-10

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-14-10

[illegible]

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Friday  
**Date:** 10-15-10

**Weather Forecast**

**Fri.:** Cloudy, cool, and windy. Temperatures are to range from 50-59-48°F. Wind from WNW-west at 16-23 mph. Relative humidity is 55-65% with rain expected in the afternoon.

**Sat.:** Sunny, cool, windy. Temps: 49-60-45°F. Wind: 25>18 mph from WNW. RH 55-65%, no ppt.

**Sun.:** Sunny. Temps: 46-65-48°F. Wind: 16>10 mph from W-WNW. RH 65-70%, no ppt.

**Gallons Processed for the 3-day Period (10/15-10/18):** 1,698,427 Gallons

**Plant Operating Hours:** 72:00 hrs.

**Total Downtime:** 00:00 hrs.

**Reason for Downtime:**

No downtime required

**Significant Operational Problems:**

None

**Corrective Maintenance Performed:**

General plant clean up

**Verbal/Written Instruction from Government Personnel:**

No new instructions received

**Inspections Performed and Results:**

Daily site safety inspection performed – no new issues observed.

The NYS motor vehicle annual inspection was completed by local service station

**Record of any tests performed, samples taken, and personnel involved:**

No tests were performed or samples taken

**Available Analytical Results:**

No new data available

**Calibration Procedures Performed:**

No calibrations required

**General Remarks:**

The plant operation has been very stable. Influent and effluent flows have been steady at ~372 gpm in and 390+ gpm out. Injection well levels are steady.

General plant O&M continues

James Jackson (JSJ) and Peter Takach (PET) were on site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 18, 2010

Attachments:

Daily Operating Log  
Daily Site Safety Inspection Log  
Daily Activities Summary Report  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J JACKSON Day: FRIDAY Date: 10-25-10 Time: 0520

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
392	0	24175

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	328350	166610					65613
EW-2	267232	182580					57555
EW-3	244058	190880					61220

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.1	96	4227251	Light RAIN, ON AND OFF
IW-2	126.1	95	3881574	PLANT IS RUNNING FINE
IW-3	113.7	113	4661427	
IW-4	155.0	80	3519055	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74723	NM	1	8	
INF 2	73488		SB	SB	STAND-BY
INF 3	28474		3	13	
ASF 1	41780		1	34	
ASF 2	49414		SB	SB	STAND-BY
ASF 3	42598		0	31	
GAC 1	45082		4	17	
GAC 2	48533		SB	SB	STAND-BY
GAC 3	33499		4	18	
REC 1	21934		OFF	OFF	
REC 2	20747		OFF	OFF	
INJ 1	65498		6	27	
INJ 2	39456		8	27	
INJ 3	-		NIS	NIS	NOT IN SERVICE
SUMP					
BLOWER		V			

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	13	11
AIR DRIER (PSI)	02	02
AS Blower (H <sub>2</sub> O")	4.7	
Air Temp (°F)	56°	56°
Water Temp (°F)		74°
V-GAC #1 (H <sub>2</sub> O")	2.60	0.00
V-GAC #2 (H <sub>2</sub> O")	02	02

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.30	
Reactor Tank 2	5.32	
AS. Feed	6.22	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/4"	

Additional comments:

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Supervisors Signature: P. [Signature]Date: 10-18-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACKSON

DATE: 10-15-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
• THE PLANT RAN FINE LAST NIGHT	
• THE DAILY OPERATOR LOG WAS COMPLETED	
• TRUCK WAS DROPPED OFF TO NIGBIL STATION FOR INSPECTION	
• PAPER WORK WAS DONE	
• WENT OVER THE OPEN ENROLLMENT	

[illegible][illegible]

Petrol 10-18-10



# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-15-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids	Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
POLYMER				
CAUSTIC				NOT
POTASSIUM PERMANGANATE				IN
HYDROCHLORIC ACID				SERVICE

Process Tanks	Valves	Tanks	COMMENTS (include areas of leaks)
EQUALIZATION	✓	✓	OK
TREATED WATER	✓	✓	OK
REACTORS	✓	✓	
CLARIFIERS	✓	✓	
SAND FILTERS	✓	✓	
CARBON VESSELS (liq)	✓	✓	

Process Systems	Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
INFLUENT	✓	✓		OK
SLUDGE SETTLER	✓	✓	✓	OK
RECYCLE	✓	✓	✓	OK
AIR STRIPPER FEED	✓	✓	✓	OK
CARBON FEED	✓	✓	✓	OK
INJECTION	✓	✓		OK

Floor and General Work Areas	General Conditions and Comments
SLIP, TRIP, & FALL HAZARDS	NONE
SHARP EDGES	"
PINCH POINTS	"
OTHER HAZARDS	"

Air Compressor	General Conditions and Comments
TANK	
AFTER COOLER	OFF
AIR DRIER	LINE
MOTOR & COMPRESSOR	

Air Stripper	General Conditions and Comments
COLUMN	OK
BLOWER & BELTS	OK
CARBON VESSELS	OK

Notes and Comments:

SIGNED:



DATE:

10-18-10

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 16-15-10

25

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Monday  
**Date:** 10-18-10

**Weather Forecast (am):** Cloudy, cold, and damp. Temperatures are to range from 50-63-48°F. Wind is 7-10-7 mph from WNW-west. Relative humidity is 65-50% with no rain expected.

**Total Gallons Processed for Day:** 559,128 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 00:00 hrs.

**Reason for Downtime:**  
No downtime required

**Significant Operational Problems:**  
None

**Corrective Maintenance Performed:**  
General indoor and out door clean up

**Verbal/Written Instruction from Government Personnel:**  
No new instructions received

**Inspections Performed and Results:**  
Daily site inspection performed. No new issues to note.

**Record of any tests performed, samples taken, and personnel involved:**  
Performed plant air monitoring task – no emissions observed  
Plant discharge pH and temperature recorded.

**Available Analytical Results:**  
No new data available

**Calibration Procedures Performed:**  
The lab pH meter was calibrated. The lab PID meter was calibrated.  
Process pH electrodes were calibrated

**General Remarks:**  
Flows into and out of the plant have been stable. The plant discharge averaged 390 gpm for the period while the influent was 370 gpm. The injection well levels have been steady.

General O&M activities continue inside and outside the plant

James Jackson and Peter Takach were on-site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach".

Peter Takach, October 19, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Air Monitoring Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J. JACKSON

Day: MONDAY

Date: 10-19-10

Time: 0508

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
391	0	24344

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS ( HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	328841	163280	163550	166560	166610		63661
EW-2	267770	179490	179530	182710	182580		57404
EW-3	244615	187330	187460	190480	190880		6768

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.2	96	4268880	COOL MORNING, TEMPO @ 52°F AND PARTLY CLOUDY PLANT RAN FINE OVER WEEKEND.
IW-2	127.1	98	3922579	
IW-3	113.8	114	4110613	
IW-4	153.1	80	3553701	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74793	N/M	2	6	
INF 2	73488		SB	SB	STAND-BY
INF 3	28545		3	13	
ASF 1	41851		1	33	
ASF 2	49464		SB	SB	STAND-BY
ASF 3	42669		0	31	
GAC 1	45152		4	18	
GAC 2	48533		SB	SB	STAND-BY
GAC 3	33569		4	18	
REC 1	21934		OFF	OFF	
REC 2	26742		OFF	OFF	
INJ 1	65566		7	27	
INJ 2	39527		8	27	
INJ 3	-		NIS	NIS	NOT IN SERVICE
SUMP BLOWER		V			

	INLET	OUTLET
GAC #1 (PSI)	12	8
GAC #2 (PSI)	13	11
AIR DRIER (PSI)	OL	OL

AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	56°	56°
Water Temp (°F)		15°c
V-GAC #1 (H <sub>2</sub> O")	2.55	0.00
V-GAC #2 (H <sub>2</sub> O")	OL	OL

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.30	578/14°C
Reactor Tank 2	5.32	598/14°C
AS. Feed	6.22	627/14°C
PLANT DISCHARGE - pH		5.42
PLANT DISCHARGE - Temp.		14°C

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:

Supervisors Signature: [Signature]

Date: 10-19-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J JACKSON

DATE: 10/18/10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
• COOL MORNING, FEELS LIKE FALL, TEMP @ 52°F AND PARTLY CLOUDY	
• PLANT RAN FINE OVER THE WEEK END	
• THE WEEKLY TEMP & PH'S COMPLETED	
• THE PID WAS CALIBRATED - AIR MONITORING WAS DONE.	
• THE OPERATORS LOG WAS FINISHED	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
• THE REMAINING MONITORING WELL - FOR WATER	
• WELL BE LEAVING EARLY - HAVE CPR ADULT TRAINING THIS EVENING.	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS

*Tate Hail* 10-19-10

DATE: 10-18-10

Chemical Feed Skids  
POLYMER  
CAUSTIC  
POTASSIUM PERMANGANATE  
HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT IN SERVICE

Process Tanks

- EQUALIZATION
- TREATED WATER
- REACTORS
- CLARIFIERS
- SAND FILTERS
- CARBON VESSELS (liq)

[illegible]

Process Systems

- INFLUENT
- SLUDGE SETTLER
- RECYCLE
- AIR STRIPPER FEED
- CARBON FEED
- INJECTION

Pumps	Valves	Tanks	COMMENTS (Include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

Floor and General Work Areas  
SLIP, TRIP, & FALL HAZARDS  
SHARP EDGES  
PINCH POINTS  
OTHER HAZARDS

General Conditions and Comments	
NONE	
0	
0	
0	

Air Compressor  
TANK  
AFTER COOLER  
AIR DRIER  
MOTOR & COMPRESSOR

General Conditions and Comments	
	DEF LINE

Air Stripper  
COLUMN  
BLOWER & BELTS  
CARBON VESSELS

General Conditions and Comments	
OLC	
OLC	
OLC	

Notes and Comments:

SIGNED:

DATE:

10-19-10

# AIR MONITORING LOG CLAREMONT POLYCHEMICAL SUPERFUND SITE

Sampler J. JACKSON

Date 10-18-10

Calibration Standard(s) 100 PPM / ISOLIBUTENE  
Post-cal Readings 114.0 PPM / 100 PPM

Location		Reading (ppm)
CONTROL ROOM		
	Laboratory	0.0
	Bathroom	0.0
	Office	0.0
PLANT		
	Influent Area	0.0
	Sludge Storage Area	0.0
	Sand Filter Area	0.0
	Air Compressor Area	0.0
	Sludge Press Area	0.0
EXTERIOR		
	Storage Tanks	0.0
	Upper (South West) Lot	0.0
	Lower (South East) Lot	0.0
	Air Stripper Area	0.0
	Back (North)	0.0
GAC VESSELS		
	#1 Influent	0.0
	#1 Effluent	0.0
	#2 Influent	0.0
	#2 Effluent	0.0

Comments: PID WAS CALIBRATED - AIR MONITORING  
DONE

PGT



CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-18-10  
(MON)

Doc. No.: CPS-Form-011

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Tuesday  
**Date:** 10-19-10

**Weather Forecast (am):** Cloudy, rain, and cool. Temperatures are to range from 48-59-47°F. The wind will be from the SSE-SSW at 1-5 mph. Relative humidity is 70% with clearing in afternoon.

**Total Gallons Processed for period:** 561,304 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 0:00 hrs.

**Reason for Downtime:**

No downtime required

**Significant Operational Problems:**

Differential pressure is rising in carbon adsorber vessels

**Corrective Maintenance Performed:**

Outdoor clean up

Leveled stone at pavement to remove trip hazard

**Verbal/Written Instruction from Government Personnel:**

No new instructions received

**Inspections Performed and Results:**

Site safety inspection was conducted with nothing new to report.

**Record of any tests performed, samples taken, and personnel involved:**

No tests performed or samples taken

**Available Analytical Results:**

No new analytical results were available

**Calibration Procedures Performed:**

No calibrations required

**General Remarks:**

The general plant operation has been very stable. Flows into and out of the plant are high but steady – influent 370 gpm, effluent 390 gpm. The injection well water levels are holding steady.

James Jackson and Peter Takach were on-site for O&M.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 20, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J. JACKSON

Day: Tuesday

Date: 10-19-10

Time: 0545

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
185	185	370

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
390	0	24402

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS ( HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	329011	166850					63678
EW-2	267956	183150					57420
EW-3	244811	191250					61785

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.2	96	4283242	Light RAIN, Temp 43°F PLANT IS RUNNING FINE
IW-2	127.3	94	3931698	
IW-3	113.7	114	4127577	
IW-4	155.0	79	3565636	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74817	NM	2	8	
INF 2	73488		SB	SB	STAND-BY
INF 3	28519		3	13	
ASF 1	41875		2	32	
ASF 2	49464		SB	SB	STAND-BY
ASF 3	42693		0	30	
GAC 1	45176		4	18	
GAC 2	48533		SB	SB	STAND-BY
GAC 3	33593		4	17	
REC 1	21934		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	65593		6	27	
INJ 2	39551		8	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP					
BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	12	8
GAC #2 (PSI)	13	11
AIR DRIER (PSI)	OL	OL
AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	56°	56°
Water Temp (°F)		15°
V-GAC #1 (H <sub>2</sub> O")	2.60	0.00
V-GAC #2 (H <sub>2</sub> O")	OL	OL

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.30	
Reactor Tank 2	5.32	
AS. Feed	6.22	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:

Supervisors Signature: Pete Whal

Date: 10-20-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACILSON

DATE: 10-19-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
• Light RAIN this MORNING - TEMP AT 43°F	
• THE DAILY OPERATOR LOG WAS COMPLETED	
• THE PLANT HOUSE KEEPING WAS DONE, OLD PUMP, BUTTERFLY VALVES WERE TAKEN TO SCRAP YARD.	
• THE REAR TRUCK BED WAS CLEANED OUT	
• STONE WERE PUT AGAINST WALKWAY TO	

[illegible][illegible]

Peter Hall 10-20-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-19-10

**Check all areas, process systems, and equipment for general unsafe conditions.  
This is to include but is not limited to the observation of leaks, noise, abnormal function.**

### Chemical Feed Skids

POLYMER  
CAUSTIC  
POTASSIUM PERMANGANATE  
HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT
			IN
			SERVICE

### Process Tanks

EQUALIZATION  
TREATED WATER  
REACTORS  
CLARIFIERS  
SAND FILTERS  
CARBON VESSELS (liq)

Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK

### Process Systems

INFLUENT  
SLUDGE SETTLER  
RECYCLE  
AIR STRIPPER FEED  
CARBON FEED  
INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

### Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
SHARP EDGES  
PINCH POINTS  
OTHER HAZARDS

General Conditions and Comments
NONE

### Air Compressor

TANK  
AFTER COOLER  
AIR DRIER  
MOTOR & COMPRESSOR

General Conditions and Comments
OFF
LINE

### Air Stripper

COLUMN  
BLOWER & BELTS  
CARBON VESSELS

General Conditions and Comments
OK
OK
OK

### Notes and Comments:


SIGNED: \_\_\_\_\_

*[Signature]*

DATE: 10-20-10

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-19-10



**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Wednesday

**Date:** 10-20-10

**Weather Forecast (am):** Cloudy, cold, and damp. Temperatures are to range from 45-62-50°F. Wind will be from the WNW-SSW at 1-11-10 mph. Relative humidity is 55-70% with no precipitation expected.

**Total Gallons Processed for day:** 564,706 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 00:00hrs.

**Reason for Downtime:**

No downtime required

**Significant Operational Problems:**

None

**Corrective Maintenance Performed:**

Repaired parts of shed  
Rebuilt truck bed fixture

**Verbal/Written Instruction from Government Personnel:**

Submitted ASR for November samples

**Inspections Performed and Results:**

Site safety inspection was conducted with nothing new to report.

**Record of any tests performed, samples taken, and personnel involved:**

No tests performed or samples taken

**Available Analytical Results:**

No new data available.

**Calibration Procedures Performed:**

No calibrations required

**General Remarks:**

The plant is running in a very stable mode with consistent influent and effluent flows. Influent flow is set at 370 gpm and plant effluent averaged 390 gpm for the day.

Continue to clean up plant and equipment.

James Jackson (JSJ) and Peter Takach were on site.



Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 21, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J. JACKSON Day: WEDNESDAY Date: 10-20-10 Time: 0650

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
185	186	371

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
389	0	24459

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	329176	165710					63694
EW-2	288137	181890					57436
EW-3	245001	189930					61801

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	112.2	96	4297308	PLANT RAN FINE OVER NIGHT COOL MORNING TEMP @ 50°F
IW-2	127.8	94	3950488	
IW-3	113.7	113	4144194	
IW-4	155.2	80	3577318	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74641	NM	2	8	
INF 2	73488		SB	SB	STAND-BY
INF 3	28592		3	13	
ASF 1	21898		1	32	
ASF 2	49464		SB	SB	STAND-BY
ASF 3	42716		0	31	
GAC 1	45200		4	18	
GAC 2	48533		SB	SB	STAND-BY
GAC 3	33617		4	18	
REC 1	21934		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	15616		6	27	
INJ 2	39574		8	27	
INJ 3	-		NIS	NIS	NOT IN SERVICE
SUMP BLOWER		V			

	INLET	OUTLET
GAC #1 (PSI)	11	8
GAC #2 (PSI)	14	11
AIR DRIER (PSI)	02	01
AS Blower (H <sub>2</sub> O")	4.7	
Air Temp (°F)	56°	56°
Water Temp (°F)		142
V-GAC #1 (H <sub>2</sub> O")	2.60	0.00
V-GAC #2 (H <sub>2</sub> O")	02	02

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.31	
Reactor Tank 2	5.32	
AS. Feed	6.22	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/4"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:

Supervisors Signature: [Signature]

Date: 10-21-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: JACKSON

DATE: 10-20-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
• COOL MORNING IN THE AREA, TEMP @ 50°F, SHOULD REACH 70'S TODAY	
• THE PLANT DID RUN WELL OVER NIGHT	
• THE DAILY OPERATORS LOG WAS DONE	
• WENT TO HOME DEPOT, TO PICK UP NEEDED ITEMS.	
• REPAIR MADE TO PLANT SHELL - FALLEN TRIM	

[illegible]

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS

Pete Whall 10-21-10

**DAILY SITE SAFETY INSPECTION**  
**CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)**

DATE: 10-20-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			OUT
			OF
			SERVICE

Process Tanks  
 EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK

Process Systems  
 INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

Floor and General Work Areas  
 SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

**General Conditions and Comments**

NONE

Air Compressor  
 TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

**General Conditions and Comments**

OFF
LINE


Air Stripper  
 COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

**General Conditions and Comments**

OK
OK
OK

Notes and Comments:

SIGNED:



DATE: 10-21-10

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-20-16

Doc. No.: CPS-Form-011  
March 3 2008

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Thursday  
**Date:** 10-21-10

**Weather Forecast (am):** Cloudy, cold, and damp. Temperatures are to range from 53-63-47°F. Wind to be 8-16-10 mph from the SSW-WNW. RH is 65-50%. Scattered showers are expected.

**Total Gallons Processed for day:** 446,397 gallons

**Plant Operating Hours:** 19:30 hrs. **Plant Total Downtime:** 4:30 hrs.

**Reason for Downtime:**

Both Carbon Adsorber (CA) vessels were sparged and backwashed

**Significant Operational Problems:**

Influent pump #3 failed upon restart of plant. Overload relay would not reset.

**Corrective Maintenance Performed:**

Backwashed CA vessels through 2 cycles each

Removed, cleaned, and calibrated ASF pH electrode. It would not take calibration – error E2

Rotated process pumps from 1&3 to 2&3

INF P3 was electrically tested at MCC bucket. It was taken off line.

**Verbal/Written Instruction from Government Personnel:**

US EPA assigned DESA Lab for the November PD samples.

**Inspections Performed and Results:**

Site safety inspection was completed with no new issues to note.

**Record of any tests performed, samples taken, and personnel involved:**

Injection well falling head tests were completed. IW-2 is reading ~ 30 below actual water level.

**Available Analytical Results:**

No new data is available.

**Calibration Procedures Performed:**

Calibrated process ASF pH electrode

**General Remarks:**

The treatment plant continues to run in a stable mode with flows near maximum.

The backwashing of the CA vessels revealed a lot of fines in the beds. Several more cycles will be required to clean them.

James Jackson and Peter Takach were on-site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 22, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J JACKSON Day: Thursday Date: 10-21-10 Time: 0539

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
183	185	368

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
368	0	24514

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS ( HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	329332	163290					63710
EW-2	268309	179120					57452
EW-3	245181	186820					61817

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	112.2	96	4310925	PLANT IS RUNNING FINE ANOTHER COOL MORNING, TEMP AT 49°F
IW-2	128.1	91	3913684	
IW-3	113.7	114	4160167	
IW-4	155.3	79	3588542	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74864	NM	1	5	
INF 2	73488		SB	SB	STAND-BY
INF 3	28615		3	13	
ASF 1	41921		2	33	
ASF 2	49414		SB	SB	STAND-BY
ASF 3	42740		0	31	
GAC 1	45223		4	18	
GAC 2	48533		SB	SB	STAND-BY
GAC 3	33640		4	18	
REC 1	21934		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	65639		6	27	
INJ 2	39598		8	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	12	8
GAC #2 (PSI)	14	12
AIR DRIER (PSI)	OL	OL
AS Blower (H <sub>2</sub> O")	4.7	
Air Temp (°F)	56°	56°
Water Temp (°F)		14°
V-GAC #1 (H <sub>2</sub> O")	2.60	0.00
V-GAC #2 (H <sub>2</sub> O")	OL	OL

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.30	
Reactor Tank 2	5.32	
AS. Feed	6.22	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/4"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:  
PLANT DOWN @ 6:50 FOR BACK  
WASH.

Supervisors Signature: P. H. Akach

Date: 10-22-10



DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK

OPERATOR: J Jackson

DATE: 10-21-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
• PLANT OPERATOR LOG WAS COMPLETED	
• THE PLANT WAS SHUT DOWN @ 0650	
• AIR IS NOW BEING PUT IN CAC #1 @ 0740 - BEGIN BACKWASH @ 0755 AM	
• 0810 - 1ST BACKWASH @ CAC #1 - WATER VERY DIRTY FINISH AIR @ 0830	
• 0905 - 2ND BACKWASH DONE @ CAC #1	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
• 0908- AIR INTRODUCED TO CAC #2 - BACKWASH AT 0930	
• THE FIRST BACKWASH AT CAC #2 @ 10:15	
• 2ND BACK WASH DONE	
• 1200 PLANT BACK ON LINE -	
• Problem With #3 INFLUENT PUMP - NO JUICE COMING OUT BLOCK.	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS

*Peter Akal* 10-22-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-21-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (Include areas of leaks)
			OUT
			DE
			SERVICE

Process Tanks  
 EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

Valves	Tanks	COMMENTS (Include areas of leaks)
✓	✓	OK
✓	✓	OK - DOWN!
✓	✓	OK
-	-	DOWN
-	-	DOWN
-	-	DOWN

Process Systems  
 INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (Include areas of leaks)
-	CLOSED		BACKWASH IN Progress
-	CLOSED	-	-
DOWN	DOWN	-	BACKWASH IN Progress
DOWN	DOWN	-	BACKWASH IN Progress
DOWN	DOWN	-	BACKWASH IN Progress
✓			USED FOR BACKWASH

Floor and General Work Areas  
 SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

### General Conditions and Comments

NONE
"
"
"

Air Compressor  
 TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

### General Conditions and Comments

OFF
LINE

Air Stripper  
 COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

### General Conditions and Comments

DOWN - BACKWASH IN Progress
DOWN - BACKWASH IN Progress
DOWN - BACKWASH IN Progress

Notes and Comments:

1200 - BACKWASH COMPLETE - PLANT BACK ON LINE  
 Problem With INFLUENT PUMP SEEM TO CORRECT IN SELF

SIGNED:

*[Signature]*

DATE:

10-22-10

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-21-10

②

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Friday  
**Date:** 10-22-10

**Weather Forecast (am):**

**Fri:** Cloudy and cool. Temps are expected to reach 46-54-42°F. Winds to be 14-18-13 mph from WNW. RH is 65-45 with no precipitation expected.

**Sat:** Sunny, 43-63-51°F, wind 13-16 mph from WSW, 55% RH, chance of late showers

**Sun:** Cloudy, 52-65-56°F, wind 12-6 mph from south, 79% RH, scattered showers

**Total Gallons Processed for period (9/17-9/20):** 1,683,763 gallons

**Plant Operating Hours:** 72:00 hrs.

**Plant Total Downtime:** 0:00 hrs.

**Reason for Downtime:**

No downtime to report

**Significant Operational Problems:**

None

**Corrective Maintenance Performed:**

Decanted sludge tank

Winterized outdoor tank level monitor elements

Drained truck plow pump of hydraulic fluid.

**Verbal/Written Instruction from Government Personnel:**

No new communications

**Inspections Performed and Results:**

Daily site safety inspection completed with no new issues.

Completed comprehensive site safety inspections

**Record of any tests performed, samples taken, and personnel involved:**

Plant sound level monitoring was completed.

**Available Analytical Results:**

No new data was available.

**Calibration Procedures Performed:**

Sound level meter was calibrated

**General Remarks:**

The plant has been running in a pretty steady state. Influent Pump 3 restarted and ran without problems. Plant influent flows are stable at ~370gpm and plant effluent flows are holding at

390gpm.

Normal plant O&M activities continued and end of the month documentation is underway.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach".

Peter Takach, October 25, 2010

Attachments:

Daily Operating Log  
Daily activities Summary Report  
Daily Site Safety Inspection  
Sound Level Monitoring Worksheet  
Employee Sign-In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J JACOBSON Day: FRIDAY Date: 10-22-10 Time: 0510

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
187	186	373

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
385	0	24558

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	329459	127760					63122
EW-2	266447	140450					57464
EW-3	245326	146460					61829

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	163.2	94	4321319	PLANT RAN FINE OVERNIGHT
IW-2	115.8	91	3974311	USED COMPRESSOR SLIGHTLY
IW-3	163.3	110	4172566	
IW-4	153.4	81	3597761	DRAINED SLUDGE TANK

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74882	NM	1	7	
INF 2	73505		1	12	
INF 3	28616		SB	SB	STAND-BY
ASF 1	41922		SB	SB	STAND-BY
ASF 2	49481		0	30	
ASF 3	42758		0	31	
GAC 1	45224		SB	SB	STAND-BY
GAC 2	48551		2	15	
GAC 3	33654		2	16	
REC 1	21934		OFF	OFF	
REC 2	26742		OFF	OFF	
INJ 1	25638		6	26	
INJ 2	39616		7	26	
INJ 3	NIS		NIS	NIS	NOT IN SERVICE
SUMP BLOWER		V			

	INLET	OUTLET
GAC #1 (PSI)	9	8
GAC #2 (PSI)	10	11
AIR DRIER (PSI)	OL	OL

AS Blower (H <sub>2</sub> O")	4.9	
Air Temp (°F)	56°	52°
Water Temp (°F)		15°c
V-GAC #1 (H <sub>2</sub> O")	245	0.00
V-GAC #2 (H <sub>2</sub> O")	01	02

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.31	
Reactor Tank 2	5.33	
AS. Feed	6.34	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1		
Treat. Train 2		

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:  
DECANT VALVE #1

Supervisors Signature: P. W. K. A. L.

Date: 10-25-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACKSON

DATE: 10-22-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • THE DAILY OPERATORS LOG WAS COMPLETED	
2)	
3) • SUMP DUMP TURNED ON TO PUMP OUT FLOOR	
4) SUMP.	
5)	
6) • BEGAN TO DECANT SLUDGE TANK.	
7)	
8) • LEVEL CONTROLLERS WERE INSULLATED:	
9) ① AT EQ TANK	
10) ② AT TREATMENT TANK #1	
11) ③ AT TREATMENT TANK #2	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • DRAINED HYDRAULIC OIL FROM MIXERS, ELECTRIC-LIFT	
2) AND SNOW BLOW CONTROL SYSTEM.	
3)	
4) • CALL MADE TO RW TRUCK EQUIPMENT CORP - SPOKE TO	
5) TOMY ABOUT PRICE OF HYDRAULIC OIL	
6)	
7) • PLANT TRASH CAN WAS EMPTIED FOR THE WEEK-END	
8)	
9)	
10)	
11)	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS
1)

*Patricia* 10-25-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-22-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

### Chemical Feed Skids

POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NIST
			IN
			SERVICE

### Process Tanks

EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

### Process Systems

INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

### Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

#### General Conditions and Comments

NONE - WEATHER HAS CHANGED - COOLER

### Air Compressor

TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

#### General Conditions and Comments

OFF
LINE
* USED SLIGHTLY TODAY

### Air Stripper

COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

#### General Conditions and Comments

OK
OK
OK

### Notes and Comments:

\*AIR COMPRESSOR WAS USED SLIGHTLY TODAY.

SIGNED: \_\_\_\_\_

*P. B. [Signature]*

DATE: 10-25-10



Operations and Maintenance Document

SOUND MONITORING WORK SHEET

Day	FRIDAY
Date	10-22-10
Instrument ID	GREENWICH 93-20 #310
Battery Check	OK
Calibration Check	OK
Inspector	TAKACH

Area	Reading (dB)	Conditions
Office	60-64	DOORS OPEN
HVAC Mezzanine	NM	
Clarifier Mezzanine	76-84	
Injection Pumps (at motors)	82-84	
AS Feed Pumps (at Motors)	96-98	P2 & 3
Air Compressor Station	86-92	P1
Air Stripper Tower Area	72-78	
AST Blower	84-86	
Paved Area	62-66	
Shop	74-76	DOOR TO PARK CLOSE

Comments and Observations:

NM - Not Measured

Document No.:	Date of Issue:	Revision Level:
CPS-Form-015	July 9, 2010	F

**CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET**

12

[illegible]

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Monday  
**Date:** 10-25-10

**Weather Forecast (am):** partly sunny and mild. The temps are to range from 49-68-60°F. Wind is from the SSW-south at 8-14-12 mph. Relative humidity is 80-90%. Rain is expected late with possible scattered t-storms.

**Total Volume Processed for Day:** 557,291 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 0:00 hrs.

**Reason for Downtime:**  
No downtime required

**Significant Operational Problems:**  
The pump for extraction well #1 failed. Overload relay would not reset

**Corrective Maintenance Performed:**  
Decanted sludge tank  
Secured plow pump on truck  
Performed electrical checks on EXT well #1 pump at MCC and at pump

**Verbal/Written Instruction from Government Personnel:**  
No new instructions received

**Inspections Performed and Results:**  
Conducted site safety inspection, no new issues found.  
Inspected well field

**Record of any tests performed, samples taken, and personnel involved:**  
The pH and temperature readings were taken from plant discharge stream  
Plant air monitoring task was completed

**Available Analytical Results:**  
No new data received

**Calibration Procedures Performed:**  
The lab pH meter was calibrated and logged in.  
PID meter was calibrated and logged in  
The process pH meters were calibrated

**General Remarks:**  
The plant is running smoothly. Plant discharge flow is stable and averaged ~390 gpm for the day.

Injection well levels are also stable.

End of the month documentation is underway  
James Jackson (JSJ) and Peter Takach (PET) were on site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach".

Peter Takach, October 26, 2010

Attachments:

- Daily Operating Log
- Daily Activities Summary Report
- Daily Site Safety Inspection Log
- Air Monitoring Log
- Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J JACKSON

Day: MONDAY

Date: 10-25-10

Time: 0540

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
180	187	367

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALS
386	0	24727

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	329879	163210	164670	166470	127750		63764
EW-2	269023	179270	180160	182280	140450		57516
EW-3	245932	187120	188840	190620	141460		61881

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	112.8	94	4312614	* EW-1 PUMP TRIPPED OUT, BACK ON LINE @ 0540 - FOUND WEAK AMPERAGE AT (BOX - MCC)
IW-2	117.5	95	4015023	
IW-3	163.4	110	4220822	
IW-4	104.4	79	3632917	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74885	NM	SB	SB	STAND-BY
INF 2	73576		2	11	
INF 3	28685		2	9	
ASF 1	41922		SB	SB	STAND-BY
ASF 2	49552		0	31	
ASF 3	42829		0	31	
GAC 1	45224		SB	SB	STAND-BY
GAC 2	48622		2	15	
GAC 3	33729		2	16	
REC 1	21935		OFF	OFF	
REC 2	20742		OFF	OFF	
INJ 1	65729		6	27	
INJ 2	39687		8	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP					
BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	10	8
GAC #2 (PSI)	10	11
AIR DRIER (PSI)	02	02
AS Blower (H <sub>2</sub> O")	4.7	
Air Temp (°F)	560	560
Water Temp (°F)		15°C
V-GAC #1 (H <sub>2</sub> O")	2.45	0.00
V-GAC #2 (H <sub>2</sub> O")	02	01

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	4.86	590   14°C
Reactor Tank 2	4.94	597   14°C
AS. Feed	5.92	612   14°C
PLANT DISCHARGE - pH		6.49
PLANT DISCHARGE - Temp.		14°C

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

NM = Not Measured


OL = Off Line

SB = Standby

NIS = Not in service

Additional comments:

EW-1 WELL DOWN @ 6:15 PM

Supervisors Signature: 

Date 10-26-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: JAMES JACKSON

DATE: 10-25-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • COOL, Foggy Morning, Temp @	
2)	
3) • the WEEKLY PH & TEMP WAS COMPLETED	
4)	
5) • THE PID WAS CALIBRATED - AIR MONITORING WAS	
6) COMPLETED	
7)	
8) • the OPERATED WAS COMPLETED	
9)	
10) • EXT-1 TRIPPED OUT OVER WEEK END RESET THIS	
11) MORNING @ 0520 AM	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • CHECK (AC) AMPERAGE LOW - COMING OUT BOX.	
2)	
3) • INVESTIGATION AT EXT-1 WELL, ALL WIRES WERE TIGHT.	
4)	
5) • FINISH DRAIN WATER FROM SLUDGE TANK	
6)	
7) • SECURED THE SNOW PLOW ARM BY ADDING WASHERS	
8) TO BOLTS.	
9)	
10)	
11)	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS
1)

*Peterson* 10-26-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-25-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT
			IN
			SERVICE

Process Tanks

EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK

Process Systems

INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

General Conditions and Comments

NONE
11
11
11

Air Compressor

TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

General Conditions and Comments

OFF
LINE

Air Stripper

COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

General Conditions and Comments

OK
OK
OK

Notes and Comments:

EXT-1 PUMP TRIPPED OUT OVER WEEK END - RESET -  
 STILL HAS WEAK AMPERAGE AT M.E. BLOCK.

SIGNED:

*[Signature]*

DATE:

10-26-10

# AIR MONITORING LOG CLAREMONT POLYCHEMICAL SUPERFUND SITE

Sampler JAMES JACKSON

Date 10-25-10

Calibration Standard(s) 100 PPM 1 ISOL BUTYLENE  
Post-cal Readings 81.5 PPM 1 100 PPM

Location		Reading (ppm)
CONTROL ROOM		
	Laboratory	0.0
	Bathroom	0.0
	Office	0.0
PLANT		
	Influent Area	0.0
	Sludge Storage Area	0.0
	Sand Filter Area	0.0
	Air Compressor Area	0.0
	Sludge Press Area	0.0
EXTERIOR		
	Storage Tanks	0.0
	Upper (South West) Lot	0.0
	Lower (South East) Lot	0.0
	Air Stripper Area	0.0
	Back (North)	0.0
GAC VESSELS		
	#1 Influent	0.0
	#1 Effluent	0.0
	#2 Influent	0.0
	#2 Effluent	0.0

Comments: PID CALIBRATED - AIR MONITORING WAS DONE.

(Pet)



**CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET**

DATE: 10-25-10

Doc. No.: CPS-Form-011  
March 3, 2008.

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Tuesday  
**Date:** 10-26-10

**Weather Forecast (am):** Sunny, warm, and damp. Temperatures are expected to range from 62-67-61°F. Wind will come from the SSW at 9-12 mph. Relative humidity is 85-95 with no rain expected.

**Total Volume Processed for Day:** 561,560 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 00:00 hrs.

**Reason for Downtime:**  
No downtime to report

**Significant Operational Problems:**  
Carbon sludge buildup in RCY tank introduced carbon into the treatment flow. Some turbidity ensued.

**Corrective Maintenance Performed:**  
Emptied sludge tank of carbon waste through filter press  
Removed some carbon sludge from RCY tank  
Worked on EXT 1 pump overload relay, got reset and returned pump to service

**Verbal/Written Instruction from Government Personnel:**  
No new instructions

**Inspections Performed and Results:**  
Site safety inspection was completed. There is nothing new to report.

**Record of any tests performed, samples taken, and personnel involved:**  
No tests performed or samples taken

**Available Analytical Results:**  
No new data is available.

**Calibration Procedures Performed:**  
No calibrations required.

**General Remarks:**  
The plant is stable at current flow levels. Influent flow is at 372 gpm and plant discharge is 392.  
End of the month documentation has started.

James Jackson (JSJ) and Peter Takach (PET) were on site today.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 27, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J. JACKSON

Day: TUESDAY

Date: 10-26-10

Time: 0519

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
181	181	374

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
390	0	247.82

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	329892	24770					63765
EW-2	269275	253090					57539
EW-3	246197	263860					61903

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	1629	96	4375966	WARM MORNING - TEMP 67°C PLANT IS RUNNING FINE
IW-2	1163	95	4028323	
IW-3	1634	111	4236578	
IW-4	1548	81	3644327	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74885	NM	SB	SB	STAND-BY
INF 2	73599		1	11	
INF 3	28708		2	8	
ASF 1	41922		SB	SB	STAND-BY
ASF 2	49575		6	31	
ASF 3	42852		0	31	
GAC 1	45224		SB	SB	STAND-BY
GAC 2	48645		2	15	
GAC 3	33753		2	16	
REC 1	21935		OFF	OFF	
REC 2	20142		OFF	OFF	
INJ 1	65750		7	27	
INJ 2	39710		8	27	
INJ 3	-		12	61	
SUMP					OFF LINE
BLOWER		✓			

	INLET	OUTLET
GAC #1 (PSI)	8	8
GAC #2 (PSI)	9	11
AIR DRIER (PSI)	01	01
AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	56°	56°
Water Temp (°F)		15°C
V-GAC #1 (H <sub>2</sub> O")	2.45	0.40
V-GAC #2 (H <sub>2</sub> O")	01	01

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	4.88	
Reactor Tank 2	4.63	
AS. Feed	5.93	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:

Supervisors Signature: [Signature]

Date

10-27-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACKSON

DATE: 10-26-10

LISTING OF OPERATIONS ACTIVITIES		EQUIPMENT/MATERIALS USED
1)	• THIS IS RATHER A WARM MORNING, TEMP @ 67°F	
2)		
3)	• THE PLANT IS RUNNING FINE - NO MAJOR PROBLEMS	
4)		
5)	• THE DAILY OPERATORS LOG WAS COMPLETED	
6)		
7)	• HOSE BROUGHT IN TO DRAIN SLUDGE TANK - HOSE	
8)	WAS NOT NEEDED.	
9)		
10)	• SLUDGE TANK PUMP, WOULD NOT PUMP, UNION RE	
11)	MOVED, OIL PUT IN CHAMBER, STILL DID NOT PUMP	

LISTING OF MAINTENANCE ACTIVITIES		EQUIPMENT/MATERIALS USED
1)	INCREASED PRESSURE, WITH TAPPING THE CASING	
2)	IT BEGAN TO WORK	
3)		
4)	• OCEAN SLUDGE TR WAS EMPTIED, AND AIR PUT TO	
5)	FILTER PRESS.	
6)		
7)	• WHILE FILLING FILTER PRESS WITH SLUDGE	
8)		
9)		
10)		
11)		

**IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS**

1)	

*Richard* 10-27-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-26-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT
			IN
			SERVICE

### Process Tanks

EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

### Process Systems

INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

### Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

#### General Conditions and Comments

SOME WATER ON FLOOR
NONE
"
"

### Air Compressor

TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

#### General Conditions and Comments

OK
OK
OK
USED BRIEFLY TO AIR OUT SLUDGE TK.

### Air Stripper

COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

#### General Conditions and Comments

OK
OK
OK

### Notes and Comments:

SLUDGE TANK IS BEING EMPTIED, SLUDGE BEING SENT TO FILTER PRESS.

SIGNED: Peter T. K...

DATE: 10-27-10

CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET

DATE: 10-22-10

[illegible]

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Wednesday

**Date:** 10-27-10

**Weather Forecast (am):** Raining, warm, and muggy. Temperatures are to range from 66-70-56°F. Wind is expected from the SSW at 12-8 mph. Relative humidity is 85-100%. Rain is expected throughout the day, heavy at times with possible T-storm activity.

**Total Volume Processed for Day:** 568,688 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 0:00 hrs.

**Reason for Downtime:**  
No downtime to report

**Significant Operational Problems:**  
A large amount of carbon has found its way into the RCY tank

**Corrective Maintenance Performed:**  
Worked on carbon problem in RCY tank  
Cleaned pH electrodes in reaction tanks

**Verbal/Written Instruction from Government Personnel:**  
No new instructions received

**Inspections Performed and Results:**  
Conducted site safety inspection, there were no new safety or equipment issues.

**Record of any tests performed, samples taken, and personnel involved:**  
No tests were performed or samples taken

**Available Analytical Results:**  
No new results available.

**Calibration Procedures Performed:**  
No calibrations required.

**General Remarks:**  
The plant operation has been steady. The injection well levels are stable as flows to them remain maximized. Influent flows are at ~372 gpm and effluent flows are averaging 391 gpm.

End of the month documentation continues.

James Jackson (JSJ) and Peter Takach (PET) were on site.



Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 28, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: D. JACKSON Day: WEDNESDAY Date: 10-27-10 Time: 0503

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	187	373

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALS
242	0	24839

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	330043	65650					63780
EW-2	269470	232950					57556
EW-3	246401	242730					61921

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.9	96	4389944	ANOTHER WARM MORNING. SOME RAIN AT TIMES. PLANT IS RUNNING FINE
IW-2	117.7	94	4042148	
IW-3	163.4	112	4252984	
IW-4	154.6	81	365504	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74885	NM	SB	SB	STAND-BY
INF 2	73623		2	6	
INF 3	28732		2	7	
ASF 1	41922		SB	SB	STAND-BY
ASF 2	49599		0	31	
ASF 3	42876		0	31	
GAC 1	45224		SB	SB	STAND-BY
GAC 2	48619		2	15	
GAC 3	33776		2	16	
REC 1	21936		OFF	DEF	
REC 2	20742		OFF	DEF	
INJ 1	65776		6	27	
INJ 2	39734		8	27	
INJ 3			NIS	NIS	NOT IN SERVICE
SUMP BLOWER					

	INLET	OUTLET
GAC #1 (PSI)	8	8
GAC #2 (PSI)	10	11
AIR DRIER (PSI)	01	01

AS Blower (H <sub>2</sub> O")	46	
Air Temp (°F)	56°	56°
Water Temp (°F)		16° C
V-GAC #1 (H <sub>2</sub> O")	2.45	0.25
V-GAC #2 (H <sub>2</sub> O")	01	01

Additional comments:

---



---



---

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.30	
Reactor Tank 2	5.34	
AS. Feed	6.36	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Supervisors Signature: [Signature]

Date: 10-28-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: JACKSON

DATE: 10-27-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • WARM MORNING - WITH A STEADY RAIN AT TIMES	
2)	
3) • PLANT RAN FINE LAST NIGHT	
4)	
5) • THE DAILY OPERATOR LOG WAS COMPLETED	
6)	
7) • BEGAN PUMPING OUT THE PLANT SUMP	
8)	
9) • TURNED COMPRESSOR ON, BEGAN AIRING OUT	
10) THE CARBON IN RECYCLING TANK, BEGAN	
11) DRAINING WATER TO SUMP.	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
1)	
2)	
3)	
4)	
5)	
6)	
7)	
8)	
9)	
10)	
11)	

IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS
1)

*Patricia* 10-28-10

# DAILY SITE SAFETY INSPECTION

## CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-27-10

**Check all areas, process systems, and equipment for general unsafe conditions.**  
**This is to include but is not limited to the observation of leaks, noise, abnormal function.**

Chemical Feed Skids  
 POLYMER  
 CAUSTIC  
 POTASSIUM PERMANGANATE  
 HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NOT
			IN
			SERVICE

### Process Tanks

EQUALIZATION  
 TREATED WATER  
 REACTORS  
 CLARIFIERS  
 SAND FILTERS  
 CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

### Process Systems

INFLUENT  
 SLUDGE SETTLER  
 RECYCLE  
 AIR STRIPPER FEED  
 CARBON FEED  
 INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	PUMP WATER FROM SUMP
✓	✓	✓	TANK HAS CARBON
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK

### Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
 SHARP EDGES  
 PINCH POINTS  
 OTHER HAZARDS

#### General Conditions and Comments

SOME WATER ON FLOOR
NONE
NONE
NONE

### Air Compressor

TANK  
 AFTER COOLER  
 AIR DRIER  
 MOTOR & COMPRESSOR

#### General Conditions and Comments

ON LINE TODAY
" " "
" " "
" " "

### Air Stripper

COLUMN  
 BLOWER & BELTS  
 CARBON VESSELS

#### General Conditions and Comments

OK
OK
OK

### Notes and Comments:

AIRING OUT THE CARBON IN RECYCLE TANK, WATER GOING TO SUMP. FROM SUMP WATER IS BEING PUMP TO SLUDGE TANK.

SIGNED: Ruth Akal

DATE: 10-28-10

**CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET**

WLB

7

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Thursday  
**Date:** 10-28-10

**Weather Forecast (am):** Cloudy, warm, humid, and damp. Temperatures are to range from 64-71-47°F. Wind is from the WSW-west at 9-13-10 mph. Relative humidity is 70-55% with no rain expected. Temps to drop overnight.

**Total Volume Processed for Day:** 562,577 gallons

**Plant Operating Hours:** 24:00 hrs. **Total Downtime:** 00:00 hrs.

**Reason for Downtime:**

No downtime to report .

**Significant Operational Problems:**

None

**Corrective Maintenance Performed:**

M-8 pump was disassembled, cleaned, and reassembled. Pump was used to pump carbon from RCY tank to sump. It was also used to pump sludge to sludge tank.

**Verbal/Written Instruction from Government Personnel:**

No new instructions received

**Inspections Performed and Results:**

Conducted site safety inspection, no new issues found.

**Record of any tests performed, samples taken, and personnel involved:**

Water level readings were taken at the infiltration galleries. The IG meter readings were recorded.

**Available Analytical Results:**

No new data received

**Calibration Procedures Performed:**

No calibrations required

**General Remarks:**

The plant continues to operate at high flow rates. Plant influent flow is set at 372 gpm and effluent flow is ~390 gpm.

The carbon sludge was removed from the RCY tank.

End of the month documentation continues.

James Jackson (JSJ) was out and Peter Takach (PET) was on site.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach". The signature is fluid and cursive, with the first name "Peter" and last name "Takach" clearly distinguishable.

Peter Takach, October 29, 2010

Attachments:

Daily Operating Log  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Operator: TAKACH

Day: THURSDAY

Date: 10-28-10

Time: 7:20

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	186	372

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
391	NM	24899 @ 7M

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	330215	166290	/	/	/	NM	63797
EW-2	269659	182400	/	/	/		57573
EW-3	246599	189910	/	/	/		61938

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	162.9	95.1	44046057	
IW-2	118.0	94.0	40566765	
IW-3	163.4	111.7	42702076	
IW-4	154.9	81.6	36635544	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74885	NM	OL	—	
INF 2	73648		0	10	
INF 3	28757		1.5	9.0	LEAK AT PI OUT
ASF 1	41922		OL	—	
ASF 2	49624		0	31	
ASF 3	42901		0	30	
GAC 1	45224		OL	—	
GAC 2	48694		1	15.5	
GAC 3	33801		0	16.0	
REC 1	21936		SB	—	
REC 2	20942		SB	—	
INJ 1	65801		7	2.7	
INJ 2	39759		9	2.7	
INJ 3	—		NIS	—	
SUMP	15547		—	—	
BLOWER	—		—	—	

	INLET	OUTLET
GAC #1 (PSI)	10	9
GAC #2 (PSI)	11	11
AIR DRIER (PSI)	OL	—

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.29	NM
Reactor Tank 2	5.33	
AS. Feed	6.34	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

AS Blower (H <sub>2</sub> O")	4.5	—
Air Temp (°F)	5.5	56
Water Temp (°F)	58	—
V-GAC #1 (H <sub>2</sub> O")	2.60	0.60
V-GAC #2 (H <sub>2</sub> O")	OL	—

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13.5	
Treat. Train 2	13.0	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:

RCY IS DOWN AS CARBON STILL  
NEEDS TO BE CLEANED OUT

Supervisors Signature: Peter Akal

Date

10-29-10



# DAILY SITE SAFETY INSPECTION CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-28-10

**Check all areas, process systems, and equipment for general unsafe conditions.  
This is to include but is not limited to the observation of leaks, noise, abnormal function.**

**Chemical Feed Skids**  
POLYMER  
CAUSTIC  
POTASSIUM PERMANGANATE  
HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			NIS NO leaks

**Process Tanks**  
EQUALIZATION  
TREATED WATER  
REACTORS  
CLARIFIERS  
SAND FILTERS  
CARBON VESSELS (liq)

Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓	OK
✓	✓	OK
✓	✓	OK
✓	✓	OK

**Process Systems**  
INFLUENT  
SLUDGE SETTLER  
RECYCLE  
AIR STRIPPER FEED  
CARBON FEED  
INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK Removing Carbs
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

**Floor and General Work Areas**  
SLIP, TRIP, & FALL HAZARDS  
SHARP EDGES  
PINCH POINTS  
OTHER HAZARDS

**General Conditions and Comments**

OK
OK
OK
OK

**Air Compressor**  
TANK  
AFTER COOLER  
AIR DRIER  
MOTOR & COMPRESSOR

**General Conditions and Comments**

OK
OK
OK
OK

**Air Stripper**  
COLUMN  
BLOWER & BELTS  
CARBON VESSELS

**General Conditions and Comments**

OK
OK
OK

**Notes and Comments:**

SIGNED: \_\_\_\_\_

10-29-10

DATE: \_\_\_\_\_

**CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET**

DATE: OCT 28

Doc. No.: CPS-Form-011  
March 3, 2008  
Rev.: C

**DAILY QUALITY CONTROL REPORT**  
O&M OF GROUNDWATER TREATMENT SYSTEM  
CLAREMONT POLYCHEMICAL TREATMENT SYSTEM  
OLD BETHPAGE, NEW YORK  
Contract No. W912 DQ-07-D-0044-0001

**Day:** Friday  
**Date:** 10-29-10

**Weather Forecast (am):**

**Fri.:** Sunny and cool. Temps are to range 48-56-40°F. Wind from the WNW-NW at 8-15 mph. Relative humidity is 50% with no precipitation expected.

**Sat.:** Sunny, cool, 41-57-46°F. Wind 18 mph SW, RH at 55%, no rain expected.

**Sun.:** Mostly sunny, 47-55-41°F. Wind at 15>5 mph from NW-Ne. RH at 60%, no ppt.

**Total Volume Processed for period (10/29 -11/1):** 1,700,393 gallons

**Plant Operating Hours:** 72:00 hrs. **Total Downtime:** 00:00 hrs.

**Reason for Downtime:**

No downtime to report

**Significant Operational Problems:**

Sludge tank is packed and will not drain

**Corrective Maintenance Performed:**

Rotated process pumps from 2&3 to 1&2

Cleared rocks away from sump tank lids

Set up M-8 to feed the press from the sludge tank

**Verbal/Written Instruction from Government Personnel:**

No new instructions

**Inspections Performed and Results:**

Site safety inspection was completed. There is nothing new to report.

**Record of any tests performed, samples taken, and personnel involved:**

The process motor amperage draws were recorded

**Available Analytical Results:**

No new data available

**Calibration Procedures Performed:**

No calibrations required

**General Remarks:**

Plant operation has been stable with steady influent and effluent flows.

Cleaning up plant and base-lining equipment

End of the month documentation continues

James Jackson and Peter Takach (PET) were on site today.

Plant Manager Signature:

A handwritten signature in black ink, appearing to read "Peter Takach".

Peter Takach, November 1, 2010

Attachments:

Daily Operating Log  
Daily Activities Summary Report  
Daily Site Safety Inspection Log  
Sign In Sheet

cc: SAIC Program Manager  
USACE Project Manager  
File

Table 8-2 - DAILY OPERATING LOG (Revised 1-21-10)

Operator: J. JACKSON

Day: FRIDAY

Date: 10-29-10

Time: 0905

PLANT INFLUENT FLOW (GPM)		
TRAIN 1	TRAIN 2	TOTAL
186	187	373

PLANT EFFLUENT FLOW (GPM)		
PUMP	SYPHON	METER (X 10,000) GALs
391	0	24951

Extraction Wells	Signet Flow Meter Total Volume	TOTAL EXTRACTED GALLONS (HMI - Flow Data) (12:00 am to 12:00 am)				Motor Amp Load	System Operating Hours
		T-1	T-2	T-3	T-4		
EW-1	336367	167890				11.6	63812
EW-2	269825	184040				11.1	57588
EW-3	246774	191860				13.1	61953

Injection Wells	Water Level ft. AMSL (HMI)	Signet Meter Flow Rate	Signet Meter Total Volume	Observations and Comments
IW-1	163.0	96	4417152	FRANK RAN WELL OVERNIGHT Temp @ 52°, RATHER COOL
IW-2	117.6	94	4069093	
IW-3	163.4	112	4284911	
IW-4	154.8	81	3679158	

Process Pumps	System Operating Hours	Motor Amp Load	System Pressure Gauges		COMMENTS
			Suction Side PSI	Discharge Side PSI	
INF 1	74885	0.7	SB	SB	STAND-BY
INF 2	73669	1.4	2	8	
INF 3	28778	1.2	2	9	
ASF 1	41922	8.6	SB	SB	STAND-BY
ASF 2	49645	6.4	0	31	
ASF 3	42922	6.7	0	31	
GAC 1	45224	5.0	SB	SB	STAND-BY
GAC 2	48715	6.5	2	15	
GAC 3	33823	6.7	2	16	
REC 1	21936	1.1	OFF	OFF	
REC 2	20742	1.7	OFF	OFF	
INJ 1	65822	5.6	6	27	
INJ 2	39780	7.8	8	27	
INJ 3					
SUMP BLOWER		1.2	NIS	NIS	NOT IN SERVICE
		2.8			

	INLET	OUTLET
GAC #1 (PSI)	10	8
GAC #2 (PSI)	10	11
AIR DRIER (PSI)	OL	OL
AS Blower (H <sub>2</sub> O")	4.6	
Air Temp (°F)	56°	56°
Water Temp (°F)		
V-GAC #1 (H <sub>2</sub> O")	2.65	0.00
V-GAC #2 (H <sub>2</sub> O")	OL	OL

pH	System Probe	Lab Meter
	DAILY	WEEKLY
Reactor Tank 1	5.30	
Reactor Tank 2	5.33	
AS. Feed	6.35	
PLANT DISCHARGE - pH		
PLANT DISCHARGE - Temp.		

SAND FILTER DEPTH TO WATER (INCHES)		
	Measurement 1	Measurement 2
	AM	If needed
Treat. Train 1	13 3/4"	
Treat. Train 2	13 1/2"	

NM = Not Measured  
OL = Off Line  
SB = Standby

NIS = Not in service

Additional comments:

Supervisors Signature: *[Signature]*

Date: 11-1-10

**DAILY ACTIVITIES SUMMARY REPORT  
CLAREMONT POLYCHEMICAL SUPERFUND SITE  
OLD BETHPAGE, NEW YORK**

OPERATOR: J. JACKSON

DATE: 10-29-10

LISTING OF OPERATIONS ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • THIS MORNING IS A COOL FALL LIKE MORNING. TEMP	
2) AT 52°F, NO FROST YET - IT WILL REMAIN COOL THROUGH	
3) OUT THE DAY.	
4)	
5) • THE DAILY OPERATORS LOG WAS COMPLETED	
6)	
7) • THE MONTHLY AMP DRAWS WERE TAKEN	
8)	
9) • THE LOWER LEVEL OF PLANT WAS MIDDLED	
10)	
11) • THE SLUDGE DECANT VALVE IS OPENED	

LISTING OF MAINTENANCE ACTIVITIES	EQUIPMENT/MATERIALS USED
1) • M1 - PUMP BEING USED TO PUMP SLUDGE &	
2) CARBON TO FILTER PRESS.	
3)	
4) • HANWARD VALVE SEEM TO BE WORKING OP-	
5) POSITE OF WHAT IT SHOULD BE WORKING. THE	
6) HANDLE MAY HAVE SLIPPED-	
7)	
8)	
9)	
10)	
11)	

**IDENTIFIED PROBLEMS AND RECOMMENDED ACTIONS**

1)

*Pat Jackson 11-1-10*

# DAILY SITE SAFETY INSPECTION CLAREMONT POLYCHEMICAL SUPERFUND SITE (Revised 082207)

DATE: 10-29-10

**Check all areas, process systems, and equipment for general unsafe conditions.  
This is to include but is not limited to the observation of leaks, noise, abnormal function.**

## Chemical Feed Skids

POLYMER  
CAUSTIC  
POTASSIUM PERMANGANATE  
HYDROCHLORIC ACID

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
			N/A
			NO
			SERVICE

## Process Tanks

EQUALIZATION  
TREATED WATER  
REACTORS  
CLARIFIERS  
SAND FILTERS  
CARBON VESSELS (liq)

	Valves	Tanks	COMMENTS (include areas of leaks)
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK
	✓	✓	OK

## Process Systems

INFLUENT  
SLUDGE SETTLER  
RECYCLE  
AIR STRIPPER FEED  
CARBON FEED  
INJECTION

Pumps	Valves	Tanks	COMMENTS (include areas of leaks)
✓	✓		OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓	✓	OK
✓	✓		OK

## Floor and General Work Areas

SLIP, TRIP, & FALL HAZARDS  
SHARP EDGES  
PINCH POINTS  
OTHER HAZARDS

### General Conditions and Comments

SOME WATER ON FLOOR
NONE
"
"

## Air Compressor

TANK  
AFTER COOLER  
AIR DRIER  
MOTOR & COMPRESSOR

### General Conditions and Comments

OK
OK
OK
RUNNING FOUR HOURS Today

## Air Stripper

COLUMN  
BLOWER & BELTS  
CARBON VESSELS

### General Conditions and Comments

OK
OK
OK

## Notes and Comments:

SIGNED: \_\_\_\_\_

DATE: 11-1-10

**CLAREMONT POLYCHEMICAL SUPERFUND SITE  
EMPLOYEE SIGN IN SHEET**

DATE: 10-29-16

17