

**CLAREMONT POLYCHEMICAL SUPERFUND SITE  
Groundwater Treatment System  
Old Bethpage, New York**

**MONTHLY REPORT  
of the  
Operations & Maintenance Activities  
During  
August 2012**

WA D006130-19  
SITE # 130015

Prepared for the:

**New York State Department of Environmental Conservation**

Prepared by:

**HRP Associates, Inc  
dba HRP Engineering, P.C.  
197 Scott Swamp Road  
Farmington, CT 06032**

**Prepared: September 7, 2012**

# TABLE OF CONTENTS

Page

<b>ACRONYMS AND ABBREVIATIONS .....</b>	<b>Preceding Text</b>
<b>1.0 OPERATION AND MAINTENANCE ACTIVITIES.....</b>	<b>1</b>
1.1 DAILY OPERATIONS SUMMARY REPORTS .....	1
1.2 SUMMARY OF MAINTENANCE ACTIVITIES.....	1
<b>2.0 MAINTENANCE LOGS .....</b>	<b>2</b>
<b>3.0 TECHNICAL SUPPORT ACTIVITIES.....</b>	<b>3</b>
3.1 HRP PERSONNEL .....	3
3.2 NYSDEC PERSONNEL, SUB-CONTRACTORS AND OTHER VISITORS .....	3
3.3 DELIVERIES.....	3
<b>4.0 HEALTH AND SAFETY.....</b>	<b>3</b>
<b>5.0 PLANNED ACTIVITIES AND SCHEDULES.....</b>	<b>4</b>
<b>8.0 CHEMICAL CONSUMPTION .....</b>	<b>5</b>
<b>9.0 CARBON SYSTEMS .....</b>	<b>5</b>
9.1 AQUEOUS-PHASE CARBON.....	5
9.2 VAPOR-PHASE CARBON.....	6
<b>10.0 WASTE DISPOSAL .....</b>	<b>6</b>
<b>11.0 MONTHLY DISCHARGE MONITORING REPORT .....</b>	<b>6</b>
<b>12.0 OTHER OPERATIONS, MAINTENANCE, OR MANAGEMENT ISSUES .....</b>	<b>6</b>
<b>13.0 PLANT DOCUMENTS.....</b>	<b>7</b>
<b>14.0 TREATMENT PLANT AND WELL FIELD MONITORING RESULTS .....</b>	<b>7</b>
14.1 OFF-SITE ANALYTICAL DATA RESULTS .....	7
14.2 FIELD DATA.....	8
<b>15.0 PROCESS ANALYSIS, INTERPRETATIONS, AND CONCLUSIONS.....</b>	<b>10</b>
15.1 EXTRACTION AND INFLUENT PROCESSES .....	10
15.2 FLOW THROUGH AERATION PROCESS .....	10
15.3 SETTLING FILTER PROCESS.....	11
15.4 AIR STRIPPING PROCESS.....	11
15.5 AQUEOUS-PHASE CARBON TREATMENT PROCESS .....	11
15.6 TREATED WATER INJECTION PROCESS .....	11
<b>16.0 GROUNDS .....</b>	<b>12</b>
16.1 PLANT PERIMETER.....	12
16.2 WELL FIELD.....	12
16.3 OTHER .....	12

## **TABLE OF CONTENTS** (cont'd)

### **LIST OF FIGURES**

Figure 14-1, Injection Well Water Elevations and Daily Flow.....	Following Text
Figure 14-2, Injection Well Falling Head Test .....	Following Text
Figure 14-3, Comparison of Falling Head Tests .....	Following Text

### **LIST OF TABLES**

Table 7-1, Magnetic Flow Meter Daily Totalizer Readings.....	Following Text
Table 12-1, Plant Maintenance Issues.....	Following Text
Table 14-1, Plant Discharge- Monthly pH Average.....	Following Text
Table 14-2, Injection Well Soundings.....	Following Text
List of Associated and Referenced Documents.....	Following Text

## ACRONYMS AND ABBREVIATIONS

AS	air stripping
ASF	air stripper feed
CA	carbon adsorber
CLP	contract laboratories program
DBA	doing business as
DOSR	daily operations summary report
DTW	depth to water
gpd	gallons per day
gpm	gallons per minute
GW	groundwater
GWTP	groundwater treatment plant
GWTS	groundwater extraction, treatment, and reinjection system
HCl	hydrochloric acid
HMI	human-machine interface
HRP	HRP Associates, Inc. dba HRP Engineering, P.C.
HVAC	heating, ventilation, and air conditioning
IG	infiltration gallery
IW	injection well
LGAC, LCA	Liquid phase granular activated carbon
LTRA	Long Term Response Action
MCC	motor control cabinet
MCP	master (main) control panel
NYSDEC	New York State Department of Environmental Conservation
O&M	operation and maintenance
PDB	Passive Diffusion Bags
PD	plant discharge
PID	photo ionization detector
PLC	programmable logic controller
psi	pressure in pounds per square inch
PW	process water
SAIC	Science Applications International Corporation
SAP	sampling and analysis plan
SOP	standard operating procedure
SSHPP	site safety and health plan
USACE	United States Army Corps of Engineers
VGAC, VCA	vapor-phase granular activated carbon
VFD	variable frequency drive
VOCs	volatile organic compounds

## **1.0 OPERATION AND MAINTENANCE ACTIVITIES**

HRP Associates, Inc. dba HRP Engineering, P.C. (HRP) continued its daily operation and maintenance (O&M) of the Claremont Polychemical Superfund Site and its groundwater treatment system (GWTS) for August 2012. This period is defined as 0600 hours, August 1, 2012, through 0600 hours, September 1, 2012. O&M conducted during this reporting period was performed in accordance with the site O&M Manual.

The system operated for 31 days in this reporting period with 320 minutes of downtime due to the backwashing of the liquid phase carbon adsorber beds (LCA).

Each workday morning, readings of key process parameters are recorded. These readings are used to monitor the plant's performance and as a basis for adjustments to the plant operations. These readings are recorded in the Daily Database which is an electronic file maintained in monthly operating data folders.

***At the end of this report is a list of the manuals, logs, reports, and databases maintained by the treatment plant. The locations of these documents are included.***

### **1.1 Daily Operations Summary Reports**

The daily operation of the GWTS is documented in the Daily Operations Summary Reports (DOSR). The DOSRs include a summary of the daily O&M activities and are based on the daily operating logs and worksheets. These worksheets include:

Daily Operating Log – process meter readings (CPS-Form-008)  
Daily Activities Summary Report - plant operator activities (CPS-Form-007)  
Daily Site Safety Inspection – equipment checklist for unsafe conditions (CPS-Form-009)  
Employee Sign –In Sheet – employee sign in (CPS-Form-11)

### **1.2 Summary of Maintenance Activities**

Maintenance of the treatment system and associated equipment is performed in accordance with the Claremont Groundwater Treatment System O&M Manual. Routine activities and equipment function tests completed during this reporting period are summarized in the Monthly Maintenance Log. This report is electronically filed and is available for review.

System maintenance incorporates the equipment manufacturers' recommendations, operations experience, and good engineering and maintenance practices. A detailed accounting of daily operation and maintenance activities is provided in the plant operator's daily logbook, the site supervisor's daily logbook, the operator's daily activities summary reports, and the site supervisor's daily plant activity notes.

Significant maintenance activities completed during this reporting period included the following:

- Scheduled routine monthly tasks which included motor amp load readings, injection well (IW) depth soundings, IW falling head tests, valve function tests, comprehensive site inspections, and infiltration gallery readings.
- Outdoor site maintenance was performed as needed. This included various clean up tasks and grounds keeping.
- The process pumps were rotated (two on-line, one off) three times during this period as part of the preventive maintenance task.
- In addition to routine PM on the plant truck, the oil, oil filter, and wipers were changed.
- The grass around the plant and at select wells was cut.
- The injection well soundings were recorded.
- The LCA vessels were backwashed through several cycles which included air sparging.
- The weed control project continued.
- The backwashed carbon waste was dried through the filter press and collected in a drum. ~ 1/2 drum of dry carbon cake was collected.
- PM work was completed on the air compressors.
- Scaling and algae were removed from selected areas of the clarifiers and settling tanks.
- The process pH electrode at reaction tank 1 was cleaned, calibrated and adjusted.
- Influent flows to IW- 2 continue to be restricted.
- The PDB tethers for monitoring wells SW-1 and DW-1 were re-installed in the correct wells.
- The BP3 well cluster was inspected.

## **2.0 MAINTENANCE LOGS**

The following operating logbooks are currently in use:

- |                               |       |
|-------------------------------|-------|
| • Well Maintenance Field Log  | CL-28 |
| • Sampling support Field Log  | CL-37 |
| • Site Supervisor's Daily Log | CL-41 |
| • Plant Operator's Daily Log  | CL-42 |

15 of the 42 project log books have been scanned and both the scanned copy and the project logbook have been sent to the DEC PM. HRP-NY has the remaining 25 logbooks, except for the 4 listed above, which are on site. All of the logbooks are identified on a master logbook inventory control file and are routinely checked as part of the site quality control program.

### **3.0 TECHNICAL SUPPORT ACTIVITIES**

#### **3.1 HRP Personnel**

There were no HRP personnel at the GWTP during this period.

#### **3.2 NYSDEC Personnel, sub-contractors and other visitors**

- TestAmerica-LIC was onsite to pick up the GW samples for delivery to TA-Edison (8/9)
- TestAmerica-LIC was onsite to pick up the PD samples for delivery to TA-Edison (8/15)
- Kevin Kamm of BK Fire was onsite to provide a quotation for the fire sprinkler inspection.
- Din Weng – TOB Lab was in to pick up GW samples.
- Valerie Eagen of NCDPW was in to pick up GW samples.
- Bill Par of BK Fire was in to perform the quarterly sprinkler inspection.
- Plainview Fire was in for their annual fire inspection.

#### **3.3 Deliveries**

- Mail was delivered six times in August
- Fed Ex delivered sampling seals.

### **4.0 HEALTH AND SAFETY**

Work at the Claremont Polychemical groundwater treatment plant (GWTP) was conducted in accordance with the approved Site Safety and Health Plan (SSHP). Site safety inspections were performed daily and the reports are filed on-site. In addition to the daily safety inspections, comprehensive safety inspections were performed twice in August. These worksheets are also on file.

No safety incidents or accidents occurred during this August 2012 period.

## **5.0 PLANNED ACTIVITIES AND SCHEDULES**

The status of project work and significant corrective maintenance activities is updated on a monthly basis. This Project Status Report was updated August 28 and is electronically filed. In addition to this report, Table 12-1 - Summary of Maintenance Issues has been updated. This is a table of action items and maintenance issues concerning the treatment system.

Separate tentative schedules for equipment maintenance events are shown in the O&M Manual and the Sampling and Analysis Plan (SAP).

The upcoming plant discharge sampling task has been scheduled for September 19. At this time, monitoring wells SW-1 and DW-2 will be re-sampled.

## **6.0 MONITORING WELL WATER ELEVATIONS**

The water level elevations and water quality data for the well system was updated after the May quarterly groundwater sampling event. Due to the stabilized nature of PDB samples, the water quality data will no longer be recorded. After the August GW sampling event, the monitoring well water elevations were recorded. This database is available for review. The water level elevation data is included in the quarterly groundwater monitoring report.

The next update of this database will take place after the quarterly groundwater event scheduled for November.

## **7.0 TREATMENT SYSTEM FLOWS**

The volume of treated water discharged by the treatment plant to the injection well field is determined daily from readings of the magnetic flow meter on the plant effluent line. A summary of these meter readings is provided in Table 7-1. The total volume of treated water discharged in August, as measured from 0600 hours on August 1, 2012, to 0600 hours on September 1, 2012, was 15,369,112 gallons. This volume is approximately 103 percent of the monthly targeted treatment goal. The cumulative volume of water discharged for this contract year (June 1, 2012 to present) was 47,692,112 and is ~8% above target. A graphic representation of the daily system flows are provided in Figure 14-1. (Targeted goals are based on a treated water discharge rate of 335 gpm.)

In August, the plant discharge flow averaged 344 gallons per minute (gpm) and 495,778 gallons per day (gpd). These numbers are down from July (357/513,599) as the flow to IW-2 has been restricted due to its overflow conditions.

The flow monitoring units for the individual IW systems and infiltration galleries are fully functioning. This allows for reading the flow rate and volume discharged to each system. The relative flows for August are indicated below:



Injection Well System	Flow Average (gpm)	Volume Discharged (gallons)*
IW-1	19	844,316
IG-1	76	3,377,264
IW-2	61	2,702,860
IW-3	28	1,264,344
IG-3	81	3,598,516
IW-4	78	3,479,410
<b>System</b>	<b>341</b>	<b>15,226,710</b>

The discrepancy between the individual injection system meter readings and the total plant effluent meter readings (~3 gpm) is due in part to the type of flow meters utilized to measure the discharge (paddle wheel vs. magnetic vs. turbine), sludge build up in the piping at the flow elements, rounding factors in the meters, and the relative time the readings are taken.

Flow is maximized to IW-1 and IW-3 when the field valves to the wells are open full and the field valves to the galleries are opened 50% or greater. Currently the butterfly valves are set and flow to IW-1 and IW-3 is maximized. Both galleries are draining adequately.

The plant's total effluent discharge is limited plumbing constrains, by injection pump capacity and the ability of the wells to accept water.

## 8.0 CHEMICAL CONSUMPTION

The four chemical feed systems are offline, and their future use is not anticipated. The systems are periodically tested and are operational. With the exception of the permanganate feed tank, the chemical feed tanks and feed tubing contain water for testing and inspection purposes. Currently the KMnO<sub>4</sub> tank needs a repair to a cracked drain flange.

There are no bulk chemicals onsite.

## 9.0 CARBON SYSTEMS

### 9.1 Aqueous-Phase Carbon

The presence of volatile or semi volatile organic compounds have not been detected in the effluent streams of the liquid-phase Carbon Adsorber (LCA) vessels. The influent and effluent streams of the vessels continue to be monitored on a quarterly basis.

Each vessel on initial charge (May 2008) contained ~600 cu. ft. (12,000 lbs.) of carbon.

As part of the daily monitoring task, the differential pressure across each vessel is recorded. Based on this data and the discharge pressure of the LCA feed pumps, the vessels were backwashed on August 21. At this time ~ 3.5 cubic feet of carbon was removed from the

vessels. Currently the differential pressure across vessel #1 is 2.0 psi and across vessel #2 is 3.0 psi.

No carbon has been added to the vessels.

## **9.2 Vapor-Phase Carbon**

Two vapor-phase Carbon Adsorber vessels (VCA) are available for the off gas treatment of the air stripping (AS) stream. Currently, VCA-1 is online. VCA-2 is offline and ready for service. Monitoring of VOCs in the influent and effluent air stream of the active vessel is performed weekly with a photo-ionization detector (PID).

Occasionally VOCs are detected in the effluent stream of the online carbon bed. When detected, a follow up test is performed to see if a false reading has occurred. If volatiles are detected a second time, corrective action is taken. If not, more frequent monitoring is undertaken. No VOC emissions were recorded this period.

No spent vapor-phase carbon was generated during this period, and no carbon was added to the vessels.

## **10.0 WASTE DISPOSAL**

- There was ~3.5 ft<sup>3</sup> of non-hazardous carbon cake waste collected in August.
- Currently, there are 6 drums of non-hazardous carbon waste stored in the facility.
- There was no waste removed from the facility in August.

## **11.0 MONTHLY DISCHARGE MONITORING REPORT**

The plant is currently operating under an equivalency permit from the New York State Department of Environmental Conservation (NYSDEC). While the permit requires periodic submittal of discharge monitoring results, monthly discharge monitoring reporting is not required. A review of the monthly discharge analytical results, which are included within Section 14.0, indicated all analyzed parameters were below noted permit limits.

The plant's water discharge permit expires December 31, 2013.

## **12.0 OTHER OPERATIONS, MAINTENANCE, OR MANAGEMENT ISSUES**

- The facility PID unit is failing. Due to its age and model, the unit is not serviceable.
- The USPGA staged a golf tournament on the Black Course 8/21-8/26. While some inconveniences were encountered, there were no real impacts on the operation of the facility.
- The plant truck is due for its biennial emission inspection. This is required to be undertaken in CT.

- The output of influent pump 1 continues to drift as the Variable Frequency Drive (VFD) keeps the pump in the ramping mode. The VFD for air stripper feed pump 2 continues to give earth fault errors.
- The transducers in IW-2, IW-3, and IW-4 are not functioning correctly.
- The level monitor at ASF Tank 1 is giving a temporary false low level signal and alarm. This causes the pumps to slow or shut off. In line cleaning has not helped. Next is to remove and inspect the units.
- Influent flow has been restricted to IW-2 (90+ gpm down to 50 gpm), lowering overall plant discharge from ~380 gpm to 340 gpm.
- The emergency light for the SW exit door is to be replaced
- A second thermostat for the outdoor heat trace wiring is to be assembled and installed.
- Other on-going plant maintenance issues are summarized on Table 12-1 and in the Project Status Report (filed on-site).

### **13.0 PLANT DOCUMENTS**

Procedures and standard forms are written, reviewed, and revised as needed. In August:

- Field Notes Worksheet (Form-031) was revised to rev. H.

### **14.0 TREATMENT PLANT AND WELL FIELD MONITORING RESULTS**

The Claremont Polychemical GWTS is monitored through the analysis of off-site laboratory analytical data and on-site field data.

#### **14.1 Off-site Analytical Data Results**

Monthly plant discharge (PD) samples are taken for organic analysis in compliance with the NYSDEC discharge permit. Quarterly groundwater (GW) samples are taken for organic analysis, and quarterly process water (PW) samples are taken for organic, inorganic, and generic analysis. August's sampling activities included:

- The quarterly groundwater samples were collected 8/6-8/8 and shipped to TA-Edison for organic analysis.
- The PDBs for the next GW event were installed in the monitoring wells
- The monthly plant discharge samples were collected 8/15 and shipped to TA-Edison for organic analysis
- The September PD samples are scheduled for 9/19.
- A problem was discovered with the August GW samples for wells DW-1 and SW-1. The PDB systems were improperly installed in the wells resulting in unusable analytical samples.
- The re-sampling of wells DW-1 and SW-1 is also scheduled for 9/19

On July 18 and August 15, the plant discharge was sampled. The results for those samples follow:

Plant Discharge				
Parameters	Discharge Limitations	Units	Results July '12	Results August '12
pH (range)	5.5 – 8.5	SU	6.54	6.32
Tetrachloroethylene	5	ug/l	U	U
Trichloroethylene	5	ug/l	0.18 J	0.17 J
1,2-(cis) Dichloroethylene	5	ug/l	U	U
1,2-(trans)Dichloroethylene	5	ug/l	U	U
Methylene Chloride	5	ug/l	U	U
1,1 Dichloroethylene	5	ug/l	U	U
1,1-Dichloroethane	5	ug/l	U	U
Chloroform	7	ug/l	U	U
1,1,1-Trichloroethane	5	ug/l	U	U
Benzene	0.7	ug/l	U	U
Toluene	5	ug/l	U	U
Chlorobenzene	5	ug/l	U	U
Ethylbenzene	5	ug/l	U	U
Bis(2-ethylhexyl)phthalate	4200	ug/l	U	U
Di-n-butyl phthalate	770	ug/l	U	U
Antimony, Total recoverable	3	ug/l	U	NS
Arsenic, Total recoverable	50	ug/l	U	NS
Barium, Total recoverable	2000	ug/l	80.6 J	NS
Lead, Total recoverable	50	ug/l	U	NS
Selenium, Total recoverable	40	ug/l	U	NS
Iron, Total recoverable	500	ug/l	449	NS
Manganese, Total recoverable	500	ug/l	27.5	NS
Nitrogen, Total (as N)	10	mg/l	U	NS
Solids, Total Dissolved	1000	mg/l	330	NS
Chromium, Hexavalent	100	ug/l	U	NS
Chloride Ion	NL	mg/l	128	NS
Fluoride Ion	NL	mg/l	U	NS
Sulfate Ion	NL	mg/l	29.5	NS

NS – not samples

U – analyzed for but not detected

J – estimated value

NL – monitor only

## 14.2 Field Data

Treatment plant effluent is monitored for pH and temperature on a weekly basis in order to obtain a monthly average in compliance with the NYSDEC discharge permit requirements. These readings are obtained from discharge samples taken from a controlled point with calibrated portable meters. A summary of these data is as follows:

Date	pH	Temperature (°C)
August 6	6.30	19
August 13	6.67	15
August 20	5.93	15
August 27	6.37	17
<b>August 2012 Average</b>	<b>6.32</b>	<b>16.5</b>

The NYSDEC discharge permit requires the plant discharge to have an average monthly pH greater than 5.50. The treatment plant effluent pH averaged 6.32 in August and met the monthly average pH discharge requirement. A graph of the plant discharge monthly pH average over several months is provided in Table 14.1.

Weekly air monitoring readings are taken with a PID of the influent and effluent air streams to the active vapor phase carbon adsorber vessel following the air stripper. Currently vessel #1 is on-line. A summary of the results for August follows:

Date	Inlet (ppm)	Outlet (ppm)
August 7	0.0	<b>0.0</b>
August 13	0.0	0.0
August 20	0.0	0.0
August 27	0.0	0.0
*PID readings indicate that the VOCs in the air stream are lower than the part per million levels (ppm) of the instrument's capability.		

Measurements to determine the depth from the top of the well column to the bottom of the IWs were taken on August 15. A summary of the historical data is included in Table 14-2. While the wells are stable, there has been an accumulation of sediment in the four injection wells. IW-1 is the most severe case, with the influx of sand accounting for more than 100 feet of sediment in the bottom of the well. Recent sediment accumulation in IW-2 seems to have stabilized.

Water elevations in the IWs are normally recorded on a daily basis as is the daily total flow discharged to the well field. These are depicted in Figure 14-1. The IW levels were generally steady while the pumps are active. With the exception of IW-1, the transducers in IW-2, IW-3, and IW-4 are producing unreliable signals. The water levels are physically monitored more frequently.

The injection well falling head test was performed on August 21. Due to the questionable output of the level transducers, the only data recorded was for IW-1. A graphic representation of the time required to drop the water level to a static condition is presented

in Figure 14-2. Comparisons of baseline data from March 2006 to that of recent tests (Figure 14-3) indicate that IW-1 is stable.

Other data collected during August included:

- The plant sound level readings were recorded twice (8/3, 8/17), (included with daily worksheets).
- The depth-to-water readings were recorded (8/15) for the injection wells. This was compared to the soundings and the transducer readings (included with daily worksheets)
- The flow-meter readings and the depth of water in the infiltration galleries were recorded in site supervisor's notebook and included with the monthly filings. (8/28)
- The process motors amp load readings were recorded (8/31)
- Weekly utility meter readings were recorded.

## **15.0 PROCESS ANALYSIS, INTERPRETATIONS, AND CONCLUSIONS**

### **15.1 Extraction and Influent Processes**

- Currently, the three extraction well pumps are on-line. The pumps are controlled by water level set points in the wells and in the EQ tank. The transducer set points are adjusted as necessary.
- The 3 extraction well flow monitors are fully functional.
- Currently, the three influent pumps are operational with 2 pumps on-line at a time.
- There continues to be some drift in the signal to influent pump-1.
- The influent pumps were rotated 3 times in August.
- The 2 influent flow controllers are fully functional.

No other new issues arose with the extraction or influent systems. Routine maintenance continues.

### **15.2 Flow through Aeration Process**

Both treatment trains are on-line and the influent water is split relatively evenly to each train.

The polymer, potassium permanganate, caustic, and hydrochloric acid feed systems remain out of service as current water conditions make their use unnecessary. The flash and flocculation mixers at the clarifiers remain idle due to the discontinued use of the polymer and lack of solids generation. The reaction tanks and clarifier systems continue to operate as pass-through settling tanks.

### **15.3 Settling Filter Process**

Air sparging of screens is performed as necessary. With lower flows through the plant, the frequency has diminished. The tanks are drained and cleaned as necessary. The system is fully functional.

### **15.4 Air Stripping Process**

- The three ASF pumps are operational and are rotated into service two at a time. They were rotated three times in August.
- The VFD for ASF P2 continues to exhibit an earth ground fault. When on-line, Pump 2 operates through the off line pump's VFD.
- The tank level monitors were isolated and flushed in-line. This did not remove the false LL alarm. The condition will continue to be monitored.
- Pump #3 emits a high pitched whine, which will require future address.
- The vapor phase carbon beds are drained of condensate as necessary.
- The blower is checked daily and is fully functional.

No other issues arose with the air stripping system. Routine maintenance continues.

### **15.5 Aqueous-Phase Carbon Treatment Process**

- All three feed pumps are operational, with two pumps rotated into service at a time. The pumps were rotated 3 times in August.
- The pin-hole leak in the side wall of LCA-2 is stable and remains of low concern
- Both vessels were backwashed in August. Currently the differential pressure across the vessels is well within operating range and backwashing will not be required again for some time.

Other routine maintenance tasks continued.

### **15.6 Treated Water Injection Process**

The plant's total discharge flow rate and volume are measured by a magnetic flow meter on the injection pump discharge manifold. The paddle wheel flow sensors and flow transmitters installed in the discharge line to each injection well system are on-line and connected to the MCP and HMI. The turbine flow meters in the infiltration gallery valve boxes are fully functional.

- The plant discharge system is online and fully operational.
- All three INJ pumps are operational with 2 units generally on-line. The pumps were rotated 2 times in August.
- There is a leak in the pump discharge manifold prior to the plant effluent flow sensor. This leak is minor and no action is required.
- Except for IW-1, the injection well transducers are all producing unreliable signals.
- The galleries are adequately draining.
- Flow to IW-2 was restricted to ~50 gpm (from ~90) due to high water levels.
- When pump 3 is in rotation, it is solely run as it is more efficient in this mode.

No other issues were encountered with the injection system in August. Routine maintenance tasks continue.

## **16.0 GROUNDS**

Routine maintenance tasks continue outside the plant. This includes weather related clean up tasks and landscaping duties.

### **16.1 Plant Perimeter**

- General outdoor clean up continues.
- The grass was cut as necessary.

### **16.2 Well Field**

- The grass at selected wells was mowed as necessary.
- The frequency of DTW readings has increased due to the poor signals from the injection well transducers.

### **16.3 Other**


- The monthly inspection of the plant truck was completed.
- The truck's oil, oil filter and windshield wipers were changed.
- Miscellaneous trips for local purchases were made.
- Spent motor oil was transported to local recycling area.

There were no other significant issues outside the plant. Routine maintenance continues.




## FIGURES


**Figure 14-1 Injection Well Elevations and Daily Flow**





**Figure 14-2 Injection Well Falling Head Test - August 21, 2012**



**Figure 14-3 Comparison of Falling Head Tests**





# TABLES

TABLE 7-1  
 MAGNETIC FLOWMETER DAILY TOTALIZER READINGS

August 2012

DATE	TOTALIZER READING	GALLONS PER DAY	GALLONS PER MINUTE
8/1/2012	591227302	542698	377
8/2/2012	591770000	520000	361
8/3/2012	592290000	1530000	354
8/6/2012	593820000	520000	361
8/7/2012	594340000	510000	354
8/8/2012	594850000	510000	354
8/9/2012	595360000	520000	361
8/10/2012	595880000	1510000	350
8/13/2012	597390000	510000	354
8/14/2012	597900000	510000	354
8/15/2012	598410000	490000	340
8/16/2012	598900000	500000	347
8/17/2012	599400000	1510000	350
8/20/2012	600910000	480000	333
8/21/2012	601390000	400000	278
8/22/2012	601790000	440000	306
8/23/2012	602230000	590000	410
8/24/2012	602820000	1380000	319
8/27/2012	604200000	480000	333
8/28/2012	604680000	480000	333
8/29/2012	605160000	490000	340
8/30/1931	605650000	490000	340
8/31/2012	606140000	456414	317
9/1/2012	606596414		
<b>August '12 Treated Water Volume</b>		<b>15,369,112</b>	
<b>August '12 Avg. GPM Discharged</b>			<b>344</b>

### Miscellaneous Outstanding Maintenance Issues at the Claremont Polychemical GWTP (updated 08-28-12)

Date Added	Problem or Condition	Action	Cost	Option	Option Cost	Priority level
June 2011	ASF Sys Pump #3 Motor motor bearings are making noise	Replace 10.0 hp motor when it fails	\$800	none	n/a	2
June 2011	VFD ASF-P2	Replace/service	\$?	Leave out of service	0	2
2008	INF Sys check valves (3) not operating correctly, must be manually opened and closed	Rebuild existing check valves in place (3)	\$675 ea	a-replace CV with like kind cast iron swing check b-replace CV with pvc ball check (3) c-manually control valves	\$X \$400 0	2
2008	L-CA Sys. Check valves not operating correctly, must be manually opened and closed	Rebuild existing check valves in place (3)	\$675 ea	a-replace CV with like kind cast iron swing check b-replace CV with pvc ball check c-manually control valves	\$X \$400 + 0	2
2008	INJ Pump shut off valves cannot isolate individual pumps	Replace valves (4) w/ 6" PVC valves	\$400 ea	Leave valves in place	\$0	2
2008	ASF Sys check valves not operating correctly, must be manually opened and closed	Rebuild check valves (3)	\$675 ea	a-replace CV with like kind cast iron swing check b-replace CV with pvc ball check c-manually control valves	\$X \$400+ 0	2
Aug. 2009	EQ Tank Discharge Valve Cannot isolate tank	Replace valve w/8" PVC valve	\$900	Leave valve in place (empty tank when it needs to be isolated)	\$0	3
2008	RCY Sys. Check valves not operating correctly, must be manually opened and closed	Rebuild check valves (2)	\$675 ea	a-replace CV with like kind cast iron swing check b-replace CV with pvc ball check c-manually control valves	\$X \$400+ 0	3
July 2011	VFD INF-P1 Ramping	Replace/service	\$?	Leave in Place – Control flow by throttling valves	0	2
2008	INJ Pump check valves (2) not operating correctly, must be manually opened and closed	Rebuild existing check valves in place (2)	\$800 ea	a-replace CV with like kind cast iron swing check b-replace CV with pvc swing check c-manually control valves	\$1300 \$1500+ 0	2



Date Added	Problem or Condition	Action	Cost	Option	Option Cost	Priority level
Dec. 2011	LCA -V2 (Pin Hole leak)	Drips -not a hazard cost \$1000 to weld and need to shut down plant	\$1000	Under enhanced inspection action taken as needed	0	3
Aug. 2010 April 2012	IW-2 Transducer IW-3, IW-4 Transducer	Replace transducer (may require tech support)	\$1200/ea	Manually monitor wells	0	3
2008	Discharge Manifold leak	Make repairs	\$500	Leave as is	0	3
Aug. 2008	Air Compressor system is worn and leaking and in need of an overhaul	Have system serviced	12,000	a-replace both units with one sized for current duty b-run system on as-needed basis	\$ 0	4
2009	Filter Press – control cabinet hydraulic leaks	Have system serviced	\$?	Leave as is		4
2009	Sludge Transfer Pump is undersized for filter press feed	Replace pump with M-8	\$2500	Use existing pump	\$0	4
2009	Sludge transfer piping	Re-pipe press feed	\$200	Leave piping as is use 2" hose to M-8 pump	\$0	4
	INF Pump Seals (historically, pump 2 is due to fail)	Proactively replace seals	\$300	Replace seals when needed	\$0	Budget for
Jan. 2012	INF Pump-2 Motor (1) Motor bearings are starting to make noise	Proactively Replace 5.0 hp motor	\$600	Replace motor when necessary		Budget for
April 2012	Seal leak at INJ P2	Replace seal	300	Pull pump and make repairs if possible Leave as is until repairs are required	0	3
April 2012	Drain nozzle leak on permanganate tank	Re-weld nozzle	500	-Replace nozzle with bulkhead fitting -Leave as is	100 0	4
May 2012	Tank LL alarm-pump control false signals	Have units serviced	?	Do nothing Keep flushing system	0	3
May 2012	Seasonal heat trace wiring on outdoor piping is not controlled	Install thermostats on each system	\$450	Leave as is and manually actuate	0	1
Course of action Taken - RED	Priority level – 1- Urgent and must be done 2- Not urgent but needs to be done 3 – Not urgent but should be done 4 – Would like done					

Month	Avg. pH
May '11	6.25
June '11	6.33
July '11	6.12
Aug '11	6.39
Sept '11	6.38
Oct '11	6.22
Nov '11	6.62
Dec '11	6.60
Jan '12	6.58
Feb '12	6.50
Mar '12	6.57
Apr '12	6.52
May '12	6.28
June '12	6.32
July '12	6.54
Aug '12	6.32
Sept '12	




TABLE 14-2 Injection Well Soundings

Recent injection well depth readings

2/24/2011	144.50	-1.33	241.60	0.00	249.10	0.00	197.98	-0.02
3/22/2011	145.80	1.30	241.60	0.00	248.90	-0.20	198.00	0.02
4/12/2011	145.80	0.00	241.60	0.00	248.50	-0.40	197.50	-0.50
5/23/2011	148.80	3.00	241.60	0.00	248.40	-0.10	197.50	0.00
6/22/2011	145.80	-3.00	241.60	0.00	248.00	-0.40	197.83	0.33
7/15/2011	147.28	1.48	241.60	0.00	247.70	-0.30	197.80	-0.03
8/12/2011	145.85	-1.43	241.50	-0.10	248.25	0.55	197.80	0.00
9/21/2011	145.90	0.05	241.10	-0.40	248.25	0.00	197.73	-0.07
10/7/2011	144.30	-1.60	239.95	-1.15	247.90	-0.35	197.75	0.02
11/17/2011	145.70	1.40	236.70	-3.25	248.72	0.82	197.70	-0.05
12/2/2011	145.95	0.25	233.80	-2.90	248.30	-0.42	194.65	-3.05
1/5/2012	148.80	2.85	233.20	-0.60	247.98	-0.32	197.70	3.05
2/2/2012	145.85	-2.95	224.45	-8.75	248.10	0.12	197.60	-0.10
3/7/2012	147.85	2.00	223.30	-1.15	248.10	0.00	197.50	-0.10
4/2/2012	148.80	0.95	218.80	-4.50	247.97	-0.13	197.50	0.00
5/18/2012	145.80	-3.00	217.95	-0.85	247.78	-0.19	197.49	-0.01
6/26/2012	144.3	-1.50	205.70	-12.25	217.00	-30.78	197.40	-0.09
7/20/2012	145.85	1.55	205.55	-0.15	248.00	31.00	197.40	0.00
8/16/2012	144.90	-0.95	205.70	0.15	248.10	0.10	197.20	-0.20
Change From 6/17/04 to Present								
		<b>-103.60</b>		<b>-42.80</b>		<b>-5.10</b>		<b>-7.80</b>
Change From 6-04 thru 2-06								
		-1.00		-2.81		-4.01		-1.02
*Injection wells IW-2 and IW-3 redeveloped during week ending 3/17/2006								
Change from 3-06 thru 10/07								
		-2.90		-3.57		-0.87		-3.61
Injection wells IW-1 and IW-3 were redeveloped during week ending 11/9/07								
Change 11-07 thru 3/08								
		-21.70		-0.10		-0.10		-1.75
Injection wells IW-1 and IW-3 were redeveloped during week ending 4/25/08								
Change 4/08 to present								
		<b>-77.60</b>		<b>-36.32</b>		<b>-1.50</b>		<b>-1.78</b>

## Associated and Referenced Documents

Document	Location
Daily Worksheets Daily Operating Log Daily activities Summary Report Daily Site Safety Inspection Employee Sign-in Sheet	Original paper copies in monthly file folders at plant. Electronic copies on Farmington Server: >Claremont Data>year>month>month daily worksheets
Supporting Worksheets Visitor/Subcontractor Sign-in Sheet Air Monitoring Log Sound Monitoring Worksheet Daily Plant Activity Notes Comprehensive Site Safety Inspections	Original paper copies in monthly file folders at plant. Electronic copies on Farmington Server: -with daily worksheets -with daily worksheets -with daily work sheets >operating data>Daily Plant Activity Notes>yr>month >Claremont Data>yr>mo>by date of inspection
Plant Operator's Daily Log Book	Current book issued to operator, completed books on file in shop cabinet
Site Supervisor's Daily Log Book	Current book issued to supervisor, completed books on file in shop cabinet
Daily Database	Current database is an Electronic file on site, in Claremont Docs/Claremont Ops Data/ monthly folder. Past docs on server: > Claremont Data>yr>month>
Daily Operations Summary Report	Current report is an Electronic file on site, in Claremont Docs/Claremont Ops Data/ monthly folder. Past docs on server: > Claremont Data>yr>month>
Monthly O&M Report	Electronic file on server: >Claremont Data>yr>month>
Monthly Maintenance Log	Electronic file on server: > Claremont Data>yr>month>
Project Status Report formerly Activities Schedule	Electronic file on server: >Claremont Data>yr>month>
Groundwater Elevation and Water Quality Database	Electronic file on server: >Operating data
Monthly Plant Truck Inspection Worksheet	Electronic file on server: >Claremont Data>yr>month>
Stand Alone Documents Claremont O&M Manual Site Safety and Health Plan Standard Operating Procedures and Instruction manual Sampling and Analysis Plan Log of Operating System Drawings	Binded copies in control room, electronic copies on server> Stand Alone Documents
Sampling forms	Electronic file on server: >Sampling> Sampling Forms
Chain of Custody Documents	Electronic File on server: >Sampling> yr>mo
Claremont Site Notebook	Electronic file on server : >Stand alone documents> Claremont notebook

Farmington Server Path: HRP CT Server: J drive/N/Newen..../Claremont Polychemical.../Operating Data (4-6-12)