

**CLAREMONT POLYCHEMICAL SUPERFUND SITE
Groundwater Treatment System
Old Bethpage, New York**

**MONTHLY REPORT
of the
Operations & Maintenance Activities
During
July 2013**

WA D006130-19
SITE # 130015

Prepared for the:

New York State Department of Environmental Conservation

Prepared by:

**HRP Associates, Inc
dba HRP Engineering, P.C.
1 Fairchild Square, Suite 110
Clifton Park, New York 12065**

Prepared: August 7, 2013

TABLE OF CONTENTS

Page

| | |
|---|-----------------------|
| ACRONYMS AND ABBREVIATIONS | Preceding Text |
| 1.0 OPERATION AND MAINTENANCE ACTIVITIES..... | 1 |
| 1.1 DAILY OPERATIONS SUMMARY REPORTS | 1 |
| 1.2 SUMMARY OF MAINTENANCE ACTIVITIES..... | 1 |
| 2.0 MAINTENANCE LOGS | 2 |
| 3.0 TECHNICAL SUPPORT ACTIVITIES..... | 2 |
| 3.1 HRP PERSONNEL | 2 |
| 3.2 NYSDEC PERSONNEL, SUB-CONTRACTORS AND OTHER VISITORS | 3 |
| 3.3 DELIVERIES..... | 3 |
| 4.0 HEALTH AND SAFETY..... | 3 |
| 5.0 PLANNED ACTIVITIES AND SCHEDULES..... | 4 |
| 6.0 MONITORING WELL WATER ELEVATIONS | 4 |
| 7.0 TREATMENT SYSTEM FLOWS | 4 |
| 8.0 CHEMICAL CONSUMPTION | 5 |
| 9.0 CARBON SYSTEMS | 6 |
| 9.1 AQUEOUS-PHASE CARBON..... | 6 |
| 9.2 VAPOR-PHASE CARBON..... | 6 |
| 10.0 WASTE DISPOSAL | 6 |
| 11.0 MONTHLY DISCHARGE MONITORING REPORT | 6 |
| 12.0 OTHER OPERATIONS, MAINTENANCE, OR MANAGEMENT ISSUES | 7 |
| 13.0 PLANT DOCUMENTS..... | 7 |
| 14.0 TREATMENT PLANT AND WELL FIELD MONITORING RESULTS | 7 |
| 14.1 OFF-SITE ANALYTICAL DATA RESULTS | 7 |
| 14.2 FIELD DATA | 8 |
| 15.0 PROCESS ANALYSIS, INTERPRETATIONS, AND CONCLUSIONS | 10 |
| 15.1 EXTRACTION AND INFLUENT PROCESSES | 10 |
| 15.2 FLOW THROUGH AERATION PROCESS | 11 |
| 15.3 SETTLING FILTER PROCESS | 11 |
| 15.4 AIR STRIPPING PROCESS..... | 11 |
| 15.5 AQUEOUS-PHASE CARBON TREATMENT PROCESS | 11 |
| 15.6 TREATED WATER INJECTION PROCESS | 11 |
| 16.0 GROUNDS | 12 |
| 16.1 PLANT PERIMETER..... | 12 |
| 16.2 WELL FIELD..... | 12 |
| 16.3 OTHER | 12 |

TABLE OF CONTENTS (cont'd)

LIST OF FIGURES

| | |
|--|----------------|
| Figure 14-1, Injection Well Water Elevations and Daily Flow..... | Following Text |
| Figure 14-2, Injection Well Falling Head Test | Following Text |
| Figure 14-3, Comparison of Falling Head Tests | Following Text |

LIST OF TABLES

| | |
|--|----------------|
| Table 7-1, Magnetic Flow Meter Daily Totalizer Readings..... | Following Text |
| Table 12-1, Plant Maintenance Issues..... | Following Text |
| Table 14-1, Plant Discharge- Monthly pH Average..... | Following Text |
| Table 14-2, Injection Well Soundings..... | Following Text |
| List of Associated and Referenced Documents..... | Following Text |

ACRONYMS AND ABBREVIATIONS

| | |
|-----------|---|
| AS | air stripping |
| ASF | air stripper feed |
| CA | carbon adsorber |
| CLP | contract laboratories program |
| DBA | doing business as |
| DOSR | daily operations summary report |
| DTW | depth to water |
| gpd | gallons per day |
| gpm | gallons per minute |
| GW | groundwater |
| GWTP | groundwater treatment plant |
| GWTS | groundwater extraction, treatment, and reinjection system |
| HCl | hydrochloric acid |
| HMI | human-machine interface |
| HRP | HRP Associates, Inc. dba HRP Engineering, P.C. |
| HVAC | heating, ventilation, and air conditioning |
| IG | infiltration gallery |
| IW | injection well |
| LGAC, LCA | Liquid phase granular activated carbon |
| LTRA | Long Term Response Action |
| MCC | motor control cabinet |
| MCP | master (main) control panel |
| NYSDEC | New York State Department of Environmental Conservation |
| O&M | operation and maintenance |
| PDB | Passive Diffusion Bags |
| PD | plant discharge |
| PID | photo ionization detector |
| PLC | programmable logic controller |
| psi | pressure in pounds per square inch |
| PW | process water |
| SAIC | Science Applications International Corporation |
| SAP | sampling and analysis plan |
| SOP | standard operating procedure |
| SSHPP | site safety and health plan |
| USACE | United States Army Corps of Engineers |
| VGAC, VCA | vapor-phase granular activated carbon |
| VFD | variable frequency drive |
| VOCs | volatile organic compounds |

1.0 OPERATION AND MAINTENANCE ACTIVITIES

HRP Associates, Inc. dba HRP Engineering, P.C. (HRP) continued its daily operation and maintenance (O&M) of the Claremont Polychemical Superfund Site groundwater treatment system (GWTS) for July 2013. This period is defined as 0600 hours, July 1, 2013, through 0600 hours, August 1, 2013. O&M conducted during this reporting period was performed in accordance with the site O&M Manual.

The plant and grounds were maintained for 31 days in this reporting period. The plant experienced 7 days of downtime due to an off-site severed power feed. While operating, the treatment system was generally stable with steady flows.

During July, readings of key process parameters were recorded each work day morning. These readings are used to monitor the plant's performance and as a basis for adjustments to the plant processes. These readings are recorded in the Daily Database which is an electronic file maintained in the monthly operating data folders.

1.1 Daily Operations Summary Reports

The operation of the GWTS is documented in the Daily Operations Summary Reports (DOSR). The DOSRs include a summary of the daily O&M activities and are based on the daily operating logs and worksheets. These worksheets include:

Daily Operating Log – process meter readings (CPS-Form-008)

Daily Activities Summary Report - plant operator activities (CPS-Form-007)

Daily Site Safety Inspection – Site checklist for unsafe conditions (CPS-Form-009)

Employee Sign-In Sheet – employee log in (CPS-Form-11)

1.2 Summary of Maintenance Activities

Maintenance of the treatment system and associated equipment is performed in accordance with the Claremont Groundwater Treatment System O&M Manual. Routine activities and equipment function tests completed during this reporting period are summarized in the Monthly Maintenance Log. This report is electronically filed and is available for review.

System maintenance incorporates the equipment manufacturers' recommendations, operations experience, and good engineering and maintenance practices. A detailed accounting of daily operation and maintenance activities is provided in the plant operator's daily logbook, the site supervisor's daily logbook, the operator's daily activities summary reports, and the site supervisor's daily plant activity notes.

At the end of this report is a list of the manuals, logs, reports, and databases maintained by the treatment plant. The locations of these documents are included.

HRP Engineering, P.C.

Significant maintenance activities completed during this reporting period included the following:

- General maintenance activities continued, including outdoor clean up tasks, landscaping tasks, housekeeping, system inspections and system monitoring.
- Scheduled monthly tasks which included motor amp load readings, injection well (IW) depth soundings, IW falling head tests, valve function tests, comprehensive site inspections, and infiltration gallery readings.
- The process pumps were rotated from 2&3 to 1&2
- The motor to pump coupling for INF P2 was replaced
- The sludge tank was drained through the filter press
- Injection Pump-2 failed upon startup. The shaft was bound up and was mechanically freed.
- The extraction well packers were recharged from a portable compressor.
- Vines were cleared from the wires at the front gate.
- The off-site severed power line was repaired by an outside contractor, the power was restored after LIPA inspected the repairs, and the plant restarted.
- Motor wiring at the MCC modules was changed to correct the rotation of the equipment motors.
- The Autodialer failed, however the temporary down time did not affect the system. After troubleshooting, the battery was recharged, a fuse replaced and system returned to service.
- Waste drums were consolidated and Drum 2102-03 was closed.
- A well cover was fabricated and installed on EW-2C.

2.0 MAINTENANCE LOGS

The following operating logbooks are currently in use:

- | | |
|-------------------------------|-------|
| • Well Maintenance Field Log | CL-28 |
| • Sampling support Field Log | CL-37 |
| • Site Supervisor's Daily Log | CL-45 |
| • Plant Operator's Daily Log | CL-46 |

Of the completed project logbooks, 40 are in the process of being scanned and delivered to the NYSDEC and 4 are on file at Claremont. All of the logbooks are identified on a master logbook inventory control file and are routinely checked as part of the site quality control program.

3.0 TECHNICAL SUPPORT ACTIVITIES

3.1 HRP Personnel

- Other than the plant operators, there were no HRP personnel on site in July.

HRP Engineering, P.C.

3.2 NYSDEC Personnel, sub-contractors and other visitors

- Mike Gele of Plainview Water was in to look at site drawings and to mark the underground water lines (7/3)
- Nate Cardino and Mark Feldman (principles of MANA Construction) were in several times during the repairs to the power lines
- Ben Rung (NYSDEC) was onsite for the USEPA 5-yr Review meeting (7/18)
- Maria Jon, Chuck Nace, Bob Alvey, and Cecelia Echols (USEPA) were in for the USEPA meeting (7/18)
- Mike Flaherty (NCDPW) was in for the USEPA meeting (7/18)
- Peter Murray and John Schripter of Geotech were in for an update (7/23)
- TA-NY was in to pick up the PD samples (7/24)

3.3 Deliveries

- Mail was delivered 2x
- UPS delivered insurance papers
- Fed Ex delivered insurance papers

4.0 HEALTH AND SAFETY

Work at the Claremont Polychemical groundwater treatment plant (GWTP) was conducted in accordance with the approved Site Safety and Health Plan (SSHP). Site safety inspections were performed daily and the reports are filed on-site. In addition to the daily safety inspections, comprehensive safety inspections were performed twice in July. These worksheets are also on file.

- The plant supervisor completed the HAZWOPER 8-hr Refresher Training by DVD.
- HRP-NY is working on revisions to the site Safety and Health Plan

No safety incidents or accidents occurred during this July 2013 period.

5.0 PLANNED ACTIVITIES AND SCHEDULES

The status of project work and significant corrective maintenance activities is updated on a monthly basis. This status of plant conditions and concerns was updated July 24 and is electronically filed. It can be found at the end of this report as Table 12-1 – Claremont Corrective Action Summary.

Separate tentative schedules for equipment maintenance events are shown in the O&M Manual and the Sampling and Analysis Plan (SAP).

The August PW samples are scheduled for August 20, 2013.

6.0 MONITORING WELL WATER ELEVATIONS

The well system water level elevation data table was updated after the June quarterly groundwater sampling event. This database is available for review. The water level elevation data is included in the quarterly groundwater monitoring report.

Due to the stabilized nature of PDB samples, the water quality data will no longer be recorded. The next update of the water level data will take place after the quarterly groundwater event to be scheduled for September.

7.0 TREATMENT SYSTEM FLOWS

The volume of treated water discharged by the treatment plant to the injection well field is determined daily from readings of the magnetic flow meter on the plant effluent line. A summary of these meter readings for July is provided in Table 7-1. The total volume of treated water discharged in July, as measured from 0600 hours on July 1, 2013, to 0600 hours on August 1, 2013, was 12,602,888 gallons. This volume is approximately 84 percent of the monthly targeted treatment goal. The cumulative volume of water discharged for this contract year (June 1, 2013 to present) was 27,009,023 and is ~8 percent below target. A graphic representation of the daily system flows are provided in Figure 14-1. (Targeted goals are based on a treated water discharge rate of 335 gpm.) The plant was offline for 164.8 hours.

In July, the plant discharge flow averaged 282 gallons per minute (gpm) and 406545 gallons per day (gpd).

| Month | Flow Average (gpm) | Volume Discharged (gpd) |
|---------------|--------------------|-------------------------|
| June '12 | 380 | 546,715 |
| July '12 | 357 | 513,599 |
| August '12 | 344 | 495,778 |
| September '12 | 338 | 487,288 |
| October '12 | 320 | 460,217 |

HRP Engineering, P.C.

| | | |
|--------------|------------|----------------|
| November '12 | 343 | 493,409 |
| December '12 | 47 | 68,314 |
| January '13 | 0 | 0 |
| February '13 | 0 | 0 |
| March '13 | 0 | 0 |
| April '13 | 0 | 0 |
| May '13 | 152 | 219,330 |
| June '13 | 333 | 480,205 |
| July '13 | 282 | 406,545 |
| Goal | 335 | 482,400 |

The flow monitoring units for the individual IW systems and infiltration galleries are fully functioning. This allows for reading the flow rate and volume discharged to each system. The relative flows for July are indicated below:

| Injection Well System | Flow Average (gpm) | Volume Discharged to well (gallons)* |
|------------------------------|---------------------------|---|
| IW-1 | 14 | 645,924 |
| IG-1 | 55 | 2,456,499 |
| IW-2 | 66 | 2,929,654 |
| IW-3 | 44 | 1,957,508 |
| IG-3 | 43 | 1,922,587 |
| IW-4 | 67 | 3,003,355 |
| System | 289 | 12,915,528 |

The discrepancy between the individual injection system meter readings and the total plant effluent meter readings (~7 gpm) is due in part to the type of flow meters utilized to measure the discharge (paddle wheel vs. magnetic vs. turbine), sludge build up in the piping at the flow elements, rounding factors in the meters, and the relative time the readings are taken. The flow elements and local pipe were cleaned in February.

The flow to IW-1 and IW-3 is maximized and the valves to the galleries are fully open. Both galleries are draining adequately.

The plant's total effluent discharge is limited by plumbing constraints, by injection pump capacity and the ability of the wells to accept water.

8.0 CHEMICAL CONSUMPTION

The four chemical feed systems are not in service. The systems are periodically tested and are operational. With the exception of the permanganate feed tank, the chemical feed tanks and feed tubing contain water for testing and inspection purposes. Currently the KMnO₄ tank needs a repair to a cracked drain nozzle.

There are no bulk chemicals onsite.

9.0 CARBON SYSTEMS

9.1 Aqueous-Phase Carbon

The presence of volatile or semi volatile organic compounds have not been detected in the discharge of the liquid-phase Carbon Adsorber (LCA) vessels. The influent and effluent streams of the vessels continue to be monitored on a quarterly basis.

As part of the daily monitoring task, the differential pressure across each vessel is recorded. This data and the discharge pressures of the LCA feed pumps are used to determine whether backwashing is required. The vessels were last backwashed in December. Currently the differential pressure across vessel #1 is 4.0 psi and across vessel #2 is 4.0 psi. Backwashing of the vessels is not required at this time.

No carbon has been added to or removed from the vessels in July.

9.2 Vapor-Phase Carbon

Two vapor-phase Carbon Adsorber vessels (VCA) are available for the off gas treatment of the air stripping (AS) stream. Currently, VCA-1 is online. VCA-2 is offline and ready for service. Monitoring of VOCs in the influent and effluent air stream of the active vessel is performed weekly with a photo-ionization detector (PID). No emissions from the vessel were observed in July.

No spent vapor-phase carbon was generated during this period, and no carbon was added to the vessels.

10.0 WASTE DISPOSAL

Currently, there are 8 metal drums of non-hazardous carbon waste stored inside the facility. There was no waste removed from the facility in July.

11.0 MONTHLY DISCHARGE MONITORING REPORT

The plant is currently operating under an equivalency permit from the New York State Department of Environmental Conservation (NYSDEC). While the permit requires periodic submittal of discharge monitoring results, monthly discharge monitoring reporting is not required. A review of the monthly discharge analytical results, which are included within Section 14.0, indicated all analyzed parameters were below noted permit limits.

The plant's water discharge permit expires December 31, 2013. Efforts are currently underway for the permit renewal/extension.

12.0 OTHER OPERATIONS, MAINTENANCE, OR MANAGEMENT ISSUES

Jennifer Kotch has been named project manager for the Claremont Polychemical Site. The project will be run out of the HRP -NY office.

MANA Construction Group is leasing the Claremont property at the old plant. They will store and stage their equipment there. MANA proposed connecting to our water main and taking over responsibilities for the entire water usage bill. NYSDEC agreed to this change and the connection was made 7/24.

The GWTS lost power (7/10-7/17) when an off-site underground power line was severed. Other than lost time, the plant suffered no damages due to the power outage.

The USEPA conducted its 5-year review of the Claremont System. Discussions included documentation, process changes, and how the project would be terminated. Also discussed was the capture of the off-site generated contamination.

Other on-going plant maintenance issues are summarized on Table 12-1.

13.0 PLANT DOCUMENTS

Procedures and standard forms are written, reviewed, and revised as needed. In July, the following changes were made:

- The Significant Events document and Monthly O&M Report were revised to include a section for the extraction well packer pressures.

14.0 TREATMENT PLANT AND WELL FIELD MONITORING RESULTS

The Claremont Polychemical GWTS is monitored through the analysis of off-site laboratory analytical data and on-site field data.

14.1 Off-site Analytical Data Results

Monthly plant discharge (PD) samples are taken for organic analysis in compliance with the NYSDEC discharge permit. Quarterly groundwater (GW) samples are taken for organic analysis, and quarterly process water (PW) samples are taken for organic, inorganic, and generic analysis. Julys' sampling activities included:

- The plant discharge was sampled 7/24 and shipped to TA-Edison for organic analysis.
- The analytical data for the June groundwater samples was uploaded to EQulS.
- The analytical data for the June plant discharge samples was uploaded to EQulS.

The plant discharge is sampled monthly. The latest available analytical results are for June 25 2013. The analytical results for these samples follow:

| Plant Discharge | | | |
|------------------------------|-----------------------|-------|------------------|
| Parameters | Discharge Limitations | Units | Results June '13 |
| pH (range) | 5.5 – 8.5 | SU | 6.52 |
| Tetrachloroethylene | 5 | ug/l | U |
| Trichloroethylene | 5 | ug/l | 0.16 |
| 1,2-(cis) Dichloroethylene | 5 | ug/l | U |
| 1,2-(trans)Dichloroethylene | 5 | ug/l | U |
| Methylene Chloride | 5 | ug/l | U |
| 1,1 Dichloroethylene | 5 | ug/l | U |
| 1,1-Dichloroethane | 5 | ug/l | U |
| Chloroform | 7 | ug/l | U |
| 1,1,1-Trichloroethane | 5 | ug/l | U |
| Benzene | 0.7 | ug/l | U |
| Toluene | 5 | ug/l | U |
| Chlorobenzene | 5 | ug/l | U |
| Ethylbenzene | 5 | ug/l | U |
| Bis(2-ethylhexyl)phthalate | 4200 | ug/l | U |
| Di-n-butyl phthalate | 770 | ug/l | U |
| Antimony, Total recoverable | 3 | ug/l | U |
| Arsenic, Total recoverable | 50 | ug/l | U |
| Barium, Total recoverable | 2000 | ug/l | NS |
| Lead, Total recoverable | 50 | ug/l | NS |
| Selenium, Total recoverable | 40 | ug/l | NS |
| Iron, Total recoverable | 500 | ug/l | NS |
| Manganese, Total recoverable | 500 | ug/l | NS |
| Nitrogen, Total (as N) | 10 | mg/l | NS |
| Solids, Total Dissolved | 1000 | mg/l | NS |
| Chromium, Hexavalent | 100 | ug/l | NS |
| Chloride Ion | NL | mg/l | NS |
| Fluoride Ion | NL | mg/l | NS |
| Sulfate Ion | NL | mg/l | NS |

NS not sampled

U analyzed for but not detected

J estimated value

NL monitor only

14.2 Field Data

Treatment plant effluent is monitored for pH and temperature on a weekly basis in order to obtain a monthly average in compliance with the NYSDEC discharge permit requirements. These readings are obtained from discharge samples taken from a controlled point with calibrated portable meters. A summary of these data is as follows:

| Date | pH | Temperature (°C) |
|----------------------|-------------|------------------|
| July 1, 2013 | 6.56 | 18 |
| July 8, 2013 | 6.63 | 18 |
| July 22, 2013 | 6.53 | 18 |
| July 29, 2013 | 6.63 | 18 |
| July Averages | 6.59 | 18 |

The NYSDEC discharge permit requires the plant discharge to have an average monthly pH greater than 5.50. The treatment plant effluent pH averaged 6.59 in July and met the monthly average pH discharge requirement. A graph of the plant discharge monthly pH average trend over several months is provided in Table 14-1.

Using a handheld, calibrated PID meter, weekly air monitoring readings are taken of the influent and effluent air streams of the active vapor phase carbon adsorber vessel following the air stripping tower. Currently vessel #1 is on-line.

| Date | Inlet | Outlet |
|---|-------|--------|
| July 1, 2013 | 0.0 | 0.0 |
| July 8, 2013 | 0.0 | 0.0 |
| July 16, 2013 | 0.0 | 0.0 |
| July 22, 2013 | 0.0 | 0.0 |
| July 29, 2013 | 0.0 | 0.0 |
| *PID readings indicate that the VOCs in the air stream are lower than the part per million levels (ppm) of the instrument's capability. | | |

No emissions were observed in the discharge of the active vessel VCA-1.

Measurements to determine the well depth from the top of the injection well column to the bottom were taken on 7/29. A summary of the historical data is included in Table 14-2. Although there has been an accumulation of sediment in all four injection wells, the wells currently appear to be stable.

Water elevations in the IWs are recorded on a daily basis as is the daily total flow discharged to the well field. These are depicted in Figure 14-1. The IW levels were generally steady while the pumps are active. With the exception of IW-1, the transducers in IW-2, IW-3, and IW-4 are producing unreliable signals. The water levels are physically monitored more frequently. On 7/29 the DTW readings for the injection wells were recorded.

| | Sounding Depth (ft) | Transducer | Depth to Water (ft) |
|------|---------------------|------------|---------------------|
| IW-1 | 145.6 | 160.7 | 6.5 |
| IW-2 | 135.8 | 112.1 | 8.6 |
| IW-3 | 247.8 | 129.3 | 7.9 |
| IW-4 | 196.3 | 128.7 | 15.6 |

The injection well falling head test was conducted on July 23. Due to the questionable output of the level transducers, the only data recorded was for IW-1. A graphic representation of the time required to drop the water level to a static condition is presented in Figure 14-2. Comparisons of baseline data from March 2006 to that of recent tests (Figure 14-3) indicate that the performance of IW-1 is unchanged. All wells appear to be draining adequately.

Other routine data collected during July included:

- The plant sound level readings were recorded twice (7/16, 7/26)
- The flow-meter readings and the depth of water in the infiltration galleries were recorded in site supervisor's notebook and included with the monthly filings. (7/25)
- Weekly utility meter readings were recorded.
- The extraction well packer pressures were recorded on several occasions (see Sec. 15.1)

15.0 PROCESS ANALYSIS, INTERPRETATIONS, AND CONCLUSIONS

15.1 Extraction and Influent Processes

- The three extraction well pumps are fully functional and are on-line.
- The three influent pumps are operational with 2 pumps on-line at a time.
- There continues to be some drift in the VFD control of influent pump-1.
- The influent pumps were rotated once in July.
- The 2 influent flow controllers are fully functional.
- Routine maintenance continues.

Extraction Well packer pressure readings:

| Date | EX-1 | EX-2 |
|------|--------------------------------------|--------------------------------------|
| 7/3 | 25 psi | 43 psi |
| 7/8 | 24 psi | 44 psi |
| 7/9 | 23 psi - packer charged to 40 psi | 43 psi - packer charged to 49 psi |
| 7/16 | 36 psi | 48 psi |
| 7/22 | 33 psi | 48 psi |
| 7/26 | 31 psi | 48 psi |

| | | |
|------|--------|--------|
| 7/29 | 31 psi | 48 psi |
|------|--------|--------|

15.2 Flow through Aeration Process

- Both treatment trains are on-line and the influent water is matched to the output of the ASF pumps.
- The polymer, potassium permanganate, caustic, and hydrochloric acid feed systems remain out of service as current water conditions make their use unnecessary.
- The flash and flocculation mixers at the clarifiers remain idle due to the discontinued use of the polymer and lack of solids generation.
- The reaction tanks and clarifier systems continue to operate as pass-through settling tanks.

15.3 Settling Filter Process

- The system is fully functional.
- Maintenance is performed as required.

15.4 Air Stripping Process

- The three ASF pumps are operational and are rotated into service two at a time. They were rotated once in July.
- The VFD for ASF P2 exhibits an earth ground fault. When on-line, Pump 2 operates through the off line pump's VFD.
- The VFD for ASF P1 is starting to become problematic. It does not seem to control by tank level and has latched to the VFD for pump 3.
- The blower is checked daily and is fully functional.
- No other issues arose with the air stripping system. Routine maintenance continues.

15.5 Aqueous-Phase Carbon Treatment Process

- All three feed pumps are operational, with two pumps rotated into service at a time. The pumps were rotated once in July.
- Currently the differential pressure across the vessels is rising and backwashing will be required soon.
- Other routine maintenance tasks continued.

15.6 Treated Water Injection Process

The plant's total discharge flow rate and volume are measured by a magnetic flow meter on the injection pump discharge manifold. The paddle wheel flow sensors and flow transmitters installed in the discharge line to each injection well system are on-line and connected to the

MCP and HMI. The turbine flow meters in the infiltration gallery valve boxes are fully functional.

- The plant discharge system is online and operational.
- Difficulties with INJ P2 were repaired and all pumps are operational.
- Except for IW-1, the injection well transducers are all producing unreliable signals.
- The galleries are adequately draining.
- No other issues were encountered with the injection system in July. Routine maintenance tasks continue.

16.0 GROUNDINGS

Routine maintenance tasks continue outside the plant.

16.1 Plant Perimeter

- General outdoor clean up continues. This includes landscaping tasks.
- Repairs were made to the below ground power feed supplying the facility. (outside contractors)

16.2 Well Field

- The frequency of DTW readings has increased due to the poor signals from the injection well transducers.
- EX well packer pressure readings continue.

16.3 Other

- The monthly in-house inspection of the plant truck was completed.
- Miscellaneous trips for local purchases were made.

There were no other significant issues outside the plant. Routine maintenance continues.

FIGURES

Figure 14-1 Injection Well Elevations and Daily Flow




Figure 14-2 Injection Well Falling Head Test - July 23, 2013







Figure 14-3 Comparison of Falling Head Tests





TABLES

TABLE 7-1

MAGNETIC FLOWMETER DAILY TOTALIZER READINGS

July 2013

| DATE | TOTALIZER READING | GALLONS PER DAY | GALLONS PER MINUTE |
|--------------------------------------|----------------------|--------------------|-----------------------|
| 7/1/2013 | 673635365 | 554635 | 385 |
| 7/2/2013 | 674190000 | 510000 | 354 |
| 7/3/2013 | 674700000 | 1010000 | 351 |
| 7/5/2013 | 675710000 | 1620000 | 375 |
| 7/8/2013 | 677330000 | 550000 | 382 |
| 7/9/2013 | 677880000 | 500000 | 347 |
| 7/10/2013 | 678380000 | 140000 | 97 |
| 7/17/2013 | 678520000 | 430000 | 299 |
| 7/18/2013 | 678950000 | 480000 | 333 |
| 7/19/2013 | 679430000 | 1640000 | 380 |
| 7/22/2013 | 681070000 | 520000 | 361 |
| 7/23/2013 | 681590000 | 500000 | 347 |
| 7/24/2013 | 682090000 | 520000 | 361 |
| 7/25/2013 | 682610000 | 530000 | 368 |
| 7/26/2013 | 683140000 | 1560000 | 361 |
| 7/29/2013 | 684700000 | 530000 | 368 |
| 7/30/2013 | 685230000 | 520000 | 361 |
| 7/31/2013 | 685750000 | 488253 | 339 |
| 8/1/2013 | 686238253 | | |
| July '13 Treated Water Volume | | 12,602,888 | |
| July '13 Avg. GPM Discharged | | | 282 |

Table 12-1

Plant conditions and concerns (updated 7/24/13)

| Date | Condition to be corrected | Status | Priority | Notes |
|----------|--|---|----------|--|
| 2007 | PD manifold leak | Leave as is and monitor | 3 | Leak is monitored and deemed to be not serious |
| 2008 | Check Valve failures | Valves are manually controlled | 2 | Plant wide – 13 units, this situation creates problems for any remote control of the processes. |
| 2008 | Injection Pump 1&2 shut off valve failures | Leave as is | 2 | Minimum 4 units. Pumps cannot be isolated |
| Aug '08 | Air Compressor overhaul | Run system on an 'as needed' basis | 4 | This method has been working well. A failure may prevent some tasks. |
| 2009 | EQ tank isolation valve failure | Leave as is | 2 | The tank cannot be isolated |
| 2009 | Filter press hydraulic fluid leak | Add fluid as needed | 4 | The hydraulic pump system will require outside service. |
| Aug '10 | IWs transducer replacement | Leave as is and manually measure water levels | 3 | 3 units, only the transducer in IW-1 gives a reliable signal |
| Aug '10 | Access stairs from plant to wellfield | Leave as is | 4 | Need to generate a plan with costs |
| May '11 | pH meter failures at RX1, 2, and ASF | Leave as is | 3 | pH control is no longer required |
| June '11 | ASF P2 VFD repair | Leave out of service | 2 | P-2 is run on off-line pump's VFD |
| July '11 | INF P1 VFD repair | Leave as is | 2 | Pump flow is controlled by throttling the P-1 discharge valve |
| Jan '12 | INF P2 motor noise | Await failure | 4 | Replace motor at failure |
| Apr '12 | INJ P2 leak | Leave as is | 2 | Shut down item – replace seal |
| Apr '12 | Permanganate tank repair | Leave as is | 4 | Off line, tank is not needed |
| June '12 | ASF Level Monitor | Operate as is | 3 | Monitor give false LL conditions which cycles the pump |
| Sept '12 | Optimize PD flow | Leave as is | 4 | -Change extraction containment flow requirements -change discharge & manifold plumbing -change out pump impellers -resize pumps |
| Nov. '12 | Clean Process tanks | Clean when possible EQ, TW, ASF | 4 | Plant shutdown items: See below for completed tanks |
| Ongoing | Non-Hazardous Waste Accumulation | Indoor storage | 3 | Waste removal will be scheduled when sufficient quantity is accumulated. |
| Jan '13 | Rust spots on storage tank shells | Project has started, lower sections of the TW and EQ tanks have been prepped and spot primed | 2 | Rusted areas are to be abraded clean and spot painted |
| May '13 | VFD for ASF P1 – not tracking tank levels | P1 system is currently tracking VFD 3 | 2 | Need electronics tech to look at control system |
| May '13 | EX well Blockers – leaking air | Periodically charging bladders. The pumps and packers were pulled, repairs were made, and then were re-installed (6/17). EX-2 holds pressure, EX-1 loses pressure over time. Bladder recharged as needed. | 1 | Charged system affects the transducer activity. |
| May '13 | EX well capacity testing | Pump tests completed 6/22/13 | 2 | Equipment may not support the tests as designed |
| May '13 | INJ P2 is not functioning | Repairs made 7/2 | 3 | Further testing is required |

| | | | | |
|--------------------------|---|--|---|--|
| June '13 | Flow control on EX discharge lines is not adequate. | Butterfly valves are shut off valves not control valves Globe valves were installed. Flanged connections replaced BF valve immediately downstream of flow element. BF shut off valve was moved as far down stream as possible. | 1 | Install globe upstream of flow elements. Re-plumb as possible to move disturbances away from flow element |
| July '13 | INF P2 motor to pump coupling failure | Replace coupling coupling replaced and pump returned to service 7/23 | 2 | Take pump out of service and replace element. |
| July '13 | Well caps (drive-over) are missing or damaged at EW-6c and EW-2c | fabricate or purchase caps | 4 | one well is on golf course and one at the paper processor |
| July '13 | Rotation of motors was reversed when repairs to broken power leads was made | Reverse wires in MCC Repairs made 7/17 | 1 | possible damage to motors and impellers as well as low output |
| | | | | |
| Recently completed Tasks | Condition | Remedy | | |
| 12/14/12 | ASF Tank Level alarm faults | Units cleaned and returned to service. | | Plant is down so effectiveness of remedy has not been tested |
| 11/15/12 | Out Door Heat Trace controllers | Two units for the 3 tanks have been installed and actuated | | |
| 11/15/12 | IW-2 high water level | Reduced plant flow and several shut down periods righted the problem | | |
| 11/14/12 | Plant truck emission test | Truck passed | | |
| 12/6/12 | PID failure | New unit purchased and in use | | |
| 12/11/12 | INJ Flow meter errors | Cleaned flow elements and piping spool pieces | | |
| 12/12/12 | EX flow meters | Cleaned flow elements and piping spool pieces | | |
| 12/4/12 | Plow pump leaks | Unit was rebuilt | | |
| 12/20 | Clean EQ strainer | Cleaned when tank was emptied | | |
| Sept '12 | Emergency light failure NE door | New unit installed 1/30/13 | 2 | Fully functional |
| Nov. '12 | Clean process flow monitoring systems | Ex cleaned 12/12 PD cleaned 1/3 IW cleaned 12/11 | 3 | Plant shutdown items: PD, INJ, INF, EX |
| Dec. '12 | AST media evaluation | Tower opened and media inspected 1/14 | 4 | Iron sludge coating, media open - OK |
| Dec. '12 | Valve Actuators on Settling tanks are a potential hazard | Actuators removed 1/18 | 3 | Controllers disconnected, actuators stowed |
| June '11 | ASF P3 motor replacement | Replaced motor with one removed from P2 (1/18/11) | 2 | Has not been tested under load |
| Dec '11 | LCA vessel 2 - pin hole leaks | Repaired 2/14 | 3 | Fully functional Feb '13 |
| Nov. '12 | Clean Process tanks | Clean when possible EQ , RX-1, RX-2, ST-1 | 4 | Tanks cleaned during shutdown: RX-1, RX2, CL1, CL2, ST1, ST2, GACF1 ASF1 |

Groundwater Treatment System O&M Activities
Claremont Polychemical Superfund Site

Site # 130015

July 2013

| | | | | |
|-----------|---|--|---|--|
| Dec '12 | Plant heater failure | The heater was adjusted and is now functional | 3 | Fully Functional Feb '13 |
| Dec. '12 | LCA vessel 1 pinhole leaks | Repaired 2/15 | 3 | Fully functional |
| Dec. '12 | EQ tank pin hole leaks | Repaired 2/19 | 2 | Fully functional |
| March '13 | More EQ tank pin-hole leaks | Welder has been contacted to provide quote prior to NYSDEC approvals – Tank repaired(5/16) | 1 | 5 leaks have been observed |
| 2009 | Sludge tank transfer piping replacement | Piping disconnected and pump removed | 4 | Hoses and an M-8 are being used in place of the hard plumbed system. |
| | | | | |

Priority Level 1- Urgent and must be done 3- Not urgent but should be done
 2- Not urgent but must be done 4- Not urgent but would like done

Table 14-1

| Month | pH _{AVG.} |
|----------|--------------------|
| May '11 | 6.25 |
| June '11 | 6.33 |
| July '11 | 6.12 |
| Aug '11 | 6.39 |
| Sept '11 | 6.38 |
| Oct '11 | 6.22 |
| Nov '11 | 6.62 |
| Dec '11 | 6.60 |
| Jan '12 | 6.58 |
| Feb '12 | 6.50 |
| Mar '12 | 6.57 |
| Apr '12 | 6.52 |
| May '12 | 6.28 |
| June '12 | 6.32 |
| July '12 | 6.54 |
| Aug '12 | 6.32 |
| Sept '12 | 6.20 |
| Oct '12 | 6.15 |
| Nov '12 | 6.39 |
| Dec '12 | 6.11 |
| Jan '13 | 6.35 |
| Feb '13 | nr |
| Mar '13 | nr |
| Apr '13 | nr |
| May '13 | 6.05 |
| June '13 | 6.33 |
| July '13 | 6.59 |





TABLE 14-2 Injection Well Soundings

This table contains selected dates and data

| Date | Injection Well 1 | | Injection Well 2 | | Injection Well 3 | | Injection Well 4 | |
|------------|----------------------|------------|----------------------|------------|----------------------|------------|----------------------|------------|
| | Depth to Bottom (ft) | Difference | Depth to Bottom (ft) | Difference | Depth to Bottom (ft) | Difference | Depth to Bottom (ft) | Difference |
| 6/17/2004 | 248.50 | -- | 248.50 | -- | 253.20 | -- | 205.00 | -- |
| 7/23/2004 | 247.97 | -0.53 | 248.19 | -0.31 | 251.20 | -2.00 | 203.50 | -1.50 |
| 2/16/2006 | 247.50 | -0.01 | 245.69 | -0.40 | 249.19 | -0.02 | 203.98 | 0.00 |
| 3/23/2006* | 247.59 | 0.0 | | | | | | |
| 10/25/2007 | 244.69 | -1.1 | | | | | | |
| 11/19/2007 | 242.20 | -2.4 | | | | | | |
| 12/21/2007 | 235.02 | -7.1 | | | | | | |
| 1/29/2008 | 232.46 | -2.5 | | | | | | |
| 2/29/2008 | 226.58 | -5.8 | | | | | | |
| 3/27/2008 | 220.50 | -6.0 | | | | | | |
| 4/29/2008 | 222.50 | 2.0 | | | | | | |
| 5/30/2008 | 218.55 | -3.9 | | | | | | |
| 11/20/2008 | 198.05 | -2.6 | | | | | | |
| 12/29/2008 | 178.29 | -19.1 | | | | | | |
| 1/26/2009 | 167.50 | -10.1 | | | | | | |
| 2/25/2009 | 151.20 | -16.1 | | | | | | |
| 3/13/2009 | 148.68 | -2.5 | | | | | | |
| 9/21/2011 | 145.90 | 0.0 | | | | | | |
| 10/7/2011 | 144.30 | -1.6 | | | | | | |
| 11/17/2011 | 145.70 | 1.40 | 236.70 | -3.25 | 248.72 | 0.82 | 197.70 | -0.05 |
| 12/2/2011 | 145.95 | 0.25 | 233.80 | -2.90 | 248.30 | -0.42 | 194.65 | -3.05 |
| 1/5/2012 | 148.80 | 2.85 | 233.20 | -0.60 | 247.98 | -0.32 | 197.70 | 3.05 |
| 2/2/2012 | 145.85 | -2.95 | 224.45 | -8.75 | 248.10 | 0.12 | 197.60 | -0.10 |
| 3/7/2012 | 147.85 | 2.00 | 223.30 | -1.15 | 248.10 | 0.00 | 197.50 | -0.10 |
| 4/2/2012 | 148.80 | 0.95 | 218.80 | -4.50 | 247.97 | -0.13 | 197.50 | 0.00 |
| 5/18/2012 | 145.80 | -3.00 | 217.95 | -0.85 | 247.78 | -0.19 | 197.49 | -0.01 |
| 6/26/2012 | 144.30 | -1.50 | 205.70 | -12.25 | 217.00 | -30.78 | 197.40 | -0.09 |
| 7/20/2012 | 145.85 | 1.55 | 205.55 | -0.15 | 248.00 | 31.00 | 197.40 | 0.00 |
| 8/16/2012 | 144.90 | -0.95 | 205.70 | 0.15 | 248.10 | 0.10 | 197.20 | -0.20 |
| 9/20/2012 | 145.84 | 0.94 | 205.70 | 0.00 | 248.09 | -0.01 | 197.10 | -0.10 |
| 11/1/2012 | 145.95 | 0.11 | 205.15 | -0.55 | 248.00 | -0.09 | 197.00 | -0.10 |
| 11/16/2012 | 144.30 | -1.65 | 203.90 | -1.25 | 248.15 | 0.15 | 197.00 | 0.00 |
| 1/2/2013 | 145.90 | 1.60 | 202.65 | -1.25 | 248.10 | -0.05 | 197.05 | 0.05 |
| 1/29/2013 | 145.90 | 0.00 | 200.80 | -1.85 | 247.78 | -0.32 | 196.78 | -0.27 |
| 2/26/2013 | 145.70 | -0.20 | 199.10 | -1.70 | 233.10 | -14.68 | 196.76 | -0.02 |
| 3/18/2013 | 145.70 | 0.00 | 199.10 | 0.00 | 247.95 | 14.85 | 197.30 | 0.54 |
| 4/18/2013 | 144.05 | -1.65 | 199.10 | 0.00 | 247.70 | -0.25 | 197.25 | -0.05 |
| 5/14/2013 | 145.70 | 1.65 | 198.10 | -1.00 | 247.80 | 0.10 | 198.43 | 1.18 |
| 6/27/2013 | 145.55 | -0.15 | 198.10 | 0.00 | 247.80 | 0.00 | 198.43 | 0.00 |
| 7/29/2013 | 145.60 | 0.05 | 135.80 | -62.30 | 247.80 | 0.00 | 196.27 | -2.16 |



Associated and Referenced Documents

| Document | Location |
|--|--|
| Daily Worksheets Daily Operating Log Daily activities Summary Report Daily Site Safety Inspection Employee Sign-in Sheet | Original paper copies in monthly file folders at plant. Electronic copies on Farmington Server: >Claremont Data>year>month>month daily worksheets |
| Supporting Worksheets Visitor/Subcontractor Sign-in Sheet Air Monitoring Log Sound Monitoring Worksheet Daily Plant Activity Notes Comprehensive Site Safety Inspections | Original paper copies in monthly file folders at plant. Electronic copies on Farmington Server |
| Plant Operator's Daily Log Book | Current book issued to operator, completed books on file in shop cabinet |
| Site Supervisor's Daily Log Book | Current book issued to supervisor, completed books on file in shop cabinet |
| Daily Database | Current database is an Electronic file on site, in Claremont Docs/Claremont Ops Data/ monthly folder. Past docs on server: > Claremont Data>yr>month> |
| Daily Operations Summary Report | Current report is an Electronic file on site, in Claremont Docs/Claremont Ops Data/ monthly folder. Past docs on server: > Claremont Data>yr>month> |
| Monthly O&M Report | Electronic file on server: >Claremont Data>yr>month> |
| Monthly Maintenance Log | Electronic file on server: > Claremont Data>yr>month> |
| Project Status Report formerly Activities Schedule | Electronic file on server: >Claremont Data>yr>month> |
| Groundwater Elevation and Water Quality Database | Electronic file on server: >Operating data |
| Monthly Plant Truck Inspection Worksheet | Electronic file on server: >Claremont Data>yr>month> |
| Stand Alone Documents Claremont O&M Manual Site Safety and Health Plan Standard Operating Procedures and Instruction manual Sampling and Analysis Plan Log of Operating System Drawings | Binded copies in control room, electronic copies on server> Stand Alone Documents |
| Sampling forms | Electronic file on server: >Sampling> Sampling Forms |
| Chain of Custody Documents | Electronic File on server: >Sampling> yr>mo |
| Claremont Site Notebook | Electronic file on server : >Stand alone documents> Claremont notebook |

Associated documents and worksheets used to generate this report can also be found on shared folder' CPC Monthly Logs from Plant'