

CHECK LIST		SOURCE	QTY	ITEM OR PART DESCRIPTION	
<input type="checkbox"/> COMPRESSOR					
<input type="checkbox"/> SUCTION	PSI				
<input type="checkbox"/> HEAD	PSI				
<input type="checkbox"/> VOLTS	AMPS				
<input type="checkbox"/> ELECTRICAL CONNECTIONS					
<input type="checkbox"/> CONTACTS TIGHT & CLEAN					
<input type="checkbox"/> OIL LEVEL & CONDITION					
<input type="checkbox"/> CONDENSER OIL					
<input type="checkbox"/> CLEAN COIL & CHECK FIN COND.					
<input type="checkbox"/> ENT	*F   LVG *F				
<input type="checkbox"/> REFRIGERANT					
<input type="checkbox"/> LEAK	<input type="checkbox"/> CHARGE				
<input type="checkbox"/> FAN AND MOTOR					
<input type="checkbox"/> VOLTS	AMPS				
<input type="checkbox"/> ELECTRICAL CONNECTIONS					
<input type="checkbox"/> CONTACTS TIGHT & CLEAN					
<input type="checkbox"/> FAN PULLEYS (ADJUST BELT)					
<input type="checkbox"/> CHECK LUB BEARINGS & MOTOR					
<input type="checkbox"/> CFM					
<input type="checkbox"/> EVAPORATOR COIL					
<input type="checkbox"/> CLEAN COIL & CHECK FIN					
<input type="checkbox"/> ENT DB	*F   LVG DB *F				
<input type="checkbox"/> ΔT					
<input type="checkbox"/> CONDENSATE AREAS					
<input type="checkbox"/> INSPECT & CLEAN DRAIN PAN					
<input type="checkbox"/> INSPECT & CLEAN DRAIN					
<input type="checkbox"/> AIR FILTERS					
<input type="checkbox"/> CLEANED	<input type="checkbox"/> REPLACED				
<input type="checkbox"/> HEATING ASSY.					
<input type="checkbox"/> BURNER & HEAT EXCHANGER					
<input type="checkbox"/> FUEL SUPPLY & PRESSURE					
<input type="checkbox"/> PILOT ASSEMBLY					
<input type="checkbox"/> FLAME ADJUSTMENT					
<input type="checkbox"/> PRIMARY RELAY & FLUE					
<input type="checkbox"/> FAN & LIMIT SWITCH OPER.					
<input type="checkbox"/> BLOWER ASSEMBLY					
<input type="checkbox"/> RV VALVE					
<input type="checkbox"/> STRIP HEAT					
<input type="checkbox"/> DEFROST CYCLE					
<input type="checkbox"/> ELECTRICAL COMP'TS					
<input type="checkbox"/> RELAYS	<input type="checkbox"/> CONTACTORS				
<input type="checkbox"/> OVERLOAD	<input type="checkbox"/> PRESS. SWITCH				
<input type="checkbox"/> THERMOSTAT					
<input type="checkbox"/> O.K.	<input type="checkbox"/> REPLACE				
<input type="checkbox"/> RELOCATE					
EFFICIENCY					
Stack					
Smoke					
CO <sub>2</sub>					
O <sub>2</sub>					
DOF					
D.O.B.					
Efficiency					
Safety Time					
TECHNICIAN SIGNATURE					
MANAGEMENT APPROVAL					
RECOMMENDATIONS:		<input type="checkbox"/> OFFICE TO CALL		<input type="checkbox"/> ORDER PART	<input type="checkbox"/> LEFT PROPOSAL
NAME		STREET		CITY	STATE
PHONE		ZIP		MAKE	MODEL
SERIAL NUMBER		FILTER SIZE		BELT SIZE	
REASON FOR CALL:		DIAGNOSTIC EVALUATION:			
SERVICE PERFORMED / REPAIRS COMPLETED:		CUSTOMER REQUEST:			
JOB COMPLETE		MUST RETURN		SERVICE FEE	
REPAIRS		PMM		COMM. LABOR	
COMM. PARTS		SUBTOTAL		TAX	
TOTAL AMOUNT DUE		DATE		SEE REVERSE SIDE FOR WARRANTY	

**All Weather**  
TEMPERATURE CONTROL, INC.

Air Conditioning, Heating & Indoor Air Quality Specialist Since 1969

**AIR CONDITIONING & HEATING**

35 COURT STREET COPIAGUE, NEW YORK 11726  
TELEPHONE (631) 842-8777 FAX (631) 842-8970  
AllWeatherTemp.com

DATE 5/5/21  
JOB# 291950

☐ WARRANTY  
☐ CHARGE  
☐ PM MEMBER  
☐ CALL BACK  
☐ RES. ☐ COMM.  
☐ SURVEY

**JOB TIME**

TIME RECEIVED 10:45  
TIME ARRIVED 11:15  
TIME DEPARTED

Weather Rtc  
3/4 ID -- 200 HH  
5/11, 5/22  
Mfg Date 10/14/97

REASON FOR CALL: Ten Check HVAC System to this order for a damaged motor  
DIAGNOSTIC EVALUATION: shaft cone and fly wheel  
5/11 5/22 see it this is correct!  
SERVICE PERFORMED / REPAIRS COMPLETED: 15 min + Repair  
shaft is sheared on pulley  
need shaft bearing replacement hubs  
need to look into ports