

THOMAS R. SUOZZI
COUNTY EXECUTIVE



RAYMOND A. RIBEIRO, P.E.
COMMISSIONER

**COUNTY OF NASSAU
DEPARTMENT OF PUBLIC WORKS
1194 PROSPECT AVENUE
WESTBURY, NEW YORK 11590-2723**

June 21, 2008



New York State Department of
Environmental Conservation
Division of Environmental Remediation
Bureau of Hazardous Site Control
625 Broadway
Albany, New York 12233

Att: Cynthia Whitfield, P.E.
Environmental Engineer II

Re: 2008 Monthly Effluent Monitoring Reports
Nassau County Fireman's Training Center, Site #1-30-042

Ladies and Gentlemen:

Attached are the April and May 2008 Monthly Effluent Monitoring Reports for the groundwater remediation at the Fireman's Training Center site in Old Bethpage, New York.

If you have any questions concerning the monthly monitoring reports, please contact Mr. Joseph Walker, Assistant Superintendent of Water Supply, at (516) 571-6983.

Very truly yours,

Kenneth G. Arnold, P.E.
Sanitary Engineer IV
Unit Head, Water/Wastewater Engineering Unit

KGA:JNW:jb
Attachments

c: Joseph L. Davenport, Deputy Commissioner of Public Works
William Spitz, Region 1, NYSDEC
Joseph N. Walker, Assistant Superintendent of Water Supply

**NASSAU COUNTY FIREMAN'S TRAINING CENTER
GROUNDWATER REMEDIATION FACILITY
MONTHLY EFFLUENT MONITORING REPORT
OUTFALL 001**

APRIL 2008

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1 4/1/08	WEEK 2 04/08/08	WEEK 3 04/15/08	WEEK 4 04/22/08	WEEK 5 04/29/08
FLOW, DAILY AVG	MONITOR	GPD	NA	831700	826743	823243	834629	706871
FLOW, DAILY MAX	MONITOR	GPD	NA	836500	840800	840600	844600	837900
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
ACETONE	50	µ g/l	10.0	BDL	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
CHLOROFORM	7	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL	BDL
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL	BDL
METHYL ETHYL KEYTONE	50	µ g/l	10.0	BDL	BDL	BDL	BDL	BDL
NAPHTHALENE	10	µ g/l	1.7	BDL	BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL	BDL
TETRACHLOROETHENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	1.7	BDL	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL	BDL
TOTAL VOCs		µ g/l	0.0	0.0	0.0	0.0	0.0	0.0
BIS(2-ETHYLHEXYL)PHTHALATE	4.3	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
DIETHYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
DIMETHYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
DI-N-OCTYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
FLUORENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
PHENANTHRENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
PYRENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL	BDL
ALUMINUM, TOTAL	2000	µ g/l	40.0	30.0	22.0	7.0	15.0	BDL
ARSENIC, TOTAL	50	µ g/l	48.0	BDL	BDL	BDL	BDL	BDL
CHROMIUM, TOTAL	50	µ g/l	2.0	BDL	BDL	BDL	BDL	BDL
IRON, TOTAL	600	µ g/l	2.0	96.0	55.0	32.0	47.0	32.0
MANGANESE, TOTAL	600	µ g/l	1.0	126.0	107.0	106.0	118.0	111.0
NICKEL, TOTAL	2000	µ g/l	5.0	BDL	BDL	BDL	BDL	BDL
SUM IRON & MANGANESE	1000	µ g/l	NA	222.0	162.0	138.0	165.0	143.0

**NASSAU COUNTY FIREMAN'S TRAINING CENTER
GROUNDWATER REMEDIATION FACILITY
MONTHLY EFFLUENT MONITORING REPORT
OUTFALL 001**

MAY 2008

EFFLUENT PARAMETER	DISCHARGE LIMITATIONS	UNITS	COMPT MDL	WEEK 1	WEEK 2	WEEK 3	WEEK 4
				5/6/08	05/13/08	05/21/08	05/27/08
FLOW, DAILY AVG	MONITOR	GPD	NA	834050	831193	659538	612500
FLOW, DAILY MAX	MONITOR	GPD	NA	838900	835600	836200	613980
1,1,1-TRICHLOROETHANE	5	µ g/l	1.4	BDL	BDL	BDL	BDL
1,1-DICHLOROETHANE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
1,1-DICHLOROETHENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
1,2(CIS)-DICHLOROETHENE	5	µ g/l	1.0	BDL	BDL	BDL	BDL
1,2(TRANS)-DICHLOROETHENE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
ACETONE	50	µ g/l	10.0	BDL	BDL	BDL	BDL
BENZENE	0.7	µ g/l	0.7	BDL	BDL	BDL	BDL
CHLOROFORM	7	µ g/l	1.1	BDL	BDL	BDL	BDL
DIBROMOCHLOROMETHANE	50	µ g/l	0.7	BDL	BDL	BDL	BDL
DICHLOROBROMOMETHANE	50	µ g/l	0.9	BDL	BDL	BDL	BDL
m,p-XYLENE	5	µ g/l	2.4	BDL	BDL	BDL	BDL
METHYL ETHYL KEYTONE	50	µ g/l	10.0	BDL	BDL	BDL	BDL
NAPHTHALENE	10	µ g/l	1.7	BDL	BDL	BDL	BDL
o-XYLENE	5	µ g/l	1.3	BDL	BDL	BDL	BDL
TETRACHLOROETHENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
TOLUENE	5	µ g/l	1.2	BDL	BDL	BDL	BDL
TRICHLOROETHENE	10	µ g/l	1.7	BDL	BDL	BDL	BDL
VINYL CHLORIDE	5	µ g/l	1.1	BDL	BDL	BDL	BDL
TOTAL VOCs		µ g/l	0.0	0.0	0.0	0.0	0.0
BIS(2-ETHYLHEXYL)PHTHALATE	4.3	µ g/l	1.0	BDL	BDL	BDL	BDL
DIETHYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL
DIMETHYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL
DI-N-OCTYL PHTHALATE	50	µ g/l	1.0	BDL	BDL	BDL	BDL
FLUORENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL
PHENANTHRENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL
PYRENE	50	µ g/l	1.0	BDL	BDL	BDL	BDL
ALUMINUM, TOTAL	2000	µ g/l	40.0	6.0	24.0	4.0	41.0
ARSENIC, TOTAL	50	µ g/l	48.0	BDL	BDL	BDL	BDL
CHROMIUM, TOTAL	50	µ g/l	2.0	BDL	BDL	BDL	BDL
IRON, TOTAL	600	µ g/l	2.0	27.0	80.0	70.0	70.0
MANGANESE, TOTAL	600	µ g/l	1.0	109.0	113.0	40.0	91.0
NICKEL, TOTAL	2000	µ g/l	5.0	BDL	7.0	BDL	8.0
SUM IRON & MANGANESE	1000	µ g/l	NA	136.0	200.0	110.0	169.0