

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

April 22, 1974

11-1132


County

COMPLETION REPORT - LONG ISLAND WELL

Well No.

OWNER <i>John F. ...</i>				* LOG	
ADDRESS <i>35 ...</i>				Ground Surface	
LOCATION OF WELL " " " " "				El. _____ ft. above sea	
DEPTH OF WELL BELOW SURFACE <i>30</i> ft.		DEPTH TO GROUND WATER FROM SURFACE <i>45</i> ft.		$\frac{A}{V}$ _____ ft.	
CASINGS					
DIAMETER <i>6</i> in.		in.		in.	
LENGTH <i>8-7</i> ft.		ft.		ft.	
SEALING		CASINGS REMOVED			
SCREENS					
MAKE <i>Cock</i>		OPENINGS <i># 14</i>			
DIAMETER <i>4</i> in.		<i>3</i> in.		in.	
LENGTH <i>5</i> ft.		<i>1</i> ft.		ft.	
DEPTH TO TOP FROM TOP OF CASING <i>52'</i>					
PUMPING TEST					
DATE <i>5/1/76</i>		TEST OR PERMANENT PUMP? <i>Test</i>			
DURATION OF TEST days _____ hours <i>2</i>		MAXIMUM DISCHARGE <i>35</i> gallons per min.			
STATIC LEVEL PRIOR TO TEST ft. _____		LEVEL DURING MAXIMUM PUMPING in. below top of casing _____			
MAXIMUM DRAWDOWN ft. _____		Approximate time of return to normal vel after cessation of pumping hrs. _____ min. _____			
PUMP INSTALLED					
TYPE <i>Submers</i>		MAKE <i>Joan 22</i>		MODEL NO. <i>1554D</i>	
MOTIVE POWER <i>Elec.</i>		MAKE <i>Finn. Klein</i>		H.P. <i>1 1/2</i>	
CAPACITY <i>25</i> g.p.m. against		ft. of discharge head			
NUMBER BOWLS OR STAGES <i>11</i>		<i>180'</i> ft. of total head			
DROP LINE			SUCTION LINE		
DIAMETER <i>1 1/2</i> in.			DIAMETER in.		
LENGTH <i>63</i> ft.			LENGTH ft.		
METHOD OF DRILLING <input type="checkbox"/> rotary <input checked="" type="checkbox"/> cable tool <input type="checkbox"/> other _____			USE OF WATER <i>Cooling</i>		
WORK STARTED <i>8/1</i>			COMPLETED <i>7/1/76</i>		
DATE <i>5/12/76</i>		DRILLER <i>United Well Pump Corp.</i>		LICENSE NO. <i>000</i>	

*NOTE: Show log of well - materials encountered, with depth below ground surface, water bearing beds and water levels in each, casings, screens, pump, additional pumping tests and other matters of interest. Describe repair job. See Instructions as to Well Drillers' Licenses and Reports. Pages 5 - 7.



Locate well with respect to at least two streets or roads,
showing distance from corner and front of lot.

Show North Point

Check the Town in which the project is located:

Nassau County:

☒ Hempstead

☐ North Hempstead

☐ Oyster Bay

Suffolk County:

☐ Babylon

☐ Brookhaven

☐ East Hampton

☐ Huntington

☐ Islip

☐ Riverhead

☐ Shelter Island

☐ Smithtown

☐ Southampton

☐ Southold