

ORIGINAL--TO COMMISSION

County Albany

State of New York JAN 1 - 1949

Department of Conservation

Division of Water Power and Control COMMISSION

COMPLETION REPORT--LONG ISLAND WELLS

Well No. 12231-
(on preliminary report)

LOG

Surf. El. ft. above sea

Top of Well

Owner John J. Murphy - 0-8
Address Hicksville - Old 5
Location of well Burrows - Hicksville Rd 8-29
Depth below surface 129 feet
Depth to water: Ground water 79 ft.; Finished well 1129 ft.

CASINGS:

Diameter 8 in. in. in. in. 29-41
Length 114 ft. ft. ft. ft.
Sealing Cook Lead packer
Casings removed

SCREENS:

Make Cook Wire Wound Openings #25
Diameter 7 3/4 in. in. in. in. 41-73
Length 15 ft. ft. ft. ft.
Depth to top from top of casing 114 ft.

PUMPING TEST: Date June 23/47 Test or permanent pump?
Duration of Test 3 days hours
Maximum Discharge 103 gallons per minute
Static Level Prior to Test 79 ft. 91 in. below top of casing
Level during Max. Pumping 91 ft. in. below top of casing
Maximum Drawdown 12 ft.
Approx. time of return to normal level after cessation of pumping Very fast (2) minutes

PUMP INSTALLED:

Type Turbine Make Cook Model No.
Motive power Electric Make Century H.P. 7 1/2
Capacity 100 g.p.m. against 40.65 ft. of discharge head
No. bowls or stages 11 } against 40.65 ft. of total head

DROP LINE:

Diameter 7 1/2 bowls - in. in. in.
Length 100 ft. ft. ft.

SUCTION LINE:

Coleman
Diameter 6 in. in. in.
Length 6 ft. ft. ft.


Use of water Household & Home
Work started May 8/47 Completed * Jan/4/49
Date Jan - 2/50 Driller Frank J. ...
License No. 208

NOTE: Show log of well--materials encountered, with depth below ground surface, water-bearing beds and water levels in each, casings, screens, pump, additional pumping tests and other matters of interest. Describe repair job.

See Instructions as to Well Drillers' Licenses and Reports--pp. 5-7.

* after much delay we have for all get
Tough to accept this pump for such amount. but after
much of time for - as yet - this water is not
by the way of cooperation

Well
pit
fine sand
& coarse
gravel
Very
coarse
gravel
red
sand
some
pebbles
yellow
coarse
sand
white
coarse
sand
&
large
gravel
coarse
yellow
sand
about
20% large
pebbles



Locate well with respect to at least two streets or roads, showing distance from corner and front of lot.

Show North Point



STATE OF NEW YORK
CONSERVATION DEPARTMENT
DIVISION OF WATER POWER AND CONTROL



WATER POWER AND CONTROL COMMISSION

Long Island Water Application for Water

JOHN J. KELLY, Chairman

DECISION

OFFICIAL RECORD

TO REMAIN IN THE CUSTODY OF THE WATER POWER AND CONTROL COMMISSION



State of New York
Department of Conservation
WATER POWER AND CONTROL COMMISSION

Long Island Well Application No. W-882

In the Matter of the Application

- of -

JOHN and WILLIAM STARYK

for approval of the sinking of a
new well on their property on
Hicksville Ave., in the Town of
Oyster Bay, County of Nassau,
State of New York.

Fairway Farms

D E C I S I O N

Application filed November 19, 1946

Hearing held in Hicksville,
November 29, 1946

Decision

January 7, 1947

DECISION ON LONG ISLAND WELL APPLICATION NO. W-882

This is an application made under the provisions of Section 521-a of the Conservation Law for approval of a well to be put down in Nassau county.

Petition verified by John Staryk, partner, in the partnership of John and William Staryk, on November 18, 1946, and filed in the office of the Water Power and Control Commission on November 19, 1946. Due notice of the hearing was given by publication in the Nassau Daily Review-Star of Hempstead, and the hearing was held before Arthur H. Johnson, Associate Engineer of the Commission, in the Court House, Hicksville, on November 29, 1946, at 10 o'clock in the forenoon. Petitioner was represented by John Staryk, partner. No objections were filed. W. Fred Welson, Senior Engineer in the Department of Public Works, and David H. Davids, Sanitary Engineer in the Department of Health, appeared as observers for Nassau county.

After due study of the petition and its exhibits and the evidence and arguments given at the hearing, the Commission finds as follows:

John and William Staryk, a partnership, are owners of Fairway Farms, a milk processing plant located at the northeast corner of the intersection of Burns Avenue and Hicksville Avenue, in Hicksville, town of Oyster Bay, Nassau county. At this location applicant is constructing a new plant for processing milk.

Well water is desired for cooling in the refrigeration machinery, washing cans and bottles, drinking and sanitary use.

Applicant proposes to sink a well 85 feet south of Hicksville Avenue and 75 feet west of Burns Avenue, with 8-inch casing and screen, about 100 feet deep, equipped with an electrically operated deep well turbine pump of 100 gallons a minute capacity. Pressures are to be maintained by a 2,000-gallon pneumatic storage tank located underground. Water pumped from the proposed well, after use in the cooling operations, is to be returned to the ground through an open seepage basin located at least 100 feet from the proposed well. Water from washing operations and other uses is to be discharged into a cesspool to be located about 120 feet from the proposed well. The use of water is estimated to be 45,000 gallons daily and 5 1/2 millions of gallons annually.

Unless water can be obtained from the proposed well it will have to be purchased from Hicksville Water District, which distributes water from local wells.

The nearest source of public water supply are wells of Hicksville Water District, located about one and one-half miles distant from applicant's plant.

There are no sewers in the area. All water after use is returned to the ground through seepage basins or cesspools.

Experience has indicated that the water to be obtained from the proposed well will be fresh, safe to drink and suitable although there is always a possibility that heavy pumping may change conditions. The action of this Commission in approving this well must not be considered as in any wise limiting the action of the local and State health authorities in supervising the water used on this property for drinking and other purposes and the location of sewage disposal plants and seepage pits in relation to the well.

If this project is carried out as proposed there will be little net change in existing ground water conditions and it therefore, cannot have any adverse effect on wells used as sources of public water supply. This application may be approved.

The Commission finds it to be necessary to protect the interests of the applicant and of the people of the State to impose the following conditions:

1. By authority of this decision and approval applicant is authorized to sink the well described above, equipped with a pump of 100 gallons a minute capacity. Water for cooling purposes, after use must be returned to the ground through the proposed seepage basin or some other equivalent satisfactory structure. Pumping is limited to 100 gallons in any one minute and 5.5 millions of gallons in any one year.
2. Applicant must install suitable connections to enable the discharge of the pump to be measured. Such fittings and the locations thereof will be specified by the Commission.
3. No cross connection to any other source of water supply may be installed or maintained.

4. Detailed plans showing each part of this project must have been submitted to and approved by this Commission before work is started on such part. The entire project must be fully completed in accordance with approved plans.
5. No chemical or polluting substance may be discharged in this water or into the diffusion pit.
6. Nothing in this decision or approval contained shall be held as imposing any restriction on the action of the duly constituted health authorities, State or local, in connection with questions arising as to the quality of the well water or the location of sewage disposal works or recharge basins.
7. This decision and approval shall not be held to grant exemption from general restrictions of the use of water for this particular purpose which may at any time be imposed by competent authority.
8. The Commission reserves the right to reconsider this approval on January 1, 1952, or at any later date and after due notice and hearing, at that time to continue, rescind or modify this decision in such manner as may be found to be just and equitable.
9. These works shall be completely constructed prior to January 1, 1950.
10. All water must be diffused into the same aquifer from which it was pumped.

In view of the above, the Water Power and Control Commission determines and decides that approval of this application as above modified will protect the public health and public welfare in conserving the supply of water of Long Island for domestic consumption.

WHEREFORE, the Water Power and Control Commission does hereby approve the said application, maps and plans of John and William Staryk, as thus modified.

IN WITNESS WHEREOF, the Water Power and Control Commission has caused this determination and approval to be signed and has caused its official seal to be affixed hereto and has filed the same with all maps, plans, reports and other papers relating thereto in its office in the city of Albany, this 7th day of January, 1947.

WATER POWER AND CONTROL COMMISSION


W. L. S. S. S.
Deputy Conservation Commissioner-Alternate

G. M. R. S.
Deputy Chief Engineer-Representative

W. L. S. S. S.
Attorney-General

Attest:

P. S. S.
Secretary to the Commission

M. STARYK

FAIRWAY FARMS

HICKSVILLE

NEW YORK

November 15, 1946

Water Power and Control Commission,
90-79 Sutphin Boulevard,
Jamaica, 2, N. Y.

Gentlemen:

I enclose application for approval of the
sinking of a private well on my property at Smith Ave.
and Hicksville Ave., Hicksville, N. Y.

The application consists of:

Petition

Layout and location of well

Undertaking

The hearing can be held at my office at the
address above.

Yours very truly,



STATE OF NEW YORK.
Department of Conservation
WATER POWER AND CONTROL COMMISSION.



In the matter of
The Application of John and William Staryk, for approval of the
sinking of a new well on their property on Hicksville Ave., in
the Town of Oyster Bay, County of Nassau, State of New York.

P E T I T I O N

To the Water Power and Control Commission of the State of New
York:

The Petition of John and William Staryk, respectfully
Shows:

First: John and William Staryk are the owners of a new
milk processing plant located on Hicksville Ave., Town of Oyster
Bay, County of Nassau, State of New York.

Second: Applicants are constructing a new plant at this
location and desire to use well water for operating the necessary
refrigerating units, bottle washers and other machinery pertinent
to this type of business.

Third: It is proposed to sink a well at the point and on
on the accompanying plan. This well is to be of the Cook-Jack
back type, using 8" well casing and is to be approximately 100
deep. An electrically operated deep well turbine pump of 100
gallons per minute capacity is to be installed in the well and is
to be automatically operated on a pressure tank.

Fourth: The applicants desire to use well water, es-
pecially for cooling purposes as well water is much cooler than
city water so that less water will be used.

after use the water will be returned into the ground

-2-

Fifth: Applicants believe that this project can be carried out without injury to other interests, that the proposed works will be safe and suitable and that the quality of the water from the proposed well will be suitable for the purpose for which it is to be employed.

WHEREFORE, Applicants respectfully pray that the Water Power and Control Commission approve of this well project.

Signed:


John Starvo

William Starvo

STATE OF NEW YORK)
) ss.
COUNTY OF NASSAU)

John Staryk being duly sworn, deposes and says
that he is a partner of the new mill processing plant and he
has read the foregoing petition and knows the contents thereof
and the same is true to his own knowledge and belief as to the
matters therein stated to be alleged and he believes and swears
that as to those matters he believes the same to be true.

Signed



Subscribed and sworn

before me this

18th day of September 1946


Notary Public

HARRY A. DROMI, GRD
NOTARY PUBLIC in the State of New York
Residing in Nassau County
Nassau County No. 443
Suffolk County No. 5237
My Commission Expires March 30, 1947

WIDENING

444

121

...and other

27-00000-100

1990

10-10-68

100

... ..

100

100

1999, 2000, 2001, 2002, 2003, 2004, 2005, 2006, 2007, 2008, 2009, 2010, 2011, 2012, 2013, 2014, 2015, 2016, 2017, 2018, 2019, 2020, 2021, 2022, 2023, 2024, 2025, 2026, 2027, 2028, 2029, 2030, 2031, 2032, 2033, 2034, 2035, 2036, 2037, 2038, 2039, 2040, 2041, 2042, 2043, 2044, 2045, 2046, 2047, 2048, 2049, 2050, 2051, 2052, 2053, 2054, 2055, 2056, 2057, 2058, 2059, 2060, 2061, 2062, 2063, 2064, 2065, 2066, 2067, 2068, 2069, 2070, 2071, 2072, 2073, 2074, 2075, 2076, 2077, 2078, 2079, 2080, 2081, 2082, 2083, 2084, 2085, 2086, 2087, 2088, 2089, 2090, 2091, 2092, 2093, 2094, 2095, 2096, 2097, 2098, 2099, 2100, 2101, 2102, 2103, 2104, 2105, 2106, 2107, 2108, 2109, 2110, 2111, 2112, 2113, 2114, 2115, 2116, 2117, 2118, 2119, 2120, 2121, 2122, 2123, 2124, 2125, 2126, 2127, 2128, 2129, 2130, 2131, 2132, 2133, 2134, 2135, 2136, 2137, 2138, 2139, 2140, 2141, 2142, 2143, 2144, 2145, 2146, 2147, 2148, 2149, 2150, 2151, 2152, 2153, 2154, 2155, 2156, 2157, 2158, 2159, 2160, 2161, 2162, 2163, 2164, 2165, 2166, 2167, 2168, 2169, 2170, 2171, 2172, 2173, 2174, 2175, 2176, 2177, 2178, 2179, 2180, 2181, 2182, 2183, 2184, 2185, 2186, 2187, 2188, 2189, 2190, 2191, 2192, 2193, 2194, 2195, 2196, 2197, 2198, 2199, 2200, 2201, 2202, 2203, 2204, 2205, 2206, 2207, 2208, 2209, 2210, 2211, 2212, 2213, 2214, 2215, 2216, 2217, 2218, 2219, 2220, 2221, 2222, 2223, 2224, 2225, 2226, 2227, 2228, 2229, 2230, 2231, 2232, 2233, 2234, 2235, 2236, 2237, 2238, 2239, 2240, 2241, 2242, 2243, 2244, 2245, 2246, 2247, 2248, 2249, 2250, 2251, 2252, 2253, 2254, 2255, 2256, 2257, 2258, 2259, 2260, 2261, 2262, 2263, 2264, 2265, 2266, 2267, 2268, 2269, 2270, 2271, 2272, 2273, 2274, 2275, 2276, 2277, 2278, 2279, 2280, 2281, 2282, 2283, 2284, 2285, 2286, 2287, 2288, 2289, 2290, 2291, 2292, 2293, 2294, 2295, 2296, 2297, 2298, 2299, 2300, 2301, 2302, 2303, 2304, 2305, 2306, 2307, 2308, 2309, 2310, 2311, 2312, 2313, 2314, 2315, 2316, 2317, 2318, 2319, 2320, 2321, 2322, 2323, 2324, 2325, 2326, 2327, 2328, 2329, 2330, 2331, 2332, 2333, 2334, 2335, 2336, 2337, 2338, 2339, 2340, 2341, 2342, 2343, 2344, 2345, 2346, 2347, 2348, 2349, 2350, 2351, 2352, 2353, 2354, 2355, 2356, 2357, 2358, 2359, 2360, 2361, 2362, 2363, 2364, 2365, 2366, 2367, 2368, 2369, 2370, 2371, 2372, 2373, 2374, 2375, 2376, 2377, 2378, 2379, 2380, 2381, 2382, 2383, 2384, 2385, 2386, 2387, 2388, 2389, 2390, 2391, 2392, 2393, 2394, 2395, 2396, 2397, 2398, 2399, 2400, 2401, 2402, 2403, 2404, 2405, 2406, 2407, 2408, 2409, 2410, 2411, 2412, 2413, 2414, 2415, 2416, 2417, 2418, 2419, 2420, 2421, 2422, 2423, 2424, 2425, 2426, 2427, 2428, 2429, 2430, 2431, 2432, 2433, 2434, 2435, 2436, 2437, 2438, 2439, 2440, 2441, 2442, 2443, 2444, 2445, 2446, 2447, 2448, 2449, 2450, 2451, 2452, 2453, 2454, 2455, 2456, 2457, 2458, 2459, 2460, 2461, 2462, 2463, 2464, 2465, 2466, 2467, 2468, 2469, 2470, 2471, 2472, 2473, 2474, 2475, 2476, 2477, 2478, 2479, 2480, 2481, 2482, 2483, 2484, 2485, 2486, 2487, 2488, 2489, 2490, 2491, 2492, 2493, 2494, 2495, 2496, 2497, 2498, 2499, 2500, 2501, 2502, 2503, 2504, 2505, 2506, 2507, 2508, 2509, 2510, 2511, 2512, 2513, 2514, 2515, 2516, 2517, 2518, 2519, 2520, 2521, 2522, 2523, 2524, 2525, 2526, 2527, 2528, 2529, 2530, 2531, 2532, 2533, 2534, 2535, 2536, 2537, 2538, 2539, 2540, 2541, 2542, 2543, 2544, 2545, 2546, 2547, 2548, 2549, 2550, 2551, 2552, 2553, 2554, 2555, 2556, 2557, 2558, 2559, 2560, 2561, 2562, 2563, 2564, 2565, 2566, 2567, 2568, 2569, 2570, 2571, 2572, 2573, 2574, 2575, 2576, 2577, 2578, 2579, 2580, 2581, 2582, 2583, 2584, 2585, 2586, 2587, 2588, 2589, 2590, 2591, 2592, 2593, 2594, 2595, 2596, 2597, 2598, 2599, 2600, 2601, 2602, 2603, 2604, 2605, 2606, 2607, 2608, 2609, 2610, 2611, 2612, 2613, 2614, 2615, 2616, 2617, 2618, 2619, 2620, 2621, 2622, 2623, 2624, 2625, 2626, 2627, 2628, 2629, 2630, 2631, 2632, 2633, 2634, 2635, 2636, 2637, 2638, 2639, 2640, 2641, 2642, 2643, 2644, 2645, 2646, 2647, 2648, 2649, 2650, 2651, 2652, 2653, 2654, 2655, 2656, 2657, 2658, 2659, 2660, 2661, 2662, 2663, 2664, 2665, 2666, 2667, 2668, 2669, 2670, 2671, 2672, 2673, 2674, 2675, 2676, 2677, 2678, 2679, 2680, 26

100

1

THE

100

100

THE

100

100

100

... ..

100

1990

100

[illegible]

100

10

STATE OF NEW YORK—DEPARTMENT OF CONSERVATION
WATER POWER AND CONTROL COMMISSION

PUBLIC NOTICE

A public hearing will be held in the Court House

on November 27, 1946, at 10 A.M. on the application of
JOHN AND WILLIAM STARVEY
made under Section 621-a, Conservation Law, for approval of
well project at Railway Farms, Hicksville Avenue, Hicksville,
Town of Greenvale, Nassau County.

Papers filed may be consulted at Office of Commission
30-29 Sutphin Boulevard, Jamaica 2, New York, N.Y.

Objectors may be heard only on written objections
specifying the grounds thereof, filed in the above office
not later than November 26, 1946.


Jamaica 2, N.Y., N.Y.

November 26, 1946.

Russell Suter
Executive Engineer

110. W. 882

110. W. 882



STATE OF NEW YORK—DEPARTMENT OF CONSERVATION
WATER POWER AND CONTROL COMMISSION

PUBLIC NOTICE

A public hearing will be held in the Court House, Hicksville,
New York,

on November 29, 1946, at 10 A.M. on the application of
JOHN AND WILLIAM STARYK
made under Section 521-a, Conservation Law, for approval of a
well project at Fairway Farms, Hicksville Avenue, Hicksville,
Town of Oyster Bay, Nassau County.

Papers filed may be consulted at Office of Commission,
90-79 Sutphin Boulevard, Jamaica 2, New York, N. Y.

Objectors may be heard only on written objections,
specifying the grounds thereof, filed in the above office
not later than November 28, 1946.

Jamaica, New York, N. Y.

November 20, 1946.

Russell Suter,
Executive Engineer.

~~XXXXXX~~

November 20, 1946

Long Island Well Application No. W-382
John and William Staryk

Mr. John Staryk
Burns Avenue
Hicksville, New York

Dear Sir:

We send you herewith copies of notice of hearing in the above entitled matter. We request you to cause this notice to be published once in the NASSAU DAILY REVIEW-STAR, of Hempstead; such publication should be made as soon as possible after receipt of this order.

Such publication is to be in the general style and form of a legal notice. We will require that proof of this publication, together with a duplicate receipted bill for the same, be produced at the hearing.

In case, for any reason, the above notice cannot be published, or is not published, as herein required, this Commission should immediately be advised of the facts, in order that it may take suitable action in the premises.

Bill for this publication should be made out by the newspaper as a charge against the applicant.

Kindly make the necessary arrangements for the use of the Court House.

Very truly yours,

WATER POWER AND CONTROL COMMISSION,

By


ARTHUR H. JOHNSON,
Associate Engineer.

CE3
Encls.

Copy of notice of hearing sent to: County of Nassau
Hicksville Water District

8/1/1918

Long Island Water Supply
Hicksville, New York

Mr. John G. Smith
Hicksville, New York

Dear Sir:

We are sorry to hear that the above mentioned notice to be published in the Nassau County of Long Island, New York, is not possible at this time.

We are sorry to hear that the above mentioned notice to be published in the Nassau County of Long Island, New York, is not possible at this time.

We are sorry to hear that the above mentioned notice to be published in the Nassau County of Long Island, New York, is not possible at this time.

We are sorry to hear that the above mentioned notice to be published in the Nassau County of Long Island, New York, is not possible at this time.

We are sorry to hear that the above mentioned notice to be published in the Nassau County of Long Island, New York, is not possible at this time.

We are sorry to hear that the above mentioned notice to be published in the Nassau County of Long Island, New York, is not possible at this time.


We are sorry to hear that the above mentioned notice to be published in the Nassau County of Long Island, New York, is not possible at this time.



STATE OF NEW YORK }
COUNTY OF NASSAU } ss.:

Ann E. Hansen of Rockville Centre

Nassau County, N. Y., being duly sworn, says that she is, and at the time of publication of the annexed Notice was the Principal Clerk of the Publisher of the Nassau Daily Review-Star, a newspaper published in the Village of Hempstead, in the Town of Hempstead, County of Nassau and State of New York, and that the Notice of which the annexed is a true printed copy, was published in said newspaper on the 26th day of November, 1946.



Ann E. Hansen

Sworn to before me this 26th

day of November 19 46

Elizabeth Whitaker

Notary Public, #1787

Nassau County, N. Y.

**STATE OF NEW YORK--DEPARTMENT OF CONSERVATION
WATER POWER AND CONTROL COMMISSION**

THIS IS TO CERTIFY that, under the provisions of Section 523 of the Conservation Law, the annexed account of Nassau Daily Review-Star in the amount of \$4.75, is a due and proper charge against ~~the~~ John and William Staryk, it being part of the expense of the hearing and determination by this Commission upon the water supply application of said applicant, which was filed November 19, 1946. The law requires the payment of this account to the person entitled thereto within thirty days of the date of this certificate.

Albany, N. Y.,
December 3 1946

WATER POWER AND CONTROL COMMISSION


Secretary.

110.W.882

Nassau Daily Review-Star

ROCKVILLE CENTRE, N. Y. November 26th, 1946

Mr. John Staryk

Burns Ave.

Hicksville, N.Y.



REVIEW BUILDING, SUNSET HIGHWAY

To Publication, Public Notice, re:

Application of John & William Staryk.

\$4.75

November 26th, 1946.

*Received
per A. Hansen Review
Nassau Daily Star
\$4.75 Paid
November 26/46*

Application No. W-382

Well No. N-2231

STATE OF NEW YORK



DEPARTMENT OF CONSERVATION
DIVISION OF WATER POWER AND CONTROL

APPROVAL OF WELL AND PERMIT TO OPERATE

Owner: John and William Staryk

Address: Hicksville Avenue, Hicksville, N. Y.

Location: Burns & Hicksville Avenues, Hicksville, N. Y. (Fairway Farms)

Depth 129 ft. Diameter casings 8 in. Diameter screen ^{7-3/4} in.

Pump: Elec. deep well turbine of 100 gallons per minute capacity

Water to be used for cooling, washing, drinking and sanitary

Special conditions: Pumping is limited to 100 gallons per minute; water must be returned to the ground through the proposed seepage basin or some other equivalent satisfactory structure; no chemical or polluting substance may be discharged in this water or into diffusion pit; may be revoked after January 1, 1952.

Driller: Fred Habenicht & Son, 335 South Broadway, Hicksville, N. Y.

THIS WELL has been constructed in accordance with provisions of Decision of January 7, 1947, and may be operated subject to the terms of that decision.

Albany, New York

Date September 14 1950

WATER POWER AND CONTROL COMMISSION

By
(L.S.) J. C. Thompson,
Secretary

Post this notice near well

County Nassau App. No. W-8 2 Well No. N-2231

WATER POWER AND CONTROL COMMISSION

Report on Completed Long Island Well

Owner John and William Staryk

Address Hicksville Avenue, Hicksville, New York

Location Burns & Hicksville Avenues, Hicksville, N.Y. (Fairway Farm)

Driller Fred Habenicht & Son Date Completed January 4, 1949

Casings 114 ft. of 8 in.; ft. of in.; ft. of in.

Screen 15 ft. of 7-3/4 in. ^{slot} Cook W.W. #25/ Total depth 129 ft.
below grade

Pump Cook deep well turbine Motor U.S. Elec. 7 1/2 H.P.

Capacity 100 g.p.m. (Nominal - ~~by test~~)

Use of water cooling in refrigeration machinery, washing & sanitary

Other wells on premises (if diffusion, make report thereon) none


Well Driller's preliminary report made 1/11/47 final report 1/5/50


Remarks Inspected by Engineer Saccareccia. Water is pumped into
2,000 gallon pneumatic storage tank. Water used for cooling
refrigeration machinery is discharged into seepage basin. Water
used for washing and sanitary purposes is discharged into septic
tanks and cesspools (3 each). Orifice plate installed on discharge
line. All conditions complied with.

Recommendations Approve and issue operating permit.

Date Inspected August 11, 1950 Date Report August 14, 1950

Approved:


Associate Engineer


Title Associate Engineer

* See over

State of New York Department of Conservation
WATER POWER AND CONTROL COMMISSION

Inspection of Diffusion Installations

Name J. & W. Staryk (Fairway Farms) Supply well No. W-2231
Address Hicksville & Burns Ave. (Hicksville) Diffusion well No. W-882
Application No. W-882


Date of Inspection	5/10/52	5/10/52	11/27/56	7/24/59
Inspector	J. S. Staryk	J. A. S.	W. W.	J. S.
Person contacted	J. Staryk	—	—	J. Staryk
Debris at supply well	—	—	—	—
Debris at diffusion well	—	—	—	—
Test nipple installed	—	—	—	—
Permit posted	—	—	—	In-office
Operating pressure	28" L.S.P.	—	—	—
Supply temperature	52°	—	—	—
Diffusion "	—	—	—	—
Cross connections	—	—	—	—
HP & pump capacity	7 1/2 H.P.	—	—	—
Meters installed	—	—	—	—
Diffuser accessible	Seepage 2.5 ft	—	—	—
1/4" inspection plug & port	Cement Cover	—	—	Well Not in op - getting new
Back pressure	—	—	—	Tank - AS still used however
Diffuser last cleaned	—	—	—	—
Use of water	—	—	—	—
Period of operation	—	—	—	—
Annual pumpage	9.5	—	—	11/11/60 - To be in opr
S.W.L.	—	—	—	—

Remarks: 4/10/52 W. W. Staryk Handwritten 420
W. W. Staryk Handwritten 420

17
 J. E. W. Starik
 Farming Farms

U-231

Blackville, Mo.



1. Estimate of air measurement

2. Cross Connections - 10000

and 10000

3. The following are for the same

4. To 1400000 pneumatic

5. Water for cooling, the same

6. Water for heating, the same

RECHARGE BASIN INSPECTION

Name Mr. W. J. [unclear] Appl. No. 880
 Address 1000 [unclear] Date 6/11/51
Hicksville

Well Data:

Well number N-200
 Depth of well 100
 Formation supplying water N
 Amount of water pumped per year _____
 Number of days pumped per year 56
 Use of water Dairy

Disposal Data:

Size of recharge basin 10' diameter 15' deep
 Number of compartments 200
 Formation receiving discharge 7
 Any storm drainage discharging into basin No
 Any sewage discharging into basin No
 Quality of water discharged into basin Good
 Depth of water now in basin _____
 Probable ground water level _____
 Any silt in basin No
 Any maintenance work Basin constructed about a year
ago. [unclear] former structure
collapsed.

Remarks:

No silt was found in basin when it was
replaced. Consists of [unclear] water

6/11/51
[unclear]

Signature [unclear]

Fairway Farms

W-802

An inspection made 6/11/51 disclosed the following:

This is a dairy & pasteurizing plant located in the N.W. section of Hicksville on Nevada Ave. (changed from Hicksville Ave) and Burns Ave (is also called Cambridge St.). A $7\frac{1}{2}$ HP motor supposedly pumps about 60 gpm. The water after use goes to either

1. Dirty water through cess pools to leaching field.
2. Clean water to covered seepage basin 10' dia. 15' deep. This basin collapsed about a year ago and was replaced. At that time no silt was found in the basin which is in a sandy soil.

H. H. H. H.

MINUTES OF HEARING

LONG ISLAND WELL APPLICATION NO. W-882

JOHN AND WILLIAM STARYK
(Fairway Farms)

Hicksville Avenue, Oyster Bay, Nassau County

Hearing in Court House, Hicksville, New York,

on November 29, 1946 at 10 A.M.

Applicant by John Staryk, Wm. M. M. M.

H. J. Davis, Sanitary Eng. Dept. Health - Nassau Co.
W. F. Weller, Nassau Co.

Objectors:

None

Proof of publication filed:

Nassau Daily Review Star of Hempstead

Location of plant

On N.E. corner of the intersection of Nassau Ave. & Hicksville Ave. Village of Hicksville, Town of Oyster Bay.

Proposed to mine a well - located 85' S. of
Hicksville Ave. & 75' W. of Nassau Ave. Hicksville.
Well - 100' deep 8" casing, & seven Pump Plot
But pump 100 gpm.

Use Casing in refrigerators, washing
cars & bottles, dishwashing & Sanitary. After use
returned to the ground (from casing) through seepage
basin located 100' or more from the well. Sanitary
wastes - cesspool located 119' from the well.

Size plot 320' x 500'

Consumption - 65% used for casing operations.

Pipeline Supply - 45,000 gallons daily, 5.5 million

Hicksville W. District. nearest well 1 1/2 miles.

Water pumped into underground pressure tank 2,000 gallons.
Water - will install.

W. F. Weller

M. JARYK

Telephone Hicksville 8;

FAIRWAY FARMS

HICKSVILLE • NEW YORK

