

ORIGINAL TO COMMISSION

State of New York
Department of Conservation
Division of Water Power and Control
COMPLETION REPORT—LONG ISLAND WELL

Well No. 11-7
(on preliminary report)

LOG

Ground Surf. El.ft. above sea

Top of Well

Owner ...

Address ...

Location of well ...

Depth of well below surface ... 101'-6" ...feet

Depth to ground water from surface ... 01'-0" ...feet

CASINGS:

Diameter ... in.in.in.in.

Length ... 23'-6" ...ft.ft.ft.ft.

Sealing ...

Casings removed ...

SCREENS: Make ... Cook ... Openings ... 25 slot ...

Diameter ... in.in.in.in.

Length ... 8 ...ft.ft.ft.ft.

Depth to top from top of casing ... 23'-6" ...ft.

PUMPING TEST: Date ... June 18, 1957 ... Test or permanent pump? ... Test

Duration of Test ... days ... 2 ... hours

Maximum Discharge ... 75 ... gallons per minute

Static level prior to test ... 61 ...ft. ... 8 ...in. below top of casing

Level during Max. Pumping ...ft.in. below top of casing

Maximum Drawdown ... 10 ...ft.

Approx. time of return to normal level after cessation of pumping ... hours ... minutes

PUMP INSTALLED: PUMP TO BE INSTALLED LATER

Type ... Turbine ... Make Model No. ... 4701 ...

Motive power ... 1/4 H.P. ... Make ... H.P. ... 75 ...

Capacity ... 75 ... g.p.m. against ...ft. of discharge

No. bowls or stages ... 110 ...ft. of total

DRIVE LINE:

Diameter ... in.in.

Length ...ft.ft.

Use of water ... Air Conditioning & Cooling ...

Work started ... June 12, 1957 ... Complete ... June 15, 1957 ...

Date ... June 21, 1957 ... Driller ... Kathleen Hall & Pump Co., Inc.


License No. ... 153 ...

NOTE: Show log of well—materials encountered, with depth below ground surface, water bearing beds and water levels in each, casings, screens, pump, additional pumping tests and other matters of interest. Describe repair job. See Instructions as to Well Drillers' Licenses and Reports—pp. 3-7.

11'	Sand & gravel
55'	Coarse brown sand & coarse gravel
64'	Brown sand & grits
67'	Coarse brown sand & small gravel
101'	Brown sand-grits-small gravel - 8"

STATE OF NEW YORK
WATER POWER AND
COMMISSION
JUN 24 1957
COR. 21 COMMISSION
RECEIVED

WELL LOCATION



Locate well with respect to at least two streets or roads, showing distance from corner and front of lot.
Show North Point