

County Name

ORIGINAL TO COMMISSION

Well No. N 8601
for preliminary report

State of New York
Department of Conservation
Division of Water Resources

LOG
Ground Surf. El.ft. above sea

COMPLETION REPORT--LONG ISLAND WELL

^
.....ft.
v
Top of Well

Owner Holy Road Cemetery

Address Old Country Road, Westbury

Location of well Same

Depth of well below surface 340'-2" feet

Depth to ground water from surface 43'-6" feet

CASINGS:

Diameter 8 in. 4 in. in. in.

Length 237 ft 187-319 ft. ft. ft.

Sealing

Casings removed

SCREENS: Make Johnson S.S. Top 10'-16 slot
Openings bottom 10'-20 slot

Diameter 4 in. in. in. in.

Length 20 ft. ft. ft. ft.

Depth to top from top of casing 319 ft.

PUMPING TEST Date 11-14-69 Test or permanent pump? T

Duration of Test days 8 hours

Maximum Discharge 229 gallons per minute

Static level prior to test 43 ft. 2 in. below top of casing

Level during Max. Pumping 59 ft. in. below top of casing

Maximum Drawdown 16 ft.

Approx. time of return to normal level after cessation
of pumping hours minutes

PUMP INSTALLED:

Type Sub. Make Gould Model No. UG66MM-32

Motive power Elec. Make H.P. 15

Capacity 150 g.p.m. against 210 ft. of discharge head

No. bowls or stages 270 ft. of total head

DROP LINE:

Diameter 3 in. in.

Length 80 ft. ft.

SECTION LINE:

Method of Drilling (Rotary, cable tool, etc.) Cable Tool

Use of Water Irrigation

Work started 10-1-69 Completed 11-14-69

Date 5-7-70 Driller THE LAUMAN CO., INC.


License No. 23

NOTE: Show log of well--materials encountered, with depth below ground surface,
water bearing beds and water levels in each, casings, screens, pump, addi-
tional pumping tests and other matters of interest. Describe repair job.

See Instructions as to Well Drillers' Licenses and Reports pp. 5-7.

MAY 15 1970

SKETCH OF LOCATION



Locate well with respect to at least two streets or lots, showing distance from corner and front of lot

Show North Point

- 0-52 Sd & Gravel
- 52-68 Brn cl
- 68-173 F. brn clayey sd
- 173-203 " " " "
- 203-208 Brn & blk cl
- 208-230 Tan sd & cl
- 230-239 F. brn clayey sd
- 239-280 Tan clayey sd
- 280-284 F. " " "
- 284-277 Clayey fi sd
- 277-309 F. Tan sd
- 309-236 F. & Gse brn sd
- 336-340 F. sd, few grts

W-2697

Z

6:17.69	
6:11.89	
7:8.69	
7:35.69	
8:11.69	
8:11.69	
5:13.70	
7:6.71	
7:28.71	
7:30.71	

History

Approved

1988-1989

10728

22

4-360 7:30:71

STATE OF NEW YORK
CONSERVATION DEPARTMENT



WATER RESOURCES COMMISSION

Long Island Well Application No. W-2697

THE ROMAN CATHOLIC DIOCESE
OF ROCKVILLE CENTRE, NEW YORK

D E C I S I O N

OFFICIAL RECORD

TO REMAIN IN THE CUSTODY OF THE WATER RESOURCES COMMISSION

State of New York
Conservation Department
WATER RESOURCES COMMISSION

Long Island Well Application No. W-2697

In the Matter of the Application

- of -

THE ROMAN CATHOLIC DIOCESE
OF ROCKVILLE CENTRE, NEW YORK,

for the approval of the sinking of
a well at the CEMETERY OF THE HOLY
ROOD at OLD COUNTRY ROAD AND POST
AVENUE, Westbury, Town of North
Hempstead, Nassau County, New York.

D E C I S I O N

Application filed	June 11, 1969
Hearing held at Westbury,	July 8, 1969
Decision	July 25, 1969

DECISION ON LONG ISLAND WELL APPLICATION NO. W-2697

PROCEEDINGS

This is an application made under the provisions of Section 476 of the Conservation Law for approval of a well project in Suffolk County.

Petition verified by the Very Reverend Monsignor Thomas R. Daly, Secretary-Treasurer of the Roman Catholic Diocese of Rockville Centre, on behalf of the Cemetery of the Holy Rood, on May 29, 1969 and filed in the office of the Water Resources Commission on June 11, 1969. Due notice of the hearing was given by publication in the Westbury Times and the hearing was held before Walter G. Waterman, Associate Engineer of the Commission, in the office of the Commission in Westbury on July 8, 1969 at 10 o'clock in the forenoon. The petitioner was represented at the hearing by Robert E. Scholly, Esq., its attorney. No objections were filed and no one appeared at the hearing in opposition to approval of the project.

PROJECT

Applicant proposes, at its Cemetery of the Holy Rood in Westbury, Nassau County, to sink a new well with an 8-inch diameter casing to a depth of 150 feet and to equip it with a pump having a capacity of 150 gallons a minute. All water pumped from the proposed well will be used for irrigation purposes only.

FINDINGS OF FACT

1. The Roman Catholic Diocese of Rockville Centre is a domestic religious corporation and is engaged, among other activities, in the operation and maintenance of a 67-acre cemetery known as The Cemetery of the Holy Rood, located on the north side of Old Country Road, between Post Avenue and School Street, in Westbury, Nassau County. The principal office of the applicant is at 50 North Park Avenue, Rockville Centre, New York.

2. There have been no prior applications concerning this cemetery.

3. It is now proposed to sink a well at the cemetery to secure water for irrigation purposes only. The proposed well

is to be located about 800 feet north of Old Country Road and 160 feet west of School Street. The well is to have an 8-inch diameter casing sunk to a depth of 150 feet and is to be equipped with an electrically operated submersible type pump having a capacity of 150 gallons a minute.

4. It is estimated that there will be an intermittent use of water for a period not to exceed 200 days in a year at a rate not to exceed 70,000 gallons of water a day or 15 million gallons per year.

5. Water from this proposed well will be used solely for irrigation purposes. Water for all other purposes (including drinking and sanitary uses) will be obtained, as at present, from the public supply mains of the Westbury Water District.

6. The nearest public water supply well to the location of the proposed well, is Well No. N-2602, owned by the Westbury Water District and located 1,600 feet east of the proposed well.

7. Because of the relatively small capacity of the proposed well and its intermittent use, it appears that approving the above application will have no material effect on the groundwater levels of Long Island.

CONDITIONS

The Commission finds it to be necessary to protect the interests of the applicant and of the people of the State to impose the following conditions:

- A. Applicant shall install, maintain and operate a meter or other measuring device to measure and record the amount of water pumped from the proposed well and shall preserve the records obtained. Such measuring device and the entire plant and apparatus connected therewith shall be open at all reasonable hours to inspection or test by duly accredited representatives of this Commission. Applicant shall report monthly to this Commission the amount of water pumped from the proposed well.
- B. Upon completion of the proposed well and before a permit to operate will be issued,

applicant shall submit to the Commission the results of an analysis made from a sample of water taken from this well, as prescribed by the Commission.

- C. This decision and approval shall not be held to grant any exemption from general restrictions on the use of water for this particular purpose which at any time may be imposed by other competent authority.
- D. The Commission reserves the right to reconsider this approval at any time and, after due notice and hearing, at that time to continue, rescind or modify this decision in such a manner as may be found to be just and equitable.
- E. Unless this new well shall have been completely constructed by August 1, 1972, or within such extended time as may have been applied for and granted by the Commission, then and on that date this approval shall be deemed to have lapsed.

STATUTORY DETERMINATION

In view of the above, the Water Resources Commission, under the provisions of Section 476 of the Conservation Law, determines and decides that approval of this application as above modified will protect the public health and public welfare in conserving the supply of water of Long Island for domestic consumption.

- 4 -

DECISION

WHEREFORE, the Water Resources Commission does hereby approve the said application, maps and plans of THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW YORK, as thus modified.

IN WITNESS WHEREOF, the Water Resources Commission has caused this determination and approval to be signed and has caused its official seal to be affixed hereto and has filed the same with all maps, plans, reports and other papers relating thereto in its Westbury office this 25th day of July, 1969.

WATER RESOURCES COMMISSION



W. M. Lawrence

Deputy Commissioner, Conservation
Department, Alternate -
Acting Chairman

Attest:

Robert S. Drew

Secretary

7/28/69

Applicant
Hersaw County
Hickory

6-1697
77 13 2697

The Chancery
Diocese of Rockville Centre
50 North Park Avenue
Rockville Centre, New York 11570



June 9, 1969

RECEIVED
JUN 11 1969
COMMISSIONER

Water Resources Commission
373 Maple Avenue
Westbury, New York 11590

Re: Roman Catholic Diocese of
Rockville Centre

Gentlemen:

North Enclosed is an application for the approval
of the construction of a well at the Cemetery of the
Holy Rood, Old Country Road and Post Avenue, Westbury,
Town of Hempstead, Nassau County, New York.

The application consists of -
Petition
Undertaking
Plot Plan

The area is open to you for inspection at your
convenience.

It will be agreeable to us to have the hearing
at the Commission Office.

Please direct all correspondence to The Lauman
Company, Inc., 100 Lauman Lane, Bethpage, New York 11714.

Very truly yours,

ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE

By: Thomas R. Daly
Thomas R. Daly, Sec'y - Treas.

TRD/rr
Encs.

c.c. Rev. Joseph P. Minturn

STATE OF NEW YORK
Department of Conservation
WATER RESOURCES COMMISSION



In the Matter of
The Application of THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE,
NEW YORK, for the approval of the sinking of a well at the CEMETERY
OF THE HOLY ROOD at OLD COUNTRY ROAD AND POST AVENUE, Westbury,
Town of ^{Herth} Hempstead, Nassau County, New York.

P E T I T I O N

To the WATER RESOURCES COMMISSION of the State of New York:

The petition of THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE,
NEW YORK, respectfully shows:

FIRST: THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW
YORK, is a religious corporation, with main offices located at 50
North Park Avenue, Rockville Centre, New York. The Diocese owns
and operates the Cemetery of the Holy Rood in Westbury, Town of
Hempstead, Nassau County, New York.

SECOND: Applicant desires to install a new water service for
lawn plot irrigation at the Cemetery at which the well is sought to
be installed. Well water is to be used exclusively for irrigation.

THIRD: Applicant proposes to install a well at the location
as indicated on the attached plot plan. Well is to be constructed
with gravel filter wall surrounding the screen, either by artificially

introducing gravel or by development of natural formation. The permanent well casing will be not less than 8-inch diameter extended to an estimated depth of 150 feet below grade level.

It is proposed to install an electrically operated submersible deep well pump on this well with rated capacity of 150 gallons of water per minute.

FOURTH: It is estimated that this plant will be in intermittent operation approximately 200 days during any one year. The requirements are estimated not to exceed 70,000 gallons of water during any one day and 15 million gallons per annum.

FIFTH: There are no known wells on the property at this time.

SIXTH: All the water pumped from the proposed well will be used for irrigation purposes only. Water for all other purposes will be purchased from the public supplier, Westbury Water District, as heretofore.

All pumped water except that lost by evapo-transpiration will be returned to the ground water reservoir.

SEVENTH: The total property area in the Cemetery of the Holy Rood is approximately 67 acres. Approximately 50% of this area will be irrigated. At normal annual rainfall on the open area, the infiltration of precipitation in this Cemetery contributes more than double the amount of water to the ground water reservoir that will be pumped for irrigation purposes.

EIGHTH: Investigation of the ground water conditions at this location indicate that the static water table is approximately 65 feet above sea level. This indicates an abundance of ground water in this general area. Based upon information received from competent authorities applicant verily believes that the static ground water table is uniform with only slight seasonal fluctuations during the past few years.

NINTH: The closest public water supply wells are as follows:

Well No. N-5654 Westbury Water District 3000' N/E

Well No. N-2607 Westbury Water District 1600' E

TENTH: The applicant has found it to be an economical necessity to install its own well for irrigation purposes. To deny applicant the right to use ground water would cause applicant considerable financial damage.

ELEVENTH: That I, Very Reverend Monsignor Thomas R. Daly, certify that I am an officer, namely, Secretary-Treasurer of the applicant and I am duly authorized to make this application.

The applicant is of the firm belief this project can be carried out without injury to other interests.

WHEREFORE applicant respectfully prays that the Water Resources Commission grant approval of this well project.

ATTEST:

THE ROMAN CATHOLIC DIOCESE OF
ROCKVILLE CENTRE, NEW YORK

By

Thomas R. Daly
Secretary-Treasurer

-3-

Timothy J. Balducci

Vice-President

STATE OF NEW YORK)
) SS:
COUNTY OF NASSAU)

VERY REVEREND MONSIGNOR THOMAS M. DALY, being duly sworn,
deposes and says that he is the Secretary-Treasurer of the pe-
titioner corporation herein; that he has read the foregoing
petition and knows the contents thereof and the same is true
to his own knowledge except as to the matters therein stated
on information and belief and that as to those matters he
believes the petition to be true. Deponent further states
that this verification is made by him because the petitioner
is a religious corporation and deponent is an officer thereof,
to wit, its Secretary-Treasurer.

Thomas M. Daly

Sworn to before me this

21st day of May, 1969.

Robert E. Scholl
ROBERT E. SCHOLL
NOTARY PUBLIC, State of New York
No. 10-0843103
Qualified in Nassau County
Term Expires March 30, 1970

STATE OF NEW YORK -- WATER RESOURCES COMMISSION

UNDERTAKING

WHEREAS, THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW YORK, has, under the provision of Article XI of the Conservation Law, applied to the Water Resources Commission of the State of New York, for approval of a water supply well in the County of Nassau, State of New York.

WHEREAS, an undertaking is required to be given under Section 523 of the Conservation Law to cover the expenses of the hearing and determination by said Commission on said application and the amount of said undertaking has been fixed by said Commission in the sum of One Hundred (\$100.00) Dollars.

NOW, THEREFORE, the said THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW YORK is held and firmly bound unto the People of the State of New York, in the penal sum of One Hundred (\$100.00) Dollars lawful money of the United States of America, to be paid to the said People of the State of New York, their attorney or assigns for which payment well and truly to be made said Diocese binds itself and its successors.

NOW, the conaction of this obligation, is such that if the said THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW YORK, shall honestly and faithfully pay on demand by said Commission all expenses of the hearing and determination on said application, as provided by law, then this obligation shall be void and of no effect, otherwise to remain in full force and virtue.

ATTEST:

(SEAL)

IN WITNESS WHEREOF, the said THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW YORK, has hereunto set its hand and affixed its seal this 27th day of June, 1969.

THE ROMAN CATHOLIC DIOCESE OF
ROCKVILLE CENTRE, NEW YORK,

BY

Thomas R. Daly
Secretary-Treasurer

Thomas R. Daly
Thomas R. Daly (Individual)

Vincent J. Gallo


Vice-President




STATE OF NEW YORK)
) SS.:
COUNTY OF NASSAU)




On this 29th day of ~~June~~ ^{May}, 1969, before me personally came VERY REVEREND MONSIGNOR THOMAS R. DALY, to me known, who being by me duly sworn, did depose and say that he resides at No. 2399 Fendroy Street, East Meadow, New York; that he is the Secretary-Treasurer of THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW YORK, the corporation described in and which executed the foregoing instrument; that he knows the seal of said corporation; that the seal affixed to said instrument is such corporate seal; that it was so affixed by order of the Board of Trustees of said corporation and that he signed his name thereto by like order.


ROBERT E. SCHOLLY
NOTARY PUBLIC, State of New York
No. 32 0840303
Qualified in Nassau County
Term Expires March 30, 1970


STATE OF NEW YORK)
) ss:
COUNTY OF Nassau)



VERY REVEREND MONSIGNOR THOMAS R. DALY, being duly sworn,
says that he is the Secretary-Treasurer of THE ROMAN CATHOLIC
DIOCESE OF ROCKVILLE CENTRE, NEW YORK, and the surety named in the
foregoing undertaking, and being duly sworn says that he is a
resident and freeholder within the State of New York, and is
worth the sum of One Hundred (\$100.00) Dollars, over and above
all debts and liabilities which he owes or has incurred, and
exclusive of property except by law from levy and sale under an
execution.


THOMAS R. DALY

Subscribed and sworn to
before me this 9th day
of June, 1969.


Notary Public

CYRIL F. SMITH
NOTARY PUBLIC, State of New York
No. 30-3718200
Qualified in Nassau County
Commission Expires March 30, 1971




The LAUMAN COMPANY

INCORPORATED

100 LAUMAN LANE • BETHPAGE, L.I., NEW YORK 11714
510 WELLS 1-2305 • BRENTWOOD 3-2424 • N.Y.C. 212 445-7600

June 12, 1969



Water Resources Commission
373 Maple Avenue
Westbury, New York 11590

Attn: Mr. Walter G. Waterman


Re: L. I. Well Appl. #W-2697
The Roman Catholic Diocese of
Rockville Centre
The Cenetery of the Holy Rood
Westbury, New York

Gentlemen:

This is to advise that the required
arrangements for the hearing are being made.

Very truly yours,

THE LAUMAN COMPANY, INC.



F. J. Bensin

FJB:hd

July 28, 1969

Long Island Well Application No. W-2697
The Roman Catholic Diocese of Rockville Centre
(The Cemetery of the Holy Rood)

Reverend Thomas R. Daly
The Chancery
Diocese of Rockville Centre
50 North Park Avenue
Rockville Centre, New York 11570

Dear Sir:

We are serving you herewith one certified copy of the decision of the Water Resources Commission in the above entitled matter. This application was approved by the Commission on July 25, 1969.

Permit to Operate finished well must be obtained before well legally may be used.

Your attention is called to Condition "B" in the above decision, which requires the submission of an initial analysis of the water from the proposed well. This analysis must be made by an approved laboratory and include the following determinations:

Physical and Chemical

Color	Turbidity	Temperature (water at well)
Odor	Manganese	Specific conductivity
pH	Nitrate	Anionic Detergents
Iron	Chloride	

A copy of the results of these determinations must be filed with this office before the Operating Permit can be issued.

Very truly yours

WATER RESOURCES COMMISSION

By

WALTER G. WATERMAN
Associate Engineer

WCW:sm
Enclosure

The Chancery
Diocese of Rockville Centre
50 North Park Avenue
Rockville Centre, New York 11570

STATE OF NEW YORK
WATER RESOURCES

JUL 31 1969

COMMISSION
RECEIVED

July 30, 1969

Mr. Walter G. Waterman, Associate Engineer
State of New York Water Resources Commission
373 Maple Avenue
Westbury, New York 11590

Dear Mr. Waterman:

This is to acknowledge receipt of the decision pertaining to Application No. W-2697 Holy Rood Cemetery, property of the Roman Catholic Diocese of Rockville Centre. I appreciate your assistance in this matter and wish to assure you that the Diocese will cooperate in every way possible in following the instructions and conditions of the said application.

Thanking you again, I am

Very truly yours,



Very Rev. Msgr. Thomas R. Daly
Chancellor

TRD:rh




The LAUMAN COMPANY
INCORPORATED

100 LAUMAN LANE • BETHPAGE, L.I., NEW YORK 11714
516 WELLS 1-2305 • BRENTWOOD 3-2424 • N.Y.C. 212 445-7600

July 16, 1971

Department of Environmental Conservation
373 Maple Avenue
Westbury, New York 11590



Re: HOLY ROOD CEMETERY
N-8601

Gentlemen:

Our original permit for drilling this well anticipated a depth of 150 feet.

During the drilling operations we found that there were no suitable water bearing formations capable of yielding the desired capacity. The well was therefore continued to a depth of some 340 feet, at which point a suitable aquifer was located and the well completed at that depth.

Very truly yours,

THE LAUMAN COMPANY, INC.


A. Kreitman

AK:gm

DIVISION OF RESOURCE MANAGEMENT SERVICES
BUREAU OF WATER REGULATION
373 Maple Avenue, Westbury, New York 11590

July 20, 1971

Long Island Well Application No. W-2697
The Roman Catholic Diocese of Rockville Centre, New York
(The Cemetery of the Holy Rood)

Reverend Thomas R. Daly
The Chancery
Diocese of Rockville Centre
50 North Park Avenue
Rockville Centre, New York 11570

Dear Sir:

We are sending you herewith formal approval of Well No. N-8601 and Permit to Operate the same, issued by the Department of Environmental Conservation on July 20, 1971.

Please note that this Operating Permit must be posted on the premises near the well.

As required in the decision an installed meter must be maintained and pagepage reported monthly to this Department.

In order to standardize the figures submitted, will you kindly make the monthly reports in the following form:

Well No. N-8601

Meter reading on (Date of last reading) (reading) Gallons or Cu. Ft.

Meter reading on (Date of previous reading) (reading) Gallons or Cu. Ft.

Total consumption _____ Gallons


Very truly yours

R. A. COOK
Director

By: Walter G. Waterman
Supervisor, Long Island Operations

WGW:sm
CC and Operating Permit to:
Mr. Neal S. Barlin
Cemetery of the Holy Rood
Old Country Road and Post Avenue
Westbury, New York 11590

STATE OF NEW YORK - DEPARTMENT OF CONSERVATION
WATER RESOURCES COMMISSION



PUBLIC NOTICE

A public hearing will be held in the office of the Commission, 373 Maple Avenue, Westbury, on July 8, 1969, at 10 A. M. on the application of

THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW YORK, made under Section 476 of the Conservation Law, for approval of ~~construction of~~ the construction of one well at the Cemetery of the Holy Rood located on the west side of School Street, north of Old Country Road in the Village of Westbury, Nassau County. The proposed well is to have an 8-inch diameter casing sunk to a depth of about 150 feet and is to be equipped with a pump of 150 gallons a minute capacity. Water pumped from this well is to be used only for sprinkling purposes on the property.

Papers filed may be consulted at Office of Commission, 373 Maple Avenue, Westbury, New York.

Objectors may be heard only on written objections, specifying the grounds thereof, filed in the above office not later than July 7, 1969.

Westbury, New York

June 11, 1969

ROBERT S. DREW
~~Robert S. Drew~~
Secretary to the Commission

Notice of Hearing sent to:

NYS Dept. of Health
Nassau County Dept. of Health
Nassau County Dept. of Public Works
A. M. Sarr, District Engineer
R. M. Stelle, Melville
Westbury Water District

June 11, 1969

Long Island Well Application No. W-2697
The Roman Catholic Diocese of Rockville
Centre, New York
(The Cemetery of the Holy Rood,

Notice of Publication to:

The Lauman Company
Bethpage, New York

Reverend Thomas R. Daly
The Chancery
Diocese of Rockville Centre
50 North Park Avenue
Rockville Centre, New York 11570

Dear Sir:

In connection with the above project it will be necessary for you to publish the enclosed legal notice of the hearing in the June 19, 1969 issue of THE WESTBURY TIMES.

You are directed to notify this office by June 19th that you are making arrangements to:

1. Have present at the hearing either the applicant, an officer of the concern or a representative with a notarized power of attorney.
2. Present to the Commission's representative at the hearing an affidavit of publication from the newspaper.
3. Present to the Commission's representative at the hearing a receipted bill from the newspaper covering the cost of publication.

Very truly yours,

WATER RESOURCES COMMISSION
By

WALTER G. WATERMAN
Associate Engineer

JAS:kb
Enclosures

THE WESTBURY TIMES	SERVING THE HEART OF NASSAU COUNTY
	ESTABLISHED 1907.

MEMBER
Audit Bureau of Circulations
New York Press Association
Inter-American Press Association
Nassau County Press Association
AFFILIATE MEMBER
National Editorial Association

Published Every Thursday at 57 Old Country Rd., Westbury, N. Y. 11590 • EDgewood 4-3362

To: The Lauman Company Inc.
100 Lauman Lane
Bethpage, N. Y. 11704

Invoice **24954**


Date June 19, 1969

ORIGINAL

LOCAL ADVERTISING AGENCY: Catholic Diocese of
Rockville Centre

(10) June 19 11:00 AM '69 12

12.90



Enclosures - 100

1 7/20/69

THE WESTBURY TIMES

AFFIDAVIT OF PUBLICATION

STATE OF NEW YORK
DEPARTMENT OF
CONSERVATION
WATER RESOURCES
COMMISSION
PUBLIC NOTICE

A public hearing will be held in the office of the Commission, 371 Maple Avenue, Westbury, on June 8, 1969, at 10 A.M. on the application of THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW YORK, made under Section 476 of the Conservation Law, for approval of the construction of one well at the Cemetery of the Holy Rood located on the west side of School Street, north of Old Country Road in the Village of Westbury, Nassau County. The proposed well is to have an 8-inch diameter casing sunk to a depth of about 150 feet and is to be equipped with a pump of 150 gallons a minute capacity. Water pumped from this well is to be used only for sprinkling purposes on the property.

Papers filed may be consulted at Office of Commission, 371 Maple Avenue, Westbury, New York.

Objectors may be heard only on written objections, specifying the grounds thereof, filed in the above office not later than July 7, 1969.

ROBERT S. DREW
Secretary
to the Commission

Westbury, New York
June 11, 1969
619-14293-1X

110W-2697



State of New York } ss.:
County of Nassau }

Martin S. Weiss being duly sworn, doth depose and say that he is Publisher of a newspaper called THE WESTBURY TIMES, published weekly in the Village of Westbury, in the County of Nassau, that a Notice

Public Notice

of which the annexed is a true copy, has been regularly published in the said newspaper for 1X consecutive weeks, as follows:

June 19, 1969

Martin S. Weiss

Sworn to before me this 19th

day of June 1969

Patricia C. Volpicella

Notary Public, Nassau County, N. Y.

PATRICIA C. VOLPICELLA
Notary Public, State of New York
No. 50-9186575
Qualified in Nassau County
Term Expires March 30, 1970

THE WESTBURY TIMES WESTBURY, LONG ISLAND

LAUMAN LABORATORIES, INC.

100 LAUMAN LANE • BETHPAGE, N. Y. 11714 • (516) 931-2305



REPORT OF CHEMICAL ANALYSES

ENVIRONMENTAL
ANALYSIS

DATE June 3, 1971

TO _____

SOURCE OF SAMPLE

Holy Road Cemetery

Westbury, N. Y.

COLLECTED 5/24/71

RECEIVED 5/24/71

REPORTED 6/3/71

SAMPLING POINT


TIME

1. Pump discharge

2. _____

3. _____

4. _____



		1	2	3	4
TURBIDITY	UNITS	2			
HYDROGEN ION CONCENTRATION	pH	6.3			
FREE CARBON DIOXIDE, AS CO ₂	mg/l				
ALKALINITY P, AS CaCO ₃	mg/l				
TOTAL ALKALINITY, AS CaCO ₃	mg/l				
HARDNESS, TOTAL AS CaCO ₃	mg/l				
CHLORIDES, AS Cl	mg/l	12.0			
IRON, AS Fe	mg/l	0.28			
MANGANESE, AS Mn	mg/l	*0.05			
AMMONIA, FREE, AS N	mg/l				
NITRATES, AS N	mg/l	3.3			
SYNTHETIC DETERGENTS, AS MBAS	mg/l				
Color		*5			
Odor		0			
Specific Conductivity	micromhos	50			

REMARKS All values within U. S. P. H. S. standards for potable water.
* less than

LAB. NO. C-9413

LAUMAN LABORATORIES, INC.

COLLECTED BY The Lauman Company

ANALYZED BY TT

Balderson
DIRECTOR

1000-10

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION
PERMIT TO OPERATE AN APPROVED WELL SYSTEM



W-2697
 Application No.

W-8601
 Well No.

OWNER

The Roman Catholic Diocese of Rockville Centre, New York

ADDRESS

50 North Park Avenue, Rockville Centre, New York 11570

LOCATION

Cemetery of the Holy Rood, Westbury, Nassau County

DEPTH

340

Feet

DIAMETER CASINGS

8 & 4

Inches

DIAMETER SCREEN

4

Inches

PUMP

Electric submersible

OF

150

Gallons per minute capacity

WATER TO BE USED FOR

sprinkling purposes only

SPECIAL CONDITIONS

Installed meter must be maintained and pumpage reported monthly to this Department. The total amount of water pumped shall not exceed 15 million gallons in any one year.

DRILLER

The Lauman Company, Inc., Bethpage, New York

All construction has been completed in accordance with the provisions of Decision(s) **July 25, 1969** and the system may be operated subject to the terms thereof.

July 20, 1971

Date

Department of Environmental Conservation
 Albany, New York

POST THIS NOTICE NEAR WELL

S 7/20/71

County Nassau

Appl. No. W-2697

Well No. N-8601

DEPARTMENT OF ENVIRONMENTAL CONSERVATION

Report on Completed Long Island Well

Owner The Roman Catholic Diocese of Rockville Centre, New York

Address 50 North Park Avenue, Rockville Centre, New York 11570

Location Cemetery of the Holy Rood, Westbury, Nassau County

Driller The Lauman Company, Inc. Date Completed 11/4/69

Casings 237 ft. of 8 in.; 132 ft. of 4 in.; ft. of in.

Screen 20 ft. of 4 in. 20 slots ^{Johnson Nos. 16 &} Total depth 340 ft.
(below grade)

Pump Gould submersible Motor Electric 15 Hp

Capacity 150 g.p.m. (Nominal - by-test)

Use of water sprinkling purposes

Other wells on premises None

Well Driller's preliminary report made 8/11/69 final report 5/13/70

Remarks Inspected by Engineer Saccar. Well has been put down into the Mid-Magothy zone because upper Magothy at the 150 foot level would not yield the required capacity. (See letter of 7/15/71 from the Lauman Company, Inc.)

All other work completed as authorized.

Recommendations Approve and issue Operating Permit.

Date Inspected 7/6/71 Date Report 7/20/71

W. H. Korman
Associate Engineer

State of New York Department of Conservation
WATER RESOURCES COMMISSION

Inspection of Wells over 45 gpm without diffusion

Name P. C. Dir. of Rock Ctr. Well No. N-8601
Address 46 Bay Road, Connetquot Appl. No. W-2697

Neis Harbor 624,670 gal - 100

Date of inspection	7/6/71				
Inspector	JS	Mr. Berber			
Person contacted					
Status	Under Act				
Type & size of pump					
Capacity					
Period of operation	Season				
Operating pressures					
Diam. discharge line	4"				
Flow meas. fittings	✓				
Use of water	Sprinkler				
Est. annual pumpage	Report				
Temperature					
No. of wells	1				
Meters installed -	0766870 gal				
S.W.L.					
Analysis Recd.	OK				

Remarks OP

MINUTES OF HEARING
Long Island Well Application No. W- 2697
THE ROMAN CATHOLIC DIOCESE OF ROCKVILLE CENTRE, NEW YORK

Place Office of the Commission, Westbury

Date July 8, 1969

Time 10 A.M.

Applicant represented by Robert E. Schelly Esq its attorney

Objectors None

Appearances Richard Kauman, Kauman Co (well drillers)
Rev Joseph P. Mirtura Director of
Cemeteries

Proof of publication in The Westbury Times

Location of property Cemetery N of Old Country Road
between Post Road and School Street in Westbury

Remarks:-

Kauman
Well water is planned for irrigation
purposes, water for all other purposes is
supplied from the Westbury Water District.
Well is to be located 500' N of Old
Country Road & 140' West of School Street.
Well is to have an 8" diameter casing
run to a depth of 150' and is to be
equipped with a submersible pump
having a capacity of 150 gpm. Pumping
season is estimated to be about 200
days and daily use of water when
required will not exceed 70,000 gpd
and the annual use will not exceed
15 m.g. The property totals about
67 acres of which about 1/2 will

he ingated.

STATE OF NEW YORK
WATER COMMISSION
JUL 10 1969
DEPT. OF ENVIRONMENTAL CONSERVATION


*Admitted
H. Matman.*

9/11/69

N 8602

Sutter Homestead Works

84' deep, 2"



installed August 1, 1969

water is in natural well
in water /.

Ellis T. [signature]
U.S.G.S.