



December 5, 2007

Mr. Peter Witkowski
COUNTY OF NASSAU DEPARTMENT OF PUBLIC WORKS
CEDAR CREEK WATER POLLUTION CONTROL PLANT
3340 Merrick Road
Wantagh, NY 11793

Re: **Sanitary Wastewater**
299 Main Street - Westbury, NY 11590

Dear Mr. Witkowski:

The above-referenced premises was recently connected to the Nassau County sewer system. Attached are the sample results for the standing wastewater within the sanitary leaching pool. The sample was collected in the presence of Wayne Kempinski of the Nassau County Department of Health.

At this time we request that you review the sample results for approval to be accepted at the County's Cedar Creek Water Pollution Control Plant. We estimate the volume of liquid to be on the order of 1,500 gallons.

If you have any questions or need additional information, please do not hesitate to call our Office.

Sincerely,

CARICH CONSULTANTS, INC.

Steve Sobstyl
Project Manager

Enclosure

cc: John Lovejoy, NCDH
Joe Jones, NYSDEC
Sam Padilla
Alex Holuka
Larry Schnapf, Esq.

ECOTEST LABORATORIES, INC.

ENVIRONMENTAL TESTING

377 SHEFFIELD AVE. • N. BABYLON, N.Y. 11703 • (631) 422-5777 • FAX (631) 422-5770

Email: ecotestlab@aol.com Website: www.ecotestlabs.com

LAB NO.274893.04

11/21/07

C.A. Rich Consultants, Incorporated
17 Dupont Street
Plainview, NY 11803

ATTN: Steve Sobstyl

PO#:

SOURCE OF SAMPLE: 299 Main Street-19 Liberty LDT, #299 Main Street

SOURCE OF SAMPLE:

COLLECTED BY: Client

DATE COL'D:11/08/07 RECEIVED:11/08/07

TIME COL'D:1025

MATRIX:Water

SAMPLE: CP-01(L)


ANALYTICAL PARAMETERS	UNITS	RESULT	FLAG	DATE OF ANALYSIS	LRL	ANALYTICAL METHOD
Vinyl Chloride	ug/L	< 5		11/15/07	5	EPA8260
Trichlorofluoromethane	ug/L	< 5		11/15/07	5	EPA8260
1,1 Dichloroethene	ug/L	< 5		11/15/07	5	EPA8260
Methylene Chloride	ug/L	< 5		11/15/07	5	EPA8260
t-1,2-Dichloroethene	ug/L	< 5		11/15/07	5	EPA8260
1,1 Dichloroethane	ug/L	< 5		11/15/07	5	EPA8260
2,2-Dichloropropane	ug/L	< 5		11/15/07	5	EPA8260
c-1,2-Dichloroethene	ug/L	< 5		11/15/07	5	EPA8260
Bromochloromethane	ug/L	< 5		11/15/07	5	EPA8260
Chloroform	ug/L	< 5		11/15/07	5	EPA8260
111 Trichloroethane	ug/L	< 5		11/15/07	5	EPA8260
1,1-Dichloropropene	ug/L	< 5		11/15/07	5	EPA8260
Carbon Tetrachloride	ug/L	< 5		11/15/07	5	EPA8260
Benzene	ug/L	< 5		11/15/07	5	EPA8260
1,2 Dichloroethane	ug/L	< 5		11/15/07	5	EPA8260
Trichloroethene	ug/L	< 5		11/15/07	5	EPA8260
1,2 Dichloropropane	ug/L	< 5		11/15/07	5	EPA8260
Bromodichloromethane	ug/L	< 5		11/15/07	5	EPA8260
Dibromomethane	ug/L	< 5		11/15/07	5	EPA8260
Toluene	ug/L	49		11/15/07	5	EPA8260
112 Trichloroethane	ug/L	< 5		11/15/07	5	EPA8260
Tetrachloroethene	ug/L	< 5		11/15/07	5	EPA8260
1,3-Dichloropropane	ug/L	< 5		11/15/07	5	EPA8260
Chlorodibromomethane	ug/L	< 5		11/15/07	5	EPA8260
1,2 Dibromoethane	ug/L	< 5		11/15/07	5	EPA8260

cc:

LRL=Laboratory Reporting Limit

REMARKS:

DIRECTOR



ECOTEST LABORATORIES, INC.

ENVIRONMENTAL TESTING

377 SHEFFIELD AVE. • N. BABYLON, N.Y. 11703 • (631) 422-5777 • FAX (631) 422-5770

Email: ecotestlab@aol.com Website: www.ecotestlabs.com

LAB NO.274893.04

11/21/07

C.A. Rich Consultants, Incorporated
17 Dupont Street
Plainview, NY 11803

ATTN: Steve Sobstyl

PO#:

SOURCE OF SAMPLE: 299 Main Street-19 Liberty LDT, #299 Main Street

SOURCE OF SAMPLE:

COLLECTED BY: Client

DATE COL'D:11/08/07 RECEIVED:11/08/07

TIME COL'D:1025

MATRIX:Water

SAMPLE: CP-01(L)

ANALYTICAL PARAMETERS	UNITS	RESULT	FLAG	DATE OF ANALYSIS	LRL	ANALYTICAL METHOD
1112Tetrachloroethane	ug/L	< 5		11/15/07	5	EPA8260
Chlorobenzene	ug/L	< 5		11/15/07	5	EPA8260
Ethyl Benzene	ug/L	< 5		11/15/07	5	EPA8260
m + p Xylene	ug/L	< 10		11/15/07	10	EPA8260
o Xylene	ug/L	< 5		11/15/07	5	EPA8260
Styrene	ug/L	< 5		11/15/07	5	EPA8260
Bromoform	ug/L	< 5		11/15/07	5	EPA8260
Isopropylbenzene	ug/L	< 5		11/15/07	5	EPA8260
1122Tetrachloroethane	ug/L	< 5		11/15/07	5	EPA8260
Bromobenzene	ug/L	< 5		11/15/07	5	EPA8260
123-Trichloropropane	ug/L	< 5		11/15/07	5	EPA8260
n-Propylbenzene	ug/L	< 5		11/15/07	5	EPA8260
2-Chlorotoluene	ug/L	< 5		11/15/07	5	EPA8260
135-Trimethylbenzene	ug/L	< 5		11/15/07	5	EPA8260
4-Chlorotoluene	ug/L	< 5		11/15/07	5	EPA8260
tert-Butylbenzene	ug/L	< 5		11/15/07	5	EPA8260
124-Trimethylbenzene	ug/L	< 5		11/15/07	5	EPA8260
sec-Butylbenzene	ug/L	< 5		11/15/07	5	EPA8260
p-Isopropyltoluene	ug/L	10		11/15/07	5	EPA8260
1,2 Dichlorobenzene (v)	ug/L	< 5		11/15/07	5	EPA8260
1,3 Dichlorobenzene (v)	ug/L	< 5		11/15/07	5	EPA8260
1,4 Dichlorobenzene (v)	ug/L	32		11/15/07	5	EPA8260
DBCP	ug/L	< 5		11/15/07	5	EPA8260
124-Trichlorobenzene (v)	ug/L	< 5		11/15/07	5	EPA8260
Hexachlorobutadiene	ug/L	< 5		11/15/07	5	EPA8260

cc:

LRL=Laboratory Reporting Limit

REMARKS:

DIRECTOR

ECOTEST LABORATORIES, INC.

ENVIRONMENTAL TESTING

377 SHEFFIELD AVE. • N. BABYLON, N.Y. 11703 • (631) 422-5777 • FAX (631) 422-5770

Email: ecotestlab@aol.com Website: www.ecotestlabs.com

LAB NO.274893.04

11/21/07

C.A. Rich Consultants, Incorporated
17 Dupont Street
Plainview, NY 11803

ATTN: Steve Sobstyl

PO#:

SOURCE OF SAMPLE: 299 Main Street-19 Liberty LDT, #299 Main Street

SOURCE OF SAMPLE:

COLLECTED BY: Client DATE COL'D:11/08/07 RECEIVED:11/08/07
TIME COL'D:1025

MATRIX:Water SAMPLE: CP-01(L)

ANALYTICAL PARAMETERS	UNITS	RESULT	FLAG	DATE OF ANALYSIS	LRL	ANALYTICAL METHOD
Naphthalene(v)	ug/L	< 5		11/15/07	5	EPA8260
123-Trichlorobenzene	ug/L	< 5		11/15/07	5	EPA8260
c-1,3Dichloropropene	ug/L	< 5		11/15/07	5	EPA8260
t-1,3Dichloropropene	ug/L	< 5		11/15/07	5	EPA8260
Acetone	ug/L	< 50		11/15/07	50	EPA8260

cc:

LRL=Laboratory Reporting Limit

REMARKS:

DIRECTOR

rn = 34031

NYSDOH ID # 10320

Page 3 of 4

ECOTEST LABORATORIES, INC.

ENVIRONMENTAL TESTING

377 SHEFFIELD AVE. • N. BABYLON, N.Y. 11703 • (631) 422-5777 • FAX (631) 422-5770

Email: ecotestlab@aol.com Website: www.ecotestlabs.com

LAB NO.274893.04

11/21/07

C.A. Rich Consultants, Incorporated
17 Dupont Street
Plainview, NY 11803

ATTN: Steve Sobstyl

PO#:

SOURCE OF SAMPLE: 299 Main Street-19 Liberty LDT, #299 Main Street

SOURCE OF SAMPLE:

COLLECTED BY: Client

DATE COL'D:11/08/07 RECEIVED:11/08/07

TIME COL'D:1025

MATRIX:Water

SAMPLE: CP-01(L)

ANALYTICAL PARAMETERS	UNITS	RESULT	FLAG	DATE OF ANALYSIS	LRL	ANALYTICAL METHOD
Arsenic as As	mg/L	0.005		11/12/07	0.005	EPA200.7
Barium as Ba	mg/L	0.031		11/12/07	0.005	EPA200.7
Cadmium as Cd	mg/L	< 0.005		11/12/07	0.005	EPA200.7
Chromium as Cr	mg/L	< 0.005		11/12/07	0.005	EPA200.7
Lead as Pb	mg/L	0.022		11/12/07	0.005	EPA200.7
Mercury as Hg	mg/L	< 0.00025		11/13/07	0.0002	EPA245.2
Selenium as Se	mg/L	< 0.01		11/12/07	0.01	EPA200.7
Silver as Ag	mg/L	< 0.005		11/12/07	0.005	EPA200.7
pH (lab) units		7.3		11/08/07	0.1	SM4500HB

cc:

LRL=Laboratory Reporting Limit

REMARKS:

DIRECTOR