



FINAL REPORT

**PERFORMANCE MONITORING
OF THE VAPOR CONTROL SYSTEM
LOCATED AT THE UNISYS
GREAT NECK FACILITY**

Prepared for:

Unisys Corporation
365 Lakeville Road, MS 1P10
Great Neck, New York 11020



Prepared by:

Remediation Technologies, Inc
Damonmill Square
9 Pond Lane
Concord, Massachusetts 01742

Project # 8-1153-200

October 1993




FINAL REPORT

**PERFORMANCE MONITORING
OF THE VAPOR CONTROL SYSTEM
LOCATED AT THE UNISYS
GREAT NECK FACILITY**

Prepared for:

**Unisys Corporation
365 Lakeville Road, MS 1P10
Great Neck, New York 11020**



Prepared by:

**Remediation Technologies, Inc
Damonmill Square
9 Pond Lane
Concord, Massachusetts 01742**

Prepared by: _____

Approved by: _____

Project # 3-1153-200

October 1993

TABLE OF CONTENTS

NO.	DESCRIPTION	PAGE NO.
1.0	INTRODUCTION	1-1
2.0	SITE HISTORY	2-1
2.1	VAPOR CONTROL SYSTEM	2-1
3.0	SCOPE OF WORK	3-1
3.1	GAS STREAM SAMPLING LOCATIONS AND CHARACTERIZATION	3-1
3.1.1	Inlet Sample Location	3-1
3.1.2	Outlet Sample Location	3-1
3.1.3	Gas Stream Characterization	3-1
3.2	DETERMINATION OF ORGANIC CONCENTRATIONS	3-4
3.2.1	Sampling Train	3-4
3.2.2	Adsorbent Tubes	3-5
3.2.3	Condensates	3-7
3.3	DETERMINATION OF HCL CONCENTRATIONS	3-7
3.3.1	Sampling Train	3-7
4.0	LABORATORY ANALYSIS	4-1
4.1	ORGANIC ANALYSIS	4-1
4.1.1	Desorption Efficiency Test	4-1
4.1.2	Analytical Procedure	4-1
4.2	HCL ANALYSIS	4-2
5.0	RESULTS	5-1
5.1	CALCULATION OF GAS VELOCITY	5-1
5.2	CALCULATION OF GAS FLOW RATES	5-2
5.3	CALCULATION OF SAMPLE TRAIN VOLUMES	5-3
5.4	ORGANIC ANALYTICAL RESULTS	5-4
5.4.1	Measured Concentrations of Organics	5-5
5.5	HCL RESULTS	5-11
5.6	CONCLUSIONS	5-11
Appendix A - Analytical Laboratory Report		A-1
Appendix B - Field Data Sheets		A-2

LIST OF TABLES

1-1	Compounds of Concern For the Vapor Monitoring Program Unisys Corporation Great Neck, New York	1-2
5-1	Inlet Organic Results	5-6
5-2	Detected Organic Effluent Results	5-8
5-3	Detected Impinger Organic Results	5-9
5-4	Destruction Efficiency	5-10
5-5	HCL Emissions	5-12

LIST OF FIGURES

2-1	Organic Control Schematic	2-2
2-2	Scrubber Control Schematic	2-3
3-1	Inlet Sample Point	3-2
3-2	Outlet Sample Point	3-3

1.0 INTRODUCTION

Remediation Technologies, Inc. (RETEC) was contracted to conduct a performance monitoring program on a newly installed soil vapor off-gas control system located at the Unisys Great Neck, New York facility. The monitoring program was designed to validate the effectiveness of the system, which was designed to achieve an organic destruction efficiency for the compounds of concern of 95 to 99 percent. Compounds of concern for this program are presented in Table 1-1.

The Unisys vapor control system was comprised of two major components: a catalytic oxidizer to control volatile organic compounds (VOCs); and a spray chamber scrubber to control hydrogen chloride (HCL). Details of the vapor control system are presented in Section 2.0.

RETEC performed simultaneous sampling of the inlet and outlet vapor stream of the catalytic oxidizer to determine the efficiency of the vapor control system. Outlet sampling was performed on the HCL scrubber to determine its emission rate. Three sample test runs were performed as part of the emission monitoring program. Sampling procedures followed the methods presented in the RETEC Work Plan (September, 1993). Results from the sampling and analytical programs are presented in Sections 3.0 and 5.0 of this document.

Table 1-1

Compounds of Concern
For the Vapor Monitoring Program
Unisys Corporation
Great Neck, New York

Compounds
Benzene
2-Butanone (MEK)
Chloroform
1,2-Dichlorobenzene
1,2-Dichloroethane
1,1-Dichloroethene
1,2-Dichloroethene (total)
Ethylbenzene
Methylene Chloride
Tetrachloroethene
Toluene
1,1,1-Trichloroethane
Trichloroethene
Xylene
Freon 113
Naphthalene
Hydrochloric Acid

2.0 SITE HISTORY

In December 1991, a pilot soil vapor extraction (SVE) test was performed by Unisys at their Great Neck facility. Data collected during the program was used to estimate organic levels in the vapor stream to evaluate and select an appropriate vapor control system. Based on the results of the SVE program test, Unisys chose catalytic oxidation as the vapor control system.

2.1 VAPOR CONTROL SYSTEM

Treatment of the extracted vapors was achieved by catalytic oxidation. Unisys chose a Chloro-Cat oxidizer, manufactured by Global Technologies, Inc., for the thermal oxidizer. A schematic of the system is presented in Figure 2-1.

Organic laden air is drawn into the system by way of a soil vapor vacuum blower and then through a heat exchanger prior to the natural gas fired burner. The burner raises the temperature of the vapors to the catalyzing temperature of approximately 650°F. The organics in the stream are converted to carbon dioxide, water vapor and inorganic acids. A spray chamber scrubber is used to neutralize the inorganic acids prior to the release to the atmosphere. A schematic of the scrubber system is presented in Figure 2-2.

The treated vapors leave the scrubber and enter the discharge stack at a temperature of approximately 135°F. The stack is eight inches in diameter, thirty-five feet high, and terminates ten feet above the roof of the building.

3.0 SCOPE OF WORK

RETEC performed an emission test on the vapor control system to measure the destruction efficiency for selected organics and the emission rate of HCL. Sampling procedures followed methods detailed in the RETEC Work Plan (September 1993). This section details the sampling methodologies followed during the emission testing program.

3.1 GAS STREAM SAMPLING LOCATIONS AND CHARACTERIZATION

RETEC located gas sampling ports on the vapor control system following the guidelines established by the U.S. EPA. A schematic of the sampling ports on the vapor control system used during the program are presented in Figures 3-1 and 3-2.

3.1.1 Inlet Sample Location





















The inlet sampling port for organic measurement was located in a four inch diameter pipe, leading from the soil vapor system, to the catalytic oxidizer. The sample port was located before the soil vapor vacuum blower, so the stream was under negative pressure during the monitoring program.


3.1.2 Outlet Sample Location

The combined outlet sampling port for organic and HCL measurement was located in the exhaust stack (8-inch diameter) from the inorganic gas scrubber. The port was accessible by way of the building roof and was approximately eight feet from the end of the stack.

3.1.3 Gas Stream Characterization

Gas velocity measurements were performed on the inlet and outlet gas streams with a standard pitot tube and inclined manometer. The number of traverse points and the verification of absence of cyclonic flow was performed following the procedures presented in the RETEC Work Plan.


MEASUREMENT VARIABLE		SIGNAL CONDITION / UTILITY		VALVE / DEVICE		MISCELLANEOUS		NOTATIONS	
A	ANALYSIS	A	ALARM	D-D	VALVE NORMALLY OPEN OR UNSPECIFIED		CEMTRIFUGAL BLOWER		ELECTRIC MOTOR
F	FLOW RATE	C	CONTROLLER		VALVE NORMALLY CLOSED		POSITIVE DISPLACEMENT BLOWER		SIGNAL
I	CURRENT	C	CENTRIFUGAL	D-D	DAIR VALVE		PUMP/DUCTWORK		
L	LEVEL	E	PRIMARY ELEMENT		CHECK VALVE		ELECTRICAL WIRING		
P	PRESSURE	H	HIGH		BUTTERFLY VALVE		PANEL MOUNTED INSTRUMENT		
T	TEMPERATURE	I	INDICATOR		DAMPEN		LOCALLY MOUNTED INSTRUMENT		
		L	LIGHT		FLOW DRAINCE		MOUNTED INSIDE PANEL		
		L	LOW		PRESSURE REGULATOR (SELF CONTAINED)		ALARM		
		R	RECORD		PRESSURE REGULATOR (EXTERNAL BACKLOG)				
		S	SWITCH						
		T	TRANSMITTER						
		V	VALVE						



1. THE PROCESS INLET VALVE IS HELD CLOSED AND THE DRUM AIR PRESSURE IS BUILT UP TO THE CATALYST INLET TEMPERATURE REQUIRED AT A DESIRED LEVEL.
2. THE DRUM AIR VALVE IS CONTROLLED BY THE DESIGNER CAUSED BY THE LEVEL OF SOLVENT LOADING, AS THE OUTLET TEMPERATURE RISES THE DRUM AIR VALVE IS OPENED TO KEEP THE UNIT FROM SHUTTING DOWN ON HIGH OUTLET TEMPERATURE.
3. THE STACK TEMPERATURE IS MONITORED TO PREVENT HCl CONDENSATION, IF A LOW STACK TEMPERATURE IS DETECTED THE RALE VALVE CLOSERS AND THE DRUM AIR VALVE ARE OPENED.
4. SETPOINT CATALYST VOLUME REQUIREMENT IS DEPENDENT UPON SPECIFIC PROCESS VOLUME AND CONSTITUENTS AS WELL AS CATALYST MANUFACTURER'S RECOMMENDATIONS FOR THE SPECIFIC SETPOINT. CATALYST CONSUMPTION IS AS FOLLOWS:
$$\text{MOLES/l CHLORAL} = 3 \text{ g./cu. in.}$$

Information contained here is the exclusive property of General Corporation, Inc. and is provided for informational purposes only. It is not to be used in the furtherance of or the promotion of any political or financial interest of General Corporation or its directors, officers, or employees.

Figure 3-1 Inlet Sample Port

 GLOBAL		Global Technologies, Inc.		Milwaukee, Wisconsin	
K&F KLS		C&P		W&S, CORP.	
PLATE #	REG 10-17				
DECD	DATE	REG NO.	77	EXPAC NO.	77-1
APPRO	DATE	EXP. D.	07-01-02	PAGE 1	OF 1
112 303 5574 CALVERT GARDEN - OREGONIAN SOUTHERN LUMBER CO.					

Gas velocities were measured before and after each inlet and outlet sampling run. Initial and final gas velocities are reported separately, but were averaged to calculate the final gas flow for each sample run.

Temperature of the inlet and outlet gas streams were also measured during the sample program using a thermocouple capable of measuring temperatures to within 1.5 percent of the minimum absolute stack temperature. Barometric pressure was obtained from the National Weather Service, corrected for elevation.

3.2 DETERMINATION OF ORGANIC CONCENTRATIONS

Samples of organics in the inlet and outlet gas streams from the catalytic oxidizer were collected using a leak-less sample pump and carbon adsorption tubes in accordance with the RETEC Work Plan. The carbon tubes were sent to the analytical laboratory, subsequently desorbed, and analyzed for the specific organics of interest by gas chromatography and mass spectrometry.

A preliminary sample analysis survey was performed on the inlet gas stream with a portable organic vapor analyzer before and during each sample run with the carbon adsorption tubes. The analyzer measured total organics in the gas stream, on a ppmv basis, using a photo ionization detector (PID). The portable analyzer was calibrated prior to use with a standard concentration of 100 ppmv isobutylene mixed with air. This qualitative analysis provided an appropriate loading rate and subsequent total sample volume for the charcoal adsorbent tubes to prevent constituent break-through. The measured concentration (ppmv) was converted to a mg/m^3 concentration using the relationship of 1 ppmv of isobutylene is equal to $2.29 \text{ mg}/\text{m}^3$ (at standard conditions).

3.2.1 Sampling Train

The sampling trains used for inlet and outlet sampling consisted of a stainless steel probe (approximately $\frac{1}{4}$ inches in diameter), midget glass impingers to condense water vapor, inert (Teflon) flexible tubing to connect the probe to the midget impingers, and carbon adsorption tubes. Sample gas to the oxidizer was pulled through the sampling system using a battery

operated personnel pump. Samples from the exhaust stream were collected using electric vacuum pumps equipped with critical flow orifices.

The personnel pump, equipped with a pressure sensitive flow control needle valve, had a sample rate of 1.5 liters per minute ($\pm 5\%$). The electric vacuum pump, equipped with the critical flow orifice, had a flow setting of 2 liters per minute ($\pm 15\%$).

The flow rate for each sample train was calculated using the following formula:

$$Q_T = \frac{M_C \times 0.20}{(2.5 \times C_A) \times 2.29 \times \theta}$$

where:

Q_T	=	Sample train flow rate (m^3/min)
M_C	=	Mass of carbon (mg)
C_A	=	Concentration of gas stream (ppmv)
θ	=	Total run time (minutes)

The mass of carbon in the tubes were assumed to be only 20% efficient in collecting organics, so the mass of carbon in the formula is multiplied by 0.20. A relative response factor of 2.5 was also used to account for photo ionization detector sensitivity.

The calibration of the pump flow rate through the adsorption tubes was performed with a bubble tube flow meter prior to and at the conclusion of each sample run. The flow rate used during the organic sample run was corrected to dry standard conditions following the formula:

$$V_{sb}(\text{std}) = V_{sb} \left(\frac{T_{\text{std}} P_s}{T_s P_{\text{std}}} \right)$$

and,

$$Q_{std} = \left(\frac{V_{sb}(std)}{\theta} \right)$$

where:

$V_{sb}(std)$	=	Volume of gas as measured by the soap bubble meter corrected to standard conditions (scf)
V_{sb}	=	Volume of gas as measured by the soap bubble meter (ft ³)
Q_{std}	=	Volumetric flow rate through critical orifice (scf/min)
θ	=	Time (minutes)
P_s	=	Ambient pressure (in Hg)
P_{std}	=	Standard pressure (29.92 in Hg)

Sample probes were located in the centroid of both the inlet and outlet pipes. Midget impingers were placed in an ice bath and allowed to cool prior to sampling. Total sample times, sample flow rates, barometric pressure and temperatures were recorded for each run.

3.2.2 Adsorbent Tubes

The adsorbent tubes, activated charcoal, were obtained commercially and had the following general specifications: glass tube, 11 cm long, 1 cm OD, 8 mm ID, flamed sealed ends, containing two sections of activated (60°C) coconut shell charcoal (front = 800 mg, back = 200 mg) separated by a 4 mm urethane foam plug. A glass wool plug preceded the front section and a 4 mm urethane foam plug followed the back section.

Two tubes were used in series during the monitoring program to detect possible constituent break-through. The back tube was connected in the reverse direction such that the 200 mg section was first. This configuration allowed the contents of the first tube (1,000 mg) and the back-half of the second tube (200 mg) to be combined as one sample (1,200 mg). The remaining 800 mg of charcoal in the back tube was analyzed for break-through. Results are presented in Section 5.0

3.2.3 Condensates

Liquid condensates collected in the impingers during the sample run were poured into 20 ml VOA vials. Any available space in the vials was filled with distilled water before sealing. Samples were stored and shipped at 4°C.

3.3 DETERMINATION OF HCL CONCENTRATIONS

The concentration of hydrogen chloride in the outlet gas stream from the spray chamber scrubber was performed following the RETEC Work Plan. The method involved the passage of sample gas through a dilute sulfuric acid solution by means of a midget impinger. The solution was then measured for chloride ions using ion chromatography. Three sample runs were conducted on the outlet gas stream during the monitoring program.

3.3.1 Sampling Train

The sampling train included a probe lined with borosilicate glass, six 30 ml midget impingers with leak free glass connectors, sample line, and a sampling pump equipped with a 2 lpm limiting flow orifice.

The impingers were connected in series with a knockout impinger first. The next two impingers contained 15 ml of absorbing solution (0.1 N sulfuric acid). The fourth and fifth impingers contained 15 ml of scrubber solution (0.1 N sodium hydroxide). The sixth impinger acted as the drying tube.

The probe was placed at the centroid of the duct. Sample run times were 60 minutes each. Total sample time, flow rate, barometric pressure, and atmospheric temperature were recorded for each run.

Sample recovery was performed by quantitatively transferring the contents of the first three impingers (knockout impinger and the two absorbing solution impingers) to a leak-free storage bottle. Water rinses of each of these impingers and connecting glassware (probe) were added to the same storage bottle. The sample bottles were labeled and the fluid level marked so that if any sample was lost during shipment, a correction proportional to the lost volume could be applied.

4.0 LABORATORY ANALYSIS

Samples collected in the field were shipped back to the analytical laboratory at the conclusion of the sampling program. The following sections detail the analytical procedures used on the samples to analyze for the constituents of concern.

4.1 ORGANIC ANALYSIS

Upon receipt at the laboratory, the charcoal adsorbent tubes were desorbed using either carbon disulfide or toluene in accordance with the RETEC Work Plan. The use of toluene as a desorption solvent enabled the laboratory to detect the following compounds without the elution interference caused by carbon disulfide:

- 2-Butanone (MEK);
- Chloroform; and
- Methylene Chloride

The resulting extract was analyzed by GC/MS for the organic constituents of concern.

4.1.1 Desorption Efficiency Test

The laboratory performed a desorption efficiency (DE) test on the activated carbon for the constituents of concern using carbon disulfide or toluene. The desorption efficiency test followed the guidelines detailed in NIOSH Method 1501. The DE was determined by preparing three carbon tubes at five organic levels plus three media blanks. The desorption test was performed using the same batch of activated charcoal that was used in the field.

Results from the test are presented in the laboratory report, which is included in this report as Appendix A.

4.1.2 Analytical Procedure

In general, the contents of both sorbent tubes were combined in a single vial for analysis. Samples submitted for constituent breakthrough analysis, however, required a different

preparation scheme. In these instances, the contents of the first tube (1,000 mg) and the primary section of the second tube (200mg), were combined and analyzed. The remaining portion of the second tube (800mg) was analyzed separately to detect breakthrough.

An appropriate volume of solvent (1-3 ml) was added to the contents of the vial(s) which were sealed immediately using a crimp cap. The covered vial was set aside for a minimum of thirty minutes, with occasional agitation.

The extracted samples were analyzed by GC/MS. The GC was calibrated daily with a minimum of five working standards over the range of anticipated constituent concentrations. The results of these analysis provided concentration data (ug/ml) for the specific indicator compounds. Detection limits for the compounds are presented in the laboratory report.

Liquid condensates were analyzed by GC/MS following the procedures detailed in U.S EPA SW-846: Method 8240. Organic compounds were introduced into the gas chromatography by purge and trap method. An inert gas was bubbled through the solution at ambient temperature where the organic components are efficiently transferred from the aqueous phase to the vapor phase. The vapors are swept through a sorbent column where the organic components are trapped. After the purging was completed, the sorbent column was heated and backflushed with inert gas to desorb the components into the GC. The gas chromatograph separates the components of interest which are quantified by the mass spectrometer. The final results are presented in $\mu\text{g/L}$.

The detected organics in the sample charcoal tube and any corresponding condensate were summed to obtain a total organic and compound specific concentration in milligrams (mg) for the sample run. A final concentration, in mg/m^3 , was calculated by dividing the detected mass by the total volume sampled, corrected to dry standard conditions as detailed in Section 3.

4.2 HCL ANALYSIS

Samples received for HCL analysis were performed using ion chromatography. The instrument was calibrated with standards covering an appropriate concentration range, starting with the lowest concentration standard. Duplicate injections of a QC sample, followed by a water blank and the field sample was performed. A final injection of the calibration standard

was made to allow for compensation of any drift in the instrument during analysis of the field samples.

The peak Cl^- area was measured for all sample injections. The average response from duplicate samples was used to determine the field sample concentrations by comparing it to a linear calibration curve generated from the standards. The concentration of Cl^- in the sample is reported in $\mu\text{g}/\text{L}$.

The mass of HCl in the sample (μg) was calculated by multiplying the Cl^- concentration (blank corrected) by the molecular weight of HCl ($\mu\text{g}/\mu\text{g-mole}$) and then dividing the product by the atomic weight of Cl ($\mu\text{g}/\mu\text{g-mole}$). A final concentration, in mg/m^3 , was calculated by dividing the mass of HCL by the total volume of gas sampled, corrected to dry standard conditions.

5.0 RESULTS

This section details the results of the compliance emission monitoring program conducted on the Unisys thermal catalytic oxidizer on September 16, 1993. The analytical laboratory report is presented in Appendix A. Field data sheets are presented in Appendix B.

5.1 CALCULATION OF GAS VELOCITY

The calculation to determine the gas velocities within the inlet and outlet gas streams are as follows:

$$V_s = 5130 \times C_p \times SDE \times \left(\frac{1}{PS \times MW} \right)^{0.5}$$

where:

V_s	=	Average stack velocity (ft/sec)
C_p	=	Pitot tube constant (.99)
MW	=	Molecular weight of stack gas (lb/lb mole)
SDE	=	Δ Pressure x Δ Temperature
PS	=	Absolute stack pressure (inches Hg)

SDE was calculated as:

$$SDE = (\sqrt{\Delta P_{AV}}) \times (\sqrt{TS_{AV} + 460})$$

5.1.1 Inlet Gas Velocities

Three sample runs were performed on the inlet gas stream for organic compounds of concern. Gas pressure readings were taken before (initial) and after (final) each sample run. Results are recorded on the filed data sheets presented in Appendix B.

The average initial and final gas pressure readings for sample run one was 0.053 and 0.052 inches of H_2O , respectively, with an average sample run pressure of 0.052. Run two had

average initial and final pressure readings of 0.066 and 0.062 inches of H₂O, with an average sample pressure of 0.064. Run three had average initial and final pressure readings of 0.058 and 0.060 inches of H₂O, with an average pressure of 0.059. The pressure readings recorded during each sample run indicated that inlet velocities remained constant during each sampling run and during the sampling program as a whole.

Using the above formulas, the gas velocity during sample Run 1 was calculated to be 905.4 afpm. Sample Run 2 had a gas velocity of 1,005 afpm and Run 3 had a recorded velocity of 961.6 afpm.

5.1.2 Exhaust Gas Velocities

Three sample runs performed on the outlet gas stream for organic compounds of concern and HCL, recorded gas velocities before and after each sample run. Results are recorded on the field data sheets, which are presented in Appendix B.

The average initial and final gas pressure readings for sample Run 1 was 0.230 and 0.232 inches of H₂O, respectively, with an average sample run pressure of 0.231. Run 2 had average initial and final pressure readings of 0.232 and 0.237 inches of H₂O, with an average sample run pressure of 0.234. Run three had an average initial pressure reading of 0.232, but the final pressure was not recorded. The oxidizer was turned off prior to the final flow measurement.

The pressure readings indicate that the outlet velocities remained constant during individual sampling runs and the sampling program as a whole.

Using the above formulas, the gas velocity out the stack during sample Run 1 was calculated to be 2,049.4 afpm. Sample Run 2 had a gas velocity of 2,053.6 afpm and Run 3 had a recorded velocity of 2,054.8 afpm, using the initial measured velocity.

5.2 CALCULATION OF GAS FLOW RATES

The equation used to determine the gas flow rates is as follows:

$$Q = \left(\frac{V_s}{A_s} \right)$$

where:

Q = Volumetric stack gas flow rate at actual conditions (acfm)
 V_s = Average actual stack velocity (afpm)
 A_s = Cross sectional area of stack (ft²)

Using the calculated velocities presented in Section 6.1, the flow rates for the inlet gas stream was calculated by dividing the velocity by the area of the inlet pipe, which was 4 inches in diameter ($\pi(r)^2$ or 0.087 ft²). The gas flow rate during Run 1 was 78.9 acfm. Run 2 was calculated to be 87.6 acfm and Run 3 was 83.8 acfm. Flows were consistent between sample runs, as to be expected from the results of the gas velocity measurements.

Calculated flow rates for the exhaust stream (8 inch pipe) were: 715.0 acfm for Run 1; 716.5 acfm for Run 2; and 716.9 acfm for Run 3 (using the initial velocity reading).

5.3 CALCULATION OF SAMPLE TRAIN VOLUMES

Battery powered sample pumps used at the inlet sample location were calibrated using a primary calibration standard: a gas bubble tube. Electric vacuum pumps used to sample the exhaust stream were equipped with critical flow orifices. Recorded flow rates from the bubble tube and critical flow orifices, presented on field data sheets in Appendix B, were converted to dry standard conditions using the formula present in Section 3.2.2.

Sample duration for the inlet and outlet locations lasted 60 minutes. Two sample trains were used to sample the inlet and outlet gas streams at the oxidizer to provide sample tubes for carbon disulfide and toluene extraction procedure.

The average, actual flow rate recorded for inlet sample train 1 was 1,500 cm³/min. The corresponding standard flow was calculated to be 1,468 cm³/min. The actual flow recorded from inlet sample train 2 was 1,630 cm³/min, which corresponds to a standard flow rate of

1,595 cm³/min. Tubes collected using sample train 1 were desorbed using carbon disulfide. Tubes from sample train 2 were desorbed with toluene.

The actual recorded flow rate from the critical flow orifices during the exhaust sampling program was 2,000 cm³/min. Three pumps were used: two pumps to collect organic compounds onto carbon tubes, the other pump to pull a sample of stack gas through the HCL train. The flow rates were corrected to standard conditions at a rate of 1,957 cm³/min.

Total volume sampled over each sample period was computed as:

$$(Q_{std}) \times (\text{run time})$$

Total times for each of the three sampling runs were recorded at 60 minutes. Inlet sample volumes for sample train 1, for each of the three sample runs, was calculated to be 0.090 m³. Inlet sample volumes for sample train 2, for each of the three sample runs, was calculated to be 0.098 m³.

Exhaust sample volumes for organic sample trains 1, 2 and the HCL train, for each of the three sample runs, was calculated to be 0.117 m³.

5.4 ORGANIC ANALYTICAL RESULTS

Results from the desorption efficiency test indicated percent recoveries for organic constituents of concern from 55 to 120 percent. 1,2-Dichloroethene had the lowest recovery with 55%, trichloroethene had the highest at 120%.

Previous sample results from the Unisys oxidizer for organic concentrations reported initial results in units of ug/tube. Concerns over this unit value by NYDEC were acknowledged by RETEC and was corrected prior to this final monitoring program. Analytical results presented in the laboratory report, Appendix A, report the detected levels of organics in units of ug/ml, ug/g, and ug/tube.

To obtain the mass of carbon in the sampling tube, RETEC advised the laboratory to obtain an average carbon weight by measuring the weight of blank carbon tubes from the same batch used for the gas sampling. An average weight of carbon for the front and back sections

were calculated. The weight of the front tube, or the primary section, was measured to be 1.27 grams. The weight of the back tube, or the secondary section, was measured to be 0.84 grams. These masses were used to calculate a constituent concentration on the carbon tubes in units of ug/g.

Constituent breakthrough analysis was conducted on every carbon tube. Problems of constituent breakthrough were not detected in any of the inlet gas stream samples, all detected constituent concentrations in the back section of the tubes were less than 10%.

Constituent breakthrough did occur on run 1 and run 3 for the effluent sampling runs. Sample run 1 detected breakthrough for 1,2-dichloroethene (12.6%), tetrachlorethane (80%), and trichloroethene (17.1%). Sample run 3 detected breakthrough for freon 113 (14.6%). Sample run 2 had no breakthrough concentrations.

The ability of carbon to absorb the compounds was proven during the analysis of the inlet carbon tubes. High concentrations of organic constituents did not breakthrough the primary section of the tube. Low outlet concentrations would also indicate no breakthrough for the constituents. The only difference between the inlet and outlet organic sampling trains was in their flow rates. Constituent breakthrough on sample runs 1 and 3 may be explained by too low of a constituent concentration and too high of a sampling flow rate. A high moisture content of the exhaust stream may have also contributed to the breakthrough concentrations, however an impinger was used prior to the carbon tube to knockout any moisture in the sample gas stream.

5.4.1 Measured Concentrations of Organics

Table 5-1 presents the results of the three organic sample runs on the inlet gas stream to the catalytic oxidizer on September 16, 1993. Thirteen out of the sixteen organic compounds of concern were detected during the monitoring program. 2-Butanone, 1,1-dichloroethene, and naphthalene were the three organic compounds which were not detected in any of the three inlet sampling runs.

Three compounds made up the majority of the organic concentration in the inlet stream, approximately 88.8%. They are: tetrachloroethene at 38.4%; trichloroethene at 25.7%; and 1,2-

TABLE 5-1

**DETECTED INFLUENT ORGANIC RESULTS
COMPLIANCE MONITORING PROGRAM
UNISYS CORPORATION
GREAT NECK, NEW YORK**

Compounds	Detection Limit ug/ml	Detected Compounds Run 1			Detected Compounds Run 2			Detected Compounds Run 3			Average Levels		
		ug/sample	ug/m ³	lbs/hr	ug/sample	ug/m ³	lbs/hr	ug/sample	ug/m ³	lbs/hr	ug/sample	ug/m ³	lbs/hr
Benzene	0.5	116	1,317	0.00039	109.1	1,240	0.00041	129.5	1,472	0.00046	118.2	1,343	0.00042
2-Butanone	5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
Chloroform	0.5	42	476	0.00014	41.0	466	0.00015	48.5	551	0.00017	43.8	498	0.00016
1,2-Dichlorobenzene	0.5	39	443	0.00013	35.1	398	0.00013	42.9	487	0.00015	39.0	443	0.00014
1,2-Dichloroethane	0.5	21	236	0.00007	20.8	236	0.00008	24.2	275	0.00009	21.9	249	0.00008
1,1-Dichloroethene	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
1,2-Dichloroethene (total)	0.5	109,091	1,239,669	0.36699	96,000.0	1,090,909	0.35755	145,636.4	1,654,959	0.52055	116,909.1	1,328,512	0.41503
Ethylbenzene	0.5	248	2,821	0.00084	251.7	2,861	0.00094	265.5	3,017	0.00095	255.2	2,900	0.00091
Methylene Chloride	0.5	29	332	0.00010	55.8	634	0.00021	53.1	603	0.00019	46.0	523	0.00017
Tetrachloroethene	0.5	100,000	1,136,364	0.33640	85,714.3	974,026	0.31924	100,000.0	1,136,364	0.35743	95,238.1	1,082,251	0.33769
Toluene	0.5	21,935	249,267	0.07379	26,580.6	302,053	0.09900	24,838.7	282,258	0.08878	24,451.6	277,859	0.08719
1,1,1-Trichloroethane	0.5	546	6,205	0.00184	492.1	5,592	0.00183	569.7	6,473	0.00204	536.0	6,090	0.00190
Trichloroethene	0.5	55,250	627,841	0.18586	57,500.0	653,409	0.21416	55,000.0	625,000	0.19659	55,916.7	635,417	0.19887
Xylene	0.5	448	5,087	0.00151	438.1	4,978	0.00163	452.4	5,141	0.00162	446.0	5,069	0.00158
Freon 113	0.5	3,600	40,909	0.01211	5,640.0	64,091	0.02101	5,730.0	65,114	0.02048	4,990.0	56,705	0.01787
Naphthalene	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
Total		291,365	3,310,968	0.98	272,879	3,100,894	1.02	332,791	3,781,714	1.19	299,012	3,397,858	1.06

ND = Not Detected

NC = Not Calculated

1,2-dichloroethene (total) at 24.7%. Two other compounds, toluene (8.7%) and freon 113 (1.9%) make up an additional 10.6% of the organic concentration for the inlet gas stream. These five organic compounds comprise 99.4% of the inlet gas concentrations to the catalytic oxidizer. The remaining eight compounds make up less than 0.20% of the organic concentration.

Inlet sampling results also indicate a very low organic loading rate to the catalytic oxidizer. An average mass of organic measured during the program was 0.299 grams. With an average flow rate of 83.4 acfm, this relates to a loading rate of only 1.06 lbs/hr.

Table 5-2 presents the results from the sampling of the exhaust stream. Table 5-3 presents the organic results for the collected liquid condensates and Table 5-4 details the calculated destruction efficiencies.

Six out of the thirteen organic compounds detected in the inlet gas stream were detected in the exhaust gas. The detected organic compounds of concern and their average concentrations ($\mu\text{g}/\text{m}^3$) in the exhaust gas stream are:

- benzene (13);
- 1,2-dichloroethene (194, total);
- methylene chloride (9);
- tetrachloroethene (204);
- trichloroethene (262); and
- freon 113 (1,403).

The detection of 1,2-dichloroethene, tetrachloroethene, and trichloroethene represents a destruction efficiency greater than 97% for 88.8% of the total detected organics in the inlet gas stream. Toluene, which made up 8.7% of the inlet gas organic concentration, was below the detection limit of the exhaust sampling train, subsequently a destruction efficiency was not calculated. The other compound Freon 113, which made up 1.9% of the inlet organic stream, was reduced in concentration from 55,444 $\mu\text{g}/\text{m}^3$ to 11,583 $\mu\text{g}/\text{m}^3$, but increased in emission rate from 0.02 to 0.032 lbs/hr. This indicates that the reduction in freon 113 concentration was caused by sample stream dilution with ambient air and not by the oxidizer. Methylene chloride also showed an increase in emission rate between the inlet and outlet gas streams, from 0.00019 to 0.00021 lbs/hr.

TABLE 5-2

**DETECTED EFFLUENT ORGANIC RESULTS
COMPLIANCE MONITORING PROGRAM
UNISYS CORPORATION
GREAT NECK, NEW YORK**

Compounds	Detection Limit ug/ml	Detected Compounds Run 1			Detected Compounds Run 2			Detected Compounds Run 3			Average Levels		
		ug/sample	ug/m ³	lbs/hr	ug/sample	ug/m ³	lbs/hr	ug/sample	ug/m ³	lbs/hr	ug/sample	ug/m ³	lbs/hr
Benzene	0.5	1.7	14.6	0.00004	1.7	14.6	0.00004	1.7	14.6	0.00004	1.7	14.6	0.00004
2-Butanone	5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
Chloroform	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
1,2-Dichlorobenzene	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
1,2-Dichloroethane	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
1,1-Dichloroethene	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
1,2-Dichloroethene (total)	0.5	336.4	2874.9	0.0077	392.7	3356.6	0.0090	327.3	2797.2	0.0075	352.1	3,010	0.0081
Ethylbenzene	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
Methylene Chloride	0.5	13.8	118.0	0.0003	9.6	81.7	0.0002	1.6	15.4	0.00004	8.3	72	0.0002
Tetrachloroethene	0.5	259.0	2214.1	0.0059	151.4	1294.3	0.0035	171.4	1465.2	0.0039	194.0	1,658	0.0044
Toluene	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
1,1,1-Trichloroethane	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
Trichloroethene	0.5	211.7	1809.1	0.0048	225.0	1923.1	0.0052	217.5	1859.0	0.0050	218.1	1,864	0.0050
Xylene	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
Freon 113	0.5	2010.0	17179.5	0.0460	1770.0	15128.2	0.0406	428.0	3658.1	0.0098	1,402.7	11,989	0.0321
Naphthalene	0.5	ND	NC	NC	ND	NC	NC	ND	NC	NC	ND	NC	NC
Total		2,833	24,210	0.065	2,550	21,798	0.058	1,147	9,809	0.026	2,177	18,606	0.050

ND = Not Detected
NC = Not Calculated

TABLE 5-3

**DETECTED IMPINGER ORGANIC RESULTS
COMPLIANCE MONITORING PROGRAM
UNISYS CORPORATION
GREAT NECK, NEW YORK**

Compounds	Detection Limit ug/L	Detected Compounds Run 1			Detected Compounds Run 2			Detected Compounds Run 3			Average Levels		
		Vol. (L)	ug/L	ug/samp.	Vol. (L)	ug/L	ug/samp.	Vol. (L)	ug/L	ug/samp.	Vol. (L)	ug/L	ug/samp.
Benzene	1	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
2-Butanone	10	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
Chloroform	1	0.067	2.2	0.15	0.065	3.0	0.20	0.064	2.7	0.17	0.065	2.63	0.17
1,2-Dichlorobenzene	1	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
1,2-Dichloroethane	1	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
1,1-Dichloroethene	1	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
1,2-Dichloroethene (total)	1	0.067	2.9	0.19	0.065	2.9	0.19	0.064	3.8	0.24	0.065	3.20	0.21
Ethylbenzene	1	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
Methylene Chloride	1	0.067	7.3	0.49	0.065	10.0	0.65	0.064	8.1	0.52	0.065	8.47	0.55
Tetrachloroethene	1	0.067	1.3	0.09	0.065	1.4	0.09	0.064	1.5	0.10	0.065	1.40	0.09
Toluene	1	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
1,1,1-Trichloroethane	1	0.067	2.1	0.14	0.065	1.2	0.08	0.064	ND	ND	0.065	1.10	0.07
Trichloroethene	1	0.067	2.1	0.14	0.065	ND	ND	0.064	ND	ND	0.065	0.70	0.05
Xylene	1	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
Freon 113	1	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
Naphthalene	1	0.067	ND	ND	0.065	ND	ND	0.064	ND	ND	0.065	ND	ND
Chloride	100	0.067	4,000	268.0	0.065	4,900	318.5	0.064	2,300	147.2	0.065	3,733.3	244.6
Total Organics			17.9	1.20		18.5	1.20		16.1	1.03		17.5	1.14

TABLE 5-4

**ORGANIC DESTRUCTION EFFICIENCY
COMPLIANCE MONITORING PROGRAM
UNISYS CORPORATION
GREAT NECK, NEW YORK**

Compounds	Influent Average Levels			Effluent Average Levels			Destruction Efficiency
	ug/sample	ug/m ³	lbs/hr	ug/sample	ug/m ³	lbs/hr	
Benzene	118	1,343	0.00042	1.70	14.6	0.00004	90.7%
2-Butanone	ND	NC	NC	ND	NC	NC	NC
Chloroform	44	498	0.00016	<1.5	<12.8	<0.00003	>78.0%
1,2-Dichlorobenzene	39	443	0.00014	<1.5	<12.8	<0.00003	>75.2%
1,2-Dichloroethane	22	249	0.00008	<1.5	<12.8	<0.00003	>56.0%
1,1-Dichloroethene	ND	NC	NC	ND	NC	NC	NC
1,2-Dichloroethene (total)	116,909	1,328,512	0.41503	352.12	3009.6	0.00807	98.1%
Ethylbenzene	255	2,900	0.00091	<1.5	<12.8	<0.00003	>96.2%
Methylene Chloride	46	523	0.00017	8.32	71.7	0.00019	-16.2%
Tetrachloroethene	95,238	1,082,251	0.33769	193.97	1657.8	0.00444	98.7%
Toluene	24,452	277,859	0.08719	<1.5	<12.8	<0.00003	100.0%
1,1,1-Trichloroethane	536	6,090	0.00190	<1.5	<12.8	<0.00003	>98.2%
Trichloroethene	55,917	635,417	0.19887	218.06	1863.7	0.00499	97.5%
Xylene	446	5,069	0.00158	<1.5	<12.8	<0.00003	>97.8%
Freon 113	4,990	56,705	0.01787	1402.67	11988.6	0.03212	-79.8%
Naphthalene	ND	NC	NC	ND	NC	NC	NC
Total	260,339	2,892,660	1.0619	2,006	16,716	0.05	>93.9%

ND = Not Detected (0.5 ug/ml)

NC = Not Calculated

Freon 113, or 1,1,2-trichloro-1,2,2-trifluoroethane, has a very low heat of combustion value and is rated by the US EPA as one of the hardest organic compounds to oxidize. Methylene chloride in the off-gas may be a product of incomplete combustion (PIC) of tetrachloroethene.

Benzene emission rate was reduced from 0.0004 to 0.00004 lbs/hr, indicating a destruction efficiency of 90.7%. Problems obtaining an appropriate destruction efficiency for benzene, as well as methylene chloride, may be attributed to insufficient loading on the inlet gas stream. Published reports¹ of incinerator testing indicate that low inlet loading rates can contribute to poor destruction efficiencies.

5.5 HCL RESULTS

Samples for Cl⁻ ions in the outlet gas stream were collected by RETEC. Sample results were calculated to represent hydrochloric acid concentrations by multiplying the Cl⁻ concentration by the molecular weight of HCL (36.46 ug/ug-mole) and dividing by the atomic weight of Cl⁻ (35.453 ug/ug-mole). Results are presented in Table 5-5.

Results indicate HCL emissions to be less than 1 lb/hr, specifically 0.006 lbs/hr.

5.6 CONCLUSIONS

Results from the compliance emission monitoring program show an ability of the oxidizer to destroy organic constituents of concern at the Unisys Great Neck, New York facility. Inlet compounds, with a high enough loading rates, indicated greater than 97% destruction efficiency. This includes the organic compounds which make up 88% of the inlet organic concentration to the oxidizer. Hydrochloric acid emissions were less than 1 lb/hr.

Problems occurred from the fact that insufficient organic loading to the oxidizer took place during the monitoring program. Destruction efficiencies for chloroform, 1,2-dichlorobenzene, 1,2-dichloroethane were reported with a greater than sign since they were all calculated using their specific detection limit. Ethylbenzene, 1,1,1-trichloroethane and xylene

TABLE 5-5
HCL EMISSIONS
COMPLIANCE MONITORING PROGRAM
UNISYS CORPORATION
GREAT NECK, NEW YORK

Compound	Detection Limit (ug/L)	Detected Compounds Run 1			Detected Compounds Run 2			Detected Compounds Run 3			Average Levels			Emission Rate (lbs/hr)
		ug/L	ug/samp.	mg/m ³	ug/L	ug/samp.	mg/m ³	ug/L	ug/samp.	mg/m ³	ug/L	ug/samp.	mg/m ³	
Chloride	100	4,000	268.00		4,900	318.50		2,300	147.20		3,733	244.57		
Hydrogen Chloride			275.61	2.36		327.55	2.80		151.38	1.29		251.51	2.15	0.0058

destruction efficiencies were reported above 96%, calculated using their detection limit concentrations as well. Low loading rates for benzene and methylene chloride in the inlet stream may have caused inefficient destruction efficiencies for benzene, as well as methylene chloride in the exhaust stream.

Concentrations of freon 113 detected in the exhaust stream may be attributed to its low heat of combustion or its high resistance to thermal oxidation. The US EPA rates freon 113 as one of the lowest organic compounds for heat of combustion potential and subsequently the hardest to oxidize.

¹Trenholm, A, Hathaway, R, Oberacker, D Products of Incomplete Combustion From Hazardous Waste Incinerators, 1988

Appendix A

Analytical Laboratory Report

REPORT OF ANALYTICAL RESULTS

Case Numbers: D0923-15
D0923-16
D0923-17

Prepared for:

Remediation Technologies, Inc.
9 Pond Lane
Concord, MA 01742
Attn: Rich Roat

Prepared by:

New England Testing Laboratory, Inc.
1254 Douglas Avenue
North Providence, RI 02904

Date Reported: October 3, 1993

Reviewed By: 

Mark H. Bishop
Laboratory Director

NEW ENGLAND TESTING LABORATORY, INC.

1254 Douglas Avenue, North Providence, Rhode Island 02904-5392 • 401-353-3420

Sample Description

The following samples were submitted to New England Testing Laboratory on 23 SEPT 1993:

"Unisys, NY - Air"

D0923-15

Carbon tubes:
"Effluent"

1. Run-1 P-1
2. Run-1 S-1
3. Run-1 P-2
4. Run-1 S-2
5. Run-2 P-1
6. Run-2 S-1
7. Run-2 P-2
8. Run-2 S-2
9. Run-3 P-1
10. Run-3 S-1
11. Run-3 P-2
12. Run-3 S-2
13. Field Blank

D0923-16

Carbon tubes
"Influent"

1. Run-1 P-1
2. Run-1 S-1
3. Run-1 P-2
4. Run-1 S-2
5. Run-2 P-1
6. Run-2 S-1
7. Run-2 P-2
8. Run-2 S-2
9. Run-3 P-1
10. Run-3 S-1
11. Run-3 P-2
12. Run-3 S-2
13. Field Blank

D0923-17

Impinger/Rinse
Composite Sol'ns

1. Run-1
2. Run-2
3. Run-3

Custody records are included in this report. The samples were assigned internal identification codes (case numbers) for laboratory information management purposes. The case numbers for this sample submission appear in bold face type in the column headings above.

Sample Description

The following samples were submitted to New England Testing Laboratory on 23 SEPT 1993:

"Unisys, NY - Air"

D0923-15	D0923-16	D0923-17
Carbon tubes: "Effluent"	Carbon tubes "Influent"	Impinger/Rinse Composite Sol'ns
1. Run-1 P-1	1. Run-1 P-1	1. Run-1
2. Run-1 S-1	2. Run-1 S-1	2. Run-2
3. Run-1 P-2	3. Run-1 P-2	3. Run-3
4. Run-1 S-2	4. Run-1 S-2	
5. Run-2 P-1	5. Run-2 P-1	
6. Run-2 S-1	6. Run-2 S-1	
7. Run-2 P-2	7. Run-2 P-2	
8. Run-2 S-2	8. Run-2 S-2	
9. Run-3 P-1	9. Run-3 P-1	
10. Run-3 S-1	10. Run-3 S-1	
11. Run-3 P-2	11. Run-3 P-2	
12. Run-3 S-2	12. Run-3 S-2	
13. Field Blank	13. Field Blank	

Custody records are included in this report. The samples were assigned an internal identification codes (case numbers) for laboratory information management purposes. The case numbers for this sample submission appear in bold face type in the column headings above.

Analysis/Methods

Carbon tubes:

Carbon tubes were prepared for analysis by NIOSH Method 1500. A carbon disulfide desorption was used for all compounds except those which elute before or during the elution of the carbon disulfide solvent. The remaining compounds were desorbed with toluene.

After desorption, the extracts were analyzed by EPA Method 8240.

Impinger composite solutions:

The impinger solutions were analyzed for chloride content by EPA Method 26 and for volatile organic compounds by EPA Method 8240.

Average carbon charge in sampling tubes:

In addition to performing the analysis detailed above seven random carbon tubes were selected from the batch of tubes used in collecting the samples. The carbon loading in both sections of these tubes was weighed. The results are tabulated in Table #1.

Quality Assurance/Control Statements

All samples were found to be properly preserved/cooled upon receipt. Procedure/calibration checks required by the designated protocols were within control limits.

New York Laboratory ID: 11382

Desorption Efficiency Evaluation

A desorption efficiency evaluation was performed for both the carbon disulfide and toluene extraction/analysis sequences. The results of this evaluation are presented in the following table.

Desorption efficiency

Subject: Volatile Organic Compounds

<u>Compound</u>	<u>Recovery, %</u>
Benzene	88
2-Butanone	68
Chloroform	68
1,2-Dichlorobenzene	77
1,2-Dichloroethane	62
1,2-Dichloroethene (total)	55
Ethylbenzene	87
Methylene chloride	113
Tetrachloroethane	105
Toluene	93
1,1,1-Trichloroethene	89
Trichloroethene	120
Xylene, Total	63

ANALYTICAL RESULTS

TABLE 1**Carbon tube sectional weights**

Replicate	Front	Back
1	0.8761	0.2214
2	0.8397	0.2097
3	0.8454	0.2135
4	0.7962	0.2094
5	0.8431	0.2105
6	0.8712	0.2131
7	0.809	0.2119
Average	0.8401	0.212785714
Standard deviation	0.027139934	0.001745566
Weight for Primary Section	1.27	
Weight for Secondary Section	0.84	

Detection Limits:

Subject: Volatile Organic Compounds

Primary section (Entire P tube + 200 mg section of S tube)

Ave Primary section carbon weight = 1.27g

	Concentration, ug/ml	Desorbition volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Benzene	0.5	3	1.18	1.5
2-Butanone	5	3	11.81	15
Chloroform	0.5	3	1.18	1.5
1,2-Dichlorobenzene	0.5	3	1.18	1.5
1,2-Dichloroethane	0.5	3	1.18	1.5
1,2-Dichloroethene (total)	0.5	3	1.18	1.5
Ethylbenzene	0.5	3	1.18	1.5
Methylene chloride	0.5	3	1.18	1.5
Tetrachloroethane	0.5	3	1.18	1.5
Toluene	0.5	3	1.18	1.5
1,1,1-Trichloroethene	0.5	3	1.18	1.5
Trichloroethene	0.5	3	1.18	1.5
Xylene, Total	0.5	3	1.18	1.5
Freon 113	0.5	3	1.18	1.5
Naphthalene	0.5	3	1.18	1.5

Detection Limits:

Subject: Volatile Organic Compounds

Secondary section (800 mg section of S tube)

Ave Secondary section carbon weight=0.84g

	Concentration, ug/ml	Desorbtion volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Benzene	0.5	2	1.19	1
2-Butanone	5	2	11.90	10
Chloroform	0.5	2	1.19	1
1,2-Dichlorobenzene	0.5	2	1.19	1
1,2-Dichloroethane	0.5	2	1.19	1
1,2-Dichloroethene (total)	0.5	2	1.19	1
Ethylbenzene	0.5	2	1.19	1
Methylene chloride	0.5	2	1.19	1
Tetrachloroethane	0.5	2	1.19	1
Toluene	0.5	2	1.19	1
1,1,1-Trichloroethene	0.5	2	1.19	1
Trichloroethene	0.5	2	1.19	1
Xylene, Total	0.5	2	1.19	1
Freon 113	0.5	2	1.19	1
Naphthalene	0.5	2	1.19	1

Analytical Results:

Run-1 Effluent, Primary Section:

	Concentration, ug/ml	Desorbition volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Benzene	0.5	3	1.18	1.5
1,2-Dichloroethene (total)	57	3	134.65	171
Methylene chloride	5.2	3	12.28	15.6
Tetrachloroethane	50	3	118.11	150
Trichloroethene	76	3	179.53	228
Freon 113	670	3	1582.68	2010

Run-1 Effluent, Secondary Section

	Concentration, ug/ml	Desorbition volume, ml	Carbon Conc. ug/g	Loading, ug/sample
1,2-Dichloroethene (total)	7.2	2	17.14	14.4
Tetrachloroethane	61	2	145.24	122
Trichloroethene	13	2	30.95	26

Analytical Results:

Run-2 Effluent, Primary Section:

	Concentration, ug/ml	Desorbtion volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Benzene	0.5	3	1.18	1.5
1,2-Dichloroethene (total)	72	3	170.08	216
Methylene chloride	3.6	3	8.50	10.8
Tetrachloroethane	53	3	125.20	159
Trichloroethene	90	3	212.60	270
Freon 113	590	3	1393.70	1770

Run-2 Effluent, Secondary Section

	Concentration, ug/ml	Desorbtion volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Tetrachloroethane	0.6	2	1.43	1.2

Analytical Results:

Run-3 Effluent, Primary Section:

	Concentration, ug/ml	Desorbition volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Benzene	0.5	3	1.18	1.5
1,2-Dichloroethene (total)	60	3	141.73	180
Methylene chloride	0.6	3	1.42	1.8
Tetrachloroethane	60	3	141.73	180
Trichloroethene	87	3	205.51	261
Freon 113	130	3	307.09	390

Run-3 Effluent, Secondary Section

	Concentration, ug/ml	Desorbition volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Tetrachloroethane	0.6	2	1.43	1.2
Freon 113	19	2	45.24	38

Analytical Results:

Run-1 Influent, Primary Section:

	Concentration, ug/ml	Desorbtion volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Benzene	34	3	80.31	102
Chloroform	9.5	3	22.44	28.5
1,2-Dichlorobenzene	10	3	23.62	30
1,2-Dichloroethane	4.3	3	10.16	12.9
1,2-Dichloroethene (total)	20000	3	47244.09	60000
Ethylbenzene	72	3	170.08	216
Methylene chloride	11	3	25.98	33
Tetrachloroethane	35000	3	82677.17	105000
Toluene	6800	3	16062.99	20400
1,1,1-Trichloroethene	162	3	382.68	486
Trichloroethene	22100	3	52204.72	66300
Xylene, Total	94	3	222.05	282
Freon 113	1200	3	2834.65	3600

Run-1 Influent, Secondary Section

	Concentration, ug/ml	Desorbtion volume, ml	Carbon Conc. ug/g	Loading, ug/sample
1,2-Dichloroethene (total)	0.8	2	1.90	1.6
Tetrachloroethane	16	2	38.10	32
Trichloroethene	7.5	2	17.86	15

Analytical Results:

Run-3 Influent, Primary Section:

	Concentration, ug/ml	Desorbition volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Benzene	38	3	89.76	114
Chloroform	11	3	25.98	33
1,2-Dichlorobenzene	11	3	25.98	33
1,2-Dichloroethane	5	3	11.81	15
1,2-Dichloroethene (total)	26700	3	63070.87	80100
Ethylbenzene	77	3	181.89	231
Methylene chloride	20	3	47.24	60
Tetrachloroethane	35000	3	82677.17	105000
Toluene	7700	3	18188.98	23100
1,1,1-Trichloroethene	169	3	399.21	507
Trichloroethene	22000	3	51968.50	66000
Xylene, Total	95	3	224.41	285
Freon 113	1910	3	4511.81	5730

Run-3 Influent, Secondary Section

	Concentration, ug/ml	Desorbition volume, ml	Carbon Conc. ug/g	Loading, ug/sample
1,2-Dichloroethene (total)	6.3	2	15.00	12.6
Tetrachloroethane	15	2	35.71	30
Trichloroethene	6.7	2	15.95	13.4


Analytical Results:

Run-2 Influent, Primary Section:

	Concentration, ug/ml	Desorbtion volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Benzene	32	3	75.59	96
Chloroform	9.3	3	21.97	27.9
1,2-Dichlorobenzene	9	3	21.26	27
1,2-Dichloroethane	4.3	3	10.16	12.9
1,2-Dichloroethene (total)	17600	3	41574.80	52800
Ethylbenzene	73	3	172.44	219
Methylene chloride	21	3	49.61	63
Tetrachloroethane	30000	3	70866.14	90000
Toluene	8240	3	19464.57	24720
1,1,1-Trichloroethene	146	3	344.88	438
Trichloroethene	23000	3	54330.71	69000
Xylene, Total	92	3	217.32	276
Freon 113	1880	3	4440.94	5640

Run-2 Influent, Secondary Section

	Concentration, ug/ml	Desorbtion volume, ml	Carbon Conc. ug/g	Loading, ug/sample
1,2-Dichloroethene (total)	9	2	21.43	18
Tetrachloroethane	8	2	19.05	16
Trichloroethene	3	2	7.14	6



Analytical Results:

Sample

Field Bias Blank-Effluent: No compounds detected

Field Bias Blank-Influent

	Concentration, ug/ml	Desorbtion volume, ml	Carbon Conc. ug/g	Loading, ug/sample
Tetrachloroethane	0.8	2	1.52	1.6

Note: Carbon Conc. based on 1.05 g carbon per tube

Detection Limits

Impinger solutions:

	Conc. ug/l	Vol, l (nominal)	Loading ug/sample
Benzene	1	0.065	0.065
2-Butanone	10	0.065	0.65
Chloroform	1	0.065	0.065
1,2-Dichlorobenzene	1	0.065	0.065
1,2-Dichloroethane	1	0.065	0.065
1,2-Dichloroethene (total)	1	0.065	0.065
Ethylbenzene	1	0.065	0.065
Methylene chloride	3	0.065	0.195
Tetrachloroethane	1	0.065	0.065
Toluene	1	0.065	0.065
1,1,1-Trichloroethene	1	0.065	0.065
Trichloroethene	1	0.065	0.065
Xylene, Total	1	0.065	0.065
Freon 113	1	0.065	0.065
Naphthalene	1	0.065	0.065
Chloride	100	0.065	6.5

Analytical Results

Impinger solutions:

Run-1	Conc. ug/l	Vol, l	Loading ug/sample
Chloroform	2.2	0.067	0.1474
1,2-Dichloroethene (total)	2.9	0.067	0.1943
Methylene chloride	7.3	0.067	0.4891
Tetrachloroethane	1.3	0.067	0.0871
1,1,1-Trichloroethene	2.1	0.067	0.1407
Trichloroethene	2.1	0.067	0.1407
Chloride	4000	0.067	268

Analytical Results

Impinger solutions:

Run-2	Conc. ug/l	Vol, l	Loading ug/sample
Chloroform	3	0.065	0.195
1,2-Dichloroethene (total)	2.9	0.065	0.1885
Methylene chloride	10	0.065	0.65
Tetrachloroethane	1.4	0.065	0.091
1,1,1-Trichloroethene	1.2	0.065	0.078
Chloride	4900	0.065	318.5

Analytical Results

Impinger solutions:

Run-3	Conc. ug/l	Vol, l	Loading ug/sample
Chloroform	2.7	0.064	0.1728
1,2-Dichloroethene (total)	3.8	0.064	0.2432
Methylene chloride	8.1	0.064	0.5184
Tetrachloroethane	1.5	0.064	0.096
Chloride	2300	0.064	147.2

CUSTODY RECORDS

DO923-15

RETEC
REMEDICATION
TECHNOLOGIES INC

REMEDICATION TECHNOLOGIES
Damonmill Square
9 Pond Lane
Concord, MA 01742

DO923-16

RE/EC
REMEDICATION
TECHNOLOGIES INC.

REMEDICATION TECHNOLOGIES
Damonmill Square
9 Pond Lane
Concord, MA 01742

Appendix B

Field Data Sheets

REMEDATION TECHNOLOGIES, INC
FIELD DATA SHEET

INLET GAS STREAM RECORD

Facility Name: Unisys
Date: 9/16/93
Run Number: 1

Ambient Temp: 72°F
Barometric Pressure: 29.29 inches
Static Pressure :PST -0.25 inches

GAS FLOW READINGS

Dry Bulb Reading: ND
Wet Bulb Reading: ND
Impinger Volume (moisture: MD)
Start zero
End zero

Stack Gas Temp: TS
Start 55 °F
End 55 °F

Formulas:

Gas Velocity (afpm) = VS
 $VS = 5130^a \times C_p \times \text{avg SDE} \times [1/PS \times MW]^{0.5}$
 C_p = pitot tube coefficient
 $\text{avgSDE} = [\text{avg.pressure}]^{0.5} \times [TS + 460]^{0.5}$
 $PS = PB + - \text{avg.PST}$
 $MW = MWD^b \times MD + 18(1-MD)$

Gas Flow Rate (acfm) = Q_a
 $Q_a = VS/A_s$
 A_s = Area of Stack (ft²)

Results:

Gas Velocity Run 1 905.44 afpm
Gas Flow Rate: 78.97 acfm
Gas Flow Rate: 2.24 m³/min

Pitot Tube Type: standard
Stack Dimensions: 4 inches

Initial Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.2	0.050
2	14.7%	0.6	0.055
3	29.5%	1.2	0.050
4	70.5%	2.8	0.045
5	85.3%	3.4	0.055
6	95.6%	3.8	0.060
Average			0.053

Final Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.2	0.045
2	14.7%	0.6	0.050
3	29.5%	1.2	0.055
4	70.5%	2.8	0.050
5	85.3%	3.4	0.050
6	95.6%	3.8	0.060
Average			0.052

Run Avg.	0.052
AvgSTD	5.179
PS	29.27
MW	28.83

REMEDATION TECHNOLOGIES, INC
FIELD DATA SHEET

OUTLET GAS STREAM RECORD

Facility Name: Unisys
Date: 9/16/93
Run Number: 1

Ambient Temp: 62 °F
Barometric Pressure: 29.29 inches
Static Pressure :PST 0.2 inches

GAS FLOW READINGS

Dry Bulb Reading: ND
Wet Bulb Reading: ND
Impinger Volume (moisture: MD)
Start zero
End zero

Stack Gas Temp: TS
Start 136 °F
End 136 °F

Formulas:

Gas Velocity (afpm) = VS
 $VS = 5130^a \times C_p \times \text{avg SDE} \times [1/PS \times MW]^{0.5}$
 C_p = pitot tube coefficient
 $\text{avgSDE} = [\text{avg.pressure}]^{0.5} \times [TS + 460]^{0.5}$
 $PS = PB + - \text{avg.PST}$
 $MW = MWD^b \times MD + 18(1-MD)$

Gas Flow Rate (acfm) = Q_a
 $Q_a = VS/A_s$
 A_s = Area of Stack (ft²)

Results:
 Gas Velocity Run 2 2049.43 afpm
 Gas Flow Rate: 715.02 acfm
 Gas Flow Rate: 20.25 m³/min

Pitot Tube Type: standard
Stack Dimensions: 8 inches

Initial Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.4	0.200
2	14.7%	1.2	0.230
3	29.5%	2.4	0.240
4	70.5%	5.6	0.240
5	85.3%	6.8	0.240
6	95.6%	7.6	0.230
Average			0.230

Final Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.4	0.220
2	14.7%	1.2	0.240
3	29.5%	2.4	0.240
4	70.5%	5.6	0.230
5	85.3%	6.8	0.230
6	95.6%	7.6	0.230
Average			0.232

Run Avg.	0.231
AvgSTD	11.729
PS	29.30
MW	28.83

REMEDATION TECHNOLOGIES, INC
FIELD DATA SHEET

INLET GAS STREAM RECORD

Facility Name: Unisys
Date: 9/16/93
Run Number: 2

Ambient Temp: 72 °F
Barometric Pressure: 29.29 inches
Static Pressure :PST -0.2 inches

GAS FLOW READINGS

Dry Bulb Reading: ND
Wet Bulb Reading: ND
Impinger Volume (moisture: MD)
Start zero
End zero

Stack Gas Temp: TS
Start 55 °F
End 55 °F

Formulas:

Gas Velocity (afpm) = VS
 $VS = 5130^a \times C_o \times \text{avg SDE} \times [1/PS \times MW]^{0.5}$
 C_o = pitot tube coefficient
 $\text{avgSDE} = [\text{avg.pressure}]^{0.5} \times [TS + 460]^{0.5}$
 $PS = PB + - \text{avg.PST}$
 $MW = MWD^b \times MD + 18(1-MD)$

Gas Flow Rate (acfm) = Q_a
 $Q_a = VS/A_s$
 A_s = Area of Stack (ft²)

Results:
Gas Velocity Run 2 1004.93 afpm
Gas Flow Rate: 87.65 acfm
Gas Flow Rate: 2.48 m³/min

Pitot Tube Type: standard
Stack Dimensions: 4 inches

Initial Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.2	0.070
2	14.7%	0.6	0.070
3	29.5%	1.2	0.065
4	70.5%	2.8	0.055
5	85.3%	3.4	0.070
6	95.6%	3.8	0.070
Average			0.067

Final Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.2	0.060
2	14.7%	0.6	0.070
3	29.5%	1.2	0.060
4	70.5%	2.8	0.060
5	85.3%	3.4	0.055
6	95.6%	3.8	0.065
Average			0.062

Run Avg.	0.064
AvgSTD	5.749
PS	29.28
MW	28.83

REMEDATION TECHNOLOGIES, INC FIELD DATA SHEET

OUTLET GAS STREAM RECORD

Facility Name: Unisys
Date: 9/16/93
Run Number: 2

Ambient Temp: 68 °F
Barometric Pressure: 29.29 inches
Static Pressure :PST 0.25 inches

GAS FLOW READINGS

Dry Bulb Reading: ND
Wet Bulb Reading: ND
Impinger Volume (moisture: MD)
Start zero
End zero

Stack Gas Temp: TS
Start 130 °F
End 130 °F

Formulas:

Gas Velocity (afpm) = VS
 $VS = 5130^a \times C_p \times \text{avg SDE} \times [1/PS \times MW]^{0.5}$
 C_p = pitot tube coefficient
 $\text{avgSDE} = [\text{avg.pressure}]^{0.5} \times [TS + 460]^{0.5}$
 $PS = PB + - \text{avg.PST}$
 $MW = MWD^b \times MD + 18(1-MD)$

Gas Flow Rate (acfm) = Q_a
 $Q_a = VS/A_s$
 A_s = Area of Stack (ft²)

Results:
Gas Velocity Run 2: 2053.63 afpm
Gas Flow Rate: 716.49 acfm
Gas Flow Rate: 20.29 m³/min

Pitot Tube Type: standard
Stack Dimensions: 8 inches

Initial Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.4	0.210
2	14.7%	1.2	0.230
3	29.5%	2.4	0.230
4	70.5%	5.6	0.230
5	85.3%	6.8	0.240
6	95.6%	7.6	0.250
Average			0.232

Final Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.4	0.240
2	14.7%	1.2	0.240
3	29.5%	2.4	0.230
4	70.5%	5.6	0.230
5	85.3%	6.8	0.240
6	95.6%	7.6	0.240
Average			0.237

Run Avg.	0.234
AvgSTD	11.754
PS	29.31
MW	28.83

REMEDATION TECHNOLOGIES, INC
FIELD DATA SHEET

INLET GAS STREAM RECORD

Facility Name: Unisys
Date: 9/16/93
Run Number: 3

Ambient Temp: 72 °F
Barometric Pressure: 29.29 inches
Static Pressure :PST -0.22 inches

GAS FLOW READINGS

Dry Bulb Reading: ND
Wet Bulb Reading: ND
Impinger Volume (moisture: MD)
Start zero
End zero

Pitot Tube Type: standard
Stack Dimensions: 4 inches

Stack Gas Temp: TS
Start 55 °F
End 55 °F

Formulas:

Gas Velocity (afpm) = VS
 $VS = 5130^a \times C_p \times \text{avg SDE} \times [1/PS \times MW]^{0.5}$
 C_p = pitot tube coefficient
 $\text{avgSDE} = [\text{avg.pressure}]^{0.5} \times [TS + 460]^{0.5}$
 $PS = PB + \text{avg.PST}$
 $MW = MWD^b \times MD + 18(1-MD)$

Gas Flow Rate (acfm) = Q_a
 $Q_a = VS/A_s$
 A_s = Area of Stack (ft²)

Results:
 Gas Velocity Run 1: 961.61 afpm
 Gas Flow Rate: 83.87 acfm
 Gas Flow Rate: 2.38 m³/min

Initial Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.2	0.060
2	14.7%	0.6	0.060
3	29.5%	1.2	0.055
4	70.5%	2.8	0.050
5	85.3%	3.4	0.060
6	95.6%	3.8	0.060
Average			0.058

Final Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.2	0.055
2	14.7%	0.6	0.065
3	29.5%	1.2	0.065
4	70.5%	2.8	0.060
5	85.3%	3.4	0.055
6	95.6%	3.8	0.060
Average			0.060

Run Avg.	0.059
AvgSTD	5.501
PS	29.27
MW	28.83

REMEDATION TECHNOLOGIES, INC
FIELD DATA SHEET

OUTLET GAS STREAM RECORD

Facility Name: Unisys
Date: 9/16/93
Run Number: 3

Ambient Temp: 72°F
Barometric Pressure: 29.29 inches
Static Pressure :PST 0.22 inches

GAS FLOW READINGS

Dry Bulb Reading: ND
Wet Bulb Reading: ND
Impinger Volume (moisture: MD)
Start zero
End zero

Stack Gas Temp: TS
Start 137 °F
End 0 °F

Formulas:

Gas Velocity (afpm) = VS
 $VS = 5130^a \times C_p \times \text{avg SDE} \times [1/PS \times MW]^{0.5}$
 C_p = pitot tube coefficient
 $\text{avgSDE} = [\text{avg.pressure}]^{0.5} \times [TS + 460]^{0.5}$
PS = PB + - avg.PST
 $MW = MWD^b \times MD + 18(1-MD)$

Gas Flow Rate (acfm) = Q_a
 $Q_a = VS/A_s$
 A_s = Area of Stack (ft²)

Results:
Gas Velocity Run 3 2054.80 afpm
Gas Flow Rate: 716.90 acfm
Gas Flow Rate: 20.30 m³/min

Pitot Tube Type: standard
Stack Dimensions: 8 inches

Initial Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.4	0.210
2	14.7%	1.2	0.220
3	29.5%	2.4	0.240
4	70.5%	5.6	0.250
5	85.3%	6.8	0.240
6	95.6%	7.6	0.230
Average			0.232

Final Traverse Points	% Distance of diameter	Measurement Δ point (inch)	Pressure Readings
1	4.4%	0.4	0.000
2	14.7%	1.2	0.000
3	29.5%	2.4	0.000
4	70.5%	5.6	0.000
5	85.3%	6.8	0.000
6	95.6%	7.6	0.000
Average			0.000

Run Avg.	0.232
AvgSTD	11.760
PS	29.31
MW	28.83