

Michael Quinlan
Senior Program Manager
Site Investigation & Remediation



June 20, 2025

Mr. Tracey Garland
Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation
625 Broadway
Albany, New York 12233-7014

**Summary of Intrusive Activities
East Garden City Former Stewart Avenue Holder Station
East Garden City, New York
Site No. 130120
Order on Consent Index No. A2-0552-0606**

Dear Mr. Garland:

This letter provides a summary to the New York State Department of Environmental Conservation (NYSDEC) of intrusive activities conducted at the East Garden City Former Stewart Avenue Holder Station Site (the Site).

On May 21, 2025, New York Power Authority (NYPA) retained Champion Specialty Services Provider (Champion) and Elecnor Hawkeye LLC (Hawkeye) to advance one geotechnical soil boring on the west side of the substation operated by Public Service Enterprise Group Long Island (PSEG-LI). **Figure 1** depicts the approximate boring location. This boring is associated with a larger project that is being conducted on the adjoining NYPA property to the west of the PSEG-LI substation.

National Grid's Site Investigation and Remediation (SIR) consultant, GEI Consultants Engineering, Geology, Architecture & Landscape Architecture (GEI) was on-site during intrusive activities to log completed activities, perform soil inspections (visual and olfactory and screening with a photoionization detector [PID]), and conduct Community Air Monitoring (CAMP) per the requirements of the Site Management Plan (SMP) for the Site.

The boring was advanced via vacuum truck to 10 feet below grade surface (bgs) and soil samples were collected by others at 5 and 10 feet bgs for soil resistivity. All soil removed was used as backfill in the borehole.

No soil impacts were noted by GEI. In addition, no exceedances of particulate matter or volatile organic compounds were noted during the intrusive activities. Air monitoring data can be provided upon request.

If you have any questions, feel free to contact me at (516) 220-4363 or by email at michael.quinlan@nationalgrid.com.

Very truly yours,

A handwritten signature in black ink, appearing to read "Chi Min", written over a light blue horizontal line.

101

**Summary of Intrusive Activities
East Garden City Former Stewart Avenue Holder Station
East Garden City, New York**

Christopher Morris, P.G.
On behalf of Michael Quinlan

Attachment
cc: J. Mitchell (National Grid)






Photo 1: Location of NYPA borehole



Photo 2: View of soil pile removed from the borehole location



Photo 3: View of the borehole backfilled using the material excavated



Photo 4: Location restored to original surface