

FACILITY INFORMATION REPORT

Facility: Tarrytown Municipal Housing Authority 50 White Street Tarrytown, NY 10591 Operator: Wilfredo Gonzalez, Jr. Operator phone: Emergency: Wilfredo Gonzalez, Jr. Emergency phone: (914) 631-1991	PBS no.: 3-600333 Reg. issued: 08/08/2008 Reg. expires: 09/23/2013 Last inspected: 08/12/2013 Vapor recovery ID: 3-600333 Last Stage II test: Next Stage II test due: Site Type: Apartment/Office Building
Owner: Tarrytown Municipal Housing Authority 50 White Street Tarrytown, NY 10591 Type of ownership: Phone:	Mail: Tarrytown Municipal Housing Authority 50 White Street Tarrytown, NY 10591 Phone: (914) 631-1991 Email:

TankID	1	2	
Tank Location	5. Underground	3. Aboveground on saddles,legs,stilts,racks or cradle	
Status	1. In-Service	1. In-Service	
Install	05/01/1994	02/01/1992	
Capacity	6000	550	
Product	2. No. 4 fuel oil	6. Diesel	
%			
Tank Type	1. Steel/Carbon steel/Iron	1. Steel/Carbon steel/Iron	
Tank Internal Protection	4. Glass liner	99. Other	
Tank External Protection	7. Jacketed (tank) 2. Sacrificial Anode (no retrofit)	99. Other	
Tank Secondary Containment	4. Double-Walled (underground only)	1. Diking (aboveground only)	
Tank Leak Detection	1. Electronic Interstitial Monitoring	99. Other	
Tank Overfill Prevention	2. High Level Alarm	2. High Level Alarm	
Spill Prevention	1. Catch Basin	1. Catch Basin	
Dispenser	2. Suction	2. Suction	
Piping Location	2. Underground/on Ground	1. Aboveground	
Piping Type	2. Galvanized Steel	2. Galvanized steel	
Piping External Protection		99. Other	
Piping Secondary Containment			
Piping Leak Detection			
Last Test			
Next Test Due	NTR	NTR	
Closed			

TankID			
Tank Location			
Status			
Install			
Capacity			
Product			
%			
Tank Type			
Tank Internal Protection			
Tank External Protection			
Tank Secondary Containment			
Tank Leak Detection			
Tank Overfill Prevention			
Spill Prevention			
Dispenser			
Piping Location			
Piping Type			
Piping External Protection			
Piping Secondary Containment			
Piping Leak Detection			
Last Test			
Next Test Due			
Closed			

