

THE MORIE CO.
Laboratory Report

CUSTOMER: CAMP DRESSER & MCKEE
P.O. NUM: S.O.
GRADE: #0 W.G.
DATE: 08-21-1985
T.C. NO: 8631-85

U.S. STANDARD SEIVE	CUM %	% RET	% PASS
#4	0.0	0.0	100.0
#6	0.0	0.0	100.0
#8	0.0	0.0	100.0
#10	0.0	0.0	100.0
#12	0.0	0.0	100.0
#14	0.0	0.0	100.0
#16	2.0	2.0	98.0
#18	14.1	12.1	85.9
#20	53.9	39.8	46.1
#25	84.4	30.5	15.6
#30	95.0	10.6	5.0
#35	99.4	4.4	0.6
#40	99.8	0.4	0.2
#50	100.0	0.2	0.0
#70	100.0	0.0	0.0
PAN	100.0	0.0	0.0

EFFECTIVE SIZE MM 0.647
UNIFORMITY CO-EFF 1.386
NOTES: SAMPLE
TESTED BY: RC