

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

Division of Water, Bureau of Permits
625 Broadway, Albany, New York 12233-3505
P: (518) 402-8111 | F: (518) 402-9029
www.dec.ny.gov

MEMORANDUM

TO: Sarah Saucier, Section A, Remedial Bureau E, DER
FROM: Donald E. Canestrari, Chief, Central Permit Section, BWP, DOW *DeCanestrari*
SUBJECT: Dzus Fastener Remedial Cleanup, Site Number 1-52-033 - Modification
DATE: November 8, 2019

This modification is in response to your e-mail dated November 7, 2019 requesting a change to the iron limit. Data submitted demonstrates elevated ambient iron levels in the discharge receiving water. Therefore, based on the average of the ambient iron values reported, the iron effluent limit has been changed to 3.5 mg/L.

The DOW does not have any regulatory authority over a discharge from a State, PRP, or Federal Superfund Site. DER will be responsible for ensuring compliance with the attached effluent limitations and monitoring requirements, and approval of all engineering submissions. Footnote 1 identifies the appropriate DER Section Chief as the place to send all effluent results, engineering submissions, and modification requests. The Regional Water Engineer should be kept apprised of the status of this discharge and, in accordance with the attached criteria, receive a copy of the effluent results for informational purposes.

If you have any questions, please call me at 518-402-8138.

Attachment (Effluent Limitations and Monitoring Requirements)

ec: Cathy Haas, Region 1 (w/attach)
Mike Cruden, DER



Department of
Environmental
Conservation

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning January 1, 2019 and lasting until January 1, 2021 the discharges from the wastewater treatment facility to Willets Creek water index number AO-GSB-205 and Lake Capri, water index number AO-GSB-205-P934. Both waterbodies are Class C and discharges shall be limited and monitored by the operator as specified below:

Outfall Number and Parameter	Discharge Limitations		Units	Minimum Monitoring Requirements	
	Monthly Avg.	Daily Max		Measurement Frequency	Sample Type
Outfall 001 – Discharges from Stream Dewatering, Sediment Dewatering, and Water Collected during Remedial Activities. Discharge to Willets Creek at Latitude: 40.704626, Longitude -73.300187					
Flow		1.0	MGD	Continuous	Recorder
pH (range)	6.5-8.5		SU	Daily	Grab
Turbidity		10	NTU	Continuous	Recorder
Aluminum, Total		6.1	mg/l	Weekly	Grab
Cadmium, Total		0.007	mg/l	Weekly	Grab
Chromium, Total		0.24	mg/l	Weekly	Grab
Cyanide, Free		0.032	mg/l	Weekly	Grab
iron, Total		3.5	mg/l	Weekly	Grab
Lead, Total		0.01	mg/l	Weekly	Grab
Zinc, Total		0.26	mg/l	Weekly	Grab

Outfall Number and Parameter	Discharge Limitations		Units	Minimum Monitoring Requirements	
	Monthly Avg.	Daily Max		Measurement Frequency	Sample Type
Outfall 002 – Discharges from Stream Dewatering, Sediment Dewatering, and Water Collected during Remedial Activities. Discharge to Willets Creek at Latitude: 40.699423, Longitude -73.300826					
Flow		1.0	MGD	Continuous	Recorder
pH (range)	6.5-8.5		SU	Daily	Grab
Turbidity		10	NTU	Continuous	Recorder
Aluminum, Total		6.1	mg/l	Weekly	Grab
Cadmium, Total		0.007	mg/l	Weekly	Grab
Chromium, Total		0.24	mg/l	Weekly	Grab
Cyanide, Free		0.032	mg/l	Weekly	Grab
Iron, Total		3.5	mg/l	Weekly	Grab
Lead, Total		0.01	mg/l	Weekly	Grab
Zinc, Total		0.26	mg/l	Weekly	Grab

Outfall Number and Parameter	Discharge Limitations		Units	Minimum Monitoring Requirements	
	Monthly Avg.	Daily Max		Measurement Frequency	Sample Type
Outfall 003 – Discharges from Stream Dewatering, Sediment Dewatering, and Water Collected during Remedial Activities. Discharge to Lake Capri at Latitude: 40.697984, Longitude -73.300957					
Flow		1.44	MGD	Continuous	Recorder
pH (range)	6.5-8.5		SU	Daily	Grab
Turbidity		10	NTU	Continuous	Recorder
Aluminum, Total		6.1	mg/l	Weekly	Grab
Cadmium, Total		0.005	mg/l	Weekly	Grab
Chromium, Total		0.18	mg/l	Weekly	Grab
Cyanide, Free		0.024	mg/l	Weekly	Grab
Iron, Total		3.5	mg/l	Weekly	Grab
Lead, Total		0.007	mg/l	Weekly	Grab
Zinc, Total		0.19	mg/l	Weekly	Grab

Additional Conditions:

1. Discharge is only valid for one discharge point during remedial activities. If remediation and discharge will result in simultaneous discharges from multiple outfalls, a request to modify the discharge criteria must be submitted to the Department two (2) months prior to commencing simultaneous discharges.
2. Discharge is not authorized until an engineering submission showing the method of treatment is approved by the Department. The discharge rate may not exceed the effective or design treatment system capacity. All monitoring data, engineering submissions and modification requests must be submitted to:

Sarah Saucier, PE
Division of Environmental Remediation
NYSDEC, 625 Broadway, Albany, New York 12233- 5060, 518-402-9819

With a copy sent to:

Regional Water Engineer, Region 1
Cathy Haas, PE
SUNY @ Stony Brook
50 Circle Road
Stony Brook, NY 11790

3. Only site generated wastewater is authorized for treatment and discharge.
4. Authorization to discharge is valid only for the period noted above but may be renewed if appropriate. A request for renewal must be received 6 months prior to the expiration date to allow for a review of monitoring data and reassessment of monitoring requirements.
5. Any use of corrosion/scale inhibitors, biocidal-type compounds, or other water treatment chemicals used in the treatment process must be approved by the department prior to use.
6. This discharge and administration of this discharge must comply with the substantive requirements of 6NYCRR Part 750.

