


**Lawler,
Matusky
& Skelly
Engineers LLP**

Environmental Science & Engineering Consultants



June 6, 2000
File No. 650-395

Mr. Carl Hoffman
New York State Department of Environmental Conservation
Operation and Maintenance Section - Bureau of Hazardous Site Control
Division of Environmental Remediation
50 Wolf Road
Albany, New York 12233-7010

Re: **Servall Laundry Site
Bay Shore, Suffolk County
Site No. 1-52-077, Work Assignment No. D002676-39.2
Monthly Report - APRIL 2000**

Dear Mr. Hoffman:

Attached please find the Monthly Report for April 2000, the sixth monthly report submitted under Work Assignment No. D002676-39.2.

The plant operated at an average flow rate of 159 gpm for the month and a total volume of 3,862,440 gallons of water was processed. The influent VOC concentration was 145.45 ppb; the plant removed approximately 97.8% of the influent VOCs. Effluent concentrations of total VOCs, manganese and iron were within discharge limitations. Influent compliance data has revealed that MTBE is present at concentrations of 8.8 ppb. The presence of MTBE, a gasoline additive, is indicative of a gasoline spill and not typically found at a site impacted by dry cleaner operations. This may indicate that groundwater contained within the extraction system's radius of influence is impacted by a nearby gasoline spill. Effluent MTBE concentration in April 2000 was 0.5 ppb. Currently, there is no guidance value for MTBE concentrations in groundwater. Historically, a guidance concentration of 50 ppb was used but this is under re-evaluation. Pursuant to our conversation last week, LMS and H2M are proceeding with an investigation to determine the cause of the frequent air compression shutdowns. As soon as results are available we will forward them to you.

LMS will continue to provide task management of the plant operations until September 30, 2000 unless otherwise directed by the NYSDEC. If you have any questions or comments please feel free to contact me at x 249.

Very Truly Yours,

Robert DeGiorgio, P.E.
Project Manager

Enclosures

Servall Laundry Site
Site No. 1-52-077
Groundwater Remediation
Operation and Maintenance

Monthly Operations Report

April-00

LAWLER, MATUSKY & SKELLY ENGINEERS LLP
Environmental Science & Engineering Consultants
One Blue Hill Plaza
Pearl River, New York 10965

650-395

Servall Laundry Site
Site No. 1-52-077
Groundwater Remediation
Operation and Maintenance

Monthly Operations Report

Summary Report
Compliance Sampling
Graphical Data Trends
Summary Notes and Action Items
H2M Reports

LAWLER, MATUSKY & SKELLY ENGINEERS LLP
Environmental Science & Engineering Consultants
One Blue Hill Plaza
Pearl River, New York 10965

650-395

Servall Laundry
Site No. 1-52-077
Groundwater Remediation -2000 Operation and Maintenance
Summary Report

Plant Operating Data	unit	Monthly Average (to date)	January-00	February-00	March-00	April-00	Total 2000
Flow Rate	gpm	108	160.44	160.39	160.2	158.57	-
Gallons processed	gallons	3,724,217	4,154,420	5,390,400	3,744,760	3,862,440	17,152,020
Percent of Time Operating	%	57%	62%	86%	56%	60%	-
Influent VOC concentration	ug/L	118	63.9	100.3	150.6	145.45	-
Effluent VOC concentration	ug/L	1.94	1.5	2	6.1	3.22	-
VOC removal efficiency	%	97.5%	97.7%	98.0%	95.9%	97.8%	-
Pounds of VOCs Treated	lb	4.4	2.16	4.42	4.51	4.58	16
Influent Total Iron	ug/L	522	1270	308	689	426	-
Influent Total Manganese	ug/L	442	593	542	517	499	-
Effluent Total Iron	ug/L	76	100	32	32	75.5	-
Effluent Total Manganese	ug/L	561	583	533	492	506	-
Total Iron removal efficiency	%	77.6%	92.1%	89.6%	95.4%	82.3%	-
Total Manganese removal efficiency	%	1.1%	1.7%	1.7%	4.8%	-1.4%	-
Sodium hypochlorite (12%)	lb	676	500	500	500	500	2,000
Polymer	lb	33	0	0	0	0	0
Hydrogen peroxide (50%)	lb	3453	4538	4538	4538	4538	18,153
Caustic (50%)	lb	1581	5534	5534	5534	5534	22,134
Hydrochloric Acid	lb	86	0	0	0	0	0
Cartridge Filters	ea	1	3	0	0	0	3
Spare Parts or other	at cost	\$582	\$196	\$0	\$0	\$0	\$196
Consumables cost	\$	\$3,126	\$4,162	\$3,516	\$3,516	\$3,516	\$14,710
Sludge generated (20% dewatered)	gal	25	25	25	25	25	100
Sludge disposed of	gal	24	0	0	0	0	0
Sludge disposal cost	\$	\$66.17	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00
Gas (estimated)	therms	871	800	800	800	800	3,200
Electricity (estimated)	kw hr	40908	37,800	37,800	37,800	37,800	151,200
Utilities cost	\$	\$3,987	\$3,682	\$3,682	\$3,682	\$3,682	\$14,728
Compliance Sampling	at cost	\$969.09	\$655.50	\$650.00	\$650.00	\$650.00	\$2,606
Redevelopment	at cost	\$2,688	\$0.00	\$0.00	\$0.00	\$0.00	\$0
Operator	Month	\$9,661	\$5,790	\$6,500	\$4,000	\$5,000	\$21,290
Management & Engineering	at cost	\$3,244	\$931	\$1,239.99	\$1,200.00	\$856.00	\$4,227
Services cost	\$	\$16,562	\$7,376	\$8,390	\$5,850	\$6,506	\$28,122
Operating Cost (Estimated)	\$	\$23,740	\$15,221	\$15,588	\$13,048	\$13,704	\$57,561

Servall Laundry Site
Site No. 1-52-077
Groundwater Remediation - Operation and Maintenance

2000 Compliance Sampling

Influent										
Constituents	Discharge Criteria	units	January	February	March	April	May	June		
Chlorobenzene	5	ug/L	U			U	U			
Vinyl Chloride	2	ug/L	U			U	U			
1,1-Dichloroethene	5	ug/L	0.1	J		U	U			
Trichloroethene	5	ug/L	1	1	1	1	1			
Tetrachloroethene	5	ug/L	54	E	87	E	130	E		
1,1,1-Trichloroethane	5	ug/L	0.2	J		U	U			
Toluene	5	ug/L	U	0.5		U	U			
cis-1,2-Dichloroethene	5	ug/L	0.3	J	0.6	0.8	0.6			
trans-1,2-Dichloroethene	5	ug/L	U			U	U			
Methylene Chloride	N/A	ug/L	U	1.6	JD	U	2.6	JDB		
1,1,1-Trichloroethane	N/A	ug/L	0.5			U	0.4	J		
Chloroform	N/A	ug/L	0.2	J	0.2	U	1.9	JDB		
Bromodichloromethane	N/A	ug/L	U			U	U			
Trichlorofluoromethane	N/A	ug/L	U			U	U			
Methyl tert-Butyl Ether	N/A	ug/L	7.6	9.4	8.8	8.8	J			
Total VOCs	N/A	ug/L	63.9	100.3	150.6	145.5				
Iron (total)	600 ⁴	ug/L	1270	308	689	426				
Manganese (total)	600 ⁴	ug/L	593	542	517	499				
Alkalinity	N/A	mg/L	27	29	16	15				
Total Suspended Solids	N/A	mg/L	10	U	10	U	5	U		
Total Solids	N/A	mg/L	159	162	145	156				
Effluent										
Constituents	Discharge Criteria	units	January	February	March	April	May	June		
Chlorobenzene	5	ug/L	U			U	U			
Vinyl Chloride	2	ug/L	U			U	U			
1,1-Dichloroethene	5	ug/L	U			U	U			
Trichloroethene	5	ug/L	U			U	U			
Tetrachloroethene	5	ug/L	0.7	1.4	4.2	2.4				
1,1-Dichloroethane	5	ug/L	U			U	U			
Toluene	5	ug/L	U	0.2	JB	U	U			
cis-1,2-Dichloroethene	5	ug/L	U			U	U			
trans-1,2-Dichloroethene	5	ug/L	U			U	U			
Methylene Chloride	N/A	ug/L	U			U	0.2	JB		
1,1,1-Trichloroethane	N/A	ug/L	0.3	J		U	U			
Chloroform	N/A	ug/L	0.3	J	0.7	B	0.1	JB		
Bromodichloromethane	N/A	ug/L	0.2	J	0.4	J	U			
Methyl tert-Butyl Ether	N/A	ug/L	U	0.4	0.8	0.5	J			
Total VOCs	N/A	ug/L	1.5	2	6.1	3.2				
Iron (total)	600 ⁴	ug/L	100	32	32	U	75.5	B		
Manganese (total)	600 ⁴	ug/L	583	533	492	506				
Alkalinity	N/A	mg/L	2	U	38	41	43			
Total Suspended Solids	N/A	mg/L	10	U	10	U	5	U		
Total Solids	N/A	mg/L	170	171	163	183				

Notes:

1. Analytical data analyzed by STL Laboratories.
- 2 (U) Undetected.
- 3 (J) Estimate value. Result is below sample practical quantitation limit, but above the instrument detection limit
- 4 The combined effluent concentration of Iron and Manganese will not exceed 1,000 ug/L.
- 5 N/A - No limit established for this site
- 6 (E) Estimate value.
- 7 N-A - Not Analyzed
- 8 "-" indicates not performed.
9. Bold values exceed discharge limits.
10. (P) pesticide/aroclor target analyte. Greater than 25% difference between the two GC columns.
- 11 Concentration between EPA contract detection limit and instrument detection limit

Servall Laundry Site
Site No. 1-52-077
Groundwater Remediation - Operation and Maintenance

Graphical Data Trends




Figure 1 - Total Volatile Organic Compound (VOC) Influent and Effluent Trends




Figure 2 - Monthly Average Operating Cost Breakdown - to date is \$23,740
Avg. Monthly operating costs in the Year 2000 is \$14,390

NOTES

1. Plant down due to reinjection well fouling (November 19, 1998 to January 23, 1999)
2. Brief Shut down in May: May 8- May 10, 1999
3. Low influent flow due to reinjection well fouling.

Servall Laundry
 Site No. 1-52-077
 Groundwater Remediation - Operations and Maintenance Costs to Date




Figure 3 - Average Operating Cost Trends (Estimated)

Servall Laundry Site
Site No. 1-52-077
Groundwater Remediation

Summary Notes and Action Items

Month	Notes	Action	Resolutions
January	None		
February	MTBE detected, indicative of a gasoline spill unrelated to Servall site		
March	Increase in PCE concentration. Air compressor circuit trip was often	Effluent concentrations below effluent limit.	Recommend the air compressor circuit is re-designed to prevent frequent faults. NYSDEC to respond.
April	None		
May			
June			
July			
August			
September			
October			
November			
December			



575 Broad Hollow Road, Melville, NY 11747-5076
(516) 756-8000 • Fax: (516) 694-4122

May 25, 2000

Robert J. DiGiorgio
Lawler, Matusky, & Skelly Engineers, LLP
One Blue Hill Plaza
Pearl River, NY 10965

Re: Servall Laundry QWETP
Bay Shore, New York
April 2000 Operations Report

Dear Mr. DeGiorgio:

As you are aware, Holzmacher, McLendon, & Murrell, P.C. (H2M) is currently conducting the daily operation and maintenance duties for the above referenced site. A summary of activity with respect to the groundwater extraction and treatment plant for the month of April 2000 is provided below.

Overview

Routine equipment maintenance was performed and daily process equipment readings were collected during the month.

Event Schedule

The following timeline represents specific tasks completed during the month of April.

- 4/3/00 System went off-line. The air compressor circuit breaker was reset to correct.
- 4/4/00 System went off-line. The air compressor and sand feed filter pump circuit breakers were reset to correct.

Clean effluent filters were installed into their respective tanks.

- 4/5/00 System went off-line. The air compressor circuit breaker was reset to correct.
- 4/6/00 System went off-line. The air compressor and sand feed filter pump circuit breakers were reset to correct.

➤ 4/7/00 System went off-line. The air compressor circuit breaker was reset to correct.

➤ 4/24/00 System went off-line. The air compressor circuit breaker was reset to correct.

Clean effluent filters were installed into their respective tanks.

➤ 4/25/00 System went off-line. The air compressor circuit breaker was reset to correct.

➤ 4/26/00 Clean effluent filters were installed into their respective tanks.

➤ 4/27/00 System went off-line. The air compressor circuit breaker was reset to correct.

The monthly water compliance samples were collected, packed in ice, and shipped to Severn-Trent Laboratories via Federal Express, overnight delivery.

➤ 4/28/00 Available treatment chemical volumes as of the end of ~~March~~ April, 2000 are approximated as follows:

Tank	Level	Volume
Acid	54 in.	2644 gal
Caustic	4 in.	195 gal
Peroxide	42 in.	2056 gal

Plant Performance

Between March 31, 2000 and April 28, 2000, the treatment plant discharged 3,862,440 gallons of treated water. The average flowrate of the UV/Oxidation system was 158.57 gallons per minute during operating conditions. Operational data and daily chemistry records for the respective monitoring period have been included as an attachment to this report.

Waste Disposal

No waste was shipped off-site during the reporting period.


If you should have any questions or require additional information, please contact Philip Schade at (631) 756-8000, extension 1623.

Very truly yours,

HOLZMACHER, McLENDON, & MURRELL, P.C.



Philip J. Schade, P.E.
Project Manager



David Nadler
Environmental Scientist

DWN/

enclosures

cc: Gary J. Miller, P.E./H2M

Daily Operation Check List
Servall Laundry Site

Page 1 of 2

Day	Tuesday	Wednesday	Thursday	Friday	Monday	Tuesday	Wednesday	Thursday	Friday	Monday
Date	3/21/00	3/22/00	3/23/00	3/24/00	3/27/00	3/28/00	3/29/00	3/30/00	3/31/00	4/1/00
Time	5:00-5:15	5:00-5:15	5:00-5:15	5:00-5:15	8:55-9:10	9:05-9:20	8:40-8:55	8:35-8:50	8:50-9:05	9:00-9:15
Extraction Well Level (feet)	56.1	56.2	58.9	59.9	57.2	66.3	59.5	57.7	58.3	60.2
Influent Flow Rate (gpm)	157.29	158.32	105.30	160.17	164.32	159.28	161.20	165.38	161.24	167.73
Influent Filter in Service (yes/no)	no	no	no	no	no	no	no	no	no	no
Inlet Pressure (psi)	20	20	15	20	20	20	20	20	20	20
Outlet Pressure (psi)	18	18	15	15	16	16	16	18	16	16
Cartridge Filter Flow Rate (gpm)	146.61	148.08	145.35	144.38	145.88	144.19	144.37	145.72	144.39	144.70
Equalization Tank										
Level (inches)	51.89	52.03	53.12	52.72	53.27	52.33	52.86	51.87	52.66	50.99
pH	7.44	7.46	7.89	7.88	7.79	7.81	7.88	7.85	7.79	7.69
Mixer (on/off)	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Acid Pump Settings: Speed / Stroke	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
UV/Oxidation Pump in Service (4A/4B)	4A	4A	4A/4B	4B	4B	4B	4B	4B	4B	4B
UV/Oxidation Flow Rate (gpm)	155.81	156.45	177.58	168.37	171.23	173.41	172.39	171.61	172.53	172.19
UV/Oxidation Unit										
Lamp # 1 (on/off)	on	on	on	on	on	on	on	on	on	on
KV	258.25	258.52	252	252	252	252	252	252	252	252
Amps	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8
Time	10:40:27	10:50:40	10:50:56	10:51:05	10:52:22	10:53:02	10:53:04	10:54:17	10:55:33	10:55:33
Lamp # 2 (on/off)	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
KV	0	0	0	0	0	0	0	0	0	0
Amps	0	0	0	0	0	0	0	0	0	0
Time	5:08:48	5:08:48	5:08:48	5:08:48	5:08:48	5:08:48	5:08:48	5:08:48	5:08:48	5:08:48
Lamp # 3 (on/off)	on	on	on	on	on	on	on	on	on	on
KV	258	258	258	258	258	258	258	258	258	258
Amps	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0
Time	8:26:27	8:26:27	8:26:27	8:26:27	8:26:27	8:26:27	8:26:27	8:26:27	8:26:27	8:26:27
Peroxide Pump Settings: Speed / Stroke	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50
Peroxide Residual Concentration (mg/l)	14	13	16	15	14	15	14	13	14	15
Totalizer Reading (gpm)	84106100	84217410	84227190	84250450	84250900	84261100	8426430	8440000	8440400	8440700

Daily Operation Check List
Servall Laundry Site

Page 1 of 2

Day	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Monday
Date	4/18/00	4/19/00	4/20/00	4/21/00	4/22/00	4/23/00	4/24/00	4/25/00	4/26/00	4/27/00	4/28/00	4/29/00	4/30/00	5/01/00
Time	12:00	8:30	9:05	13:30	13:40	13:40	13:40	8:10	9:05	8:30	8:35	8:45	8:45	8:45
Extraction Well Level (feet)	65.6	58.9	60.2	59.7	53.7	53.7	53.7	54.2	56.1	53.9	54.2	54.3	54.3	54.3
Influent Flow Rate (gpm)	160.01	161.23	160.33	159.87	161.22	161.22	161.22	160.22	159.37	158.71	159.13	160.48	160.48	160.48
Influent Filter in Service (yes/no)	no	no	no	no	no	no	no	no	no	no	no	no	no	no
Inlet Pressure (psi)	20	20	20	20	20	20	20	20	20	20	20	20	20	20
Outlet Pressure (psi)	18	16	16	16	16	16	16	18	18	16	18	18	18	18
Cartridge Filter Flow Rate (gpm)	140.20	141.91	140.38	140.92	141.83	141.83	141.83	142.91	143.74	142.61	142.24	143.57	143.57	143.57
Equalization Tank														
Level (inches)	51.90	51.88	52.10	52.02	51.89	51.89	51.89	52.61	52.39	53.12	51.98	52.19	52.19	52.19
pH	7.67	7.65	7.67	7.68	7.65	7.65	7.65	7.80	7.91	7.88	7.87	7.79	7.79	7.79
Mixer (on/off)	off	off	off	off	off	off	off	off	off	off	off	off	off	off
Acid Pump Settings: Speed / Stroke	6FF	6FF	6FF	6FF	6FF	6FF	6FF	6FF	6FF	6FF	6FF	6FF	6FF	6FF
UV/Oxidation Pump in Service (4A/4B)	4B	4B	4B	4B	4B	4B	4B	4B	4B	4B	4A	4A	4A	4A
UV/Oxidation Flow Rate (gpm)	150.07	151.21	150.91	150.89	153.72	153.72	153.72	152.11	151.72	156.28	154.53	153.11	153.11	153.11
UV/Oxidation Unit														
Lamp # 1 (on/off)	on	on	on	on	on	on	on	on	on	on	on	on	on	on
KV	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8
Amps	252	252	252	252	252	252	252	252	252	252	252	252	252	252
Time	10:15.36	10:44.79	10:46.58	10:48.19	10:53.27	10:53.27	10:53.27	10:59.50	10:54.12	10:58.23	10:52.51	10:52.40	10:52.40	10:52.40
Lamp # 2 (on/off)	off	off	off	off	off	off	off	off	off	off	off	off	off	off
KV	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Amps	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Time	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86	5:04.86
Lamp # 3 (on/off)	on	on	on	on	on	on	on	on	on	on	on	on	on	on
KV	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0
Amps	258	258	258	258	258	258	258	258	258	258	258	258	258	258
Time	9:27.62	9:29.04	9:29.04	9:31.54	9:32.50	9:32.50	9:32.50	9:32.73	9:34.35	9:36.46	9:34.72	9:34.81	9:34.81	9:34.81
Peroxide Pump Settings: Speed / Stroke	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50
Peroxide Residual Concentration (mg/l)	12	12	11	12	11	11	11	12	12	11	13	12	12	12
Totalizer Reading (gpm)	8694880	87232190	87410450	87650220	87691550	87691550	87691550	87752220	87837190	87887510	87937860	88092210	88092210	88092210

Daily Operation Check List

Servall Laundry Site

Page 2 of 2

Date	4/18/06	4/19/06	4/20/06	4/21/06	4/22/06	4/23/06	4/24/06	4/25/06	4/26/06	4/27/06	4/28/06	5/01/06
pH Adjust Tank												
Level (inches)	50.33	51.10	52.00	50.00	51.33	50.93	51.23	50.87	51.20	51.20	52.13	
pH	6.77	6.78	6.78	6.79	6.72	6.79	6.80	6.78	6.78	6.78	6.73	
Mixer (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	
Caustic Pump Settings: Speed / Stroke	50/35	50/35	50/35	50/35	50/35	50/35	50/35	50/35	50/35	50/35	50/35	50/35
Polymer Feed Settings	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Solution Pump: Speed / Stroke												
Dilution Water Rate												
Polymeer Bucket Weight (lbs.)												
Sand Filter Feed Pump in Service (6A/6B)	6A	6A	6A	6A	6A	6A	6A	6A	6A	6A	6B	6B
Sand Filters												
Filter # 1 inlet pressure (psi)	20	20	20	20	22	20	20	22	20	22	20	20
Filter #1 outlet pressure (psi)	18	20	18	22	22	22	18	20	22	20	22	20
Filter # 2 inlet pressure (psi)	20	20	20	22	20	22	22	20	22	20	22	22
Filter #2 outlet pressure (psi)	20	18	22	20	20	20	22	18	20	20	20	20
Filter # 3 inlet pressure (psi)	20	20	20	20	20	22	20	20	20	20	20	20
Filter #3 outlet pressure (psi)	20	22	22	22	20	22	20	20	20	20	20	20
Filter # 4 inlet pressure (psi)	22	20	22	20	22	20	22	22	22	22	20	20
Filter #4 outlet pressure (psi)	22	22	20	20	20	22	20	20	22	22	22	22
Effluent Flow Rate (gpm)	146.31	145.70	142.73	139.47	142.22	143.71	144.11	145.66	144.52	143.88		
Effluent Filter in Service (yes/no)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Inlet Pressure (psi)	20	20	20	20	20	20	20	20	20	20	20	20
Outlet Pressure (psi)	16	15	16	16	16	16	16	16	14	14	16	16
Reinjection Well Level (feet)	68.39	68.09	67.94	68.34	67.31	68.22	67.91	66.34	68.20	68.13		
Chemical Storage Levels												
Caustic Level (NaOH)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Peroxide Level (H ₂ O ₂)	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3
Acid Level (H ₂ SO ₄)	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9
Air Compressor (psi)	150	160	150	150	160	140	150	150	150	150	160	160
Compressed Air Dryer (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chlorine Pump: Speed / Stroke	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85
Chlorine Residual Concentration (mg/l)	0.1	0.1	0.1	0.1	0.1	0.3	0.3	0.2	0.2	0.2	0.2	0.2

Daily Operation Check List

Servall Laundry Site

Page 1 of 2

Day	Tuesday	Wednesday	Thursday	Friday	Monday	Tuesday	Wednesday	Thursday	Friday	Monday
Date	4/4/00	4/5/00	4/6/00	4/7/00	4/10/00	4/11/00	4/12/00	4/13/00	4/14/00	4/15/00
Time	8:00	8:20	9:10	9:00	8:30	8:50	8:45	8:30	8:00	9:00
Extraction Well Level (feet)	60.4	61.2	60.7	60.1	59.0	59.1	59.2	57.1	58.4	65.4
Influent Flow Rate (gpm)	172.38	169.43	168.31	165.22	159.99	152.71	160.00	154.19	153.27	154.93
Influent Filter in Service (yes/no)	no	no	no	no	no	no	no	no	no	no
Inlet Pressure (psi)	20	20	20	20	20	20	20	20	20	20
Outlet Pressure (psi)	18	16	16	16	16	15	16	14	14	16
Cartridge Filter Flow Rate (gpm)	148.33	146.12	147.09	148.37	149.27	148.20	140.71	144.38	143.88	145.23
Equalization Tank										
Level (inches)	52.07	52.11	52.19	51.99	52.00	51.83	52.07	51.93	52.01	52.61
pH	7.20	7.18	7.11	7.18	7.49	7.43	7.60	7.63	7.62	7.70
Mixer (on/off)	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Acid Pump Settings: Speed / Stroke	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
UV/Oxidation Pump in Service (4A/4B)	4B	4B	4A	4A	4B	4B	4B	4B	4B	4B
UV/Oxidation Flow Rate (gpm)	181.23	178.64	177.42	173.29	149.78	150.11	153.94	152.93	153.11	155.31
UV/Oxidation Unit										
Lamp # 1 (on/off)	on	on	on	on	on	on	on	on	on	on
KV	252	252	252	252	252	252	252	252	252	252
Amps	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8
Time	10:56:31	10:57:01	10:57:12	10:57:50	10:62:58	10:64:63	10:67:11	10:68:56	10:71:30	10:74:62
Lamp # 2 (on/off)	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
KV	0	0	0	0	0	0	0	0	0	0
Amps	0	0	0	0	0	0	0	0	0	0
Time	5:58:48	5:58:48	5:58:48	5:58:48	5:58:48	5:58:48	5:58:48	5:58:48	5:58:48	5:58:48
Lamp # 3 (on/off)	on	on	on	on	on	on	on	on	on	on
KV	258	258	258	258	258	258	258	258	258	258
Amps	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0
Time	8:59:14	8:59:14	9:00:14	9:00:14	9:02:14	9:04:14	9:06:14	9:08:14	9:10:14	9:12:14
Peroxide Pump Settings: Speed / Stroke	50	50	50	50	50	50	50	50	50	50
Peroxide Residual Concentration (mg/l)	12	11	12	12	11	12	12	13	12	12
Totalizer Reading (gpm)	84419450	84421200	84427000	84433700	84440400	84447100	84453800	84460500	84467200	84473900

Daily Operation Check List
Servall Laundry Site

Page 2 of 2

Date	4/4/00	4/5/00	4/6/00	4/7/00	4/10/00	4/11/00	4/12/00	4/13/00	4/14/00	4/17/00
pH Adjust Tank										
Level (inches)	51.29	52.37	53.10	52.91	50.05	51.70	49.98	50.37	51.29	52.80
pH	6.81	6.91	7.02	7.11	6.77	6.74	6.78	6.71	6.74	6.77
Mixer (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Caustic Pump Settings: Speed / Stroke	50/35	50/35	50/35	50/35	50/35	50/35	50/35	50/35	50/35	50/35
Polymer Feed Settings	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Solution Pump: Speed / Stroke										
Dilution Water Rate										
Polymeer Bucket Weight (lbs.)										
Sand Filter Feed Pump in Service (6A/6B)	6B	6B	6A	6A	6A	6A	6A	6A	6A	6A
Sand Filters										
Filter # 1 inlet pressure (psi)	22	20	24	26	18	18	20	20	20	20
Filter #1 outlet pressure (psi)	20	22	22	24	20	20	20	20	20	20
Filter # 2 inlet pressure (psi)	22	24	22	28	18	18	20	20	22	20
Filter #2 outlet pressure (psi)	22	22	24	24	20	20	20	20	18	20
Filter # 3 inlet pressure (psi)	24	22	24	28	18	18	20	20	22	18
Filter #3 outlet pressure (psi)	22	20	22	28	20	20	20	20	20	20
Filter # 4 inlet pressure (psi)	20	22	24	26	18	18	20	18	22	20
Filter #4 outlet pressure (psi)	20	20	24	28	20	20	20	20	20	22
Effluent Flow Rate (gpm)	147.10	145.71	146.82	144.81	145.01	149.33	140.73	144.41	143.72	143.51
Effluent Filter in Service (yes/no)	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES
Inlet Pressure (psi)	16	16	16	16	16	16	16	16	16	16
Outlet Pressure (psi)	10	12	10	10	10	10	10	10	12	10
Reinjection Well Level (feet)	61.44	62.33	61.82	62.33	67.41	66.94	68.67	68.14	67.91	68.33
Chemical Storage Levels										
Caustic Level (NaOH)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Peroxide Level (H ₂ O ₂)	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3
Acid Level (H ₂ SO ₄)	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9
Air Compressor (psi)	150	160	150	160	140	150	150	140	150	140
Compressed Air Dryer (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chlorine Pump: Speed / Stroke	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85
Residual Disinfectant Concentration (mg/l)	0.2	0.2	0.1	0.1	0.2	0.2	0.2	0.1	0.2	0.2

Servall Laundry Process Control Samples

Date	4/3/00	4/4/00	4/5/00	4/6/00	4/7/00	4/10/00	4/11/00	4/12/00	4/13/00	4/14/00	4/15/00	4/18/00
Time	9:30	8:30	9:00	9:30	9:20	8:55	9:30	9:15	9:05	8:35	9:25	12:20
Influent												
Flow	167.73	172.38	169.43	168.31	165.22	159.99	152.71	160.00	154.19	153.27	154.23	160.01
pH	5.74	5.68	5.76	5.75	5.69	5.72	5.69	5.73	5.59	5.62	5.61	5.70
Iron	0.4	0.4	0.3	0.5	0.4	0.4	0.4	0.3	0.4	0.5	0.3	0.3
UVOX												
Peroxide Residual	15	12	11	12	12	11	12	12	13	12	12	12
pH	6.46	6.04	6.03	5.99	5.97	5.93	5.96	5.99	5.88	5.84	5.91	5.96
Effluent												
pH	7.02	7.08	6.95	7.11	7.14	7.04	7.00	6.98	7.03	7.09	6.83	6.89
Iron	0.1	0.1	0.1	0.2	0.2	0.2	0.1	0.2	0.3	0.2	0.3	0.2
Chlorine	0.1	0.2	0.2	0.1	0.1	0.2	0.2	0.2	0.1	0.2	0.2	0.1

Date	4/19/00	4/20/00	4/21/00	4/24/00	4/25/00	4/26/00	4/27/00	4/28/00				
Time	9:00	9:30	14:00	14:05	9:00	9:35	9:00	9:00				
Influent												
Flow	161.23	160.33	159.87	161.22	160.22	159.37	152.71	159.13				
pH	5.66	5.71	5.74	5.68	5.65	5.72	5.81	5.70				
Iron	0.4	0.3	0.4	0.5	0.3	0.3	0.4	0.4				
UVOX												
Peroxide Residual	12	11	12	11	12	12	11	13				
pH	6.01	6.02	6.01	5.96	5.94	5.93	5.87	5.90				
Effluent												
pH	6.78	6.91	7.04	7.11	7.12	7.18	7.16	7.09				
Iron	0.1	0.1	0.2	0.2	0.2	0.1	0.2	0.2				
Chlorine	0.1	0.1	0.1	0.2	0.3	0.3	0.2	0.2				