


**Lawler,
Matusky
& Skelly
Engineers LLP**

Environmental Science & Engineering Consultants



September 28, 2000
File No. 650-395

Mr. Carl Hoffman
New York State Department of Environmental Conservation
Operation and Maintenance Section - Bureau of Hazardous Site Control
Division of Environmental Remediation
50 Wolf Road
Albany, New York 12233-7010

Re: **Servall Laundry Site**
Bay Shore, Suffolk County
Site No. 1-52-077, Work Assignment No. D002676-39.2
Monthly Report – September 2000

Dear Mr. Hoffman:

Attached please find the Monthly Report for September 2000, the last monthly report submitted under Work Assignment No. D002676-39.2.

The plant operation data for the month of September is due from H2M at the end of the month, no later than October 13, 2000. At that time, the information will be forwarded to you. This report was based on compliance samples collected on September 8, 2000. The plant removed approximately 48% of the influent VOCs. The reduced efficiency is apparently due to the presence of Tetrahydrofuran (THF). THF was detected at influent concentrations of 180 ppb and effluent concentrations of 100 ppb. The concentrations of THF contributed 88% of total influent VOCs and 94% of total effluent VOCs. The plant removed only 44% of THF compared to 86% removal of other VOCs. Overall effluent concentrations of total VOCs were within discharge limitations however, THF exceeded its Class GA groundwater standard of 50 ppb. THF is not in the current permit for the site.

THF has been observed since May 2000 and now represents a high percentage of the overall VOC's detected. THF is widely used in industry with applications in the manufacture of polymers and resins, lacquers, glues, paints, and inks. Also, preliminary investigation reveals that THF is one of the possible ingredients for PVC cements and pipe solvents in plumbing. Reviewing several MSDS's for PVC cements indicated the presence of THF. Deteriorating pipe joints or connections in the plant which are made of PVC might be possible sources of THF.

Effluent concentrations of iron and manganese were within the discharge limitations. The September data reveals that the influent iron concentration was at 25,700 ppb, which appears unrealistically high. This concentration is 25 times more than the average concentration and five times more than the highest measured historical concentration of iron. The effluent iron concentration was within discharge limit at 85.5 ppb. This represents more than 99.66 % removal of total iron which exceeds the average capacity of the plant and has never been observed suggesting error in the sampling procedure or analytical error.


\\LMS-SRVR1\DATA\06xx-xxx\0650-NYSDEC\0650-395\monthly reports\Sept00 mnthly rpt cvltr.doc

Mr. Carl Hoffman
NYS Dept. of Environmental Conservation

September 21, 2000
Page....2

LMS will continue to provide task management of the plant operations until September 30, 2000 unless otherwise directed by the NYSDEC. If you have any questions or comments please feel free to contact me at x 249.

Very Truly Yours,




Robert DeGiorgio, P.E.
Project Manager

Enclosures

cc: Phil Schade, H2M

**Lawler,
Matusky
& Skelly
Engineers LLP**

Environmental Science & Engineering Consultants



Mr. Carl Hoffman
New York State Department of Environmental Conservation
Operation and Maintenance Section - Bureau of Hazardous Site Control
Division of Environmental Remediation
50 Wolf Road
Albany, New York 12233-7010

Re: **Servall Laundry Site**
8 Drayton Avenue, Bay Shore, Suffolk County
Site No. 1-52-077, Work Assignment No. D002676-39.2
National Waste Disposal Corp.

Dear Mr. Hoffman:

Please be aware on September 30, 2000, Lawler, Matusky & Skelly Engineers LLP (LMS) will no longer be providing task management of the plant operations, including handling waste disposal, at the Servall Laundry Site. The NYSDEC shall coordinate directly with National Waste Disposal Corp. at (516) 242-0300 to update the contact information and billing arrangements.

This letter serves as formal notice of change in contact for both the NYSDEC and National Waste Disposal Corp. The final payment of \$390 shall be made from LMS during the week of September 11, 2000 resulting in a \$0.00 balance for waste disposal services as of September 30, 2000. If you have any questions or comments please feel free to contact me at extension 249.

Very Truly Yours,

Robert DeGiorgio, P.E.
Project Manager

cc: National Waste Disposal Corp.

**Lawler
Matusky
& Skelly
Engineers LLP**

Environmental Science & Engineering Consultants

October 13, 2000
File No. 650-395

Mr. Carl Hoffman
New York State Department of Environmental Conservation
Operation and Maintenance Section - Bureau of Hazardous Site Control
Division of Environmental Remediation
50 Wolf Road
Albany, New York 12233-7010

Re: **Servall Laundry Site
Bay Shore, Suffolk County
Site No. 1-52-077, Work Assignment No. D002676-39.2
Monthly Report – September 2000**

Dear Mr. Hoffman:

Attached please find the Monthly Report for September 2000, the last monthly report submitted under Work Assignment No. D002676-39.2. This version includes the H2M report, which was not included in the previous monthly report, sent to you on September 28, 2000.

If you have any questions or comments please feel free to contact me at x 249.

Very Truly Yours,



Robert DeGiorgio, P.E.
Project Manager


Enclosures

cc: Phil Schade, H2M

Servall Laundry Site
Site No. 1-52-077
Groundwater Remediation
Operation and Maintenance

Monthly Operations Report

September-00



LAWLER, MATUSKY & SKELLY ENGINEERS LLP
Environmental Science & Engineering Consultants
One Blue Hill Plaza
Pearl River, New York 10965

650-395

Sewall Laundry
Site No. 1-52-077
Groundwater Remediation -2000 Operation and Maintenance
Summary Report

Plant Operating Data	unit	Monthly Average (to date)	Monthly Average (2000)	January-00	February-00	March-00	April-00	May-00	June-00	July-00	August-00	September-00	Total Year 2000
Flow Rate	gpm	116	153	160.44	160.39	160.2	158.57	152.09	144.05	149.45	147.49	145.19	-
Gallons processed	gallons	3,468,692	3,389,778	4,154,420	5,390,400	3,744,760	3,862,440	3,408,300	1,839,960	2,771,780	3,023,240	2,312,700	30,508,000
Percent of Time Operating	%	53%	52%	62%	86%	56%	60%	51%	28%	43%	45%	35%	52%
Pounds of VOCs Treated	lb	1.6	3.3	2.16	4.42	4.51	4.58	3.63	5.00	0.86	2.38	1.89	29.45
Influent VOC concentration	ug/L	131	144	63.9	100.3	150.6	145.45	131.82	350.93	42.89	104.46	204.19	-
Effluent VOC concentration	ug/L	9.80	18.17	1.5	2	6.1	3.22	3.97	25.16	5.57	10.05	105.99	-
Influent Total Iron	ug/L	2,296	4,130	1270	308	689	426	1430	6320	444	583	25700	-
Effluent Total Iron	ug/L	444	805	100	32	32	75.5	3010	1780	732	1400	84.5	-
Influent Total Manganese	ug/L	737	900	593	542	517	499	864	2900	992	514	682	-
Effluent Total Manganese	ug/L	522	470	583	533	492	506	417	16.6	841	399	439	-
VOC removal efficiency	%	95.8%	89.4%	97.7%	98.0%	95.9%	97.8%	97.0%	92.8%	87.0%	90.4%	48.1%	89.4%
Total Iron removal efficiency	%	46.3%	23.9%	92.1%	89.6%	95.4%	82.3%	-110.5%	71.8%	-64.9%	-140.1%	99.7%	23.9%
Total Manganese removal efficiency	%	14.1%	25.7%	1.7%	1.7%	4.8%	-1.4%	51.7%	99.4%	15.2%	22.4%	35.6%	25.7%
Cartridge Filters	ea	1	0	3	0	0	0	0	0	0	0	1	4
Sodium hypochlorite (12%)	lb	628	500	500	500	500	500	500	500	500	500	500	4,000
Polymer	lb	0	0	0	0	0	0	0	0	0	0	0	0
Hydrogen peroxide (50%)	lb	3704	4522	4538	4538	4538	4538	4538	4392	4538	4538	4538	40,698
Caustic (50%)	lb	2200	4839	5534	5177	5534	5355	5534	5355	357	5355	5355	43,554
Hydrochloric Acid	lb	63	0	0	0	0	0	0	0	0	0	0	0
Spare Parts or other	at cost	\$424	\$22	\$196	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$196
Sludge generated (20% dewatered)	gal	25	25	25	25	25	25	25	25	25	25	25	225
Sludge disposed of	gal	18	0	0	0	0	0	0	0	0	0	0	0
Electricity (estimated)	kw hr	39767	37156	37,800	37,800	37,800	37,800	37,800	32,000	37,800	37,800	37,800	334,400
Gas (estimated)	therms	852	800	800	800	800	800	800	800	800	800	800	7,200
Compliance Sampling	at cost	\$882.10	\$650.61	\$655.50	\$650.00	\$650.00	\$650.00	\$650.00	\$650.00	\$650.00	\$650.00	\$650.00	\$5,856
Operator	Month	\$8,795	\$6,021	\$5,790	\$6,500	\$7,190	\$4,548	\$4,549	\$7,593	\$6,749	\$4,570	\$6,700	\$54,189
Redevelopment	at cost	\$1,955	\$0	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0
Management & Engineering	at cost	\$2,807	\$1,408	\$931	\$1,239.99	\$1,200.00	\$856.00	\$856.00	\$1,065.00	\$1,118.60	\$2,202.22	\$3,200.00	\$12,669
Consumables cost	\$	\$3,173	\$3,451	\$4,162	\$3,441	\$3,516	\$3,479	\$3,516	\$3,406	\$2,429	\$3,479	\$3,629	\$31,056
Sludge disposal cost	\$	\$48.13	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0
Utilities cost	\$	\$3,877	\$3,624	\$3,682	\$3,682	\$3,682	\$3,682	\$3,682	\$3,160	\$3,682	\$3,682	\$3,682	\$32,616
Services cost	\$	\$14,439	\$8,079	\$7,376	\$8,390	\$9,040	\$6,054	\$6,055	\$9,308	\$8,518	\$7,422	\$10,550	\$72,713
Operating Cost (Estimated)	\$	\$21,537	\$15,154	\$15,221	\$15,513	\$16,238	\$13,215	\$13,253	\$15,874	\$14,629	\$14,583	\$17,861	\$136,386

Serrall Laundry Site
Site No. 1-52-077
Groundwater Remediation - Operation and Maintenance
2000 Compliance Sampling

Influent												
Constituents	Discharge Criteria	units	January	February	March	April	May	June				
			ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Chlorobenzene	5	ug/L	U	U	U	U	U	U	U	U	U	U
Vinyl Chloride	2	ug/L	U	U	U	U	U	U	U	U	U	U
1,1-Dichloroethene	5	ug/L	0.1	J	U	U	U	U	U	U	U	U
Trichloroethene	5	ug/L	1	1	1	1.1	0.8					
Tetrachloroethene	5	ug/L	54	E	87	140	E	130	E	47	E	14
1,1-Dichloroethane	5	ug/L	0.2	J	U	U	U	U	U	U	U	U
cis-1,2-Dichloroethene	5	ug/L	0.3	J	0.6	0.8	0.6	0.3	J	7.5	JD	
trans-1,2-Dichloroethene	5	ug/L	U	U	U	U	U	U	U	U	U	U
Methylene Chloride	N/A	ug/L	U	1.6	JD	U	2.6	JD	0.4	JB	13	DB
1,1,1-Trichloroethane	N/A	ug/L	0.5	U	U	U	0.4	J	0.4	J		
Chloroform	N/A	ug/L	0.2	J	0.2	U	1.9	JD	6.4	JB	5.2	
Bromodichloromethane	N/A	ug/L	U	U	U	U	U	0.38	J			
Trichlorofluoromethane	N/A	ug/L	U	U	U	U	U	0.1	J	310	E	
Tetrahydrofuran	N/A	ug/L						73				
Methyl tert-Butyl Ether	N/A	ug/L	7.6	9.4	8.8	8.8	J	3.1	J	0.89	J	
Total VOCs	N/A	ug/L	63.9	100.3	150.6	145.5	131.82	350.93				
pH												
Iron (total)	600 ⁴	ug/L	1270	308	689	426	1430	6320				
Manganese (total)	600 ⁴	ug/L	593	542	517	499	864	2900				
Alkalinity	N/A	mg/L	27	29	15	5	U	6				
Total Suspended Solids	N/A	mg/L	159	162	145	156	261	344				
Total Solids	N/A	mg/L										

Effluent												
Constituents	Discharge Criteria	units	January	February	March	April	May	June				
			ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
Chlorobenzene	5	ug/L	U	U	U	U	U	U	U	U	U	U
Vinyl Chloride	2	ug/L	U	U	U	U	U	U	U	U	U	U
1,1-Dichloroethene	5	ug/L	U	U	U	U	U	U	U	U	U	U
Trichloroethene	5	ug/L	U	U	U	U	U	U	U	U	U	U
Tetrachloroethene	5	ug/L	0.7	1.4	4.2	2.4	2.2	0.98				
1,1-Dichloroethane	5	ug/L	U	U	U	U	U	U	U	U	U	U
5 (POC)	5	ug/L						5.5	DB			
Toluene	5	ug/L	U	0.2	JB	U	U	U	U	U	U	U
cis-1,2-Dichloroethene	5	ug/L	U	U	U	U	U	U	U	U	U	U
trans-1,2-Dichloroethene	5	ug/L	U	U	U	U	U	U	U	U	U	U
Methylene Chloride	N/A	ug/L	U	U	U	0.2	JB	0.38	JB	7.6LE	DB	
1,1,1-Trichloroethane	N/A	ug/L	0.3	J	U	U	U	U	U	U	U	U
Chloroform	N/A	ug/L	0.3	J	0.7	B	0.1	JB	0.84			
Tetrahydrofuran	50	ug/L								18	J	
Acetone	N/A	ug/L								100LE		
2-Butanone	N/A	ug/L								49LE	DB	
Bromodichloromethane	N/A	ug/L	0.2	J	0.4	J	U	U	U	U	U	U
Methyl tert-Butyl Ether	N/A	ug/L	U	0.4	0.8	0.5	J	0.55	J	0.23	J	
Total VOCs	N/A	ug/L	1.5	2	6.1	3.2	3.97	25.16				
pH												
Iron (total)	600 ⁴	ug/L	100	32	32	U	75.5	B	3010	1780		
Manganese (total)	600 ⁴	ug/L	583	533	492	506	417	16.6				
Alkalinity	N/A	mg/L	2	38	41	43	25.8	U	5	43		
Total Suspended Solids	N/A	mg/L	10	U	10	U	5	U				
Total Solids	N/A	mg/L										

Notes:
1. Analytical data analyzed by STL Laboratories.
2. (U) Undetected.
3. (J) Estimate value. Result is below sample practical quantitation limit, but above the instrument detection limit.
4. The combined effluent concentration of Iron and Manganese will not exceed 1,000 ug/L.
5. N/A - No limit established for this site.
6. (E) Estimate value.
7. N/A - Not Analyzed.
8. "-" indicates not performed.
9. Bold values exceed discharge limits.
10. (P) pesticide/herbicide target analyte. Greater than 25% difference between the two GC columns.
11. Concentration between EPA contract detection limit and instrument detection limit
12. POC = principal organic contaminant
13. LE - lab error or contamination likely

Servall Laundry Site
 Site No. 1-52-077
 Groundwater Remediation - Operation and Maintenance
 2000 Compliance Sampling

Influent												
Constituents	Discharge Criteria	units	July	August	September	October	November	December	Chlorobenzene	Vinyl Chloride	1,1-Dichloroethene	Trichloroethene
Chlorobenzene	5	ug/L	U	U	U	U						
Vinyl Chloride	2	ug/L	U	U	U	U						
1,1-Dichloroethene	5	ug/L	U	U	U	U						
Trichloroethene	5	ug/L	0.94	U	U	U						
Tetrachloroethene	5	ug/L	22	1.2	U	U						
1,1-Dichloroethane	5	ug/L	U	U	U	U						
Toluene	5	ug/L	1.7	U	U	21						
cis-1,2-Dichloroethene	5	ug/L	0.43	U	U	U						
trans-1,2-Dichloroethene	5	ug/L	0.36	JB	1.2	JPB						
Methylene Chloride	N/A	ug/L	0.32	JB	U	U						
1,1,1-Trichloroethane	N/A	ug/L	1.9	U	U	0.47	JD					
Chloroform	N/A	ug/L	U	U	U	U						
Bromodichloromethane	N/A	ug/L	U	U	U	0.42	JD					
Trichlorofluoromethane	N/A	ug/L	U	U	U	U						
Tetrahydrofuran	N/A	ug/L	16	J	100	J	180	D				
Methyl tert-Butyl Ether	N/A	ug/L	1.5	JB	1	1.1	JD					
Total VOCs	N/A	ug/L	42.89	104.46	204.19							
pH			6.38	7.18	6.66							
Iron (total)	600*	ug/L	444	583	25700							
Manganese (total)	600*	ug/L	992	514	682							
Alkalinity	N/A	mg/L	25	119	72							
Total Suspended Solids	N/A	mg/L	5	U	16							
Total Solids	N/A	mg/L	138	283	165							
Effluent												
Constituents	Discharge Criteria	units	July	August	September	October	November	December	Chlorobenzene	Vinyl Chloride	1,1-Dichloroethene	Trichloroethene
Chlorobenzene	5	ug/L	U	U	U	U						
Vinyl Chloride	2	ug/L	U	U	U	U						
1,1-Dichloroethene	5	ug/L	U	U	U	U						
Trichloroethene	5	ug/L	22	1.2	U	U						
Tetrachloroethene	5	ug/L	0.94	U	U	U						
1,1-Dichloroethane	5	ug/L	U	U	U	U						
Toluene	5	ug/L	1.7	U	U	21						
cis-1,2-Dichloroethene	5	ug/L	0.43	U	U	U						
trans-1,2-Dichloroethene	5	ug/L	0.36	JB	1.2	JPB						
Methylene Chloride	N/A	ug/L	0.32	JB	U	U						
1,1,1-Trichloroethane	N/A	ug/L	1.9	U	U	0.47	JD					
Chloroform	N/A	ug/L	U	U	U	U						
Bromodichloromethane	N/A	ug/L	U	U	U	0.42	JD					
Trichlorofluoromethane	N/A	ug/L	U	U	U	U						
Tetrahydrofuran	N/A	ug/L	16	J	100	J	180	D				
Methyl tert-Butyl Ether	N/A	ug/L	1.5	JB	1	1.1	JD					
Total VOCs	N/A	ug/L	42.89	104.46	204.19							
pH			6.38	7.18	6.66							
Iron (total)	600*	ug/L	444	583	25700							
Manganese (total)	600*	ug/L	992	514	682							
Alkalinity	N/A	mg/L	25	119	72							
Total Suspended Solids	N/A	mg/L	5	U	16							
Total Solids	N/A	mg/L	138	283	165							

Notes:
 1. Analytical data analyzed by STL Laboratories.
 2. (U) Undetected.
 3. (J) Estimate value. Result is below sample practical quantitation detection limit.
 4. The combined effluent concentration of Iron and Manganese.
 5. N/A - No limit established for this site.
 6. (F) Estimate value.
 7. N-A - Not Analyzed.
 8. "-" indicates not performed.
 9. Bold values exceed discharge limits.
 10. (P) pesticide/aroclor target analyte. Greater than 25% of 11. Concentration between EPA contract detection limit and 12. POC = principal organic contaminant
 13. LE - lab error or contamination likely

- NOTES
1. Plant shut down due to reinjection well fouling (November 19, 1998 to January 23, 1999)
 2. Brief Shut down in May: May 8 - May 10, 1999
 3. Low influent flow due to reinjection well fouling.

Figure 2 - Monthly Average Operating Cost Breakdown - to date is \$23,915
Avg. Monthly operating costs in the Year 2000 is \$15,154





Figure 1 - Total Volatile Organic Compound (VOC) Influent and Effluent Trends



Servall Laundry
Site No. 1-52-077
Groundwater Remediation - Operations and Maintenance Costs to Date




Figure 3 - Average Operating Cost Trends (Estimated)

575 Broad Hollow Road, Melville, NY 11747-5076
(516) 756-8000 • Fax: (516) 694-4122

October 10, 2000

Robert J. DiGiorgio
Lawler, Matusky, & Skelly Engineers, LLP
One Blue Hill Plaza
Pearl River, NY 10965

Re: Servall Laundry QWETP
Bay Shore, New York
September 2000 Operations Report

Dear Mr. DeGiorgio:

As you are aware, Holzmacher, McLendon, & Murrell, P.C. (H2M) is currently conducting the daily operation and maintenance duties for the above referenced site. A summary of activity with respect to the groundwater extraction and treatment plant for the month of September is provided below.

Overview

Routine equipment maintenance was performed and daily process equipment readings were collected during the month. H2M's current contract, relative to operation and maintenance of the subject facility, ended on September 30, 2000. Therefore, the facility was temporarily shut-down as of September 29, 2000.

Event Schedule

The following timeline represents specific tasks completed during the month of September.

- 9/7/00 The monthly compliance samples were collected and sent to Severn Trent Laboratories via Federal Express.
- 9/12/00 Clean effluent filters were installed into their respective canisters.
- 9/25/00 All four sand filter canisters were manually backwashed.
- 9/26/00 A filter press cycle was performed. The sump was emptied into the equalization tank.

- 9/27/00 A small amount of sludge was collected from the previous day's filter press procedure.

Effluent filters were taken out of the acid baths, washed down, and placed on top of the trench drain.

General maintenance around the facility (i.e., mopping and cleaning) was accomplished.

- 9/28/00 The equalization tank was drained until only a trace amount of water remained within it. The valves from the extraction pipe were closed.

The pumps controlling the delivery of sodium hydroxide (caustic), hydrogen peroxide, and sodium hypochlorite (bleach) were turned off. The pumps controlling the flow of water (4A, 4B, 6A and 6B) were turned off through the master control panel. The air compressor was shut down by switching it off through the master control panel. The sump pumps were turned off by means of the control panel immediately next to the sump.

- 9/29/00 Sand filter canisters were drained and vented, and solids were removed from the vent opening on the top of each canister.

The pumps in the facility were serviced as per manufacturers' recommendations.

The natural gas heating system thermostat was set to 66 degrees Fahrenheit.

Available treatment chemical volumes as of the end of September 2000 are as follows:

Tank	Level	Volume
Acid	54 in.	2644 gal
Caustic	20 in.	600 gal
Peroxide	20 in.	800 gal

Plant Performance

Between September 1, 2000 and September 29, 2000, the treatment plant discharged 2,312,700 gallons of treated water. The average flowrate of the UV/Oxidation system was 145.19 gallons per minute during operating conditions. Operational data and daily chemistry records for the respective monitoring period have been included as an attachment to this report.


Waste Disposal

No waste was shipped off-site during the reporting period.


If you should have any questions or require additional information, please contact Philip Schade at (631) 756-8000, extension 1623.

Very truly yours,

HOLZMACHER, McLENDON, & MURRELL, P.C.



Philip J. Schade, P.E.
Project Manager



David W. Nadler
Environmental Scientist

DWN/

enclosures

cc: Gary J. Miller, P.E./H2M

Daily Operation Check List Servall Laundry Site

Page 1 of 2

Day	Fri	Mon	Tue	Wed	Thur	Fri	Mon	Tue	Wed	Thur	Fri
Date	9/1	9/5	9/6	9/7	9/8	9/9	9/10	9/11	9/12	9/13	9/14
Time	8:20	7:45	8:30	7:30	7:20	7:20	7:20	7:20	7:40	8:00	8:10
Extraction Well Level (feet)	53.9	52.9	52.8	53.1	55.0	55.2	55.2	55.2	55.2	51.7	50.9
Influent Flow Rate (gpm)	154.29	156.87	153.72	152.14	156.33	154.49	153.71	153.71	153.71	151.50	156.63
Influent Filter in Service (yes/no)	no	no	no	no	no	no	no	no	no	no	no
Inlet Pressure (psi)	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
Outlet Pressure (psi)	1.8	1.8	1.8	1.8	1.6	1.8	1.8	1.8	1.8	1.8	1.8
Cartridge Filter Flow Rate (gpm)	147.20	151.60	150.97	149.72	144.23	149.36	150.08	150.08	146.23	147.92	149.88
Equalization Tank											
Level (inches)	54.81	52.86	51.96	52.23	51.90	51.86	53.27	53.27	54.11	56.20	54.47
pH	7.72	7.69	7.70	7.78	7.79	7.78	7.78	7.78	7.69	7.72	7.65
Mixer (on/off)	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Acid Pump Settings: Speed / Stroke	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
UV/Oxidation Pump in Service (4A/4B)	4A	4B	4B	4B	4B	4B	4B	4B	4B	4B	4B
UV/Oxidation Flow Rate (gpm)	149.37	148.41	149.23	144.91	146.68	147.69	145.53	145.53	146.39	146.62	145.54
UV/Oxidation Unit											
Lamp # 1 (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
KV	252	252	252	252	252	252	252	252	252	252	252
Amps	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8
Time	12:14:14	12:19:53	12:20:80	12:25:75	12:24:96	12:28:84	12:30:54	12:30:54	12:32:09	12:35:10	12:37:07
Lamp # 2 (on/off)	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
KV	0	0	0	0	0	0	0	0	0	0	0
Amps	0	0	0	0	0	0	0	0	0	0	0
Time	5:58:18	5:58:48	5:58:86	5:58:86	5:58:86	5:58:86	5:58:86	5:58:86	5:58:86	5:58:86	5:58:86
Lamp # 3 (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
KV	258	258	258	258	258	258	258	258	258	258	258
Amps	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0
Time	10:50:76	10:56:15	10:61:42	10:63:37	10:65:58	10:69:46	10:71:16	10:71:16	10:73:71	10:75:62	10:77:46
Peroxide Pump Settings: Speed / Stroke	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50
Peroxide Residual Concentration (mg/l)	13	12	11	11	13	12	11	11	12	13	12
Totalizer Reading (gpm)	9432.1710	9464.3650	9473.2410	9482.8740	9491.6530	9502.7270	9513.6890	9524.4970	9535.2600	9546.0720	9556.8840

Daily Operation Check List
Servall Laundry Site

Page 2 of 2

Date	9/1	9/5	9/6	9/7	9/8	9/11	9/12	9/13	9/14	9/15
pH Adjust Tank										
Level (inches)	51.52	52.36	51.91	52.01	53.61	54.27	52.91	51.86	50.99	52.17
pH	7.68	7.67	7.63	7.65	7.62	7.68	7.61	7.63	7.64	7.67
Mixer (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Caustic Pump Settings: Speed / Stroke	45/35	45/35	45/35	45/35	45/35	45/35	45/35	45/35	45/35	45/35
Polymer Feed Settings	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Solution Pump: Speed / Stroke										
Dilution Water Rate										
Polymer Bucket Weight (lbs.)										
Sand Filter Feed Pump in Service (6A/6B)	6B	6B	6B	6B	6B	6B	6B	6B	6B	6B
Sand Filters										
Filter # 1 inlet pressure (psi)	20	20	20	22	22	20	22	20	20	22
Filter #1 outlet pressure (psi)	18	20	22	20	22	20	20	18	18	18
Filter # 2 inlet pressure (psi)	20	20	22	20	20	22	20	20	20	22
Filter #2 outlet pressure (psi)	20	22	20	20	22	20	20	20	20	20
Filter # 3 inlet pressure (psi)	20	20	20	20	20	20	22	20	20	20
Filter #3 outlet pressure (psi)	20	22	20	20	20	20	22	20	20	20
Filter # 4 inlet pressure (psi)	20	20	20	22	20	20	20	20	20	22
Filter #4 outlet pressure (psi)	20	18	20	20	20	18	20	20	22	20
Effluent Flow Rate (gpm)	141.11	142.08	141.43	145.60	143.98	149.39	142.61	142.28	147.36	141.80
Effluent Filter in Service (yes/no)	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Inlet Pressure (psi)	16	16	16	16	16	16	18	18	18	18
Outlet Pressure (psi)	10	10	12	12	12	12	12	12	14	14
Reinjection Well Level (feet)	57.18	56.22	54.21	53.19	53.37	52.81	51.60	53.81	52.60	51.94
Chemical Storage Levels										
Caustic Level (NaOH)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Peroxide Level (H ₂ O ₂)	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3
Acid Level (H ₂ SO ₄)	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9
Air Compressor (psi)	150	150	150	150	140	150	160	160	150	150
Compressed Air Dryer (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chlorine Pump: Speed / Stroke	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85
Chlorine Residual Concentration (mg/l)	0.2	0.2	0.1	0.3	0.2	0.2	0.3	0.3	0.3	0.2

Daily Operation Check List
Servall Laundry Site

Page 1 of 2

Day	Mon	Tue	Wed	Thur	Fri	Mon	Tue	Wed	Thur	Fri
Date	9/18	9/19	9/20	9/21	9/22	9/23	9/24	9/25	9/26	9/27
Time	8:30	8:20	7:50	7:30	8:00	8:10	8:20	8:30	8:40	9:00
Extraction Well Level (feet)	54.1	55.3	52.7	53.6	53.0	54.1	55.2	52.1	51.7	51.7
Influent Flow Rate (gpm)	152.61	153.17	154.90	153.11	152.67	154.73	156.20	150.91	0	0
Influent Filter in Service (yes/no)	N0	N0	N0	N0	N0	N0	N0	N0	N0	N0
Inlet Pressure (psi)	16	16	16	16	16	16	16	16	16	16
Outlet Pressure (psi)	10	10	10	10	10	10	12	12	12	12
Cartridge Filter Flow Rate (gpm)	143.97	146.72	145.91	143.40	145.37	144.71	143.42	146.29	0	0
Equalization Tank										
Level (inches)	53.71	54.11	52.91	53.88	54.19	53.66	54.13	53.72	55.1	55.1
pH	7.60	7.61	7.67	7.69	7.59	7.54	7.58	7.60	7.58	7.58
Mixer (on/off)	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Acid Pump Settings: Speed / Stroke	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
UV/Oxidation Pump in Service (4A/4B)	4A	4A	4A	4A	4A	4A	4A	4A	OFF	OFF
UV/Oxidation Flow Rate (gpm)	147.30	142.99	141.61	140.86	142.83	140.91	144.46	142.16	0	0
UV/Oxidation Unit										
Lamp # 1 (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	OFF	OFF
KV	252	252	252	252	252	252	252	252	0	0
Amps	7.8	7.8	7.8	7.8	7.8	7.8	7.8	7.8	0	0
Time	1242.64	1242.86	1245.81	1247.08	1249.13	1250.54	1253.02	1250.25	1250.35	1255.34
Lamp # 2 (on/off)	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
KV	0	0	0	0	0	0	0	0	0	0
Amps	0	0	0	0	0	0	0	0	0	0
Time	5984.86	5984.86	5984.86	5984.86	5984.86	5984.86	5984.86	5984.86	5984.86	5984.86
Lamp # 3 (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	OFF	OFF
KV	258	258	258	258	258	258	258	258	0	0
Amps	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.0	0	0
Time	10817.26	10834.48	10856.43	10875.70	10895.75	10915.16	10936.64	10954.97	10954.97	10954.97
Peroxide Pump Settings: Speed / Stroke	50/50	50/50	50/50	50/50	50/50	50/50	50/50	50/50	OFF	OFF
Peroxide Residual Concentration (mg/l)	12	14	14	12	13	1250/500	13	12	—	—
Totalizer Reading (gpm)	100970280	101050020	101157030	101196010	100327500	101457930	101577860	101634710	101634710	101634710

Daily Operation Check List
Servall Laundry Site

Page 2 of 2

Date	9/18	9/19	9/20	9/21	9/22	9/23	9/24	9/25	9/26	9/27	9/28	9/29
pH Adjust Tank												
Level (inches)	52.81	53.17	52.88	53.70	51.67	52.71	53.86	54.20	53.12	52.12		
pH	7.62	7.77	7.80	7.76	7.72	7.70	7.71	7.70				
Mixer (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	OFF	OFF	OFF	OFF
Caustic Pump Settings: Speed / Stroke	45/35	45/35	45/35	45/35	45/35	45/35	45/35	45/35	45/35	45/35	45/35	45/35
Polymer Feed Settings	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Solution Pump: Speed / Stroke												
Dilution Water Rate												
Polymeer Bucket Weight (lbs.)												
Sand Filter Feed Pump in Service (6A/6B)	6A	6A	6A	6A	6A	6A	6A	6A	6A	6A	6A	6A
Sand Filters												
Filter # 1 inlet pressure (psi)	20	22	20	22	18	20	20	20	20	20	20	20
Filter #1 outlet pressure (psi)	20	20	18	20	20	20	22	22	22	22	20	20
Filter # 2 inlet pressure (psi)	20	20	20	20	20	20	20	20	20	20	20	18
Filter #2 outlet pressure (psi)	22	20	20	20	22	22	22	22	22	20	20	18
Filter # 3 inlet pressure (psi)	20	20	18	22	20	20	20	22	20	22	20	20
Filter #3 outlet pressure (psi)	20	22	20	22	22	22	22	22	22	20	20	18
Filter # 4 inlet pressure (psi)	22	20	22	20	20	20	20	20	20	20	20	20
Filter #4 outlet pressure (psi)	20	20	22	20	22	20	22	20	22	18	20	18
Effluent Flow Rate (gpm)	143.71	144.19	140.16	141.23	142.17	141.29	140.91	141.11	140.91	141.11	141.11	141.11
Effluent Filter in Service (yes/no)	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES	YES
Inlet Pressure (psi)	18	16	16	16	16	16	16	16	16	16	16	16
Outlet Pressure (psi)	12	10	10	10	12	14	14	12	12	12	12	12
Reinjection Well Level (feet)	56.80	54.23	54.72	55.12	52.88	51.84	52.70	51.80	52.70	51.71	51.71	51.71
Chemical Storage Levels												
Caustic Level (NaOH)	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Peroxide Level (H ₂ O ₂)	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3	58.3
Acid Level (H ₂ SO ₄)	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9	76.9
Air Compressor (psi)	150	150	140	150	150	140	150	140	150	140	140	140
Compressed Air Dryer (on/off)	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON	ON
Chlorine Pump: Speed / Stroke	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85	60/85
Chlorine Residual Concentration (mg/l)	0.3	0.3	0.2	0.3	0.2	0.2	0.3	0.2	0.3	0.2	0.2	0.2

Servall Laundry Process Control Samples

Date	9/1	9/5	9/6	9/7	9/8	9/11	9/12	9/13	9/14	9/15	9/18	9/19
Time	9:00	9:05	9:30	8:50	9:55	10:00	8:50	9:40	9:30	9:20	10:05	10:00
Influent												
Flow	154.29	156.87	153.72	152.14	156.33	154.49	153.71	151.50	156.63	159.24	152.61	153.17
pH	6.07	6.10	6.00	6.08	5.98	6.01	6.03	6.07	5.98	6.01	6.11	6.04
Iron	0.7	0.6	0.7	0.7	0.8	0.5	0.6	0.5	0.4	0.6	0.5	0.6
UVOX												
Peroxide Residual	13	12	11	11	13	12	11	12	13	12	12	14
pH	6.04	5.92	5.98	6.13	6.01	6.04	5.94	5.94	5.97	6.00	5.92	5.96
Effluent												
pH	7.79	7.72	7.81	7.69	7.68	7.72	7.77	7.64	7.60	7.59	7.61	7.68
Iron	0.3	0.3	0.3	0.2	0.3	0.3	0.3	0.2	0.3	0.2	0.2	0.2
Chlorine	0.2	0.2	0.1	0.3	0.2	0.2	0.3	0.3	0.3	0.2	0.3	0.3

Date	9/20	9/21	9/22	9/25	9/26	9/27	9/28	9/29				
Time	9:40	9:30	9:40	10:00	9:40	9:30	—	—				
Influent												
Flow	154.90	153.11	152.67	154.73	156.20	150.91	0	0				
pH	5.99	6.04	6.00	5.95	5.96	5.94	—	—				
Iron	0.6	0.5	0.5	0.4	0.4	0.5	—	—				
UVOX												
Peroxide Residual	14	12	13	12	13	12	—	—				
pH	5.96	6.00	6.01	5.99	5.92	5.91	—	—				
Effluent												
pH	7.73	7.72	7.76	7.80	7.65	7.69	—	—				
Iron	0.3	0.2	0.2	0.2	0.2	0.3	—	—				
Chlorine	0.2	0.3	0.2	0.2	0.3	0.2	—	—				