

LEGGETTE, BRASHEARS & GRAHAM, INC.

PROFESSIONAL GROUND-WATER AND ENVIRONMENTAL ENGINEERING SERVICES

126 MONROE TURNPIKE
TRUMBULL, CT 06611
203-452-3100
FAX 203-452-3111
www.lbgweb.com

March 14, 2005

Mr. Jeffery Trad
Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation, Construction Services
625 Broadway, 12th floor
Albany, NY 12233-7013

RE: January 2005 Status Report
Ground-Water Remedial Action
Rowe Industries Superfund Site
Sag Harbor, New York


Dear Mr. Trad:

The enclosed letter report details the operation status of the full-scale ground-water pump and treat system at the above referenced site. LBG has enclosed an additional copy of the report to be forwarded to the Chief of the Operation Maintenance and Support Section.

Should you or the Operation Maintenance and Support Section have any questions, please feel free to contact myself, Paul Jobmann, or Al Kovalik at (203) 452-3100.

Very truly yours,

LEGGETTE, BRASHEARS & GRAHAM, INC.




Mark M. Goldberg, P.E.
Senior Environmental Engineer

MG:ng

Enclosures

H:\NABIS\2005\Monthly Reports\Jan 2005\trad_Jan2005_report.doc



-DRAFT-

PROJECT STATUS MEMORANDUM

NO. 01-05

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Alfred N. Kovalik, P.E.

DATE: March 9, 2005

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
January 2005 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from January 1, 2005 through January 31, 2005. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground-water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(January 1, 2005 through January 31, 2005)

- | | |
|--|-----------------|
| 1. Hours of operation during the reporting period: | 532 hours (72%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 13,013,430 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 2.5 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 154.1 pounds |

8. Effluent VOC vapor concentration for the reporting period: 0.082 mg/m³ (Table 3)
9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.: yes (0.00070 lbs/hr)
(calculations can be provided upon request)

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow Required for Plume Capture (gpm)	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-1*	227,022	17	26	3.6	0.007
RW-2*	454,567	27.0	26	25.0	0.09
RW-3*	227,319	17.9	23	ND	ND
RW-4**	657,600	40.0	13	171.4	0.94
RW-5	1,855,510	55.0	42	19.6	0.30
RW-6	927,852	29.1	28	94.2	0.73
RW-7***	2,240,375	70.1	54	38.1	0.71
RW-8	1,415,563	40.2	46	14.8	0.17
RW-9****	821,708	25.7	68	9.0	0.06

* RW-1, RW-2 and RW-3 resumed operation on January 20, 2005. These wells were shut down on November 19, 2004 to minimize GW flow away from the FDSA and allow the EHCTM product to treat the contaminants in the source area. ND indicates VOCs were not detected above laboratory reporting limits.

**Estimated volume and flow due to faulty flow sensor. RW-4 motor malfunctioned on January 12, 2005. A replacement motor has been ordered.

*** RW-7 flow was estimated from the average flow reading and the total time of operation in 2005. The RW-7 flow totalizer is not providing accurate readings. This is being investigated.

**** The RW-9 flow totalizer malfunctioned. RW-9 flow was estimated from the average flow reading and the total time of operation for January 2005. The flow totalizer will be reset in February 2005.

Recovery wells RW-1, RW-3, RW-8 and RW-9 had average flows below the minimum design flow to capture the plume. Despite periodic pipe cleanings RW-1, RW-3 and RW-8 have decreased in flow due to iron build-up in the wells and pipes. Well rehabilitation activities for RW-8 are scheduled for March 2005 with new treatment chemicals. If these treatment chemicals are effective, then well rehabilitation with these new treatment chemicals will be proposed for other wells in the future. To reclaim flow at RW-9, the construction of the new clean-out port

located between RW-8 and RW-9 has been scheduled for the spring of 2005.

The effluent pH values are below the State Pollutant Discharge Elimination System (SPDES) Applicable or Relevant and Appropriate Requirements (ARARs) of 6.5 on a routine basis. pH readings of water samples from the recovery wells are observed to be in the range of approximately 5.8 to 6.5, which is the background pH for the ground water in this area.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
Jan. 1 to Jan 31	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M MODIFICATIONS AND FUTURE O&M ACTIVITIES

- From January 12 to January 14, 2005, vault and below-grade pipe cleaning for RW-2, 4, 6 and 9 was completed. An elbow was replaced with a "tee" fitting in the RW-4 vault to allow easier jet cleaning of below-grade pipes at RW-4. A new flow meter was installed in RW-4.
- On January 13, 2005, a blown fuse for the RW-1 control panel was replaced.
- On January 25, 2005, a service representative from ACFM Dynamics evaluated the current condition of the air stripper blower (ASB) and booster blower (BB) equipment. Recommended follow-up service for the blowers includes providing an inlet air filter, replacing V-belt components, adding isolation dampers, conducting a wheel balance, completing an alignment and re-tensioning of the V-belts and replacing the ASB bearings.

Future O&M activities scheduled for the winter/spring of 2005 include:

- Install a new flow transmitter circuit board in the RW-4 flow meter in February 2005;
- Completing the semi-annual ground-water sampling event in March 2005;
- Completing the RW-8 well rehabilitation with new treatment chemicals in March 2005;
- Constructing a new clean-out port between RW-8 and RW-9;
- Installing a new motor and power cable in RW-4;
- Troubleshoot RW-7 and RW-9 flow meters.

cc: Terry Gerrish, CH2M Hill
Mark Lucas, CH2M Hill
Phil McAndrew, Kraft Foods, N.A. – .pdf
Lisa Krogman, Kraft Foods, N.A. (Environ) – .pdf
Jeff Trad, NYSDEC
Chief-Operation Maintenance and Support Section
Robert Schneck, RWE, R-1, NYSDEC
David Gilmartin, Jr., Esq., Town of Southampton

MMG:ng

Attachments

H:\NABIS\2005\Monthly Reports\Jan 2005\Status0105Jan.doc

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(January 1, 2005 through January 31, 2005)

Date	Time	System Changes/Modifications	Personnel
1/4/2005		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	TS
		Recovery wells RW-1, 2, and 3 remain off to minimize ground-water flow away from FDSA to maximize effectiveness of EHC™ injection.	
		When attempting to collect a ground-water sample from RW-1, the pump would not operate. Troubleshooting revealed that a blown fuse in the RW-1 control panel was the cause. RW-1 was not sampled until a fuse could be purchased.	TS, MG
1/12/2005	10:00 AM	Turned system off for vault pipe, flow meter and below-grade pipe cleaning. Pipe cleaning at recovery wells RW-2, 4, 6 and 9 began.	ETL, TS
		RW-4 vault piping was modified by replacing an elbow with a "tee" to allow for more effective below-grade pipe cleaning with the high pressure water jet. New flow meter installed in RW-4.	ETL, TS
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	TS
1/13/2005		Recovery well vault pipe cleaning continues.	ETL, MG
		Purchased new 2 amp fuse for RW-1. Replaced old fuse with a new 2 amp fuse in the RW-1 control panel.	MG
1/14/2005	10:47 AM	Restarted the system after completing recovery well pipe cleaning	ETL, TS
		Recovery well RW-4 would not ramp-up to speed; left RW-4 in the "off" position until the problem can be investigated.	TS
		Recovery well RW-8 is operating, however flow reading is not being received by the computer. Troubleshooting the RW-8 flow meter will be conducted. RW-8 left on.	TS
1/15/2005	9:54 PM	Communication Failure Alarm and Central Room Temperature Alarm. System Shut Down.	
1/20/2005		Re-set the 480 V and 120 V circuit breaker for the heaters and heat trace tape and turned on the heaters to allow the building to warm up. Water in the pipes was partially frozen. No damage to the piping was observed.	MG
	10:58 AM	Once the building warmed-up, the water in the pipes thawed; the alarms were reset and the system was restarted. Resumed operation of RW-1, RW-2 and RW-3 after a two month shut down to allow the EHC™ product to treat the contaminants in the FDSA.	MG
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	MG
1/23/2005	7:43 AM	Booster Blower Failure Alarm. System shut down	
	8:03 AM	Power Failure Alarm.	

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(January 1, 2005 through January 31, 2005)

Date	Time	System Changes/Modifications	Personnel
1/25/2005	9:35 AM	A service technician from ACFM Dynamics representing New York Blower diagnosed the condition of the air stripper blower (ASB) and the booster blower (BB) to determine if there are performance issues with the blowers. Recommended follow-up service for the blowers includes providing an inlet air filter, replacing V-belt components, isolation dampers, conducting a wheel balance, completing an alignment and re-tensioning of the V-Belts and replacing the ASB bearings.	MG, PR
		Changed multi-bag filter bags (400 um) in bank 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	MG
	1:00 PM	Reset alarms and restarted the system	MG
1/26/2005		Changed multi-bag filter bags (400 um) in banks 1 and 3 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	MG, SS

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled	pH ^{1/}	TDS (mg/L)	PCE (ug/L)	1,1,1-TCA (ug/L)	TCE (ug/L)	1,1-DCA (ug/L)	1,1-DCE (ug/L)	1,2-DCE (ug/L)	Xylene (ug/L)	Bromoform (ug/L)	Dibromo- chloromethane (ug/L)	Methylene Chloride (ug/L)	Freon 113 (ug/L)	Naph- thalene (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)
SPDES Limits	6.5 to 8.5	---	1	5	5	5	5	5	5	---	---	5	---	10	7	---	---	---
4-Jan-05	5.3	96	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.00	0.0902
12-Jan-05	5.3	120	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	0.703	0.171
20-Jan-05	5.3	120	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	119 ^{3/}	1.96 ^{3/}
26-Jan-05	5.3	86	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.22	0.374

SPDES: State Pollutant Discharge Elimination System

mg/L: Milligrams per liter

ug/L: Micrograms per liter

---: Not established

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. pH was measured using litmus paper. Influent pH values from recovery wells, which reflect the pH of natural ground water, are below 6.5 on a regular basis.

2. "Effluent" samples were collected from sample port labeled NP2-10.

3. The January 20, 2005 effluent sample was collected shortly after restarting the system. It is believed that system startups cause iron sediment in the tanks and tower sump to be re-suspended in the water temporarily.

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																					TOTAL
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ020504:924NP4-1	2/5/2004	9:24	1.12	0.052	0.052	ND	ND	ND	0.036	0.004	0.002	ND	ND	0.01	0.062	ND	0.07	0.022	ND	ND	ND	ND	ND	1.43
AQ030304:910NP4-1	3/3/2004	9:10	0.48	0.02	ND	ND	ND	ND	0.014	0.004	ND	ND	ND	0.01	ND	ND	ND	0.068	ND	ND	ND	ND	ND	0.60
AQ040904:1000NP4-1	4/9/2004	10:00	0.425	0.02	0.033	ND	ND	ND	0.023	0.005	ND	ND	ND	0.013	ND	ND	0.04	0.008	ND	ND	ND	ND	ND	0.57
AQ050504:1355NP4-1	5/5/2005	13:55	0.375	0.023	0.035	ND	ND	ND	0.015	0.005	0.0023	ND	ND	0.005	0.06	ND	0.04	0.063	ND	ND	ND	ND	ND	0.62
AQ060204:1200NP4-1	6/2/2004	12:00	0.28	0.013	0.017	ND	ND	ND	0.027	0.005	0.012	0.007	0.002	0.007	0.023	0.005	0.058	0.12	ND	0.004	ND	ND	ND	0.58
AQ070704:1415NP4-1	7/7/2004	14:15	0.86	0.03	0.12	ND	ND	ND	0.02	0.02	ND	ND	ND	0.009	0.05	ND	0.08	0.07	ND	ND	ND	ND	ND	1.26
AQ080404:1330NP4-1	8/4/2004	13:30	1.3	0.089	0.22	0.012	0.016	0.007	0.031	0.004	0.003	0.001	0.004	0.013	0.044	0.005	0.076	0.067	ND	0.001	ND	ND	ND	1.89
AQ090204:1431NP4-1	9/2/2004	14:31	0.83	0.054	0.13	0.009	0.013	0.004	0.028	0.008	0.004	0.001	0.003	0.01	0.073	0.003	0.078	0.04	ND	0.001	ND	ND	ND	1.29
AQ100704:1210NP4-1	10/7/2004	12:10	0.4	0.035	0.058	0.005	0.005	0.003	0.038	0.008	0.003	0.001	0.002	0.008	0.05	ND	0.045	0.06	ND	0.001	ND	ND	ND	0.72
AQ110304:945NP4-1	11/3/2004	9:45	0.44	0.032	0.074	0.01	0.022	0.004	0.02	0.008	0.0018	ND	0.0012	0.008	0.1	0.006	0.02	0.152	ND	ND	ND	ND	ND	0.90
AQ120204:1100NP4-1 ^{1/}	12/2/2004	11:00	0.4	0.026	0.08	0.01	0.022	0.004	0.052	0.03	0.006	0.0014	0.002	ND	1.04	0.012	0.05	0.24	ND	0.0018	ND	ND	ND	1.04
AQ010405:1145NP4-1	1/4/2005	11:45	0.06	0.025	0.0775	ND	ND	ND	0.015	0.005	ND	ND	ND	0.005	0.025	ND	ND	0.04	ND	ND	ND	ND	ND	0.25

Midcarbon			Parameters (mg/m3)																					TOTAL
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ020504:926NP4-2	2/5/2004	9:26	1.1	0.160	0.061	0.011	0.026	0.005	0.048	0.004	0.006	ND	ND	0.013	0.047	ND	0.045	0.015	ND	ND	ND	ND	ND	1.54
AQ030304:912NP4-2	3/3/2004	9:12	0.41	0.057	0.024	ND	ND	ND	0.009	0.002	ND	ND	ND	0.006	0.007	ND	ND	0.005	ND	ND	ND	ND	ND	0.52
AQ040904:1002NP4-2	4/9/2004	10:02	0.325	0.040	0.033	ND	0.023	ND	0.03	0.005	0.002	ND	ND	ND	0.008	ND	0.063	0.008	ND	ND	ND	ND	ND	0.54
AQ050504:1357NP4-2	5/5/2005	13:57	0.25	0.033	0.035	ND	ND	ND	0.02	0.005	0.003	ND	ND	0.008	0.055	ND	0.063	0.083	ND	0.003	ND	ND	ND	0.56
AQ060204:1202NP4-2	6/2/2004	12:02	0.012	0.002	ND	ND	ND	ND	0.02	0.003	0.002	0.0008	0.001	ND	0.021	0.003	0.041	0.057	ND	0.0008	ND	ND	ND	0.16
AQ070704:1420NP4-2	7/7/2004	14:20	0.013	0.002	ND	ND	ND	ND	0.032	0.004	0.003	0.0009	0.003	ND	0.058	0.004	0.097	0.027	ND	0.001	ND	ND	ND	0.24
AQ080404:1335NP4-2	8/4/2004	13:35	0.048	0.002	ND	0.005	ND	ND	0.031	0.002	0.003	0.001	0.003	ND	0.063	0.004	0.078	0.071	ND	0.001	ND	ND	ND	0.31
AQ090204:1432NP4-2	9/2/2004	14:32	0.014	0.002	ND	0.005	ND	ND	0.059	0.005	0.005	0.001	0.003	ND	0.088	0.003	0.086	0.025	ND	0.002	ND	ND	ND	0.30
AQ100704:1212NP4-2	10/7/2004	12:12	0.021	0.001	ND	0.006	0.01	ND	0.016	0.007	0.003	0.001	0.002	0.002	0.011	ND	0.036	0.057	ND	0.001	ND	ND	ND	0.17
AQ110304:947NP4-2	11/3/2004	9:47	0.015	ND	ND	0.007	0.014	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.034	0.005	0.018	0.026	ND	0.0004	ND	ND	ND	0.15
AQ120204:1102NP4-2 ^{1/}	12/2/2004	11:02	0.004	ND	ND	0.009	0.017	0.002	0.034	0.003	0.003	0.0005	0.003	0.011	0.097	0.004	0.025	0.08	ND	0.001	ND	ND	ND	0.23
AQ010405:1150NP4-2	1/4/2005	11:50	0.004	ND	0.045	0.011	0.028	0.003	0.024	0.002	0.001	ND	0.002	0.018	0.009	ND	0.015	0.028	ND	ND	ND	ND	ND	0.19

Postcarbon			Parameters (mg/m3)																					TOTAL
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ020504:928NP4-3	2/5/2004	9:28	0.017	0.019	0.093	0.012	0.024	0.01	0.04	0.004	0.005	ND	ND	0.017	0.046	ND	0.055	0.015	ND	ND	ND	ND	ND	0.36
AQ030304:914NP4-3	3/3/2004	9:14	ND	0.002	0.034	ND	ND	ND	0.011	0.002	ND	ND	ND	0.008	0.008	ND	0.019	0.007	ND	ND	ND	ND	ND	0.09
AQ040904:1005NP4-3	4/9/2004	10:05	0.004	ND	0.028	0.006	0.013	0.004	0.037	0.003	0.004	0.001	0.003	ND	0.009	ND	0.048	0.014	ND	0.001	ND	ND	ND	0.18
AQ050504:1400NP4-3	5/5/2004	14:00	0.004	0.005	0.031	0.006	0.015	0.004	0.016	0.004	0.002	0.0005	0.001	0.008	0.034	0.005	0.039	0.16	ND	0.0007	ND	ND	ND	0.34
AQ060204:1204NP4-3	6/2/2004	12:04	0.003	0.002	ND	ND	ND	ND	0.019	0.002	0.002	0.0005	0.001	ND	0.02	0.004	0.039	0.1	ND	0.0006	ND	ND	ND	0.19
AQ070704:1425NP4-3	7/7/2004	14:25	0.003	0.002	ND	ND	ND	ND	0.032	0.004	0.003	0.0009	0.003	ND	0.062	ND	0.11	0.006	ND	0.001	ND	ND	ND	0.23
AQ080404:1340NP4-3	8/4/2004	13:40	0.02	0.002	ND	ND	ND	ND	0.03	0.004	0.003	0.001	0.004	ND	0.055	0.004	0.067	0.055	ND	0.001	ND	ND	ND	0.25
AQ090204:1433NP4-3	9/2/2004	14:33	0.023	0.003	ND	ND	ND	ND	0.062	0.008	0.005	0.001	0.003	ND	0.087	0.004	0.085	0.033	ND	0.002	ND	ND	ND	0.32
AQ100704:1215NP4-3	10/7/2004	12:15	0.001	0.001	ND	ND	ND	ND	0.045	0.004	0.003	0.0009	0.003	ND	0.011	ND	0.033	0.034	ND	0.001	ND	ND	ND	0.14
AQ110304:950NP4-3	11/3/2004	9:50	0.005	ND	ND	0.002	ND	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.032	ND	0.017	0.022	ND	0.0005	ND	ND	ND	0.11
AQ120204:1105NP4-3 ^{1/}	12/2/2004	11:05	ND	0.002	ND	0.006	ND	ND	0.035	0.011	0.003	0.0006	0.003	ND	0.27	0.005	0.025	0.064	ND	0.001	ND	ND	ND	0.19
AQ010405:1155NP4-3	1/4/2005	11:55	0.002	ND	ND	0.007	0.013	0.002	0.023	0.002	0.002	ND	0.002	ND	0.006	ND	0.015	0.008	ND	ND	ND	ND	ND	0.08

Notes: 1. Methylene Chloride concentrations in all three air samples collected during the December 2, 2004 sampling event are greatly elevated due to suspected laboratory contamination. Methylene chloride was confirmed as a suspected laboratory contaminant by the laboratory supervisor. The methylene chloride concentrations from the November 3, 2004 sampling event were used instead of the December 2, 2004 methylene chloride concentrations to calculate the total VOCs for December 2004.

PCE - Tetrachloroethane
TCE - Trichloroethane
TCA - 1,1,1-Trichloroethane

DCE - 1,1-Dichloroethane
DCA - 1,1-Dichloroethane
cis-DCE - cis-1,2-Dichloroethane
CT - Carbon Tetrachloride

CF - Chloroform
MC - Methylene Chloride
CM - Chloromethane
CD - Carbon Disulfide

BM - Bromomethane
CB - Chlorobenzene
EB - Ethylbenzene
VC - Vinyl Chloride

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropyl-benzene (ug/L) NE	1,1-Dichloro-ethane (ug/L) 5	cis-1,2-Dichloro-ethene (ug/L) 5	1,1-Dichloro-ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloromethane (ug/L) NE	Naphthalene (ug/L) NE
RW-1	21-Mar-03	ND<1	ND<1	ND<1	ND<1	1.4	4.3	0.566	ND<0.02	ND<1	ND<1	ND<1	ND<1	10	ND<1	ND<1	ND<1
	23-Apr-03	ND<1	ND<1	ND<1	ND<1	1.2	8.6	0.053	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	ND<1	ND<1	ND<1	ND<1	1.8	8.7	0.051	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1	ND<1
	11-Jun-03	ND<1	ND<1	ND<1	ND<1	ND<1	8.1	0.0290	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	ND<1	ND<1	ND<1	ND<1	2.9	6.6	0.0100	0.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	ND<1	ND<1	ND<1	ND<1	2.6	9.4	0.0930	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	ND<1	ND<1	ND<1	ND<1	3.2	14	0.0540	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0613	0.0074	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	ND<1	ND<1	ND<1	ND<1	2.2	9.4	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	ND<1	ND<1	ND<1	ND<1	4.0	2.2	0.0098	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	ND<1	ND<1	ND<1	4.6	5.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	ND<1	ND<1	ND<1	ND<1	4.1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.5
	14-Apr-04	ND<1	ND<1	ND<1	ND<1	2.9	6.1	0.0240	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	ND<1	ND<1	ND<1	ND<1	5.6	6.8	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.1 *	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	2.0	3.4	0.0454	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	ND<1	ND<1	ND<1	ND<1	ND<1	3.1	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	8.0
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04 ****	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05 ****	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-2	21-Mar-03	26	1.8	ND<1	ND<1	ND<1	ND<1	11.4	0.059	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Apr-03	14	1.3	ND<1	ND<1	ND<1	ND<1	6.31	0.212	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	2	ND<1	ND<1	ND<1	ND<1	5.51	0.052	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1
	11-Jun-03	15	0.6	ND<1	ND<1	ND<1	ND<1	3.01	0.885	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	5.34	0.438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	7.9	ND<1	ND<1	ND<1	ND<1	ND<1	5.99	0.758	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	9.2	0.5	ND<1	ND<1	ND<1	ND<1	6.0	0.899	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	8.1	0.7	ND<1	ND<1	ND<1	ND<1	6.79	0.101	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	5.5	ND<1	ND<1	ND<1	ND<1	ND<1	5.5	0.0213	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	8.7	ND<1	ND<1	ND<1	ND<1	ND<1	1.1	0.207	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	3.9	0.0748	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	4.9	ND<1	ND<1	ND<1	ND<1	ND<1	3.3	0.343	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	4.4	ND<1	ND<1	ND<1	ND<1	ND<1	2.8	0.224	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	4.7	0.691	ND<1	ND<1	ND<1	ND<1	5.6 *	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	52.5	1.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	6.5	ND<1	ND<1	ND<1	ND<1	ND<1	1.3	4.88	0.704	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	1.5	4.78	0.213	ND<1	ND<1	ND<1	ND<1	2.1	1.5	ND<1
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04 ****	10	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05 ****	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropyl- benzene (ug/L) NE	1,1-Dichloro- ethane (ug/L) 5	cis-1,2-Dichloro- ethene (ug/L) 5	1,1-Dichloro- ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloromethane (ug/L) NE	Naphthalene (ug/L) NE
RW-3	21-Mar-03	2.4	3.6	1.1	ND<1	ND<1	ND<1	1.84	0.013	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Apr-03	1.1	1.2	ND<1	ND<1	ND<1	ND<1	1.81	0.395	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	2.2	2.5	1.1	ND<1	ND<1	ND<1	1.68	0.166	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1
	11-Jun-03	2.4	3.4	1.8	ND<1	ND<1	ND<1	2.37	0.517	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	2.3	5.7	2.3	ND<1	ND<1	ND<1	1.77	0.636	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	2.8	5.8	2.9	ND<1	ND<1	ND<1	2.24	1.57	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	2.1	5.3	2.6	ND<1	ND<1	ND<1	1.86	1.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	1.9	5.2	3.3	ND<1	ND<1	ND<1	2.59	1.27	ND<1	ND<1	0.6	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	1.2	5.8	ND<1	ND<1	ND<1	ND<1	1.96	0.129	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.2	6.9	3.2	ND<1	ND<1	ND<1	1.96	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	3.6	2.2	ND<1	ND<1	ND<1	1.63	1.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	1.2	5.0	2.3	ND<1	ND<1	ND<1	3.34	0.542	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	28-Apr-04	1.3	8.8	4.4	ND<1	ND<1	ND<1	3.07	1.32	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	ND<1
	5-May-04	0.9	6.9	3.6	ND<1	ND<1	ND<1	2.07	1.96	ND<1	ND<1	ND<1	ND<1	5.6*	ND<1	ND<1	ND<1
	30-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.619	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	2.4	6.1	2.6	ND<1	ND<1	ND<1	2.07	1.79	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	2.7	21	8.7	ND<1	ND<1	ND<1	1.91	0.42	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	2.2	12	5.0	ND<1	ND<1	ND<1	2.09	1.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.5	6.5	2.6	ND<1	ND<1	ND<1	1.87	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04 ****	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.77	0.489	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05 ****	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-4	21-Mar-03	150	3.6	ND<1	ND<1	ND<1	ND<1	1.36	0.041	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Apr-03	110	3.1	ND<1	ND<1	ND<1	ND<1	3.18	0.136	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	170	5.4	1.0	ND<1	ND<1	ND<1	3.4	0.023	ND<1	ND<1	ND<1	ND<1	3.3	ND<1	ND<1	ND<1
	11-Jun-03	170	4.8	ND<1	ND<1	ND<1	ND<1	1.03	0.572	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	200	5.9	1.3	ND<1	ND<1	ND<1	2.67	0.292	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	210	5.7	1.1	ND<1	ND<1	ND<1	3.21	0.529	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	390	8.2	1.0	ND<1	ND<1	ND<1	2.95	0.922	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	380	6.8	1.6	ND<1	ND<1	ND<1	6.93	0.221	ND<1	1.2	0.9	0.8	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	270	7.9	ND<1	ND<1	ND<1	ND<1	5.45	0.0331	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	270	5.9	ND<1	ND<1	ND<1	ND<1	3.56	0.48	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	170	6.9	14.0	ND<1	ND<1	ND<1	3.28	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	170	5.8	4.5	ND<1	ND<1	ND<1	1.61	0.0691	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.982	0.173	ND<1	ND<1	ND<1	ND<1	2.1*	ND<1	ND<1	ND<1
	5-May-04	470	6.2	7.8	ND<1	ND<1	ND<1	7.08	2.33	ND<1	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<1
	30-Jun-04	110	3.8	26	ND<1	ND<1	ND<1	4.44	1.11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	110	3.2	29	ND<1	ND<1	ND<1	1.4	5.00	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	120	3.7	18	ND<1	ND<1	ND<1	2.98	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	3.2	ND<1	ND<1
	7-Oct-04	94	ND<1	14	ND<1	ND<1	ND<1	3.65	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	130	4.2	11	ND<1	ND<1	ND<1	4.75	0.205	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	230	5.7	35	ND<1	ND<1	ND<1	1.90	1.62	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	1/4/2005 ****	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropyl- benzene (ug/L) NE	1,1-Dichloro- ethane (ug/L) 5	cis-1,2-Dichloro- ethene (ug/L) 5	1,1-Dichloro- ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloromethane (ug/L) NE	Naphthalene (ug/L) NE
RW-5	21-Mar-03	19	ND<1	ND<1	ND<1	ND<1	ND<1	0.489	0.013	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Apr-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	ND<1	ND<1	ND<1	0.8	6.7	0.146	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1	ND<1
	11-Jun-03	21	ND<1	ND<1	ND<1	ND<1	6.2	0.76	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	11	ND<1	ND<1	ND<1	1.1	9.7	6.47	0.068	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	15	ND<1	ND<1	ND<1	0.9	7.3	0.269	0.021	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	18	ND<1	ND<1	ND<1	ND<1	8.1	0.043	0.016	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	18	ND<1	ND<1	ND<1	ND<1	ND<1	13.1	0.0097	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	ND<1	ND<1	ND<1	ND<1	7.5	0.0523	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	14	ND<1	ND<1	ND<1	0.9	4.0	0.05	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	14	ND<1	ND<1	ND<1	1.0	6.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	14	ND<1	ND<1	ND<1	ND<1	5.0	0.0852	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	18	ND<1	1.5	ND<1	ND<1	6.1	0.147	0.015	ND<1	ND<1	ND<1	ND<1	2*	ND<1	ND<1	ND<1
	5-May-04	38	0.8	3.2	ND<1	1.5	8.0	0.055	0.015	ND<1	ND<1	ND<1	ND<1	6.4*	ND<1	ND<1	ND<1
	14-Jun-04	17	ND<1	4.6	ND<1	ND<1	3.9	0.054	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	21	ND<1	4.6	ND<1	ND<1	3.1	0.0254	0.0265	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	24	ND<1	6.5	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.3	ND<1	ND<1
	7-Oct-04	16	ND<1	5.2	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	ND<1	1.8	1.4	ND<1
	3-Nov-04	15	ND<1	6.4	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	28	ND<1	28	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-6	21-Mar-03	130	1.0	ND<1	ND<1	ND<1	ND<1	3.05	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Apr-03	79	1.0	ND<1	ND<1	ND<1	ND<1	0.028	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	120	1.8	ND<1	ND<1	0.6	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.5	ND<1	ND<1	ND<1
	11-Jun-03	120	0.7	ND<1	ND<1	ND<1	ND<1	0.0097	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	150	0.6	ND<1	ND<1	ND<1	ND<1	0.186	0.034	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	140	2.2	ND<1	ND<1	ND<1	ND<1	0.089	0.018	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	140	2.6	ND<1	ND<1	ND<1	ND<1	0.023	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	180	3.3	1.0	ND<1	ND<1	ND<1	0.342	0.0083	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	120	2.6	ND<1	ND<1	ND<1	ND<1	0.017	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	160	2.4	ND<1	ND<1	ND<1	ND<1	0.015	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	130	3.3	1.1	ND<1	ND<1	1.7	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	110	2.7	ND<1	ND<1	ND<1	1.6	0.077	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	110	2.9	1.3	ND<1	ND<1	2.6	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8*	ND<1	ND<1	ND<1
	5-May-04	210	4.8	ND<1	ND<1	ND<1	3.2	0.719	ND<0.02	ND<1	ND<1	ND<1	ND<1	5.9*	ND<1	ND<1	ND<1
	14-Jun-04	92	3.6	1.3	ND<1	ND<1	2.1	0.151	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	100	2.8	1.2	ND<1	ND<1	1.7	0.437	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1
	7-Oct-04	94	ND<1	1.6	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.9	2.0	ND<1
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	2.5	0.0111	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	200	3.8	16	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropyl-benzene (ug/L) NE	1,1-Dichloro-ethane (ug/L) 5	cis-1,2-Dichloro-ethene (ug/L) 5	1,1-Dichloro-ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloromethane (ug/L) NE	Naphthalene (ug/L) NE
RW-7	21-Mar-03	160	2.3	ND<1	ND<1	ND<1	ND<1	0.405	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Apr-03	100	1.8	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	140	3.1	1.0	ND<1	ND<1	ND<1	0.032	ND<0.02	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1	ND<1
	11-Jun-03	140	2.0	ND<1	ND<1	ND<1	ND<1	0.0246	0.0086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	150	2.1	ND<1	ND<1	ND<1	ND<1	0.024	0.041	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	120	2.3	ND<1	ND<1	ND<1	ND<1	0.011	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	130	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	140	3.4	1.1	ND<1	ND<1	ND<1	0.0464	ND<0.02	ND<1	ND<1	0.2	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	110	2.8	ND<1	ND<1	ND<1	ND<1	0.0239	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	190	3.7	ND<1	ND<1	ND<1	ND<1	0.0069	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	120	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	100	3.0	ND<1	ND<1	ND<1	ND<1	0.0205	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	79	2.5	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.2*	ND<1	ND<1	ND<1
	5-May-04	130	4.0	ND<1	ND<1	ND<1	ND<1	0.012	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<1
	14-Jun-04	59	2.7	ND<1	ND<1	ND<1	ND<1	0.018	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	55	2.1	ND<1	ND<1	ND<1	ND<1	0.791	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	ND<1	ND<1
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	0.0272	0.00876	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-8	21-Mar-03	70	2.9	2.7	ND<1	ND<1	ND<1	0.544	0.141	ND<1	1.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Apr-03	41	2.0	1.8	ND<1	ND<1	ND<1	11.8	0.352	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	61	3.9	3.8	ND<1	ND<1	ND<1	10.1	0.068	ND<1	1.8	ND<1	ND<1	3.4	ND<1	ND<1	ND<1
	11-Jun-03	57	3.1	2.7	ND<1	ND<1	ND<1	9.14	1.10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	35	1.9	3.2	ND<1	ND<1	ND<1	10.5	0.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	30	1.7	3.6	ND<1	ND<1	ND<1	11.1	1.18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	28	2.5	4.4	ND<1	ND<1	ND<1	9.93	0.40	ND<1	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.3	5.4	ND<1	ND<1	ND<1	13.3	0.21	ND<1	4.1	0.7	1.3	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	17	2.1	2.6	ND<1	ND<1	ND<1	9.16	0.05	ND<1	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	16	2.2	4.1	ND<1	ND<1	ND<1	9.73	2.72	ND<1	3.5	ND<1	1.5	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	15	2.2	4.7	ND<1	ND<1	ND<1	8.74	0.19	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	22	2.7	4.3	ND<1	ND<1	ND<1	11.9	0.23	ND<1	3.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	14	2.0	6.2	ND<1	ND<1	ND<1	10.7	0.14	ND<1	5.7	ND<1	ND<1	1.9*	ND<1	ND<1	ND<1
	5-May-04	27	4.1	8.3	ND<1	ND<1	ND<1	8.77	0.21	ND<1	8.7	ND<1	ND<1	8.5*	ND<1	ND<1	ND<1
	14-Jun-04	10	2.4	5.8	ND<1	ND<1	ND<1	9.15	0.10	ND<1	4.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04 **	3	1.0	3.7	ND<1	ND<1	ND<1	4.18	0.21	ND<1	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	28.8	0.2	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	10.6	0.3	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	16	ND<1	22	ND<1	ND<1	ND<1	15.6	0.1	ND<1	15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	ND<1	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-9	21-Mar-03	23	2.2	2.8	ND<1	ND<1	ND<1	11.0	0.013	ND<1	1.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Apr-03	15	1.2	1.8	ND<1	ND<1	ND<1	3.55	1.97	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	1.8	3.6	ND<1	ND<1	ND<1	2.95	0.046	ND<1	1.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Jun-03	18	1.6	4.8	ND<1	ND<1	ND<1	2.75	1.74	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	4.7	1.6	7.3	ND<1	ND<1	ND<1	3.60	0.467	ND<1	3.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	25	1.2	3.5	ND<1	ND<1	ND<1	4.05	2.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	22	2.1	5.8	ND<1	ND<1	ND<1	3.49	2.88	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.2	8.2	ND<1	ND<1	ND<1	5.39	1.72	ND<1	5.2	ND<1	1.4	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	1.7	5.4	ND<1	ND<1	ND<1	1.94	1.57	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.3	2.2	13	ND<1	ND<1	ND<1	0.638	0.029	ND<1	1.8	ND<1	1.5	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	2.2	12	ND<1	ND<1	ND<1	1.24	0.222	ND<1	3.7	ND<1	1.3	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	5.6	1.7	10	ND<1	ND<1	ND<1	2.65	1.22	ND<1	5.9	ND<1	2.0	2.0*	ND<1	ND<1	ND<1
	5-May-04	3.7	1.7	13	ND<1	ND<1	ND<1	2.58	1.83	ND<1	6.7	ND<1	1.7	7.1*	ND<1	ND<1	ND<1
	14-Jun-04	1.8	1.9	8.2	ND<1	ND<1	ND<1	3.03	1.11	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	3.4	1.3	5.1	ND<1	ND<1	ND<1	2.6	1.95	ND<1	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	ND<1	1.9	ND<1	ND<1	ND<1	1.6	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

ND: Not detected

<#: Less than method detection limit

ug/L: Micrograms per liter

-: Not analyzed

PCE: Tetrachloroethylene

TCE: Trichloroethene

TCA: 1,1,1-Trichloroethane

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl Tertiary Butyl Ether

NM: Not Measured

ARAR's are chemical specific aquifer restoration goals for ground-water at the Former Rowe Industries Superfund Site.

Bold values indicate an exceedance of the ARAR standard established for the site.

*Methylene Chloride detected in laboratory method blank

NE: ARAR goal was not established for this compound by the EPA.

** The July 14, 2004 sample collected for RW-8 only represents water in the pipe since the RW-8 pump was not operating at this time.


*** The August 26, 2004 samples were lost during shipment.

**** Recovery wells RW-1, RW-2 and RW-3 were turned on briefly in December 2004 and January 2005 to collect the monthly ground-water samples on the dates shown.

GRAPHS


GRAPH 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
(January 1, 2005 through January 31, 2005)




GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
JANUARY 2005 LABORATORY ANALYTICAL REPORTS

Monday, January 10, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0501027

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/6/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0501027

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0501027-01A	WQ010405:1130 NP2-6	2429	1/4/2005	1/6/2005
0501027-01B	WQ010405:1130 NP2-6	2429	1/4/2005	1/6/2005
0501027-01C	WQ010405:1130 NP2-6	2429	1/4/2005	1/6/2005
0501027-02A	WQ010405:1135 NP2-7	2429	1/4/2005	1/6/2005
0501027-02B	WQ010405:1135 NP2-7	2429	1/4/2005	1/6/2005
0501027-02C	WQ010405:1135 NP2-7	2429	1/4/2005	1/6/2005
0501027-03A	WQ010405:1140 NP2-10	2429	1/4/2005	1/6/2005
0501027-03B	WQ010405:1140 NP2-10	2429	1/4/2005	1/6/2005
0501027-03C	WQ010405:1140 NP2-10	2429	1/4/2005	1/6/2005

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1130 NP2-6
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-01A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,1,1-Trichloroethane	3.7	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
2-Butanone	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
2-Hexanone	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Acetone	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Benzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Bromobenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Bromoform	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Bromomethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Chloroethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1130 NP2-6
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-01A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Chloromethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Dibromomethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/6/2005 11:23:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Methylene chloride	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Naphthalene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
o-Xylene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Styrene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Tetrachloroethene	26	1.0		µg/L	1	1/6/2005 11:23:00 PM
Toluene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Trichloroethene	0.98	1.0	J	µg/L	1	1/6/2005 11:23:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/6/2005 11:23:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/6/2005 11:23:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1130 NP2-6
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-01B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	1.45	0.0200		mg/L	1	1/7/2005 9:57:41 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1130 NP2-6
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-01C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.307	0.0200		mg/L	1	1/7/2005 9:55:21 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1135 NP2-7
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-02A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
2-Butanone	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
2-Hexanone	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Acetone	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Benzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Bromobenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Bromoform	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Bromomethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Chloroethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1135 NP2-7
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-02A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Chloromethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Dibromomethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/6/2005 11:57:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Methylene chloride	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Naphthalene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
o-Xylene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Styrene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Toluene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Trichloroethene	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/6/2005 11:57:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/6/2005 11:57:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1135 NP2-7
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-02B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	7.70	0.0200		mg/L	1	1/7/2005 10:14:18 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1135 NP2-7
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-02C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0786	0.0200		mg/L	1	1/7/2005 10:02:12 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1140 NP2-10
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-03A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
2-Butanone	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
2-Hexanone	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Acetone	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Benzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Bromobenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Bromoform	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Bromomethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Chloroethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1140 NP2-10
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-03A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Chloromethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Dibromomethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/7/2005 12:30:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Methylene chloride	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Naphthalene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
o-Xylene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Styrene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Toluene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Trichloroethene	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/7/2005 12:30:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/7/2005 12:30:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1140 NP2-10
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-03B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	1.00	0.0200		mg/L	1	1/7/2005 10:19:50 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 10-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010405:1140 NP2-10
Lab Order:	0501027	Tag Number:	2429
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501027-03C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0902	0.0200		mg/L	1	1/7/2005 10:16:31 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	96	1.0		mg/L	1	1/7/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

Tuesday, January 11, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0501029

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 1/6/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director




American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0501029

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0501029-01A	GWQ010405:1215 NP1-1-2		1/4/2005	1/6/2005
0501029-01B	GWQ010405:1215 NP1-1-2		1/4/2005	1/6/2005
0501029-01C	GWQ010405:1215 NP1-1-2		1/4/2005	1/6/2005
0501029-01D	GWQ010405:1215 NP1-1-2		1/4/2005	1/6/2005
0501029-02A	GWQ010405:1230 NP1-1-3		1/4/2005	1/6/2005
0501029-02B	GWQ010405:1230 NP1-1-3		1/4/2005	1/6/2005
0501029-02C	GWQ010405:1230 NP1-1-3		1/4/2005	1/6/2005
0501029-02D	GWQ010405:1230 NP1-1-3		1/4/2005	1/6/2005
0501029-03A	GWQ010405:1245 NP1-1-4		1/4/2005	1/6/2005
0501029-03B	GWQ010405:1245 NP1-1-4		1/4/2005	1/6/2005
0501029-03C	GWQ010405:1245 NP1-1-4		1/4/2005	1/6/2005
0501029-03D	GWQ010405:1245 NP1-1-4		1/4/2005	1/6/2005
0501029-04A	GWQ010405:1300 NP1-1-5		1/4/2005	1/6/2005
0501029-04B	GWQ010405:1300 NP1-1-5		1/4/2005	1/6/2005
0501029-04C	GWQ010405:1300 NP1-1-5		1/4/2005	1/6/2005
0501029-04D	GWQ010405:1300 NP1-1-5		1/4/2005	1/6/2005
0501029-05A	GWQ010405:1315 NP1-1-6		1/4/2005	1/6/2005
0501029-05B	GWQ010405:1315 NP1-1-6		1/4/2005	1/6/2005
0501029-05C	GWQ010405:1315 NP1-1-6		1/4/2005	1/6/2005
0501029-05D	GWQ010405:1315 NP1-1-6		1/4/2005	1/6/2005
0501029-06A	GWQ010405:1330 NP1-1-7		1/4/2005	1/6/2005
0501029-06B	GWQ010405:1330 NP1-1-7		1/4/2005	1/6/2005
0501029-06C	GWQ010405:1330 NP1-1-7		1/4/2005	1/6/2005
0501029-06D	GWQ010405:1330 NP1-1-7		1/4/2005	1/6/2005
0501029-07A	GWQ010405:1345 NP1-1-8		1/4/2005	1/6/2005
0501029-07B	GWQ010405:1345 NP1-1-8		1/4/2005	1/6/2005
0501029-07C	GWQ010405:1345 NP1-1-8		1/4/2005	1/6/2005
0501029-07D	GWQ010405:1345 NP1-1-8		1/4/2005	1/6/2005
0501029-08A	GWQ010405:1400 NP1-1-9		1/4/2005	1/6/2005
0501029-08B	GWQ010405:1400 NP1-1-9		1/4/2005	1/6/2005
0501029-08C	GWQ010405:1400 NP1-1-9		1/4/2005	1/6/2005
0501029-08D	GWQ010405:1400 NP1-1-9		1/4/2005	1/6/2005



NYSDOH	ELAP	11418
CTDOH	PH-0205	
NJDEP	NY050	
PADEP	68-573	

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT: Leggett Brashears & Graham Inc. Client Sample ID: GWQ010405:1215 NP1-1-2
 Lab Order: 0501029 Tag Number:
 Project: Rowe Industries Collection Date: 1/4/2005
 Lab ID: 0501029-01A Date Received: 1/6/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
2-Butanone	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
2-Hexanone	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Acetone	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Benzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Bromobenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Bromoform	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Bromomethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Chloroethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1215 NP1-1-2
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-01A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Chloromethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Dibromomethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/7/2005 1:08:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Methylene chloride	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Naphthalene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
o-Xylene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Styrene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Tetrachloroethene	25	1.0		µg/L	1	1/7/2005 1:08:00 AM
Toluene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Trichloroethene	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/7/2005 1:08:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/7/2005 1:08:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1215 NP1-1-2
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-01B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	4.81	0.0200		mg/L	1	1/7/2005 10:25:47 AM
Manganese	0.486	0.0200		mg/L	1	1/7/2005 10:25:47 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1215 NP1-1-2
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-01C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	1.50	0.0200		mg/L	1	1/7/2005 10:23:50 AM
Manganese	0.493	0.0200		mg/L	1	1/7/2005 10:23:50 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1215 NP1-1-2
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-01D	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	35.5	1.00	M2340 B	mg/L	1	1/7/2005
TOTAL DISSOLVED SOLIDS						Analyst: AT
Total Dissolved Solids (Residue, Filterable)	23	1.0	E160.1	mg/L	1	1/7/2005
TURBIDITY						Analyst: KK
Turbidity	2.50	1.00	E180.1	NTU	1	1/10/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ010405:1230 NP1-1-3
Lab Order: 0501029 **Tag Number:**
Project: Rowe Industries **Collection Date:** 1/4/2005
Lab ID: 0501029-02A **Date Received:** 1/6/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
2-Butanone	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
2-Hexanone	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Acetone	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Benzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Bromobenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Bromoform	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Bromomethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Chloroethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1230 NP1-1-3
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-02A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Chloromethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Dibromomethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/7/2005 1:41:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Methylene chloride	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Naphthalene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
o-Xylene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Styrene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Toluene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Trichloroethene	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/7/2005 1:41:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/7/2005 1:41:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1230 NP1-1-3
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-02B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	2.60	0.0200		mg/L	1	1/7/2005 10:32:18 AM
Manganese	0.0911	0.0200		mg/L	1	1/7/2005 10:32:18 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1230 NP1-1-3
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-02C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	2.24	0.0200		mg/L	1	1/7/2005 10:29:33 AM
Manganese	0.0890	0.0200		mg/L	1	1/7/2005 10:29:33 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1230 NP1-1-3
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-02D	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	33.1	1.00		mg/L	1	1/7/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	93	1.0		mg/L	1	1/7/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	5.10	1.00		NTU	1	1/10/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ010405:1245 NP1-1-4
 Lab Order: 0501029 Tag Number:
 Project: Rowe Industries Collection Date: 1/4/2005
 Lab ID: 0501029-03A Date Received: 1/6/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,1,1-Trichloroethane	7.3	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
2-Butanone	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
2-Hexanone	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Acetone	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Benzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Bromobenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Bromoform	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Bromomethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Chloroethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1245 NP1-1-4
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-03A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Chloromethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Dibromomethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/7/2005 2:14:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Methylene chloride	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Naphthalene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
o-Xylene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Styrene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Tetrachloroethene	160	1.0		µg/L	1	1/7/2005 2:14:00 AM
Toluene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Trichloroethene	4.1	1.0		µg/L	1	1/7/2005 2:14:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/7/2005 2:14:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/7/2005 2:14:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1245 NP1-1-4
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-03B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	6.11	0.0200		mg/L	1	1/7/2005 10:37:13 AM
Manganese	1.86	0.0200		mg/L	1	1/7/2005 10:37:13 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1245 NP1-1-4
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-03C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	3.28	0.0200		mg/L	1	1/7/2005 10:35:10 AM
Manganese	1.79	0.0200		mg/L	1	1/7/2005 10:35:10 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1245 NP1-1-4
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-03D	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	33.2	1.00		mg/L	1	1/7/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	95	1.0		mg/L	1	1/7/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	3.40	1.00		NTU	1	1/10/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1300 NP1-1-5
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-04A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,1,1-Trichloroethane	5.6	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
2-Butanone	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
2-Hexanone	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Acetone	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Benzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Bromobenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Bromoform	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Bromomethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Chloroethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ010405:1300 NP1-1-5
 Lab Order: 0501029 Tag Number:
 Project: Rowe Industries Collection Date: 1/4/2005
 Lab ID: 0501029-04A Date Received: 1/6/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Chloromethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Dibromomethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/7/2005 2:47:00 AM
Methyl tert-butyl ether	2.0	1.0		µg/L	1	1/7/2005 2:47:00 AM
Methylene chloride	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Naphthalene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
o-Xylene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Styrene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Tetrachloroethene	12	1.0		µg/L	1	1/7/2005 2:47:00 AM
Toluene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Trichloroethene	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/7/2005 2:47:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/7/2005 2:47:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1300 NP1-1-5
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-04B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0269	0.0200		mg/L	1	1/7/2005 10:48:18 AM
Manganese	U	0.0200		mg/L	1	1/7/2005 10:48:18 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1300 NP1-1-5
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-04C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0172	0.0200	J	mg/L	1	1/7/2005 10:39:27 AM
Manganese	U	0.0200		mg/L	1	1/7/2005 10:39:27 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1300 NP1-1-5
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-04D	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	33.3	1.00		mg/L	1	1/7/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	1/7/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	1/10/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ010405:1315 NP1-1-6
 Lab Order: 0501029 Tag Number:
 Project: Rowe Industries Collection Date: 1/4/2005
 Lab ID: 0501029-05A Date Received: 1/6/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,1,1-Trichloroethane	3.7	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
2-Butanone	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
2-Hexanone	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Acetone	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Benzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Bromobenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Bromoform	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Bromomethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Chloroethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1315 NP1-1-6
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-05A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Chloromethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Dibromomethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/7/2005 3:20:00 AM
Methyl tert-butyl ether	2.4	1.0		µg/L	1	1/7/2005 3:20:00 AM
Methylene chloride	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Naphthalene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
o-Xylene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Styrene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Tetrachloroethene	86	1.0		µg/L	1	1/7/2005 3:20:00 AM
Toluene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Trichloroethene	2.1	1.0		µg/L	1	1/7/2005 3:20:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/7/2005 3:20:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/7/2005 3:20:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1315 NP1-1-6
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-05B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0279	0.0200		mg/L	1	1/7/2005 10:53:46 AM
Manganese	0.253	0.0200		mg/L	1	1/7/2005 10:53:46 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1315 NP1-1-6
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-05C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	1/7/2005 10:51:29 AM
Manganese	0.244	0.0200		mg/L	1	1/7/2005 10:51:29 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1315 NP1-1-6
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-05D	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	35.5	1.00	M2340 B	mg/L	1	1/7/2005
TOTAL DISSOLVED SOLIDS						Analyst: AT
Total Dissolved Solids (Residue, Filterable)	130	1.0	E160.1	mg/L	1	1/7/2005
TURBIDITY						Analyst: KK
Turbidity	U	1.00	E180.1	NTU	1	1/10/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ010405:1330 NP1-1-7
 Lab Order: 0501029 Tag Number:
 Project: Rowe Industries Collection Date: 1/4/2005
 Lab ID: 0501029-06A Date Received: 1/6/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B	Analyst: LDS	
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
2-Butanone	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
2-Hexanone	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Acetone	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Benzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Bromobenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Bromoform	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Bromomethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Chloroethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1330 NP1-1-7
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-06A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Chloromethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Dibromomethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/7/2005 3:53:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Methylene chloride	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Naphthalene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
o-Xylene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Styrene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Tetrachloroethene	37	1.0		µg/L	1	1/7/2005 3:53:00 AM
Toluene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Trichloroethene	1.1	1.0		µg/L	1	1/7/2005 3:53:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/7/2005 3:53:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/7/2005 3:53:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1330 NP1-1-7
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-06B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0343	0.0200		mg/L	1	1/7/2005 10:58:15 AM
Manganese	0.0436	0.0200		mg/L	1	1/7/2005 10:58:15 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1330 NP1-1-7
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-06C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	1/7/2005 10:56:09 AM
Manganese	0.0446	0.0200		mg/L	1	1/7/2005 10:56:09 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1330 NP1-1-7
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-06D	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	28.4	1.00		mg/L	1	1/7/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	89	1.0		mg/L	1	1/7/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	1/10/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ010405:1345 NP1-1-8
 Lab Order: 0501029 Tag Number:
 Project: Rowe Industries Collection Date: 1/4/2005
 Lab ID: 0501029-07A Date Received: 1/6/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,1,1-Trichloroethane	3.9	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,1-Dichloroethane	2.7	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
2-Butanone	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
2-Hexanone	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Acetone	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Benzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Bromobenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Bromoform	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Bromomethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Chloroethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ010405:1345 NP1-1-8
 Lab Order: 0501029 Tag Number:
 Project: Rowe Industries Collection Date: 1/4/2005
 Lab ID: 0501029-07A Date Received: 1/6/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Chloromethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Dibromomethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/7/2005 6:43:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Methylene chloride	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Naphthalene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
o-Xylene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Styrene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Tetrachloroethene	6.9	1.0		µg/L	1	1/7/2005 6:43:00 AM
Toluene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Trichloroethene	1.3	1.0		µg/L	1	1/7/2005 6:43:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/7/2005 6:43:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/7/2005 6:43:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1345 NP1-1-8
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-07B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	8.92	0.0200		mg/L	1	1/7/2005 11:03:10 AM
Manganese	0.616	0.0200		mg/L	1	1/7/2005 11:03:10 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1345 NP1-1-8
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-07C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	2.85	0.0200		mg/L	1	1/7/2005 11:00:48 AM
Manganese	0.603	0.0200		mg/L	1	1/7/2005 11:00:48 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1345 NP1-1-8
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-07D	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	23.8	1.00		mg/L	1	1/7/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	170	1.0		mg/L	1	1/7/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	2.70	1.00		NTU	1	1/10/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1400 NP1-1-9
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-08A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,1,1-Trichloroethane	6.4	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,1-Dichloroethane	1.6	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
2-Butanone	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
2-Hexanone	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Acetone	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Benzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Bromobenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Bromoform	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Bromomethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Chloroethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1400 NP1-1-9
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-08A	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
Chloroform	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Chloromethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Dibromomethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/7/2005 7:15:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Methylene chloride	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Naphthalene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
o-Xylene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Styrene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Toluene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Trichloroethene	0.96	1.0	J	µg/L	1	1/7/2005 7:15:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/7/2005 7:15:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/7/2005 7:15:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1400 NP1-1-9
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-08B	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	2.35	0.0200		mg/L	1	1/7/2005 11:09:40 AM
Manganese	0.972	0.0200		mg/L	1	1/7/2005 11:09:40 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1400 NP1-1-9
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-08C	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	1.72	0.0200		mg/L	1	1/7/2005 11:07:17 AM
Manganese	0.965	0.0200		mg/L	1	1/7/2005 11:07:17 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 11-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ010405:1400 NP1-1-9
Lab Order:	0501029	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/4/2005
Lab ID:	0501029-08D	Date Received:	1/6/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	26.6	1.00		mg/L	1	1/7/2005
TOTAL DISSOLVED SOLIDS						Analyst: AT
Total Dissolved Solids (Residue, Filterable)	91	1.0		mg/L	1	1/7/2005
TURBIDITY						Analyst: KK
Turbidity	1.70	1.00		NTU	1	1/10/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits		

Monday, January 24, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0501118

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 4 sample(s) on 1/18/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0501118**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0501118-01A	WQ011305:1100 NP2-6	3213	1/13/2005	1/18/2005
0501118-01B	WQ011305:1100 NP2-6	3213	1/13/2005	1/18/2005
0501118-01C	WQ011305:1100 NP2-6	3213	1/13/2005	1/18/2005
0501118-02A	WQ011305:1105 NP2-7	3213	1/13/2005	1/18/2005
0501118-02B	WQ011305:1105 NP2-7	3213	1/13/2005	1/18/2005
0501118-02C	WQ011305:1105 NP2-7	3213	1/13/2005	1/18/2005
0501118-03A	WQ011305:1110 NP2-10	3213	1/13/2005	1/18/2005
0501118-03B	WQ011305:1110 NP2-10	3213	1/13/2005	1/18/2005
0501118-03C	WQ011305:1110 NP2-10	3213	1/13/2005	1/18/2005
0501118-04A	GWQ011305:1300 NP1-1-1	3213	1/13/2005	1/18/2005
0501118-04B	GWQ011305:1300 NP1-1-1	3213	1/13/2005	1/18/2005
0501118-04C	GWQ011305:1300 NP1-1-1	3213	1/13/2005	1/18/2005
0501118-04D	GWQ011305:1300 NP1-1-1	3213	1/13/2005	1/18/2005

56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ011305:1100 NP2-6
 Lab Order: 0501118 Tag Number: 3213
 Project: Rowe Industries Collection Date: 1/13/2005
 Lab ID: 0501118-01A Date Received: 1/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,1,1-Trichloroethane	3.8	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
2-Butanone	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
2-Hexanone	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Acetone	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Benzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Bromobenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Bromoform	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Bromomethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Chloroethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ011305:1100 NP2-6
Lab Order: 0501118 **Tag Number:** 3213
Project: Rowe Industries **Collection Date:** 1/13/2005
Lab ID: 0501118-01A **Date Received:** 1/18/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Chloromethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Dibromomethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/19/2005 10:33:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Methylene chloride	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Naphthalene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
o-Xylene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Styrene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Tetrachloroethene	27	1.0		µg/L	1	1/19/2005 10:33:00 AM
Toluene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Trichloroethene	1.0	1.0		µg/L	1	1/19/2005 10:33:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/19/2005 10:33:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/19/2005 10:33:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011305:1100 NP2-6
Lab Order:	0501118	Tag Number:	3213
Project:	Rowe Industries	Collection Date:	1/13/2005
Lab ID:	0501118-01B	Date Received:	1/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		{SW3010A}		Analyst: JP
Iron	4.17	0.0200		mg/L	1	1/21/2005 10:45:49 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011305:1100 NP2-6
Lab Order:	0501118	Tag Number:	3213
Project:	Rowe Industries	Collection Date:	1/13/2005
Lab ID:	0501118-01C	Date Received:	1/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0820	0.0200		mg/L	1	1/21/2005 10:42:09 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 4 of 17

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ011305:1105 NP2-7
 Lab Order: 0501118 Tag Number: 3213
 Project: Rowe Industries Collection Date: 1/13/2005
 Lab ID: 0501118-02A Date Received: 1/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
2-Butanone	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
2-Hexanone	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Acetone	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Benzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Bromobenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Bromoform	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Bromomethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Chloroethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ011305:1105 NP2-7
 Lab Order: 0501118 Tag Number: 3213
 Project: Rowe Industries Collection Date: 1/13/2005
 Lab ID: 0501118-02A Date Received: 1/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Chloromethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Dibromomethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/19/2005 11:05:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Methylene chloride	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Naphthalene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
o-Xylene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Styrene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Toluene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Trichloroethene	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/19/2005 11:05:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/19/2005 11:05:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011305:1105 NP2-7
Lab Order:	0501118	Tag Number:	3213
Project:	Rowe Industries	Collection Date:	1/13/2005
Lab ID:	0501118-02B	Date Received:	1/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	2.60	0.0200		mg/L	1	1/21/2005 10:50:42 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ011305:1110 NP2-10
 Lab Order: 0501118 Tag Number: 3213
 Project: Rowe Industries Collection Date: 1/13/2005
 Lab ID: 0501118-03A Date Received: 1/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
2-Butanone	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
2-Hexanone	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Acetone	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Benzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Bromobenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Bromoform	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Bromomethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Chloroethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ011305:1110 NP2-10
 Lab Order: 0501118 Tag Number: 3213
 Project: Rowe Industries Collection Date: 1/13/2005
 Lab ID: 0501118-03A Date Received: 1/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Chloromethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Dibromomethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/19/2005 11:41:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Methylene chloride	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Naphthalene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
o-Xylene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Styrene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Toluene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Trichloroethene	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/19/2005 11:41:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/19/2005 11:41:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011305:1110 NP2-10
Lab Order:	0501118	Tag Number:	3213
Project:	Rowe Industries	Collection Date:	1/13/2005
Lab ID:	0501118-03B	Date Received:	1/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	0.703	0.0200		mg/L	1	1/21/2005 11:12:07 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011305:1110 NP2-10
Lab Order:	0501118	Tag Number:	3213
Project:	Rowe Industries	Collection Date:	1/13/2005
Lab ID:	0501118-03C	Date Received:	1/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.171	0.0200		mg/L	1	1/21/2005 11:09:31 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	1/19/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ011305:1300 NP1-1-1
 Lab Order: 0501118 Tag Number: 3213
 Project: Rowe Industries Collection Date: 1/13/2005
 Lab ID: 0501118-04A Date Received: 1/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
2-Butanone	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
2-Hexanone	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Acetone	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Benzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Bromobenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Bromoform	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Bromomethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Chloroethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ011305:1300 NP1-1-1
 Lab Order: 0501118 Tag Number: 3213
 Project: Rowe Industries Collection Date: 1/13/2005
 Lab ID: 0501118-04A Date Received: 1/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	1.5	1.0		µg/L	1	1/19/2005 12:25:00 PM
Chloromethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Dibromomethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/19/2005 12:25:00 PM
Methyl tert-butyl ether	2.1	1.0		µg/L	1	1/19/2005 12:25:00 PM
Methylene chloride	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Naphthalene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
o-Xylene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Styrene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Toluene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Trichloroethene	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/19/2005 12:25:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/19/2005 12:25:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011305:1300 NP1-1-1
Lab Order:	0501118	Tag Number:	3213
Project:	Rowe Industries	Collection Date:	1/13/2005
Lab ID:	0501118-04B	Date Received:	1/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0703	0.0200		mg/L	1	1/21/2005 11:23:10 AM
Manganese	0.251	0.0200		mg/L	1	1/21/2005 11:23:10 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ011305:1300 NP1-1-1
Lab Order: 0501118 **Tag Number:** 3213
Project: Rowe Industries **Collection Date:** 1/13/2005
Lab ID: 0501118-04C **Date Received:** 1/18/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0326	0.0200		mg/L	1	1/21/2005 11:20:03 AM
Manganese	0.251	0.0200		mg/L	1	1/21/2005 11:20:03 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	250	1.0		mg/L	1	1/19/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011305:1300 NP1-1-1
Lab Order:	0501118	Tag Number:	3213
Project:	Rowe Industries	Collection Date:	1/13/2005
Lab ID:	0501118-04D	Date Received:	1/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	52.8	1.00		mg/L	1	1/21/2005
TURBIDITY						Analyst: KK
Turbidity	U	1.00		NTU	1	1/20/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Monday, January 31, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0501149

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/21/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0501149

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0501149-01A	WQ012005:1120 NP2-6	2255	1/20/2005	1/21/2005
0501149-01B	WQ012005:1120 NP2-6	2255	1/20/2005	1/21/2005
0501149-01C	WQ012005:1120 NP2-6	2255	1/20/2005	1/21/2005
0501149-02A	WQ012005:1122 NP2-7	2255	1/20/2005	1/21/2005
0501149-02B	WQ012005:1122 NP2-7	2255	1/20/2005	1/21/2005
0501149-02C	WQ012005:1122 NP2-7	2255	1/20/2005	1/21/2005
0501149-03A	WQ012005:1125 NP2-10	2255	1/20/2005	1/21/2005
0501149-03B	WQ012005:1125 NP2-10	2255	1/20/2005	1/21/2005
0501149-03C	WQ012005:1125 NP2-10	2255	1/20/2005	1/21/2005

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ012005:1120 NP2-6
 Lab Order: 0501149 Tag Number: 2255
 Project: Rowe Industries Collection Date: 1/20/2005
 Lab ID: 0501149-01A Date Received: 1/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,1,1-Trichloroethane	2.4	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
2-Butanone	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
2-Hexanone	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Acetone	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Benzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Bromobenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Bromoform	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Bromomethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Chloroethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ012005:1120 NP2-6
Lab Order: 0501149 **Tag Number:** 2255
Project: Rowe Industries **Collection Date:** 1/20/2005
Lab ID: 0501149-01A **Date Received:** 1/21/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Chloromethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
cis-1,2-Dichloroethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Dibromomethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/24/2005 1:25:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Methylene chloride	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Naphthalene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
o-Xylene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Styrene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Tetrachloroethene	27	1.0		µg/L	1	1/24/2005 1:25:00 PM
Toluene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Trichloroethene	1.6	1.0		µg/L	1	1/24/2005 1:25:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/24/2005 1:25:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/24/2005 1:25:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012005:1120 NP2-6
Lab Order:	0501149	Tag Number:	2255
Project:	Rowe Industries	Collection Date:	1/20/2005
Lab ID:	0501149-01B	Date Received:	1/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	18.6	0.0200		mg/L	1	1/25/2005 11:22:19 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012005:1120 NP2-6
Lab Order:	0501149	Tag Number:	2255
Project:	Rowe Industries	Collection Date:	1/20/2005
Lab ID:	0501149-01C	Date Received:	1/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0792	0.0200		mg/L	1	1/25/2005 11:20:09 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ012005:1122 NP2-7
 Lab Order: 0501149 Tag Number: 2255
 Project: Rowe Industries Collection Date: 1/20/2005
 Lab ID: 0501149-02A Date Received: 1/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
2-Butanone	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
2-Hexanone	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Acetone	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Benzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Bromobenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Bromoform	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Bromomethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Chloroethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ012005:1122 NP2-7
Lab Order: 0501149 **Tag Number:** 2255
Project: Rowe Industries **Collection Date:** 1/20/2005
Lab ID: 0501149-02A **Date Received:** 1/21/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Chloromethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Dibromomethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/24/2005 1:58:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Methylene chloride	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Naphthalene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
o-Xylene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Styrene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Toluene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Trichloroethene	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/24/2005 1:58:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/24/2005 1:58:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012005:1122 NP2-7
Lab Order:	0501149	Tag Number:	2255
Project:	Rowe Industries	Collection Date:	1/20/2005
Lab ID:	0501149-02B	Date Received:	1/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	155	0.0200		mg/L	1	1/25/2005 11:27:13 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012005:1122 NP2-7
Lab Order:	0501149	Tag Number:	2255
Project:	Rowe Industries	Collection Date:	1/20/2005
Lab ID:	0501149-02C	Date Received:	1/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	1.44	0.0200		mg/L	1	1/25/2005 11:24:52 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ012005:1125 NP2-10
 Lab Order: 0501149 Tag Number: 2255
 Project: Rowe Industries Collection Date: 1/20/2005
 Lab ID: 0501149-03A Date Received: 1/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
2-Butanone	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
2-Hexanone	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Acetone	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Benzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Bromobenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Bromoform	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Bromomethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Chloroethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ012005:1125 NP2-10

Lab Order: 0501149

Tag Number: 2255

Project: Rowe Industries

Collection Date: 1/20/2005

Lab ID: 0501149-03A

Date Received: 1/21/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Chloromethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Dibromomethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/24/2005 2:30:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Methylene chloride	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Naphthalene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
o-Xylene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Styrene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Toluene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Trichloroethene	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/24/2005 2:30:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/24/2005 2:30:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012005:1125 NP2-10
Lab Order:	0501149	Tag Number:	2255
Project:	Rowe Industries	Collection Date:	1/20/2005
Lab ID:	0501149-03B	Date Received:	1/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	119	0.0200		mg/L	1	1/25/2005 11:46:44 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 31-Jan-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012005:1125 NP2-10
Lab Order:	0501149	Tag Number:	2255
Project:	Rowe Industries	Collection Date:	1/20/2005
Lab ID:	0501149-03C	Date Received:	1/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	1.96	0.0200		mg/L	1	1/25/2005 11:43:59 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	1/25/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Tuesday, February 01, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0501177

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/27/2005 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0501177

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0501177-01A	WQ012605:950 NP2-6		1/26/2005	1/27/2005
0501177-01B	WQ012605:950 NP2-6		1/26/2005	1/27/2005
0501177-01C	WQ012605:950 NP2-6		1/26/2005	1/27/2005
0501177-02A	WQ012605:902 NP2-7		1/26/2005	1/27/2005
0501177-02B	WQ012605:902 NP2-7		1/26/2005	1/27/2005
0501177-02C	WQ012605:902 NP2-7		1/26/2005	1/27/2005
0501177-03A	WQ012605:905 NP2-10		1/26/2005	1/27/2005
0501177-03B	WQ012605:905 NP2-10		1/26/2005	1/27/2005
0501177-03C	WQ012605:905 NP2-10		1/26/2005	1/27/2005

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ012605:950 NP2-6
 Lab Order: 0501177 Tag Number:
 Project: Rowe Industries Collection Date: 1/26/2005
 Lab ID: 0501177-01A Date Received: 1/27/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
2-Butanone	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
2-Hexanone	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Acetone	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Benzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Bromobenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Bromoform	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Bromomethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Chloroethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ012605:950 NP2-6
 Lab Order: 0501177 Tag Number:
 Project: Rowe Industries Collection Date: 1/26/2005
 Lab ID: 0501177-01A Date Received: 1/27/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Chloromethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Dibromomethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/28/2005 12:41:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Methylene chloride	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Naphthalene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
o-Xylene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Styrene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Tetrachloroethene	17	1.0		µg/L	1	1/28/2005 12:41:00 AM
Toluene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Trichloroethene	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/28/2005 12:41:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/28/2005 12:41:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012605:950 NP2-6
Lab Order:	0501177	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/26/2005
Lab ID:	0501177-01B	Date Received:	1/27/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	6.35	0.0200		mg/L	1	1/31/2005 10:15:07 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012605:950 NP2-6
Lab Order:	0501177	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/26/2005
Lab ID:	0501177-01C	Date Received:	1/27/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.101	0.0200		mg/L	1	1/31/2005 10:11:51 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012605:902 NP2-7
Lab Order:	0501177	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/26/2005
Lab ID:	0501177-02A	Date Received:	1/27/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
2-Butanone	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
2-Hexanone	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Acetone	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Benzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Bromobenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Bromoform	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Bromomethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Chloroethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ012605:902 NP2-7

Lab Order: 0501177

Tag Number:

Project: Rowe Industries

Collection Date: 1/26/2005

Lab ID: 0501177-02A

Date Received: 1/27/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Chloromethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Dibromomethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/28/2005 1:19:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Methylene chloride	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Naphthalene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
o-Xylene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Styrene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Toluene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Trichloroethene	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/28/2005 1:19:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/28/2005 1:19:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012605:902 NP2-7
Lab Order:	0501177	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/26/2005
Lab ID:	0501177-02B	Date Received:	1/27/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	3.66	0.0200		mg/L	1	1/31/2005 10:29:43 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 7 of 12

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012605:902 NP2-7
Lab Order:	0501177	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/26/2005
Lab ID:	0501177-02C	Date Received:	1/27/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.662	0.0200		mg/L	1	1/31/2005 10:17:54 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ012605:905 NP2-10
Lab Order: 0501177 **Tag Number:**
Project: Rowe Industries **Collection Date:** 1/26/2005
Lab ID: 0501177-03A **Date Received:** 1/27/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
2-Butanone	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
2-Hexanone	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Acetone	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Benzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Bromobenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Bromoform	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Bromomethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Chloroethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 9 of 12

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ012605:905 NP2-10
 Lab Order: 0501177 Tag Number:
 Project: Rowe Industries Collection Date: 1/26/2005
 Lab ID: 0501177-03A Date Received: 1/27/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Chloromethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Dibromomethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/28/2005 1:57:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Methylene chloride	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Naphthalene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
o-Xylene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Styrene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Toluene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Trichloroethene	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/28/2005 1:57:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/28/2005 1:57:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012605:905 NP2-10
Lab Order:	0501177	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/26/2005
Lab ID:	0501177-03B	Date Received:	1/27/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	2.22	0.0200		mg/L	1	1/31/2005 10:36:47 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 01-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012605:905 NP2-10
Lab Order:	0501177	Tag Number:	
Project:	Rowe Industries	Collection Date:	1/26/2005
Lab ID:	0501177-03C	Date Received:	1/27/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.374	0.0200		mg/L	1	1/31/2005 10:32:40 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Fillerable)	86	1.0		mg/L	1	1/31/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

ANALYTICAL REPORT

JOB NUMBER: 208456

Prepared For:

LEGGETTE, BRASHEARS & GRAHAM
126 Monroe Turnpike
Trumbull, CT 06611

Project: ROWE INDUSTRIES

Attention: Mark Goldberg

Date: 01/17/2005




Signature

Name: William D. Goodman

Title: Project Manager

E-Mail: wgoodman@stl-inc.com



Date

STL Connecticut
128 Long Hill Cross Road
Shelton, CT 06484

This Report Contains (110) Pages

STL Report : 208456
LEGGETTE, BRASHEARS, & GRAHAM

Case Narrative

Sample Receipt – All samples were received in good condition.

Volatile Organics – Air volatile organics were determined by purge and trap GC/MS using guidance provided in Method TO-17. The instrumentation used was a Perkin Elmer ATD 50 interfaced with a Hewlett-Packard Model 5972A GC/MS/DS.

Sample Calculation:

Sample ID- AQ010405 1145NP4-1
Compound-Bromomethane

$$\frac{(72333)(25)}{(473344)(.233)} = 16.39 = 16 \text{ ng}$$

$$\frac{(16\text{NG})(.08206)(298)}{(.4\text{L})(95)(1.0\text{ATM})} = 10.29 = 10.3 \text{ nL/L.}$$

Sample AQ010405 1145NP4-1 was analyzed at a sample volume of .4L for high targets.

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in the case narrative.

Date: 01/17/2005

```
Project Number.....: 20000283
Customer Project ID....: ROWE INDUSTRIES
Project Description....: Rowe Industries
```

Page 1

STL Connecticut		Form 1		
		Client Sample ID	1145NP4-1	
Method: T017		Lab Sample ID	208456-1	
Sample Volume (L)	0.400	Date Sampled	1/4/2005	
Temp (C)	25	Date Analyzed	1/7/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	24.2 U	24.2	0.0500 U	0.050
Vinyl Chloride	19.6 U	19.6	0.0500 U	0.050
Bromomethane	10.3 JB	12.9	0.0400 JB	0.050
Chloroethane	19.0 U	19.0	0.0500 U	0.050
1,1-Dichloroethene	6.3 U	6.3	0.0250 U	0.025
Carbon Disulfide	8.0 U	8.0	0.0250 U	0.025
Methylene Chloride	7.2	7.2	0.0250	0.025
trans-1,2-Dichloroethene	6.4 U	6.4	0.0250 U	0.025
1,1-Dichloroethane	6.2 U	6.2	0.0250 U	0.025
cis-1,2-Dichloroethene	6.4 U	6.4	0.0250 U	0.025
Chloroform	1.0 J	5.1	0.0050 J	0.025
1,1,1-Trichloroethane	14.2	4.6	0.0775	0.025
Carbon Tetrachloride	4.0 U	4.0	0.0250 U	0.025
Benzene	1.6 JB	7.8	0.0050 JB	0.025
1,2-Dichloroethane	6.2 U	6.2	0.0250 U	0.025
Trichloroethene	4.7	4.7	0.0250	0.025
1,2-Dichloropropane	5.4 U	5.4	0.0250 U	0.025
Bromodichloromethane	3.7 U	3.7	0.0250 U	0.025
cis-1,3-Dichloropropene	5.5 U	5.5	0.0250 U	0.025
Toluene	4.0 J	6.6	0.0150 J	0.025
trans-1,3-Dichloropropene	5.5 U	5.5	0.0250 U	0.025
1,1,2-Trichloroethane	4.6 U	4.6	0.0250 U	0.025
Tetrachloroethene	8.8	3.7	0.0600	0.025
Dibromochloromethane	2.9 U	2.9	0.0250 U	0.025
Chlorobenzene	5.4 U	5.4	0.0250 U	0.025
Ethylbenzene	5.8 U	5.8	0.0250 U	0.025
m&p-Xylenes	5.8 U	5.8	0.0250 U	0.025
o-Xylene	5.8 U	5.8	0.0250 U	0.025
Styrene	5.9 U	5.9	0.0250 U	0.025
Bromoform	2.4 U	2.4	0.0250 U	0.025
1,1,2,2-Tetrachloroethane	3.6 U	3.6	0.0250 U	0.025

STL Connecticut		Form 1		
		Client Sample ID	1150NP4-2	
Method: T017		Lab Sample ID	208456-2	
Sample Volume (L)	1.000	Date Sampled	1/4/2005	
Temp (C)	25	Date Analyzed	1/7/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	9.7 U	9.7	0.0200 U	0.020
Vinyl Chloride	7.8 U	7.8	0.0200 U	0.020
Bromomethane	7.2 B	5.1	0.0280 B	0.020
Chloroethane	7.6 U	7.6	0.0200 U	0.020
1,1-Dichloroethene	2.8	2.5	0.0110	0.010
Carbon Disulfide	4.8	3.2	0.0150	0.010
Methylene Chloride	2.6 J	2.9	0.0090 J	0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.0100 U	0.010
1,1-Dichloroethane	6.9	2.5	0.0280	0.010
cis-1,2-Dichloroethene	0.8 J	2.5	0.0030 J	0.010
Chloroform	3.7	2.1	0.0180	0.010
1,1,1-Trichloroethane	8.3	1.8	0.0450	0.010
Carbon Tetrachloride	1.6 U	1.6	0.0100 U	0.010
Benzene	0.6 JB	3.1	0.0020 JB	0.010
1,2-Dichloroethane	2.5 U	2.5	0.0100 U	0.010
Trichloroethene	1.9 U	1.9	0.0100 U	0.010
1,2-Dichloropropane	2.2 U	2.2	0.0100 U	0.010
Bromodichloromethane	1.5 U	1.5	0.0100 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.0100 U	0.010
Toluene	6.4	2.7	0.0240	0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.0100 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.0100 U	0.010
Tetrachloroethene	0.6 J	1.5	0.0040 J	0.010
Dibromochloromethane	1.2 U	1.2	0.0100 U	0.010
Chlorobenzene	2.2 U	2.2	0.0100 U	0.010
Ethylbenzene	2.3 U	2.3	0.0100 U	0.010
m&p-Xylenes	0.2 J	2.3	0.0010 J	0.010
o-Xylene	2.3 U	2.3	0.0100 U	0.010
Styrene	0.5 J	2.4	0.0020 J	0.010
Bromoform	1.0 U	1.0	0.0100 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.0100 U	0.010

STL Connecticut		Form 1	
		Client Sample ID	1150NP4-3
Method: T017		Lab Sample ID	208456-3
Sample Volume (L)	1.000	Date Sampled	1/4/2005
Temp (C)	25	Date Analyzed	1/7/2005
		nL/L	
Compound	(ppbv/v) Qualifier	RL	mg/M3 Qualifier RL
Chloromethane	9.7 U	9.7	0.0200 U 0.020
Vinyl Chloride	7.8 U	7.8	0.0200 U 0.020
Bromomethane	2.1 JB	5.1	0.0080 JB 0.020
Chloroethane	7.6 U	7.6	0.0200 U 0.020
1,1-Dichloroethene	1.8 J	2.5	0.0070 J 0.010
Carbon Disulfide	4.8	3.2	0.0150 0.010
Methylene Chloride	1.7 J	2.9	0.0060 J 0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.0100 U 0.010
1,1-Dichloroethane	3.2	2.5	0.0130 0.010
cis-1,2-Dichloroethene	0.5 J	2.5	0.0020 J 0.010
Chloroform	2.1 U	2.1	0.0100 U 0.010
1,1,1-Trichloroethane	1.8 U	1.8	0.0100 U 0.010
Carbon Tetrachloride	1.6 U	1.6	0.0100 U 0.010
Benzene	0.6 JB	3.1	0.0020 JB 0.010
1,2-Dichloroethane	2.5 U	2.5	0.0100 U 0.010
Trichloroethene	1.9 U	1.9	0.0100 U 0.010
1,2-Dichloropropane	2.2 U	2.2	0.0100 U 0.010
Bromodichloromethane	1.5 U	1.5	0.0100 U 0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.0100 U 0.010
Toluene	6.1	2.7	0.0230 0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.0100 U 0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.0100 U 0.010
Tetrachloroethene	0.3 J	1.5	0.0020 J 0.010
Dibromochloromethane	1.2 U	1.2	0.0100 U 0.010
Chlorobenzene	2.2 U	2.2	0.0100 U 0.010
Ethylbenzene	2.3 U	2.3	0.0100 U 0.010
m&p-Xylenes	0.5 J	2.3	0.0020 J 0.010
o-Xylene	2.3 U	2.3	0.0100 U 0.010
Styrene	0.5 J	2.4	0.0020 J 0.010
Bromoform	1.0 U	1.0	0.0100 U 0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.0100 U 0.010

Job Number: 208456

LABORATORY CHRONICLE

Date: 01/17/2005

CUSTOMER: LEGGETTE, BRASHEARS & GRAHAM

PROJECT: ROWE INDUSTRIES

ATTN: Mark Goldberg

Lab ID: 208456-1	Client ID: AQ010405:1145NP4-1	Date Recvd: 01/05/2005	Sample Date: 01/04/2005		
METHOD	DESCRIPTION	RUN# BATCH# PREP BT #(S)	DATE/TIME ANALYZED	DILUTION	
T017	Volatile Organics (Air)	1 43221	01/07/2005 1553	1.00000	
Lab ID: 208456-2	Client ID: AQ010405:1150NP4-2	Date Recvd: 01/05/2005	Sample Date: 01/04/2005		
METHOD	DESCRIPTION	RUN# BATCH# PREP BT #(S)	DATE/TIME ANALYZED	DILUTION	
T017	Volatile Organics (Air)	1 43221	01/07/2005 1641	1.00000	
Lab ID: 208456-3	Client ID: AQ010405:1155NP4-3	Date Recvd: 01/05/2005	Sample Date: 01/04/2005		
METHOD	DESCRIPTION	RUN# BATCH# PREP BT #(S)	DATE/TIME ANALYZED	DILUTION	
T017	Volatile Organics (Air)	1 43221	01/07/2005 1716	1.00000	

AIR
2A
~~WATER~~ VOLATILE SYSTEM MONITORING COMPOUND RECOVERY

Jan 11/14/05

Lab Name: STL-CT

Contract:

Lab Code: STLCT

Case No.: 208456 SAS No.:

SDG No.: 208456

	EPA SAMPLE NO.	SMC1 #	SMC2 (DCE) #	SMC3 (TOL) #	OTHER (BFB) #	TOT OUT
01	VBLKTY	117	112	96	92	
02	020 PPBLCS	109	112	94	92	
03	1145NP4-1	107	106	95	87	
04	1150NP4-2	112	112	96	84	
05	1150NP4-3	109	103	96	94	
06						
07						
08						
09						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

QC LIMITS
 SMC1 = Dibromofluoromethane (70-130)
 SMC2 (DCE) = 1,2-Dichloroethane-d4 (70-130)
 SMC3 (TOL) = Toluene-d8 (70-130)
 OTHER (BFB) = Bromofluorobenzene (70-130)

Column to be used to flag recovery values

* Values outside of contract required QC limits

D System Monitoring Compound diluted out

FORM 3

Data File: \\TARGET1_CT\\Files\\chem\\VOA\\mst.i\\T054023.b\\T4027.D Page 3
Report Date: 07-Jan-2005 15:44

STL-CT

RECOVERY REPORT

Client Name: Client SDG: SDGa24843
Sample Matrix: LIQUID Fraction: VOA
Lab Smp Id: 020_ppbLCS Client Smp ID: 020_ppbLCS
Level: LOW Operator: M.Crowe
Data Type: MS DATA SampleType: LCS
SpikeList File: AIRQCS.spk Quant Type: ISTD
Sublist File: all.sub
Method File: \\TARGET1_CT\\Files\\chem\\VOA\\mst.i\\T054023.b\\TAIRFULL.m
Misc Info: : LCS;;; 020_ppbQCS ; TO-17 ; * 1 L* ; AIR

SPIKE COMPOUND	CONC ADDED ug/L	CONC RECOVERED ug/L	% RECOVERED	LIMITS
4 Vinyl Chloride	20	14	69.09	60-140
5 Bromomethane	20	27	132.74	60-140
6 Chloroethane	20	17	82.53	60-140
12 1,1-Dichloroethene	20	17	85.74	60-140
11 Trichlorotrifluoro	20	20	101.07	60-140
17 Acetone	20	18	87.94	60-140
13 Carbon Disulfide	20	13	67.34	60-140
16 Methylene Chloride	20	18	92.08	60-140
18 trans-1,2-Dichloro	20	18	88.92	60-140
28 1,1-Dichloroethane	20	17	82.77	60-140
30 cis-1,2-Dichloroet	20	17	85.15	60-140
40 2-Butanone	20	16	81.31	60-140
33 Chloroform	20	19	93.95	60-140
38 1,1,1-Trichloroeth	20	24	121.61	60-140
39 Carbon Tetrachlori	20	28	138.31	60-140
51 1,2-Dichloroethane	20	20	100.77	60-140
48 Benzene	20	17	84.08	60-140
56 Trichloroethene	20	21	104.39	60-140
63 cis-1,3-Dichloropr	20	16	78.64	60-140
72 4-Methyl-2-Pentano	20	12	61.51	60-140
69 Toluene	20	17	84.90	60-140
66 trans-1,3-Dichloro	20	13	64.11	60-140
67 1,1,2-Trichloroeth	20	19	95.37	60-140
73 Tetrachloroethene	20	21	106.23	60-140
75 Dibromochlorometha	20	19	95.91	60-140
80 Chlorobenzene	20	19	95.89	60-140
82 Ethylbenzene	20	19	96.82	60-140
83 Xylene (total)mp	40	38	95.14	60-140
84 Xylene (total)o	20	20	98.01	60-140
85 Styrene	20	16	79.07	60-140
86 Bromoform	20	20	99.71	60-140
89 1,1,2,2-Tetrachlor	20	16	80.92	60-140
101 1,3-Dichlorobenzen	20	19	95.98	60-140
102 1,4-Dichlorobenzen	20	20	100.53	60-140
103 1,2-Dichlorobenzen	20	20	98.34	60-140

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 01/17/2005

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC. Lab Cert. ID# 10604
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviation

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the reporting limit.
- < Not detected at or above the reporting limit.
- J Result is less than the RL, but greater than or equal to the method detection limit.
- B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
- S Result was determined by the Method of Standard Additions.

Inorganic Flags (Flag Column)

- ICV,CCV,ICB,CCB,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed the upper or lower control limits.
- * LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
- + MSA correlation coefficient is less than 0.995.
- 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
- E SD: Serial dilution exceeds the control limits.
- H MB, EB: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
- N MS, MSD: Spike recovery exceeds the upper or lower control limits.
- W PS: Post-digestion spike was outside 85-115% control limits.

Organic Qualifiers (Q - Column)

- U Analyte was not detected at or above the reporting limit.
- ND Compound not detected.
- J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
- Q Result was qualitatively confirmed, but not quantified.
- C Pesticide identification was confirmed by GC/MS.
- Y The chromatographic response resembles a typical fuel pattern.
- Z The chromatographic response does not resemble a typical fuel pattern.
- E Result exceeded calibration range, secondary dilution required.

Organic Flags (Flags Column)

- MB,EB, MLE: Batch QC is greater than reporting limit.
- * LCS, LCD, CCV, MS, MSD, Surrogate, RS:Batch QC exceeds the upper or lower control limits.
- A Concentration exceeds the instrument calibration range or below the reporting limit.
- B Compound was found in the blank.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is greater than 25%.

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 01/17/2005

Abbreviations

Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column
CCB	Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation Analysis
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
Dil Fac	Dilution Factor
DL	Secondary dilution and analysis
DLFac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB	Extraction Blank
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A
ISB	Interference Check Sample B
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group
Lab ID	An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PACK	Packed Column
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PS	Post Spike
PSD	Post Spike Duplicate
RA	Re-analysis
RE	Re-extraction and analysis
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RS	Reference Standard
RT	Retention Time
RTW	Retention Time Window
SampleID	A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB	Seeded Control Blank
SD	Serial Dilution
UCB	Unseeded Control Blank

One or a combination of these data qualifiers and abbreviations may appear in the analytical report.

OFFICES LOCATED IN:

MASSACHUSETTS • CONNECTICUT • NEW YORK • NEW JERSEY

PENNSYLVANIA • FLORIDA • OHIO • WISCONSIN • ILLINOIS • MISSOURI

MINNESOTA • TEXAS • SOUTH DAKOTA