

LEGGETTE, BRASHEARS & GRAHAM, INC.

PROFESSIONAL GROUND-WATER AND ENVIRONMENTAL ENGINEERING SERVICES

126 MONROE TURNPIKE
TRUMBULL, CT 06611
203-452-3100
FAX 203-452-3111
www.lbgweb.com

March 23, 2005

Mr. Jeffery Trad
Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation, Construction Services
625 Broadway, 12th floor
Albany, NY 12233-7013

RE: February 2005 Status Report
Ground-Water Remedial Action
Rowe Industries Superfund Site
Sag Harbor, New York

Dear Mr. Trad:

The enclosed letter report details the operation status of the full-scale ground-water pump and treat system at the above referenced site. LBG has enclosed an additional copy of the report to be forwarded to the Chief of the Operation Maintenance and Support Section.

Should you or the Operation Maintenance and Support Section have any questions, please feel free to contact myself, Paul Jobmann, or Al Kovalik at (203) 452-3100.

Very truly yours,

LEGGETTE, BRASHEARS & GRAHAM, INC.


Mark M. Goldberg

Mark M. Goldberg, P.E.
Senior Environmental Engineer


MG:ng

Enclosures

H:\NABIS\2005\Monthly Reports\Feb 2005\trad_Feb2005_report.doc



-DRAFT-



PROJECT STATUS MEMORANDUM

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Alfred N. Kovalik, P.E.

DATE: March 23, 2005

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
February 2005 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from February 1, 2005 through February 28, 2005. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground-water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(February 1, 2005 through February 28, 2005)

- | | |
|--|-----------------|
| 1. Hours of operation during the reporting period: | 603 hours (90%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 13,970,078 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 4.1 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 158.2 pounds |

8. Effluent VOC vapor concentration for the reporting period: 0.064 mg/m³ (Table 3)
9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.: yes (0.00060 lbs/hr)
(calculations can be provided upon request)

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/l. Laboratory analytical reports are included as Appendix I.

Well	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow Required for Plume Capture (gpm)	Total VOC Concentration (ug/l)	VOC Recovery (lbs)
RW-1	501,530	16.4	26	4.6	0.02
RW-2	1,003,009	27.0	26	18.0	0.15
RW-3	472,018	15.3	23	2.9	0.01
RW-4*	0	0	13	Not Analyzed	0
RW-5**	2,087,453	55.0	42	11.0	0.19
RW-6**	976,902	27.2	28	120.0	0.98
RW-7**	2,532,217	70.0	54	45.0	0.95
RW-8***	1,255,214	34.7	46	19.3	0.20
RW-9****	832,486	22.4	68	10.0	0.07

* The RW-4 motor was not operating in February 2005. A replacement motor has been ordered and the motor is scheduled for installation in spring 2005.

** RW-5, RW-6 and RW-7 flow totalizer readings were not accurate because of malfunctioning flow meters at these wells for all or a portion of February. The volume of ground water pumped in February 2005 was determined in a two-step process. A portion of the volume of ground water pumped was determined by reviewing the totalizer reading for the time that the flow totalizer was working properly. Another portion of the volume of ground water pumped was determined by calculating the average of the instantaneous flows and the time of operation when the flow totalizers were not working. These two portions were summed together to determine the total volume of ground water pumped in February 2005. RW-5 and RW-6 flow totalizers will be reset in the computer program in March. The RW-7 flow totalizer inaccuracy is being investigated.

*** RW-8 flow meter was providing valid flow readings from February 1, 2005 to February 4, 2005. For the remainder of the month, the RW-8 flow readings were not accurate. This is believed to be the result of excessive iron build-up in the RW-8 flow meter. The RW-8 flow meter will be cleaned during RW-8 well rehabilitation activities scheduled for March 2005. RW-8 flow measurements were estimated using the average of the instantaneous flow readings collected in the beginning of February 2005 and the time of operation for February 2005.

**** The RW-9 flow totalizer was not providing accurate readings from February 1 to February 8, 2005. The flow totalizer was reset in the computer program on February 8, 2004. A portion of the volume of ground water pumped was determined by reviewing the totalizer reading for the time that the flow totalizer was working properly. Another portion of the volume of ground water pumped was determined by calculating the average of the instantaneous flows and the time of operation when the flow totalizers were not working. These two portions were summed together to determine the total volume of ground water pumped in February 2005 from RW-9.

Recovery wells RW-1, RW-3, RW-4, RW-6, RW-8 and RW-9 had average flows below the minimum design flow to capture the plume. Despite periodic pipe cleanings, RW-1, RW-3 have decreased in flow due to iron build-up in the below-grade pipes. RW-4 was not operating due to a malfunctioning motor. Iron build-up in the RW-8 flow meter is believed to be the cause of the flow decrease. Well rehabilitation activities with new treatment chemicals and the servicing of RW-8 pump are expected to improve flow conditions in this well. The RW-8 well rehabilitation activities are scheduled for March 2005. The flow in RW-6 has slowly been decreasing over time. This flow reduction is believed to be the result of slime build-up in the pump, well screen, and the surrounding formation. If the new treatment chemicals are effective in RW-8, then well rehabilitation with these new treatment chemicals will be proposed for RW-6 and other wells in the future. The low flow at RW-9 is believed to be caused by iron build-up in a section of the below-grade piping not accessible to high pressure jet-washing techniques. To recover flow at RW-9, the construction of the new clean-out port located between RW-8 and RW-9 has been scheduled for the spring of 2005.

The effluent pH values are below the State Pollutant Discharge Elimination System (SPDES) Applicable or Relevant and Appropriate Requirements (ARARs) of 6.5 on a routine basis. pH readings of water samples from the recovery wells are observed to be in the range of approximately 5.8 to 6.5, which is the background pH for the ground water in this area.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
Feb. 1 to Feb 28	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M MODIFICATIONS AND FUTURE O&M ACTIVITIES

- On February 8, 2005, an adjustment to the booster blower fan guard was completed to avoid "rubbing" with moving parts. Static water levels were updated in the computer program for the recovery wells.
- On February 16, 2005, the inoperable RW-4 flow transmitter board was replaced with a new flow transmitter board.
- On February 24, 2005, the serviced and re-calibrated booster blower air flow sensor was re-installed in the system. The onsite combined, offsite combined and effluent flow meters were reprogrammed so the local flow meter displays were functioning properly. The RW-8 flow meter display was replaced.

Future O&M activities scheduled for spring 2005 include:

- Completing the semi-annual ground-water sampling event in March 2005;
- Completing the RW-8 well rehabilitation with new treatment chemicals in March 2005;
- Constructing a new clean-out port between RW-8 and RW-9;
- Installing a new motor and power cable in RW-4;
- Troubleshoot RW-7 and RW-8 flow meters.

cc: Terry Gerrish, CH2M Hill
Mark Lucas, CH2M Hill
Phil McAndrew, Kraft Foods, N.A. – .pdf
Lisa Krogman, Kraft Foods, N.A. (Environ) – .pdf
Jeff Trad, NYSDEC
Chief-Operation Maintenance and Support Section
Robert Schneck, RWE, R-1, NYSDEC
Eileen A. Powers, Esq., Town of Southampton

MMG:ng

Attachments

H:\NABIS\2005\Monthly Reports\Feb 2005\Status.doc

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(February 1, 2005 through February 28, 2005)

Date	Time	System Changes/Modifications	Personnel
2/1/2005	4:18 AM	Booster Blower (BB) Failure Alarm, Power Failure Alarm, system shut down.	
2/2/2005	12:00 PM	Rebooted the system, reset the BB drive, reset the alarms and restarted the system.	MG
2/6/2005	11:54 PM	System Communication Failure, system shut down.	
2/8/2005		Static depth to water for recovery wells was updated.	MG/SS
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	MG/SS
	10:21 AM	Re-booted the computer, reset the alarms and re-started the system.	MG/SS
	10:22 AM	Booster blower making a loud noise, shut down the system (lockout/tagout) and re-aligned the booster blower belt guard to make sure it was not "rubbing" against moving parts.	MG/SS
		Computer flow totalizers were not functioning for RW-9, EQTP101, and effluent flow. Cumulative totalizers were reset to zero for these flow meters.	MG/SS
	10:45 AM	Restarted the system.	MG/SS
2/9/2005	10:10 AM	Power Failure Alarm and RW-1, RW-2 and RW-3 pump fault alarms. The system continued to operate without RW-1, RW-2 and RW-3.	
	10:14 AM	Control room temperature alarm. The system continued to operate without RW-1, RW-2 and RW-3.	
2/10/2005		The RW-6 pump was not operating properly. Computer display showed negative frequency and no flow. The system was shut down and rebooted to reset the RW-6 drive. At this time the RW-1, RW-2 and RW-3 drives were reset.	TS/PJ
	12:44 PM	After rebooting the computer, the computer alarms were reset and the system was restarted. The temperature in the building was adequately warm.	TS/PJ
2/16/2005		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	MG
		Replaced the malfunctioning RW-4 flow transmitter board and old flow meter battery.	MG
2/24/2005	8:55 AM	Turned off system to conduct maintenance activities.	PJ
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	PJ
		Installed the serviced and recalibrated booster blower air flow sensor.	PJ
		Local displays on the onsite combined flow meter, offsite combined flow meter and effluent flow meter wer not working. Reprogrammed these flow meters to get the local displays to work.	PJ
	11:30 AM	Restarted the system	PJ

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled	pH ¹	TDS (mg/L)	PCE (ug/L)	1,1,1-TCA (ug/L)	TCE (ug/L)	1,1-DCA (ug/L)	1,1-DCE (ug/L)	1,2-DCE (ug/L)	Xylene (ug/L)	Bromoform (ug/L)	Dibromo- chloromethane (ug/L)	Methylene Chloride (ug/L)	Freon 113 (ug/L)	Naph- thalene (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)
SPDES Limits	6.5 to 8.5	---	1	5	5	5	5	5	5	---	---	5	---	10	7	---	---	---
2-Feb-05	5.3	98	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	7.16	0.343
8-Feb-05	5.3	110	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.52	< 0.02
16-Feb-05	5.3	120	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.63	0.281
24-Feb-05	5.3	80	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	7.78	0.335

SPDES: State Pollutant Discharge Elimination System

mg/L: Milligrams per liter

ug/L: Micrograms per liter

---: Not established

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. pH was measured using litmus paper. Influent pH values from recovery wells, which reflect the pH of natural ground water, are below 6.5 on a regular basis.

2. "Effluent" samples were collected from sample port labeled NP2-10.

TABLE 3

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																					TOTAL
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ030304:910NP4-1	3/3/2004	9:10	0.48	0.02	ND	ND	ND	ND	0.014	0.004	ND	ND	ND	ND	0.01	ND	ND	0.068	ND	ND	ND	ND	ND	0.80
AQ040904:1000NP4-1	4/9/2004	10:00	0.425	0.02	0.033	ND	ND	ND	0.023	0.005	ND	ND	ND	ND	0.013	ND	ND	0.008	ND	ND	ND	ND	ND	0.57
AQ050504:1355NP4-1	5/5/2005	13:55	0.375	0.023	0.035	ND	ND	ND	0.015	0.005	0.0023	ND	ND	0.005	0.06	ND	0.04	0.063	ND	ND	ND	ND	ND	0.62
AQ060204:1200NP4-1	6/2/2004	12:00	0.28	0.013	0.017	ND	ND	ND	0.027	0.005	0.012	0.007	0.002	0.007	0.023	0.005	0.058	0.12	ND	0.004	ND	ND	ND	0.58
AQ070704:1415NP4-1	7/7/2004	14:15	0.86	0.03	0.12	ND	ND	ND	0.02	0.02	ND	ND	ND	0.009	0.05	ND	0.06	0.07	ND	ND	ND	ND	ND	1.26
AQ080404:1330NP4-1	8/4/2004	13:30	1.3	0.089	0.22	0.012	0.016	0.007	0.031	0.004	0.003	0.001	0.004	0.013	0.044	0.005	0.076	0.067	ND	0.001	ND	ND	ND	1.89
AQ090204:1431NP4-1	9/2/2004	14:31	0.83	0.054	0.13	0.009	0.013	0.004	0.028	0.008	0.004	0.001	0.003	0.01	0.073	0.003	0.078	0.04	ND	0.001	ND	ND	ND	1.29
AQ100704:1210NP4-1	10/7/2004	12:10	0.4	0.035	0.058	0.005	0.005	0.003	0.038	0.008	0.003	0.001	0.002	0.008	0.05	ND	0.045	0.06	ND	0.001	ND	ND	ND	0.72
AQ0110304:945NP4-1	11/3/2004	9:45	0.44	0.032	0.074	0.01	0.022	0.004	0.02	0.008	0.0018	ND	0.0012	0.008	0.1	0.006	0.02	0.152	ND	ND	ND	ND	ND	0.90
AQ120204:1100NP4-1	12/2/2004	11:00	0.4	0.028	0.08	0.01	0.022	0.004	0.052	0.03	0.008	0.0014	0.002	ND	1.04	0.012	0.05	0.24	ND	0.0018	ND	ND	ND	1.04
AQ010405:1145NP4-1	1/4/2005	11:45	0.08	0.025	0.0775	ND	ND	ND	0.015	0.005	ND	ND	ND	0.005	0.025	ND	ND	0.04	ND	ND	ND	ND	ND	0.25
AQ020205:1345NP4-1	2/2/2005	13:45	0.45	0.0325	0.0675	ND	ND	ND	0.02	0.0075	ND	ND	ND	0.0075	0.0325	ND	ND	0.185	ND	ND	ND	ND	ND	0.80

Midcarbon			Parameters (mg/m3)																					TOTAL
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ030304:912NP4-2	3/3/2004	9:12	0.41	0.057	0.024	ND	ND	ND	0.009	0.002	ND	ND	ND	0.006	0.007	ND	ND	0.005	ND	ND	ND	ND	ND	0.52
AQ040904:1002NP4-2	4/9/2004	10:02	0.325	0.040	0.033	ND	0.023	ND	0.03	0.005	0.002	ND	ND	ND	0.006	ND	0.063	0.008	ND	ND	ND	ND	ND	0.54
AQ050504:1357NP4-2	5/5/2005	13:57	0.25	0.033	0.035	ND	ND	ND	0.02	0.005	0.003	ND	ND	0.008	0.055	ND	0.063	0.083	ND	0.003	ND	ND	ND	0.56
AQ060204:1202NP4-2	6/2/2004	12:02	0.012	0.002	ND	ND	ND	ND	0.02	0.003	0.002	0.0006	0.001	ND	0.021	0.003	0.041	0.057	ND	0.0006	ND	ND	ND	0.16
AQ070704:1420NP4-2	7/7/2004	14:20	0.013	0.002	ND	ND	ND	ND	0.032	0.004	0.003	0.0009	0.003	ND	0.058	0.004	0.097	0.027	ND	0.001	ND	ND	ND	0.24
AQ080404:1335NP4-2	8/4/2004	13:35	0.048	0.002	ND	0.005	ND	ND	0.031	0.002	0.003	0.001	0.003	ND	0.063	0.004	0.078	0.071	ND	0.001	ND	ND	ND	0.31
AQ090204:1432NP4-2	9/2/2004	14:32	0.014	0.002	ND	0.005	ND	ND	0.059	0.005	0.005	0.001	0.003	ND	0.088	0.003	0.088	0.025	ND	0.002	ND	ND	ND	0.30
AQ100704:1212NP4-2	10/7/2004	12:12	0.021	0.001	ND	0.008	0.01	ND	0.016	0.007	0.003	0.001	0.002	0.002	0.011	ND	0.036	0.057	ND	0.001	ND	ND	ND	0.17
AQ110304:947NP4-2	11/3/2004	9:47	0.015	ND	ND	0.007	0.014	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.034	0.005	0.018	0.028	ND	0.0004	ND	ND	ND	0.15
AQ120204:1102NP4-2	12/2/2004	11:02	0.004	ND	ND	0.009	0.017	0.002	0.034	0.003	0.003	0.0005	0.003	0.011	0.097	0.004	0.025	0.08	ND	0.001	ND	ND	ND	0.23
AQ010405:1150NP4-2	1/4/2005	11:50	0.004	ND	0.045	0.011	0.028	0.003	0.024	0.002	0.001	ND	0.002	0.018	0.009	ND	0.015	0.028	ND	ND	ND	ND	ND	0.19
AQ020205:1350NP4-2	2/2/2005	13:50	ND	ND	0.15	0.011	0.033	0.005	0.019	0.001	ND	ND	ND	0.018	0.019	ND	0.013	0.004	ND	ND	ND	ND	ND	0.27

Postcarbon			Parameters (mg/m3)																					TOTAL
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ030304:914NP4-3	3/3/2004	9:14	ND	0.002	0.034	ND	ND	ND	0.011	0.002	ND	ND	ND	0.008	0.008	ND	0.019	0.007	ND	ND	ND	ND	ND	0.09
AQ040904:1005NP4-3	4/9/2004	10:05	0.004	ND	0.028	0.008	0.013	0.004	0.037	0.003	0.004	0.001	0.003	ND	0.009	ND	0.048	0.014	ND	ND	ND	ND	ND	0.18
AQ050504:1400NP4-3	5/5/2004	14:00	0.004	0.005	0.031	0.008	0.015	0.004	0.018	0.004	0.002	0.0005	0.001	0.008	0.034	0.005	0.039	0.16	ND	0.0007	ND	ND	ND	0.34
AQ060204:1204NP4-3	6/2/2004	12:04	0.003	0.002	ND	ND	ND	ND	0.019	0.002	0.002	0.0005	0.001	ND	0.02	0.004	0.039	0.1	ND	0.0006	ND	ND	ND	0.19
AQ070704:1425NP4-3	7/7/2004	14:25	0.003	0.002	ND	ND	ND	ND	0.032	0.004	0.003	0.0009	0.003	ND	0.062	ND	0.11	0.006	ND	0.001	ND	ND	ND	0.23
AQ080404:1340NP4-3	8/4/2004	13:40	0.02	0.002	ND	ND	ND	ND	0.03	0.004	0.003	0.001	0.004	ND	0.055	0.004	0.067	0.055	ND	0.001	ND	ND	ND	0.25
AQ090204:1433NP4-3	9/2/2004	14:33	0.023	0.003	ND	ND	ND	ND	0.062	0.008	0.005	0.001	0.003	ND	0.087	0.004	0.085	0.033	ND	0.002	ND	ND	ND	0.32
AQ100704:1215NP4-3	10/7/2004	12:15	0.001	0.001	ND	ND	ND	ND	0.045	0.004	0.003	0.0009	0.003	ND	0.011	ND	0.033	0.034	ND	0.001	ND	ND	ND	0.14
AQ0110304:950NP4-3	11/3/2004	9:50	0.005	ND	ND	0.002	ND	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.032	ND	0.017	0.022	ND	0.0005	ND	ND	ND	0.11
AQ120204:1105NP4-3	12/2/2004	11:05	ND	0.002	ND	0.008	ND	ND	0.035	0.011	0.003	0.0006	0.003	ND	0.27	0.005	0.025	0.064	ND	0.001	ND	ND	ND	0.19
AQ010405:1155NP4-3	1/4/2005	11:55	0.002	ND	ND	0.007	0.013	0.002	0.023	0.002	0.002	ND	0.002	ND	0.006	ND	0.015	0.008	ND	ND	ND	ND	ND	0.08
AQ020205:1355NP4-3	2/2/2005	13:55	0.004	ND	ND	ND	ND	ND	0.021	0.002	ND	ND	0.001	ND	0.023	ND	0.013	ND	ND	ND	ND	ND	ND	0.06

Notes: 1. Methylene Chloride concentrations in all three air samples collected during the December 2, 2004 sampling event are greatly elevated due to suspected laboratory contamination. Methylene chloride was confirmed as a suspected laboratory contaminant by the laboratory supervisor. The methylene chloride concentrations from the November 3, 2004 sampling event were used instead of the December 2, 2004 methylene chloride concentrations to calculate the total VOCs for December 2004.

PCE - Tetrachloroethane
TCE - Trichloroethane
TCA - 1,1,1-Trichloroethane

DCE - 1,1-Dichloroethane
DCA - 1,1-Dichloroethane
cis-DCE - cis-1,2-Dichloroethane
CT - Carbon Tetrachloride

CF - Chloroform
MC - Methylene Chloride
CM - Chloromethane
CD - Carbon Disulfide

BM - Bromomethane
CB - Chlorobenzene
EB - Ethylbenzene
VC - Vinyl Chloride

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropyl- benzene (ug/L) NE	1,1-Dichloro- ethane (ug/L) 5	cis-1,2-Dichloro- ethane (ug/L) 5	1,1-Dichloro- ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochl- oromethane (ug/L) NE	Naphth- alene (ug/L) NE
RW-1	23-Apr-03	ND<1	ND<1	ND<1	ND<1	1.2	8.6	0.053	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	ND<1	ND<1	ND<1	ND<1	1.8	8.7	0.051	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Jun-03	ND<1	ND<1	ND<1	ND<1	ND<1	8.1	0.0290	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	ND<1	ND<1	ND<1	ND<1	2.9	6.6	0.0100	0.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	ND<1	ND<1	ND<1	ND<1	2.6	9.4	0.0930	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	ND<1	ND<1	ND<1	ND<1	3.2	14	0.0540	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0613	0.0074	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	ND<1	ND<1	ND<1	ND<1	2.2	9.4	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	ND<1	ND<1	ND<1	ND<1	4.0	2.2	0.0098	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	ND<1	ND<1	ND<1	4.6	5.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	ND<1	ND<1	ND<1	ND<1	4.1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.5
	14-Apr-04	ND<1	ND<1	ND<1	ND<1	2.9	6.1	0.0240	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	ND<1	ND<1	ND<1	ND<1	5.6	6.8	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.1*	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	2.0	3.4	0.0454	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	ND<1	ND<1	ND<1	ND<1	ND<1	3.1	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	8.0
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-2	23-Apr-03	14	1.3	ND<1	ND<1	ND<1	ND<1	6.31	0.212	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	2	ND<1	ND<1	ND<1	3.8	5.51	0.052	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Jun-03	15	0.6	ND<1	ND<1	ND<1	ND<1	3.01	0.885	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	5.34	0.438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	7.9	ND<1	ND<1	ND<1	ND<1	ND<1	5.99	0.758	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	9.2	0.5	ND<1	ND<1	ND<1	6.0	4.49	0.899	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	8.1	0.7	ND<1	ND<1	ND<1	ND<1	6.79	0.101	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	5.5	ND<1	ND<1	ND<1	ND<1	5.5	5.46	0.0213	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	8.7	ND<1	ND<1	ND<1	ND<1	1.1	5.57	0.207	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	5.4	ND<1	ND<1	ND<1	ND<1	3.9	3.77	0.0748	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	4.9	ND<1	ND<1	ND<1	ND<1	3.3	0.343	0.318	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	4.4	ND<1	ND<1	ND<1	ND<1	2.8	5.59	0.224	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	8.2	ND<1	ND<1	ND<1	ND<1	4.7	4.5	0.691	ND<1	ND<1	ND<1	ND<1	5.6*	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	52.5	1.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	6.5	ND<1	ND<1	ND<1	ND<1	1.3	4.88	0.704	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	1.5	4.78	0.213	ND<1	ND<1	ND<1	ND<1	ND<1	2.1	1.5	ND<1
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropyl- benzene (ug/L) NE	1,1-Dichloro- ethane (ug/L) 5	cis-1,2-Dichloro- ethene (ug/L) 5	1,1-Dichloro- ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloromethane (ug/L) NE	Naphthalene (ug/L) NE
RW-3	23-Apr-03	1.1	1.2	ND<1	ND<1	ND<1	ND<1	1.81	0.395	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	2.2	2.5	1.1	ND<1	ND<1	ND<1	1.68	0.166	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1
	11-Jun-03	2.4	3.4	1.8	ND<1	ND<1	ND<1	2.37	0.517	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	2.3	5.7	2.3	ND<1	ND<1	ND<1	1.77	0.636	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	2.8	5.8	2.9	ND<1	ND<1	ND<1	2.24	1.57	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	2.1	5.3	2.6	ND<1	ND<1	ND<1	1.86	1.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	1.9	5.2	3.3	ND<1	ND<1	ND<1	2.59	1.27	ND<1	ND<1	0.6	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	1.2	5.8	ND<1	ND<1	ND<1	ND<1	1.96	0.129	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.2	6.9	3.2	ND<1	ND<1	ND<1	1.96	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	3.6	2.2	ND<1	ND<1	ND<1	1.63	1.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	1.2	5.0	2.3	ND<1	ND<1	ND<1	3.34	0.542	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	28-Apr-04	1.3	8.8	4.4	ND<1	ND<1	ND<1	3.07	1.32	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	ND<1
	5-May-04	0.9	6.9	3.6	ND<1	ND<1	ND<1	2.07	1.96	ND<1	ND<1	ND<1	ND<1	5.6*	ND<1	ND<1	ND<1
	30-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.619	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	2.4	6.1	2.6	ND<1	ND<1	ND<1	2.07	1.79	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	2.7	21	8.7	ND<1	ND<1	ND<1	1.91	0.42	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	2.2	12	5.0	ND<1	ND<1	ND<1	2.09	1.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.5	6.5	2.6	ND<1	ND<1	ND<1	1.87	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.77	0.489	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-4	23-Apr-03	110	3.1	ND<1	ND<1	ND<1	ND<1	3.18	0.136	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	170	5.4	1.0	ND<1	ND<1	ND<1	2.38	0.023	ND<1	ND<1	ND<1	ND<1	3.3	ND<1	ND<1	ND<1
	11-Jun-03	170	4.8	ND<1	ND<1	ND<1	ND<1	1.03	0.572	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	200	5.9	1.3	ND<1	ND<1	ND<1	2.67	0.292	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	210	5.7	1.1	ND<1	ND<1	ND<1	3.21	0.529	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	390	8.2	1.0	ND<1	ND<1	ND<1	2.95	0.922	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	380	6.8	1.6	ND<1	ND<1	ND<1	6.93	0.221	ND<1	1.2	0.9	0.8	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	270	7.9	ND<1	ND<1	ND<1	ND<1	5.45	0.0331	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	270	5.9	ND<1	ND<1	ND<1	ND<1	3.56	0.48	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	170	6.9	14.0	ND<1	ND<1	ND<1	3.28	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	170	5.8	4.5	ND<1	ND<1	ND<1	1.61	0.0691	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.982	0.173	ND<1	ND<1	ND<1	ND<1	2.1*	ND<1	ND<1	ND<1
	5-May-04	470	6.2	7.8	ND<1	ND<1	ND<1	7.08	2.33	ND<1	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<1
	30-Jun-04	110	3.8	26	ND<1	ND<1	ND<1	4.44	1.11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	110	3.2	29	ND<1	ND<1	ND<1	5.00	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	120	3.7	18	ND<1	ND<1	ND<1	2.98	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	3.2	ND<1	ND<1
	7-Oct-04	94	ND<1	14	ND<1	ND<1	ND<1	3.65	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	130	4.2	11	ND<1	ND<1	ND<1	4.75	0.205	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	230	5.7	35	ND<1	ND<1	ND<1	1.90	1.62	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	180	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropyl- benzene (ug/L) NE	1,1-Dichloro- ethane (ug/L) 5	cis-1,2-Dichloro- ethene (ug/L) 5	1,1-Dichloro- ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloro- methane (ug/L) NE	Naphth- alene (ug/L) NE
RW-5	23-Apr-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	ND<1	ND<1	ND<1	0.8	6.7	0.146	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1	ND<1
	11-Jun-03	21	ND<1	ND<1	ND<1	ND<1	6.2	0.76	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	11	ND<1	ND<1	ND<1	1.1	9.7	6.47	0.068	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	15	ND<1	ND<1	ND<1	0.9	7.3	0.269	0.021	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	18	ND<1	ND<1	ND<1	ND<1	8.1	0.043	0.016	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	18	ND<1	ND<1	ND<1	ND<1	ND<1	13.1	0.0097	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	ND<1	ND<1	ND<1	ND<1	7.5	0.0523	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	14	ND<1	ND<1	ND<1	0.9	4.0	0.05	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	14	ND<1	ND<1	ND<1	1.0	6.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	14	ND<1	ND<1	ND<1	ND<1	5.0	0.0852	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	18	ND<1	1.5	ND<1	ND<1	6.1	0.147	0.015	ND<1	ND<1	ND<1	ND<1	2*	ND<1	ND<1	ND<1
	5-May-04	38	0.8	3.2	ND<1	1.5	8.0	0.055	0.015	ND<1	ND<1	ND<1	ND<1	6.4*	ND<1	ND<1	ND<1
	14-Jun-04	17	ND<1	4.6	ND<1	ND<1	3.9	0.054	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	21	ND<1	4.6	ND<1	ND<1	3.1	0.0254	0.0265	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	24	ND<1	6.5	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.3	ND<1	ND<1
	7-Oct-04	16	ND<1	5.2	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	ND<1	1.8	1.4	ND<1
	3-Nov-04	15	ND<1	6.4	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	28	ND<1	28	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	12	ND<1	5.8	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-6	23-Apr-03	79	1.0	ND<1	ND<1	ND<1	ND<1	0.028	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	120	1.8	ND<1	ND<1	0.6	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.5	ND<1	ND<1	ND<1
	11-Jun-03	120	0.7	ND<1	ND<1	ND<1	ND<1	0.0097	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	150	0.6	ND<1	ND<1	ND<1	ND<1	0.186	0.034	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	140	2.2	ND<1	ND<1	ND<1	ND<1	0.089	0.018	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	140	2.6	ND<1	ND<1	ND<1	ND<1	0.023	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	180	3.3	1.0	ND<1	ND<1	ND<1	0.342	0.0083	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	120	2.6	ND<1	ND<1	ND<1	ND<1	0.017	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	160	2.4	ND<1	ND<1	ND<1	ND<1	0.015	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	130	3.3	1.1	ND<1	ND<1	1.7	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	110	2.7	ND<1	ND<1	ND<1	1.6	0.077	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	110	2.9	1.3	ND<1	ND<1	2.6	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8*	ND<1	ND<1	ND<1
	5-May-04	210	4.8	ND<1	ND<1	ND<1	3.2	0.719	ND<0.02	ND<1	ND<1	ND<1	ND<1	5.9*	ND<1	ND<1	ND<1
	14-Jun-04	92	3.6	1.3	ND<1	ND<1	2.1	0.151	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	100	2.8	1.2	ND<1	ND<1	1.7	0.437	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1
	7-Oct-04	94	ND<1	1.6	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.9	2.0	ND<1
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	2.5	0.0111	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	200	3.8	16	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0278	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-7	23-Apr-03	100	1.8	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	140	3.1	1.0	ND<1	ND<1	ND<1	0.032	ND<0.02	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1	ND<1
	11-Jun-03	140	2.0	ND<1	ND<1	ND<1	ND<1	0.0246	0.0086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	150	2.1	ND<1	ND<1	ND<1	ND<1	0.024	0.041	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	120	2.3	ND<1	ND<1	ND<1	ND<1	0.011	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	130	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	140	3.4	1.1	ND<1	ND<1	ND<1	0.0464	ND<0.02	ND<1	ND<1	0.2	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	110	2.8	ND<1	ND<1	ND<1	ND<1	0.0239	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	190	3.7	ND<1	ND<1	ND<1	ND<1	0.0069	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	120	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	100	3.0	ND<1	ND<1	ND<1	ND<1	0.0205	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	79	2.5	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.2*	ND<1	ND<1	ND<1
	5-May-04	130	4.0	ND<1	ND<1	ND<1	ND<1	0.012	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<1
	14-Jun-04	59	2.7	ND<1	ND<1	ND<1	ND<1	0.018	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	55	2.1	ND<1	ND<1	ND<1	ND<1	0.791	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	ND<1
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	0.0272	0.00878	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-8	23-Apr-03	41	2.0	1.8	ND<1	ND<1	ND<1	11.8	0.352	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	61	3.9	3.8	ND<1	ND<1	ND<1	10.1	0.068	ND<1	1.8	ND<1	ND<1	3.4	ND<1	ND<1	ND<1
	11-Jun-03	57	3.1	2.7	ND<1	ND<1	ND<1	9.14	1.10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	35	1.9	3.2	ND<1	ND<1	ND<1	10.5	0.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	30	1.7	3.6	ND<1	ND<1	ND<1	11.1	1.18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	28	2.5	4.4	ND<1	ND<1	ND<1	9.93	0.40	ND<1	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.3	5.4	ND<1	ND<1	ND<1	13.3	0.21	ND<1	4.1	0.7	1.3	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	17	2.1	2.6	ND<1	ND<1	ND<1	9.16	0.05	ND<1	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	16	2.2	4.1	ND<1	ND<1	ND<1	9.73	2.72	ND<1	3.5	ND<1	1.5	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	15	2.2	4.7	ND<1	ND<1	ND<1	8.74	0.19	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	22	2.7	4.3	ND<1	ND<1	ND<1	11.9	0.23	ND<1	3.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	14	2.0	6.2	ND<1	ND<1	ND<1	10.7	0.14	ND<1	5.7	ND<1	ND<1	1.9*	ND<1	ND<1	ND<1
	5-May-04	27	4.1	8.3	ND<1	ND<1	ND<1	8.77	0.21	ND<1	8.7	ND<1	ND<1	8.5*	ND<1	ND<1	ND<1
	14-Jun-04	10	2.4	5.8	ND<1	ND<1	ND<1	9.15	0.10	ND<1	4.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04 **	3	1.0	3.7	ND<1	ND<1	ND<1	4.18	0.21	ND<1	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	28.8	0.2	ND<1	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	10.6	0.3	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	16	ND<1	22	ND<1	ND<1	ND<1	15.6	0.1	ND<1	15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	ND<1	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	ND<1	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-9	23-Apr-03	15	1.2	1.8	ND<1	ND<1	ND<1	3.55	1.97	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	1.8	3.6	ND<1	ND<1	ND<1	2.95	0.046	ND<1	1.9	ND<1	ND<1	3.2	ND<1	ND<1	ND<1
	11-Jun-03	18	1.6	4.8	ND<1	ND<1	ND<1	2.75	1.74	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	4.7	1.6	7.3	ND<1	ND<1	ND<1	3.60	0.467	ND<1	3.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	25	1.2	3.5	ND<1	ND<1	ND<1	4.05	2.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	22	2.1	5.8	ND<1	ND<1	ND<1	3.49	2.88	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.2	8.2	ND<1	ND<1	ND<1	5.39	1.72	ND<1	5.2	ND<1	1.4	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	1.7	5.4	ND<1	ND<1	ND<1	1.94	1.57	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.3	2.2	13	ND<1	ND<1	ND<1	0.638	0.029	ND<1	1.8	ND<1	1.5	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	2.2	12	ND<1	ND<1	ND<1	1.24	0.222	ND<1	3.7	ND<1	1.3	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	5.6	1.7	10	ND<1	ND<1	ND<1	2.65	1.22	ND<1	5.9	ND<1	2.0	2.0*	ND<1	ND<1	ND<1
	5-May-04	3.7	1.7	13	ND<1	ND<1	ND<1	2.58	1.83	ND<1	6.7	ND<1	1.7	7.1*	ND<1	ND<1	ND<1
	14-Jun-04	1.8	1.9	8.2	ND<1	ND<1	ND<1	3.03	1.11	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	3.4	1.3	5.1	ND<1	ND<1	ND<1	2.6	1.95	ND<1	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	ND<1	1.9	ND<1	ND<1	ND<1	1.6	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

ND: Not detected

<#: Less than method detection limit

ug/L: Micrograms per liter

-: Not analyzed

ARAR's are chemical specific aquifer restoration goals for ground-water at the Former Rowe Industries Superfund Site.

Bold values indicate an exceedance of the ARAR standard established for the site.

PCE: Tetrachloroethylene

TCE: Trichloroethylene

TCA: 1,1,1-Trichloroethane

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl Tertiary Butyl Ether

NM: Not Measured

*Methylene Chloride detected in laboratory method blank

NE: ARAR goal was not established for this compound by the EPA.


** The July 14, 2004 sample collected for RW-8 only represents water in the pipe since the RW-8 pump was not operating at this time.

*** The August 26, 2004 samples were lost during shipment.

GRAPHS


GRAPH 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
(February 1, 2005 through February 28, 2005)




GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
FEBRUARY 2005 LABORATORY ANALYTICAL REPORTS

Friday, February 11, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0502040

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 2/4/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0502040

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0502040-01A	WQ020205:1330 NP2-6	4635	2/2/2005	2/4/2005
0502040-01B	WQ020205:1330 NP2-6	4635	2/2/2005	2/4/2005
0502040-01C	WQ020205:1330 NP2-6	4635	2/2/2005	2/4/2005
0502040-02A	WQ020205:1335 NP2-7	4635	2/2/2005	2/4/2005
0502040-02B	WQ020205:1335 NP2-7	4635	2/2/2005	2/4/2005
0502040-02C	WQ020205:1335 NP2-7	4635	2/2/2005	2/4/2005
0502040-03A	WQ020205:1340 NP2-10	4635	2/2/2005	2/4/2005
0502040-03B	WQ020205:1340 NP2-10	4635	2/2/2005	2/4/2005
0502040-03C	WQ020205:1340 NP2-10	4635	2/2/2005	2/4/2005

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ020205:1330 NP2-6
 Lab Order: 0502040 Tag Number: 4635
 Project: Rowe Industries Collection Date: 2/2/2005
 Lab ID: 0502040-01A Date Received: 2/4/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,1,1-Trichloroethane	2.3	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,2,4-Trimethylbenzene	11	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
2-Butanone	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
2-Hexanone	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Acetone	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Benzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Bromobenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Bromoform	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Bromomethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Chloroethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ020205:1330 NP2-6

Lab Order: 0502040

Tag Number: 4635

Project: Rowe Industries

Collection Date: 2/2/2005

Lab ID: 0502040-01A

Date Received: 2/4/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Chloromethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Dibromomethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/7/2005 8:10:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Methylene chloride	U	1.0	B	µg/L	1	2/7/2005 8:10:00 PM
Naphthalene	9.2	1.0		µg/L	1	2/7/2005 8:10:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
o-Xylene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Styrene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Tetrachloroethene	21	1.0		µg/L	1	2/7/2005 8:10:00 PM
Toluene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Trichloroethene	1.0	1.0		µg/L	1	2/7/2005 8:10:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/7/2005 8:10:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/7/2005 8:10:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020205:1330 NP2-6
Lab Order:	0502040	Tag Number:	4635
Project:	Rowe Industries	Collection Date:	2/2/2005
Lab ID:	0502040-01B	Date Received:	2/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	3.60	0.0200		mg/L	1	2/8/2005 9:59:38 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020205:1330 NP2-6
Lab Order:	0502040	Tag Number:	4635
Project:	Rowe Industries	Collection Date:	2/2/2005
Lab ID:	0502040-01C	Date Received:	2/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0553	0.0200		mg/L	1	2/8/2005 9:56:20 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ020205:1335 NP2-7

Lab Order: 0502040

Tag Number: 4635

Project: Rowe Industries

Collection Date: 2/2/2005

Lab ID: 0502040-02A

Date Received: 2/4/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
2-Butanone	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
2-Hexanone	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Acetone	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Benzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Bromobenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Bromoform	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Bromomethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Chloroethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT: Leggett Brashears & Graham Inc.

Client Sample ID: WQ020205:1335 NP2-7

Lab Order: 0502040

Tag Number: 4635

Project: Rowe Industries

Collection Date: 2/2/2005

Lab ID: 0502040-02A

Date Received: 2/4/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Chloromethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Dibromomethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/7/2005 8:41:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Methylene chloride	U	1.0	B	µg/L	1	2/7/2005 8:41:00 PM
Naphthalene	3.2	1.0		µg/L	1	2/7/2005 8:41:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
o-Xylene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Styrene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Toluene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Trichloroethene	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/7/2005 8:41:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/7/2005 8:41:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020205:1335 NP2-7
Lab Order:	0502040	Tag Number:	4635
Project:	Rowe Industries	Collection Date:	2/2/2005
Lab ID:	0502040-02B	Date Received:	2/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	28.7	0.0200		mg/L	1	2/8/2005 10:19:18 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020205:1335 NP2-7
Lab Order:	0502040	Tag Number:	4635
Project:	Rowe Industries	Collection Date:	2/2/2005
Lab ID:	0502040-02C	Date Received:	2/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.376	0.0200		mg/L	1	2/8/2005 10:01:43 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ020205:1340 NP2-10

Lab Order: 0502040

Tag Number: 4635

Project: Rowe Industries

Collection Date: 2/2/2005

Lab ID: 0502040-03A

Date Received: 2/4/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
2-Butanone	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
2-Hexanone	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Acetone	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Benzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Bromobenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Bromoform	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Bromomethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Chloroethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 9 of 12

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ020205:1340 NP2-10
 Lab Order: 0502040 Tag Number: 4635
 Project: Rowe Industries Collection Date: 2/2/2005
 Lab ID: 0502040-03A Date Received: 2/4/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Chloromethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Dibromomethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/7/2005 9:11:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Methylene chloride	U	1.0	B	µg/L	1	2/7/2005 9:11:00 PM
Naphthalene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
o-Xylene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Styrene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Toluene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Trichloroethene	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/7/2005 9:11:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/7/2005 9:11:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020205:1340 NP2-10
Lab Order:	0502040	Tag Number:	4635
Project:	Rowe Industries	Collection Date:	2/2/2005
Lab ID:	0502040-03B	Date Received:	2/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	7.16	0.0200		mg/L	1	2/8/2005 10:26:53 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020205:1340 NP2-10
Lab Order:	0502040	Tag Number:	4635
Project:	Rowe Industries	Collection Date:	2/2/2005
Lab ID:	0502040-03C	Date Received:	2/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.343	0.0200		mg/L	1	2/8/2005 10:23:35 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	98	1.0		mg/L	1	2/9/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Wednesday, February 16, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0502081

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 2/10/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0502081**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0502081-01A	WQ020805:1145 NP2-6	3214	2/8/2005	2/10/2005
0502081-01B	WQ020805:1145 NP2-6	3214	2/8/2005	2/10/2005
0502081-01C	WQ020805:1145 NP2-6	3214	2/8/2005	2/10/2005
0502081-02A	WQ020805:1147 NP2-7	3214	2/8/2005	2/10/2005
0502081-02B	WQ020805:1147 NP2-7	3214	2/8/2005	2/10/2005
0502081-02C	WQ020805:1147 NP2-7	3214	2/8/2005	2/10/2005
0502081-03A	WQ020805:1150 NP2-10	3214	2/8/2005	2/10/2005
0502081-03B	WQ020805:1150 NP2-10	3214	2/8/2005	2/10/2005
0502081-03C	WQ020805:1150 NP2-10	3214	2/8/2005	2/10/2005

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0502081
Project: Rowe Industries
Lab ID: 0502081-01A

Client Sample ID: WQ020805:1145 NP2-6
Tag Number: 3214
Collection Date: 2/8/2005
Matrix: LIQUID

Date Received: 2/10/2005

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,1,1-Trichloroethane	3.5	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ020805:1145 NP2-6
 Lab Order: 0502081 Tag Number: 3214
 Project: Rowe Industries Collection Date: 2/8/2005
 Lab ID: 0502081-01A Date Received: 2/10/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 1:22:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Tetrachloroethene	23	1.0		µg/L	1	2/11/2005 1:22:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Trichloroethene	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 1:22:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 1:22:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020805:1145 NP2-6
Lab Order:	0502081	Tag Number:	3214
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502081-01B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	2.96	0.0200		mg/L	1	2/14/2005 11:00:22 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020805:1145 NP2-6
Lab Order:	0502081	Tag Number:	3214
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502081-01C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 10:57:58 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ020805:1147 NP2-7
 Lab Order: 0502081 Tag Number: 3214
 Project: Rowe Industries Collection Date: 2/8/2005
 Lab ID: 0502081-02A Date Received: 2/10/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ020805:1147 NP2-7
Lab Order: 0502081 **Tag Number:** 3214
Project: Rowe Industries **Collection Date:** 2/8/2005
Lab ID: 0502081-02A **Date Received:** 2/10/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 1:54:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Trichloroethene	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 1:54:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 1:54:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020805:1147 NP2-7
Lab Order:	0502081	Tag Number:	3214
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502081-02B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	12.3	0.0200		mg/L	1	2/14/2005 11:15:09 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020805:1147 NP2-7
Lab Order:	0502081	Tag Number:	3214
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502081-02C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 11:02:40 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ020805:1150 NP2-10
Lab Order: 0502081 **Tag Number:** 3214
Project: Rowe Industries **Collection Date:** 2/8/2005
Lab ID: 0502081-03A **Date Received:** 2/10/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM

Qualifiers:
 * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ020805:1150 NP2-10

Lab Order: 0502081

Tag Number: 3214

Project: Rowe Industries

Collection Date: 2/8/2005

Lab ID: 0502081-03A

Date Received: 2/10/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 2:27:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Trichloroethene	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 2:27:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 2:27:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020805:1150 NP2-10
Lab Order:	0502081	Tag Number:	3214
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502081-03B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	2.52	0.0200		mg/L	1	2/14/2005 11:20:52 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ020805:1150 NP2-10
Lab Order:	0502081	Tag Number:	3214
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502081-03C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 11:17:12 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	110	1.0		mg/L	1	2/11/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Wednesday, February 16, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0502082

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 2/10/2005 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director




American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0502082

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0502082-01A	GWQ020805:1000 NP1-1-1	4609	2/8/2005	2/10/2005
0502082-01B	GWQ020805:1000 NP1-1-1	4609	2/8/2005	2/10/2005
0502082-01C	GWQ020805:1000 NP1-1-1	4609	2/8/2005	2/10/2005
0502082-01D	GWQ020805:1000 NP1-1-1	4609	2/8/2005	2/10/2005
0502082-02A	GWQ020805:1010 NP1-1-2	4609	2/8/2005	2/10/2005
0502082-02B	GWQ020805:1010 NP1-1-2	4609	2/8/2005	2/10/2005
0502082-02C	GWQ020805:1010 NP1-1-2	4609	2/8/2005	2/10/2005
0502082-02D	GWQ020805:1010 NP1-1-2	4609	2/8/2005	2/10/2005
0502082-03A	GWQ020805:1020 NP1-1-3	4609	2/8/2005	2/10/2005
0502082-03B	GWQ020805:1020 NP1-1-3	4609	2/8/2005	2/10/2005
0502082-03C	GWQ020805:1020 NP1-1-3	4609	2/8/2005	2/10/2005
0502082-03D	GWQ020805:1020 NP1-1-3	4609	2/8/2005	2/10/2005
0502082-04A	GWQ020805:1040 NP1-1-5	4609	2/8/2005	2/10/2005
0502082-04B	GWQ020805:1040 NP1-1-5	4609	2/8/2005	2/10/2005
0502082-04C	GWQ020805:1040 NP1-1-5	4609	2/8/2005	2/10/2005
0502082-04D	GWQ020805:1040 NP1-1-5	4609	2/8/2005	2/10/2005
0502082-05A	GWQ020805:1050 NP1-1-6	4609	2/8/2005	2/10/2005
0502082-05B	GWQ020805:1050 NP1-1-6	4609	2/8/2005	2/10/2005
0502082-05C	GWQ020805:1050 NP1-1-6	4609	2/8/2005	2/10/2005
0502082-05D	GWQ020805:1050 NP1-1-6	4609	2/8/2005	2/10/2005
0502082-06A	GWQ020805:1100 NP1-1-7	4609	2/8/2005	2/10/2005
0502082-06B	GWQ020805:1100 NP1-1-7	4609	2/8/2005	2/10/2005
0502082-06C	GWQ020805:1100 NP1-1-7	4609	2/8/2005	2/10/2005
0502082-06D	GWQ020805:1100 NP1-1-7	4609	2/8/2005	2/10/2005
0502082-07A	GWQ020805:1110 NP1-1-8	4609	2/8/2005	2/10/2005
0502082-07B	GWQ020805:1110 NP1-1-8	4609	2/8/2005	2/10/2005
0502082-07C	GWQ020805:1110 NP1-1-8	4609	2/8/2005	2/10/2005
0502082-07D	GWQ020805:1110 NP1-1-8	4609	2/8/2005	2/10/2005
0502082-08A	GWQ020805:1120 NP1-1-9	4609	2/8/2005	2/10/2005
0502082-08B	GWQ020805:1120 NP1-1-9	4609	2/8/2005	2/10/2005
0502082-08C	GWQ020805:1120 NP1-1-9	4609	2/8/2005	2/10/2005
0502082-08D	GWQ020805:1120 NP1-1-9	4609	2/8/2005	2/10/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC 4609

NYSDOH 11418
CTDOH PH-0205
NJDEP NY050
PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS

LBG
126 Monroe Turnpike
Trumbull, CT 06611

CONTACT:

Mark Goldberg

SAMPLER (SIGNATURE)

Steve Silvestri (MMG)

SAMPLE(S)
SEALED

YES / NO

SAMPLER NAME (PRINT)

Steve Silvestri

CORRECT
CONTAINER(S)

YES / NO

PROJECT LOCATION:

Rowe

LABORATORY
ID #

MATRIX

CON-
TAINERS

SAMPLING
DATE/
TIME

SAMPLE # - LOCATION

ANALYSIS
REQUIRED

8260
MTBE
Furon
Tot: Diss. I-Con
Tot: Diss. Hexane
Hardness
Turbidity
TDS

FOR
METHANOL PRESERVED
SAMPLES
[VOLATILE VIAL #]

LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION
0502082-1 ABCD	L	5	2/8/05	610020805:1000 NPI-1-1
2 ABCD				1010 NPI-1-2
3 ABCD				1020 NPI-1-3
4 ABCD				1040 NPI-1-5
5 ABCD				1050 NPI-1-6
6 ABCD				1100 NPI-1-7
7 ABCD				1110 NPI-1-8
8 ABCD				1120 NPI-1-9

COOLER TEMPERATURE:

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WPIE; P=PAINT CHIPS; B=BULK MATERIAL
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

TURNAROUND REQUIRED:

NORMAL ☒ STAT ☐ BY / /

COMMENTS / INSTRUCTIONS

RELINQUISHED BY (SIGNATURE)

Mark M. Goldberg

DATE
TIME

2/8/05
16:00

PRINTED NAME

M. Goldberg

RECEIVED BY LAB (SIGNATURE)

[Signature]

DATE

2/10/05

TIME

11:30

PRINTED NAME

P. Antonio

RELINQUISHED BY (SIGNATURE)

DATE

TIME

PRINTED NAME

RECEIVED BY LAB (SIGNATURE)

DATE

TIME

PRINTED NAME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ020805:1000 NP1-1-1

Lab Order: 0502082

Tag Number: 4609

Project: Rowe Industries

Collection Date: 2/8/2005

Lab ID: 0502082-01A

Date Received: 2/10/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B	Analyst: LDS	
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 1 of 40

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggett Brashears & Graham Inc.

Client Sample ID: GWQ020805:1000 NP1-1-1

Lab Order: 0502082

Tag Number: 4609

Project: Rowe Industries

Collection Date: 2/8/2005

Lab ID: 0502082-01A

Date Received: 2/10/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	4.6	1.0		µg/L	1	2/11/2005 2:58:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 2:58:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Trichloroethene	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 2:58:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 2:58:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Page 2 of 40

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1000 NP1-1-1
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-01B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 11:26:25 AM
Manganese	0.188	0.0200		mg/L	1	2/14/2005 11:26:25 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1000 NP1-1-1
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-01C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 11:23:47 AM
Manganese	0.195	0.0200		mg/L	1	2/14/2005 11:23:47 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1000 NP1-1-1
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-01D	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	49.8	1.00		mg/L	1	2/14/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	190	1.0		mg/L	1	2/11/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	2/14/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0502082
Project: Rowe Industries
Lab ID: 0502082-02A

Client Sample ID: GWQ020805:1010 NP1-1-2
Tag Number: 4609
Collection Date: 2/8/2005
Matrix: LIQUID

Date Received: 2/10/2005

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ020805:1010 NP1-1-2

Lab Order: 0502082

Tag Number: 4609

Project: Rowe Industries

Collection Date: 2/8/2005

Lab ID: 0502082-02A

Date Received: 2/10/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 3:33:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Tetrachloroethene	18	1.0		µg/L	1	2/11/2005 3:33:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Trichloroethene	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 3:33:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 3:33:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1010 NP1-1-2
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-02B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	5.01	0.0200		mg/L	1	2/14/2005 11:30:26 AM
Manganese	1.19	0.0200		mg/L	1	2/14/2005 11:30:26 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1010 NP1-1-2
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-02C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 11:28:30 AM
Manganese	1.16	0.0200		mg/L	1	2/14/2005 11:28:30 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1010 NP1-1-2
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-02D	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	52.2	1.00		mg/L	1	2/14/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	2/11/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	1.80	1.00		NTU	1	2/14/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1020 NP1-1-3
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-03A	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1020 NP1-1-3
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-03A	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 4:05:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Tetrachloroethene	1.6	1.0		µg/L	1	2/11/2005 4:05:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Trichloroethene	1.3	1.0		µg/L	1	2/11/2005 4:05:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 4:05:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 4:05:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Page 12 of 40

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1020 NP1-1-3
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-03B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	2.10	0.0200		mg/L	1	2/14/2005 11:35:50 AM
Manganese	0.111	0.0200		mg/L	1	2/14/2005 11:35:50 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1020 NP1-1-3
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-03C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	1.15	0.0200		mg/L	1	2/14/2005 11:33:38 AM
Manganese	0.107	0.0200		mg/L	1	2/14/2005 11:33:38 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1020 NP1-1-3
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-03D	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	38.5	1.00		mg/L	1	2/14/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	84	1.0		mg/L	1	2/11/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	3.20	1.00		NTU	1	2/14/2005

Qualifiers:

- Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ020805:1040 NP1-1-5

Lab Order: 0502082

Tag Number: 4609

Project: Rowe Industries

Collection Date: 2/8/2005

Lab ID: 0502082-04A

Date Received: 2/10/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B	Analyst: LDS	
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1040 NP1-1-5
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-04A	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 4:37:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Tetrachloroethene	11	1.0		µg/L	1	2/11/2005 4:37:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Trichloroethene	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 4:37:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 4:37:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1040 NP1-1-5
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-04B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 11:56:05 AM
Manganese	U	0.0200		mg/L	1	2/14/2005 11:56:05 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1040 NP1-1-5
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-04C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 11:38:17 AM
Manganese	U	0.0200		mg/L	1	2/14/2005 11:38:17 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1040 NP1-1-5
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-04D	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	37.0	1.00		mg/L	1	2/14/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	140	1.0		mg/L	1	2/11/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	2/14/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1050 NP1-1-6
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-05A	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						Analyst: LDS
						SW8260B
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,1,1-Trichloroethane	7.6	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ020805:1050 NP1-1-6

Lab Order: 0502082

Tag Number: 4609

Project: Rowe Industries

Collection Date: 2/8/2005

Lab ID: 0502082-05A

Date Received: 2/10/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 5:09:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Tetrachloroethene	110	1.0		µg/L	1	2/11/2005 5:09:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Trichloroethane	2.4	1.0		µg/L	1	2/11/2005 5:09:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 5:09:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 5:09:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 22 of 40

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1050 NP1-1-6
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-05B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 12:01:34 PM
Manganese	0.273	0.0200		mg/L	1	2/14/2005 12:01:34 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1050 NP1-1-6
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-05C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 11:59:22 AM
Manganese	0.276	0.0200		mg/L	1	2/14/2005 11:59:22 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1050 NP1-1-6
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-05D	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	38.2	1.00		mg/L	1	2/14/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	140	1.0		mg/L	1	2/11/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	2/14/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ020805:1100 NP1-1-7

Lab Order: 0502082

Tag Number: 4609

Project: Rowe Industries

Collection Date: 2/8/2005

Lab ID: 0502082-06A

Date Received: 2/10/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ020805:1100 NP1-1-7

Lab Order: 0502082

Tag Number: 4609

Project: Rowe Industries

Collection Date: 2/8/2005

Lab ID: 0502082-06A

Date Received: 2/10/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 5:41:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Tetrachloroethene	45	1.0		µg/L	1	2/11/2005 5:41:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Trichloroethene	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 5:41:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 5:41:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1100 NP1-1-7
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-06B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 12:05:59 PM
Manganese	0.0528	0.0200		mg/L	1	2/14/2005 12:05:59 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1100 NP1-1-7
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-06C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 12:03:52 PM
Manganese	0.0509	0.0200		mg/L	1	2/14/2005 12:03:52 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1100 NP1-1-7
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-06D	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO ₃)	30.3	M2340 B 1.00		mg/L	1	Analyst: JP 2/14/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	92	E160.1 1.0		mg/L	1	Analyst: AT 2/11/2005
TURBIDITY Turbidity	U	E180.1 1.00		NTU	1	Analyst: KK 2/14/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1110 NP1-1-8
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-07A	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,1,1-Trichloroethane	7.2	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,1-Dichloroethane	4.7	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggett Brashears & Graham Inc. **Client Sample ID:** GWQ020805:1110 NP1-1-8
Lab Order: 0502082 **Tag Number:** 4609
Project: Rowe Industries **Collection Date:** 2/8/2005
Lab ID: 0502082-07A **Date Received:** 2/10/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 6:13:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Tetrachloroethene	7.4	1.0		µg/L	1	2/11/2005 6:13:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Trichloroethene	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 6:13:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 6:13:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1110 NP1-1-8
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-07B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	8.24	0.0200		mg/L	1	2/14/2005 12:10:31 PM
Manganese	0.661	0.0200		mg/L	1	2/14/2005 12:10:31 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1110 NP1-1-8
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-07C	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst JP
Iron	U	0.0200		mg/L	1	2/14/2005 12:08:20 PM
Manganese	0.637	0.0200		mg/L	1	2/14/2005 12:08:20 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggett Brashears & Graham Inc. **Client Sample ID:** GWQ020805:1110 NP1-1-8
Lab Order: 0502082 **Tag Number:** 4609
Project: Rowe Industries **Collection Date:** 2/8/2005
Lab ID: 0502082-07D **Date Received:** 2/10/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO ₃)	24.9	M2340 B 1.00		mg/L	1	Analyst: JP 2/14/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	92	E160.1 1.0		mg/L	1	Analyst: AT 2/11/2005
TURBIDITY Turbidity	6.00	E180.1 1.00		NTU	1	Analyst: KK 2/14/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ020805:1120 NP1-1-9

Lab Order: 0502082

Tag Number: 4609

Project: Rowe Industries

Collection Date: 2/8/2005

Lab ID: 0502082-08A

Date Received: 2/10/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,1,1-Trichloroethane	10	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
2-Butanone	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
2-Hexanone	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Acetone	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Benzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Bromobenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Bromoform	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Bromomethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Chloroethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1120 NP1-1-9
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-08A	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Chloromethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Dibromomethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/11/2005 6:45:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Methylene chloride	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Naphthalene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
o-Xylene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Styrene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Toluene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Trichloroethene	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/11/2005 6:45:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/11/2005 6:45:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1120 NP1-1-9
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-08B	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0974	0.0200		mg/L	1	2/14/2005 12:17:39 PM
Manganese	1.08	0.0200		mg/L	1	2/14/2005 12:17:39 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ020805:1120 NP1-1-9**Lab Order:** 0502082**Tag Number:** 4609**Project:** Rowe Industries**Collection Date:** 2/8/2005**Lab ID:** 0502082-08C**Date Received:** 2/10/2005**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	2/14/2005 12:15:23 PM
Manganese	1.06	0.0200		mg/L	1	2/14/2005 12:15:23 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 16-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ020805:1120 NP1-1-9
Lab Order:	0502082	Tag Number:	4609
Project:	Rowe Industries	Collection Date:	2/8/2005
Lab ID:	0502082-08D	Date Received:	2/10/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	24.9	1.00		mg/L	1	2/14/2005
TOTAL DISSOLVED SOLIDS		E180.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	92	1.0		mg/L	1	2/11/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	2/14/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Friday, February 25, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0502190

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 2/23/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0502190

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0502190-01A	WQ021605:850 NP2-6	4626	2/16/2005	2/23/2005
0502190-01B	WQ021605:850 NP2-6	4626	2/16/2005	2/23/2005
0502190-01C	WQ021605:850 NP2-6	4626	2/16/2005	2/23/2005
0502190-02A	WQ021605:852 NP2-7	4626	2/16/2005	2/23/2005
0502190-02B	WQ021605:852 NP2-7	4626	2/16/2005	2/23/2005
0502190-02C	WQ021605:852 NP2-7	4626	2/16/2005	2/23/2005
0502190-03A	WQ021605:855 NP2-10	4626	2/16/2005	2/23/2005
0502190-03B	WQ021605:855 NP2-10	4626	2/16/2005	2/23/2005
0502190-03C	WQ021605:855 NP2-10	4626	2/16/2005	2/23/2005

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ021605:850 NP2-6
 Lab Order: 0502190 Tag Number: 4626
 Project: Rowe Industries Collection Date: 2/16/2005
 Lab ID: 0502190-01A Date Received: 2/23/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,1,1-Trichloroethane	3.8	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
2-Butanone	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
2-Hexanone	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Acetone	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Benzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Bromobenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Bromoform	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Bromomethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Chloroethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ021605:850 NP2-6

Lab Order: 0502190

Tag Number: 4626

Project: Rowe Industries

Collection Date: 2/16/2005

Lab ID: 0502190-01A

Date Received: 2/23/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Chloromethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Dibromomethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/24/2005 4:29:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Methylene chloride	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Naphthalene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
o-Xylene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Styrene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Tetrachloroethene	22	1.0		µg/L	1	2/24/2005 4:29:00 AM
Toluene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Trichloroethene	3.0	1.0		µg/L	1	2/24/2005 4:29:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/24/2005 4:29:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/24/2005 4:29:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ021605:850 NP2-6
Lab Order:	0502190	Tag Number:	4626
Project:	Rowe Industries	Collection Date:	2/16/2005
Lab ID:	0502190-01B	Date Received:	2/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	3.38	0.0200		mg/L	1	2/24/2005 3:17:28 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ021605:850 NP2-6
Lab Order:	0502190	Tag Number:	4626
Project:	Rowe Industries	Collection Date:	2/16/2005
Lab ID:	0502190-01C	Date Received:	2/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.148	0.0200		mg/L	1	2/24/2005 3:14:45 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0502190
Project: Rowe Industries
Lab ID: 0502190-02A

Client Sample ID: WQ021605:852 NP2-7
Tag Number: 4626
Collection Date: 2/16/2005
Matrix: LIQUID

Date Received: 2/23/2005

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
2-Butanone	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
2-Hexanone	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Acetone	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Benzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Bromobenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Bromoform	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Bromomethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Chloroethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT: Leggett Brashears & Graham Inc. **Client Sample ID:** WQ021605:852 NP2-7
Lab Order: 0502190 **Tag Number:** 4626
Project: Rowe Industries **Collection Date:** 2/16/2005
Lab ID: 0502190-02A **Date Received:** 2/23/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Chloromethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Dibromomethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/24/2005 6:12:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Methylene chloride	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Naphthalene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
o-Xylene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Styrene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Toluene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Trichloroethene	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/24/2005 6:12:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/24/2005 6:12:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ021605:852 NP2-7
Lab Order:	0502190	Tag Number:	4626
Project:	Rowe Industries	Collection Date:	2/16/2005
Lab ID:	0502190-02B	Date Received:	2/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	11.6	0.0200		mg/L	1	2/24/2005 3:21:52 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ021605:852 NP2-7
Lab Order:	0502190	Tag Number:	4626
Project:	Rowe Industries	Collection Date:	2/16/2005
Lab ID:	0502190-02C	Date Received:	2/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.188	0.0200		mg/L	1	2/24/2005 3:19:32 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ021605:855 NP2-10
Lab Order:	0502190	Tag Number:	4626
Project:	Rowe Industries	Collection Date:	2/16/2005
Lab ID:	0502190-03A	Date Received:	2/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
2-Butanone	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
2-Hexanone	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Acetone	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Benzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Bromobenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Bromoform	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Bromomethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Chloroethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ021605:855 NP2-10
Lab Order: 0502190 **Tag Number:** 4626
Project: Rowe Industries **Collection Date:** 2/16/2005
Lab ID: 0502190-03A **Date Received:** 2/23/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Chloromethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Dibromomethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/24/2005 6:43:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Methylene chloride	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Naphthalene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
o-Xylene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Styrene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Toluene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Trichloroethene	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/24/2005 6:43:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/24/2005 6:43:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ021605:855 NP2-10
Lab Order:	0502190	Tag Number:	4626
Project:	Rowe Industries	Collection Date:	2/16/2005
Lab ID:	0502190-03B	Date Received:	2/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	1.63	0.0200		mg/L	1	2/24/2005 3:26:48 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 25-Feb-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ021605:855 NP2-10
Lab Order:	0502190	Tag Number:	4626
Project:	Rowe Industries	Collection Date:	2/16/2005
Lab ID:	0502190-03C	Date Received:	2/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.281	0.0200		mg/L	1	2/24/2005 3:24:41 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	90	1.0		mg/L	1	2/23/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Monday, March 07, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0503010

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/1/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director




American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0503010

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0503010-01A	WQ022405:1300 NP2-6	4610	2/24/2005	3/1/2005
0503010-01B	WQ022405:1300 NP2-6	4610	2/24/2005	3/1/2005
0503010-01C	WQ022405:1300 NP2-6	4610	2/24/2005	3/1/2005
0503010-02A	WQ022405:1305 NP2-7	4610	2/24/2005	3/1/2005
0503010-02B	WQ022405:1305 NP2-7	4610	2/24/2005	3/1/2005
0503010-02C	WQ022405:1305 NP2-7	4610	2/24/2005	3/1/2005
0503010-03A	WQ022405:1310 NP2-10	4610	2/24/2005	3/1/2005
0503010-03B	WQ022405:1310 NP2-10	4610	2/24/2005	3/1/2005
0503010-03C	WQ022405:1310 NP2-10	4610	2/24/2005	3/1/2005

TAG # / COC 4610

NYSDOH	11418
CTDOH	PH-0205
NJDEP	NY050
PADEP	68-573

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the Instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ022405:1300 NP2-6

Lab Order: 0503010

Tag Number: 4610

Project: Rowe Industries

Collection Date: 2/24/2005

Lab ID: 0503010-01A

Date Received: 3/1/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,1,1-Trichloroethane	3.2	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
2-Butanone	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
2-Hexanone	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Acetone	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Benzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Bromobenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Bromoform	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Bromomethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Chloroethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ022405:1300 NP2-6
Lab Order: 0503010 **Tag Number:** 4610
Project: Rowe Industries **Collection Date:** 2/24/2005
Lab ID: 0503010-01A **Date Received:** 3/1/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Chloromethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Dibromomethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/3/2005 2:33:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Methylene chloride	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Naphthalene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
o-Xylene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Styrene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Tetrachloroethene	23	1.0		µg/L	1	3/3/2005 2:33:00 AM
Toluene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Trichloroethene	1.9	1.0		µg/L	1	3/3/2005 2:33:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/3/2005 2:33:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/3/2005 2:33:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022405:1300 NP2-6
Lab Order:	0503010	Tag Number:	4610
Project:	Rowe Industries	Collection Date:	2/24/2005
Lab ID:	0503010-01B	Date Received:	3/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	3.21	0.0200		mg/L	1	3/2/2005 1:54:49 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022405:1300 NP2-6
Lab Order:	0503010	Tag Number:	4610
Project:	Rowe Industries	Collection Date:	2/24/2005
Lab ID:	0503010-01C	Date Received:	3/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0936	0.0200		mg/L	1	3/2/2005 1:52:34 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ022405:1305 NP2-7

Lab Order: 0503010

Tag Number: 4610

Project: Rowe Industries

Collection Date: 2/24/2005

Lab ID: 0503010-02A

Date Received: 3/1/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
2-Butanone	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
2-Hexanone	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Acetone	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Benzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Bromobenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Bromoform	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Bromomethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Chloroethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM

Qualifiers:
 * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT: Leggett Brashears & Graham Inc. Client Sample ID: WQ022405:1305 NP2-7
 Lab Order: 0503010 Tag Number: 4610
 Project: Rowe Industries Collection Date: 2/24/2005
 Lab ID: 0503010-02A Date Received: 3/1/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Chloromethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Dibromomethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/3/2005 3:06:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Methylene chloride	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Naphthalene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
o-Xylene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Styrene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Tetrachloroethene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Toluene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Trichloroethene	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/3/2005 3:06:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/3/2005 3:06:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022405:1305 NP2-7
Lab Order:	0503010	Tag Number:	4610
Project:	Rowe Industries	Collection Date:	2/24/2005
Lab ID:	0503010-02B	Date Received:	3/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	15.1	0.0200		mg/L	1	3/2/2005 1:59:03 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022405:1305 NP2-7
Lab Order:	0503010	Tag Number:	4610
Project:	Rowe Industries	Collection Date:	2/24/2005
Lab ID:	0503010-02C	Date Received:	3/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.242	0.0200		mg/L	1	3/2/2005 1:56:57 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022405:1310 NP2-10
Lab Order:	0503010	Tag Number:	4610
Project:	Rowe Industries	Collection Date:	2/24/2005
Lab ID:	0503010-03A	Date Received:	3/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
2-Butanone	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
2-Hexanone	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Acetone	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Benzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Bromobenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Bromoform	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Bromomethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Chloroethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ022405:1310 NP2-10
Lab Order: 0503010 **Tag Number:** 4610
Project: Rowe Industries **Collection Date:** 2/24/2005
Lab ID: 0503010-03A **Date Received:** 3/1/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Chloromethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Dibromomethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/3/2005 3:37:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Methylene chloride	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Naphthalene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
o-Xylene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Styrene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Tetrachloroethene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Toluene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Trichloroethene	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/3/2005 3:37:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/3/2005 3:37:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022405:1310 NP2-10
Lab Order:	0503010	Tag Number:	4610
Project:	Rowe Industries	Collection Date:	2/24/2005
Lab ID:	0503010-03B	Date Received:	3/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	7.78	0.0200		mg/L	1	3/2/2005 2:03:44 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022405:1310 NP2-10
Lab Order:	0503010	Tag Number:	4610
Project:	Rowe Industries	Collection Date:	2/24/2005
Lab ID:	0503010-03C	Date Received:	3/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.335	0.0200		mg/L	1	3/2/2005 2:01:30 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	80	1.0		mg/L	1	3/2/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

ANALYTICAL REPORT

JOB NUMBER: 208718


Prepared For:

LEGGETTE, BRASHEARS & GRAHAM
126 Monroe Turnpike
Trumbull, CT 06611

Project: ROWE INDUSTRIES

Attention: Mark Goldberg

Date: 02/18/2005




Signature

Name: William D. Goodman

Title: Project Manager

E-Mail: wgoodman@stl-inc.com



Date

STL Connecticut
128 Long Hill Cross Road
Shelton, CT 06484

This Report Contains (104) Pages

STL Report : 208718
LEGGETTE, BRASHEARS, & GRAHAM

Case Narrative

Sample Receipt – All samples were received in good condition.

Volatile Organics – Air volatile organics were determined by purge and trap GC/MS using guidance provided in Method TO-17. The instrumentation used was a Perkin Elmer ATD 50 interfaced with a Hewlett-Packard Model 5972A GC/MS/DS.

Sample Calculation:

Sample ID- AQ020205:1345NP4-1
Compound-Bromomethane

$$\frac{(275554)(25)}{(397908)(.233)} = 74.3 = 74 \text{ ng}$$

$$\frac{(74\text{NG})(.08206)(298)}{(.4\text{L})(95)(1.0\text{ATM})} = 47.6 \text{ nL/L.}$$

Sample AQ020205:1345NP4-1 was analyzed at a sample volume of .4L for high targets.

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in the case narrative.

Date: 02/18/2005

Project Number.....: 20000283
Customer Project ID....: ROWE INDUSTRIES
Project Description....: Rowe Industries

[illegible]

STL Connecticut		Form 1		
		Client Sample ID	1345NP4-1	
Method: T017		Lab Sample ID	208718-1	
Sample Volume (L)	0.400	Date Sampled	2/2/2005	
Temp (C)	25	Date Analyzed	2/4/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	24.2 U	24.2	0.0500 U	0.050
Vinyl Chloride	19.6 U	19.6	0.0500 U	0.050
Bromomethane	47.6 B	12.9	0.1850 B	0.050
Chloroethane	19.0 U	19.0	0.0500 U	0.050
1,1-Dichloroethene	6.3 U	6.3	0.0250 U	0.025
Carbon Disulfide	8.0 U	8.0	0.0250 U	0.025
Methylene Chloride	9.4	7.2	0.0325	0.025
trans-1,2-Dichloroethene	6.4 U	6.4	0.0250 U	0.025
1,1-Dichloroethane	6.2 U	6.2	0.0250 U	0.025
cis-1,2-Dichloroethene	6.4 U	6.4	0.0250 U	0.025
Chloroform	1.5 J	5.1	0.0075 J	0.025
1,1,1-Trichloroethane	12.4	4.6	0.0675	0.025
Carbon Tetrachloride	4.0 U	4.0	0.0250 U	0.025
Benzene	2.3 JB	7.8	0.0075 JB	0.025
1,2-Dichloroethane	6.2 U	6.2	0.0250 U	0.025
Trichloroethene	6.1	4.7	0.0325	0.025
1,2-Dichloropropane	5.4 U	5.4	0.0250 U	0.025
Bromodichloromethane	3.7 U	3.7	0.0250 U	0.025
cis-1,3-Dichloropropene	5.5 U	5.5	0.0250 U	0.025
Toluene	5.3 J	6.6	0.0200 J	0.025
trans-1,3-Dichloropropene	5.5 U	5.5	0.0250 U	0.025
1,1,2-Trichloroethane	4.6 U	4.6	0.0250 U	0.025
Tetrachloroethene	66.3	3.7	0.4500	0.025
Dibromochloromethane	2.9 U	2.9	0.0250 U	0.025
Chlorobenzene	5.4 U	5.4	0.0250 U	0.025
Ethylbenzene	5.8 U	5.8	0.0250 U	0.025
m&p-Xylenes	5.8 U	5.8	0.0250 U	0.025
o-Xylene	5.8 U	5.8	0.0250 U	0.025
Styrene	5.9 U	5.9	0.0250 U	0.025
Bromoform	2.4 U	2.4	0.0250 U	0.025
1,1,2,2-Tetrachloroethane	3.6 U	3.6	0.0250 U	0.025

STL Connecticut		Form 1		
		Client Sample ID	1350NP4-2	
Method: T017		Lab Sample ID	208718-2	
Sample Volume (L)	1.000	Date Sampled	2/2/2005	
Temp (C)	25	Date Analyzed	2/4/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	9.7 U	9.7	0.0200 U	0.020
Vinyl Chloride	7.8 U	7.8	0.0200 U	0.020
Bromomethane	1.0 JB	5.1	0.0040 JB	0.020
Chloroethane	7.6 U	7.6	0.0200 U	0.020
1,1-Dichloroethene	2.8	2.5	0.0110	0.010
Carbon Disulfide	4.2	3.2	0.0130	0.010
Methylene Chloride	5.5	2.9	0.0190	0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.0100 U	0.010
1,1-Dichloroethane	8.2	2.5	0.0330	0.010
cis-1,2-Dichloroethene	1.3 J	2.5	0.0050 J	0.010
Chloroform	3.7	2.1	0.0180	0.010
1,1,1-Trichloroethane	27.6	1.8	0.1500	0.010
Carbon Tetrachloride	1.6 U	1.6	0.0100 U	0.010
Benzene	0.3 JB	3.1	0.0010 JB	0.010
1,2-Dichloroethane	2.5 U	2.5	0.0100 U	0.010
Trichloroethene	1.9 U	1.9	0.0100 U	0.010
1,2-Dichloropropane	2.2 U	2.2	0.0100 U	0.010
Bromodichloromethane	1.5 U	1.5	0.0100 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.0100 U	0.010
Toluene	5.0	2.7	0.0190	0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.0100 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.0100 U	0.010
Tetrachloroethene	1.5 U	1.5	0.0100 U	0.010
Dibromochloromethane	1.2 U	1.2	0.0100 U	0.010
Chlorobenzene	2.2 U	2.2	0.0100 U	0.010
Ethylbenzene	2.3 U	2.3	0.0100 U	0.010
m&p-Xylenes	2.3 U	2.3	0.0100 U	0.010
o-Xylene	2.3 U	2.3	0.0100 U	0.010
Styrene	2.4 U	2.4	0.0100 U	0.010
Bromoform	1.0 U	1.0	0.0100 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.0100 U	0.010

STL Connecticut		Form 1	
		Client Sample ID	1355NP4-3
Method: T017		Lab Sample ID	208718-3
Sample Volume (L)	1.000	Date Sampled	2/2/2005
Temp (C)	25	Date Analyzed	2/4/2005
		nL/L	
Compound	(ppbv/v) Qualifier	RL	mg/M3 Qualifier RL
Chloromethane	9.7 U	9.7	0.0200 U 0.020
Vinyl Chloride	7.8 U	7.8	0.0200 U 0.020
Bromomethane	5.1 U	5.1	0.0200 U 0.020
Chloroethane	7.6 U	7.6	0.0200 U 0.020
1,1-Dichloroethene	2.5 U	2.5	0.0100 U 0.010
Carbon Disulfide	4.2	3.2	0.0130 0.010
Methylene Chloride	6.6	2.9	0.0230 0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.0100 U 0.010
1,1-Dichloroethane	2.5 U	2.5	0.0100 U 0.010
cis-1,2-Dichloroethene	2.5 U	2.5	0.0100 U 0.010
Chloroform	2.1 U	2.1	0.0100 U 0.010
1,1,1-Trichloroethane	1.8 U	1.8	0.0100 U 0.010
Carbon Tetrachloride	1.6 U	1.6	0.0100 U 0.010
Benzene	0.6 JB	3.1	0.0020 JB 0.010
1,2-Dichloroethane	2.5 U	2.5	0.0100 U 0.010
Trichloroethene	1.9 U	1.9	0.0100 U 0.010
1,2-Dichloropropane	2.2 U	2.2	0.0100 U 0.010
Bromodichloromethane	1.5 U	1.5	0.0100 U 0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.0100 U 0.010
Toluene	5.6	2.7	0.0210 0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.0100 U 0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.0100 U 0.010
Tetrachloroethene	0.6 J	1.5	0.0040 J 0.010
Dibromochloromethane	1.2 U	1.2	0.0100 U 0.010
Chlorobenzene	2.2 U	2.2	0.0100 U 0.010
Ethylbenzene	2.3 U	2.3	0.0100 U 0.010
m&p-Xylenes	2.3 U	2.3	0.0100 U 0.010
o-Xylene	2.3 U	2.3	0.0100 U 0.010
Styrene	0.2 J	2.4	0.0010 J 0.010
Bromoform	1.0 U	1.0	0.0100 U 0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.0100 U 0.010

Job Number: 208718

LABORATORY CHRONICLE

Date: 02/18/2005

CUSTOMER: LEGGETTE, BRASHEARS & GRAHAM

PROJECT: ROWE INDUSTRIES

ATTN: Mark Goldberg

Lab ID: 208718-1	Client ID: Aq020205:1345NP4-1	Date Recvd: 02/03/2005	Sample Date: 02/02/2005	
METHOD	DESCRIPTION	RUN# BATCH# PREP BT #(S)	DATE/TIME ANALYZED	DILUTION
T017	Volatile Organics (Air)	1 44731	02/04/2005 1425	1.00000
Lab ID: 208718-2	Client ID: Aq020205:1350NP4-2	Date Recvd: 02/03/2005	Sample Date: 02/02/2005	
METHOD	DESCRIPTION	RUN# BATCH# PREP BT #(S)	DATE/TIME ANALYZED	DILUTION
T017	Volatile Organics (Air)	1 44731	02/04/2005 1523	1.00000
Lab ID: 208718-3	Client ID: Aq020205:1355NP4-3	Date Recvd: 02/03/2005	Sample Date: 02/02/2005	
METHOD	DESCRIPTION	RUN# BATCH# PREP BT #(S)	DATE/TIME ANALYZED	DILUTION
T017	Volatile Organics (Air)	1 44731	02/04/2005 1612	1.00000

AIP
~~WATER~~ VOLATILE SYSTEM MONITORING COMPOUND RECOVERY
 Am 2/15/05

2A

Lab Name: STL-CT

Contract:

Lab Code: STLCT

Case No.: 208718 SAS No.:

SDG No.: 208718

	EPA SAMPLE NO.	SMC1 #	SMC2 (DCE) #	SMC3 (TOL) #	OTHER (BFB) #	TOT OUT
01	VLKTE	95	91	99	95	
02	LCS	100	99	96	97	
03	1345NP4-1	98	97	95	91	
04	1350NP4-2	98	97	95	93	
05	1355NP4-3	98	95	96	93	
06						
07						
08						
09						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

QC LIMITS

SMC1 = Dibromofluoromethane (70-130)
 SMC2 (DCE) = 1,2-Dichloroethane-d4 (70-130)
 SMC3 (TOL) = Toluene-d8 (70-130)
 OTHER (BFB) = Bromofluorobenzene (70-130)

Column to be used to flag recovery values

* Values outside of contract required QC limits

D System Monitoring Compound diluted out

Form 3

Data File: \\Target1_ct\\Files\\chem\\VOA\\mst.i\\T054163.b\\T4166.D Page 3
Report Date: 16-Feb-2005 11:15

STL Connecticut

RECOVERY REPORT

Client Name: Client SDG: 208718
Sample Matrix: LIQUID Fraction: VOA
Lab Smp Id: LCS Client Smp ID: LCS
Level: LOW Operator: M.Crowe
Data Type: MS DATA SampleType: LCS
SpikeList File: AIRQCS.spk Quant Type: ISTD
Sublist File: all.sub
Method File: \\TARGET1_CT\\Files\\chem\\VOA\\mst.i\\T054163.b\\TAIRFULL.m
Misc Info: : LCS;;; 020_ppbQCS ; TO-17 ; * 1 L* ; AIR

SPIKE COMPOUND	CONC ADDED ug/L	CONC RECOVERED ug/L	% RECOVERED	LIMITS
4 Vinyl Chloride	20	15	72.76	60-140
5 Bromomethane	20	20	100.70	60-140
6 Chloroethane	20	17	86.79	60-140
12 1,1-Dichloroethene	20	16	78.00	60-140
11 Trichlorotrifluoro	20	17	82.72	60-140
17 Acetone	20	18	90.97	60-140
13 Carbon Disulfide	20	14	67.92	60-140
16 Methylene Chloride	20	18	91.63	60-140
18 trans-1,2-Dichloro	20	17	85.64	60-140
28 1,1-Dichloroethane	20	17	86.34	60-140
30 cis-1,2-Dichloroet	20	15	77.22	60-140
40 2-Butanone	20	19	95.82	60-140
33 Chloroform	20	17	87.43	60-140
38 1,1,1-Trichloroeth	20	21	103.48	60-140
39 Carbon Tetrachlori	20	22	110.35	60-140
51 1,2-Dichloroethane	20	18	91.22	60-140
48 Benzene	20	17	86.04	60-140
56 Trichloroethene	20	17	87.11	60-140
63 cis-1,3-Dichloropr	20	16	80.77	60-140
72 4-Methyl-2-Pentano	20	15	73.12	60-140
69 Toluene	20	17	85.83	60-140
66 trans-1,3-Dichloro	20	13	66.18	60-140
67 1,1,2-Trichloroeth	20	17	84.41	60-140
73 Tetrachloroethene	20	18	90.02	60-140
75 Dibromochlorometha	20	17	85.87	60-140
80 Chlorobenzene	20	17	85.31	60-140
82 Ethylbenzene	20	17	86.84	60-140
83 Xylene (total)mp	40	34	85.02	60-140
84 Xylene (total)o	20	17	86.86	60-140
85 Styrene	20	14	70.10	60-140
86 Bromoform	20	17	86.88	60-140
89 1,1,2,2-Tetrachlor	20	18	91.20	60-140
101 1,3-Dichlorobenzen	20	16	82.37	60-140
102 1,4-Dichlorobenzen	20	17	85.76	60-140
103 1,2-Dichlorobenzen	20	17	83.88	60-140

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 02/18/2005

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC. Lab Cert. ID# 10604
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviation

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the reporting limit.
- < Not detected at or above the reporting limit.
- J Result is less than the RL, but greater than or equal to the method detection limit.
- B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
- S Result was determined by the Method of Standard Additions.

Inorganic Flags (Flag Column)

- ICV,CCV,ICB,CCB,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed the upper or lower control limits.
- * LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
- + MSA correlation coefficient is less than 0.995.
- 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
- E SD: Serial dilution exceeds the control limits.
- H MB, EB: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
- N MS, MSD: Spike recovery exceeds the upper or lower control limits.
- W PS: Post-digestion spike was outside 85-115% control limits.

Organic Qualifiers (Q - Column)

- U Analyte was not detected at or above the reporting limit.
- ND Compound not detected.
- J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
- Q Result was qualitatively confirmed, but not quantified.
- C Pesticide identification was confirmed by GC/MS.
- Y The chromatographic response resembles a typical fuel pattern.
- Z The chromatographic response does not resemble a typical fuel pattern.
- E Result exceeded calibration range, secondary dilution required.

Organic Flags (Flags Column)

- MB,EB, MLE: Batch QC is greater than reporting limit.
- * LCS, LCD, CCV, MS, MSD, Surrogate, RS:Batch QC exceeds the upper or lower control limits.
- A Concentration exceeds the instrument calibration range or below the reporting limit.
- B Compound was found in the blank.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is greater than 25%.

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 02/18/2005

Abbreviations

Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column
CCB	Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation Analysis
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
Dil Fac	Dilution Factor
DL	Secondary dilution and analysis
DLFac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB	Extraction Blank
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A
ISB	Interference Check Sample B
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group
Lab ID	An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PACK	Packed Column
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PS	Post Spike
PSD	Post Spike Duplicate
RA	Re-analysis
RE	Re-extraction and analysis
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RS	Reference Standard
RT	Retention Time
RTW	Retention Time Window
SampleID	A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB	Seeded Control Blank
SD	Serial Dilution
UCB	Unseeded Control Blank

One or a combination of these data qualifiers and abbreviations may appear in the analytical report.

STL-Connecticut

Certification Summary (as of October 2004)

The laboratory identification numbers for the STL-Connecticut laboratory are provided in the following table. Many states certify laboratories for specific parameters or tests within a category (i.e. method 325.2 for wastewater). The information in the following table indicates the lab is certified in a general category of testing such as drinking water or wastewater analysis. The laboratory should be contacted directly if parameter-specific certification information is required.

State	Responsible Agency	Test Category	Certification Date	Lab Number
Connecticut	Department of Health Services	Drinking Water, Wastewater	12/31/04	PH-0497
Maine	Department of Health and Environmental Services	Drinking Water, Wastewater/Solid, Hazardous Waste	04/18/06	CT023
Massachusetts	Department of Environmental Protection	Potable/Non-Potable Water	06/30/05	CT023
New Hampshire	Department of Environmental Services	Drinking Water, Wastewater	08/29/05	2528
New Jersey	Department of Environmental Protection	Drinking Water, Wastewater	06/30/05	46410
New York	Department of Health	CLP, Drinking Water, Wastewater, Solid/ Hazardous Waste NELAC	04/01/05	10602
Rhode Island	Department of Health	Chemistry...Non- Potable Water and Wastewater	12/30/04	A43
Utah	Department of Health	RCRA	05/31/05	2032614458