


LBG ENGINEERING SERVICES, P.C.

Professional Environmental & Civil Engineers



126 Monroe Turnpike
Trumbull, CT 06611
(203) 452-3110
(203) 452-3119 (FAX)

May 20, 2005



Mr. Jeffery Trad
Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation, Construction Services
625 Broadway, 12th floor
Albany, NY 12233-7013

RE: March 2005 Status Report
Ground-Water Remedial Action
Rowe Industries Superfund Site
Sag Harbor, New York

Dear Mr. Trad:

The enclosed letter report details the operation status of the full-scale ground-water pump and treat system at the above referenced site. LBG has enclosed an additional copy of the report to be forwarded to the Chief of the Operation Maintenance and Support Section.

Should you or the Operation Maintenance and Support Section have any questions, please feel free to contact myself, Paul Jobmann, or Al Kovalik at (203) 452-3100.

Very truly yours,

LEGGETTE, BRASHEARS & GRAHAM, INC.

Mark M. Goldberg

Mark M. Goldberg, P.E.
Senior Environmental Engineer

MG:ng

Enclosures

H:\NABIS\2005\Monthly Reports\March 2005\trad_Mar2005_report.doc

-DRAFT-

PROJECT STATUS MEMORANDUM


NO. 03-05

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Alfred N. Kovalik, P.E.

DATE: May 20, 2005

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
March 2005 Status Report
Sag Harbor, New York



LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from March 1, 2005 through March 31, 2005. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION
(March 1, 2005 through March 31, 2005)

- | | |
|---|-----------------------------------|
| 1. Hours of operation during the reporting period: | 644 hours (87%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 12,919,620 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: | yes, (Graph 1) |
| 6. Mass of VOCs recovered during the reporting period: | 4.2 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 162.4 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.120 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00111 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meet or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow (gpm)	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-1	578,105	15.3	26	2.5	0.01
RW-2	1,037,959	26.8	26	21.1	0.18
RW-3	547,571	14.4	23	21.0	0.10
RW-4*	0	0	13	Not Analyzed	0
RW-5**	2,069,237	55.0	42	20.9	0.36
RW-6**	1,045,960	27.6	28	131.6	1.15
RW-7**	2,626,288	70.0	54	45.2	0.99
RW-8***	892,185	35.0	46	14.5	0.11
RW-9	739,898	18.8	68	7.3	0.05

* The RW-4 motor was not operating in March 2005. A replacement motor has been ordered and the motor is scheduled for installation in Spring 2005.

** RW-5, RW-6 and RW-7 flow totalizer readings were not accurate because of malfunctioning flow meters at these wells from March 1 to March 10, 2005. The volume of ground water pumped from March 1 to March 10, 2005 was calculated based on average flow for these wells and the hours of operation. After the flow totalizer was reset in RW-7 on March 10, 2005, the instantaneous flow readings and the average flow readings were within 10% of each other. A comparison of the RW-7 instantaneous flow readings and the average flow readings will continue to be monitored.

*** The RW-8 flow meter is sending an erroneous (180 gpm flow rate) signal from the flow meter to the main computer causing a high flow alarm. The communication wiring for RW-8 was disconnected in the remediation building to allow it to operate at its current flow rate of 35 gpm. The RW-8 flow was determined by reading the local flow display at select times and determining the total hours of operation for March.

Recovery wells RW-1, RW-3, RW-4, RW-6, RW-8 and RW-9 had average flows below the minimum design flow to capture the plume. Despite periodic pipe cleanings, RW-1, RW-3 have decreased in flow due to iron build-up in the below-grade pipes. RW-4 was not operating due to a malfunctioning motor. Iron build-up in the RW-8 flow meter is believed to be the cause of the flow decrease. The flow in RW-6 has slowly been decreasing over time. This condition is believed to be the result of bio-fouling in the pump, well screen, and the surrounding formation. The RW-8 pump motor was observed to have "burn" marks, therefore, a new pump motor was purchased and installed in RW-8 after well rehabilitation activities were completed. Well rehabilitation activities at RW-8 were effective at improving the specific capacity of the well from 98 gpm/ft to 175 gpm/ft. The pumping rates for the pre-rehabilitation and post-rehabilitation pump tests were 55 gpm. Because there was an erroneous flow signal being

received at the building (and therefore "percent motor speed" was not available), the RW-8 flow was not adjusted at this time. The RW-8 flow meter will be inspected for obstructions and cleaned. High-pressure jet washing of the vault pipes and below-grade piping in the vicinity of RW-8 will also be completed. The low flow at RW-9 is believed to be caused by iron build-up in a section of the below-grade piping not accessible to high pressure jet-washing techniques. A new clean-out port was constructed between RW-8 and RW-9 on March 30 and March 31. Below-grade pipe cleaning from the new clean-out port is scheduled for the first week in April.

The effluent pH values are below the State Pollutant Discharge Elimination System (SPDES) Applicable or Relevant and Appropriate Requirements (ARARs) of 6.5 on a routine basis. pH readings of water samples from the recovery wells are in the range of approximately 5.8 to 6.4, which is the background pH for the ground water in this area.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
Mar. 1 to Mar. 31	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M MODIFICATIONS AND FUTURE O&M ACTIVITIES

- On March 10, 2005, the cross-sectional area in the ASB air flow meter computer program was adjusted to reflect the actual pipe diameter where the ASB flow meter sensor is located.
- On March 10, 2005, the RW-8 flow meter was re-wired to read from the local flow meter until the communication problem is resolved.
- On March 10, 2005, the flow totalizers were reset for recovery wells RW-1, 2, 3, 5, 6, 7 and 8.
- From March 14 to March 17, 2005, the semi-annual ground-water sampling event was conducted.
- On March 22, 23, 24, 25 and 30, the RW-8 well rehabilitation was conducted.
- On March 30 and 31, a new clean-out port was constructed between RW-8 and RW-9.

Future O&M activities scheduled for spring 2005 include:

- Install a new motor and power cable in RW-4;
- Clean below-grade piping at the new clean-out port;

- Conduct well rehabilitation for select recovery wells using the same methodology as used at RW-8; and,
- Troubleshoot the RW-8 flow meter.

cc: Terry Gerrish, CH2M Hill
Mark Lucas, CH2M Hill
Phil McAndrew, Kraft Foods, N.A. – .pdf
Lisa Krogman, Kraft Foods, N.A. (Environ) – .pdf
Jeff Trad, NYSDEC
Chief-Operation Maintenance and Support Section
Robert Schneck, RWE, R-1, NYSDEC
David Gilmartin, Jr., Esq., Town of Southampton

MMG:ng

Attachments

H:\NABIS\2005\Monthly Reports\March 2005\Status0305Mar.doc

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(March 1, 2005 through March 31, 2005)

Date	Time	System Changes/Modifications	Personnel
2/24/2005	See Note 1	The RW-8 flow meter is sending an erroneous (180 gpm flow rate) signal from the flow meter to the main computer causing a high flow alarm. The communication wiring for RW-8 was disconnected in the remediation building to allow it to operate at approximately 35 gpm. The RW-8 flow was obtained from the local flow display (this flow was obtained prior to disconnecting the wiring). Initial troubleshooting included replacing the RW-8 flow meter display, however, this did not solve the problem. The RW-8 communication problem continues to be investigated.	PJ
3/2/2005	4:18 AM	Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS
3/8/2005	9:46 AM	Booster Blower Failure Alarm, RW-6 and RW-8 pump fault alarms, and low room temperature control alarm. System shut down.	
	8:18 PM	Power Failure Alarm, RW-7 and RW-9 pump fault alarms.	
3/10/2005	9:53 AM	Reset RW-6, 7, 8 and 9 drives, reset the booster blower starter, reset alarms and restarted the system.	MG
		ASB air flow meter air flow calculation was set for a 12" diameter pipe to calculate air flow. The circumference of the outside of the pipe where the ASB flow meter sensor is located was 40.0 inches. The inside diameter was calculated to be 12.34 inches based on a pipe wall thickness of 3/16 inch. The cross-sectional area setting in the ASB air flow meter was adjusted to 0.8311 feet in the program. Air flow readings from the ASB were not significantly impacted.	MG
		The RW-8 flow meter was re-wired so it would read the RW-8 flow locally while the communication problem discussed in the 2/24/05 maintenance entry is being investigated.	MG
		Reset flow totalizers for RW-1, 2, 3, 5, 6, 7 and 8.	MG
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	MG
3/13/2005	6:00 AM	Communication Failure; System Shut down.	
3/14/2005	8:55 AM	Rebooted the computer, reset the communication failure alarm and restarted the system.	MG
		Began semi-annual ground-water sampling of recovery wells and select monitor wells.	MG/TS
3/15/2005		Continued with semi-annual ground-water sampling. Measured depth to water of all wells.	MG/TS
3/16/2005		Continued with semi-annual ground-water sampling.	SS/TS
3/17/2005		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS
		Finished semi-annual ground-water sampling.	SS
3/21/2005		Holding (frac) tank is dropped off in preparation for RW-8 well rehabilitation	ETL, SS
3/22/2005	7:30 AM	Communication Failure; system shut down.	
		RW-8 well rehabilitation begins.	ETL, SS
	9:15 AM	Rebooted the computer, reset the communication failure alarm and restarted the system.	SS
3/23/2005	7:01 PM	RW-2 pump fault alarm. Remainder of system continues to run.	

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(March 1, 2005 through March 31, 2005)

Date	Time	System Changes/Modifications	Personnel
3/24/2005	7:50 AM	Reset the RW-2 drive, reset the alarm and restarted RW-2.	TS
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	TS
3/30/2005		RW-8 well rehabilitation ends.	ETL, MG
	1:23 PM	Shut system down to construct clean-out port between RW-8 and RW-9.	ETL
3/31/2005	11:30 AM	Finished construction of the clean-out port. Restarted the system	ETL, SS
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS

Notes 1. The February 24, 2005 maintenance event was inadvertently omitted from this table in the February 2005 monthly status report.

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled	pH ¹	TDS (mg/L)	PCE (ug/L)	1,1,1-TCA (ug/L)	TCE (ug/L)	1,1-DCA (ug/L)	1,1-DCE (ug/L)	1,2-DCE (ug/L)	Xylene (ug/L)	Bromoform (ug/L)	Dibromo-chloromethane (ug/L)	Methylene Chloride (ug/L)	Freon 113 (ug/L)	Naphthalene (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)
SPDES Limits	6.5 to 8.5	—	1	5	5	5	5	5	5	—	—	5	—	10	7	—	—	—
2-Mar-05	5.3	95	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	0.18	0.114
10-Mar-05	5.3	13	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	9.17	0.769
17-Mar-05	5.3	100	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.16	0.158
24-Mar-05	5.3	70	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	2.2 ³	ND<1.0	ND<1.0	ND<1.0	ND<1.0	0.067	0.084
30-Mar-05	5.3	81	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	0.594	0.0216

SPDES: State Pollutant Discharge Elimination System

mg/L: Milligrams per liter

ug/L: Micrograms per liter

—: Not established

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. pH was measured using litmus paper. Influent pH values from recovery wells, which reflect the pH of natural ground water, are below 6.5 on a regular basis.

2. "Effluent" samples were collected from sample port labeled NP2-10.

3. Methylene chloride is a common laboratory contaminant and although this compound was not detected in the method blank, the concentration reported in the 3/24/05 effluent sample is comparable to typical laboratory contamination concentrations.

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																				TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ040804:1000NP4-1	4/8/2004	10:00	0.425	0.02	0.033	ND	ND	ND	0.023	0.005	ND	ND	ND	ND	0.013	ND	0.04	0.008	ND	ND	ND	ND	ND	0.57
AQ050504:1355NP4-1	5/5/2005	13:55	0.375	0.023	0.035	ND	ND	ND	0.015	0.005	0.0023	ND	ND	0.005	0.08	ND	0.04	0.063	ND	ND	ND	ND	ND	0.82
AQ080204:1200NP4-1	8/2/2004	12:00	0.28	0.013	0.017	ND	ND	ND	0.027	0.005	0.012	0.007	0.002	0.007	0.023	0.005	0.058	0.12	ND	0.004	ND	ND	ND	0.58
AQ070704:1415NP4-1	7/7/2004	14:15	0.86	0.03	0.12	ND	ND	ND	0.02	0.02	ND	ND	ND	0.009	0.05	ND	0.08	0.07	ND	ND	ND	ND	ND	1.26
AQ080404:1330NP4-1	8/4/2004	13:30	1.3	0.069	0.22	0.012	0.018	0.007	0.031	0.004	0.003	0.001	0.004	0.013	0.044	0.005	0.076	0.067	ND	0.001	ND	ND	ND	1.89
AQ090204:1431NP4-1	9/2/2004	14:31	0.83	0.054	0.13	0.009	0.013	0.004	0.028	0.008	0.004	0.001	0.003	0.01	0.073	0.003	0.078	0.04	ND	0.001	ND	ND	ND	1.29
AQ100704:1210NP4-1	10/7/2004	12:10	0.4	0.035	0.058	0.005	0.005	0.003	0.038	0.008	0.003	0.001	0.002	0.008	0.05	ND	0.045	0.08	ND	0.001	ND	ND	ND	0.72
AQ110304:945NP4-1	11/3/2004	9:45	0.44	0.032	0.074	0.01	0.022	0.004	0.02	0.008	0.0018	ND	0.0012	0.008	0.1	0.008	0.02	0.152	ND	ND	ND	ND	ND	0.90
AQ120204:1100NP4-1	12/2/2004	11:00	0.4	0.026	0.06	0.01	0.022	0.004	0.052	0.03	0.008	0.0014	0.002	ND	1.04	0.012	0.05	0.24	ND	0.0018	ND	ND	ND	1.04
AQ010405:1145NP4-1	1/4/2005	11:45	0.08	0.025	0.0775	ND	ND	ND	0.015	0.005	ND	ND	ND	0.005	0.025	ND	ND	0.04	ND	ND	ND	ND	ND	0.25
AQ020205:1345NP4-1	2/2/2005	13:45	0.45	0.0325	0.0675	ND	ND	ND	0.02	0.0075	ND	ND	ND	0.0075	0.0325	ND	ND	0.185	ND	ND	ND	ND	ND	0.80
AQ030205:1105NP4-1	3/2/2005	11:05	0.35	0.0325	0.0725	ND	ND	ND	0.0175	0.005	ND	ND	ND	0.005	0.015	ND	ND	0.0825	ND	ND	ND	ND	ND	0.58
Midcarbon			Parameters (mg/m3)																				TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ040804:1002NP4-2	4/8/2004	10:02	0.325	0.040	0.033	ND	0.023	ND	0.03	0.005	0.002	ND	ND	ND	0.008	ND	0.063	0.008	ND	ND	ND	ND	ND	0.54
AQ050504:1357NP4-2	5/5/2005	13:57	0.25	0.033	0.035	ND	ND	ND	0.02	0.005	0.003	ND	ND	0.008	0.055	ND	0.063	0.063	ND	0.003	ND	ND	ND	0.56
AQ080204:1202NP4-2	8/2/2004	12:02	0.012	0.002	ND	ND	ND	ND	0.02	0.003	0.002	0.0008	0.001	ND	0.021	0.003	0.041	0.057	ND	0.0008	ND	ND	ND	0.16
AQ070704:1420NP4-2	7/7/2004	14:20	0.013	0.002	ND	ND	ND	ND	0.032	0.004	0.003	0.0009	0.003	ND	0.058	0.004	0.097	0.027	ND	0.001	ND	ND	ND	0.24
AQ080404:1335NP4-2	8/4/2004	13:35	0.048	0.002	ND	0.005	ND	ND	0.031	0.002	0.003	0.001	0.003	ND	0.063	0.004	0.078	0.071	ND	0.001	ND	ND	ND	0.31
AQ080204:1432NP4-2	9/2/2004	14:32	0.014	0.002	ND	0.005	ND	ND	0.059	0.005	0.005	0.001	0.003	ND	0.088	0.003	0.086	0.025	ND	0.002	ND	ND	ND	0.30
AQ100704:1212NP4-2	10/7/2004	12:12	0.021	0.001	ND	0.008	0.01	ND	0.018	0.007	0.003	0.001	0.002	0.002	0.011	ND	0.036	0.057	ND	0.001	ND	ND	ND	0.17
AQ110304:947NP4-2	11/3/2004	9:47	0.015	ND	ND	0.007	0.014	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.034	0.005	0.018	0.028	ND	0.0004	ND	ND	ND	0.15
AQ120204:1102NP4-2	12/2/2004	11:02	0.004	ND	ND	0.009	0.017	0.002	0.034	0.003	0.003	0.0005	0.003	0.011	0.097	0.004	0.025	0.08	ND	0.001	ND	ND	ND	0.23
AQ010405:1150NP4-2	1/4/2005	11:50	0.004	ND	0.045	0.011	0.028	0.003	0.024	0.002	0.001	ND	0.002	0.018	0.009	ND	0.015	0.028	ND	ND	ND	ND	ND	0.19
AQ020205:1350NP4-2	2/2/2005	13:50	ND	ND	0.15	0.011	0.033	0.005	0.019	0.001	ND	ND	ND	0.018	0.019	ND	0.013	0.004	ND	ND	ND	ND	ND	0.27
AQ030205:1110NP4-2	3/2/2005	11:10	ND	ND	0.14	0.009	0.022	0.004	0.016	0.002	0.002	ND	ND	0.011	0.01	ND	0.008	0.021	ND	ND	ND	ND	ND	0.25
Postcarbon			Parameters (mg/m3)																				TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ040804:1005NP4-3	4/9/2004	10:05	0.004	ND	0.028	0.008	0.013	0.004	0.037	0.003	0.004	0.001	0.003	ND	0.009	ND	0.048	0.014	ND	0.001	ND	ND	ND	0.18
AQ050504:1400NP4-3	5/5/2004	14:00	0.004	0.005	0.031	0.008	0.015	0.004	0.018	0.004	0.002	0.0005	0.001	0.008	0.034	0.005	0.039	0.18	ND	0.0007	ND	ND	ND	0.34
AQ080204:1204NP4-3	8/2/2004	12:04	0.003	0.002	ND	ND	ND	ND	0.019	0.002	0.002	0.0005	0.001	ND	0.02	0.004	0.039	0.1	ND	0.0008	ND	ND	ND	0.19
AQ070704:1425NP4-3	7/7/2004	14:25	0.003	0.002	ND	ND	ND	ND	0.032	0.004	0.003	0.0009	0.003	ND	0.062	ND	0.11	0.008	ND	0.001	ND	ND	ND	0.23
AQ080404:1340NP4-3	8/4/2004	13:40	0.02	0.002	ND	ND	ND	ND	0.03	0.004	0.003	0.001	0.004	ND	0.055	0.004	0.067	0.055	ND	0.001	ND	ND	ND	0.25
AQ090204:1433NP4-3	9/2/2004	14:33	0.023	0.003	ND	ND	ND	ND	0.062	0.008	0.005	0.001	0.003	ND	0.087	0.004	0.085	0.033	ND	0.002	ND	ND	ND	0.32
AQ100704:1215NP4-3	10/7/2004	12:15	0.001	0.001	ND	ND	ND	ND	0.045	0.004	0.003	0.0009	0.003	ND	0.011	ND	0.033	0.034	ND	0.001	ND	ND	ND	0.14
AQ110304:950NP4-3	11/3/2004	9:50	0.005	ND	ND	0.002	ND	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.032	ND	0.017	0.022	ND	0.0005	ND	ND	ND	0.11
AQ120204:1106NP4-3	12/2/2004	11:05	ND	0.002	ND	0.008	ND	ND	0.035	0.011	0.003	0.0008	0.003	ND	0.27	0.005	0.025	0.084	ND	0.001	ND	ND	ND	0.19
AQ010405:1155NP4-3	1/4/2005	11:55	0.002	ND	ND	0.007	0.013	0.002	0.023	0.002	0.002	ND	0.002	ND	0.008	ND	0.015	0.008	ND	ND	ND	ND	ND	0.08
AQ020205:1355NP4-3	2/2/2005	13:55	0.004	ND	ND	ND	ND	ND	0.021	0.002	ND	ND	0.001	ND	0.023	ND	0.013	ND	ND	ND	ND	ND	ND	0.08
AQ030205:1115NP4-3	3/2/2005	11:15	ND	ND	0.023	0.009	0.031	ND	0.016	0.002	0.002	ND	0.001	0.012	0.008	ND	0.009	0.007	ND	ND	ND	ND	ND	0.12

Notes: 1. Methylene Chloride concentrations in all three air samples collected during the December 2, 2004 sampling event are greatly elevated due to suspected laboratory contamination. Methylene chloride was confirmed as a suspected laboratory contaminant by the laboratory supervisor. The methylene chloride concentrations from the November 3, 2004 sampling event were used instead of the December 2, 2004 methylene chloride concentrations to calculate the total VOCs for December 2004.

PCE - Tetrachloroethane
TCE - Trichloroethane
TCA - 1,1,1-Trichloroethane

DCE - 1,1-Dichloroethane
DCA - 1,1-Dichloroethane
cis-DCE - cis-1,2-Dichloroethane
CT - Carbon Tetrachloride

CF - Chloroform
MC - Methylene Chloride
CM - Chloromethane
CD - Carbon Disulfide

BM - Bromomethane
CB - Chlorobenzene
EB - Ethylbenzene
VC - Vinyl Chloride

TABLE 4

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-1	23-Apr-03	ND<1	ND<1	ND<1	ND<1	1.2	8.8	0.053	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	ND<1	ND<1	ND<1	ND<1	1.8	8.7	0.051	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1	ND<1
	11-Jun-03	ND<1	ND<1	ND<1	ND<1	ND<1	8.1	0.0290	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	ND<1	ND<1	ND<1	ND<1	2.9	6.6	0.0100	0.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	ND<1	ND<1	ND<1	ND<1	2.6	9.4	0.0930	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	ND<1	ND<1	ND<1	ND<1	3.2	14	0.0540	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0613	0.0074	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	ND<1	ND<1	ND<1	ND<1	2.2	9.4	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	ND<1	ND<1	ND<1	ND<1	4.0	2.2	0.0098	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	ND<1	ND<1	ND<1	4.6	5.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	ND<1	ND<1	ND<1	ND<1	4.1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.5
	14-Apr-04	ND<1	ND<1	ND<1	ND<1	2.9	6.1	0.0240	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	ND<1	ND<1	ND<1	ND<1	5.6	6.8	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.1*	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	2.0	3.4	0.0454	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	ND<1	ND<1	ND<1	ND<1	ND<1	3.1	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	8.0
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0328	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-2	23-Apr-03	14	1.3	ND<1	ND<1	ND<1	ND<1	6.31	0.212	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	2	ND<1	ND<1	ND<1	ND<1	3.8	0.052	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1
	11-Jun-03	15	0.6	ND<1	ND<1	ND<1	ND<1	3.01	0.885	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	5.34	0.438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	7.9	ND<1	ND<1	ND<1	ND<1	ND<1	5.99	0.758	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	9.2	0.5	ND<1	ND<1	ND<1	6.0	4.49	0.899	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	8.1	0.7	ND<1	ND<1	ND<1	ND<1	6.79	0.101	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	5.5	ND<1	ND<1	ND<1	ND<1	5.5	5.46	0.0213	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	8.7	ND<1	ND<1	ND<1	ND<1	1.1	5.57	0.207	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	5.4	ND<1	ND<1	ND<1	ND<1	3.9	3.77	0.0748	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	4.9	ND<1	ND<1	ND<1	ND<1	3.3	0.343	0.318	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	4.4	ND<1	ND<1	ND<1	ND<1	2.8	5.59	0.224	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	8.2	ND<1	ND<1	ND<1	ND<1	4.7	4.5	0.691	ND<1	ND<1	ND<1	ND<1	5.6 *	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	52.5	1.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	6.5	ND<1	ND<1	ND<1	ND<1	1.3	4.88	0.704	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	1.5	4.78	0.213	ND<1	ND<1	ND<1	ND<1	ND<1	2.1	1.5	ND<1
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromofom (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-3	23-Apr-03	1.1	1.2	ND<1	ND<1	ND<1	ND<1	1.81	0.395	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	2.2	2.5	1.1	ND<1	ND<1	ND<1	1.68	0.166	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1
	11-Jun-03	2.4	3.4	1.8	ND<1	ND<1	ND<1	2.37	0.517	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	2.3	5.7	2.3	ND<1	ND<1	ND<1	1.77	0.636	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	2.8	5.8	2.9	ND<1	ND<1	ND<1	2.24	1.57	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	2.1	5.3	2.6	ND<1	ND<1	ND<1	1.86	1.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	1.9	5.2	3.3	ND<1	ND<1	ND<1	2.59	1.27	ND<1	ND<1	0.6	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	1.2	5.8	ND<1	ND<1	ND<1	ND<1	1.96	0.129	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.2	6.9	3.2	ND<1	ND<1	ND<1	1.96	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	3.6	2.2	ND<1	ND<1	ND<1	1.63	1.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	1.2	5.0	2.3	ND<1	ND<1	ND<1	3.34	0.542	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	28-Apr-04	1.3	8.8	4.4	ND<1	ND<1	ND<1	3.07	1.32	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	ND<1
	5-May-04	0.9	6.9	3.6	ND<1	ND<1	ND<1	2.07	1.96	ND<1	ND<1	ND<1	ND<1	5.6*	ND<1	ND<1	ND<1
	30-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.619	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	2.4	6.1	2.6	ND<1	ND<1	ND<1	2.07	1.79	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	2.7	21	8.7	ND<1	ND<1	ND<1	1.91	0.42	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	2.2	12	5.0	ND<1	ND<1	ND<1	2.09	1.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.5	6.5	2.6	ND<1	ND<1	ND<1	1.87	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.77	0.489	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	3	13	5.0	ND<1	ND<1	ND<1	1.89	1.36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-4	23-Apr-03	110	3.1	ND<1	ND<1	ND<1	ND<1	3.18	0.136	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	170	5.4	1.0	ND<1	ND<1	ND<1	3.4	0.023	ND<1	ND<1	ND<1	ND<1	3.3	ND<1	ND<1	ND<1
	11-Jun-03	170	4.8	ND<1	ND<1	ND<1	ND<1	1.03	0.572	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	200	5.9	1.3	ND<1	ND<1	ND<1	2.67	0.292	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	210	5.7	1.1	ND<1	ND<1	ND<1	3.21	0.529	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	390	6.2	1.0	ND<1	ND<1	ND<1	2.95	0.922	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	380	6.8	1.8	ND<1	ND<1	ND<1	6.93	0.221	ND<1	1.2	0.9	0.8	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	270	7.9	ND<1	ND<1	ND<1	ND<1	5.45	0.0331	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	270	5.9	ND<1	ND<1	ND<1	ND<1	3.56	0.48	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	170	6.9	14.0	ND<1	ND<1	ND<1	3.28	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	170	5.8	4.5	ND<1	ND<1	ND<1	1.61	0.0691	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.982	0.173	ND<1	ND<1	ND<1	ND<1	2.1*	ND<1	ND<1	ND<1
	5-May-04	470	6.2	7.8	ND<1	ND<1	ND<1	7.08	2.33	ND<1	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<1
	30-Jun-04	110	3.8	28	ND<1	ND<1	ND<1	4.44	1.11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	110	3.2	29	ND<1	ND<1	ND<1	5.00	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	120	3.7	18	ND<1	ND<1	ND<1	2.98	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	3.2	ND<1	ND<1
	7-Oct-04	94	ND<1	14	ND<1	ND<1	ND<1	3.65	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	130	4.2	11	ND<1	ND<1	ND<1	4.75	0.205	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	230	5.7	35	ND<1	ND<1	ND<1	1.90	1.62	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-5	23-Apr-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	ND<1	ND<1	ND<1	0.8	6.7	0.146	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Jun-03	21	ND<1	ND<1	ND<1	ND<1	6.2	0.76	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	11	ND<1	ND<1	ND<1	1.1	9.7	6.47	0.068	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	15	ND<1	ND<1	ND<1	0.9	7.3	0.269	0.021	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	18	ND<1	ND<1	ND<1	ND<1	8.1	0.043	0.016	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	18	ND<1	ND<1	ND<1	ND<1	ND<1	13.1	0.0097	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	ND<1	ND<1	ND<1	ND<1	7.5	0.0523	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	14	ND<1	ND<1	ND<1	0.9	4.0	0.05	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	14	ND<1	ND<1	ND<1	1.0	6.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	14	ND<1	ND<1	ND<1	ND<1	5.0	0.0852	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	18	ND<1	1.5	ND<1	ND<1	6.1	0.147	0.015	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	5-May-04	38	0.8	3.2	ND<1	1.5	8.0	0.055	0.015	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jun-04	17	ND<1	4.6	ND<1	ND<1	3.9	0.054	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	21	ND<1	4.6	ND<1	ND<1	3.1	0.0254	0.0265	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	24	ND<1	6.5	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	16	ND<1	5.2	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	15	ND<1	6.4	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	28	ND<1	28	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.316	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-6	23-Apr-03	79	1.0	ND<1	ND<1	ND<1	ND<1	0.028	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	120	1.8	ND<1	ND<1	0.6	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Jun-03	120	0.7	ND<1	ND<1	ND<1	ND<1	0.0097	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	150	0.6	ND<1	ND<1	ND<1	ND<1	0.186	0.034	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	140	2.2	ND<1	ND<1	ND<1	ND<1	0.089	0.018	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	140	2.6	ND<1	ND<1	ND<1	ND<1	0.023	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	180	3.3	1.0	ND<1	ND<1	ND<1	0.342	0.0083	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	120	2.6	ND<1	ND<1	ND<1	ND<1	0.017	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	160	2.4	ND<1	ND<1	ND<1	ND<1	0.015	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	130	3.3	1.1	ND<1	ND<1	1.7	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	110	2.7	ND<1	ND<1	ND<1	1.6	0.077	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	110	2.9	1.3	ND<1	ND<1	2.6	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	5-May-04	210	4.8	ND<1	ND<1	ND<1	3.2	0.719	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jun-04	92	3.6	1.3	ND<1	ND<1	2.1	0.151	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	100	2.8	1.2	ND<1	ND<1	1.7	0.437	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	94	ND<1	1.6	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	2.5	0.0111	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	200	3.8	16	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	2.7	0.0284	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethane (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-7	23-Apr-03	100	1.8	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	140	3.1	1.0	ND<1	ND<1	ND<1	0.032	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Jun-03	140	2.0	ND<1	ND<1	ND<1	ND<1	0.0246	0.0086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	150	2.1	ND<1	ND<1	ND<1	ND<1	0.024	0.041	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	120	2.3	ND<1	ND<1	ND<1	ND<1	0.011	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	130	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	140	3.4	1.1	ND<1	ND<1	ND<1	0.0484	ND<0.02	ND<1	ND<1	0.2	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	110	2.8	ND<1	ND<1	ND<1	ND<1	0.0239	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	190	3.7	ND<1	ND<1	ND<1	ND<1	0.0069	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	120	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	100	3.0	ND<1	ND<1	ND<1	ND<1	0.0205	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	79	2.5	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.2*	ND<1	ND<1	ND<1
	5-May-04	130	4.0	ND<1	ND<1	ND<1	ND<1	0.012	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<1
	14-Jun-04	59	2.7	ND<1	ND<1	ND<1	ND<1	0.018	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	55	2.1	ND<1	ND<1	ND<1	ND<1	0.791	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	ND<1
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	0.0272	0.00876	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-8	23-Apr-03	41	2.0	1.8	ND<1	ND<1	ND<1	11.8	0.352	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	61	3.9	3.8	ND<1	ND<1	ND<1	10.1	0.068	ND<1	1.8	ND<1	ND<1	3.4	ND<1	ND<1	ND<1
	11-Jun-03	57	3.1	2.7	ND<1	ND<1	ND<1	9.14	1.10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	35	1.9	3.2	ND<1	ND<1	ND<1	10.5	0.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	30	1.7	3.6	ND<1	ND<1	ND<1	11.1	1.18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	28	2.5	4.4	ND<1	ND<1	ND<1	9.93	0.40	ND<1	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.3	5.4	ND<1	ND<1	ND<1	13.3	0.21	ND<1	4.1	0.7	1.3	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	17	2.1	2.6	ND<1	ND<1	ND<1	9.16	0.05	ND<1	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	16	2.2	4.1	ND<1	ND<1	ND<1	9.73	2.72	ND<1	3.5	ND<1	1.5	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	15	2.2	4.7	ND<1	ND<1	ND<1	8.74	0.19	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	22	2.7	4.3	ND<1	ND<1	ND<1	11.9	0.23	ND<1	3.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	14	2.0	6.2	ND<1	ND<1	ND<1	10.7	0.14	ND<1	5.7	ND<1	ND<1	1.9*	ND<1	ND<1	ND<1
	5-May-04	27	4.1	8.3	ND<1	ND<1	ND<1	8.77	0.21	ND<1	8.7	ND<1	ND<1	8.5*	ND<1	ND<1	ND<1
	14-Jun-04	10	2.4	5.8	ND<1	ND<1	ND<1	9.15	0.10	ND<1	4.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04 **	3	1.0	3.7	ND<1	ND<1	ND<1	4.18	0.21	ND<1	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	28.8	0.2	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	10.6	0.3	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	16	ND<1	22	ND<1	ND<1	ND<1	15.6	0.1	ND<1	15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	ND<1	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	ND<1	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-9	23-Apr-03	15	1.2	1.8	ND<1	ND<1	ND<1	3.55	1.97	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	1.8	3.6	ND<1	ND<1	ND<1	2.95	0.046	ND<1	1.9	ND<1	ND<1	3.2	ND<1	ND<1	ND<1
	11-Jun-03	16	1.6	4.8	ND<1	ND<1	ND<1	2.75	1.74	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	4.7	1.6	7.3	ND<1	ND<1	ND<1	3.60	0.467	ND<1	3.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	25	1.2	3.5	ND<1	ND<1	ND<1	4.05	2.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	22	2.1	5.8	ND<1	ND<1	ND<1	3.49	2.88	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.2	8.2	ND<1	ND<1	ND<1	5.39	1.72	ND<1	5.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	1.7	5.4	ND<1	ND<1	ND<1	1.94	1.57	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.3	2.2	13	ND<1	ND<1	ND<1	0.638	0.029	ND<1	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	2.2	12	ND<1	ND<1	ND<1	1.24	0.222	ND<1	3.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	5.6	1.7	10	ND<1	ND<1	ND<1	2.65	1.22	ND<1	5.9	ND<1	ND<1	2.0	2.0*	ND<1	ND<1
	5-May-04	3.7	1.7	13	ND<1	ND<1	ND<1	2.58	1.83	ND<1	6.7	ND<1	ND<1	7.1*	ND<1	ND<1	ND<1
	14-Jun-04	1.8	1.9	8.2	ND<1	ND<1	ND<1	3.03	1.11	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	3.4	1.3	5.1	ND<1	ND<1	ND<1	2.6	1.95	ND<1	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	ND<1	1.9	ND<1	ND<1	ND<1	1.6	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

ND: Not detected
<#: Less than method detection limit

ug/L: Micrograms per liter
-: Not analyzed

ARAR's are chemical specific aquifer restoration goals for ground-water at the Former Rowe Industries Superfund Site.
Bold values indicate an exceedance of the ARAR standard established for the site.

PCE: Tetrachloroethylene

TCE: Trichloroethylene

TCA: 1,1,1-Trichloroethane

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl Tertiary Butyl Ether

NM: Not Measured

*Methylene Chloride detected in laboratory method blank

NE: ARAR goal was not established for this compound by the EPA.


** The July 14, 2004 sample collected for RW-8 only represents water in the pipe since the RW-8 pump was not operating at this time.

*** The August 26, 2004 samples were lost during shipment.

GRAPHS


GRAPH 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
(March 1, 2005 through March 31, 2005)




GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
MARCH 2005 LABORATORY ANALYTICAL REPORTS

Monday, March 14, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0503046

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/4/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0503046

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0503046-01A	WQ030205:1030 NP2-6	4612	3/2/2005	3/4/2005
0503046-01B	WQ030205:1030 NP2-6	4612	3/2/2005	3/4/2005
0503046-01C	WQ030205:1030 NP2-6	4612	3/2/2005	3/4/2005
0503046-02A	WQ030205:1040 NP2-7	4612	3/2/2005	3/4/2005
0503046-02B	WQ030205:1040 NP2-7	4612	3/2/2005	3/4/2005
0503046-02C	WQ030205:1040 NP2-7	4612	3/2/2005	3/4/2005
0503046-03A	WQ030205:1050 NP2-10	4612	3/2/2005	3/4/2005
0503046-03B	WQ030205:1050 NP2-10	4612	3/2/2005	3/4/2005
0503046-03C	WQ030205:1050 NP2-10	4612	3/2/2005	3/4/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

NYSDOH

11418

TAG # / COC 4612

NYSDOH
CTDOH
NJDEP
PADEP

11418
PH-0205
NY050
68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS

LBG
126 Monroe Tpk
Trumbull, CT 06611

CONTACT:

P. Inman / M. Goldberg
203-452-3100

SAMPLER (SIGNATURE)

Steve Silvestri

SAMPLE(S)
SEALED

YES / NO

SAMPLER NAME (PRINT)

Steve Silvestri

CORRECT
CONTAINER(S)

YES / NO

PROJECT LOCATION:

Rowe

ANALYSIS
REQUIRED

B260
MTBE
Furan
Total Fe
Diss Fe
TDS

FOR
METHANOL PRESERVED
SAMPLES
[VOLATILE VIAL #]

LABORATORY
ID #

MATRIX

CON-
TAINERS

SAMPLING
DATE/
TIME

SAMPLE # - LOCATION

WQ

L

4

3/2/05/1030

WQ0302051030 NP2-6

X X X X X

0503046-1ABC

↓

↓

4

3/4/05/1040

WQ0307051040 NP2-7

X X X X X

2ABC

5

3/2/05/1050

WQ0302051050 NP2-10

X X X X X X

3ABC

COOLER TEMPERATURE:

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIFE; P=PAINT CHIPS; B=BULK MATERIAL
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

TURNAROUND REQUIRED:

NORMAL ☒ STAT ☐ BY / /

COMMENTS / INSTRUCTIONS

RELINQUISHED BY (SIGNATURE)

Steve Silvestri

DATE
3/3/05
TIME
1600

PRINTED NAME

Steve Silvestri

RECEIVED BY LAB (SIGNATURE)

[Signature]

DATE
3/4/05
TIME
1015

PRINTED NAME

P. Artonio

RELINQUISHED BY (SIGNATURE)

DATE
TIME

PRINTED NAME

RECEIVED BY LAB (SIGNATURE)

DATE
TIME

PRINTED NAME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT: Leggett Brashears & Graham Inc.

Client Sample ID: WQ030205:1030 NP2-6

Lab Order: 0503046

Tag Number: 4612

Project: Rowe Industries

Collection Date: 3/2/2005

Lab ID: 0503046-01A

Date Received: 3/4/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,1,1-Trichloroethane	9.4	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
2-Butanone	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
2-Hexanone	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Acetone	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Benzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Bromobenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Bromoform	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Bromomethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Chloroethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ030205:1030 NP2-6
 Lab Order: 0503046 Tag Number: 4612
 Project: Rowe Industries Collection Date: 3/2/2005
 Lab ID: 0503046-01A Date Received: 3/4/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Chloromethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Dibromomethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/7/2005 11:41:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Methylene chloride	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Naphthalene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
o-Xylene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Styrene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Tetrachloroethene	28	1.0		µg/L	1	3/7/2005 11:41:00 PM
Toluene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Trichloroethene	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/7/2005 11:41:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/7/2005 11:41:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 2 of 12

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ030205:1030 NP2-6
Lab Order:	0503046	Tag Number:	4612
Project:	Rowe Industries	Collection Date:	3/2/2005
Lab ID:	0503046-01B	Date Received:	3/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	4.64	0.0200		mg/L	1	3/9/2005 12:06:24 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ030205:1030 NP2-6
Lab Order:	0503046	Tag Number:	4612
Project:	Rowe Industries	Collection Date:	3/2/2005
Lab ID:	0503046-01C	Date Received:	3/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0670	0.0200		mg/L	1	3/9/2005 12:01:11 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0503046
Project: Rowe Industries
Lab ID: 0503046-02A

Client Sample ID: WQ030205:1040 NP2-7
Tag Number: 4612
Collection Date: 3/2/2005
Matrix: LIQUID

Date Received: 3/4/2005

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
2-Butanone	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
2-Hexanone	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Acetone	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Benzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Bromobenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Bromoforn	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Bromomethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Chloroethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ030205:1040 NP2-7

Lab Order: 0503046

Tag Number: 4612

Project: Rowe Industries

Collection Date: 3/2/2005

Lab ID: 0503046-02A

Date Received: 3/4/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Chloromethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Dibromomethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/8/2005 12:12:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Methylene chloride	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Naphthalene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
o-Xylene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Styrene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Tetrachloroethene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Toluene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Trichloroethene	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/8/2005 12:12:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/8/2005 12:12:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ030205:1040 NP2-7
Lab Order:	0503046	Tag Number:	4612
Project:	Rowe Industries	Collection Date:	3/2/2005
Lab ID:	0503046-02B	Date Received:	3/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	5.39	0.0200		mg/L	1	3/9/2005 12:10:24 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ030205:1040 NP2-7
Lab Order:	0503046	Tag Number:	4612
Project:	Rowe Industries	Collection Date:	3/2/2005
Lab ID:	0503046-02C	Date Received:	3/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.196	0.0200		mg/L	1	3/9/2005 12:08:24 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ030205:1050 NP2-10
 Lab Order: 0503046 Tag Number: 4612
 Project: Rowe Industries Collection Date: 3/2/2005
 Lab ID: 0503046-03A Date Received: 3/4/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8280B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
2-Butanone	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
2-Hexanone	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Acetone	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Benzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Bromobenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Bromoform	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Bromomethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Chloroethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT: Leggett Brashears & Graham Inc.

Client Sample ID: WQ030205:1050 NP2-10

Lab Order: 0503046

Tag Number: 4612

Project: Rowe Industries

Collection Date: 3/2/2005

Lab ID: 0503046-03A

Date Received: 3/4/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Chloromethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Dibromomethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/8/2005 12:44:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Methylene chloride	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Naphthalene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
o-Xylene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Styrene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Tetrachloroethene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Toluene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Trichloroethene	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/8/2005 12:44:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/8/2005 12:44:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 10 of 12

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ030205:1050 NP2-10
Lab Order:	0503046	Tag Number:	4612
Project:	Rowe Industries	Collection Date:	3/2/2005
Lab ID:	0503046-03B	Date Received:	3/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	0.114	0.0200		mg/L	1	3/9/2005 12:15:46 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 14-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ030205:1050 NP2-10
Lab Order:	0503046	Tag Number:	4612
Project:	Rowe Industries	Collection Date:	3/2/2005
Lab ID:	0503046-03C	Date Received:	3/4/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.178	0.0200		mg/L	1	3/9/2005 12:12:50 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	95	1.0		mg/L	1	3/9/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Monday, March 21, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0503123

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/15/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0503123**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0503123-01A	WQ031005:1200 NP2-6	4636	3/10/2005	3/15/2005
0503123-01B	WQ031005:1200 NP2-6	4636	3/10/2005	3/15/2005
0503123-01C	WQ031005:1200 NP2-6	4636	3/10/2005	3/15/2005
0503123-02A	WQ031005:1202 NP2-7	4636	3/10/2005	3/15/2005
0503123-02B	WQ031005:1202 NP2-7	4636	3/10/2005	3/15/2005
0503123-02C	WQ031005:1202 NP2-7	4636	3/10/2005	3/15/2005
0503123-03A	WQ031005:1205 NP2-10	4636	3/10/2005	3/15/2005
0503123-03B	WQ031005:1205 NP2-10	4636	3/10/2005	3/15/2005
0503123-03C	WQ031005:1205 NP2-10	4636	3/10/2005	3/15/2005

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS

LBG
126 Monroe Turnpike
Trumbull, CT 06661

CONTACT:

Mark Goldberg

SAMPLER (SIGNATURE)

Mark M. Goldberg

SAMPLE(S)
SEALED

YES NO

SAMPLER NAME (PRINT)

Mark M. Goldberg

CORRECT
CONTAINER(S)

YES NO

PROJECT LOCATION:

Rouse

ANALYSIS
REQUIRED

B260
MTBE
Heptane
Tol. + Diss. Ion
TAS

FOR
METHANOL PRESERVED
SAMPLES
(VOLATILE VIAL #)

LABORATORY
ID #

MATRIX

CON-
TAINERS

SAMPLING
DATE/
TIME

SAMPLE # - LOCATION

0503123-1ABC L 4 3/10/05 118031005.1200 NP2-6
2ABC 1 4 1202 NP2-7
3ABC 1 5 1205 NP2-10

COOLER TEMPERATURE:

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIFE; P=PAINT CHIPS; B=BULK MATERIAL
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

TURNAROUND REQUIRED:

NORMAL ☒ STAT ☐

COMMENTS / INSTRUCTIONS

RELINQUISHED BY (SIGNATURE)

[Signature]

DATE
3/14/05
TIME
1410

PRINTED NAME

Paul Tobman

RECEIVED BY LAB (SIGNATURE)

[Signature]

DATE
3/15/05
TIME
1035

PRINTED NAME

P. Antonio

RELINQUISHED BY (SIGNATURE)

DATE
TIME

PRINTED NAME

RECEIVED BY LAB (SIGNATURE)

DATE
TIME

PRINTED NAME

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ031005:1200 NP2-6

Lab Order: 0503123

Tag Number: 4636

Project: Rowe Industries

Collection Date: 3/10/2005

Lab ID: 0503123-01A

Date Received: 3/15/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,1,1-Trichloroethane	2.4	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
2-Butanone	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
2-Hexanone	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Acetone	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Benzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Bromobenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Bromoform	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Bromomethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Chloroethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031005:1200 NP2-6
Lab Order:	0503123	Tag Number:	4636
Project:	Rowe Industries	Collection Date:	3/10/2005
Lab ID:	0503123-01A	Date Received:	3/15/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Chloromethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Dibromomethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/16/2005 6:20:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Methylene chloride	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Naphthalene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
o-Xylene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Styrene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Tetrachloroethene	31	1.0		µg/L	1	3/16/2005 6:20:00 PM
Toluene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Trichloroethene	1.8	1.0		µg/L	1	3/16/2005 6:20:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/16/2005 6:20:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/16/2005 6:20:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031005:1200 NP2-6
Lab Order:	0503123	Tag Number:	4636
Project:	Rowe Industries	Collection Date:	3/10/2005
Lab ID:	0503123-01B	Date Received:	3/15/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	8.08	0.0200		mg/L	1	3/15/2005 1:55:05 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031005:1200 NP2-6
Lab Order:	0503123	Tag Number:	4636
Project:	Rowe Industries	Collection Date:	3/10/2005
Lab ID:	0503123-01C	Date Received:	3/15/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.184	0.0200		mg/L	1	3/15/2005 1:52:38 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT: Leggett Brashears & Graham Inc.

Client Sample ID: WQ031005:1202 NP2-7

Lab Order: 0503123

Tag Number: 4636

Project: Rowe Industries

Collection Date: 3/10/2005

Lab ID: 0503123-02A

Date Received: 3/15/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
2-Butanone	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
2-Hexanone	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Acetone	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Benzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Bromobenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Bromoforn	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Bromomethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Chloroethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ031005:1202 NP2-7

Lab Order: 0503123

Tag Number: 4636

Project: Rowe Industries

Collection Date: 3/10/2005

Lab ID: 0503123-02A

Date Received: 3/15/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Chloromethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Dibromomethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/16/2005 6:53:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Methylene chloride	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Naphthalene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
o-Xylene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Styrene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Tetrachloroethene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Toluene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Trichloroethene	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/16/2005 6:53:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/16/2005 6:53:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031005:1202 NP2-7
Lab Order:	0503123	Tag Number:	4636
Project:	Rowe Industries	Collection Date:	3/10/2005
Lab ID:	0503123-02B	Date Received:	3/15/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	11.8	0.0200		mg/L	1	3/15/2005 2:04:26 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031005:1202 NP2-7
Lab Order:	0503123	Tag Number:	4636
Project:	Rowe Industries	Collection Date:	3/10/2005
Lab ID:	0503123-02C	Date Received:	3/15/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.815	0.0200		mg/L	1	3/15/2005 2:02:20 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0503123
Project: Rowe Industries
Lab ID: 0503123-03A

Client Sample ID: WQ031005:1205 NP2-10
Tag Number: 4636
Collection Date: 3/10/2005
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
2-Butanone	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
2-Hexanone	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Acetone	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Benzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Bromobenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Bromoform	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Bromomethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Chloroethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ031005:1205 NP2-10
 Lab Order: 0503123 Tag Number: 4636
 Project: Rowe Industries Collection Date: 3/10/2005
 Lab ID: 0503123-03A Date Received: 3/15/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Chloromethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Dibromomethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/16/2005 7:30:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Methylene chloride	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Naphthalene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
o-Xylene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Styrene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Tetrachloroethene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Toluene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Trichloroethene	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/16/2005 7:30:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/16/2005 7:30:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031005:1205 NP2-10
Lab Order:	0503123	Tag Number:	4636
Project:	Rowe Industries	Collection Date:	3/10/2005
Lab ID:	0503123-03B	Date Received:	3/15/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	9.17	0.0200		mg/L	1	3/15/2005 2:08:56 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031005:1205 NP2-10
Lab Order:	0503123	Tag Number:	4636
Project:	Rowe Industries	Collection Date:	3/10/2005
Lab ID:	0503123-03C	Date Received:	3/15/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.769	0.0200		mg/L	1	3/15/2005 2:06:18 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	13	1.0		mg/L	1	3/17/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Tuesday, March 22, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0503142

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 3/17/2005 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0503142

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0503142-01A	GWQ031505:1100 NP1-1-1	4621	3/15/2005	3/17/2005
0503142-01B	GWQ031505:1100 NP1-1-1	4621	3/15/2005	3/17/2005
0503142-01C	GWQ031505:1100 NP1-1-1	4621	3/15/2005	3/17/2005
0503142-01D	GWQ031505:1100 NP1-1-1	4621	3/15/2005	3/17/2005
0503142-02A	GWQ031505:1110 NP1-1-2	4621	3/15/2005	3/17/2005
0503142-02B	GWQ031505:1110 NP1-1-2	4621	3/15/2005	3/17/2005
0503142-02C	GWQ031505:1110 NP1-1-2	4621	3/15/2005	3/17/2005
0503142-02D	GWQ031505:1110 NP1-1-2	4621	3/15/2005	3/17/2005
0503142-03A	GWQ031505:1120 NP1-1-3	4621	3/15/2005	3/17/2005
0503142-03B	GWQ031505:1120 NP1-1-3	4621	3/15/2005	3/17/2005
0503142-03C	GWQ031505:1120 NP1-1-3	4621	3/15/2005	3/17/2005
0503142-03D	GWQ031505:1120 NP1-1-3	4621	3/15/2005	3/17/2005
0503142-04A	GWQ031505:1130 NP1-1-5	4621	3/15/2005	3/17/2005
0503142-04B	GWQ031505:1130 NP1-1-5	4621	3/15/2005	3/17/2005
0503142-04C	GWQ031505:1130 NP1-1-5	4621	3/15/2005	3/17/2005
0503142-04D	GWQ031505:1130 NP1-1-5	4621	3/15/2005	3/17/2005
0503142-05A	GWQ031505:1140 NP1-1-6	4621	3/15/2005	3/17/2005
0503142-05B	GWQ031505:1140 NP1-1-6	4621	3/15/2005	3/17/2005
0503142-05C	GWQ031505:1140 NP1-1-6	4621	3/15/2005	3/17/2005
0503142-05D	GWQ031505:1140 NP1-1-6	4621	3/15/2005	3/17/2005
0503142-06A	GWQ031505:1150 NP1-1-7	4621	3/15/2005	3/17/2005
0503142-06B	GWQ031505:1150 NP1-1-7	4621	3/15/2005	3/17/2005
0503142-06C	GWQ031505:1150 NP1-1-7	4621	3/15/2005	3/17/2005
0503142-06D	GWQ031505:1150 NP1-1-7	4621	3/15/2005	3/17/2005
0503142-07A	GWQ031505:1200 NP1-1-8	4621	3/15/2005	3/17/2005
0503142-07B	GWQ031505:1200 NP1-1-8	4621	3/15/2005	3/17/2005
0503142-07C	GWQ031505:1200 NP1-1-8	4621	3/15/2005	3/17/2005
0503142-07D	GWQ031505:1200 NP1-1-8	4621	3/15/2005	3/17/2005
0503142-08A	GWQ031505:1210 NP1-1-9	4621	3/15/2005	3/17/2005
0503142-08B	GWQ031505:1210 NP1-1-9	4621	3/15/2005	3/17/2005
0503142-08C	GWQ031505:1210 NP1-1-9	4621	3/15/2005	3/17/2005
0503142-08D	GWQ031505:1210 NP1-1-9	4621	3/15/2005	3/17/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-8100 • FAX (631) 454-8027

TAG # / COC 4621

NYSDOH 11418
CTDOH PH-0205
NJDEP NY050
PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS

LBG
126 Monroe Turnpike
Trumbull, CT 06611

CONTACT:

Mark Goldberg

SAMPLER (SIGNATURE)

Mark M. Goldberg

SAMPLE(S)
SEALED

☒ YES ☐ NO

SAMPLER NAME (PRINT)

Mark M. Goldberg

CORRECT
CONTAINER(S)

☒ YES ☐ NO

PROJECT LOCATION:

Rowe

ANALYSIS
REQUIRED

SWD
MDE
From 113
Total 113 Fe
Total 113 Mn
Turbo 113
Hand 113
TDS

FOR
METHANOL PRESERVED
SAMPLES
[VOLATILE VIAL #]

LABORATORY
ID #

MATRIX

CON-
TAINERS

SAMPLING
DATE/
TIME

SAMPLE # - LOCATION

0503142-1ABCD

L

5

3/15/05

GUARD 31505; 1100 NPH-1

✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓

2ABCD

↓

↓

↓

1110 NPH-1-2

↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓

3ABCD

↓

↓

↓

1120 NPH-1-3

↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓

4ABCD

↓

↓

↓

1130 NPH-1-5

↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓

5ABCD

↓

↓

↓

1140 NPH-1-6

↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓

6ABCD

↓

↓

↓

1150 NPH-1-7

↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓

7ABCD

↓

↓

↓

1200 NPH-1-8

↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓

8ABCD

↓

↓

↓

1210 NPH-1-9

↓ ↓ ↓ ↓ ↓ ↓ ↓ ↓

COOLER TEMPERATURE:

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIFE; P=PAINT CHIPS; B=BULK MATERIAL
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

TURNAROUND REQUIRED:

NORMAL ☒ STAT ☐ BY 1 1

COMMENTS / INSTRUCTIONS

3/17/05

RELINQUISHED BY (SIGNATURE)

Mark M. Goldberg

DATE
3/16/05
TIME
16:00

PRINTED NAME

Mark M. Goldberg

RECEIVED BY LAB (SIGNATURE)

GA

DATE
3/17/05
TIME
10:55

PRINTED NAME

P. Artonio

RELINQUISHED BY (SIGNATURE)

DATE
TIME

PRINTED NAME

RECEIVED BY LAB (SIGNATURE)

DATE
TIME

PRINTED NAME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1100 NP1-1-1
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-01A	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
2-Butanone	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
2-Hexanone	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Acetone	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Benzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Bromobenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Bromoform	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Bromomethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Chloroethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ031505:1100 NP1-1-1
 Lab Order: 0503142 Tag Number: 4621
 Project: Rowe Industries Collection Date: 3/15/2005
 Lab ID: 0503142-01A Date Received: 3/17/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	2.5	1.0		µg/L	1	3/18/2005 1:48:00 PM
Chloromethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Dibromomethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/18/2005 1:48:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Methylene chloride	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Naphthalene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
o-Xylene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Styrene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Tetrachloroethene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Toluene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Trichloroethene	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/18/2005 1:48:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/18/2005 1:48:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 2 of 40

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1100 NP1-1-1
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-01B	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0285	0.0200		mg/L	1	3/21/2005 12:36:10 PM
Manganese	0.0917	0.0200		mg/L	1	3/21/2005 12:36:10 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1100 NP1-1-1
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-01C	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	3/21/2005 12:38:31 PM
Manganese	0.0910	0.0200		mg/L	1	3/21/2005 12:38:31 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1100 NP1-1-1
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-01D	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	53.8	1.00		mg/L	1	3/21/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	3/18/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	190	1.0		mg/L	1	3/18/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1110 NP1-1-2
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-02A	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
2-Butanone	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
2-Hexanone	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Acetone	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Benzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Bromobenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Bromoform	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Bromomethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Chloroethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Page 6 of 40

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ031505:1110 NP1-1-2
 Lab Order: 0503142 Tag Number: 4621
 Project: Rowe Industries Collection Date: 3/15/2005
 Lab ID: 0503142-02A Date Received: 3/17/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Chloromethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
cis-1,2-Dichloroethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Dibromomethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/18/2005 2:24:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Methylene chloride	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Naphthalene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
o-Xylene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Styrene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Tetrachloroethene	20	1.0		µg/L	1	3/18/2005 2:24:00 PM
Toluene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Trichloroethene	1.1	1.0		µg/L	1	3/18/2005 2:24:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/18/2005 2:24:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/18/2005 2:24:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 7 of 40

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1110 NP1-1-2
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-02B	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	5.28	0.0200		mg/L	1	3/21/2005 12:41:01 PM
Manganese	1.06	0.0200		mg/L	1	3/21/2005 12:41:01 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1110 NP1-1-2
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-02C	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0816	0.0200		mg/L	1	3/21/2005 12:44:05 PM
Manganese	1.08	0.0200		mg/L	1	3/21/2005 12:44:05 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1110 NP1-1-2
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-02D	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	55.2	1.00		mg/L	1	3/21/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	3.20	1.00		NTU	1	3/18/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	110	1.0		mg/L	1	3/18/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit

- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ031505:1120 NP1-1-3

Lab Order: 0503142

Tag Number: 4621

Project: Rowe Industries

Collection Date: 3/15/2005

Lab ID: 0503142-03A

Date Received: 3/17/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B	Analyst: LDS	
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,1,1-Trichloroethane	5.0	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
2-Butanone	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
2-Hexanone	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Acetone	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Benzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Bromobenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Bromoform	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Bromomethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Chloroethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1120 NP1-1-3
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-03A	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Chloromethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Dibromomethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/18/2005 2:58:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Methylene chloride	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Naphthalene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
o-Xylene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Styrene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Tetrachloroethene	3.0	1.0		µg/L	1	3/18/2005 2:58:00 PM
Toluene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Trichloroethene	13	1.0		µg/L	1	3/18/2005 2:58:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/18/2005 2:58:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/18/2005 2:58:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.**Date:** 22-Mar-05

CLIENT:	Leggette Brashcars & Graham Inc.	Client Sample ID:	GWQ031505:1120 NP1-1-3
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-03B	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	1.89	0.0200		mg/L	1	3/21/2005 12:46:55 PM
Manganese	0.113	0.0200		mg/L	1	3/21/2005 12:46:55 PM

Qualifiers:

- Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1120 NP1-1-3
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-03C	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	1.36	0.0200		mg/L	1	3/21/2005 12:50:58 PM
Manganese	0.113	0.0200		mg/L	1	3/21/2005 12:50:58 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1120 NP1-1-3
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-03D	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	41.9	1.00		mg/L	1	3/21/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	1.40	1.00		NTU	1	3/18/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	69	1.0		mg/L	1	3/18/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ031505:1130 NP1-1-5

Lab Order: 0503142

Tag Number: 4621

Project: Rowe Industries

Collection Date: 3/15/2005

Lab ID: 0503142-04A

Date Received: 3/17/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,1,1-Trichloroethane	4.3	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
2-Butanone	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
2-Hexanone	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Acetone	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Benzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Bromobenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Bromoform	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Bromomethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Chloroethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ031505:1130 NP1-1-5

Lab Order: 0503142

Tag Number: 4621

Project: Rowe Industries

Collection Date: 3/15/2005

Lab ID: 0503142-04A

Date Received: 3/17/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Chloromethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Dibromomethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/18/2005 9:02:00 AM
Methyl tert-butyl ether	2.6	1.0		µg/L	1	3/18/2005 9:02:00 AM
Methylene chloride	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Naphthalene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
o-Xylene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Styrene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Tetrachloroethene	14	1.0		µg/L	1	3/18/2005 9:02:00 AM
Toluene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Trichloroethene	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/18/2005 9:02:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/18/2005 9:02:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 17 of 40

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1130 NP1-1-5
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-04B	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.318	0.0200		mg/L	1	3/21/2005 12:53:29 PM
Manganese	0.00877	0.0200	J	mg/L	1	3/21/2005 12:53:29 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1130 NP1-1-5
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-04C	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	3/21/2005 12:55:31 PM
Manganese	0.00819	0.0200	J	mg/L	1	3/21/2005 12:55:31 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1130 NP1-1-5
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-04D	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	34.8	1.00		mg/L	1	3/21/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	3/18/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	98	1.0		mg/L	1	3/18/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1140 NP1-1-6
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-05A	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,1,1-Trichloroethane	6.6	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
2-Butanone	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
2-Hexanone	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Acetone	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Benzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Bromobenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Bromoform	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Bromomethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Chloroethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ031505:1140 NP1-1-6
 Lab Order: 0503142 Tag Number: 4621
 Project: Rowe Industries Collection Date: 3/15/2005
 Lab ID: 0503142-05A Date Received: 3/17/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Chloromethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Dibromomethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/18/2005 8:28:00 AM
Methyl tert-butyl ether	2.7	1.0		µg/L	1	3/18/2005 8:28:00 AM
Methylene chloride	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Naphthalene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
o-Xylene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Styrene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Tetrachloroethene	120	1.0		µg/L	1	3/18/2005 8:28:00 AM
Toluene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Trichloroethene	2.3	1.0		µg/L	1	3/18/2005 8:28:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/18/2005 8:28:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/18/2005 8:28:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1140 NP1-1-6
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-05B	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0294	0.0200		mg/L	1	3/21/2005 12:58:57 PM
Manganese	0.285	0.0200		mg/L	1	3/21/2005 12:58:57 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1140 NP1-1-6
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-05C	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	3/21/2005 1:02:44 PM
Manganese	0.255	0.0200		mg/L	1	3/21/2005 1:02:44 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1140 NP1-1-6
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-05D	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	35.7	1.00		mg/L	1	3/21/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	3/18/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	88	1.0		mg/L	1	3/18/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0503142
Project: Rowe Industries
Lab ID: 0503142-06A

Client Sample ID: GWQ031505:1150 NP1-1-7
Tag Number: 4621
Collection Date: 3/15/2005
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,1,1-Trichloroethane	1.7	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
2-Butanone	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
2-Hexanone	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Acetone	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Benzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Bromobenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Bromoform	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Bromomethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Chloroethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ031505:1150 NP1-1-7

Lab Order: 0503142

Tag Number: 4621

Project: Rowe Industries

Collection Date: 3/15/2005

Lab ID: 0503142-06A

Date Received: 3/17/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Chloromethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Dibromomethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/18/2005 7:54:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Methylene chloride	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Naphthalene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
o-Xylene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Styrene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Tetrachloroethene	42	1.0		µg/L	1	3/18/2005 7:54:00 AM
Toluene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Trichloroethene	1.5	1.0		µg/L	1	3/18/2005 7:54:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/18/2005 7:54:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/18/2005 7:54:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1150 NP1-1-7
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-06B	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst JP
Iron	0.0356	0.0200		mg/L	1	3/21/2005 1:18:03 PM
Manganese	0.0490	0.0200		mg/L	1	3/21/2005 1:18:03 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1150 NP1-1-7
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-06C	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	3/21/2005 1:20:08 PM
Manganese	0.0475	0.0200		mg/L	1	3/21/2005 1:20:08 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1150 NP1-1-7
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-06D	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	29.4	1.00		mg/L	1	3/21/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00		NTU	1	3/18/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	67	1.0		mg/L	1	3/18/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
E Value above quantitation range	H Holding times for preparation or analysis exceeded	ND Not Detected at the Reporting Limit
J Analyte detected below quantitation limits	U Indicates the compound was analyzed for but not detected	
S Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ031505:1200 NP1-1-8
 Lab Order: 0503142 Tag Number: 4621
 Project: Rowe Industries Collection Date: 3/15/2005
 Lab ID: 0503142-07A Date Received: 3/17/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,1,1-Trichloroethane	4.2	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
2-Butanone	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
2-Hexanone	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Acetone	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Benzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Bromobenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Bromoform	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Bromomethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Chloroethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit

U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ031505:1200 NP1-1-8
Lab Order: 0503142 **Tag Number:** 4621
Project: Rowe Industries **Collection Date:** 3/15/2005
Lab ID: 0503142-07A **Date Received:** 3/17/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Chloromethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Dibromomethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/18/2005 7:19:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Methylene chloride	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Naphthalene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
o-Xylene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Styrene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Tetrachloroethene	9.0	1.0		µg/L	1	3/18/2005 7:19:00 AM
Toluene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Trichloroethene	1.3	1.0		µg/L	1	3/18/2005 7:19:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/18/2005 7:19:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/18/2005 7:19:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1200 NP1-1-8
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-07B	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	7.54	0.0200		mg/L	1	3/21/2005 1:22:14 PM
Manganese	0.679	0.0200		mg/L	1	3/21/2005 1:22:14 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1200 NP1-1-8
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-07C	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0754	0.0200		mg/L	1	3/21/2005 1:24:48 PM
Manganese	0.659	0.0200		mg/L	1	3/21/2005 1:24:48 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1200 NP1-1-8
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-07D	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	24.6	1.00		mg/L	1	3/21/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	5.10	1.00		NTU	1	3/18/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	51	1.0		mg/L	1	3/18/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1210 NP1-1-9
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-08A	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,1,1-Trichloroethane	5.9	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
2-Butanone	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
2-Hexanone	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Acetone	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Benzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Bromobenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Bromochloromethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Bromodichloromethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Bromoform	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Bromomethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Carbon disulfide	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Chlorobenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Chloroethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1210 NP1-1-9
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-08A	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Chloromethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Dibromochloromethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Dibromomethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Ethylbenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Isopropylbenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
m,p-Xylene	U	2.0		µg/L	1	3/18/2005 5:06:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Methylene chloride	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Naphthalene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
n-Butylbenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
n-Propylbenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
o-Xylene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Styrene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Tetrachloroethene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Toluene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Trichloroethene	1.4	1.0		µg/L	1	3/18/2005 5:06:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Vinyl acetate	U	1.0		µg/L	1	3/18/2005 5:06:00 AM
Vinyl chloride	U	1.0		µg/L	1	3/18/2005 5:06:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1210 NP1-1-9
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-08B	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst JP
Iron	1.55	0.0200		mg/L	1	3/21/2005 1:27:05 PM
Manganese	1.06	0.0200		mg/L	1	3/21/2005 1:27:05 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1210 NP1-1-9
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-08C	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.507	0.0200		mg/L	1	3/21/2005 1:29:11 PM
Manganese	1.06	0.0200		mg/L	1	3/21/2005 1:29:11 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ031505:1210 NP1-1-9
Lab Order:	0503142	Tag Number:	4621
Project:	Rowe Industries	Collection Date:	3/15/2005
Lab ID:	0503142-08D	Date Received:	3/17/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	25.2	1.00		mg/L	1	3/21/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	5.60	1.00		NTU	1	3/18/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	45	1.0		mg/L	1	3/18/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Wednesday, March 23, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0503165

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/18/2005 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0503165

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0503165-01A	WQ031705:1000 NP2-6	4617	3/17/2005	3/18/2005
0503165-01B	WQ031705:1000 NP2-6	4617	3/17/2005	3/18/2005
0503165-01C	WQ031705:1000 NP2-6	4617	3/17/2005	3/18/2005
0503165-02A	WQ031705:1005 NP2-7	4617	3/17/2005	3/18/2005
0503165-02B	WQ031705:1005 NP2-7	4617	3/17/2005	3/18/2005
0503165-02C	WQ031705:1005 NP2-7	4617	3/17/2005	3/18/2005
0503165-03A	WQ031705:1010 NP2-10	4617	3/17/2005	3/18/2005
0503165-03B	WQ031705:1010 NP2-10	4617	3/17/2005	3/18/2005
0503165-03C	WQ031705:1010 NP2-10	4617	3/17/2005	3/18/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC 4617

NYSDOH 11418
CTDOH PH-0205
NJDEP NY050
PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS

LBG, Inc
126 Monroe Turnpike
Trombull, CT

CONTACT:

M. Goldberg
P. Jabmann
203-452-3100

SAMPLER (SIGNATURE)

Steve Silvestri

SAMPLE(S)
SEALED

YES / NO

SAMPLER NAME (PRINT)

Steve Silvestri

CORRECT
CONTAINER(S)

YES / NO

PROJECT LOCATION: Rowe

LABORATORY ID #	MATRIX	# CON- TAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION
--------------------	--------	-------------------	---------------------------	---------------------

0503165-ABC	L	4	3/13/05 1000	WQ0317051000NPL-6
2ABC	L	4	↓ 1005	WQ0317051005NPL-7
3ABC	↓	5	↓ 1010	WQ0317051010NPL-10

ANALYSIS
REQUIRED

8260
MTBE
Freon 113
Total Fe
Diss. Fe
TDS

FOR
METHANOL PRESERVED
SAMPLES
[VOLATILE VIAL #]

COOLER TEMPERATURE:

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

TURNAROUND REQUIRED:

NORMAL ☒ STAT ☐ BY / /

COMMENTS / INSTRUCTIONS

RELINQUISHED BY (SIGNATURE)

Steve Silvestri

DATE

3/13/05
TIME 1400

PRINTED NAME

Steve Silvestri

RECEIVED BY LAB (SIGNATURE)

10/1

DATE

3/18/05
TIME 1135

PRINTED NAME

P. Ardonio

RELINQUISHED BY (SIGNATURE)

DATE

TIME

PRINTED NAME

RECEIVED BY LAB (SIGNATURE)

DATE

TIME

PRINTED NAME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0503165
Project: Rowe Industries
Lab ID: 0503165-01A

Client Sample ID: WQ031705:1000 NP2-6
Tag Number: 4617
Collection Date: 3/17/2005
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B		Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,1,1-Trichloroethane	3.9	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
2-Butanone	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
2-Hexanone	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Acetone	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Benzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Bromobenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Bromoform	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Bromomethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Chloroethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit

U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ031705:1000 NP2-6
 Lab Order: 0503165 Tag Number: 4617
 Project: Rowe Industries Collection Date: 3/17/2005
 Lab ID: 0503165-01A Date Received: 3/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Chloromethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Dibromomethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/19/2005 2:37:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Methylene chloride	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Naphthalene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
o-Xylene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Styrene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Tetrachloroethene	32	1.0		µg/L	1	3/19/2005 2:37:00 PM
Toluene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Trichloroethene	1.6	1.0		µg/L	1	3/19/2005 2:37:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/19/2005 2:37:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/19/2005 2:37:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031705:1000 NP2-6
Lab Order:	0503165	Tag Number:	4617
Project:	Rowe Industries	Collection Date:	3/17/2005
Lab ID:	0503165-01B	Date Received:	3/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	2.09	0.0200		mg/L	1	3/21/2005 11:55:55 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031705:1000 NP2-6
Lab Order:	0503165	Tag Number:	4617
Project:	Rowe Industries	Collection Date:	3/17/2005
Lab ID:	0503165-01C	Date Received:	3/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.213	0.0200		mg/L	1	3/21/2005 11:53:37 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ031705:1005 NP2-7
 Lab Order: 0503165 Tag Number: 4617
 Project: Rowe Industries Collection Date: 3/17/2005
 Lab ID: 0503165-02A Date Received: 3/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B	Analyst: LDS	
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
2-Butanone	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
2-Hexanone	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Acetone	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Benzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Bromobenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Bromoform	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Bromomethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Chloroethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ031705:1005 NP2-7
 Lab Order: 0503165 Tag Number: 4617
 Project: Rowe Industries Collection Date: 3/17/2005
 Lab ID: 0503165-02A Date Received: 3/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Chloromethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Dibromomethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/19/2005 3:08:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Methylene chloride	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Naphthalene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
o-Xylene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Styrene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Tetrachloroethene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Toluene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Trichloroethene	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/19/2005 3:08:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/19/2005 3:08:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.**Date:** 23-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031705:1005 NP2-7
Lab Order:	0503165	Tag Number:	4617
Project:	Rowe Industries	Collection Date:	3/17/2005
Lab ID:	0503165-02B	Date Received:	3/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	1.11	0.0200		mg/L	1	3/21/2005 12:00:49 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031705:1005 NP2-7
Lab Order:	0503165	Tag Number:	4617
Project:	Rowe Industries	Collection Date:	3/17/2005
Lab ID:	0503165-02C	Date Received:	3/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.137	0.0200		mg/L	1	3/21/2005 11:58:31 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ031705:1010 NP2-10

Lab Order: 0503165

Tag Number: 4617

Project: Rowe Industries

Collection Date: 3/17/2005

Lab ID: 0503165-03A

Date Received: 3/18/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
2-Butanone	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
2-Hexanone	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Acetone	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Benzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Bromobenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Bromoform	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Bromomethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Chloroethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 9 of 12

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ031705:1010 NP2-10
 Lab Order: 0503165 Tag Number: 4617
 Project: Rowe Industries Collection Date: 3/17/2005
 Lab ID: 0503165-03A Date Received: 3/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Chloromethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Dibromomethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/19/2005 3:40:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Methylene chloride	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Naphthalene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
o-Xylene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Styrene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Tetrachloroethene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Toluene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Trichloroethene	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/19/2005 3:40:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/19/2005 3:40:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031705:1010 NP2-10
Lab Order:	0503165	Tag Number:	4617
Project:	Rowe Industries	Collection Date:	3/17/2005
Lab ID:	0503165-03B	Date Received:	3/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	1.16	0.0200		mg/L	1	3/21/2005 12:05:48 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 23-Mar-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ031705:1010 NP2-10
Lab Order:	0503165	Tag Number:	4617
Project:	Rowe Industries	Collection Date:	3/17/2005
Lab ID:	0503165-03C	Date Received:	3/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.158	0.0200		mg/L	1	3/21/2005 12:02:59 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	100	1.0		mg/L	1	3/21/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Monday, April 04, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0503224

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/29/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director



American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0503224**Work Order Sample Summary**



Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0503224-01A	WQ032405:1000 NP2-6	4613	3/24/2005	3/29/2005
0503224-01B	WQ032405:1000 NP2-6	4613	3/24/2005	3/29/2005
0503224-01C	WQ032405:1000 NP2-6	4613	3/24/2005	3/29/2005
0503224-02A	WQ032405:1005 NP2-7	4613	3/24/2005	3/29/2005
0503224-02B	WQ032405:1005 NP2-7	4613	3/24/2005	3/29/2005
0503224-02C	WQ032405:1005 NP2-7	4613	3/24/2005	3/29/2005
0503224-03A	WQ032405:1010 NP2-10	4613	3/24/2005	3/29/2005
0503224-03B	WQ032405:1010 NP2-10	4613	3/24/2005	3/29/2005
0503224-03C	WQ032405:1010 NP2-10	4613	3/24/2005	3/29/2005

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBG 126 Monroe Tpk Trumbull, CT	CONTACT: M. Goldberg	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED ☒ YES ☐ NO
		SAMPLER NAME (PRINT) Steve Silvestri	CORRECT CONTAINER(S) ☒ YES ☐ NO

PROJECT LOCATION:	Rowe	ANALYSIS REQUIRED	113	FOR
-------------------	------	-------------------	-----	-----

[illegible]

				COOLER TEMPERATURE:	
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON		TURNAROUND REQUIRED: NORMAL ☒ STAT ☐ BY / /		COMMENTS / INSTRUCTIONS 3/29/05	
RELINQUISHED BY (SIGNATURE) 	DATE 3/24/05 TIME 12:00	PRINTED NAME Steve Silvestri	RECEIVED BY LAB (SIGNATURE) 	DATE 3/29/05 TIME 10:15	PRINTED NAME P. Artonio
RELINQUISHED BY (SIGNATURE) 	DATE 3/28/05 TIME 16:00	PRINTED NAME Mark M. Goldberg	RECEIVED BY LAB (SIGNATURE) (Empty)	DATE (Empty) TIME (Empty)	PRINTED NAME (Empty)

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT: Leggette Brashears & Graham Inc.

Project: Rowe Industries

Lab Order: 0503224

CASE NARRATIVE

Samples were analyzed using the methods outlined in the following references:

Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW846, 3rd Edition

All method blanks, laboratory spikes, and/or matrix spikes met quality assurance objectives.

Methylene Chloride is a common laboratory contaminant and although this compound was not detected in the method blank applicable to sample analysis, the levels reported in samples WQ032405:1005 NP2-7 and WQ032405:1010 NP2-10 are comparable to lab contamination levels.

Lori Beyer
LABORATORY DIRECTOR

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ032405:1000 NP2-6
Lab Order: 0503224 **Tag Number:** 4613
Project: Rowe Industries **Collection Date:** 3/24/2005
Lab ID: 0503224-01A **Date Received:** 3/29/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,1,1-Trichloroethane	2.9	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
2-Butanone	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
2-Hexanone	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Acetone	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Benzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Bromobenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Bromoform	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Bromomethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Chloroethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM

Qualifiers:
 * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ032405:1000 NP2-6
 Lab Order: 0503224 Tag Number: 4613
 Project: Rowe Industries Collection Date: 3/24/2005
 Lab ID: 0503224-01A Date Received: 3/29/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Chloromethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Dibromomethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/29/2005 4:48:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Methylene chloride	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Naphthalene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
o-Xylene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Styrene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Tetrachloroethene	22	1.0		µg/L	1	3/29/2005 4:48:00 PM
Toluene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Trichloroethene	1.3	1.0		µg/L	1	3/29/2005 4:48:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/29/2005 4:48:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/29/2005 4:48:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 2 of 12

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ032405:1000 NP2-6
Lab Order:	0503224.	Tag Number:	4613
Project:	Rowe Industries	Collection Date:	3/24/2005
Lab ID:	0503224-01B	Date Received:	3/29/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	0.866	0.0200		mg/L	1	3/31/2005 2:53:49 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ032405:1000 NP2-6
Lab Order:	0503224	Tag Number:	4613
Project:	Rowe Industries	Collection Date:	3/24/2005
Lab ID:	0503224-01C	Date Received:	3/29/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0779	0.0200		mg/L	1	3/31/2005 2:51:04 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0503224
Project: Rowe Industries
Lab ID: 0503224-02A

Client Sample ID: WQ032405:1005 NP2-7
Tag Number: 4613
Collection Date: 3/24/2005
Matrix: LIQUID

Date Received: 3/29/2005

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8280B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
2-Butanone	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
2-Hexanone	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Acetone	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Benzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Bromobenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Bromoform	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Bromomethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Chloroethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ032405:1005 NP2-7

Lab Order: 0503224

Tag Number: 4613

Project: Rowe Industries

Collection Date: 3/24/2005

Lab ID: 0503224-02A

Date Received: 3/29/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Chloromethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Dibromomethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/29/2005 6:36:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Methylene chloride	2.8	1.0		µg/L	1	3/29/2005 6:36:00 PM
Naphthalene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
o-Xylene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Styrene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Tetrachloroethene	1.5	1.0		µg/L	1	3/29/2005 6:36:00 PM
Toluene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Trichloroethene	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/29/2005 6:36:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/29/2005 6:36:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ032405:1005 NP2-7
Lab Order:	0503224	Tag Number:	4613
Project:	Rowe Industries	Collection Date:	3/24/2005
Lab ID:	0503224-02B	Date Received:	3/29/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	0.520	0.0200		mg/L	1	3/31/2005 2:58:33 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ032405:1005 NP2-7
Lab Order:	0503224	Tag Number:	4613
Project:	Rowe Industries	Collection Date:	3/24/2005
Lab ID:	0503224-02C	Date Received:	3/29/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0922	0.0200		mg/L	1	3/31/2005 2:55:57 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ032405:1010 NP2-10
 Lab Order: 0503224 Tag Number: 4613
 Project: Rowe Industries Collection Date: 3/24/2005
 Lab ID: 0503224-03A Date Received: 3/29/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
2-Butanone	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
2-Hexanone	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Acetone	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Benzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Bromobenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Bromoform	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Bromomethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Chloroethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ032405:1010 NP2-10
Lab Order:	0503224	Tag Number:	4613
Project:	Rowe Industries	Collection Date:	3/24/2005
Lab ID:	0503224-03A	Date Received:	3/29/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Chloromethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Dibromomethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/29/2005 7:12:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Methylene chloride	2.2	1.0		µg/L	1	3/29/2005 7:12:00 PM
Naphthalene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
o-Xylene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Styrene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Tetrachloroethene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Toluene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Trichloroethene	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/29/2005 7:12:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/29/2005 7:12:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Apr-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ032405:1010 NP2-10

Lab Order: 0503224

Tag Number: 4613

Project: Rowe Industries

Collection Date: 3/24/2005

Lab ID: 0503224-03B

Date Received: 3/29/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	0.0670	0.0200		mg/L	1	4/11/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Apr-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ032405:1010 NP2-10

Lab Order: 0503224

Tag Number: 4613

Project: Rowe Industries

Collection Date: 3/24/2005

Lab ID: 0503224-03C

Date Received: 3/29/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0640	0.0200		mg/L	1	4/11/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	70	1.0		mg/L	1	3/30/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Thursday, April 07, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0504005

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 4/1/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0504005**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0504005-01A	WQ033005:0910 NP2-6	4634	3/30/2005	4/1/2005
0504005-01B	WQ033005:0910 NP2-6	4634	3/30/2005	4/1/2005
0504005-01C	WQ033005:0910 NP2-6	4634	3/30/2005	4/1/2005
0504005-02A	WQ033005:0912 NP2-7	4634	3/30/2005	4/1/2005
0504005-02B	WQ033005:0912 NP2-7	4634	3/30/2005	4/1/2005
0504005-02C	WQ033005:0912 NP2-7	4634	3/30/2005	4/1/2005
0504005-03A	WQ033005:0915 NP2-10	4634	3/30/2005	4/1/2005
0504005-03B	WQ033005:0915 NP2-10	4634	3/30/2005	4/1/2005
0504005-03C	WQ033005:0915 NP2-10	4634	3/30/2005	4/1/2005

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT: Leggett Brashears & Graham Inc. Client Sample ID: WQ033005:0910 NP2-6
 Lab Order: 0504005 Tag Number: 4634
 Project: Rowe Industries Collection Date: 3/30/2005
 Lab ID: 0504005-01A Date Received: 4/1/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,1,1-Trichloroethane	2.8	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
2-Butanone	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
2-Hexanone	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Acetone	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Benzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Bromobenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Bromochloromethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Bromodichloromethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Bromoform	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Bromomethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Carbon disulfide	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Chlorobenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Chloroethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ033005:0910 NP2-6
Lab Order: 0504005 **Tag Number:** 4634
Project: Rowe Industries **Collection Date:** 3/30/2005
Lab ID: 0504005-01A **Date Received:** 4/1/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Chloromethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Dibromomethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/2/2005 2:25:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Methylene chloride	U	1.0	B	µg/L	1	4/2/2005 2:25:00 AM
Naphthalene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
o-Xylene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Styrene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Tetrachloroethene	29	1.0		µg/L	1	4/2/2005 2:25:00 AM
Toluene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Trichloroethene	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/2/2005 2:25:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/2/2005 2:25:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ033005:0910 NP2-6
Lab Order:	0504005	Tag Number:	4634
Project:	Rowe Industries	Collection Date:	3/30/2005
Lab ID:	0504005-01B	Date Received:	4/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	2.26	0.0200		mg/L	1	4/5/2005 12:13:13 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ033005:0910 NP2-6
Lab Order:	0504005	Tag Number:	4634
Project:	Rowe Industries	Collection Date:	3/30/2005
Lab ID:	0504005-01C	Date Received:	4/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0600	0.0200		mg/L	1	4/5/2005 12:10:57 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ033005:0912 NP2-7

Lab Order: 0504005

Tag Number: 4634

Project: Rowe Industries

Collection Date: 3/30/2005

Lab ID: 0504005-02A

Date Received: 4/1/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
2-Butanone	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
2-Hexanone	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Acetone	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Benzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Bromobenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Bromochloromethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Bromodichloromethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Bromoform	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Bromomethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Carbon disulfide	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Chlorobenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Chloroethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ033005:0912 NP2-7
Lab Order:	0504005	Tag Number:	4634
Project:	Rowe Industries	Collection Date:	3/30/2005
Lab ID:	0504005-02A	Date Received:	4/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Chloromethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Dibromomethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/2/2005 3:03:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Methylene chloride	U	1.0	B	µg/L	1	4/2/2005 3:03:00 AM
Naphthalene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
o-Xylene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Styrene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Tetrachloroethene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Toluene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Trichloroethene	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/2/2005 3:03:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/2/2005 3:03:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ033005:0912 NP2-7
Lab Order:	0504005	Tag Number:	4634
Project:	Rowe Industries	Collection Date:	3/30/2005
Lab ID:	0504005-02B	Date Received:	4/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	0.908	0.0200		mg/L	1	4/5/2005 12:31:43 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ033005:0912 NP2-7
Lab Order:	0504005	Tag Number:	4634
Project:	Rowe Industries	Collection Date:	3/30/2005
Lab ID:	0504005-02B	Date Received:	4/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	0.908	0.0200		mg/L	1	4/5/2005 12:31:43 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ033005:0912 NP2-7
Lab Order:	0504005	Tag Number:	4634
Project:	Rowe Industries	Collection Date:	3/30/2005
Lab ID:	0504005-02C	Date Received:	4/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0223	0.0200		mg/L	1	4/5/2005 12:17:17 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ033005:0915 NP2-10
Lab Order:	0504005	Tag Number:	4634
Project:	Rowe Industries	Collection Date:	3/30/2005
Lab ID:	0504005-03A	Date Received:	4/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
2-Butanone	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
2-Hexanone	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Acetone	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Benzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Bromobenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Bromochloromethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Bromodichloromethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Bromoform	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Bromomethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Carbon disulfide	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Chlorobenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Chloroethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

Page 9 of 12

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ033005:0915 NP2-10
Lab Order: 0504005 **Tag Number:** 4634
Project: Rowe Industries **Collection Date:** 3/30/2005
Lab ID: 0504005-03A **Date Received:** 4/1/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Chloromethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Dibromomethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/2/2005 3:35:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Methylene chloride	U	1.0	B	µg/L	1	4/2/2005 3:35:00 AM
Naphthalene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
o-Xylene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Styrene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Tetrachloroethene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Toluene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Trichloroethene	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/2/2005 3:35:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/2/2005 3:35:00 AM

Qualifiers:
 * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ033005:0915 NP2-10
Lab Order:	0504005	Tag Number:	4634
Project:	Rowe Industries	Collection Date:	3/30/2005
Lab ID:	0504005-03B	Date Received:	4/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	0.594	0.0200		mg/L	1	4/5/2005 12:39:08 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Apr-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ033005:0915 NP2-10
Lab Order:	0504005	Tag Number:	4634
Project:	Rowe Industries	Collection Date:	3/30/2005
Lab ID:	0504005-03C	Date Received:	4/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0216	0.0200		mg/L	1	4/5/2005 12:36:10 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	81	1.0		mg/L	1	4/6/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- B Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

ANALYTICAL REPORT

JOB NUMBER: 208913


Prepared For:

LEGGETTE, BRASHEARS & GRAHAM
126 Monroe Turnpike
Trumbull, CT 06611

Project: ROWE INDUSTRIES

Attention: Mark Goldberg

Date: 03/15/2005




Signature

Name: William D. Goodman

Title: Project Manager

E-Mail: wgoodman@stl-inc.com



Date

STL Connecticut
128 Long Hill Cross Road
Shelton, CT 06484

STL Report : 208913
LEGGETTE, BRASHEARS, & GRAHAM

Case Narrative

Sample Receipt – All samples were received in good condition.

Volatile Organics – Air volatile organics were determined by purge and trap GC/MS using guidance provided in Method TO-17. The instrumentation used was a Perkin Elmer ATD 50 interfaced with a Hewlett-Packard Model 5972A GC/MS/DS.

Sample Calculation:

Sample ID- AQ030205:1105NP4-1
Compound-Bromomethane

$$\frac{(146627)(25)}{(475848)(.233)} = 33.05 = 33 \text{ ng}$$

$$\frac{(33\text{NG})(.08206)(298)}{(.4\text{L})(95)(1.0\text{ATM})} = 21.23 = 21.2 \text{ nL/L.}$$

Sample AQ030205:1105NP4-1 was analyzed at a sample volume of .4L for high targets.

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in the case narrative.

STL Connecticut		Form 1		
		Client Sample ID	1105NP4-1	
Method: T017		Lab Sample ID	208913-1	
Sample Volume (L)	0.400	Date Sampled	3/2/2005	
Temp (C)	25	Date Analyzed	3/8/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	24.2 U	24.2	0.0500 U	0.050
Vinyl Chloride	19.6 U	19.6	0.0500 U	0.050
Bromomethane	21.2 B	12.9	0.0825 B	0.050
Chloroethane	19.0 U	19.0	0.0500 U	0.050
1,1-Dichloroethene	6.3 U	6.3	0.0250 U	0.025
Carbon Disulfide	8.0 U	8.0	0.0250 U	0.025
Methylene Chloride	4.3 J	7.2	0.0150 J	0.025
trans-1,2-Dichloroethene	6.4 U	6.4	0.0250 U	0.025
1,1-Dichloroethane	6.2 U	6.2	0.0250 U	0.025
cis-1,2-Dichloroethene	6.4 U	6.4	0.0250 U	0.025
Chloroform	1.0 J	5.1	0.0050 J	0.025
1,1,1-Trichloroethane	13.3	4.6	0.0725	0.025
Carbon Tetrachloride	4.0 U	4.0	0.0250 U	0.025
Benzene	1.6 JB	7.8	0.0050 JB	0.025
1,2-Dichloroethane	6.2 U	6.2	0.0250 U	0.025
Trichloroethene	6.1	4.7	0.0325	0.025
1,2-Dichloropropane	5.4 U	5.4	0.0250 U	0.025
Bromodichloromethane	3.7 U	3.7	0.0250 U	0.025
cis-1,3-Dichloropropene	5.5 U	5.5	0.0250 U	0.025
Toluene	4.6 J	6.6	0.0175 J	0.025
trans-1,3-Dichloropropene	5.5 U	5.5	0.0250 U	0.025
1,1,2-Trichloroethane	4.6 U	4.6	0.0250 U	0.025
Tetrachloroethene	51.6	3.7	0.3500	0.025
Dibromochloromethane	2.9 U	2.9	0.0250 U	0.025
Chlorobenzene	5.4 U	5.4	0.0250 U	0.025
Ethylbenzene	5.8 U	5.8	0.0250 U	0.025
m&p-Xylenes	5.8 U	5.8	0.0250 U	0.025
o-Xylene	5.8 U	5.8	0.0250 U	0.025
Styrene	5.9 U	5.9	0.0250 U	0.025
Bromoform	2.4 U	2.4	0.0250 U	0.025
1,1,2,2-Tetrachloroethane	3.6 U	3.6	0.0250 U	0.025

STL Connecticut		Form 1		Client Sample ID		1110NP4-2	
Method: T017				Lab Sample ID		208913-2	
Sample Volume (L)		1.000		Date Sampled		3/2/2005	
Temp (C)		25		Date Analyzed		3/8/2005	
Compound	nL/L (ppbv/v)	Qualifier	RL	mg/M3	Qualifier	RL	
Chloromethane	9.7 U		9.7	0.0200	U	0.020	
Vinyl Chloride	7.8 U		7.8	0.0200	U	0.020	
Bromomethane	5.4 B		5.1	0.0210	B	0.020	
Chloroethane	7.6 U		7.6	0.0200	U	0.020	
1,1-Dichloroethene	2.3 J		2.5	0.0090	J	0.010	
Carbon Disulfide	2.6 J		3.2	0.0080	J	0.010	
Methylene Chloride	2.9		2.9	0.0100		0.010	
trans-1,2-Dichloroethene	2.5 U		2.5	0.0100	U	0.010	
1,1-Dichloroethane	5.4		2.5	0.0220		0.010	
cis-1,2-Dichloroethene	1.0 J		2.5	0.0040	J	0.010	
Chloroform	2.3		2.1	0.0110		0.010	
1,1,1-Trichloroethane	25.7		1.8	0.1400		0.010	
Carbon Tetrachloride	1.6 U		1.6	0.0100	U	0.010	
Benzene	0.6 JB		3.1	0.0020	JB	0.010	
1,2-Dichloroethane	2.5 U		2.5	0.0100	U	0.010	
Trichloroethene	1.9 U		1.9	0.0100	U	0.010	
1,2-Dichloropropane	2.2 U		2.2	0.0100	U	0.010	
Bromodichloromethane	1.5 U		1.5	0.0100	U	0.010	
cis-1,3-Dichloropropene	2.2 U		2.2	0.0100	U	0.010	
Toluene	4.2		2.7	0.0160		0.010	
trans-1,3-Dichloropropene	2.2 U		2.2	0.0100	U	0.010	
1,1,2-Trichloroethane	1.8 U		1.8	0.0100	U	0.010	
Tetrachloroethene	1.5 U		1.5	0.0100	U	0.010	
Dibromochloromethane	1.2 U		1.2	0.0100	U	0.010	
Chlorobenzene	2.2 U		2.2	0.0100	U	0.010	
Ethylbenzene	2.3 U		2.3	0.0100	U	0.010	
m&p-Xylenes	0.5 J		2.3	0.0020	J	0.010	
o-Xylene	2.3 U		2.3	0.0100	U	0.010	
Styrene	2.4 U		2.4	0.0100	U	0.010	
Bromoform	1.0 U		1.0	0.0100	U	0.010	
1,1,2,2-Tetrachloroethane	1.5 U		1.5	0.0100	U	0.010	

STL Connecticut		Form 1		Client Sample ID		1115NP4-3	
Method: T017		Lab Sample ID		208913-3			
Sample Volume (L)		1.000		Date Sampled		3/2/2005	
Temp (C)		25		Date Analyzed		3/8/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL			
Chloromethane	9.7 U	9.7	0.0200 U	0.020			
Vinyl Chloride	7.8 U	7.8	0.0200 U	0.020			
Bromomethane	1.8 JB	5.1	0.0070 JB	0.020			
Chloroethane	7.6 U	7.6	0.0200 U	0.020			
1,1-Dichloroethene	2.3 J	2.5	0.0090 J	0.010			
Carbon Disulfide	2.9 J	3.2	0.0090 J	0.010			
Methylene Chloride	2.3 J	2.9	0.0080 J	0.010			
trans-1,2-Dichloroethene	2.5 U	2.5	0.0100 U	0.010			
1,1-Dichloroethane	7.7	2.5	0.0310	0.010			
cis-1,2-Dichloroethene	2.5 U	2.5	0.0100 U	0.010			
Chloroform	2.5	2.1	0.0120	0.010			
1,1,1-Trichloroethane	4.2	1.8	0.0230	0.010			
Carbon Tetrachloride	1.6 U	1.6	0.0100 U	0.010			
Benzene	0.6 JB	3.1	0.0020 JB	0.010			
1,2-Dichloroethane	2.5 U	2.5	0.0100 U	0.010			
Trichloroethene	1.9 U	1.9	0.0100 U	0.010			
1,2-Dichloropropane	2.2 U	2.2	0.0100 U	0.010			
Bromodichloromethane	1.5 U	1.5	0.0100 U	0.010			
cis-1,3-Dichloropropene	2.2 U	2.2	0.0100 U	0.010			
Toluene	4.2	2.7	0.0160	0.010			
trans-1,3-Dichloropropene	2.2 U	2.2	0.0100 U	0.010			
1,1,2-Trichloroethane	1.8 U	1.8	0.0100 U	0.010			
Tetrachloroethene	1.5 U	1.5	0.0100 U	0.010			
Dibromochloromethane	1.2 U	1.2	0.0100 U	0.010			
Chlorobenzene	2.2 U	2.2	0.0100 U	0.010			
Ethylbenzene	2.3 U	2.3	0.0100 U	0.010			
m&p-Xylenes	0.5 J	2.3	0.0020 J	0.010			
o-Xylene	2.3 U	2.3	0.0100 U	0.010			
Styrene	0.2 J	2.4	0.0010 J	0.010			
Bromoform	1.0 U	1.0	0.0100 U	0.010			
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.0100 U	0.010			

LABORATORY CHRONICLE

Job Number: 208913

Date: 03/15/2005

CUSTOMER: LEGGETTE, BRASHEARS & GRAHAM

PROJECT: ROWE INDUSTRIES

ATTN: Mark Goldberg

Lab ID: 208913-1	Client ID: AQ030205:1105NP4-1	Date Recvd: 03/03/2005	Sample Date: 03/02/2005		
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)
T017	Volatile Organics (Air)	1	45842		
				DATE/TIME ANALYZED	DILUTION
				03/08/2005 1101	1.00000
Lab ID: 208913-2	Client ID: AQ030205:1110NP4-2	Date Recvd: 03/03/2005	Sample Date: 03/02/2005		
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)
T017	Volatile Organics (Air)	1	45842		
				DATE/TIME ANALYZED	DILUTION
				03/08/2005 1014	1.00000
Lab ID: 208913-3	Client ID: AQ030205:1115NP4-3	Date Recvd: 03/03/2005	Sample Date: 03/02/2005		
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)
T017	Volatile Organics (Air)	1	45842		
				DATE/TIME ANALYZED	DILUTION
				03/08/2005 0926	1.00000

AR

2A

~~WATER~~ VOLATILE SYSTEM MONITORING COMPOUND RECOVERY

Lab Name: STL-CT

Contract:

Lab Code: STL-CT

Case No.: 208913 SAS No.:

SDG No.: 208913

	EPA SAMPLE NO.	SMC1 #	SMC2 (DCE) #	SMC3 (TOL) #	OTHER (BFB) #	TOT OUT
01	VBLKTG	111	113	111	106	
02	LCS 20PPB	105	111	107	103	
03	1105NP4-3	110	111	107	102	
04	1110NP4-2	112	113	109	107	
05	1115NP4-1	113	113	110	107	
06						
07						
08						
09						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

SMC1 = Dibromofluoromethane
 SMC2 (DCE) = 1,2-Dichloroethane-d4
 SMC3 (TOL) = Toluene-d8
 OTHER (BFB) = Bromofluorobenzene

QC LIMITS
 (70-130)
 (70-130)
 (70-130)
 (70-130)

Column to be used to flag recovery values

* Values outside of contract required QC limits

D System Monitoring Compound diluted out

Data File: \\TARGET1 CT\\Files\\chem\\VOA\\mst.i\\T054407.b\\T4411.D Page 3
 Report Date: 09-Mar-2005 18:07

STL-CT

RECOVERY REPORT

Client Name: Client SDG: SDGa24843
 Sample Matrix: LIQUID Fraction: VOA
 Lab Smp Id: LCS_20ppb Client Smp ID: LCS_20ppb
 Level: LOW Operator: M.Crowe
 Data Type: MS DATA SampleType: LCS
 SpikeList File: AIRQCS.spk Quant Type: ISTD
 Sublist File: all.sub
 Method File: \\TARGET1 CT\\Files\\chem\\VOA\\mst.i\\T054407.b\\TAIRFULL.m
 Misc Info: : LCS;;; 020_ppbQCS ; TO-17 ; * 1 L* ; AIR

SPIKE COMPOUND	CONC ADDED ug/L	CONC RECOVERED ug/L	% RECOVERED	LIMITS
4 Vinyl Chloride	20	12	62.03	60-140
5 Bromomethane	20	16	79.26	60-140
6 Chloroethane	20	15	74.96	60-140
12 1,1-Dichloroethene	20	16	82.30	60-140
11 Trichlorotrifluoro	20	16	81.73	60-140
17 Acetone	20	24	120.57	60-140
13 Carbon Disulfide	20	15	73.00	60-140
16 Methylene Chloride	20	26	129.36	60-140
18 trans-1,2-Dichloro	20	18	89.42	60-140
28 1,1-Dichloroethane	20	18	89.34	60-140
30 cis-1,2-Dichloroet	20	18	88.05	60-140
40 2-Butanone	20	20	101.06	60-140
33 Chloroform	20	19	95.74	60-140
38 1,1,1-Trichloroeth	20	21	104.82	60-140
39 Carbon Tetrachlori	20	24	119.18	60-140
51 1,2-Dichloroethane	20	21	103.04	60-140
48 Benzene	20	20	98.15	60-140
56 Trichloroethene	20	21	103.43	60-140
63 cis-1,3-Dichloropr	20	18	92.16	60-140
72 4-Methyl-2-Pentano	20	14	71.48	60-140
69 Toluene	20	19	96.96	60-140
66 trans-1,3-Dichloro	20	16	78.02	60-140
67 1,1,2-Trichloroeth	20	20	98.60	60-140
73 Tetrachloroethene	20	20	102.14	60-140
75 Dibromochlorometha	20	19	96.20	60-140
80 Chlorobenzene	20	20	100.97	60-140
82 Ethylbenzene	20	21	102.78	60-140
83 Xylene (total)mp	40	41	102.47	60-140
84 Xylene (total)o	20	21	103.71	60-140
85 Styrene	20	18	91.38	60-140
86 Bromoform	20	19	97.22	60-140
89 1,1,2,2-Tetrachlor	20	18	91.03	60-140
101 1,3-Dichlorobenzen	20	20	99.25	60-140
102 1,4-Dichlorobenzen	20	21	106.76	60-140
103 1,2-Dichlorobenzen	20	20	101.47	60-140

QUALITY ASSURANCE METHODS
REFERENCES AND NOTES

Report Date: 03/15/2005

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC. Lab Cert. ID# 10604
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviation

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the reporting limit.
- < Not detected at or above the reporting limit.
- J Result is less than the RL, but greater than or equal to the method detection limit.
- B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
- S Result was determined by the Method of Standard Additions.

Inorganic Flags (Flag Column)

- ICV,CCV,ICB,CCB,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed th upper or lower control limits.
- * LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
- + MSA correlation coefficient is less than 0.995.
- 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
- E SD: Serial dilution exceeds the control limits.
- H MB, EB: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
- N MS, MSD: Spike recovery exceeds the upper or lower control limits.
- W PS: Post-digestion spike was outside 85-115% control limits.

Organic Qualifiers (Q - Column)

- U Analyte was not detected at or above the reporting limit.
- ND Compound not detected.
- J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
- Q Result was qualitatively confirmed, but not quantified.
- C Pesticide identification was confirmed by GC/MS.
- Y The chromatographic response resembles a typical fuel pattern.
- Z The chromatographic response does not resemble a typical fuel pattern.
- E Result exceeded calibration range, secondary dilution required.

Organic Flags -(Flags Column)

- MB,EB, MLE: Batch QC is greater than reporting limit.
- * LCS, LCD, CCV, MS, MSD, Surrogate, RS:Batch QC exceeds the upper or lower control limits.
- A Concentration exceeds the instrument calibration range or below the reporting limit.
- B Compound was found in the blank.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is greater than 25%.

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Report Date: 03/15/2005

Abbreviations

Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column
CCB	Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation Analysis
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
Dil Fac	Dilution Factor
DL	Secondary dilution and analysis
DLFac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB	Extraction Blank
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A
ISB	Interference Check Sample B
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group
Lab ID	An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PACK	Packed Column
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PS	Post Spike
PSD	Post Spike Duplicate
RA	Re-analysis
RE	Re-extraction and analysis
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RS	Reference Standard
RT	Retention Time
RTW	Retention Time Window
SampleID	A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB	Seeded Control Blank
SD	Serial Dilution
UCB	Unseeded Control Blank

One or a combination of these data qualifiers and abbreviations may appear in the analytical report.

STL-Connecticut Certification Summary (as of October 2004)

The laboratory identification numbers for the STL-Connecticut laboratory are provided in the following table. Many states certify laboratories for specific parameters or tests within a category (i.e. method 325.2 for wastewater). The information in the following table indicates the lab is certified in a general category of testing such as drinking water or wastewater analysis. The laboratory should be contacted directly if parameter-specific certification information is required.

State	Agency	Category	Effective Date	Lab ID
Connecticut	Department of Health Services	Drinking Water, Wastewater	12/31/04	PH-0497
Maine	Department of Health and Environmental Services	Drinking Water, Wastewater/Solid, Hazardous Waste	04/18/06	CT023
Massachusetts	Department of Environmental Protection	Potable/Non-Potable Water	06/30/05	CT023
New Hampshire	Department of Environmental Services	Drinking Water, Wastewater	08/29/05	2528
New Jersey	Department of Environmental Protection	Drinking Water, Wastewater	06/30/05	46410
New York	Department of Health	CLP, Drinking Water, Wastewater, Solid/ Hazardous Waste NELAC	04/01/05	10602
Rhode Island	Department of Health	Chemistry...Non- Potable Water and Wastewater	12/30/04	A43
Utah	Department of Health	RCRA	05/31/05	2032614458