



LBG ENGINEERING SERVICES, P.C.

Professional Environmental & Civil Engineers



126 Monroe Turnpike
Trumbull, CT 06611
(203) 452-3110
(203) 452-3119 (FAX)

July 15, 2005



Mr. Jeffery Trad
Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation, Construction Services
625 Broadway, 12th floor
Albany, NY 12233-7013

RE: May 2005 Status Report
Ground-Water Remedial Action
Rowe Industries Superfund Site
Sag Harbor, New York

Dear Mr. Trad:

The enclosed letter report details the operation status of the full-scale ground-water pump and treat system at the above referenced site. LBG has enclosed an additional copy of the report to be forwarded to the Chief of the Operation Maintenance and Support Section.

Should you or the Operation Maintenance and Support Section have any questions, please feel free to contact myself, Paul Jobmann, or Al Kovalik at (203) 452-3100.

Very truly yours,

LEGGETTE, BRASHEARS & GRAHAM, INC.

Mark M. Goldberg

Mark M. Goldberg, P.E.
Senior Environmental Engineer

MG:ng

Enclosures

H:\NABIS\2005\Monthly Reports\May 2005\trad_May2005_report.doc

-DRAFT-

PROJECT STATUS MEMORANDUM


NO. 05-05

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Alfred N. Kovalik, P.E.

DATE: July 15, 2005

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
May 2005 Status Report
Sag Harbor, New York



LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from May 1, 2005 through May 31, 2005. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground-water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(May 1, 2005 through May 31, 2005)

- | | |
|---|-----------------------------------|
| 1. Hours of operation during the reporting period: | 375 hours (50%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 10,331,540 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: | yes, (Graph 1) |
| 6. Mass of VOCs recovered during the reporting period: | 2.4 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 166.1 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.113 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00101 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow (gpm)	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-1	341,646	14.9	26	0	0
RW-2	282,800	24.0	26	8.2	0.02
RW-3	350,185	15.9	23	12.7	0.04
RW-4*	1,013,085	45.0	13	92.2	0.78
RW-5	1,304,412	55.0	42	18.7	0.20
RW-6	638,783	27.1	28	107.3	0.57
RW-7	1,381,797	70.0	54	30.0	0.35
RW-8	1,389,606	60.0	46	10.8	0.13
RW-9**	124,366	18.0	68	11.9	0.01

* The flow signal for RW-4 was restored on May 23, 2005. The flow at that time was 45 gpm. This value plus the time of operation for the system was used to compute the monthly volume of water pumped for this well.

** RW-9 operated from May 10 to May 16, 2005.

Recovery wells RW-1, RW-2, RW-3, RW-6 and RW-9 had average flows below the respective minimum design flows determined to be necessary for capture of the plume. Despite periodic pipe cleanings, RW-1, RW-2 and RW-3 have decreased in flow due to iron build-up in the below-grade pipes. The flow in RW-6 has slowly been decreasing over time. Well rehabilitation activities at RW-6 did not improve the specific capacity of this well. In addition, cleaning the RW-6 flow meter, vault piping and below-grade piping in the vicinity of RW-6 did not restore the flow to historic levels. Ground-water drawdown continues to be very high at this well. Debris and/or bacteria build-up in the formation in conjunction with the finer soils associated with the aquifer in the immediate vicinity of RW-6 may be the root cause of the decreasing well yield.

The low flow at RW-9 is believed to be caused by iron build-up in a section of the below-grade piping not accessible to high-pressure jet-washing techniques. In April, a new clean-out port on Noyac Road allowed cleaning of 135 feet of additional piping which was not previously accessible with the jet-washing equipment. However, there was still additional below-grade piping that was not accessible. Two additional clean-out ports on Noyac Road are scheduled for construction in June to address iron build-up in the remaining inaccessible

below-grade piping.

Well rehabilitation activities and pump servicing scheduled for June 2005 is planned to help improve flow at RW-2, 3 and 9.

The effluent pH values are below the State Pollutant Discharge Elimination System (SPDES) Applicable or Relevant and Appropriate Requirements (ARARs) of 6.5 on a routine basis. May pH readings of water samples from the recovery wells were observed to be in the range of approximately 4.8 to 6.2, which is the background pH for the ground water in this area. The FSP&T system does not use any chemical treatment processes to alter pH. In addition the effluent water discharge and the recovery well extraction points are located in the same aquifer. As discussed with the New York State Department of Environmental Conservation (NYSDEC), because the pH is naturally occurring, it is not considered an exceedance of the discharge requirements.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
May 1 to May 31	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M MODIFICATIONS AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in May 2005 include:

- On May 4, 2005, aquifer pumping tests were conducted at recovery wells RW-1, 2, 3, 4, 5, 6, 7 and 9. Static depth to water measurements were collected at these recovery wells. Exposed discharge piping was covered with soil.
- On May 16, 2005, the system was de-energized for gas main construction activities conducted by Keyspan Energy. A malfunctioning well-head pressure sensor was replaced at RW-4.
- On May 23, 2005, the power to RW-9 was restored. A malfunctioning transmitter board for the RW-4 flow meter was replaced. A flow signal for RW-4 is being received at the building. Well rehabilitation began for RW-6.
- On May 26, 2005, the system was de-energized for the anticipated gas main construction activities being conducted by Keyspan Energy. Well rehabilitation began for RW-9 and RW-6 well rehabilitation was completed.

O&M activities scheduled for summer 2005 include:

- Samples of the ground water from the focused pump and treat wells and select monitor wells near the FDSA will be collected and analyzed in June 2005;
- Two additional clean-out ports on Noyac Road will be constructed and the piping subsequently will be cleaned in the vicinity of these clean-out ports;
- Rehabilitation of recovery wells RW-2, 3, 4, 7 and 9 will be conducted using the same methodology as used at RW-8;
- Sediment from the air stripper tower sump and transfer tank will be removed;
- The RW-5 flow meter will be investigated and troubleshot to determine why there is no signal being received at the remediation building;
- Cove salinity monitoring will be conducted and water levels at select piezometers will be measured; and,
- The leak will be repaired and the well-head pressure sensor will be replaced at RW-9.

cc: Phil McAndrew, Kraft Foods, N.A. – .pdf
Lisa Krogman, Kraft Foods, N.A. (Environ) – .pdf
Jeff Trad, NYSDEC
Chief-Operation Maintenance and Support Section
William Spitz, RWE, R-1, NYSDEC
Eileen A. Powers, Jr., Esq., Town of Southampton

MMG:ng

Attachments

H:\NABIS\2005\Monthly Reports\May 2005\Status0505May.doc

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(May 1, 2005 through May 31, 2005)

Date	Time	System Changes/Modifications	Personnel
5/2/2005	2:15 PM	Shut down system to allow static water level conditions to prevail so pump tests could be conducted on 5/4/05.	SS
5/3/2005	8:53 AM	System Communication failure alarm. The system was already shut down.	
5/4/2005		Conducted aquifer pumping tests at recovery wells to determine which recovery wells to rehabilitate. Updated static depth to water in RW-1, 2, 3, 4, 5, 6, 7 and 9 (static depth to water in RW-8 was updated on April 26, 2005.)	TS, SS
		Covered exposed discharge piping with soil in three locations between the building and the recharge basins.	MMG
		Dug test pit on Brick Kiln Road near RW-8 to assist Keyspan with the location of our below-grade piping.	SS, TS
		Changed multi-bag filter bags (400 um) in banks 1 and 2. Seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	TS, SS
	3:30 PM	Reset alarms and restarted the system (except for RW-9; RW-9 remains off until the leak at the union can be addressed).	TS, SS
	5:32 PM	RW-2 pump fault alarm, RW-2 shut down however the rest of the system is operating.	
5/8/2005	1:55 PM	Air Stripper Blower (ASB) low pressure alarm, system shut down	
5/10/2005		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	MG
		As a temporary measure to address the leak at the RW-9 union, a funnel and some tubing were attached underneath union at RW-9 to direct leaking water back to the well.	MG
		Tower packing material was inspected for iron build-up. Build-up on the tower packing material has not increased significantly from the last observation.	MG
	12:00 PM	Replaced ASB V-belt and reset the RW-2 drive, reset the alarms and restarted the system including RW-9.	MG
5/13/2005	3:20 PM	RW-2 pump fault alarm	
5/16/2005	8:37 AM	Reset RW-2 drive, reset alarm and restarted RW-2	MG
	10:00 AM	A well-head pressure reading from RW-9 is not being received in the building. Initiated troubleshooting for the RW-9 pressure sensor. When trying to re-start RW-9 after troubleshooting, no power was being sent to the pump. The fuse in the RW-9 control panel was replaced, however, the power to RW-9 was not restored. RW-9 was left off until the problem could be investigated.	MG
		A new well-head pressure sensor and display were installed at RW-4. A well-head pressure signal was received at the building.	MG
		The flow setpoint for RW-8 was reduced from 65 gpm to 60 gpm.	MG
		Input 5/4/05 static depth to water measurements into the computer.	MG
	2:30 PM	The system was shut down and de-energized for the anticipated gas main construction work by Keyspan Energy.	MG

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(May 1, 2005 through May 31, 2005)

Date	Time	System Changes/Modifications	Personnel
5/19/2005	2:24 PM	The system was re-energized and re-started. All wells were operating except RW-9.	SS
5/23/2005	9:34 AM	Shut down RW-6 for well rehabilitation activities	PJ
		The power to RW-9 was restored. The RW-9 well-head pressure sensor was not operating properly. A new pressure sensor was ordered.	PJ
	2:27 PM	Shut down system.	PJ
5/26/2005		The system remains down and the system was de-energized for the anticipated gas main construction work by Keyspan Energy.	SS
		The flow meter signal from RW-5 is not being received at the remediation building; this will be investigated.	SS
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo- chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Naph- thalene (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	6.5 to 8.5	---	1	5	5	5	5	5	5	---	---	5	---	10	7	---	---	---
2-May-05	5.3	120	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.22	0.114
10-May-05	5.3	100	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	5.48	0.406
16-May-05	5.3	91	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.18	0.178
27-May-05	5.3	NM ^{3/}	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	NM ^{3/}	NM ^{3/}

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. pH was measured using litmus paper. Influent pH values from recovery wells, which reflect the pH of natural ground water, are below 6.5 on a regular basis.
2. "Effluent" samples were collected from sample port labeled NP2-10.
3. Iron and TDS samples were mistakenly omitted from the sampling on the week of May 27, 2005.

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																				TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ060204:1200NP4-1	6/2/2004	12:00	0.28	0.013	0.017	ND	ND	ND	0.027	0.005	0.012	0.007	0.002	0.007	0.023	0.005	0.058	0.12	ND	0.004	ND	ND	ND	0.58
AQ070704:1415NP4-1	7/7/2004	14:15	0.86	0.03	0.12	ND	ND	ND	0.02	0.02	ND	ND	ND	0.009	0.05	ND	0.08	0.07	ND	ND	ND	ND	ND	1.26
AQ080404:1330NP4-1	8/4/2004	13:30	1.3	0.089	0.22	0.012	0.016	0.007	0.031	0.004	0.003	0.001	0.004	0.013	0.044	0.005	0.076	0.067	ND	0.001	ND	ND	ND	1.89
AQ090204:1431NP4-1	9/2/2004	14:31	0.83	0.054	0.13	0.009	0.013	0.004	0.028	0.008	0.004	0.001	0.003	0.01	0.073	0.003	0.078	0.04	ND	0.001	ND	ND	ND	1.29
AQ100704:1210NP4-1	10/7/2004	12:10	0.4	0.035	0.058	0.005	0.005	0.003	0.038	0.008	0.003	0.001	0.002	0.008	0.05	ND	0.045	0.06	ND	0.001	ND	ND	ND	0.72
AQ110304:945NP4-1	11/3/2004	9:45	0.44	0.032	0.074	0.01	0.022	0.004	0.02	0.008	0.0018	ND	0.0012	0.008	0.1	0.006	0.02	0.152	ND	ND	ND	ND	ND	0.90
AQ120204:1100NP4-1	12/2/2004	11:00	0.4	0.026	0.08	0.01	0.022	0.004	0.052	0.03	0.006	0.0014	0.002	ND	1.04	0.012	0.05	0.24	ND	0.0018	ND	ND	ND	1.04
AQ010405:1145NP4-1	1/4/2005	11:45	0.06	0.025	0.0775	ND	ND	ND	0.015	0.005	ND	ND	ND	0.005	0.025	ND	ND	0.04	ND	ND	ND	ND	ND	0.25
AQ020205:1345NP4-1	2/2/2005	13:45	0.45	0.0325	0.0675	ND	ND	ND	0.02	0.0075	ND	ND	ND	0.0075	0.0325	ND	ND	0.185	ND	ND	ND	ND	ND	0.80
AQ030205:1105NP4-1	3/2/2005	11:05	0.35	0.0325	0.0725	ND	ND	ND	0.0175	0.005	ND	ND	ND	0.005	0.015	ND	ND	0.0825	ND	ND	ND	ND	ND	0.58
AQ040705:1430NP4-1	4/7/2005	14:30	0.34	0.027	0.058	0.006	0.02	ND	0.029	0.012	0.003	ND	0.002	0.006	0.053	ND	0.015	ND	ND	ND	ND	ND	ND	0.57
AQ050205:1405NP401	5/2/2005	14:05	0.52	0.032	0.116	ND	ND	ND	0.024	0.008	ND	ND	ND	ND	0.024	ND	ND	0.04	ND	ND	ND	ND	ND	0.76

Midcarbon			Parameters (mg/m3)																				TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ060204:1202NP4-2	6/2/2004	12:02	0.012	0.002	ND	ND	ND	ND	0.02	0.003	0.002	0.0008	0.001	ND	0.021	0.003	0.041	0.057	ND	0.0008	ND	ND	ND	0.16
AQ070704:1420NP4-2	7/7/2004	14:20	0.013	0.002	ND	ND	ND	ND	0.032	0.004	0.003	0.0009	0.003	ND	0.058	0.004	0.097	0.027	ND	0.001	ND	ND	ND	0.24
AQ080404:1335NP4-2	8/4/2004	13:35	0.048	0.002	ND	0.005	ND	ND	0.031	0.002	0.003	0.001	0.003	ND	0.063	0.004	0.078	0.071	ND	0.001	ND	ND	ND	0.31
AQ090204:1432NP4-2	9/2/2004	14:32	0.014	0.002	ND	0.005	ND	ND	0.059	0.005	0.005	0.001	0.003	ND	0.088	0.003	0.086	0.025	ND	0.002	ND	ND	ND	0.30
AQ100704:1212NP4-2	10/7/2004	12:12	0.021	0.001	ND	0.006	0.01	ND	0.016	0.007	0.003	0.001	0.002	0.002	0.011	ND	0.036	0.057	ND	0.001	ND	ND	ND	0.17
AQ110304:947NP4-2	11/3/2004	9:47	0.015	ND	ND	0.007	0.014	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.034	0.005	0.018	0.026	ND	0.0004	ND	ND	ND	0.15
AQ120204:1102NP4-2	12/2/2004	11:02	0.004	ND	ND	0.009	0.017	0.002	0.034	0.003	0.003	0.0005	0.003	0.011	0.097	0.004	0.025	0.08	ND	0.001	ND	ND	ND	0.23
AQ010405:1150NP4-2	1/4/2005	11:50	0.004	ND	0.045	0.011	0.028	0.003	0.024	0.002	0.001	ND	0.002	0.018	0.009	ND	0.015	0.028	ND	ND	ND	ND	ND	0.19
AQ020205:1350NP4-2	2/2/2005	13:50	ND	ND	0.15	0.011	0.033	0.005	0.019	0.001	ND	ND	ND	0.018	0.019	ND	0.013	0.004	ND	ND	ND	ND	ND	0.27
AQ030205:1110NP4-2	3/2/2005	11:10	ND	ND	0.14	0.009	0.022	0.004	0.016	0.002	0.002	ND	ND	0.011	0.01	ND	0.008	0.021	ND	ND	ND	ND	ND	0.25
AQ040705:1432NP4-2	4/7/2005	14:32	0.004	ND	0.069	0.005	0.014	0.003	0.012	0.002	ND	ND	ND	0.006	0.05	ND	ND	0.026	ND	ND	ND	ND	ND	0.19
AQ050205:1410NP4-2	5/2/2005	14:10	ND	ND	0.085	0.005	ND	0.003	0.016	0.001	ND	ND	ND	0.003	0.006	ND	0.005	0.01	ND	ND	ND	ND	ND	0.13

Postcarbon			Parameters (mg/m3)																				TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ060204:1204NP4-3	6/2/2004	12:04	0.003	0.002	ND	ND	ND	ND	0.019	0.002	0.002	0.0005	0.001	ND	0.02	0.004	0.039	0.1	ND	0.0006	ND	ND	ND	0.19
AQ070704:1425NP4-3	7/7/2004	14:25	0.003	0.002	ND	ND	ND	ND	0.032	0.004	0.003	0.0009	0.003	ND	0.062	ND	0.11	0.006	ND	0.001	ND	ND	ND	0.23
AQ080404:1340NP4-3	8/4/2004	13:40	0.02	0.002	ND	ND	ND	ND	0.03	0.004	0.003	0.001	0.004	ND	0.055	0.004	0.067	0.055	ND	0.001	ND	ND	ND	0.25
AQ090204:1433NP4-3	9/2/2004	14:33	0.023	0.003	ND	ND	ND	ND	0.062	0.008	0.005	0.001	0.003	ND	0.087	0.004	0.085	0.033	ND	0.002	ND	ND	ND	0.32
AQ100704:1215NP4-3	10/7/2004	12:15	0.001	0.001	ND	ND	ND	ND	0.045	0.004	0.003	0.0009	0.003	ND	0.011	ND	0.033	0.034	ND	0.001	ND	ND	ND	0.14
AQ110304:950NP4-3	11/3/2004	9:50	0.005	ND	ND	0.002	ND	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.032	ND	0.017	0.022	ND	0.0005	ND	ND	ND	0.11
AQ120204:1105NP4-3	12/2/2004	11:05	ND	0.002	ND	0.006	ND	ND	0.035	0.011	0.003	0.0006	0.003	ND	0.27	0.005	0.025	0.064	ND	0.001	ND	ND	ND	0.19
AQ010405:1155NP4-3	1/4/2005	11:55	0.002	ND	ND	0.007	0.013	0.002	0.023	0.002	0.002	ND	0.002	ND	0.006	ND	0.015	0.008	ND	ND	ND	ND	ND	0.08
AQ020205:1355NP4-3	2/2/2005	13:55	0.004	ND	ND	ND	ND	ND	0.021	0.002	ND	ND	0.001	ND	0.023	ND	0.013	ND	ND	ND	ND	ND	ND	0.06
AQ030205:1115NP4-3	3/2/2005	11:15	ND	ND	0.023	0.009	0.031	ND	0.016	0.002	0.002	ND	0.001	0.012	0.008	ND	0.009	0.007	ND	ND	ND	ND	ND	0.12
AQ040705:1434NP4-3	4/7/2005	14:34	0.001	ND	0.02	0.006	0.016	ND	0.013	0.002	ND	ND	ND	0.007	0.015	ND	ND	0.015	ND	ND	ND	ND	ND	0.10
AQ050205:1415NP4-3	5/2/2005	14:15	ND	ND	0.03	0.007	0.016	ND	0.019	0.01	0.0009	ND	ND	0.009	0.007	ND	0.012	0.002	ND	ND	ND	ND	ND	0.11

Notes: 1. Methylene Chloride concentrations in all three air samples collected during the December 2, 2004 sampling event are greatly elevated due to suspected laboratory contamination. Methylene chloride was confirmed as a suspected laboratory contaminant by the laboratory supervisor. The methylene chloride concentrations from the November 3, 2004 sampling event were used instead of the December 2, 2004 methylene chloride concentrations to calculate the total VOCs for December 2004.

PCE - Tetrachloroethane
 TCE - Trichloroethane
 TCA - 1,1,1-Trichloroethane

DCE - 1,1-Dichloroethane
 DCA - 1,1-Dichloroethane
 cis-DCE - cis-1,2-Dichloroethane
 CT - Carbon Tetrachloride

CF - Chloroform
 MC - Methylene Chloride
 CM - Chloromethane
 CD - Carbon Disulfide

BM - Bromomethane
 CB - Chlorobenzene
 EB - Ethylbenzene
 VC - Vinyl Chloride

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropyl- benzene (ug/L) NE	1,1-Dichloro- ethane (ug/L) 5	cis-1,2-Dichloro- ethene (ug/L) 5	1,1-Dichloro- ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloromethane (ug/L) NE	Naphthalene (ug/L) NE
RW-1	23-Apr-03	ND<1	ND<1	ND<1	ND<1	1.2	8.6	0.053	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	ND<1	ND<1	ND<1	ND<1	1.8	8.7	0.051	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1	ND<1
	11-Jun-03	ND<1	ND<1	ND<1	ND<1	ND<1	8.1	0.0290	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	ND<1	ND<1	ND<1	ND<1	2.9	6.6	0.0100	0.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	ND<1	ND<1	ND<1	ND<1	2.6	9.4	0.0930	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	ND<1	ND<1	ND<1	ND<1	3.2	14	0.0540	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0613	0.0074	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	ND<1	ND<1	ND<1	ND<1	2.2	9.4	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	ND<1	ND<1	ND<1	ND<1	4.0	2.2	0.0098	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	ND<1	ND<1	ND<1	4.6	5.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	ND<1	ND<1	ND<1	ND<1	4.1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.5
	14-Apr-04	ND<1	ND<1	ND<1	ND<1	2.9	6.1	0.0240	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	ND<1	ND<1	ND<1	ND<1	5.6	6.8	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.1 *	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	2.0	3.4	0.0454	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	ND<1	ND<1	ND<1	ND<1	3.1	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	8.0
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-2	23-Apr-03	14	1.3	ND<1	ND<1	ND<1	ND<1	6.31	0.212	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	2	ND<1	ND<1	ND<1	3.8	5.51	0.052	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1
	11-Jun-03	15	0.6	ND<1	ND<1	ND<1	ND<1	3.01	0.885	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	5.34	0.438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	7.9	ND<1	ND<1	ND<1	ND<1	ND<1	5.99	0.758	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	9.2	0.5	ND<1	ND<1	ND<1	6.0	4.49	0.899	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	8.1	0.7	ND<1	ND<1	ND<1	ND<1	6.79	0.101	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	5.5	ND<1	ND<1	ND<1	ND<1	5.5	5.46	0.0213	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	8.7	ND<1	ND<1	ND<1	ND<1	1.1	5.57	0.207	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	5.4	ND<1	ND<1	ND<1	ND<1	3.9	3.77	0.0748	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	4.9	ND<1	ND<1	ND<1	ND<1	3.3	0.343	0.318	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	4.4	ND<1	ND<1	ND<1	ND<1	2.8	5.59	0.224	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	8.2	ND<1	ND<1	ND<1	ND<1	4.7	4.5	0.691	ND<1	ND<1	ND<1	ND<1	5.6 *	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	52.5	1.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	6.5	ND<1	ND<1	ND<1	ND<1	1.3	4.88	0.704	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	1.5	4.78	0.213	ND<1	ND<1	ND<1	ND<1	ND<1	2.1	1.5	ND<1
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropylbenzene (ug/L) NE	1,1-Dichloroethane (ug/L) 5	cis-1,2-Dichloroethene (ug/L) 5	1,1-Dichloroethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloromethane (ug/L) NE	Naphthalene (ug/L) NE
RW-3	23-Apr-03	1.1	1.2	ND<1	ND<1	ND<1	ND<1	1.81	0.395	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	2.2	2.5	1.1	ND<1	ND<1	ND<1	1.68	0.166	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1
	11-Jun-03	2.4	3.4	1.8	ND<1	ND<1	ND<1	2.37	0.517	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	2.3	5.7	2.3	ND<1	ND<1	ND<1	1.77	0.636	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	2.8	5.8	2.9	ND<1	ND<1	ND<1	2.24	1.57	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	2.1	5.3	2.6	ND<1	ND<1	ND<1	1.86	1.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	1.9	5.2	3.3	ND<1	ND<1	ND<1	2.59	1.27	ND<1	ND<1	0.6	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	1.2	5.8	ND<1	ND<1	ND<1	ND<1	1.96	0.129	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.2	6.9	3.2	ND<1	ND<1	ND<1	1.96	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	3.6	2.2	ND<1	ND<1	ND<1	1.63	1.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	1.2	5.0	2.3	ND<1	ND<1	ND<1	3.34	0.542	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	28-Apr-04	1.3	8.8	4.4	ND<1	ND<1	ND<1	3.07	1.32	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	ND<1
	5-May-04	0.9	6.9	3.6	ND<1	ND<1	ND<1	2.07	1.96	ND<1	ND<1	ND<1	ND<1	5.6*	ND<1	ND<1	ND<1
	30-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.619	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	2.4	6.1	2.6	ND<1	ND<1	ND<1	2.07	1.79	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	2.7	21	8.7	ND<1	ND<1	ND<1	1.91	0.42	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	2.2	12	5.0	ND<1	ND<1	ND<1	2.09	1.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.5	6.5	2.6	ND<1	ND<1	ND<1	1.87	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.77	0.489	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	3	13	5.0	ND<1	ND<1	ND<1	1.89	1.36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	46.1	0.539	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	2.2	7.7	2.8	ND<1	ND<1	ND<1	1.85	0.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-4	23-Apr-03	110	3.1	ND<1	ND<1	ND<1	ND<1	3.18	0.136	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	170	5.4	1.0	ND<1	ND<1	ND<1	2.38	0.023	ND<1	ND<1	ND<1	ND<1	3.3	ND<1	ND<1	ND<1
	11-Jun-03	170	4.8	ND<1	ND<1	ND<1	ND<1	1.03	0.572	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	200	5.9	1.3	ND<1	ND<1	ND<1	2.67	0.292	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	210	5.7	1.1	ND<1	ND<1	ND<1	3.21	0.529	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	390	8.2	1.0	ND<1	ND<1	ND<1	2.95	0.922	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	380	6.8	1.6	ND<1	ND<1	ND<1	6.93	0.221	ND<1	1.2	0.9	0.8	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	270	7.9	ND<1	ND<1	ND<1	ND<1	5.45	0.0331	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	270	5.9	ND<1	ND<1	ND<1	ND<1	3.56	0.48	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	170	6.9	14.0	ND<1	ND<1	ND<1	3.28	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	170	5.8	4.5	ND<1	ND<1	ND<1	1.61	0.0691	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.982	0.173	ND<1	ND<1	ND<1	ND<1	2.1*	ND<1	ND<1	ND<1
	5-May-04	470	6.2	7.8	ND<1	ND<1	ND<1	7.08	2.33	ND<1	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<1
	30-Jun-04	110	3.8	26	ND<1	ND<1	ND<1	4.44	1.11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	110	3.2	29	ND<1	ND<1	ND<1	5.00	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	120	3.7	18	ND<1	ND<1	ND<1	2.98	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	3.2	ND<1	ND<1
	7-Oct-04	94	ND<1	14	ND<1	ND<1	ND<1	3.65	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	130	4.2	11	ND<1	ND<1	ND<1	4.75	0.205	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	230	5.7	35	ND<1	ND<1	ND<1	1.90	1.62	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Apr-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	2-May-05	80	2.4	9.8	ND<1	ND<1	ND<1	3.77	0.0687	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropyl- benzene (ug/L) NE	1,1-Dichloro- ethane (ug/L) 5	cis-1,2-Dichloro- ethane (ug/L) 5	1,1-Dichloro- ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloromethane (ug/L) NE	Naphthalene (ug/L) NE
RW-5	23-Apr-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	ND<1	ND<1	ND<1	0.8	6.7	0.146	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1	ND<1
	11-Jun-03	21	ND<1	ND<1	ND<1	ND<1	6.2	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	11	ND<1	ND<1	ND<1	1.1	9.7	6.47	0.068	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	15	ND<1	ND<1	ND<1	0.9	7.3	0.269	0.021	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	18	ND<1	ND<1	ND<1	ND<1	8.1	0.043	0.016	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	18	ND<1	ND<1	ND<1	ND<1	ND<1	13.1	0.0097	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	ND<1	ND<1	ND<1	ND<1	7.5	0.0523	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	14	ND<1	ND<1	ND<1	0.9	4.0	0.05	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	14	ND<1	ND<1	ND<1	1.0	6.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	14	ND<1	ND<1	ND<1	ND<1	5.0	0.0852	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	18	ND<1	1.5	ND<1	ND<1	6.1	0.147	0.015	ND<1	ND<1	ND<1	ND<1	2*	ND<1	ND<1	ND<1
	5-May-04	38	0.8	3.2	ND<1	1.5	8.0	0.055	0.015	ND<1	ND<1	ND<1	ND<1	6.4*	ND<1	ND<1	ND<1
	14-Jun-04	17	ND<1	4.6	ND<1	ND<1	3.9	0.054	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	21	ND<1	4.6	ND<1	ND<1	3.1	0.0254	0.0265	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	24	ND<1	6.5	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.3	ND<1	ND<1
	7-Oct-04	16	ND<1	5.2	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	ND<1	1.8	1.4	ND<1
	3-Nov-04	15	ND<1	6.4	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	28	ND<1	28	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	9	ND<1	4.1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	13	ND<1	5.7	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-6	23-Apr-03	79	1.0	ND<1	ND<1	ND<1	ND<1	0.028	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	120	1.8	ND<1	ND<1	0.6	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.5	ND<1	ND<1	ND<1
	11-Jun-03	120	0.7	ND<1	ND<1	ND<1	ND<1	0.0097	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	150	0.6	ND<1	ND<1	ND<1	ND<1	0.186	0.034	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	140	2.2	ND<1	ND<1	ND<1	ND<1	0.089	0.018	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	140	2.6	ND<1	ND<1	ND<1	ND<1	0.023	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	180	3.3	1.0	ND<1	ND<1	ND<1	0.342	0.0083	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	120	2.6	ND<1	ND<1	ND<1	ND<1	0.017	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	160	2.4	ND<1	ND<1	ND<1	ND<1	0.015	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	130	3.3	1.1	ND<1	ND<1	1.7	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	110	2.7	ND<1	ND<1	ND<1	1.6	0.077	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	110	2.9	1.3	ND<1	ND<1	2.6	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8*	ND<1	ND<1	ND<1
	5-May-04	210	4.8	ND<1	ND<1	ND<1	3.2	0.719	ND<0.02	ND<1	ND<1	ND<1	ND<1	5.9*	ND<1	ND<1	ND<1
	14-Jun-04	92	3.6	1.3	ND<1	ND<1	2.1	0.151	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	100	2.8	1.2	ND<1	ND<1	1.7	0.437	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1
	7-Oct-04	94	ND<1	1.6	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.9	2.0	ND<1
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	2.5	0.0111	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	200	3.8	16	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	Isopropylbenzene (ug/L) NE	1,1-Dichloroethane (ug/L) 5	cis-1,2-Dichloroethene (ug/L) 5	1,1-Dichloroethene (ug/L) 5	Methylene Chloride (ug/L) 5	Bromoform (ug/L) NE	Dibromochloromethane (ug/L) NE	Naphthalene (ug/L) NE
RW-7	23-Apr-03	100	1.8	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	140	3.1	1.0	ND<1	ND<1	ND<1	0.032	ND<0.02	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1	ND<1
	11-Jun-03	140	2.0	ND<1	ND<1	ND<1	ND<1	0.0246	0.0086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	150	2.1	ND<1	ND<1	ND<1	ND<1	0.024	0.041	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	120	2.3	ND<1	ND<1	ND<1	ND<1	0.011	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	130	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	140	3.4	1.1	ND<1	ND<1	ND<1	0.0464	ND<0.02	ND<1	ND<1	0.2	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	110	2.8	ND<1	ND<1	ND<1	ND<1	0.0239	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	190	3.7	ND<1	ND<1	ND<1	ND<1	0.0069	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	120	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	100	3.0	ND<1	ND<1	ND<1	ND<1	0.0205	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	79	2.5	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.2*	ND<1	ND<1	ND<1
	5-May-04	130	4.0	ND<1	ND<1	ND<1	ND<1	0.012	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<1
	14-Jun-04	59	2.7	ND<1	ND<1	ND<1	ND<1	0.018	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	55	2.1	ND<1	ND<1	ND<1	ND<1	0.791	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	ND<1	ND<1
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	0.0272	0.00876	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-8	23-Apr-03	41	2.0	1.8	ND<1	ND<1	ND<1	11.8	0.352	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	61	3.9	3.8	ND<1	ND<1	ND<1	10.1	0.068	ND<1	1.8	ND<1	ND<1	3.4	ND<1	ND<1	ND<1
	11-Jun-03	57	3.1	2.7	ND<1	ND<1	ND<1	9.14	1.10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	35	1.9	3.2	ND<1	ND<1	ND<1	10.5	0.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	30	1.7	3.6	ND<1	ND<1	ND<1	11.1	1.18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	28	2.5	4.4	ND<1	ND<1	ND<1	9.93	0.40	ND<1	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.3	5.4	ND<1	ND<1	ND<1	13.3	0.21	ND<1	4.1	0.7	1.3	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	17	2.1	2.6	ND<1	ND<1	ND<1	9.16	0.05	ND<1	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	16	2.2	4.1	ND<1	ND<1	ND<1	9.73	2.72	ND<1	3.5	ND<1	1.5	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	15	2.2	4.7	ND<1	ND<1	ND<1	8.74	0.19	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	22	2.7	4.3	ND<1	ND<1	ND<1	11.9	0.23	ND<1	3.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	14	2.0	6.2	ND<1	ND<1	ND<1	10.7	0.14	ND<1	5.7	ND<1	ND<1	1.9*	ND<1	ND<1	ND<1
	5-May-04	27	4.1	8.3	ND<1	ND<1	ND<1	8.77	0.21	ND<1	8.7	ND<1	ND<1	8.5*	ND<1	ND<1	ND<1
	14-Jun-04	10	2.4	5.8	ND<1	ND<1	ND<1	9.15	0.10	ND<1	4.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04 **	3	1.0	3.7	ND<1	ND<1	ND<1	4.18	0.21	ND<1	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	28.8	0.2	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	10.6	0.3	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	16	ND<1	22	ND<1	ND<1	ND<1	15.6	0.1	ND<1	15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	ND<1	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	ND<1	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	7.33	0.07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropyl-benzene (ug/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-9	23-Apr-03	15	1.2	1.8	ND<1	ND<1	ND<1	3.55	1.97	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	1.8	3.6	ND<1	ND<1	ND<1	2.95	0.046	ND<1	1.9	ND<1	ND<1	3.2	ND<1	ND<1	ND<1
	11-Jun-03	18	1.6	4.8	ND<1	ND<1	ND<1	2.75	1.74	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	4.7	1.6	7.3	ND<1	ND<1	ND<1	3.60	0.467	ND<1	3.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	25	1.2	3.5	ND<1	ND<1	ND<1	4.05	2.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	22	2.1	5.8	ND<1	ND<1	ND<1	3.49	2.88	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.2	8.2	ND<1	ND<1	ND<1	5.39	1.72	ND<1	5.2	ND<1	1.4	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	1.7	5.4	ND<1	ND<1	ND<1	1.94	1.57	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.3	2.2	13	ND<1	ND<1	ND<1	0.638	0.029	ND<1	1.8	ND<1	1.5	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	2.2	12	ND<1	ND<1	ND<1	1.24	0.222	ND<1	3.7	ND<1	1.3	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	5.6	1.7	10	ND<1	ND<1	ND<1	2.65	1.22	ND<1	5.9	ND<1	2.0	2.0*	ND<1	ND<1	ND<1
	5-May-04	3.7	1.7	13	ND<1	ND<1	ND<1	2.58	1.83	ND<1	6.7	ND<1	1.7	7.1*	ND<1	ND<1	ND<1
	14-Jun-04	1.8	1.9	8.2	ND<1	ND<1	ND<1	3.03	1.11	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	3.4	1.3	5.1	ND<1	ND<1	ND<1	2.6	1.95	ND<1	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	ND<1	1.9	ND<1	ND<1	ND<1	1.6	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0596	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

ND: Not detected

<#: Less than method detection limit

ug/L: Micrograms per liter

-: Not analyzed

ARAR's are chemical specific aquifer restoration goals for ground-water at the Former Rowe Industries Superfund Site.

Bold values indicate an exceedance of the ARAR standard established for the site.

PCE: Tetrachloroethylene

TCE: Trichloroethylene

TCA: 1,1,1-Trichloroethane

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl Tertiary Butyl Ether

NM: Not Measured

*Methylene Chloride detected in laboratory method blank

NE: ARAR goal was not established for this compound by the EPA.


** The July 14, 2004 sample collected for RW-8 only represents water in the pipe since the RW-8 pump was not operating at this time.

*** The August 26, 2004 samples were lost during shipment.

GRAPHS


GRAPH 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
(May 1, 2005 through May 31, 2005)




GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
MAY 2005 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, May 11, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0505044

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 5/5/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 11-May-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0505044**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0505044-01A	WQ050205:1320 NP2-6	4623	5/2/2005	5/5/2005
0505044-01B	WQ050205:1320 NP2-6	4623	5/2/2005	5/5/2005
0505044-01C	WQ050205:1320 NP2-6	4623	5/2/2005	5/5/2005
0505044-02A	WQ050205:1325 NP2-7	4623	5/2/2005	5/5/2005
0505044-02B	WQ050205:1325 NP2-7	4623	5/2/2005	5/5/2005
0505044-02C	WQ050205:1325 NP2-7	4623	5/2/2005	5/5/2005
0505044-03A	WQ050205:1330 NP2-10	4623	5/2/2005	5/5/2005
0505044-03B	WQ050205:1330 NP2-10	4623	5/2/2005	5/5/2005
0505044-03C	WQ050205:1330 NP2-10	4623	5/2/2005	5/5/2005

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ050205:1320 NP2-6
 Lab Order: 0505044 Tag Number: 4623
 Project: Rowe Industries Collection Date: 5/2/2005
 Lab ID: 0505044-01A Date Received: 5/5/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						Analyst: RN
SW8260B						
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,1,1-Trichloroethane	3.5	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
2-Butanone	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
2-Hexanone	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Acetone	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Benzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Bromobenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Bromoform	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Bromomethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Chloroethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ050205:1320 NP2-6

Lab Order: 0505044

Tag Number: 4623

Project: Rowe Industries

Collection Date: 5/2/2005

Lab ID: 0505044-01A

Date Received: 5/5/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Chloromethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Dibromomethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/12/2005 7:50:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Methylene chloride	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Naphthalene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
o-Xylene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Styrene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Tetrachloroethene	20	1.0		µg/L	1	5/12/2005 7:50:00 PM
Toluene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Trichloroethene	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/12/2005 7:50:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/12/2005 7:50:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ050205:1320 NP2-6
Lab Order:	0505044	Tag Number:	4623
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505044-01B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	5.11	0.0200		mg/L	1	5/10/2005 1:00:38 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ050205:1320 NP2-6
Lab Order:	0505044	Tag Number:	4623
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505044-01C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0920	0.0200		mg/L	1	5/10/2005 12:54:43 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ050205:1325 NP2-7

Lab Order: 0505044

Tag Number: 4623

Project: Rowe Industries

Collection Date: 5/2/2005

Lab ID: 0505044-02A

Date Received: 5/5/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B	Analyst: RN	
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
2-Butanone	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
2-Hexanone	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Acetone	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Benzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Bromobenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Bromoform	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Bromomethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Chloroethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ050205:1325 NP2-7

Lab Order: 0505044

Tag Number: 4623

Project: Rowe Industries

Collection Date: 5/2/2005

Lab ID: 0505044-02A

Date Received: 5/5/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Chloromethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Dibromomethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/6/2005 9:30:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Methylene chloride	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Naphthalene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
o-Xylene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Styrene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Toluene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Trichloroethene	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/6/2005 9:30:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/6/2005 9:30:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ050205:1325 NP2-7
Lab Order:	0505044	Tag Number:	4623
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505044-02B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	1.57	0.0200		mg/L	1	5/10/2005 1:05:51 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ050205:1325 NP2-7
Lab Order:	0505044	Tag Number:	4623
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505044-02C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.111	0.0200		mg/L	1	5/10/2005 1:02:45 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ050205:1330 NP2-10
Lab Order:	0505044	Tag Number:	4623
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505044-03A	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: RN		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
2-Butanone	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
2-Hexanone	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Acetone	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Benzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Bromobenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Bromoform	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Bromomethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Chloroethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ050205:1330 NP2-10
Lab Order: 0505044 **Tag Number:** 4623
Project: Rowe Industries **Collection Date:** 5/2/2005
Lab ID: 0505044-03A **Date Received:** 5/5/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Chloromethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Dibromomethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/6/2005 10:02:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Methylene chloride	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Naphthalene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
o-Xylene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Styrene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Toluene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Trichloroethene	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/6/2005 10:02:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/6/2005 10:02:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ050205:1330 NP2-10
Lab Order:	0505044	Tag Number:	4623
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505044-03B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	1.22	0.0200		mg/L	1	5/10/2005 1:11:12 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ050205:1330 NP2-10
Lab Order:	0505044	Tag Number:	4623
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505044-03C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.114	0.0200		mg/L	1	5/10/2005 1:08:23 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	5/9/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, May 17, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0505082

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 5/12/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0505082

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0505082-01A	WQ051005:1400 NP2-6	6148	5/10/2005	5/12/2005
0505082-01B	WQ051005:1400 NP2-6	6148	5/10/2005	5/12/2005
0505082-01C	WQ051005:1400 NP2-6	6148	5/10/2005	5/12/2005
0505082-02A	WQ051005:1402 NP2-7	6148	5/10/2005	5/12/2005
0505082-02B	WQ051005:1402 NP2-7	6148	5/10/2005	5/12/2005
0505082-02C	WQ051005:1402 NP2-7	6148	5/10/2005	5/12/2005
0505082-03A	WQ051005:1405 NP2-10	6148	5/10/2005	5/12/2005
0505082-03B	WQ051005:1405 NP2-10	6148	5/10/2005	5/12/2005
0505082-03C	WQ051005:1405 NP2-10	6148	5/10/2005	5/12/2005

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051005:1400 NP2-6
Lab Order:	0505082	Tag Number:	6148
Project:	Rowe Industries	Collection Date:	5/10/2005
Lab ID:	0505082-01A	Date Received:	5/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,1,1-Trichloroethane	2.1	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
2-Butanone	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
2-Hexanone	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Acetone	U	1.0	B	µg/L	1	5/13/2005 9:38:00 AM
Benzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Bromobenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Bromoform	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Bromomethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Chloroethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ051005:1400 NP2-6
Lab Order: 0505082 **Tag Number:** 6148
Project: Rowe Industries **Collection Date:** 5/10/2005
Lab ID: 0505082-01A **Date Received:** 5/12/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Chloromethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Dibromomethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/13/2005 9:38:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Methylene chloride	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Naphthalene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
o-Xylene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Styrene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Tetrachloroethene	32	1.0		µg/L	1	5/13/2005 9:38:00 AM
Toluene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Trichloroethene	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/13/2005 9:38:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/13/2005 9:38:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051005:1400 NP2-6
Lab Order:	0505082	Tag Number:	6148
Project:	Rowe Industries	Collection Date:	5/10/2005
Lab ID:	0505082-01B	Date Received:	5/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	2.22	0.0200		mg/L	1	5/13/2005 10:59:36 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051005:1400 NP2-6
Lab Order:	0505082	Tag Number:	6148
Project:	Rowe Industries	Collection Date:	5/10/2005
Lab ID:	0505082-01C	Date Received:	5/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.143	0.0200		mg/L	1	5/13/2005 10:57:31 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051005:1402 NP2-7
Lab Order:	0505082	Tag Number:	6148
Project:	Rowe Industries	Collection Date:	5/10/2005
Lab ID:	0505082-02A	Date Received:	5/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B	Analyst: LDS	
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
2-Butanone	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
2-Hexanone	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Acetone	U	1.0	B	µg/L	1	5/13/2005 10:18:00 AM
Benzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Bromobenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Bromoform	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Bromomethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Chloroethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051005:1402 NP2-7
Lab Order:	0505082	Tag Number:	6148
Project:	Rowe Industries	Collection Date:	5/10/2005
Lab ID:	0505082-02A	Date Received:	5/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Chloromethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Dibromomethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/13/2005 10:18:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Methylene chloride	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Naphthalene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
o-Xylene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Styrene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Tetrachloroethene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Toluene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Trichloroethene	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/13/2005 10:18:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/13/2005 10:18:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051005:1402 NP2-7
Lab Order:	0505082	Tag Number:	6148
Project:	Rowe Industries	Collection Date:	5/10/2005
Lab ID:	0505082-02B	Date Received:	5/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	3.22	0.0200		mg/L	1	5/13/2005 11:05:44 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 7 of 12

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051005:1402 NP2-7
Lab Order:	0505082	Tag Number:	6148
Project:	Rowe Industries	Collection Date:	5/10/2005
Lab ID:	0505082-02C	Date Received:	5/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.189	0.0200		mg/L	1	5/13/2005 11:03:14 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT: Leggett Brashears & Graham Inc. Client Sample ID: WQ051005:1405 NP2-10
 Lab Order: 0505082 Tag Number: 6148
 Project: Rowe Industries Collection Date: 5/10/2005
 Lab ID: 0505082-03A Date Received: 5/12/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
2-Butanone	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
2-Hexanone	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Acetone	U	1.0	B	µg/L	1	5/13/2005 10:51:00 AM
Benzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Bromobenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Bromoform	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Bromomethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Chloroethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ051005:1405 NP2-10
Lab Order: 0505082 **Tag Number:** 6148
Project: Rowe Industries **Collection Date:** 5/10/2005
Lab ID: 0505082-03A **Date Received:** 5/12/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Chloromethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Dibromomethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/13/2005 10:51:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Methylene chloride	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Naphthalene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
o-Xylene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Styrene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Tetrachloroethene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Toluene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Trichloroethene	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/13/2005 10:51:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/13/2005 10:51:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051005:1405 NP2-10
Lab Order:	0505082	Tag Number:	6148
Project:	Rowe Industries	Collection Date:	5/10/2005
Lab ID:	0505082-03B	Date Received:	5/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	5.48	0.0200		mg/L	1	5/13/2005 11:11:18 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051005:1405 NP2-10
Lab Order:	0505082	Tag Number:	6148
Project:	Rowe Industries	Collection Date:	5/10/2005
Lab ID:	0505082-03C	Date Received:	5/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.406	0.0200		mg/L	1	5/13/2005 11:07:48 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	100	1.0		mg/L	1	5/16/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, May 24, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0505130

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 5/18/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0505130**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0505130-01A	WQ051605:0900 NP2-6	3218	5/16/2005	5/18/2005
0505130-01B	WQ051605:0900 NP2-6	3218	5/16/2005	5/18/2005
0505130-01C	WQ051605:0900 NP2-6	3218	5/16/2005	5/18/2005
0505130-02A	WQ051605:0902 NP2-7	3218	5/16/2005	5/18/2005
0505130-02B	WQ051605:0902 NP2-7	3218	5/16/2005	5/18/2005
0505130-02C	WQ051605:0902 NP2-7	3218	5/16/2005	5/18/2005
0505130-03A	WQ051605:0905 NP2-10	3218	5/16/2005	5/18/2005
0505130-03B	WQ051605:0905 NP2-10	3218	5/16/2005	5/18/2005
0505130-03C	WQ051605:0905 NP2-10	3218	5/16/2005	5/18/2005

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0900 NP2-6
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-01A	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,1,1-Trichloroethane	6.1	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
2-Butanone	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
2-Hexanone	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Acetone	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Benzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Bromobenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Bromoform	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Bromomethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Chloroethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ051605:0900 NP2-6
Lab Order: 0505130 **Tag Number:** 3218
Project: Rowe Industries **Collection Date:** 5/16/2005
Lab ID: 0505130-01A **Date Received:** 5/18/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Chloromethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Dibromomethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/19/2005 11:32:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Methylene chloride	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Naphthalene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
o-Xylene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Styrene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Tetrachloroethene	14	1.0		µg/L	1	5/19/2005 11:32:00 AM
Toluene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Trichloroethene	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/19/2005 11:32:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/19/2005 11:32:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0900 NP2-6
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-01B	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	4.30	0.0200		mg/L	1	5/19/2005 11:03:46 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 3 of 12

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0900 NP2-6
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-01C	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.196	0.0200		mg/L	1	5/19/2005 11:01:09 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 4 of 12

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0902 NP2-7
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-02A	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
2-Butanone	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
2-Hexanone	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Acetone	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Benzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Bromobenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Bromoform	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Bromomethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Chloroethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0902 NP2-7
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-02A	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Chloromethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Dibromomethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/19/2005 12:20:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Methylene chloride	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Naphthalene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
o-Xylene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Styrene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Toluene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Trichloroethene	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/19/2005 12:20:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/19/2005 12:20:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0902 NP2-7
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-02B	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	1.07	0.0200		mg/L	1	5/19/2005 11:09:27 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0902 NP2-7
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-02C	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.158	0.0200		mg/L	1	5/19/2005 11:05:54 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ051605:0905 NP2-10
 Lab Order: 0505130 Tag Number: 3218
 Project: Rowe Industries Collection Date: 5/16/2005
 Lab ID: 0505130-03A Date Received: 5/18/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
2-Butanone	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
2-Hexanone	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Acetone	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Benzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Bromobenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Bromoform	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Bromomethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Chloroethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0905 NP2-10
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-03A	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Chloromethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Dibromomethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/19/2005 1:08:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Methylene chloride	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Naphthalene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
o-Xylene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Styrene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Toluene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Trichloroethene	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/19/2005 1:08:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/19/2005 1:08:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0905 NP2-10
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-03B	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	2.18	0.0200		mg/L	1	5/19/2005 11:24:15 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 24-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ051605:0905 NP2-10
Lab Order:	0505130	Tag Number:	3218
Project:	Rowe Industries	Collection Date:	5/16/2005
Lab ID:	0505130-03C	Date Received:	5/18/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.178	0.0200		mg/L	1	5/19/2005 11:21:37 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	91	1.0		mg/L	1	5/19/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Monday, June 13, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0506002

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 6/1/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 13-Jun-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0506002

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0506002-01A	WQ052605:1620 NP2-6	4616	5/26/2005 4:20:00 PM	6/1/2005
0506002-02A	WQ052605:1625 NP2-7	4616	5/26/2005 4:25:00 PM	6/1/2005
0506002-03A	WQ052605:1630 NP2-10	4616	5/26/2005 4:30:00 PM	6/1/2005

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 13-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ052605:1620 NP2-6
Lab Order:	0506002	Tag Number:	4616
Project:	Rowe Industries	Collection Date:	5/26/2005 4:20:00 PM
Lab ID:	0506002-01A	Date Received:	6/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
2-Butanone	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
2-Hexanone	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Acetone	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Benzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Bromobenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Bromoform	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Bromomethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Chloroethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-Jun-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ052605:1620 NP2-6

Lab Order: 0506002

Tag Number: 4616

Project: Rowe Industries

Collection Date: 5/26/2005 4:20:00 PM

Lab ID: 0506002-01A

Date Received: 6/1/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Chloromethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Dibromomethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/2/2005 10:36:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Methylene chloride	U	1.0	B	µg/L	1	6/2/2005 10:36:00 AM
Naphthalene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
o-Xylene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Styrene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Tetrachloroethene	14	1.0		µg/L	1	6/2/2005 10:36:00 AM
Toluene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Trichloroethene	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/2/2005 10:36:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/2/2005 10:36:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank

H Holding times for preparation or analysis exceeded

ND Not Detected at the Reporting Limit

U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-Jun-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ052605:1625 NP2-7

Lab Order: 0506002

Tag Number: 4616

Project: Rowe Industries

Collection Date: 5/26/2005 4:25:00 PM

Lab ID: 0506002-02A

Date Received: 6/1/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
2-Butanone	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
2-Hexanone	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Acetone	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Benzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Bromobenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Bromoform	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Bromomethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Chloroethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank

H Holding times for preparation or analysis exceeded

ND Not Detected at the Reporting Limit

U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-Jun-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ052605:1625 NP2-7

Lab Order: 0506002

Tag Number: 4616

Project: Rowe Industries

Collection Date: 5/26/2005 4:25:00 PM

Lab ID: 0506002-02A

Date Received: 6/1/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Chloromethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Dibromomethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/2/2005 11:10:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Methylene chloride	U	1.0	B	µg/L	1	6/2/2005 11:10:00 AM
Naphthalene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
o-Xylene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Styrene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Tetrachloroethene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Toluene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Trichloroethene	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/2/2005 11:10:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/2/2005 11:10:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-Jun-05

CLIENT: Legette Brashears & Graham Inc.

Client Sample ID: WQ052605:1630 NP2-10

Lab Order: 0506002

Tag Number: 4616

Project: Rowe Industries

Collection Date: 5/26/2005 4:30:00 PM

Lab ID: 0506002-03A

Date Received: 6/1/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
2-Butanone	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
2-Hexanone	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Acetone	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Benzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Bromobenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Bromoform	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Bromomethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Chloroethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 13-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ052605:1630 NP2-10
 Lab Order: 0506002 Tag Number: 4616
 Project: Rowe Industries Collection Date: 5/26/2005 4:30:00 PM
 Lab ID: 0506002-03A Date Received: 6/1/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Chloromethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Dibromomethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/2/2005 11:43:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Methylene chloride	U	1.0	B	µg/L	1	6/2/2005 11:43:00 AM
Naphthalene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
o-Xylene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Styrene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Tetrachloroethene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Toluene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Trichloroethene	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/2/2005 11:43:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/2/2005 11:43:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, May 12, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0505045

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 9 sample(s) on 5/5/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0505045

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0505045-01A	GWQ0502:1135 NP1-1-1	3219	5/2/2005	5/5/2005
0505045-01B	GWQ0502:1135 NP1-1-1	3219	5/2/2005	5/5/2005
0505045-01C	GWQ0502:1135 NP1-1-1	3219	5/2/2005	5/5/2005
0505045-01D	GWQ0502:1135 NP1-1-1	3219	5/2/2005	5/5/2005
0505045-02A	GWQ0502:1150 NP1-1-2	3219	5/2/2005	5/5/2005
0505045-02B	GWQ0502:1150 NP1-1-2	3219	5/2/2005	5/5/2005
0505045-02C	GWQ0502:1150 NP1-1-2	3219	5/2/2005	5/5/2005
0505045-02D	GWQ0502:1150 NP1-1-2	3219	5/2/2005	5/5/2005
0505045-03A	GWQ0502:1205 NP1-1-3	3219	5/2/2005	5/5/2005
0505045-03B	GWQ0502:1205 NP1-1-3	3219	5/2/2005	5/5/2005
0505045-03C	GWQ0502:1205 NP1-1-3	3219	5/2/2005	5/5/2005
0505045-03D	GWQ0502:1205 NP1-1-3	3219	5/2/2005	5/5/2005
0505045-04A	GWQ0502:1120 NP1-1-4	3219	5/2/2005	5/5/2005
0505045-04B	GWQ0502:1120 NP1-1-4	3219	5/2/2005	5/5/2005
0505045-04C	GWQ0502:1120 NP1-1-4	3219	5/2/2005	5/5/2005
0505045-04D	GWQ0502:1120 NP1-1-4	3219	5/2/2005	5/5/2005
0505045-05A	GWQ0502:1100 NP1-1-5	3219	5/2/2005	5/5/2005
0505045-05B	GWQ0502:1100 NP1-1-5	3219	5/2/2005	5/5/2005
0505045-05C	GWQ0502:1100 NP1-1-5	3219	5/2/2005	5/5/2005
0505045-05D	GWQ0502:1100 NP1-1-5	3219	5/2/2005	5/5/2005
0505045-06A	GWQ0502:1046 NP1-1-6	3219	5/2/2005	5/5/2005
0505045-06B	GWQ0502:1046 NP1-1-6	3219	5/2/2005	5/5/2005
0505045-06C	GWQ0502:1046 NP1-1-6	3219	5/2/2005	5/5/2005
0505045-06D	GWQ0502:1046 NP1-1-6	3219	5/2/2005	5/5/2005
0505045-07A	GWQ0502:1038 NP1-1-7	3219	5/2/2005	5/5/2005
0505045-07B	GWQ0502:1038 NP1-1-7	3219	5/2/2005	5/5/2005
0505045-07C	GWQ0502:1038 NP1-1-7	3219	5/2/2005	5/5/2005
0505045-07D	GWQ0502:1038 NP1-1-7	3219	5/2/2005	5/5/2005
0505045-08A	GWQ0502:1015 NP1-1-8	3219	5/2/2005	5/5/2005
0505045-08B	GWQ0502:1015 NP1-1-8	3219	5/2/2005	5/5/2005
0505045-08C	GWQ0502:1015 NP1-1-8	3219	5/2/2005	5/5/2005
0505045-08D	GWQ0502:1015 NP1-1-8	3219	5/2/2005	5/5/2005
0505045-09A	GWQ0502:1000 NP1-1-9	3219	5/2/2005	5/5/2005
0505045-09B	GWQ0502:1000 NP1-1-9	3219	5/2/2005	5/5/2005
0505045-09C	GWQ0502:1000 NP1-1-9	3219	5/2/2005	5/5/2005
0505045-09D	GWQ0502:1000 NP1-1-9	3219	5/2/2005	5/5/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC 3219

NYSDOH 11418
CTDOH PH-0205
NJDEP NY050
PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBG 126 Monroe Turnpike Trumbull, CT 06611	CONTACT: Mark Goldberg	SAMPLER (SIGNATURE) Steve Silvestri (MUG)	SAMPLE(S) SEALED YES/NO
		SAMPLER NAME (PRINT) Steve Silvestri	CORRECT CONTAINER(S) YES/NO

PROJECT LOCATION: Rowe					ANALYSIS REQUIRED										FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)				
LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	8260	MBE	From 13	Total + Diss Fe	Total + Diss Mn	Hardness	Turbidity	TDS							
0505045-1AABD	L	5	5/2/05	GWQ0502:1135 NPI-1-1	✓	✓	✓	✓	✓	✓	✓	✓							
2ABCD				:1150 NPI-1-2	✓	✓	✓	✓	✓	✓	✓	✓							
3ABCD				:1205 NPI-1-3	✓	✓	✓	✓	✓	✓	✓	✓							
4ABCD				:1120 NPI-1-4	✓	✓	✓	✓	✓	✓	✓	✓							
5ABCD				:1100 NPI-1-5	✓	✓	✓	✓	✓	✓	✓	✓							
6ABCD				:1046 NPI-1-6	✓	✓	✓	✓	✓	✓	✓	✓							
7ABCD				:1038 NPI-1-7	✓	✓	✓	✓	✓	✓	✓	✓							
8ABCD				:1015 NPI-1-8	✓	✓	✓	✓	✓	✓	✓	✓							
9ABCD	✓	✓	✓	:1000 NPI-1-9	✓	✓	✓	✓	✓	✓	✓	✓							

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON				TURNAROUND REQUIRED: NORMAL ☒ STAT ☐ BY / /		COOLER TEMPERATURE:					
RELINQUISHED BY (SIGNATURE) Mark M. Goldberg		DATE 5/3/05 TIME 16:00		PRINTED NAME Mark M. Goldberg		RECEIVED BY LAB (SIGNATURE) GA		DATE 5/5/05 TIME 1225		PRINTED NAME P. Artoni	
RELINQUISHED BY (SIGNATURE)		DATE TIME		PRINTED NAME		RECEIVED BY LAB (SIGNATURE)		DATE TIME		PRINTED NAME	

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0505045

CASE NARRATIVE

Results for total and dissolved Metals where the dissolved is higher than the total but less than a 10% difference is acceptable precision following method EPA 200.7.

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0505045
Project: Rowe Industries
Lab ID: 0505045-01A

Client Sample ID: GWQ0502:1135 NP1-1-1
Tag Number: 3219
Collection Date: 5/2/2005
Matrix: LIQUID

Date Received: 5/5/2005

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						Analyst: RN
SW8260B						
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
2-Butanone	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
2-Hexanone	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Acetone	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Benzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Bromobenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Bromoform	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Bromomethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Chloroethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ0502:1135 NP1-1-1
Lab Order: 0505045 **Tag Number:** 3219
Project: Rowe Industries **Collection Date:** 5/2/2005
Lab ID: 0505045-01A **Date Received:** 5/5/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Chloromethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Dibromomethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/11/2005 5:43:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Methylene chloride	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Naphthalene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
o-Xylene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Styrene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Tetrachloroethene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Toluene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Trichloroethene	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/11/2005 5:43:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/11/2005 5:43:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1135 NP1-1-1
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-01B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	U	0.0200		mg/L	1	5/10/2005 11:15:42 AM
Manganese	0.103	0.0200		mg/L	1	5/10/2005 11:15:42 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1135 NP1-1-1
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-01C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	5/10/2005 11:13:31 AM
Manganese	0.102	0.0200		mg/L	1	5/10/2005 11:13:31 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1135 NP1-1-1
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-01D	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	52.4	M2340 B 1.00		mg/L	1	Analyst: JP 5/10/2005
TURBIDITY Turbidity	U	E180.1 1.00	H	NTU	1	Analyst: KK 5/6/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	270	E160.1 1.0		mg/L	1	Analyst: AT 5/9/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 5 of 45

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ0502:1150 NP1-1-2

Lab Order: 0505045

Tag Number: 3219

Project: Rowe Industries

Collection Date: 5/2/2005

Lab ID: 0505045-02A

Date Received: 5/5/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						Analyst: RN
SW8260B						
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
2-Butanone	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
2-Hexanone	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Acetone	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Benzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Bromobenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Bromoform	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Bromomethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Chloroethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 6 of 45

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ0502:1150 NP1-1-2
Lab Order: 0505045 **Tag Number:** 3219
Project: Rowe Industries **Collection Date:** 5/2/2005
Lab ID: 0505045-02A **Date Received:** 5/5/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Chloromethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Dibromomethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/6/2005 11:05:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Methylene chloride	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Naphthalene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
o-Xylene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Styrene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Tetrachloroethene	8.2	1.0		µg/L	1	5/6/2005 11:05:00 PM
Toluene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Trichloroethene	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/6/2005 11:05:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/6/2005 11:05:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1150 NP1-1-2
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-02B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	3.69	0.0200		mg/L	1	5/10/2005 11:22:02 AM
Manganese	0.942	0.0200		mg/L	1	5/10/2005 11:22:02 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1150 NP1-1-2
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-02C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.170	0.0200		mg/L	1	5/10/2005 11:20:04 AM
Manganese	0.993	0.0200		mg/L	1	5/10/2005 11:20:04 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1150 NP1-1-2
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-02D	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	50.5	1.00		mg/L	1	5/10/2005
TURBIDITY						Analyst: KK
Turbidity	3.00	1.00	H	NTU	1	5/6/2005
TOTAL DISSOLVED SOLIDS						Analyst: AT
Total Dissolved Solids (Residue, Filterable)	130	1.0		mg/L	1	5/9/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ0502:1205 NP1-1-3
Lab Order: 0505045 **Tag Number:** 3219
Project: Rowe Industries **Collection Date:** 5/2/2005
Lab ID: 0505045-03A **Date Received:** 5/5/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,1,1-Trichloroethane	2.8	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
2-Butanone	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
2-Hexanone	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Acetone	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Benzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Bromobenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Bromoform	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Bromomethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Chloroethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ0502:1205 NP1-1-3
Lab Order: 0505045 **Tag Number:** 3219
Project: Rowe Industries **Collection Date:** 5/2/2005
Lab ID: 0505045-03A **Date Received:** 5/5/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Chloromethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Dibromomethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/7/2005 1:41:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Methylene chloride	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Naphthalene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
o-Xylene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Styrene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Tetrachloroethene	2.2	1.0		µg/L	1	5/7/2005 1:41:00 AM
Toluene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Trichloroethene	7.7	1.0		µg/L	1	5/7/2005 1:41:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/7/2005 1:41:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/7/2005 1:41:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1205 NP1-1-3
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-03B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	1.85	0.0200		mg/L	1	5/10/2005 11:26:27 AM
Manganese	0.109	0.0200		mg/L	1	5/10/2005 11:26:27 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 13 of 45

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1205 NP1-1-3
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-03C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.820	0.0200		mg/L	1	5/10/2005 11:24:23 AM
Manganese	0.110	0.0200		mg/L	1	5/10/2005 11:24:23 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1205 NP1-1-3
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-03D	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	39.1	1.00		mg/L	1	5/10/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00	H	NTU	1	5/6/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	95	1.0		mg/L	1	5/9/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1120 NP1-1-4
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-04A	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,1,1-Trichloroethane	9.8	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
2-Butanone	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
2-Hexanone	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Acetone	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Benzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Bromobenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Bromoform	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Bromomethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Chloroethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ0502:1120 NP1-1-4
Lab Order: 0505045 **Tag Number:** 3219
Project: Rowe Industries **Collection Date:** 5/2/2005
Lab ID: 0505045-04A **Date Received:** 5/5/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Chloromethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Dibromomethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/7/2005 2:12:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Methylene chloride	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Naphthalene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
o-Xylene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Styrene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Tetrachloroethene	80	1.0		µg/L	1	5/7/2005 2:12:00 AM
Toluene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Trichloroethene	2.4	1.0		µg/L	1	5/7/2005 2:12:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/7/2005 2:12:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/7/2005 2:12:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1120 NP1-1-4
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-04B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	3.77	0.0200		mg/L	1	5/10/2005 11:32:29 AM
Manganese	1.63	0.0200		mg/L	1	5/10/2005 11:32:29 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 18 of 45

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1120 NP1-1-4
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-04C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0687	0.0200		mg/L	1	5/10/2005 11:29:00 AM
Manganese	1.63	0.0200		mg/L	1	5/10/2005 11:29:00 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1120 NP1-1-4
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-04D	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	34.3	1.00		mg/L	1	5/10/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	2.70	1.00	H	NTU	1	5/6/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	130	1.0		mg/L	1	5/9/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ0502:1100 NP1-1-5
 Lab Order: 0505045 Tag Number: 3219
 Project: Rowe Industries Collection Date: 5/2/2005
 Lab ID: 0505045-05A Date Received: 5/5/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,1,1-Trichloroethane	5.7	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
2-Butanone	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
2-Hexanone	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Acetone	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Benzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Bromobenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Bromoform	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Bromomethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Chloroethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1100 NP1-1-5
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-05A	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Chloromethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Dibromomethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/7/2005 2:44:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Methylene chloride	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Naphthalene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
o-Xylene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Styrene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Tetrachloroethene	13	1.0		µg/L	1	5/7/2005 2:44:00 AM
Toluene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Trichloroethene	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/7/2005 2:44:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/7/2005 2:44:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1100 NP1-1-5
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-05B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0223	0.0200		mg/L	1	5/10/2005 11:37:53 AM
Manganese	0.00782	0.0200	J	mg/L	1	5/10/2005 11:37:53 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1100 NP1-1-5
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-05C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	5/10/2005 11:35:54 AM
Manganese	0.00811	0.0200	J	mg/L	1	5/10/2005 11:35:54 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1100 NP1-1-5
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-05D	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	30.4	1.00		mg/L	1	5/10/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00	H	NTU	1	5/6/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	130	1.0		mg/L	1	5/9/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1046 NP1-1-6
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-06A	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,1,1-Trichloroethane	8.5	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
2-Butanone	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
2-Hexanone	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Acetone	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Benzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Bromobenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Bromoform	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Bromomethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Chloroethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ0502:1046 NP1-1-6
 Lab Order: 0505045 Tag Number: 3219
 Project: Rowe Industries Collection Date: 5/2/2005
 Lab ID: 0505045-06A Date Received: 5/5/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Chloromethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Dibromomethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/7/2005 3:15:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Methylene chloride	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Naphthalene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
o-Xylene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Styrene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Tetrachloroethene	96	1.0		µg/L	1	5/7/2005 3:15:00 AM
Toluene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Trichloroethene	2.8	1.0		µg/L	1	5/7/2005 3:15:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/7/2005 3:15:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/7/2005 3:15:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 27 of 45

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1046 NP1-1-6
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-06B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	U	0.0200		mg/L	1	5/10/2005 11:56:13 AM
Manganese	0.241	0.0200		mg/L	1	5/10/2005 11:56:13 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1046 NP1-1-6
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-06C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	5/10/2005 11:50:03 AM
Manganese	0.247	0.0200		mg/L	1	5/10/2005 11:50:03 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1046 NP1-1-6
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-06D	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	31.0	1.00		mg/L	1	5/10/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00	H	NTU	1	5/6/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	5/9/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1038 NP1-1-7
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-07A	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
2-Butanone	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
2-Hexanone	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Acetone	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Benzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Bromobenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Bromoform	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Bromomethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Chloroethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ0502:1038 NP1-1-7
Lab Order: 0505045 **Tag Number:** 3219
Project: Rowe Industries **Collection Date:** 5/2/2005
Lab ID: 0505045-07A **Date Received:** 5/5/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Chloromethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Dibromomethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/7/2005 3:46:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Methylene chloride	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Naphthalene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
o-Xylene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Styrene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Tetrachloroethene	30	1.0		µg/L	1	5/7/2005 3:46:00 AM
Toluene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Trichloroethene	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/7/2005 3:46:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/7/2005 3:46:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1038 NP1-1-7
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-07B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0200	0.0200		mg/L	1	5/10/2005 12:02:25 PM
Manganese	0.0476	0.0200		mg/L	1	5/10/2005 12:02:25 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1038 NP1-1-7
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-07C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	5/10/2005 11:59:31 AM
Manganese	0.0473	0.0200		mg/L	1	5/10/2005 11:59:31 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1038 NP1-1-7
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-07D	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	26.7	1.00		mg/L	1	5/10/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00	H	NTU	1	5/6/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	89	1.0		mg/L	1	5/9/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggett Brashears & Graham Inc. Client Sample ID: GWQ0502:1015 NP1-1-8
 Lab Order: 0505045 Tag Number: 3219
 Project: Rowe Industries Collection Date: 5/2/2005
 Lab ID: 0505045-08A Date Received: 5/5/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,1,1-Trichloroethane	5.2	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
2-Butanone	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
2-Hexanone	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Acetone	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Benzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Bromobenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Bromoform	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Bromomethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Chloroethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ0502:1015 NP1-1-8
Lab Order: 0505045 **Tag Number:** 3219
Project: Rowe Industries **Collection Date:** 5/2/2005
Lab ID: 0505045-08A **Date Received:** 5/5/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Chloromethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Dibromomethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/7/2005 4:18:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Methylene chloride	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Naphthalene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
o-Xylene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Styrene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Tetrachloroethene	5.6	1.0		µg/L	1	5/7/2005 4:18:00 AM
Toluene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Trichloroethene	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/7/2005 4:18:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/7/2005 4:18:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1015 NP1-1-8
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-08B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	7.33	0.0200		mg/L	1	5/10/2005 12:13:15 PM
Manganese	0.678	0.0200		mg/L	1	5/10/2005 12:13:15 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1015 NP1-1-8
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-08C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0733	0.0200		mg/L	1	5/10/2005 12:08:20 PM
Manganese	0.675	0.0200		mg/L	1	5/10/2005 12:08:20 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1015 NP1-1-8
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-08D	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	22.4	1.00		mg/L	1	5/10/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	2.10	1.00	H	NTU	1	5/6/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	82	1.0		mg/L	1	5/9/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1000 NP1-1-9
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-09A	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,1,1-Trichloroethane	9.0	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
2-Butanone	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
2-Hexanone	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Acetone	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Benzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Bromobenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Bromoform	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Bromomethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Chloroethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ0502:1000 NP1-1-9
 Lab Order: 0505045 Tag Number: 3219
 Project: Rowe Industries Collection Date: 5/2/2005
 Lab ID: 0505045-09A Date Received: 5/5/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Chloromethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Dibromomethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/7/2005 4:49:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Methylene chloride	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Naphthalene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
o-Xylene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Styrene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Tetrachloroethene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Toluene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Trichloroethene	2.9	1.0		µg/L	1	5/7/2005 4:49:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/7/2005 4:49:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/7/2005 4:49:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1000 NP1-1-9
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-09B	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	2.89	0.0200		mg/L	1	5/10/2005 12:22:36 PM
Manganese	1.05	0.0200		mg/L	1	5/10/2005 12:22:36 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1000 NP1-1-9
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-09C	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0596	0.0200		mg/L	1	5/10/2005 12:17:36 PM
Manganese	1.09	0.0200		mg/L	1	5/10/2005 12:17:36 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-May-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ0502:1000 NP1-1-9
Lab Order:	0505045	Tag Number:	3219
Project:	Rowe Industries	Collection Date:	5/2/2005
Lab ID:	0505045-09D	Date Received:	5/5/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	22.8	1.00		mg/L	1	5/10/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	3.70	1.00	H	NTU	1	5/6/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AT
Total Dissolved Solids (Residue, Filterable)	87	1.0		mg/L	1	5/9/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

ANALYTICAL REPORT

JOB NUMBER: 209425

Prepared For:

LEGGETTE, BRASHEARS & GRAHAM
126 Monroe Turnpike
Trumbull, CT 06611

Project: ROWE INDUSTRIES

Attention: Mark Goldberg

Date: 05/12/2005


Signature

Name: William D. Goodman

Title: Project Manager

E-Mail: wgoodman@stl-inc.com

5/16/2005
Date

STL Connecticut
128 Long Hill Cross Road
Shelton, CT 06484

This Report Contains (103) Pages

STL Report : 209425
LEGGETTE, BRASHEARS & GRAHAM

Case Narrative

Sample Receipt – All samples were received in good condition.

Volatile Organics – Air volatile organics were determined by purge and trap GC/MS using guidance provided in Method TO-17. The instrumentation used was a Perkin Elmer ATD 50 interfaced with a Hewlett-Packard Model 5972A GC/MS/DS.

The samples in this job were collected in tedlar bags. Samples were transferred by the laboratory to Air Toxic TO-17 tubes and analyzed at sample volumes of 1L except for sample AQ050205:1405NP4-1 which was analyzed at a sample volume of .25L for high targets.

Sample Calculation:

Sample ID- AQ050205:1405NP4-1
Compound-Bromomethane

$$\frac{(29853 \text{ area})(25\text{ng})}{(337100 \text{ area})(.231 \text{ area/ng})} = 9.58 = 10 \text{ ng}$$

$$\frac{(10\text{NG})(.08206)(298)}{(.25\text{L})(95)(1.0\text{ATM})} = 10.29 = 10.3 \text{ nL/L.}$$

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in the case narrative.

Date: 05/12/2005

Project Number.....: 20000283
Customer Project ID....: ROWE INDUSTRIES
Project Description....: Rowe Industries

Page 1

STL Connecticut		Form 1		
		Client Sample ID	AQ050205:1405NP4-1	
Method: T017		Lab Sample ID	209425-1	
Sample Volume (L)	0.250	Date Sampled	5/2/2005	
Temp (C)	25	Date Analyzed	5/4/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	38.7 U	38.7	0.0800 U	0.080
Vinyl Chloride	31.3 U	31.3	0.0800 U	0.080
Bromomethane	10.3 JB	20.6	0.0400 JB	0.080
Chloroethane	30.3 U	30.3	0.0800 U	0.080
1,1-Dichloroethene	10.1 U	10.1	0.0400 U	0.040
Carbon Disulfide	12.9 U	12.9	0.0400 U	0.040
Methylene Chloride	6.9 J	11.5	0.0240 J	0.040
trans-1,2-Dichloroethene	10.2 U	10.2	0.0400 U	0.040
1,1-Dichloroethane	9.9 U	9.9	0.0400 U	0.040
cis-1,2-Dichloroethene	10.2 U	10.2	0.0400 U	0.040
Chloroform	8.2 U	8.2	0.0400 U	0.040
1,1,1-Trichloroethane	21.3	7.4	0.1160	0.040
Carbon Tetrachloride	6.4 U	6.4	0.0400 U	0.040
Benzene	2.5 JB	12.5	0.0080 JB	0.040
1,2-Dichloroethane	9.9 U	9.9	0.0400 U	0.040
Trichloroethene	6.0 J	7.5	0.0320 J	0.040
1,2-Dichloropropane	8.7 U	8.7	0.0400 U	0.040
Bromodichloromethane	6.0 U	6.0	0.0400 U	0.040
cis-1,3-Dichloropropene	8.8 U	8.8	0.0400 U	0.040
Toluene	6.4 J	10.6	0.0240 J	0.040
trans-1,3-Dichloropropene	8.8 U	8.8	0.0400 U	0.040
1,1,2-Trichloroethane	7.4 U	7.4	0.0400 U	0.040
Tetrachloroethene	76.6	5.9	0.5200	0.040
Dibromochloromethane	4.7 U	4.7	0.0400 U	0.040
Chlorobenzene	8.7 U	8.7	0.0400 U	0.040
Ethylbenzene	9.2 U	9.2	0.0400 U	0.040
m&p-Xylenes	9.2 U	9.2	0.0400 U	0.040
o-Xylene	9.2 U	9.2	0.0400 U	0.040
Styrene	9.4 U	9.4	0.0400 U	0.040
Bromoform	3.9 U	3.9	0.0400 U	0.040
1,1,2,2-Tetrachloroethane	5.8 U	5.8	0.0400 U	0.040

STL Connecticut		Form 1	
Method: T017		Client Sample ID	AQ050205:1410NP4-2
Sample Volume (L)		Lab Sample ID	209425-2
Temp (C)		Date Sampled	5/2/2005
25		Date Analyzed	5/4/2005
nL/L			
Compound	(ppbv/v) Qualifier	RL	mg/M3 Qualifier RL
Chloromethane	9.7 U	9.7	0.0200 U 0.020
Vinyl Chloride	7.8 U	7.8	0.0200 U 0.020
Bromomethane	2.6 JB	5.1	0.0100 JB 0.020
Chloroethane	7.6 U	7.6	0.0200 U 0.020
1,1-Dichloroethene	1.3 J	2.5	0.0050 J 0.010
Carbon Disulfide	3.2 U	3.2	0.0100 U 0.010
Methylene Chloride	1.7 J	2.9	0.0060 J 0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.0100 U 0.010
1,1-Dichloroethane	2.5 U	2.5	0.0100 U 0.010
cis-1,2-Dichloroethene	0.8 J	2.5	0.0030 J 0.010
Chloroform	1.4 J	2.1	0.0070 J 0.010
1,1,1-Trichloroethane	15.6	1.8	0.0850 0.010
Carbon Tetrachloride	1.6 U	1.6	0.0100 U 0.010
Benzene	0.3 JB	3.1	0.0010 JB 0.010
1,2-Dichloroethane	2.5 U	2.5	0.0100 U 0.010
Trichloroethene	1.9 U	1.9	0.0100 U 0.010
1,2-Dichloropropane	2.2 U	2.2	0.0100 U 0.010
Bromodichloromethane	1.5 U	1.5	0.0100 U 0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.0100 U 0.010
Toluene	4.2	2.7	0.0160 0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.0100 U 0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.0100 U 0.010
Tetrachloroethene	1.5 U	1.5	0.0100 U 0.010
Dibromochloromethane	1.2 U	1.2	0.0100 U 0.010
Chlorobenzene	2.2 U	2.2	0.0100 U 0.010
Ethylbenzene	2.3 U	2.3	0.0100 U 0.010
m&p-Xylenes	2.3 U	2.3	0.0100 U 0.010
o-Xylene	2.3 U	2.3	0.0100 U 0.010
Styrene	2.4 U	2.4	0.0100 U 0.010
Bromoform	1.0 U	1.0	0.0100 U 0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.0100 U 0.010

STL Connecticut		Form 1		
		Client Sample ID	AQ050205:1415NP4-3	
Method: T017		Lab Sample ID	209425-3	
Sample Volume (L)	1.000	Date Sampled	5/2/2005	
Temp (C)	25	Date Analyzed	5/4/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	9.7 U	9.7	0.0200 U	0.020
Vinyl Chloride	7.8 U	7.8	0.0200 U	0.020
Bromomethane	0.5 JB	5.1	0.0020 JB	0.020
Chloroethane	7.6 U	7.6	0.0200 U	0.020
1,1-Dichloroethene	1.8 J	2.5	0.0070 J	0.010
Carbon Disulfide	3.9	3.2	0.0120	0.010
Methylene Chloride	2.0 J	2.9	0.0070 J	0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.0100 U	0.010
1,1-Dichloroethane	4.0	2.5	0.0160	0.010
cis-1,2-Dichloroethene	2.5 U	2.5	0.0100 U	0.010
Chloroform	1.8 J	2.1	0.0090 J	0.010
1,1,1-Trichloroethane	5.5	1.8	0.0300	0.010
Carbon Tetrachloride	1.6 U	1.6	0.0100 U	0.010
Benzene	3.1 B	3.1	0.0100 B	0.010
1,2-Dichloroethane	2.5 U	2.5	0.0100 U	0.010
Trichloroethene	1.9 U	1.9	0.0100 U	0.010
1,2-Dichloropropane	2.2 U	2.2	0.0100 U	0.010
Bromodichloromethane	1.5 U	1.5	0.0100 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.0100 U	0.010
Toluene	5.0	2.7	0.0190	0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.0100 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.0100 U	0.010
Tetrachloroethene	1.5 U	1.5	0.0100 U	0.010
Dibromochloromethane	1.2 U	1.2	0.0100 U	0.010
Chlorobenzene	2.2 U	2.2	0.0100 U	0.010
Ethylbenzene	2.3 U	2.3	0.0100 U	0.010
m&p-Xylenes	0.2 J	2.3	0.0009 J	0.010
o-Xylene	2.3 U	2.3	0.0100 U	0.010
Styrene	2.4 U	2.4	0.0100 U	0.010
Bromoform	1.0 U	1.0	0.0100 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.0100 U	0.010

LABORATORY CHRONICLE

Job Number: 209425

Date: 05/12/2005

CUSTOMER: LEGGETTE, BRASHEARS & GRAHAM

PROJECT: ROWE INDUSTRIES

ATTN: Mark Goldberg

Lab ID: 209425-1 Client ID: AQ050205:1405NP4-1
METHOD DESCRIPTION
T017 Volatile Organics (Air)

Date Recvd: 05/03/2005 Sample Date: 05/02/2005
RUN# BATCH# PREP BT #(S) DATE/TIME ANALYZED DILUTION
1 48342 05/05/2005 0941 1.00000

Lab ID: 209425-2 Client ID: AQ050205:1410NP4-2
METHOD DESCRIPTION
T017 Volatile Organics (Air)

Date Recvd: 05/03/2005 Sample Date: 05/02/2005
RUN# BATCH# PREP BT #(S) DATE/TIME ANALYZED DILUTION
1 48342 05/04/2005 1810 1.00000

Lab ID: 209425-3 Client ID: AQ050205:1415NP4-3
METHOD DESCRIPTION
T017 Volatile Organics (Air)

Date Recvd: 05/03/2005 Sample Date: 05/02/2005
RUN# BATCH# PREP BT #(S) DATE/TIME ANALYZED DILUTION
1 48342 05/04/2005 1846 1.00000

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC. Lab Cert. ID# 10604
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviation

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the reporting limit.
- < Not detected at or above the reporting limit.
- J Result is less than the RL, but greater than or equal to the method detection limit.
- B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
- S Result was determined by the Method of Standard Additions.

Inorganic Flags (Flag Column)

- ICV,CCV,ICB,CCB,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed the upper or lower control limits.
- * LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
- + MSA correlation coefficient is less than 0.995.
- 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
- E SD: Serial dilution exceeds the control limits.
- H MB, EB: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
- N MS, MSD: Spike recovery exceeds the upper or lower control limits.
- W PS: Post-digestion spike was outside 85-115% control limits.

Organic Qualifiers (Q - Column)

- U Analyte was not detected at or above the reporting limit.
- ND Compound not detected.
- J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
- Q Result was qualitatively confirmed, but not quantified.
- C Pesticide identification was confirmed by GC/MS.
- Y The chromatographic response resembles a typical fuel pattern.
- Z The chromatographic response does not resemble a typical fuel pattern.
- E Result exceeded calibration range, secondary dilution required.

Organic Flags (Flags Column)

- MB,EB, MLE: Batch QC is greater than reporting limit.
- * LCS, LCD, CCV, MS, MSD, Surrogate, RS:Batch QC exceeds the upper or lower control limits.
- A Concentration exceeds the instrument calibration range or below the reporting limit.
- B Compound was found in the blank.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is greater than 25%.

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Abbreviations

Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column
CCB	Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation Analysis
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
Dil Fac	Dilution Factor
DL	Secondary dilution and analysis
DLFac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB	Extraction Blank
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A
ISB	Interference Check Sample B
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group
Lab ID	An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PACK	Packed Column
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PS	Post Spike
PSD	Post Spike Duplicate
RA	Re-analysis
RE	Re-extraction and analysis
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RS	Reference Standard
RT	Retention Time
RTW	Retention Time Window
SampleID	A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB	Seeded Control Blank
SD	Serial Dilution
UCB	Unseeded Control Blank

One or a combination of these data qualifiers and abbreviations may appear in the analytical report.

STL-Connecticut

Certification Summary (as of May 2005)

The laboratory identification numbers for the STL-Connecticut laboratory are provided in the following table. Many states certify laboratories for specific parameters or tests within a category (i.e. method 325.2 for wastewater). The information in the following table indicates the lab is certified in a general category of testing such as drinking water or wastewater analysis. The laboratory should be contacted directly if parameter-specific certification information is required.

State	Responsible Agency	Certification	Expiration Date	Lab Number
Connecticut	Department of Health Services	Drinking Water, Wastewater	12/31/06	PH-0497
Maine	Department of Health and Environmental Services	Drinking Water, Wastewater/Solid, Hazardous Waste	04/18/06	CT023
Massachusetts	Department of Environmental Protection	Potable/Non-Potable Water	06/30/05	CT023
New Hampshire	Department of Environmental Services	Drinking Water, Wastewater	08/29/05	2528
New Jersey	Department of Environmental Protection	Drinking Water, Wastewater	06/30/05	CT410
New York	Department of Health	CLP, Drinking Water, Wastewater, Solid/ Hazardous Waste NELAC	04/01/06	10602
Rhode Island	Department of Health	Chemistry...Non-Potable Water and Wastewater	12/30/05	A43
Utah	Department of Health	RCRA	05/31/05	2032614458

OFFICES LOCATED IN:

MASSACHUSETTS • CONNECTICUT • NEW YORK • NEW JERSEY
PENNSYLVANIA • FLORIDA • OHIO • WISCONSIN • ILLINOIS • MISSOURI
MINNESOTA • TEXAS • SOUTH DAKOTA