



LBG ENGINEERING SERVICES, P.C.

Professional Environmental & Civil Engineers



126 Monroe Turnpike
Trumbull, CT 06611
(203) 452-3110
(203) 452-3119 (FAX)

August 12, 2005



Mr. Jeffery Trad
Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation, Construction Services
625 Broadway, 12th floor
Albany, NY 12233-7013

RE: June 2005 Status Report
Ground-Water Remedial Action
Rowe Industries Superfund Site
Sag Harbor, New York

Dear Mr. Trad:

The enclosed letter report details the operation status of the full-scale ground-water pump and treat system at the above referenced site. LBG has enclosed an additional copy of the report to be forwarded to the Chief of the Operation Maintenance and Support Section.

Should you or the Operation Maintenance and Support Section have any questions, please feel free to contact myself, Paul Jobmann, or Al Kovalik at (203) 452-3100.

Very truly yours,

LEGGETTE, BRASHEARS & GRAHAM, INC.

A handwritten signature in cursive script that reads 'Mark M. Goldberg'. The signature is written in black ink and is positioned above the printed name.

Mark M. Goldberg, P.E.
Senior Environmental Engineer

MG:ng

Enclosures

H:\NABIS\2005\Monthly Reports\June 2005\trad_June2005_report.doc

-DRAFT-


PROJECT STATUS MEMORANDUM

NO. 06-05

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Alfred N. Kovalik, P.E.

DATE: August 11, 2005



PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
June 2005 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from June 1, 2005 through June 30, 2005. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground-water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(June 1, 2005 through June 30, 2005)

- | | |
|---|-----------------------------------|
| 1. Hours of operation during the reporting period: | 360 hours (50%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 8,359,000 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 1.0 pound |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 167.1 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.198 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00188 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well*	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow (gpm)	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-1	173,862	9.8	26	4.0	0.006
RW-2	593,811	26.9	26	15.0	0.07
RW-3	135,561	9.7	23	0	0
RW-4	149,334	43.7	13	76.6	0.10
RW-5	1,235,952	55.0	42	4.7	0.05
RW-6	289,102	19.8	28	85.7	0.21
RW-7	1,223,646	69.9	54	40.3	0.41
RW-8	1,236,225	57.0	46	12.3	0.13
RW-9	1,564,839	77.1	68	7.9	0.10

* In addition to the downtime for the system from alarms and maintenance activities, recovery wells RW-3, RW-4 and RW-7 were not in operation for additional time because of well rehabilitation activities. Well rehabilitation for RW-3 occurred from June 9-16. Well rehabilitation for RW-4 occurred from June 16-30. Well rehabilitation for RW-7 started on June 30. Well rehabilitation for RW-2 and RW-9 occurred while the system was not operating.

Recovery wells RW-1, RW-3 and RW-6 had average flows below the respective minimum design flows determined to be necessary for capture of the plume. Despite periodic pipe cleanings, RW-1 and RW-3 have decreased in flow due to iron build-up in the below-grade pipes. In addition, well rehabilitation activities for RW-3 did not restore the yield of the well. New cleanout ports in the below grade piping between RW-3 and the remediation building were constructed in June to try and jet wash previously inaccessible sections of piping to attempt to restore the flow from RW-3. Jet wash cleaning from these new clean-out ports will be scheduled in August. Because chlorinated volatile organic compound (CVOC) concentrations in the ground water at RW-1 continue to be non-detect, the restoration of flow from this well is not a top priority. Flow from RW-2 increased because of well rehabilitation activities.

Well rehabilitation activities at RW-6 did not improve the specific capacity of this well. In addition, cleaning the RW-6 flow meter, vault piping and below-grade piping in the vicinity of RW-6 did not restore the flow to historic levels. Ground-water drawdown continues to be very high at this well. Debris and/or bacteria build-up in the formation in conjunction with the finer soils

associated with the aquifer in the immediate vicinity of RW-6 may be the root cause of the decreasing well yield. Other well rehabilitation techniques have been investigated, however, because of the limited chance for success (for increasing the well yield), further well rehabilitation efforts for RW-6 are on hold. The flow in RW-6 was reduced from 25 gpm to 15 gpm to reduce excessive ground-water drawdown in the well, which could de-water the pump.

A large increase in flow at RW-9 was observed due to the cleaning of the below grade piping near RW-9 from the two new clean-out ports. Build-up in the below-grade piping in the vicinity of the new cleanout ports reduced the available cross-sectional area of the pipe from a 3 inch diameter to an approximate 0.5 inch diameter . In addition, a new pump and motor were installed at RW-9.

The effluent pH values are below the State Pollutant Discharge Elimination System (SPDES) Applicable or Relevant and Appropriate Requirements (ARARs) of 6.5 on a routine basis. June pH readings of water samples from the recovery wells were observed to be in the range of approximately 4.2 to 6.0. The pH of 4.2 was taken from RW-3 immediately after well rehabilitation activities, therefore, the pH may have been impacted by the well rehabilitation chemicals. The FSP&T system does not use any chemical treatment processes to alter pH. In addition, the effluent water discharge and the recovery well extraction points are located in the same aquifer. As discussed with the New York State Department of Environmental Conservation (NYSDEC), because the pH is naturally occurring, it is not considered an exceedance of the discharge requirements.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
June 1 to June 30	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M MODIFICATIONS AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in June 2005 include:

- From May 26 to June 8, 2005, well rehabilitation for RW-9 was completed. During well rehabilitation activities, a leaking union was replaced, however, a leaking ball valve in the RW-9 vault was observed. A new ball valve has been ordered.
- From June 3-9, 2005, well rehabilitation for RW-2 was completed.
- From June 9-16, 2005, well rehabilitation for RW-3 was completed.
- On June 13, 2005, two cleanout ports were constructed on Noyac Road near RW-9. In addition, the 90-degree elbow in the trunk line on Noyac Road was replaced with two

45-degree elbows to allow the jet washing equipment to negotiate the bends more effectively. Jet wash cleaning of the below-grade piping from these two cleanout ports was completed following their construction.

- On June 16, 2005, ground-water samples from wells in the Former Drum Storage Area (FDSA) were collected to monitor the performance of the EHC™.
- From June 16-30, 2005, well rehabilitation for RW-4 was completed.
- On June 22, 2005, air stripper blower (ASB) and booster blower (BB) maintenance was conducted. Maintenance activities included replacing bearings, shafts, belts, shivs and wheels on the blowers. In addition, alignment and balancing of the ASB and BB were completed.
- On June 22, 2005, malfunctioning wellhead pressure sensors at RW-2 and RW-9 were replaced. A fuse in the RW-5 control panel was replaced.
- On June 30, 2005, well rehabilitation for RW-7 began. Water level measurements in RW-6 were collected with a mini-troll to compare the readings with the system computer.

Future O&M activities scheduled for summer 2005 include:

- Complete well rehabilitation for RW-7;
- Conduct a safety inspection for the site;
- Construct two clean-out ports between RW-3 and the remediation building;
- Switch lead-lag pumps;
- Remove sediment from the air stripper tower sump, equalization tank and transfer tank;
- Conduct cove salinity monitoring and water level measurements at select piezometers in July; and
- Repair a leak at a ball valve in the RW-9 vault.

MMG:ng

Attachments

cc: Phil McAndrew, Kraft Foods, N.A. – .pdf
Lisa Krogman, Kraft Foods, N.A. (Environ) – .pdf
Jeff Trad, NYSDEC
Chief-Operation Maintenance and Support Section, NYSDEC
William Spitz, RWM, R-1, NYSDEC
Eileen A. Powers, Jr., Esq., Town of Southampton

H:\NABIS\2005\Monthly Reports\June 2005\Status0605June.doc

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(June 1, 2005 through June 30, 2005)

Date	Time	System Changes/Modifications	Personnel
6/1/2005		The system was powered down and de-energized on May 23rd for keyspan gas main construction work. The system remains shut down.	
6/2/2005		While keeping the power to the recovery wells de-energized, the system was turned on to treat purged water from well rehabilitation activities.	TS, ETL
6/3/2005		Well rehabilitation for RW-2 begins.	SS, ETL
6/5/2005	1:41 PM	Control Room Temperature Alarm.	
	6:16 PM	The alarm reset itself. The system remains shut down for Keyspan work.	
6/9/2005		While keeping the power to the recovery wells de-energized, the system was turned on to treat purged water from well rehabilitation activities.	SS, ETL
		RW-2 rehabilitation is completed and RW-3 rehabilitation begins.	SS, ETL
6/10/2005		While keeping the power to the recovery wells de-energized, the system was turned on to treat purged water from well rehabilitation activities. The Keyspan work was completed, however, the system was kept off for construction of two new clean-out ports near RW-9. Preparation work conducted for the construction of the cleanout ports including evacuating standing water in the below-grade pipes.	SS, ETL
6/13/2005		Construct two new clean-out ports on Noyac Road near RW-9.	SS, ETL
6/14/2005	1:05 PM	Low temperature alarm.	
	1:22 PM	Restarted the system (except for RW-3).	TS, ETL
	1:40 PM	Reset the low temperature alarm (the system was still operating). The temperature is warm so the cause of the low temperature alarm will be investigated. The activated alarm may be the high temperature alarm, even though the computer programming and labeling of the alarm indicates the low temperature alarm. The exhaust fan appears to be working adequately.	TS
6/15/2005		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS
6/16/2005	9:15 PM	RW-3 rehabilitation is completed and RW-4 rehabilitation begins. Power Failure Alarm, RW-1, 2, 3, 5, 6 and 8 pump fault alarms and control room temperature alarm.	TS, ETL
6/17/2005	7:30 AM	Reset alarms and restarted the recovery wells.	SS
6/22/2005	9:20 AM	Shut down system for ASB and BB maintenance activities. ACFM Dyanmics onsite.	MMG, ACFM Dynamics
		Maintenance activities included, replacing bearings, shafts, belts, shivs and wheels on the blowers. Alignment and balancing of the blowers was also completed.	ACFM Dynamics
		Replaced RW-2 and RW-9 wellhead pressure sensors.	MMG
		Replaced fuse in the RW-5 control panel.	MMG
	4:55 PM	Restarted the system.	MMG

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(June 1, 2005 through June 30, 2005)

Date	Time	System Changes/Modifications	Personnel
6/24/2005		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS
		Greased pumps TP1A and TP2A.	SS
6/26/2005	9:00 AM	System Communication Failure.	
6/27/2005	10:20 AM	Rebooted the system, reset the alarms and restarted the system.	TS
6/28/2005		The well yield in RW-6 has slowly decreased over time. To avoid de-watering the pump from excessive ground-water drawdown, the flow setpoint has been reduced to 15 gpm. Investigation into alternate well rehabilitation methods was conducted, however, due to the limited chance for success for increasing the well yield, further rehabilitation efforts for RW-6 are on hold. Water level measurements with a mini-troll device will be compared to computer readings and manual water level measurements to confirm if water drawdown is approaching the top of the pump in this well.	TS
6/29/2005	10:40 AM	RW-1, 2, 3, 6, 8 and 9 pump fault alarms, power failure alarm, and control room temperature alarm.	
	10:46 AM	Reset drives, reset alarms and restarted the wells.	TS
	11:05 AM	Turned off RW-6 so water levels can be measured the following day starting at static conditions.	TS
6/30/2005	9:32 AM	RW-4 well rehabilitation completed, RW-7 well rehabilitation begins.	ETL, TS
	11:40 AM	Booster Blower Failure Alarm.	
	12:09 PM	Reset motor starter, reset alarm and restarted the system	SS, TS
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS, TS
		Conducted water level test with mini-troll in RW-6.	SS, TS

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

EFFLUENT WATER QUALITY RESULTS

Date Sampled	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo-chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	6.5 to 8.5	---	1	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
2-Jun-05	5.8	960 ^{3/}	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	38.7 ^{3/}	19.8 ^{3/}
10-Jun-05	6.1	1,200 ^{3/}	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	42.8 ^{3/}	42.0 ^{3/}
15-Jun-05	5.3	240 ^{4/}	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	33 ^{5/}	ND<1.0	ND<1.0	45.0 ^{4/}	1.49
24-Jun-05	5.3	130	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.09	0.131
30-Jun-05	5.3	130	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	10.5 ^{4/}	0.362

SPDES: State Pollutant Discharge Elimination System
 mg/l: Milligrams per liter
 ug/l: Micrograms per liter
 ---: Not established

NM: Not Measured
 TDS: Total dissolved solids
 PCE: Tetrachloroethylene
 TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane
 1,1-DCE: 1,1-Dichloroethene
 1,2-DCE: 1,2-Dichloroethene
 MTBE: Methyl tert-butyl ether

Notes:

- pH was measured using litmus paper. Influent pH values from recovery wells, which reflect the pH of natural ground water, are below 6.5 on a regular basis.
- "Effluent" samples were collected from sample port labeled NP2-10.
- The TDS, total iron and dissolved iron concentrations were elevated during these sampling events because purged water from well rehabilitation activities was being processed through the system. The FSP&T system was de-energized (not operating) from June 1 to June 10 to allow Keyspan to construct a new gas main on Brick Kiln Road.
- The TDS and total iron concentrations were elevated during these sampling events because purged water from well rehabilitation activities was being processed through the system while the FSP&T system was in operation.
- The acetone detected in the June 15, 2005 effluent system sample is suspected to be from laboratory contamination.

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	Isopropylbenzene	1,1-Dichloroethane	cis-1,2-Dichloroethene	1,1-Dichloroethene	Methylene Chloride	Bromoform	Dibromochloromethane	Naphthalene	
		(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(mg/L)	(mg/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE	
RW-1	23-Apr-03	ND<1	ND<1	ND<1	ND<1	1.2	8.6	0.053	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	ND<1	ND<1	ND<1	ND<1	1.8	8.7	0.051	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1	ND<1	
	11-Jun-03	ND<1	ND<1	ND<1	ND<1	ND<1	8.1	0.0290	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	ND<1	ND<1	ND<1	ND<1	2.9	6.6	0.0100	0.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	ND<1	ND<1	ND<1	ND<1	2.6	9.4	0.0930	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	ND<1	ND<1	ND<1	ND<1	3.2	14	0.0540	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0613	0.0074	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	ND<1	ND<1	ND<1	ND<1	2.2	9.4	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	ND<1	ND<1	ND<1	ND<1	4.0	2.2	0.0098	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	ND<1	ND<1	ND<1	4.6	5.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	ND<1	ND<1	ND<1	ND<1	4.1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.5
	14-Apr-04	ND<1	ND<1	ND<1	ND<1	2.9	6.1	0.0240	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	ND<1	ND<1	ND<1	ND<1	5.6	6.8	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	6.1 *	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	2.0	3.4	0.0454	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	ND<1	ND<1	ND<1	ND<1	ND<1	3.1	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	8.0
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-2	23-Apr-03	14	1.3	ND<1	ND<1	ND<1	ND<1	6.31	0.212	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	21	2	ND<1	ND<1	ND<1	3.8	5.51	0.052	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1	
	11-Jun-03	15	0.6	ND<1	ND<1	ND<1	ND<1	3.01	0.885	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	5.34	0.438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	7.9	ND<1	ND<1	ND<1	ND<1	ND<1	5.99	0.758	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	9.2	0.5	ND<1	ND<1	ND<1	ND<1	6.0	0.899	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	8.1	0.7	ND<1	ND<1	ND<1	ND<1	6.79	0.101	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	5.5	ND<1	ND<1	ND<1	ND<1	5.5	5.46	0.0213	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	8.7	ND<1	ND<1	ND<1	ND<1	1.1	5.57	0.207	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	5.4	ND<1	ND<1	ND<1	ND<1	3.9	3.77	0.0748	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	4.9	ND<1	ND<1	ND<1	ND<1	3.3	0.343	0.318	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	4.4	ND<1	ND<1	ND<1	ND<1	2.8	5.59	0.224	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1	
	5-May-04	8.2	ND<1	ND<1	ND<1	ND<1	4.7	4.5	0.691	ND<1	ND<1	ND<1	ND<1	5.6 *	ND<1	ND<1	ND<1	
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	52.5	1.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	6.5	ND<1	ND<1	ND<1	ND<1	1.3	4.88	0.704	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	1.5	4.78	0.213	ND<1	ND<1	ND<1	ND<1	ND<1	2.1	1.5	ND<1	
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
2-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
16-Jun-05	12.0	ND<1	1.0	ND<1	ND<1	ND<1	3.5	0.0511	ND<1	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	ND<1		

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	Isopropylbenzene	1,1-Dichloroethane	cis-1,2-Dichloroethene	1,1-Dichloroethene	Methylene Chloride	Bromoform	Dibromochloromethane	Naphthalene	
		(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(mg/L)	(mg/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)
ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE	NE	
RW-3	23-Apr-03	1.1	1.2	ND<1	ND<1	ND<1	ND<1	1.81	0.395	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	2.2	2.5	1.1	ND<1	ND<1	ND<1	1.68	0.166	ND<1	ND<1	ND<1	ND<1	3.7	ND<1	ND<1	ND<1	
	11-Jun-03	2.4	3.4	1.8	ND<1	ND<1	ND<1	2.37	0.517	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	2.3	5.7	2.3	ND<1	ND<1	ND<1	1.77	0.636	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	2.8	5.8	2.9	ND<1	ND<1	ND<1	2.24	1.57	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	2.1	5.3	2.6	ND<1	ND<1	ND<1	1.86	1.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	1.9	5.2	3.3	ND<1	ND<1	ND<1	2.59	1.27	ND<1	ND<1	0.6	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	1.2	5.8	ND<1	ND<1	ND<1	ND<1	1.96	0.129	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	2.2	6.9	3.2	ND<1	ND<1	ND<1	1.96	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	ND<1	3.6	2.2	ND<1	ND<1	ND<1	1.63	1.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	1.2	5.0	2.3	ND<1	ND<1	ND<1	3.34	0.542	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	28-Apr-04	1.3	8.8	4.4	ND<1	ND<1	ND<1	3.07	1.32	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	
	5-May-04	0.9	6.9	3.6	ND<1	ND<1	ND<1	2.07	1.96	ND<1	ND<1	ND<1	ND<1	5.6*	ND<1	ND<1	ND<1	
	30-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.619	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	2.4	6.1	2.6	ND<1	ND<1	ND<1	2.07	1.79	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	2.7	21	8.7	ND<1	ND<1	ND<1	1.91	0.42	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Oct-04	2.2	12	5.0	ND<1	ND<1	ND<1	2.09	1.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	1.5	6.5	2.6	ND<1	ND<1	ND<1	1.87	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.77	0.489	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	3	13	5.0	ND<1	ND<1	ND<1	1.89	1.36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	46.1	0.539	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	2.2	7.7	2.8	ND<1	ND<1	ND<1	1.85	0.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	9.91	10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-4	23-Apr-03	110	3.1	ND<1	ND<1	ND<1	ND<1	3.18	0.136	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	170	5.4	1.0	ND<1	ND<1	ND<1	3.4	2.38	ND<1	ND<1	ND<1	ND<1	3.3	ND<1	ND<1	ND<1	
	11-Jun-03	170	4.8	ND<1	ND<1	ND<1	ND<1	1.03	0.572	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	200	5.9	1.3	ND<1	ND<1	ND<1	2.67	0.292	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	210	5.7	1.1	ND<1	ND<1	ND<1	3.21	0.529	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	390	8.2	1.0	ND<1	ND<1	ND<1	2.95	0.922	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	380	6.8	1.6	ND<1	ND<1	ND<1	6.93	0.221	ND<1	1.2	0.9	0.8	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	270	7.9	ND<1	ND<1	ND<1	ND<1	5.45	0.0331	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	270	5.9	ND<1	ND<1	ND<1	ND<1	3.56	0.48	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	170	6.9	14.0	ND<1	ND<1	ND<1	3.28	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	170	5.8	4.5	ND<1	ND<1	ND<1	1.61	0.0691	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.982	0.173	ND<1	ND<1	ND<1	ND<1	2.1*	ND<1	ND<1	ND<1	
	5-May-04	470	6.2	7.8	ND<1	ND<1	ND<1	7.08	2.33	ND<1	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<1	
	30-Jun-04	110	3.8	26	ND<1	ND<1	ND<1	4.44	1.11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	110	3.2	29	ND<1	ND<1	ND<1	1.4	5.00	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	120	3.7	18	ND<1	ND<1	ND<1	2.98	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	3.2	ND<1	ND<1	
	7-Oct-04	94	ND<1	14	ND<1	ND<1	ND<1	3.65	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	130	4.2	11	ND<1	ND<1	ND<1	4.75	0.205	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	230	5.7	35	ND<1	ND<1	ND<1	1.90	1.62	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Apr-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	2-May-05	80	2.4	9.8	ND<1	ND<1	ND<1	3.77	0.0687	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Jun-05	74	2.6	ND<1	ND<1	ND<1	ND<1	9.95	9.28	ND<1	ND<1	ND<1	ND<1	4.5*	ND<1	ND<1	ND<1	

**GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (ug/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)	
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE	
RW-5	23-Apr-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	21	ND<1	ND<1	ND<1	ND<1	0.8	0.146	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.6	ND<1	ND<1	ND<1	
	11-Jun-03	21	ND<1	ND<1	ND<1	ND<1	6.2	0.76	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	11	ND<1	ND<1	ND<1	ND<1	1.1	9.7	6.47	0.068	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	15	ND<1	ND<1	ND<1	ND<1	0.9	7.3	0.269	0.021	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	18	ND<1	ND<1	ND<1	ND<1	ND<1	8.1	0.043	0.016	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	13.1	0.0097	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	11	ND<1	ND<1	ND<1	ND<1	ND<1	7.5	0.0523	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	14	ND<1	ND<1	ND<1	ND<1	0.9	4.0	0.05	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	14	ND<1	ND<1	ND<1	ND<1	1.0	6.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	14	ND<1	ND<1	ND<1	ND<1	ND<1	5.0	0.0852	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	18	ND<1	1.5	ND<1	ND<1	ND<1	6.1	0.147	0.015	ND<1	ND<1	ND<1	ND<1	2*	ND<1	ND<1	
	5-May-04	38	0.8	3.2	ND<1	ND<1	1.5	8.0	0.055	0.015	ND<1	ND<1	ND<1	ND<1	6.4*	ND<1	ND<1	
	14-Jun-04	17	ND<1	4.6	ND<1	ND<1	ND<1	3.9	0.054	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	21	ND<1	4.6	ND<1	ND<1	ND<1	3.1	0.0254	0.0265	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	24	ND<1	6.5	ND<1	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.3	ND<1	
	7-Oct-04	16	ND<1	5.2	ND<1	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	ND<1	1.8	1.4	
	3-Nov-04	15	ND<1	6.4	ND<1	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	28	ND<1	28	ND<1	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	9	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	13	ND<1	5.7	ND<1	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-6	23-Apr-03	79	1.0	ND<1	ND<1	ND<1	ND<1	0.028	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	120	1.8	ND<1	ND<1	0.6	ND<1	0.068	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.5	ND<1	ND<1	ND<1	
	11-Jun-03	120	0.7	ND<1	ND<1	ND<1	ND<1	0.0097	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	150	0.6	ND<1	ND<1	ND<1	ND<1	0.186	0.034	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	140	2.2	ND<1	ND<1	ND<1	ND<1	0.089	0.018	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	140	2.6	ND<1	ND<1	ND<1	ND<1	0.023	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	180	3.3	1.0	ND<1	ND<1	ND<1	0.342	0.0083	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	120	2.6	ND<1	ND<1	ND<1	ND<1	0.017	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	160	2.4	ND<1	ND<1	ND<1	ND<1	0.015	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	130	3.3	1.1	ND<1	ND<1	ND<1	1.7	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	110	2.7	ND<1	ND<1	ND<1	ND<1	1.6	0.077	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	110	2.9	1.3	ND<1	ND<1	ND<1	2.6	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8*	ND<1	ND<1	
	5-May-04	210	4.8	ND<1	ND<1	ND<1	ND<1	3.2	0.719	ND<0.02	ND<1	ND<1	ND<1	ND<1	5.9*	ND<1	ND<1	
	14-Jun-04	92	3.6	1.3	ND<1	ND<1	ND<1	2.1	0.151	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	100	2.8	1.2	ND<1	ND<1	ND<1	1.7	0.437	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	
	7-Oct-04	94	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.9	2.0	
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	ND<1	2.5	0.0111	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	200	3.8	1.6	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	69	1.6	13.0	ND<1	ND<1	ND<1	ND<1	0.067	0.0195	ND<1	ND<1	ND<1	2.1	ND<1	ND<1	ND<1	

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	Isopropylbenzene	1,1-Dichloroethane	cis-1,2-Dichloroethene	1,1-Dichloroethene	Methylene Chloride	Bromoform	Dibromochloromethane	Naphthalene	
		(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE	
RW-7	23-Apr-03	100	1.8	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	140	3.1	1.0	ND<1	ND<1	ND<1	0.032	ND<0.02	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1	ND<1	
	11-Jun-03	140	2.0	ND<1	ND<1	ND<1	ND<1	0.0246	0.0086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	150	2.1	ND<1	ND<1	ND<1	ND<1	0.024	0.041	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	120	2.3	ND<1	ND<1	ND<1	ND<1	0.011	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	130	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	140	3.4	1.1	ND<1	ND<1	ND<1	ND<1	0.0464	ND<0.02	ND<1	ND<1	0.2	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	110	2.8	ND<1	ND<1	ND<1	ND<1	ND<1	0.0239	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	190	3.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.0069	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	120	2.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	100	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	0.0205	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	79	2.5	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.2*	ND<1	ND<1	ND<1
	5-May-04	130	4.0	ND<1	ND<1	ND<1	ND<1	ND<1	0.012	ND<0.02	ND<1	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<1
	14-Jun-04	59	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.018	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	55	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	0.791	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	ND<1	ND<1
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	ND<1	0.0272	0.00876	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	32	1.0	4.7	ND<1	ND<1	ND<1	ND<1	0.0753	0.02	ND<1	1.5	ND<1	ND<1	1.1	ND<1	ND<1	ND<1
RW-8	23-Apr-03	41	2.0	1.8	ND<1	ND<1	ND<1	11.8	0.352	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-May-03	61	3.9	3.8	ND<1	ND<1	ND<1	10.1	0.068	ND<1	1.8	ND<1	ND<1	3.4	ND<1	ND<1	ND<1	
	11-Jun-03	57	3.1	2.7	ND<1	ND<1	ND<1	9.14	1.10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jul-03	35	1.9	3.2	ND<1	ND<1	ND<1	10.5	0.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	30	1.7	3.6	ND<1	ND<1	ND<1	11.1	1.18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	28	2.5	4.4	ND<1	ND<1	ND<1	9.93	0.40	ND<1	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	27	2.3	5.4	ND<1	ND<1	ND<1	13.3	0.21	ND<1	4.1	0.7	1.3	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	17	2.1	2.6	ND<1	ND<1	ND<1	9.16	0.05	ND<1	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	16	2.2	4.1	ND<1	ND<1	ND<1	9.73	2.72	ND<1	3.5	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	15	2.2	4.7	ND<1	ND<1	ND<1	8.74	0.19	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	22	2.7	4.3	ND<1	ND<1	ND<1	11.9	0.23	ND<1	3.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	14	2.0	6.2	ND<1	ND<1	ND<1	10.7	0.14	ND<1	5.7	ND<1	ND<1	1.9*	ND<1	ND<1	ND<1	
	5-May-04	27	4.1	8.3	ND<1	ND<1	ND<1	8.77	0.21	ND<1	8.7	ND<1	ND<1	8.5*	ND<1	ND<1	ND<1	
	14-Jun-04	10	2.4	5.8	ND<1	ND<1	ND<1	9.15	0.10	ND<1	4.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04 **	3	1.0	3.7	ND<1	ND<1	ND<1	4.18	0.21	ND<1	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	28.8	0.2	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	10.6	0.3	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	16	ND<1	22	ND<1	ND<1	ND<1	15.6	0.1	ND<1	15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	ND<1	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	ND<1	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	7.33	0.07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	2.7	ND<1	5.8	ND<1	ND<1	ND<1	7.06	0.33	ND<1	2.1	ND<1	ND<1	1.7	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	Isopropylbenzene (ug/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Naphthalene (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	NE	5	5	5	5	NE	NE	NE
RW-9	23-Apr-03	15	1.2	1.8	ND<1	ND<1	ND<1	3.55	1.97	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-May-03	21	1.8	3.6	ND<1	ND<1	ND<1	2.95	0.046	ND<1	1.9	ND<1	ND<1	3.2	ND<1	ND<1	ND<1
	11-Jun-03	18	1.6	4.8	ND<1	ND<1	ND<1	2.75	1.74	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jul-03	4.7	1.6	7.3	ND<1	ND<1	ND<1	3.60	0.467	ND<1	3.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	25	1.2	3.5	ND<1	ND<1	ND<1	4.05	2.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	22	2.1	5.8	ND<1	ND<1	ND<1	3.49	2.88	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	27	2.2	8.2	ND<1	ND<1	ND<1	5.39	1.72	ND<1	5.2	ND<1	1.4	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	11	1.7	5.4	ND<1	ND<1	ND<1	1.94	1.57	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	2.3	2.2	13	ND<1	ND<1	ND<1	0.638	0.029	ND<1	1.8	ND<1	1.5	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	2.2	12	ND<1	ND<1	ND<1	1.24	0.222	ND<1	3.7	ND<1	1.3	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	5.6	1.7	10	ND<1	ND<1	ND<1	2.65	1.22	ND<1	5.9	ND<1	2.0	2.0*	ND<1	ND<1	ND<1
	5-May-04	3.7	1.7	13	ND<1	ND<1	ND<1	2.58	1.83	ND<1	6.7	ND<1	1.7	7.1*	ND<1	ND<1	ND<1
	14-Jun-04	1.8	1.9	8.2	ND<1	ND<1	ND<1	3.03	1.11	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	3.4	1.3	5.1	ND<1	ND<1	ND<1	2.6	1.95	ND<1	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	ND<1	1.9	ND<1	ND<1	ND<1	1.6	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0596	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
16-Jun-05	ND<1	ND<1	5.8	ND<1	ND<1	ND<1	1.38	0.149	ND<1	0.9	ND<1	1.2	ND<1	ND<1	ND<1	ND<1	

ND: Not detected
 <#: Less than method detection limit
 ug/L: Micrograms per liter
 -: Not analyzed
 ARAR's are chemical specific aquifer restoration goals for ground-water at the Former Rowe Industries Superfund Site.
 Bold values indicate an exceedance of the ARAR standard established for the site.

PCE: Tetrachloroethylene
 TCE: Trichloroethene
 TCA: 1,1,1-Trichloroethane
 1,1-DCA: 1,1-Dichloroethane


1,1-DCE: 1,1-Dichloroethene
 1,2-DCE: 1,2-Dichloroethene
 MTBE: Methyl Tertiary Butyl Ether
 NM: Not Measured

*Methylene Chloride detected in laboratory method blank
 NE: ARAR goal was not established for this compound by the EPA.
 ** The July 14, 2004 sample collected for RW-8 only represents water in the pipe since the RW-8 pump was not operating at this time.
 *** The August 26, 2004 samples were lost during shipment.

GRAPHS


GRAPH 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
(June 1, 2005 through June 30, 2005)




GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION FOR SELECT RECOVERY WELLS



APPENDIX I
JUNE 2005 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Friday, June 17, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0506057

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 6/7/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0506057

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0506057-01A	WQ060205:1200 NP2-6	6149	6/2/2005	6/7/2005
0506057-01B	WQ060205:1200 NP2-6	6149	6/2/2005	6/7/2005
0506057-01C	WQ060205:1200 NP2-6	6149	6/2/2005	6/7/2005
0506057-02A	WQ060205:1205 NP2-7	6149	6/2/2005	6/7/2005
0506057-02B	WQ060205:1205 NP2-7	6149	6/2/2005	6/7/2005
0506057-02C	WQ060205:1205 NP2-7	6149	6/2/2005	6/7/2005
0506057-03A	WQ060205:1210 NP2-10	6149	6/2/2005	6/7/2005
0506057-03B	WQ060205:1210 NP2-10	6149	6/2/2005	6/7/2005
0506057-03C	WQ060205:1210 NP2-10	6149	6/2/2005	6/7/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
 (631) 454-6100 • FAX (631) 454-8027

TAG # / COC 6149

NYSDOH 11418
 CTDOH PH-0205
 NJDEP NY050
 PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <i>LBG</i> <i>126 Monroe Turnpike</i> <i>Trumbull, CT 06611</i>	CONTACT: <i>Mark Goldberg</i>	SAMPLER (SIGNATURE) <i>Tunde Sandor (MMG)</i>	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES / <input type="checkbox"/> NO
		SAMPLER NAME (PRINT) <i>Tunde Sandor</i>	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES / <input type="checkbox"/> NO

PROJECT LOCATION: <i>Rowe</i>					ANALYSIS REQUIRED										FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]					
LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	SP60	MIBF	Freeze	Total Diss Fe	TDS											
<i>0206057-ABC L</i>		<i>4</i>	<i>6/2/05</i>	<i>WQ060205:1200 NP2-6</i>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>											
<i>2ABC ↓</i>		<i>4</i>	<i>↓</i>	<i>↓ :1205 NP2-7</i>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>											
<i>3ABC ↓</i>		<i>5</i>	<i>↓</i>	<i>↓ :1210 NP2-10</i>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>											

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON				TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY <i>1/1</i>		COOLER TEMPERATURE: COMMENTS / INSTRUCTIONS <i>Purge water from well</i> <i>Rehab</i>	
RELINQUISHED BY (SIGNATURE) <i>Mark M. Goldberg</i>	DATE <i>6/2/05</i> TIME <i>16:00</i>	PRINTED NAME <i>Mark M. Goldberg</i>	RECEIVED BY LAB (SIGNATURE) <i>PA</i>	DATE <i>6/7/05</i> TIME <i>11:00</i>	PRINTED NAME <i>J. A. Antonio</i>		
RELINQUISHED BY (SIGNATURE)	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME		

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ060205:1200 NP2-6
 Lab Order: 0506057 Tag Number: 6149
 Project: Rowe Industries Collection Date: 6/2/2005
 Lab ID: 0506057-01A Date Received: 6/7/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
2-Butanone	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
2-Hexanone	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Acetone	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Benzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Bromobenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Bromochloromethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Bromodichloromethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Bromoform	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Bromomethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Carbon disulfide	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Chlorobenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Chloroethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ060205:1200 NP2-6
 Lab Order: 0506057 Tag Number: 6149
 Project: Rowe Industries Collection Date: 6/2/2005
 Lab ID: 0506057-01A Date Received: 6/7/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Chloromethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Dibromochloromethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Dibromomethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Ethylbenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Isopropylbenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
m,p-Xylene	U	2.0		µg/L	1	6/12/2005 4:46:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Methylene chloride	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Naphthalene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
n-Butylbenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
n-Propylbenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
o-Xylene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Styrene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Tetrachloroethene	7.7	1.0		µg/L	1	6/12/2005 4:46:00 PM
Toluene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Trichloroethene	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Vinyl acetate	U	1.0		µg/L	1	6/12/2005 4:46:00 PM
Vinyl chloride	U	1.0		µg/L	1	6/12/2005 4:46:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ060205:1200 NP2-6
Lab Order:	0506057	Tag Number:	6149
Project:	Rowe Industries	Collection Date:	6/2/2005
Lab ID:	0506057-01B	Date Received:	6/7/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	52.7	0.0200		mg/L	1	6/9/2005 12:30:48 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ060205:1200 NP2-6
Lab Order: 0506057 Tag Number: 6149
Project: Rowe Industries Collection Date: 6/2/2005
Lab ID: 0506057-01C Date Received: 6/7/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	53.1	0.0200		mg/L	1	6/9/2005 12:28:23 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
E Value above quantitation range H Holding times for preparation or analysis exceeded
J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brasbears & Graham Inc. Client Sample ID: WQ060205:1205 NP2-7
 Lab Order: 0506057 Tag Number: 6149
 Project: Rowe Industries Collection Date: 6/2/2005
 Lab ID: 0506057-02A Date Received: 6/7/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						
SW8260B						Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
2-Butanone	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
2-Hexanone	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Acetone	1800	1.0		µg/L	1	6/12/2005 5:19:00 PM
Benzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Bromobenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Bromochloromethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Bromodichloromethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Bromoform	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Bromomethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Carbon disulfide	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Chlorobenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Chloroethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ060205:1205 NP2-7
 Lab Order: 0506057 Tag Number: 6149
 Project: Rowe Industries Collection Date: 6/2/2005
 Lab ID: 0506057-02A Date Received: 6/7/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Chloromethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Dibromochloromethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Dibromomethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Ethylbenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Isopropylbenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
m,p-Xylene	U	2.0		µg/L	1	6/12/2005 5:19:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Methylene chloride	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Naphthalene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
n-Butylbenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
n-Propylbenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
o-Xylene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Styrene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Tetrachloroethene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Toluene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Trichloroethene	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Vinyl acetate	U	1.0		µg/L	1	6/12/2005 5:19:00 PM
Vinyl chloride	U	1.0		µg/L	1	6/12/2005 5:19:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ060205:1205 NP2-7
Lab Order:	0506057	Tag Number:	6149
Project:	Rowe Industries	Collection Date:	6/2/2005
Lab ID:	0506057-02B	Date Received:	6/7/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	177	0.0200		mg/L	1	6/9/2005 12:51:55 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ060205:1205 NP2-7
Lab Order:	0506057	Tag Number:	6149
Project:	Rowe Industries	Collection Date:	6/2/2005
Lab ID:	0506057-02C	Date Received:	6/7/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	52.5	0.0200		mg/L	1	6/9/2005 12:48:07 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: WQ060205:1210 NP2-10
Lab Order: 0506057	Tag Number: 6149
Project: Rowe Industries	Collection Date: 6/2/2005
Lab ID: 0506057-03A	Date Received: 6/7/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
2-Butanone	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
2-Hexanone	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Acetone	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Benzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Bromobenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Bromochloromethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Bromodichloromethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Bromofom	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Bromomethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Carbon disulfide	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Chlorobenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Chloroethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ060205:1210 NP2-10
Lab Order: 0506057 **Tag Number:** 6149
Project: Rowe Industries **Collection Date:** 6/2/2005
Lab ID: 0506057-03A **Date Received:** 6/7/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Chloromethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Dibromochloromethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Dibromomethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Ethylbenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Isopropylbenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
m,p-Xylene	U	2.0		µg/L	1	6/12/2005 5:52:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Methylene chloride	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Naphthalene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
n-Butylbenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
n-Propylbenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
o-Xylene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Styrene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Tetrachloroethene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Toluene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Trichloroethene	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Vinyl acetate	U	1.0		µg/L	1	6/12/2005 5:52:00 PM
Vinyl chloride	U	1.0		µg/L	1	6/12/2005 5:52:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ060205:1210 NP2-10
Lab Order:	0506057	Tag Number:	6149
Project:	Rowe Industries	Collection Date:	6/2/2005
Lab ID:	0506057-03B	Date Received:	6/7/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	38.7	0.0200		mg/L	1	6/9/2005 1:00:07 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ060205:1210 NP2-10
Lab Order:	0506057	Tag Number:	6149
Project:	Rowe Industries	Collection Date:	6/2/2005
Lab ID:	0506057-03C	Date Received:	6/7/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	19.8	0.0200		mg/L	1	6/9/2005 12:56:15 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BK
Total Dissolved Solids (Residue, Filterable)	960	1.0		mg/L	1	6/9/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Friday, June 17, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0506119

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 6/14/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0506119

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0506119-01A	WQ061005:932 NP2-6	6229	6/10/2005 9:32:00 AM	6/14/2005
0506119-01B	WQ061005:932 NP2-6	6229	6/10/2005 9:32:00 AM	6/14/2005
0506119-01C	WQ061005:932 NP2-6	6229	6/10/2005 9:32:00 AM	6/14/2005
0506119-02A	WQ061005:934 NP2-7	6229	6/10/2005 9:34:00 AM	6/14/2005
0506119-02B	WQ061005:934 NP2-7	6229	6/10/2005 9:34:00 AM	6/14/2005
0506119-02C	WQ061005:934 NP2-7	6229	6/10/2005 9:34:00 AM	6/14/2005
0506119-03A	WQ061005:938 NP2-10	6229	6/10/2005 9:38:00 AM	6/14/2005
0506119-03B	WQ061005:938 NP2-10	6229	6/10/2005 9:38:00 AM	6/14/2005
0506119-03C	WQ061005:938 NP2-10	6229	6/10/2005 9:38:00 AM	6/14/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
 (631) 454-6100 • FAX (631) 454-8027

TAG # / COC

NYSDOH 11418
 CTDOH PH-0205
 NJDEP NY050
 PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <i>USG 126 Monroe Turnpike Trumbull, CT 06611</i>	CONTACT: <i>Mark Goldberg</i>	SAMPLER (SIGNATURE) <i>Steve Silvestri</i>	SAMPLE(S) SEALED YES / NO
		SAMPLER NAME (PRINT) <i>Steve Silvestri</i>	CORRECT CONTAINER(S) YES / NO

PROJECT LOCATION: *Rome*

LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED										FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]						
					8260	MTBE	Free Oil	Total PC	Dis. PC	TDS											
<i>0506119-1A</i>	<i>L</i>	<i>4</i>	<i>6/10/05 932</i>	<i>WQ061005:932 NP2-6</i>	<i>X</i>	<i>X</i>	<i>X</i>	<i>X</i>	<i>X</i>												
<i>2ABC</i>	<i>L</i>	<i>4</i>	<i>↓ 934</i>	<i>WQ061005:934 NP2-7</i>	<i>X</i>	<i>X</i>	<i>X</i>	<i>X</i>	<i>X</i>												
<i>3ABC</i>	<i>L</i>	<i>5</i>	<i>↓ 938</i>	<i>WQ061005:938 NP2-8</i>	<i>X</i>	<i>X</i>	<i>X</i>	<i>X</i>	<i>X</i>	<i>X</i>											

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON			TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY <i>1/1</i>		COOLER TEMPERATURE: COMMENTS / INSTRUCTIONS
RELINQUISHED BY (SIGNATURE) <i>Steve Silvestri</i>	DATE <i>6/13/05</i> TIME <i>16:00</i>	PRINTED NAME <i>Steve Silvestri</i>	RECEIVED BY LAB (SIGNATURE) <i>[Signature]</i>	DATE <i>6/14/05</i> TIME <i>0945</i>	PRINTED NAME <i>P. A. Johnston</i>
RELINQUISHED BY (SIGNATURE)	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC
56 TOLEDO STREET
FARMINGDALE, NEW YORK 11735
TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061005:932 NP2-6
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:32:00 AM
Lab ID:	0506119-01A	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
2-Butanone	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
2-Hexanone	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Acetone	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Benzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Bromobenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Bromoform	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Bromomethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Chloroethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061005:932 NP2-6
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:32:00 AM
Lab ID:	0506119-01A	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Chloromethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Dibromomethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/15/2005 1:52:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Methylene chloride	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Naphthalene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
o-Xylene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Styrene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Tetrachloroethene	9.2	1.0		µg/L	1	6/15/2005 1:52:00 AM
Toluene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Trichloroethene	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/15/2005 1:52:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/15/2005 1:52:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brasbears & Graham Inc.	Client Sample ID:	WQ061005:932 NP2-6
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:32:00 AM
Lab ID:	0506119-01B	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	62.1	0.0200		mg/L	1	6/14/2005 2:10:38 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061005:932 NP2-6
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:32:00 AM
Lab ID:	0506119-01C	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	58.5	0.0200		mg/L	1	6/14/2005 2:07:51 PM

Qualifiers:	• Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061005:934 NP2-7
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:34:00 AM
Lab ID:	0506119-02A	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
2-Butanone	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
2-Hexanone	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Acetone	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Benzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Bromobenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Bromoform	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Bromomethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Chloroethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061005:934 NP2-7
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:34:00 AM
Lab ID:	0506119-02A	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Chloromethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Dibromomethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/15/2005 2:24:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Methylene chloride	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Naphthalene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
o-Xylene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Styrene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Tetrachloroethene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Toluene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Trichloroethene	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/15/2005 2:24:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/15/2005 2:24:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 6 of 12

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061005:934 NP2-7
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:34:00 AM
Lab ID:	0506119-02B	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	75.3	0.0200		mg/L	1	6/14/2005 2:16:13 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ061005:934 NP2-7
Lab Order: 0506119 Tag Number: 6229
Project: Rowe Industries Collection Date: 6/10/2005 9:34:00 AM
Lab ID: 0506119-02C Date Received: 6/14/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	22.4	0.0200		mg/L	1	6/14/2005 2:13:33 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
E Value above quantitation range H Holding times for preparation or analysis exceeded
J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected
Page 8 of 12

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ061005:938 NP2-10
 Lab Order: 0506119 Tag Number: 6229
 Project: Rowe Industries Collection Date: 6/10/2005 9:38:00 AM
 Lab ID: 0506119-03A Date Received: 6/14/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
2-Butanone	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
2-Hexanone	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Acetone	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Benzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Bromobenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Bromoform	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Bromomethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Chloroethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Legette Brashears & Graham Inc.	Client Sample ID:	WQ061005:938 NP2-10
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:38:00 AM
Lab ID:	0506119-03A	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Chloromethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Dibromomethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/15/2005 2:56:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Methylene chloride	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Naphthalene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
o-Xylene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Styrene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Tetrachloroethene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Toluene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Trichloroethene	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/15/2005 2:56:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/15/2005 2:56:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 10 of 12

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061005:938 NP2-10
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:38:00 AM
Lab ID:	0506119-03B	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	42.8	0.0200		mg/L	1	6/14/2005 2:21:35 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 17-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061005:938 NP2-10
Lab Order:	0506119	Tag Number:	6229
Project:	Rowe Industries	Collection Date:	6/10/2005 9:38:00 AM
Lab ID:	0506119-03C	Date Received:	6/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	42.0	0.0200		mg/L	1	6/14/2005 2:18:50 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: WN
Total Dissolved Solids (Residue, Filterable)	1200	1.0		mg/L	1	6/16/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, June 29, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0506175

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 6/21/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

CLIENT: Legette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0506175

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0506175-01A	WQ061505:1000 NP2-6	4489	6/15/2005 10:00:00 AM	6/21/2005
0506175-01B	WQ061505:1000 NP2-6	4489	6/15/2005 10:00:00 AM	6/21/2005
0506175-01C	WQ061505:1000 NP2-6	4489	6/15/2005 10:00:00 AM	6/21/2005
0506175-02A	WQ061505:1005 NP2-7	4489	6/15/2005 10:05:00 AM	6/21/2005
0506175-02B	WQ061505:1005 NP2-7	4489	6/15/2005 10:05:00 AM	6/21/2005
0506175-02C	WQ061505:1005 NP2-7	4489	6/15/2005 10:05:00 AM	6/21/2005
0506175-03A	WQ061505:1010 NP2-10	4489	6/15/2005 10:10:00 AM	6/21/2005
0506175-03B	WQ061505:1010 NP2-10	4489	6/15/2005 10:10:00 AM	6/21/2005
0506175-03C	WQ061505:1010 NP2-10	4489	6/15/2005 10:10:00 AM	6/21/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
 (631) 454-6100 • FAX (631) 454-8027

TAG # / COC _____

NYSDOH 11418
 CTDOH PH-0205
 NJDEP NY050
 PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBG 126 MONROE TPK TRUMBULL CT 06611	CONTACT: MARK GOLDBERG	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED YES / NO <input checked="" type="checkbox"/>
		SAMPLER NAME (PRINT) TUNDE H. H. SANDOR	CORRECT CONTAINER(S) YES / NO <input checked="" type="checkbox"/>

PROJECT LOCATION:
 ROWE, SAG HARBOR NY.

LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED										FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]						
					GLD	MTBE	Hept 113	Total PE	Diss PE	TDS											
0506175-1ABC	WATER	4	6-15-05 / 10:00	W006175-1000 NP2-6	X	X	X	X	X												
2ABC			/ 10:05	W006175-1005 NP2-7	X	X	X	X	X												
3ABC			/ 10:10	W006175-1010 NP2-10	X	X	X	X	X												

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS, B=BULK MATERIAL
 TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

COOLER TEMPERATURE: _____

TURNAROUND REQUIRED: NORMAL STAT BY 1 / 1

COMMENTS / INSTRUCTIONS
 6/21/05

RELINQUISHED BY (SIGNATURE) 	DATE 6-20-05 TIME 4:08	PRINTED NAME TUNDE KORUVES-SANDOR	RECEIVED BY LAB (SIGNATURE) 	DATE 6/21/05 TIME 1030	PRINTED NAME G. Antonio
---------------------------------	---------------------------------	---	---------------------------------	---------------------------------	----------------------------

RELINQUISHED BY (SIGNATURE)	DATE	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE	PRINTED NAME

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0506175

CASE NARRATIVE

Samples were analyzed using the methods outlined in the following references:

Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW846, 3rd Edition

All method blanks, laboratory spikes, and/or matrix spikes met quality assurance objectives.

Acetone was detected and reported in sample WQ061505:1010 NP2-10 at 33 ug/L. This compound is a common laboratory contaminant and solvent used in the laboratory, however was not detected in the corresponding method blank and therefore was required to be reported.

Acetone results should be used with caution and should be considered suspect for this sample.

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ061505:1000 NP2-6
 Lab Order: 0506175 Tag Number: 4489
 Project: Rowe Industries Collection Date: 6/15/2005 10:00:00 AM
 Lab ID: 0506175-01A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,1,1-Trichloroethane	3.6	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Acetone	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ061505:1000 NP2-6
 Lab Order: 0506175 Tag Number: 4489
 Project: Rowe Industries Collection Date: 6/15/2005 10:00:00 AM
 Lab ID: 0506175-01A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 5:23:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Tetrachloroethene	19	1.0		µg/L	1	6/23/2005 5:23:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Trichloroethene	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 5:23:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 5:23:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061505:1000 NP2-6
Lab Order:	0506175	Tag Number:	4489
Project:	Rowe Industries	Collection Date:	6/15/2005 10:00:00 AM
Lab ID:	0506175-01B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	34.8	0.0200		mg/L	1	6/27/2005 1:33:31 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061505:1000 NP2-6
Lab Order:	0506175	Tag Number:	4489
Project:	Rowe Industries	Collection Date:	6/15/2005 10:00:00 AM
Lab ID:	0506175-01C	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	1.77	0.0200		mg/L	1	6/27/2005 1:28:43 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ061505:1005 NP2-7
 Lab Order: 0506175 Tag Number: 4489
 Project: Rowe Industries Collection Date: 6/15/2005 10:05:00 AM
 Lab ID: 0506175-02A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Acetone	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 5 of 12

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ061505:1005 NP2-7
 Lab Order: 0506175 Tag Number: 4489
 Project: Rowe Industries Collection Date: 6/15/2005 10:05:00 AM
 Lab ID: 0506175-02A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 5:59:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Tetrachloroethene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Trichloroethene	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 5:59:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 5:59:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061505:1005 NP2-7
Lab Order:	0506175	Tag Number:	4489
Project:	Rowe Industries	Collection Date:	6/15/2005 10:05:00 AM
Lab ID:	0506175-02B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	22.0	0.0200		mg/L	1	6/27/2005 1:39:44 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ061505:1005 NP2-7
Lab Order: 0506175 Tag Number: 4489
Project: Rowe Industries Collection Date: 6/15/2005 10:05:00 AM
Lab ID: 0506175-02C Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	1.33	0.0200		mg/L	1	6/27/2005 1:36:57 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
E Value above quantitation range H Holding times for preparation or analysis exceeded
J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ061505:1010 NP2-10
 Lab Order: 0506175 Tag Number: 4489
 Project: Rowe Industries Collection Date: 6/15/2005 10:10:00 AM
 Lab ID: 0506175-03A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Acetone	33	1.0		µg/L	1	6/23/2005 6:35:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ061505:1010 NP2-10
 Lab Order: 0506175 Tag Number: 4489
 Project: Rowe Industries Collection Date: 6/15/2005 10:10:00 AM
 Lab ID: 0506175-03A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 6:35:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Tetrachloroethene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Trichloroethene	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 6:35:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 6:35:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061505:1010 NP2-10
Lab Order:	0506175	Tag Number:	4489
Project:	Rowe Industries	Collection Date:	6/15/2005 10:10:00 AM
Lab ID:	0506175-03B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	45.0	0.0200		mg/L	1	6/27/2005 1:44:45 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ061505:1010 NP2-10
Lab Order:	0506175	Tag Number:	4489
Project:	Rowe Industries	Collection Date:	6/15/2005 10:10:00 AM
Lab ID:	0506175-03C	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	1.49	0.0200		mg/L	1	6/27/2005 1:42:29 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: WN
Total Dissolved Solids (Residue, Filterable)	240	1.0		mg/L	1	6/22/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, July 07, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0506239

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 6/28/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0506239

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0506239-01A	WQ062405:1205 NP2-6	6150	6/24/2005	6/28/2005
0506239-01B	WQ062405:1205 NP2-6	6150	6/24/2005	6/28/2005
0506239-01C	WQ062405:1205 NP2-6	6150	6/24/2005	6/28/2005
0506239-02A	WQ062405:1210 NP2-7	6150	6/24/2005	6/28/2005
0506239-02B	WQ062405:1210 NP2-7	6150	6/24/2005	6/28/2005
0506239-02C	WQ062405:1210 NP2-7	6150	6/24/2005	6/28/2005
0506239-03A	WQ062405:1215 NP2-10	6150	6/24/2005	6/28/2005
0506239-03B	WQ062405:1215 NP2-10	6150	6/24/2005	6/28/2005
0506239-03C	WQ062405:1215 NP2-10	6150	6/24/2005	6/28/2005

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <i>LBC</i> 126 Monroe Turnpike Trumbull, CT 06611	CONTACT: Mark Goldberg	SAMPLER (SIGNATURE) <i>Steve Silvestri (M.M.G.)</i>	SAMPLE(S) SEALED YES / NO
		SAMPLER NAME (PRINT) Steve Silvestri	CORRECT CONTAINER(S) YES / NO

PROJECT LOCATION:
Rowe

LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED		FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
<i>05D6239-ABC L</i>		<i>4</i>	<i>6/24/05</i>	<i>WR062405-1205 NP2-6</i>	<i>SOLO</i>	<i>✓</i>	
<i>2ABC</i>		<i>4</i>	<i>↓</i>	<i>1210 NP2-7</i>	<i>MTBE</i>	<i>✓</i>	
<i>3ABC</i>		<i>5</i>	<i>↓</i>	<i>1215 NP2-10</i>	<i>Freon 113</i>	<i>✓</i>	
					<i>Tot + D-SS-Fe</i>	<i>✓</i>	
					<i>TDS</i>	<i>✓</i>	

COOLER TEMPERATURE: _____

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL
 TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

TURNAROUND REQUIRED: NORMAL STAT BY *[Signature]*

COMMENTS / INSTRUCTIONS: *6/28/05*

RELINQUISHED BY (SIGNATURE) <i>Mark M. Goldberg</i>	DATE <i>6/27/05</i> TIME <i>16:00</i>	PRINTED NAME <i>Mark M. Goldberg</i>	RECEIVED BY LAB (SIGNATURE) <i>[Signature]</i>	DATE <i>6/28/05</i> TIME <i>1400</i>	PRINTED NAME <i>[Signature]</i>
RELINQUISHED BY (SIGNATURE)	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ062405:1205 NP2-6
Lab Order:	0506239	Tag Number:	6150
Project:	Rowe Industries	Collection Date:	6/24/2005
Lab ID:	0506239-01A	Date Received:	6/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
2-Butanone	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
2-Hexanone	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Acetone	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Benzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Bromobenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Bromochloromethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Bromodichloromethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Bromoform	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Bromomethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Carbon disulfide	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Chlorobenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Chloroethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ062405:1205 NP2-6
 Lab Order: 0506239 Tag Number: 6150
 Project: Rowe Industries Collection Date: 6/24/2005
 Lab ID: 0506239-01A Date Received: 6/28/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Chloromethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Dibromochloromethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Dibromomethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Ethylbenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Isopropylbenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
m,p-Xylene	U	2.0		µg/L	1	6/29/2005 5:03:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Methylene chloride	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Naphthalene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
n-Butylbenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
n-Propylbenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
o-Xylene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Styrene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Tetrachloroethene	12	1.0		µg/L	1	6/29/2005 5:03:00 PM
Toluene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Trichloroethene	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Vinyl acetate	U	1.0		µg/L	1	6/29/2005 5:03:00 PM
Vinyl chloride	U	1.0		µg/L	1	6/29/2005 5:03:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ062405:1205 NP2-6
Lab Order:	0506239	Tag Number:	6150
Project:	Rowe Industries	Collection Date:	6/24/2005
Lab ID:	0506239-01B	Date Received:	6/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	3.86	0.0200		mg/L	1	7/5/2005 11:44:47 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ062405:1205 NP2-6
Lab Order:	0506239	Tag Number:	6150
Project:	Rowe Industries	Collection Date:	6/24/2005
Lab ID:	0506239-01C	Date Received:	6/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0525	0.0200		mg/L	1	7/5/2005 11:41:51 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: WQ062405:1210 NP2-7
Lab Order: 0506239	Tag Number: 6150
Project: Rowe Industries	Collection Date: 6/24/2005
Lab ID: 0506239-02A	Date Received: 6/28/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B		Analyst: JMO
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
2-Butanone	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
2-Hexanone	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Acetone	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Benzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Bromobenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Bromochloromethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Bromodichloromethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Bromoform	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Bromomethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Carbon disulfide	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Chlorobenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Chloroethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ062405:1210 NP2-7
Lab Order:	0506239	Tag Number:	6150
Project:	Rowe Industries	Collection Date:	6/24/2005
Lab ID:	0506239-02A	Date Received:	6/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Chloromethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Dibromochloromethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Dibromomethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Ethylbenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Isopropylbenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
m,p-Xylene	U	2.0		µg/L	1	6/29/2005 5:42:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Methylene chloride	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Naphthalene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
n-Butylbenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
n-Propylbenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
o-Xylene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Styrene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Tetrachloroethene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Toluene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Trichloroethene	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Vinyl acetate	U	1.0		µg/L	1	6/29/2005 5:42:00 PM
Vinyl chloride	U	1.0		µg/L	1	6/29/2005 5:42:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ062405:1210 NP2-7
Lab Order:	0506239	Tag Number:	6150
Project:	Rowe Industries	Collection Date:	6/24/2005
Lab ID:	0506239-02B	Date Received:	6/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	1.75	0.0200		mg/L	1	7/5/2005 11:50:50 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ062405:1210 NP2-7
Lab Order:	0506239	Tag Number:	6150
Project:	Rowe Industries	Collection Date:	6/24/2005
Lab ID:	0506239-02C	Date Received:	6/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.186	0.0200		mg/L	1	7/5/2005 11:48:04 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ062405:1215 NP2-10
 Lab Order: 0506239 Tag Number: 6150
 Project: Rowe Industries Collection Date: 6/24/2005
 Lab ID: 0506239-03A Date Received: 6/28/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
2-Butanone	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
2-Hexanone	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Acetone	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Benzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Bromobenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Bromochloromethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Bromodichloromethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Bromoform	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Bromomethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Carbon disulfide	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Chlorobenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Chloroethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ062405:1215 NP2-10
Lab Order:	0506239	Tag Number:	6150
Project:	Rowe Industries	Collection Date:	6/24/2005
Lab ID:	0506239-03A	Date Received:	6/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Chloromethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Dibromochloromethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Dibromomethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Ethylbenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Isopropylbenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
m,p-Xylene	U	2.0		µg/L	1	6/29/2005 6:21:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Methylene chloride	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Naphthalene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
n-Butylbenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
n-Propylbenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
o-Xylene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Styrene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Tetrachloroethene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Toluene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Trichloroethene	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Vinyl acetate	U	1.0		µg/L	1	6/29/2005 6:21:00 PM
Vinyl chloride	U	1.0		µg/L	1	6/29/2005 6:21:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ062405:1215 NP2-10
Lab Order:	0506239	Tag Number:	6150
Project:	Rowe Industries	Collection Date:	6/24/2005
Lab ID:	0506239-03B	Date Received:	6/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	1.09	0.0200		mg/L	1	7/5/2005 11:55:39 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 07-Jul-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: WQ062405:1215 NP2-10
Lab Order: 0506239	Tag Number: 6150
Project: Rowe Industries	Collection Date: 6/24/2005
Lab ID: 0506239-03C	Date Received: 6/28/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.131	0.0200		mg/L	1	7/5/2005 11:53:39 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: WN
Total Dissolved Solids (Residue, Filterable)	130	1.0		mg/L	1	6/30/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, July 12, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0507009

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 7/1/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0507009

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0507009-01A	WQ063005:1015 NP2-6	6233	6/30/2005 10:15:00 AM	7/1/2005
0507009-01B	WQ063005:1015 NP2-6	6233	6/30/2005 10:15:00 AM	7/1/2005
0507009-01C	WQ063005:1015 NP2-6	6233	6/30/2005 10:15:00 AM	7/1/2005
0507009-02A	WQ063005:1020 NP2-7	6233	6/30/2005 10:20:00 AM	7/1/2005
0507009-02B	WQ063005:1020 NP2-7	6233	6/30/2005 10:20:00 AM	7/1/2005
0507009-02C	WQ063005:1020 NP2-7	6233	6/30/2005 10:20:00 AM	7/1/2005
0507009-03A	WQ063005:1025 NP2-10	6233	6/30/2005 10:25:00 AM	7/1/2005
0507009-03B	WQ063005:1025 NP2-10	6233	6/30/2005 10:25:00 AM	7/1/2005
0507009-03C	WQ063005:1025 NP2-10	6233	6/30/2005 10:25:00 AM	7/1/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
 (631) 454-6100 • FAX (631) 454-8027

TAG # / COC 6233

NYSDOH 11418
 CTDOH PH-0205
 NJDEP NY050
 PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBG 126 MONROE TPK TRUMBULL CT 06611	CONTACT: MARK GOLDBERG	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED YES/NO
		SAMPLER NAME (PRINT) TUNDE H KOVACS-SANDOR	CORRECT CONTAINER(S) YES/NO

PROJECT LOCATION:
ROWE INDUSTRIES, SAG HARBOR NY

LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED										FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]						
					BIOTOXICITY	HEAVY METALS	TOTAL HCB	DISSOLVED IRON	TOTAL NITROGEN	DISSOLVED NITROGEN	TDS	HARDNESS	TURBIDITY								
0507009-1A	WATER	4	6/30/05 10:15	WQ063005; 1015 MP2-6	X	X	X														
2ABC	↓	4	↓ 10:20	WQ063005; 1020 MP2-7	↓	↓	↓														
3ABC	↓	5	↓ 10:25	WQ063005; 1025 MP2-10	↓	↓	↓														
	↓	5	↓ 10:35	WQ063005; 1035 MPI-1-4	↓	↓	↓	X	X	X	X	X									

note: Put results of MPI-1-4 on separate chain

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON		TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY 1/1		COOLER TEMPERATURE: COMMENTS / INSTRUCTIONS	
RELINQUISHED BY (SIGNATURE) 	DATE 6/30/05 TIME 17:00	PRINTED NAME Mark M. Goldberg	RECEIVED BY LAB (SIGNATURE) 	DATE 7/1/05 TIME 11:00	PRINTED NAME P. Aron
RELINQUISHED BY (SIGNATURE)	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ063005:1015 NP2-6
Lab Order:	0507009	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:15:00 AM
Lab ID:	0507009-01A	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,1,1-Trichloroethane	2.3	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
2-Butanone	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
2-Hexanone	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Acetone	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Benzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Bromobenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Bromoform	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Bromomethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Chloroethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ063005:1015 NP2-6
Lab Order:	0507009	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:15:00 AM
Lab ID:	0507009-01A	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Chloromethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Dibromomethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/2/2005 4:10:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Methylene chloride	U	1.0	B	µg/L	1	7/2/2005 4:10:00 AM
Naphthalene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
o-Xylene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Styrene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Tetrachloroethene	20	1.0		µg/L	1	7/2/2005 4:10:00 AM
Toluene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Trichloroethene	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/2/2005 4:10:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/2/2005 4:10:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ063005:1015 NP2-6
Lab Order:	0507009	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:15:00 AM
Lab ID:	0507009-01B	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	2.93	0.0200		mg/L	1	7/5/2005 12:09:30 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ063005:1015 NP2-6
Lab Order:	0507009	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:15:00 AM
Lab ID:	0507009-01C	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.492	0.0200		mg/L	1	7/5/2005 12:03:36 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: WQ063005:1020 NP2-7
Lab Order: 0507009	Tag Number: 6233
Project: Rowe Industries	Collection Date: 6/30/2005 10:20:00 AM
Lab ID: 0507009-02A	Date Received: 7/1/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
2-Butanone	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
2-Hexanone	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Acetone	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Benzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Bromobenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Bromoform	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Bromomethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Chloroethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ063005:1020 NP2-7
 Lab Order: 0507009 Tag Number: 6233
 Project: Rowe Industries Collection Date: 6/30/2005 10:20:00 AM
 Lab ID: 0507009-02A Date Received: 7/1/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Chloromethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Dibromomethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/2/2005 4:42:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Methylene chloride	U	1.0	B	µg/L	1	7/2/2005 4:42:00 AM
Naphthalene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
o-Xylene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Styrene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Tetrachloroethene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Toluene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Trichloroethene	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/2/2005 4:42:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/2/2005 4:42:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ063005:1020 NP2-7
Lab Order:	0507009	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:20:00 AM
Lab ID:	0507009-02B	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	1.35	0.0200		mg/L	1	7/5/2005 12:16:12 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 7 of 12

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ063005:1020 NP2-7
Lab Order:	0507009	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:20:00 AM
Lab ID:	0507009-02C	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.369	0.0200		mg/L	1	7/5/2005 12:12:34 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 8 of 12

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ063005:1025 NP2-10
Lab Order:	0507009	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:25:00 AM
Lab ID:	0507009-03A	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
2-Butanone	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
2-Hexanone	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Acetone	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Benzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Bromobenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Bromoform	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Bromomethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Chloroethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ063005:1025 NP2-10
 Lab Order: 0507009 Tag Number: 6233
 Project: Rowe Industries Collection Date: 6/30/2005 10:25:00 AM
 Lab ID: 0507009-03A Date Received: 7/1/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Chloromethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Dibromomethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/2/2005 5:15:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Methylene chloride	U	1.0	B	µg/L	1	7/2/2005 5:15:00 AM
Naphthalene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
o-Xylene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Styrene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Tetrachloroethene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Toluene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Trichloroethene	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/2/2005 5:15:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/2/2005 5:15:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ063005:1025 NP2-10
Lab Order:	0507009	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:25:00 AM
Lab ID:	0507009-03B	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	10.5	0.0200		mg/L	1	7/5/2005 12:21:12 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 12-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ063005:1025 NP2-10
Lab Order:	0507009	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:25:00 AM
Lab ID:	0507009-03C	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.362	0.0200		mg/L	1	7/5/2005 12:19:03 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: WN
Total Dissolved Solids (Residue, Filterable)	130	1.0		mg/L	1	7/7/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, June 29, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0506176

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 6/21/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0506176

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0506176-01A	RW-9	6356	6/16/2005 2:53:00 PM	6/21/2005
0506176-01B	RW-9	6356	6/16/2005 2:53:00 PM	6/21/2005
0506176-01C	RW-9	6356	6/16/2005 2:53:00 PM	6/21/2005
0506176-01D	RW-9	6356	6/16/2005 2:53:00 PM	6/21/2005
0506176-02A	RW-8	6356	6/16/2005 3:05:00 PM	6/21/2005
0506176-02B	RW-8	6356	6/16/2005 3:05:00 PM	6/21/2005
0506176-02C	RW-8	6356	6/16/2005 3:05:00 PM	6/21/2005
0506176-02D	RW-8	6356	6/16/2005 3:05:00 PM	6/21/2005
0506176-03A	RW-7	6356	6/16/2005 3:15:00 PM	6/21/2005
0506176-03B	RW-7	6356	6/16/2005 3:15:00 PM	6/21/2005
0506176-03C	RW-7	6356	6/16/2005 3:15:00 PM	6/21/2005
0506176-03D	RW-7	6356	6/16/2005 3:15:00 PM	6/21/2005
0506176-04A	RW-6	6356	6/16/2005 3:25:00 PM	6/21/2005
0506176-04B	RW-6	6356	6/16/2005 3:25:00 PM	6/21/2005
0506176-04C	RW-6	6356	6/16/2005 3:25:00 PM	6/21/2005
0506176-04D	RW-6	6356	6/16/2005 3:25:00 PM	6/21/2005
0506176-05A	RW-5	6356	6/16/2005 3:35:00 PM	6/21/2005
0506176-05B	RW-5	6356	6/16/2005 3:35:00 PM	6/21/2005
0506176-05C	RW-5	6356	6/16/2005 3:35:00 PM	6/21/2005
0506176-05D	RW-5	6356	6/16/2005 3:35:00 PM	6/21/2005
0506176-06A	RW-3	6356	6/16/2005 1:40:00 PM	6/21/2005
0506176-06B	RW-3	6356	6/16/2005 1:40:00 PM	6/21/2005
0506176-06C	RW-3	6356	6/16/2005 1:40:00 PM	6/21/2005
0506176-06D	RW-3	6356	6/16/2005 1:40:00 PM	6/21/2005
0506176-07A	RW-2	6356	6/16/2005 1:45:00 PM	6/21/2005
0506176-07B	RW-2	6356	6/16/2005 1:45:00 PM	6/21/2005
0506176-07C	RW-2	6356	6/16/2005 1:45:00 PM	6/21/2005
0506176-07D	RW-2	6356	6/16/2005 1:45:00 PM	6/21/2005
0506176-08A	RW-1	6356	6/16/2005 1:50:00 PM	6/21/2005
0506176-08B	RW-1	6356	6/16/2005 1:50:00 PM	6/21/2005
0506176-08C	RW-1	6356	6/16/2005 1:50:00 PM	6/21/2005
0506176-08D	RW-1	6356	6/16/2005 1:50:00 PM	6/21/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
 (631) 454-6100 • FAX (631) 454-8027

TAG # / COC 6356

NYSDOH 11418
 CTDOH PH-0205
 NJDEP NY050
 PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBG 126 Monroe Turnpike Trumbull, CT 06611	CONTACT: M. Goldberg	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES / <input type="checkbox"/> NO
		SAMPLER NAME (PRINT) Steve Silvestri	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES / <input type="checkbox"/> NO

PROJECT LOCATION: Rowe					ANALYSIS REQUIRED							FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	8060	MTBE	PHEN 13	TOTAL FE	DISS. BFE	DISS. Methylene	TPS	
052061767ABC	L	5	6/16/05 1419	RW-9	X	X	X	X	X	X		
2ABC	↓	↓	1505	RW-8	↓	↓	↓	↓	↓	↓		
3ABC	↓	↓	1515	RW-7	↓	↓	↓	↓	↓	↓		
4ABC	↓	↓	1525	RW-6	↓	↓	↓	↓	↓	↓		
5ABC	↓	↓	1535	RW-5	↓	↓	↓	↓	↓	↓		
6ABC	↓	↓	1340	RW-A3	↓	↓	↓	↓	↓	↓		
7ABC	↓	↓	1345	RW-2	↓	↓	↓	↓	↓	↓		
8ABC	↓	↓	1350	RW-1	↓	↓	↓	↓	↓	↓		

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON				TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY 1 / 1		COOLER TEMPERATURE: COMMENTS / INSTRUCTIONS	
RELINQUISHED BY (SIGNATURE)	DATE	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE	PRINTED NAME		
	6/20/05 1630	Steve Silvestri		6/20/05 1050	P. Altomiro		
RELINQUISHED BY (SIGNATURE)	DATE	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE	PRINTED NAME		
	TIME			TIME			

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: RW-9
Lab Order: 0506176	Tag Number: 6356
Project: Rowe Industries	Collection Date: 6/16/2005 2:53:00 PM
Lab ID: 0506176-01A	Date Received: 6/21/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,1,1-Trichloroethane	5.8	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,1-Dichloroethane	0.91	1.0	J	µg/L	1	6/22/2005 11:24:00 PM
1,1-Dichloroethene	1.2	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
2-Butanone	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
2-Hexanone	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Acetone	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Benzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Bromobenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Bromochloromethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Bromodichloromethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Bromoform	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Bromomethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Carbon disulfide	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Chlorobenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Chloroethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: RW-9
 Lab Order: 0506176 Tag Number: 6356
 Project: Rowe Industries Collection Date: 6/16/2005 2:53:00 PM
 Lab ID: 0506176-01A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Chloromethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Dibromochloromethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Dibromomethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Ethylbenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Isopropylbenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
m,p-Xylene	U	2.0		µg/L	1	6/22/2005 11:24:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Methylene chloride	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Naphthalene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
n-Butylbenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
n-Propylbenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
o-Xylene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Styrene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Tetrachloroethene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Toluene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Trichloroethene	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Vinyl acetate	U	1.0		µg/L	1	6/22/2005 11:24:00 PM
Vinyl chloride	U	1.0		µg/L	1	6/22/2005 11:24:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-9
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 2:53:00 PM
Lab ID:	0506176-01B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7				Analyst: JP
Iron	1.38	0.0200		mg/L	1	6/27/2005 2:38:17 PM
Manganese	1.23	0.0200		mg/L	1	6/27/2005 2:38:17 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-9
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 2:53:00 PM
Lab ID:	0506176-01C	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.149	0.0200		mg/L	1	6/27/2005 2:34:49 PM
Manganese	1.21	0.0200		mg/L	1	6/27/2005 2:34:49 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-9
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 2:53:00 PM
Lab ID:	0506176-01D	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						
Hardness, Calcium/Magnesium (As CaCO3)	23.8	1.00	M2340 B	mg/L	1	6/27/2005
						Analyst: JP
TURBIDITY						
Turbidity	U	1.00	E180.1 H	NTU	1	6/22/2005
						Analyst: KK

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-8
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:05:00 PM
Lab ID:	0506176-02A	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,1,1-Trichloroethane	5.8	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,1-Dichloroethane	2.1	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,1-Dichloroethene	1.7	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Acetone	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: RW-8
 Lab Order: 0506176 Tag Number: 6356
 Project: Rowe Industries Collection Date: 6/16/2005 3:05:00 PM
 Lab ID: 0506176-02A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 1:12:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Tetrachloroethene	2.7	1.0		µg/L	1	6/23/2005 1:12:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Trichloroethene	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 1:12:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 1:12:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-8
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:05:00 PM
Lab ID:	0506176-02B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7				Analyst: JP
Iron	7.06	0.0200		mg/L	1	6/27/2005 2:59:39 PM
Manganese	0.603	0.0200		mg/L	1	6/27/2005 2:59:39 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-8
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:05:00 PM
Lab ID:	0506176-02C	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0325	0.0200		mg/L	1	6/27/2005 2:56:30 PM
Manganese	0.593	0.0200		mg/L	1	6/27/2005 2:56:30 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-8
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:05:00 PM
Lab ID:	0506176-02D	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	23.6	M2340 1.00	B	mg/L	1	Analyst: JP 6/27/2005
TURBIDITY Turbidity	U	E180.1 1.00	H	NTU	1	Analyst: KK 6/22/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** RW-7
Lab Order: 0506176 **Tag Number:** 6356
Project: Rowe Industries **Collection Date:** 6/16/2005 3:15:00 PM
Lab ID: 0506176-03A **Date Received:** 6/21/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,1,1-Trichloroethane	4.7	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,1-Dichloroethane	1.5	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,1-Dichloroethene	1.1	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Acetone	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-7
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:15:00 PM
Lab ID:	0506176-03A	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 1:48:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Tetrachloroethene	32	1.0		µg/L	1	6/23/2005 1:48:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Trichloroethene	1.0	1.0		µg/L	1	6/23/2005 1:48:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 1:48:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 1:48:00 AM

Qualifiers:	• Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
E Value above quantitation range	H Holding times for preparation or analysis exceeded	ND Not Detected at the Reporting Limit
J Analyte detected below quantitation limits	U Indicates the compound was analyzed for but not detected	
S Spike Recovery outside accepted recovery limits		

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-7
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:15:00 PM
Lab ID:	0506176-03B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0753	0.0200		mg/L	1	6/27/2005 3:05:29 PM
Manganese	0.0527	0.0200		mg/L	1	6/27/2005 3:05:29 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-7
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:15:00 PM
Lab ID:	0506176-03C	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0200	0.0200	J	mg/L	1	6/27/2005 3:02:34 PM
Manganese	0.0539	0.0200		mg/L	1	6/27/2005 3:02:34 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-7
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:15:00 PM
Lab ID:	0506176-03D	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	30.6	1.00		mg/L	1	6/27/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00	H	NTU	1	6/22/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: RW-6
 Lab Order: 0506176 Tag Number: 6356
 Project: Rowe Industries Collection Date: 6/16/2005 3:25:00 PM
 Lab ID: 0506176-04A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,1,1-Trichloroethane	13	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,1-Dichloroethene	2.1	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Acetone	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: RW-6
 Lab Order: 0506176 Tag Number: 6356
 Project: Rowe Industries Collection Date: 6/16/2005 3:25:00 PM
 Lab ID: 0506176-04A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 2:24:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Tetrachloroethene	69	1.0		µg/L	1	6/23/2005 2:24:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Trichloroethene	1.6	1.0		µg/L	1	6/23/2005 2:24:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 2:24:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 2:24:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-6
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:25:00 PM
Lab ID:	0506176-04B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0670	0.0200		mg/L	1	6/27/2005 3:13:13 PM
Manganese	0.234	0.0200		mg/L	1	6/27/2005 3:13:13 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: RW-6
 Lab Order: 0506176 Tag Number: 6356
 Project: Rowe Industries Collection Date: 6/16/2005 3:25:00 PM
 Lab ID: 0506176-04C Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0195	0.0200	J	mg/L	1	6/27/2005 3:07:57 PM
Manganese	0.249	0.0200		mg/L	1	6/27/2005 3:07:57 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-6
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:25:00 PM
Lab ID:	0506176-04D	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	33.3	M2340 1.00	B	mg/L	1	Analyst: JP 6/27/2005
TURBIDITY Turbidity	U	E180.1 1.00	H	NTU	1	Analyst: KK 6/22/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-5
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:35:00 PM
Lab ID:	0506176-05A	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Acetone	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: RW-5
 Lab Order: 0506176 Tag Number: 6356
 Project: Rowe Industries Collection Date: 6/16/2005 3:35:00 PM
 Lab ID: 0506176-05A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 3:00:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Tetrachloroethene	4.7	1.0		µg/L	1	6/23/2005 3:00:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Trichloroethene	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 3:00:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 3:00:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-5
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:35:00 PM
Lab ID:	0506176-05B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0177	0.0200	J	mg/L	1	6/28/2005 2:24:30 PM
Manganese	0.00823	0.0200	J	mg/L	1	6/28/2005 2:24:30 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-5
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 3:35:00 PM
Lab ID:	0506176-05C	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	U	0.0200		mg/L	1	6/28/2005 2:21:43 PM
Manganese	0.00860	0.0200	J	mg/L	1	6/28/2005 2:21:43 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: RW-5
Lab Order: 0506176	Tag Number: 6356
Project: Rowe Industries	Collection Date: 6/16/2005 3:35:00 PM
Lab ID: 0506176-05D	Date Received: 6/21/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	35.2	M2340 1.00	B	mg/L	1	Analyst: JP 6/28/2005
TURBIDITY Turbidity	U	E180.1 1.00	H	NTU	1	Analyst: KK 6/22/2005

Qualifiers:	• Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
E Value above quantitation range	J Analyte detected below quantitation limits	H Holding times for preparation or analysis exceeded
S Spike Recovery outside accepted recovery limits		ND Not Detected at the Reporting Limit
		U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-3
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:40:00 PM
Lab ID:	0506176-06A	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Acetone	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: RW-3
 Lab Order: 0506176 Tag Number: 6356
 Project: Rowe Industries Collection Date: 6/16/2005 1:40:00 PM
 Lab ID: 0506176-06A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 3:36:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Tetrachloroethene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Trichloroethene	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 3:36:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 3:36:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-3
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:40:00 PM
Lab ID:	0506176-06B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	9.91	0.0200		mg/L	1	6/28/2005 2:30:46 PM
Manganese	0.192	0.0200		mg/L	1	6/28/2005 2:30:46 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Legette Brashears & Graham Inc.	Client Sample ID:	RW-3
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:40:00 PM
Lab ID:	0506176-06C	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	10.0	0.0200		mg/L	1	6/28/2005 2:27:28 PM
Manganese	0.201	0.0200		mg/L	1	6/28/2005 2:27:28 PM

Qualifiers:	• Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-3
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:40:00 PM
Lab ID:	0506176-06D	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	37.4	M2340 1.00	B	mg/L	1	Analyst: JP 6/28/2005
TURBIDITY Turbidity	2.30	E180.1 1.00	H	NTU	1	Analyst: KK 6/22/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: RW-2
Lab Order: 0506176	Tag Number: 6356
Project: Rowe Industries	Collection Date: 6/16/2005 1:45:00 PM
Lab ID: 0506176-07A	Date Received: 6/21/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,1,1-Trichloroethane	1.0	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
4-isopropyltoluene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Acetone	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: RW-2
 Lab Order: 0506176 Tag Number: 6356
 Project: Rowe Industries Collection Date: 6/16/2005 1:45:00 PM
 Lab ID: 0506176-07A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
cis-1,2-Dichloroethene	2.0	1.0		µg/L	1	6/23/2005 4:12:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 4:12:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Tetrachloroethene	12	1.0		µg/L	1	6/23/2005 4:12:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Trichloroethene	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 4:12:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 4:12:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-2
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:45:00 PM
Lab ID:	0506176-07B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	3.50	0.0200		mg/L	1	6/28/2005 2:38:24 PM
Manganese	0.782	0.0200		mg/L	1	6/28/2005 2:38:24 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-2
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:45:00 PM
Lab ID:	0506176-07C	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0511	0.0200		mg/L	1	6/28/2005 2:34:51 PM
Manganese	0.793	0.0200		mg/L	1	6/28/2005 2:34:51 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-2
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:45:00 PM
Lab ID:	0506176-07D	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	38.5	1.00		mg/L	1	6/28/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00	H	NTU	1	6/22/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: RW-1
 Lab Order: 0506176 Tag Number: 6356
 Project: Rowe Industries Collection Date: 6/16/2005 1:50:00 PM
 Lab ID: 0506176-08A Date Received: 6/21/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
2-Butanone	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
2-Hexanone	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Acelone	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Benzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Bromobenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Bromochloromethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Bromodichloromethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Bromoform	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Bromomethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Carbon disulfide	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Chlorobenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Chloroethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-1
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:50:00 PM
Lab ID:	0506176-08A	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	4.0	1.0		µg/L	1	6/23/2005 4:48:00 AM
Chloromethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Dibromochloromethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Dibromomethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Ethylbenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Isopropylbenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
m,p-Xylene	U	2.0		µg/L	1	6/23/2005 4:48:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Methylene chloride	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Naphthalene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
n-Butylbenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
n-Propylbenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
o-Xylene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Styrene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Tetrachloroethene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Toluene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Trichloroethene	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Vinyl acetate	U	1.0		µg/L	1	6/23/2005 4:48:00 AM
Vinyl chloride	U	1.0		µg/L	1	6/23/2005 4:48:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-1
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:50:00 PM
Lab ID:	0506176-08B	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	U	0.0200		mg/L	1	6/28/2005 3:00:07 PM
Manganese	0.104	0.0200		mg/L	1	6/28/2005 3:00:07 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-1
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:50:00 PM
Lab ID:	0506176-08C	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE						Analyst: JP
Iron	U	0.0200		mg/L	1	6/28/2005 2:57:32 PM
Manganese	0.108	0.0200		mg/L	1	6/28/2005 2:57:32 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jun-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	RW-1
Lab Order:	0506176	Tag Number:	6356
Project:	Rowe Industries	Collection Date:	6/16/2005 1:50:00 PM
Lab ID:	0506176-08D	Date Received:	6/21/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	45.3	M2340 1.00	B	mg/L	1	Analyst: JP 6/28/2005
TURBIDITY Turbidity	U	E180.1 1.00	H	NTU	1	Analyst: KK 6/22/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Monday, July 11, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0507010

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 1 sample(s) on 7/1/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.


Sincerely,

Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0507010

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0507010-01A	GWQ063005:1035 NP1-1-4	6233	6/30/2005 10:35:00 AM	7/1/2005
0507010-01B	GWQ063005:1035 NP1-1-4	6233	6/30/2005 10:35:00 AM	7/1/2005
0507010-01C	GWQ063005:1035 NP1-1-4	6233	6/30/2005 10:35:00 AM	7/1/2005
0507010-01D	GWQ063005:1035 NP1-1-4	6233	6/30/2005 10:35:00 AM	7/1/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC 6233

NYSDOH 11418
CTDOH PH-0205
NJDEP NY050
PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBC 120 MONROE TPK TRUMBULL CT 06611	CONTACT: MARK GOLDBERG.	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES / <input type="checkbox"/> NO
		SAMPLER NAME (PRINT) TUNDE H KOVACS-SANDOR	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES / <input type="checkbox"/> NO

PROJECT LOCATION:
ROWE INDUSTRIES, SPA HARBOR NY

LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED										FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]					
					ARSENIC	BARIUM	CADMIUM	COPPER	CHLORIDE	CHROMIUM	COBALT	IRON	LEAD	MANGANESE		NICKEL	SILICA	TURBIDITY		
0507009-1A	WATER	4	6/30/05 10:15	WQ063005; 1015 MP2-6	X	X	X													
2APC		4	10:20	WQ063005; 1020 NP2-7	↓	↓	↓													
3APC		5	10:25	WQ063005; 1025 MP2-10	↓	↓	↓							X						
0507010-1A	↓	5	10:35	WQ063005; 1035 MPI-1-4	↓	↓	↓	X	X	X	X	X	X							

10:50. Put results of MPI-1-4 on separate chain

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON	TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY 1/1	COOLER TEMPERATURE:	COMMENTS / INSTRUCTIONS
RELINQUISHED BY (SIGNATURE) 	DATE 6/30/05 TIME 17:00	PRINTED NAME Mark M. Goldberg	RECEIVED BY LAB (SIGNATURE)
RELINQUISHED BY (SIGNATURE) (Blank)	DATE (Blank) TIME (Blank)	PRINTED NAME (Blank)	RECEIVED BY LAB (SIGNATURE) (Blank)
			DATE 7/1/05 TIME 11:00 PRINTED NAME P. Ardonio

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 11-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ063005:1035 NP1-1-4
 Lab Order: 0507010 Tag Number: 6233
 Project: Rowe Industries Collection Date: 6/30/2005 10:35:00 AM
 Lab ID: 0507010-01A Date Received: 7/1/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
2-Butanone	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
2-Hexanone	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Acetone	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Benzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Bromobenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Bromoform	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Bromomethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Chloroethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ063005:1035 NP1-1-4
Lab Order:	0507010	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:35:00 AM
Lab ID:	0507010-01A	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Chloromethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Dibromomethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/2/2005 8:00:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Methylene chloride	4.5	1.0	B	µg/L	1	7/2/2005 8:00:00 AM
Naphthalene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
o-Xylene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Styrene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Tetrachloroethene	74	1.0		µg/L	1	7/2/2005 8:00:00 AM
Toluene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Trichloroethene	2.6	1.0		µg/L	1	7/2/2005 8:00:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/2/2005 8:00:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/2/2005 8:00:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ063005:1035 NP1-1-4
Lab Order:	0507010	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:35:00 AM
Lab ID:	0507010-01B	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7				Analyst: JP
Iron	9.95	0.0200		mg/L	1	7/5/2005 12:24:27 PM
Manganese	1.34	0.0200		mg/L	1	7/5/2005 12:24:27 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ063005:1035 NP1-1-4
Lab Order:	0507010	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:35:00 AM
Lab ID:	0507010-01C	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	9.28	0.0200		mg/L	1	7/5/2005 12:26:33 PM
Manganese	1.28	0.0200		mg/L	1	7/5/2005 12:26:33 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 11-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ063005:1035 NP1-1-4
Lab Order:	0507010	Tag Number:	6233
Project:	Rowe Industries	Collection Date:	6/30/2005 10:35:00 AM
Lab ID:	0507010-01D	Date Received:	7/1/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	31.3	M2340 B 1.00		mg/L	1	Analyst: JP 7/1/2005
TURBIDITY Turbidity	U	E180.1 1.00		NTU	1	Analyst: KK 7/1/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	220	E160.1 1.0		mg/L	1	Analyst: WN 7/7/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

ANALYTICAL REPORT

JOB NUMBER: 209983

Prepared For:

LEGGETTE, BRASHEARS & GRAHAM
126 Monroe Turnpike
Trumbull, CT 06611


Project: ROWE INDUSTRIES

Attention: Mark Goldberg

Date: 07/20/2005



Signature



Date

Name: William D. Goodman

Title: Project Manager

E-Mail: wgoodman@stl-inc.com

STL Connecticut
128 Long Hill Cross Road
Shelton, CT 06484

This Report Contains (125) Pages

STL Report : 209983
LEGGETTE, BRASHEARS, & GRAHAM

Case Narrative

Sample Receipt – All samples were received in good condition.

Volatile Organics – Air volatile organics were determined by purge and trap GC/MS using guidance provided in Method TO-17. The instrumentation used was a Perkin Elmer ATD 50 interfaced with a Hewlett-Packard Model 5972A GC/MS/DS.

The samples in this job were collected in tedlar bags. Samples were transferred by the laboratory to Air Toxic TO-17 tubes and analyzed at sample volumes of 1L except for sample AQ062405:1240NP4-1 which was analyzed at a sample volume of .5L in addition to a 1L analysis. The .5L run was designated with the suffix “DL”.

Sample Calculation:

Sample ID- AQ062405:1240NP4-1
Compound-Bromomethane

$$\frac{(119734 \text{ area})(25\text{ng})}{(118118 \text{ area})(.318 \text{ area/ng})} = 79.69 = 80 \text{ ng}$$

$$\frac{(80\text{NG})(.08206)(298)}{(.5\text{L})(95)(1.0\text{ATM})} = 41.18 = 41.2 \text{ nL/L.}$$

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in the case narrative.

SAMPLE INFORMATION

Date: 07/20/2005

Job Number.: 209983
 Customer...: LEGGETTE, BRASHEARS & GRAHAM
 Attn.....: Mark Goldberg

Project Number.....: 20000283
 Customer Project ID....: ROWE INDUSTRIES
 Project Description....: Rowe Industries

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
209983-1	AQ062405:1240NP4-1	Air	06/24/2005	12:40	06/27/2005	14:00
209983-2	AQ062405:1241NP4-2	Air	06/24/2005	12:41	06/27/2005	14:00
209983-3	AQ062405:1242NP4-3	Air	06/24/2005	12:42	06/27/2005	14:00

STL Connecticut		Form 1		Client Sample ID 1240NP4-1	
Method: TO17		Lab Sample ID 209983-1			
Sample Volume (L)	1.000	Date Sampled 6/24/2005			
Temp (C)	25	Date Analyzed 6/28/2005			
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL	
Chloromethane	9.7 U	9.7	0.020 U	0.020	
Vinyl Chloride	7.8 U	7.8	0.020 U	0.020	
Bromomethane	5.1 U	5.1	0.020 U	0.020	
Chloroethane	7.6 U	7.6	0.020 U	0.020	
1,1-Dichloroethene	2.5 U	2.5	0.010 U	0.010	
Carbon Disulfide	19.6	3.2	0.061	0.010	
Methylene Chloride	10.7 B	2.9	0.037 B	0.010	
trans-1,2-Dichloroethene	2.5 U	2.5	0.010 U	0.010	
1,1-Dichloroethane	7.9	2.5	0.032	0.010	
cis-1,2-Dichloroethene	1.5 J	2.5	0.006 J	0.010	
Chloroform	1.4 J	2.1	0.007 J	0.010	
1,1,1-Trichloroethane	17.5	1.8	0.095	0.010	
Carbon Tetrachloride	1.6 U	1.6	0.010 U	0.010	
Benzene	5.9 B	3.1	0.019 B	0.010	
1,2-Dichloroethane	2.5 U	2.5	0.010 U	0.010	
Trichloroethene	5.6	1.9	0.030	0.010	
1,2-Dichloropropane	2.2 U	2.2	0.010 U	0.010	
Bromodichloromethane	1.5 U	1.5	0.010 U	0.010	
cis-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010	
Toluene	15.9	2.7	0.060	0.010	
trans-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010	
1,1,2-Trichloroethane	1.8 U	1.8	0.010 U	0.010	
Tetrachloroethene	50.1 A	1.5	0.340 A	0.010	
Dibromochloromethane	1.2 U	1.2	0.010 U	0.010	
Chlorobenzene	2.2 U	2.2	0.010 U	0.010	
Ethylbenzene	0.5 J	2.3	0.002 J	0.010	
m&p-Xylenes	2.3 U	2.3	0.010 U	0.010	
o-Xylene	2.3 U	2.3	0.010 U	0.010	
Styrene	1.4 J	2.4	0.006 J	0.010	
Bromoform	1.0 U	1.0	0.010 U	0.010	
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.010 U	0.010	

STL Connecticut		Form 1		Client Sample ID	1240NP4-1DL
Method: TO17				Lab Sample ID	209983-1DL
Sample Volume (L)	0.500			Date Sampled	6/24/2005
Temp (C)	25			Date Analyzed	6/28/2005
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3	Qualifier	RL
Chloromethane	19.4 U	19.4	0.040	U	0.040
Vinyl Chloride	15.7 U	15.7	0.040	U	0.040
Bromomethane	41.2 B	10.3	0.160	B	0.040
Chloroethane	15.2 U	15.2	0.040	U	0.040
1,1-Dichloroethene	5.0 U	5.0	0.020	U	0.020
Carbon Disulfide	17.4	6.4	0.054		0.020
Methylene Chloride	41.5 B	5.8	0.144	B	0.020
trans-1,2-Dichloroethene	5.1 U	5.1	0.020	U	0.020
1,1-Dichloroethane	4.9 U	4.9	0.020	U	0.020
cis-1,2-Dichloroethene	5.1 U	5.1	0.020	U	0.020
Chloroform	4.1 U	4.1	0.020	U	0.020
1,1,1-Trichloroethane	18.4	3.7	0.100		0.020
Carbon Tetrachloride	3.2 U	3.2	0.020	U	0.020
Benzene	14.4 B	6.3	0.046	B	0.020
1,2-Dichloroethane	4.9 U	4.9	0.020	U	0.020
Trichloroethene	5.2	3.7	0.028		0.020
1,2-Dichloropropane	4.3 U	4.3	0.020	U	0.020
Bromodichloromethane	3.0 U	3.0	0.020	U	0.020
cis-1,3-Dichloropropene	4.4 U	4.4	0.020	U	0.020
Toluene	19.6	5.3	0.074		0.020
trans-1,3-Dichloropropene	4.4 U	4.4	0.020	U	0.020
1,1,2-Trichloroethane	3.7 U	3.7	0.020	U	0.020
Tetrachloroethene	53.0	2.9	0.360		0.020
Dibromochloromethane	2.4 U	2.4	0.020	U	0.020
Chlorobenzene	4.3 U	4.3	0.020	U	0.020
Ethylbenzene	4.6 U	4.6	0.020	U	0.020
m&p-Xylenes	0.9 J	4.6	0.004	J	0.020
o-Xylene	4.6 U	4.6	0.020	U	0.020
Styrene	4.7 U	4.7	0.020	U	0.020
Bromoform	1.9 U	1.9	0.020	U	0.020
1,1,2,2-Tetrachloroethane	2.9 U	2.9	0.020	U	0.020

STL Connecticut		Form 1		
		Client Sample ID	1241NP4-2	
Method: TO17		Lab Sample ID	209983-2	
Sample Volume (L)	1.000	Date Sampled	6/24/2005	
Temp (C)	25	Date Analyzed	6/28/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	9.7 U	9.7	0.020 U	0.020
Vinyl Chloride	7.8 U	7.8	0.020 U	0.020
Bromomethane	5.1 U	5.1	0.020 U	0.020
Chloroethane	7.6 U	7.6	0.020 U	0.020
1,1-Dichloroethene	2.5 U	2.5	0.010 U	0.010
Carbon Disulfide	15.1	3.2	0.047	0.010
Methylene Chloride	27.7 B	2.9	0.096 B	0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.010 U	0.010
1,1-Dichloroethane	2.5 U	2.5	0.010 U	0.010
cis-1,2-Dichloroethene	2.5 U	2.5	0.010 U	0.010
Chloroform	1.4 J	2.1	0.007 J	0.010
1,1,1-Trichloroethane	11.6	1.8	0.063	0.010
Carbon Tetrachloride	1.6 U	1.6	0.010 U	0.010
Benzene	7.2 B	3.1	0.023 B	0.010
1,2-Dichloroethane	2.5 U	2.5	0.010 U	0.010
Trichloroethene	1.9 U	1.9	0.010 U	0.010
1,2-Dichloropropane	2.2 U	2.2	0.010 U	0.010
Bromodichloromethane	1.5 U	1.5	0.010 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
Toluene	18.9	2.7	0.071	0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.010 U	0.010
Tetrachloroethene	1.5 U	1.5	0.010 U	0.010
Dibromochloromethane	1.2 U	1.2	0.010 U	0.010
Chlorobenzene	2.2 U	2.2	0.010 U	0.010
Ethylbenzene	2.3 U	2.3	0.010 U	0.010
m&p-Xylenes	1.2 J	2.3	0.005 J	0.010
o-Xylene	2.3 U	2.3	0.010 U	0.010
Styrene	1.4 J	2.4	0.006 J	0.010
Bromoform	1.0 U	1.0	0.010 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.010 U	0.010

Form 1

STL Connecticut

Client Sample ID 1242NP4-3

Method: TO17

Lab Sample ID 209983-3

Sample Volume (L) 1.000

Date Sampled 6/24/2005

Temp (C) 25

Date Analyzed 6/28/2005

Compound	nL/L		mg/M3	
	(ppbv/v) Qualifier	RL	Qualifier	RL
Chloromethane	9.7 U	9.7	0.020 U	0.020
Vinyl Chloride	7.8 U	7.8	0.020 U	0.020
Bromomethane	13.9 B	5.1	0.054 B	0.020
Chloroethane	7.6 U	7.6	0.020 U	0.020
1,1-Dichloroethene	2.5 U	2.5	0.010 U	0.010
Carbon Disulfide	7.1	3.2	0.022	0.010
Methylene Chloride	18.1 B	2.9	0.063 B	0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.010 U	0.010
1,1-Dichloroethane	2.5 U	2.5	0.010 U	0.010
cis-1,2-Dichloroethene	2.5 U	2.5	0.010 U	0.010
Chloroform	0.8 J	2.1	0.004 J	0.010
1,1,1-Trichloroethane	2.2	1.8	0.012	0.010
Carbon Tetrachloride	1.6 U	1.6	0.010 U	0.010
Benzene	0.6 JB	3.1	0.002 JB	0.010
1,2-Dichloroethane	2.5 U	2.5	0.010 U	0.010
Trichloroethene	1.9 U	1.9	0.010 U	0.010
1,2-Dichloropropane	2.2 U	2.2	0.010 U	0.010
Bromodichloromethane	1.5 U	1.5	0.010 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
Toluene	9.3	2.7	0.035	0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.010 U	0.010
Tetrachloroethene	1.5 U	1.5	0.010 U	0.010
Dibromochloromethane	1.2 U	1.2	0.010 U	0.010
Chlorobenzene	2.2 U	2.2	0.010 U	0.010
Ethylbenzene	2.3 U	2.3	0.010 U	0.010
m&p-Xylenes	0.5 J	2.3	0.002 J	0.010
o-Xylene	2.3 U	2.3	0.010 U	0.010
Styrene	0.9 J	2.4	0.004 J	0.010
Bromoform	1.0 U	1.0	0.010 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.010 U	0.010

LABORATORY CHRONICLE

Job Number: 209983

Date: 07/20/2005

CUSTOMER: LEGGETTE, BRASHEARS & GRAHAM

PROJECT: ROWE INDUSTRIES

ATTN: Mark Goldberg

Lab ID:	Client ID:	Date Recvd:	Sample Date:			DILUTION
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED
209983-1	AQ062405:1240NP4-1	06/27/2005	06/24/2005			
T017	Volatile Organics (Air)	1	51282			1.00000
209983-2	AQ062405:1241NP4-2	06/27/2005	06/24/2005			
T017	Volatile Organics (Air)	1	51282			1.00000
209983-3	AQ062405:1242NP4-3	06/27/2005	06/24/2005			
T017	Volatile Organics (Air)	1	51282			1.00000

AIR 2A
 WATER VOLATILE SYSTEM MONITORING COMPOUND RECOVERY

Jan 7/19/05

Lab Name: STL-CT

Contract:

Lab Code: STL-CT

Case No.: 209983

SAS No.:

SDG No.: 209983

	EPA SAMPLE NO.	SMC1 #	SMC2 (DCE) #	SMC3 (TOL) #	OTHER (BFB) #	TOT OUT
01	20NGQCS	97	78	101	100	0
02	VBLKTK	101	81	105	102	0
03	AQ062405 124	106	82	100	101	0
04	AQ062405 124	101	81	102	103	0
05	AQ062405 124	99	78	107	100	0
06	AQ0624051240	100	76	108	101	0
07						
08						
09						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

QC LIMITS

SMC1 = Dibromofluoromethane (70-130)
 SMC2 (DCE) = 1,2-Dichloroethane-d4 (70-130)
 SMC3 (TOL) = Toluene-d8 (70-130)
 OTHER (BFB) = Bromofluorobenzene (70-130)

Column to be used to flag recovery values

* Values outside of contract required QC limits

FORM 3

Data File: \\TARGET1_CT\FILES\chem\VOA\mst.i\T054999.b\T5000.D Page 3
 Report Date: 28-Jun-2005 14:30

STL-CT

RECOVERY REPORT

Client Name: Client SDG: SDGa24843
 Sample Matrix: LIQUID Fraction: VOA
 Lab Smp Id: 20ngQCS Client Smp ID: 20ngQCS
 Level: LOW Operator: B.Kostrzewska
 Data Type: MS DATA SampleType: LCS
 SpikeList File: AIRQCS.spk Quant Type: ISTD
 Sublist File: all.sub
 Method File: \\TARGET1_CT\Files\chem\VOA\mst.i\T054999.b\TAIRFULL.m
 Misc Info: : ;;; 20ngQCS; * 1L* ; AIR

SPIKE COMPOUND	CONC. ADDED ug/L	CONC RECOVERED ug/L	% RECOVERED	LIMITS
4 Vinyl Chloride	20	18	89.20	60-140
5 Bromomethane	20	27	137.34	60-140
6 Chloroethane	20	16	77.74	60-140
12 1,1-Dichloroethene	20	16	78.78	60-140
11 Trichlorotrifluoro	20	23	115.51	60-140
17 Acetone	20	16	78.36	60-140
13 Carbon Disulfide	20	14	69.44	60-140
16 Methylene Chloride	20	54	268.72*	60-140
18 trans-1,2-Dichloro	20	16	78.16	60-140
28 1,1-Dichloroethane	20	16	81.02	60-140
30 cis-1,2-Dichloroet	20	14	72.29	60-140
40 2-Butanone	20	14	72.11	60-140
33 Chloroform	20	15	72.60	60-140
38 1,1,1-Trichloroeth	20	15	73.19	60-140
39 Carbon Tetrachlori	20	16	78.35	60-140
51 1,2-Dichloroethane	20	14	71.11	60-140
48 Benzene	20	17	87.28	60-140
56 Trichloroethene	20	15	73.66	60-140
63 cis-1,3-Dichloropr	20	16	81.81	60-140
72 4-Methyl-2-Pentano	20	11	56.58*	60-140
69 Toluene	20	16	81.53	60-140
66 trans-1,3-Dichloro	20	13	62.61	60-140
67 1,1,2-Trichloroeth	20	16	79.55	60-140
73 Tetrachloroethene	20	14	69.99	60-140
75 Dibromochlorometha	20	14	70.80	60-140
80 Chlorobenzene	20	17	83.84	60-140
82 Ethylbenzene	20	15	73.71	60-140
83 Xylene (total)mp	40	31	77.62	60-140
84 Xylene (total)o	20	16	78.28	60-140
85 Styrene	20	13	67.44	60-140
86 Bromoform	20	12	60.62	60-140
89 1,1,2,2-Tetrachlor	20	19	96.44	60-140
101 1,3-Dichlorobenzen	20	16	82.22	60-140
102 1,4-Dichlorobenzen	20	17	86.44	60-140
103 1,2-Dichlorobenzen	20	17	84.19	60-140

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC. Lab Cert. ID# 10604
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviation

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the reporting limit.
- < Not detected at or above the reporting limit.
- J Result is less than the RL, but greater than or equal to the method detection limit.
- B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
- S Result was determined by the Method of Standard Additions.

Inorganic Flags (Flag Column)

- ICV,CCV,ICB,CCB,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed th upper or lower control limits.
- * LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
- + MSA correlation coefficient is less than 0.995.
- 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
- E SD: Serial dilution exceeds the control limits.
- H MB, EB: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
- N MS, MSD: Spike recovery exceeds the upper or lower control limits.
- W PS: Post-digestion spike was outside 85-115% control limits.

Organic Qualifiers (Q - Column)

- U Analyte was not detected at or above the reporting limit.
- ND Compound not detected.
- J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
- Q Result was qualitatively confirmed, but not quantified.
- C Pesticide identification was confirmed by GC/MS.
- Y The chromatographic response resembles a typical fuel pattern.
- Z The chromatographic response does not resemble a typical fuel pattern.
- E Result exceeded calibration range, secondary dilution required.

Organic Flags (Flags Column)

- MB,EB,MLE: Batch QC is greater than reporting limit.
- * LCS, LCD, CCV, MS, MSD, Surrogate, RS:Batch QC exceeds the upper or lower control limits.
- A Concentration exceeds the instrument calibration range or below the reporting limit.
- B Compound was found in the blank.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is greater than 25%.

QUALITY ASSURANCE METHODS
REFERENCES AND NOTES

Abbreviations

Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column
CCB	Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation Analysis
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
Dil Fac	Dilution Factor
DL	Secondary dilution and analysis
DLFac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB	Extraction Blank
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A
ISB	Interference Check Sample B
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group
Lab ID	An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PACK	Packed Column
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PS	Post Spike
PSD	Post Spike Duplicate
RA	Re-analysis
RE	Re-extraction and analysis
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RS	Reference Standard
RT	Retention Time
RTW	Retention Time Window
SampleID	A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB	Seeded Control Blank
SD	Serial Dilution
UCB	Unseeded Control Blank

One or a combination of these data qualifiers and abbreviations may appear in the analytical report.

**STL-Connecticut
Certification Summary (as of May 2005)**

The laboratory identification numbers for the STL-Connecticut laboratory are provided in the following table. Many states certify laboratories for specific parameters or tests within a category (i.e. method 325.2 for wastewater). The information in the following table indicates the lab is certified in a general category of testing such as drinking water or wastewater analysis. The laboratory should be contacted directly if parameter-specific certification information is required.

State	Responsible Agency	Certification	Expiration Date	Lab Number
Connecticut	Department of Health Services	Drinking Water, Wastewater	12/31/06	PH-0497
Maine	Department of Health and Environmental Services	Drinking Water, Wastewater/Solid, Hazardous Waste	04/18/06	CT023
Massachusetts	Department of Environmental Protection	Potable/Non-Potable Water	06/30/05	CT023
New Hampshire	Department of Environmental Services	Drinking Water, Wastewater	08/29/05	2528
New Jersey	Department of Environmental Protection	Drinking Water, Wastewater	06/30/05	CT410
New York	Department of Health	CLP, Drinking Water, Wastewater, Solid/ Hazardous Waste NELAC	04/01/06	10602
Rhode Island	Department of Health	Chemistry...Non- Potable Water and Wastewater	12/30/05	A43
Utah	Department of Health	RCRA	05/31/05	2032614458

MISCELLANEOUS DOCUMENTS

Chain of Custody Record

STL Connecticut
 128 Long Hill Cross Road
 Shelton, CT 06484
 Tel: 203-929-8140

SEVERN TRENT **STL**
Severn Trent Laboratories, Inc.

STL-4124 (0901)

STL CONNECTICUT

Client LRG		Project Manager Mark Goldberg		Date 6/27/05	Chain of Custody Number 02266
Address 126 Monroe Turnpike		Telephone Number (Area Code)/Fax Number 203-452-3100 / 203-452-3111		Lab Number	
City Trumbull	State CT	Zip Code 06611	Site Contact -	Lab Contact B. H. Goodman	Page 1 of 1

Project Name and Location (State) Rowe Sag Harbor, NY	Carrier/Waybill Number	Analysis (Attach list if more space is needed)	Special Instructions/ Conditions of Receipt
Contract/Purchase Order/Quote No.			

Sample I.D. No. and Description (Containers for each sample may be combined on one line)	Date	Time	Matrix				Containers & Preservatives						Analysis				
			Air	Aqueous	Sed.	Soil	Unpres.	H2SO4	HNO3	HCl	NaOH	ZnAc/NaOH					
AQ 062405:1240 NP4-1	6/24/05	12:40	X				X										
AQ 062405:1241 NP4-2	↓	12:41	X				X										
AQ 062405:1242 NP4-3	↓	12:42	X				X										

209983 07/09/2005
 LEGGETTE, BRASHEARS GRAHAM
 MARK GOLDBERG
 ROWE INDUSTRIES

Possible Hazard Identification <input checked="" type="checkbox"/> Non-Hazard <input type="checkbox"/> Flammable <input type="checkbox"/> Skin Irritant <input type="checkbox"/> Poison B <input type="checkbox"/> Unknown	Sample Disposal <input type="checkbox"/> Return To Client <input checked="" type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months	(A fee may be assessed if samples are retained longer than 1 month)
---	--	---

Turn Around Time Required <input type="checkbox"/> 24 Hours <input type="checkbox"/> 48 Hours <input type="checkbox"/> 7 Days <input type="checkbox"/> 14 Days <input type="checkbox"/> 21 Days <input checked="" type="checkbox"/> Other Normal	QC Requirements (Specify) Full QA/QC
---	--

1. Relinquished By Mark M. Goldberg	Date 6-27-05	Time 14:00	1. Received By [Signature]	Date 6-27-05	Time 14:00
2. Relinquished By	Date	Time	2. Received By [Signature]	Date 6/27/05	Time 14:30
3. Relinquished By	Date	Time	3. Received By	Date	Time

Comments