


LEGGETTE, BRASHEARS & GRAHAM, INC.

PROFESSIONAL GROUND-WATER AND ENVIRONMENTAL ENGINEERING SERVICES

126 MONROE TURNPIKE
TRUMBULL, CT 06611
203-452-3100
FAX 203-452-3111
www.lbgweb.com

September 13, 2005



Mr. Jeffery Trad
Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation, Construction Services
625 Broadway, 12th floor
Albany, NY 12233-7013

RE: July 2005 Status Report
Ground-Water Remedial Action
Rowe Industries Superfund Site
Sag Harbor, New York

Dear Mr. Trad:

The enclosed letter report details the operation status of the full-scale ground-water pump and treat system at the above referenced site. LBG has enclosed an additional copy of the report to be forwarded to the Chief of the Operation Maintenance and Support Section.

Should you or the Operation Maintenance and Support Section have any questions, please feel free to contact myself, Paul Jobmann, or Al Kovalik at (203) 452-3100.

Very truly yours,

LEGGETTE, BRASHEARS & GRAHAM, INC.

Mark M. Goldberg
Mark M. Goldberg, P.E.
Senior Environmental Engineer

MG:ng

Enclosures

H:\NABIS\2005\Monthly Reports\July 2005\trad_July2005_report.doc

PROJECT STATUS MEMORANDUM

NO. 07-05

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Alfred N. Kovalik, P.E.

DATE: September 13, 2005

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
July 2005 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from July 1, 2005 through July 31, 2005. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground-water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(July 1, 2005 through July 31, 2005)

- | | |
|---|-----------------------------------|
| 1. Hours of operation during the reporting period: | 651 hours (88%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 15,856,240 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: | yes, (Graph 1) |
| 6. Mass of VOCs recovered during the reporting period: | 2.1 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 169.2 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.195 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00187 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow (gpm)	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-1*	102,191	8.4	26	2.1	0.002
RW-2	1,118,661	27.0	26	12.9	0.12
RW-3	457,536	12.1	23	1.6	0.01
RW-4	1,654,283	41.7	13	45.9	0.63
RW-5	2,314,445	54.9	42	9.8	0.19
RW-6	578,588	14.9	28	75.1	0.36
RW-7**	1,741,094	70.0	54	34.2	0.50
RW-8	2,314,450	52.6	46	6.0	0.12
RW-9	3,298,147	79.9	68	6.5	0.18

* RW-1 was turned off indefinitely on July 13, 2005 because the ground-water concentrations for the primary contaminants of concern (PCE, TCE and 1,1,1-TCA) have not been detected in over two years.

** In addition to the downtime for the system, recovery well RW-7 was not in operation from June 30 to July 8 because of well rehabilitation activities.

Recovery wells RW-1, RW-3 and RW-6 had average flows below the respective minimum design flows determined to be necessary for capture of the plume. Despite periodic pipe cleanings, RW-1 and RW-3 have decreased in flow due to iron build-up in the below-grade pipes. In addition, well rehabilitation activities for RW-3 did not restore flow to the well. Two new cleanout ports in the below grade piping between RW-3 and the remediation building were constructed in July to try and jet wash previously inaccessible piping to attempt to restore the flow to RW-3 (Note: the June 2005 report mistakenly reported that the cleanout ports were constructed in June). Jet wash cleaning from these new clean-out ports will be scheduled in August. Flow in RW-1 decreased to approximately 3 gpm at 100% motor speed on July 13. The primary contaminants of concern (PCE, TCE and 1,1,1-TCA) have been not been detected for at least two years in the water samples from RW-1. Accordingly, RW-1 was turned off indefinitely on July 13, 2005.

Flow at RW-6 was reduced in late June from 23 gpm to 15 gpm to address the threat of de-watering the well and damaging the pump. Build-up of microbial growth in the formation in conjunction with the finer soils associated with the aquifer in the immediate vicinity of RW-6 are believed to be causing the decrease in well yield. Well rehabilitation techniques and chemicals are being investigated for this well. The vendor who supplied the well rehabilitation chemicals previously used has offered to evaluate if he has other chemicals that may work at improving the

well yield. A water sample from this well will be collected in August and sent to the supplier for analysis.

Recovery well rehabilitation for RW-7 showed no improvement in well yield. Fortunately, flow in this well has not decreased as a result of the microbial growth. Microbial growth in RW-7 is believed to be similar to the microbial growth found in RW-6, however flow and specific capacity in RW-7 have not decreased to the same degree as RW-6.

Although the flow in RW-8 is above the minimum design flow to capture the plume, a slow decrease in flow at RW-8 is beginning to occur because of iron build-up in the flow meter and/or piping. The next scheduled pipe cleaning will include cleaning the flow meter and vault piping for RW-8.

The effluent pH values are below the State Pollutant Discharge Elimination System (SPDES) Applicable or Relevant and Appropriate Requirements (ARARs) of 6.5 on a routine basis. July pH readings of water samples from the recovery wells were observed to be in the range of approximately 4.8 to 5.9. The full scale pump and treat system (FSP&T) system does not use any chemical treatment processes to alter pH. In addition, the effluent water discharge and the recovery well extraction points are located in the same aquifer. As discussed with the New York State Department of Environmental Conservation (NYSDEC), because the pH is naturally occurring, and because of the previously mentioned factors, it is not considered an exceedance of the discharge requirements.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
July 1 to July 31	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in July 2005 include:

- From June 30 to July 8, 2005, well rehabilitation for RW-7 was completed.
- On July 7, 2005, the first day of an internal safety audit was conducted. The lead and lag transfer pumps were switched.
- On July 11, 2005, two new cleanout ports were constructed between RW-3 and the remediation building. The trench drain in the front of the building was cleaned.

- On July 12, 2005, the Equalization (EQ) tank, transfer tank and air stripper tower sump were cleaned with a high-pressure vacuum truck. Bag filter housing baskets were cleaned with a wire brush. Individual bag filter housing lines were cleaned with a high-pressure vacuum. The second day of the internal safety audit was conducted for the site.
- On July 13, 2005, RW-1 was turned off indefinitely.
- On July 14, 2005, the signal from the RW-4 pressure sensor was not being received. After troubleshooting, it was determined that the well-head pressure sensor for RW-4 needs to be replaced.

Future O&M activities scheduled for Summer 2005 include:

- Clean below-grade piping from the new cleanout ports between RW-3 and the remediation building;
- Clean the RW-8 flow meter and vault piping;
- Replace the RW-4 well-head pressure sensor;
- Conduct ground-water sampling for the FDSA in August;
- Conduct semi-annual ground-water sampling in September; and,
- Conduct cove salinity monitoring and water level measurements at select piezometers in August.

MMG:ng

Attachments

cc: Phil McAndrew, Kraft Foods, N.A. – .pdf
Lisa Krogman, Kraft Foods, N.A. (Environ) – .pdf
Jeff Trad, NYSDEC
Chief-Operation Maintenance and Support Section, NYSDEC
William Spitz, RWM, R-1, NYSDEC
Eileen A. Powers, Jr., Esq., Town of Southampton

H:\NABIS\2005\Monthly Reports\July 2005\Status0705July.doc

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(July 1, 2005 through July 31, 2005)

Date	Time	System Changes/Modifications	Personnel
7/5/2005	4:30 PM	Control Room Temperature alarm, power failure alarm, RW-1, 2, 3, 4 pump fault alarms, (the power failure alarm triggered other multiple alarms). System shut down.	
7/6/2005	7:10 AM	Reset the alarms and restarted the system.	TS
7/7/2005	11:21 AM	Shut down the system to change the lead/lag pumps. TP1A to TP1B and TP2A to TP2B.	MG
		Replaced the leaking bag filter transfer pump (used during bag filter changes).	MG, SS
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS, TS
		First day of the internal safety audit was conducted by Field Safety Corporation.	MG, MZ, FT
	12:07 PM	Restarted the system	MG
7/8/2005	9:17 AM	Booster Blower Failure Alarm, system shut down.	
	9:36 AM	Reset the booster blower motor starter and restarted the system.	TS
	11:40 AM	RW-7 well rehabilitation was completed, turned RW-7 on.	TS, ETL
	1:12 PM	Power Failure Alarm and RW 1, 2, 3, 4, 6, 8 and 9 pump fault alarms, system shut down.	
	1:20 PM	Reset the recovery well drives, the power failure alarm and pump fault alarms then restarted the system.	TS
7/11/2005	9:20 AM	Turned off RW-1, RW-2 and RW-3 to construct two new cleanout ports for the below-grade piping associated with RW-3.	TS, ETL
	3:55 PM	Construction of the two new cleanout ports was completed. RW-1, 2 and 3 will remain off for upcoming EQ tank, transfer tank and tower sump cleaning on 7/12/05.	ETL
		The trench drain in front of the building was cleaned.	ETL
		The frac tank used for well rehabilitation was cleaned.	ETL
7/12/2005		Cleaned the EQ tank, transfer tank and air stripper tower sump with a vac truck. Removed approximately 6 inches of sediment from the bottom of the EQ tank and air stripper tower. Removed approximately 6 to 12 inches of sediment from the transfer tank.	SS, ETL
		Second day of the internal safety audit for the site was conducted by Field Safety Corporation.	MG, FT
		Cleaned all of the bag filter baskets with a wire brush and vacuumed out individual bag filter housing lines.	ETL
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS, TS
7/13/2005	12:03 PM	Restarted the system. RW-1 was flowing at 3 gpm at 100% motor speed. RW-1 was shut off indefinitely because the primary contaminants of concern (PCE, TCE and 1,1,1 TCA) have been non-detect for over 2 years at this well.	TS
		The frac tank used for well rehabilitation was removed from the site.	ETL

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(July 1, 2005 through July 31, 2005)

Date	Time	System Changes/Modifications	Personnel
7/14/2005	9:26 AM	Booster Blower Failure Alarm	
	9:29 AM	Reset the motor starter on the booster blower and restarted the system.	MG
		A pressure signal from the RW-4 well was not being received. After troubleshooting, it was determined that the well head pressure sensor for RW-4 needs to be replaced.	MG
7/19/2005		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS
7/27/2005	10:00 AM	Communication Failure Alarm, the system shut down.	
7/29/2005	11:15 AM	Rebooted the computer, reset the alarm and restarted the system.	SS
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS
		Greased booster blower.	SS

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

EFFLUENT WATER QUALITY RESULTS

Date Sampled	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo-chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	6.5 to 8.5	---	1	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
7-Jul-05	5.2	380 ^{4/}	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	5.56	3.53
14-Jul-05	5.3	91	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	5.8 ^{3/}	ND<1.0	ND<1.0	ND<1.0	ND<1.0	7.45	0.121
19-Jul-05	5.3	120	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	7.2 ^{3/}	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.10	0.110
29-Jul-05	5.3	120	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	12.3	0.172

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

----: Not established

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. pH was measured using litmus paper. Influent pH values from recovery wells, which reflect the pH of natural ground water, are below 6.5 on a regular basis.
2. "Effluent" samples were collected from sample port labeled NP2-10.
3. Methylene chloride detected in these samples is suspected to be from laboratory contamination.
4. The TDS concentration was elevated during the July 7, 2005 sampling event because purged water from well rehabilitation activities was being processed through the system while the FSP&T system was in operation.

**GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																			TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs
AQ080404:1330NP4-1	8/4/2004	13:30	1.3	0.089	0.22	0.012	0.016	0.007	0.031	0.004	0.003	0.001	0.004	0.013	0.044	0.005	0.076	0.067	ND	0.001	ND	ND	1.89
AQ090204:1431NP4-1	9/2/2004	14:31	0.83	0.054	0.13	0.009	0.013	0.004	0.028	0.008	0.004	0.001	0.003	0.01	0.073	0.003	0.078	0.04	ND	0.001	ND	ND	1.29
AQ100704:1210NP4-1	10/7/2004	12:10	0.4	0.035	0.058	0.005	0.005	0.003	0.038	0.008	0.003	0.001	0.002	0.008	0.05	ND	0.045	0.152	ND	0.001	ND	ND	0.72
AQ110304:945NP4-1	11/3/2004	9:45	0.44	0.032	0.074	0.01	0.022	0.004	0.02	0.008	0.0018	ND	0.0012	0.008	0.1	0.006	0.02	0.152	ND	ND	ND	ND	0.90
AQ120204:1100NP4-1 ^{1/}	12/2/2004	11:00	0.4	0.026	0.08	0.01	0.022	0.004	0.052	0.03	0.006	0.0014	0.002	ND	1.04	0.012	0.05	0.24	ND	0.0018	ND	ND	1.04
AQ010405:1145NP4-1	1/4/2005	11:45	0.06	0.025	0.0775	ND	ND	ND	0.015	0.005	ND	ND	ND	0.005	0.025	ND	ND	0.04	ND	ND	ND	ND	0.25
AQ020205:1345NP4-1	2/2/2005	13:45	0.45	0.0325	0.0675	ND	ND	ND	0.02	0.0075	ND	ND	ND	0.0075	0.0325	ND	ND	0.185	ND	ND	ND	ND	0.80
AQ030205:1105NP4-1	3/2/2005	11:05	0.35	0.0325	0.0725	ND	ND	ND	0.0175	0.005	ND	ND	ND	0.005	0.015	ND	ND	0.0825	ND	ND	ND	ND	0.58
AQ040705:1430NP4-1	4/7/2005	14:30	0.34	0.027	0.058	0.006	0.02	ND	0.029	0.012	0.003	ND	0.002	0.006	0.053	ND	0.015	ND	ND	ND	ND	ND	0.57
AQ050205:1405NP4-1	5/2/2005	14:05	0.52	0.032	0.116	ND	ND	ND	0.024	0.008	ND	ND	ND	0.024	ND	ND	0.04	ND	ND	ND	ND	ND	0.76
AQ062405:12:40NP4-1	6/24/2005	12:40	0.36	0.028	0.1	ND	ND	ND	0.074	0.046	0.004	ND	ND	ND	0.144	ND	0.054	0.16	ND	ND	ND	ND	0.97
AQ070705:1400NP4-1	7/7/2005	14:00	0.43	0.026	0.12	ND	ND	ND	0.044	ND	0.006	0.002	0.006	ND	0.19 ^{1/}	ND	0.51 ^{1/}	0.024	ND	0.001	ND	ND	0.86

Midcarbon			Parameters (mg/m3)																			TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs
AQ080404:1335NP4-2	8/4/2004	13:35	0.048	0.002	ND	0.005	ND	ND	0.031	0.002	0.003	0.001	0.003	ND	0.063	0.004	0.078	0.071	ND	0.001	ND	ND	0.31
AQ090204:1432NP4-2	9/2/2004	14:32	0.014	0.002	ND	0.005	ND	ND	0.059	0.005	0.005	0.001	0.003	ND	0.088	0.003	0.086	0.025	ND	0.002	ND	ND	0.30
AQ100704:1212NP4-2	10/7/2004	12:12	0.021	0.001	ND	0.006	0.01	ND	0.016	0.007	0.003	0.001	0.002	0.002	0.011	ND	0.036	0.057	ND	0.001	ND	ND	0.17
AQ110304:947NP4-2	11/3/2004	9:47	0.015	ND	ND	0.007	0.014	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.034	0.005	0.018	0.026	ND	0.0004	ND	ND	0.15
AQ120204:1102NP4-2 ^{1/}	12/2/2004	11:02	0.004	ND	ND	0.009	0.017	0.002	0.034	0.003	0.003	0.0005	0.003	0.011	0.097	0.004	0.025	0.08	ND	0.001	ND	ND	0.23
AQ010405:1150NP4-2	1/4/2005	11:50	0.004	ND	0.045	0.011	0.028	0.003	0.024	0.002	0.001	ND	0.002	0.018	0.009	ND	0.015	0.028	ND	ND	ND	ND	0.19
AQ020205:1350NP4-2	2/2/2005	13:50	ND	ND	0.15	0.011	0.033	0.005	0.019	0.001	ND	ND	ND	0.018	0.019	ND	0.013	0.004	ND	ND	ND	ND	0.27
AQ030205:1110NP4-2	3/2/2005	11:10	ND	ND	0.14	0.009	0.022	0.004	0.016	0.002	0.002	ND	ND	0.011	0.01	ND	0.008	0.021	ND	ND	ND	ND	0.25
AQ040705:1432NP4-2	4/7/2005	14:32	0.004	ND	0.069	0.005	0.014	0.003	0.012	0.002	ND	ND	ND	0.006	0.05	ND	0.026	ND	ND	ND	ND	ND	0.19
AQ050205:1410NP4-2	5/2/2005	14:10	ND	ND	0.085	0.005	ND	0.003	0.016	0.001	ND	ND	ND	0.003	0.006	ND	0.005	0.01	ND	ND	ND	ND	0.13
AQ062405:1241NP4-2	6/24/2005	12:41	ND	ND	0.063	ND	ND	ND	0.071	0.023	0.005	ND	0.006	0.007	0.096	ND	0.047	ND	ND	ND	ND	ND	0.32
AQ070705:1415NP4-2	7/7/2005	14:15	ND	ND	0.036	ND	ND	ND	0.036	0.006	0.002	ND	ND	ND	0.65 ^{1/}	ND	0.49 ^{1/}	0.11	ND	ND	ND	ND	0.33

Postcarbon			Parameters (mg/m3)																			TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs
AQ080404:1340NP4-3	8/4/2004	13:40	0.02	0.002	ND	ND	ND	ND	0.03	0.004	0.003	0.001	0.004	ND	0.055	0.004	0.067	0.055	ND	0.001	ND	ND	0.25
AQ090204:1433NP4-3	9/2/2004	14:33	0.023	0.003	ND	ND	ND	ND	0.062	0.008	0.005	0.001	0.003	ND	0.087	0.004	0.085	0.033	ND	0.002	ND	ND	0.32
AQ100704:1215NP4-3	10/7/2004	12:15	0.001	0.001	ND	ND	ND	ND	0.045	0.004	0.003	0.0009	0.003	ND	0.011	ND	0.033	0.034	ND	0.001	ND	ND	0.14
AQ110304:950NP4-3	11/3/2004	9:50	0.005	ND	ND	0.002	ND	ND	0.022	0.005	0.002	0.0004	0.002	ND	0.032	ND	0.017	0.022	ND	0.0005	ND	ND	0.11
AQ120204:1105NP4-3 ^{1/}	12/2/2004	11:05	ND	0.002	ND	0.006	ND	ND	0.035	0.011	0.003	0.0006	0.003	ND	0.27	0.005	0.025	0.064	ND	0.001	ND	ND	0.19
AQ010405:1155NP4-3	1/4/2005	11:55	0.002	ND	ND	0.007	0.013	0.002	0.023	0.002	0.002	ND	0.002	ND	0.006	ND	0.015	0.008	ND	ND	ND	ND	0.08
AQ020205:1355NP4-3	2/2/2005	13:55	0.004	ND	ND	ND	ND	ND	0.021	0.002	ND	ND	0.001	ND	0.023	ND	0.013	ND	ND	ND	ND	ND	0.06
AQ030205:1115NP4-3	3/2/2005	11:15	ND	ND	0.023	0.009	0.031	ND	0.016	0.002	0.002	ND	0.001	0.012	0.008	ND	0.009	0.007	ND	ND	ND	ND	0.12
AQ040705:1434NP4-3	4/7/2005	14:34	0.001	ND	0.02	0.006	0.016	ND	0.013	0.002	ND	ND	ND	0.007	0.015	ND	ND	0.015	ND	ND	ND	ND	0.10
AQ050205:1415NP4-3	5/2/2005	14:15	ND	ND	0.03	0.007	0.016	ND	0.019	0.01	0.0009	ND	ND	0.009	0.007	ND	0.012	0.002	ND	ND	ND	ND	0.11
AQ062405:1242NP4-3	6/24/2005	12:42	ND	ND	0.012	ND	ND	ND	0.035	0.002	0.002	ND	0.004	0.004	0.063	ND	0.022	0.054	ND	ND	ND	ND	0.20
AQ070705:1420NP4-3	7/7/2005	14:20	ND	ND	0.014	ND	ND	ND	0.038	0.004	0.003	ND	0.005	ND	0.23 ^{1/}	ND	0.45 ^{1/}	0.046	ND	ND	ND	ND	0.20

Notes: 1. Methylene chloride and carbon disulfide concentrations in all three air samples collected during the July 7, 2005 sampling event are greatly elevated due to suspected laboratory contamination. The methylene chloride and carbon disulfide concentrations from the June 24, 2005 sampling event were used instead of the July 7, 2005 methylene chloride and carbon disulfide concentrations to calculate the total VOCs for July 2005.

PCE - Tetrachloroethane
 TCE - Trichloroethene
 TCA - 1,1,1-Trichloroethane

DCE - 1,1-Dichloroethene
 DCA - 1,1-Dichloroethane
 cis-DCE - cis-1,2-Dichloroethene
 CT - Carbon Tetrachloride

CF - Chloroform
 MC - Methylene Chloride
 CM - Chloromethane
 CD - Carbon Disulfide

BM - Bromomethane
 CB - Chlorobenzene
 EB - Ethylbenzene
 VC - Vinyl Chloride

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	1,1-Dichloroethane	cis-1,2-Dichloroethane	1,1-Dichloroethane	Methylene Chloride	Bromoform	Dibromochloromethane	Acetone	
		(ug/L) 5	(ug/L) 5	(ug/L) 5	(ug/L) NE	(ug/L) 7	(ug/L) NE	(mg/L) 300	(mg/L) 300	(ug/L) 5	(ug/L) 5	(ug/L) 5	(ug/L) 5	(ug/L) NE	(ug/L) NE	(ug/L) NE	
RW-1	23-Jul-03	ND<1	ND<1	ND<1	ND<1	2.9	6.6	0.0100	0.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	ND<1	ND<1	ND<1	ND<1	2.6	9.4	0.0930	0.011	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	ND<1	ND<1	ND<1	ND<1	3.2	14	0.0540	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0613	0.0074	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	ND<1	ND<1	ND<1	ND<1	2.2	9.4	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	ND<1	ND<1	ND<1	ND<1	4.0	2.2	0.0098	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	ND<1	ND<1	ND<1	ND<1	4.6	5.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	ND<1	ND<1	ND<1	ND<1	ND<1	4.1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	ND<1	ND<1	ND<1	ND<1	2.9	6.1	0.0240	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	
	5-May-04	ND<1	ND<1	ND<1	ND<1	5.6	6.8	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	6.1*	ND<1	ND<1	ND<1	
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	2.0	3.4	0.0454	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	ND<1	ND<1	ND<1	ND<1	ND<1	3.1	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	ND<1	
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	8.4*	ND<1	ND<1	6.9*		
RW-2	23-Jul-03	12	ND<1	ND<1	ND<1	ND<1	ND<1	5.34	0.438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	7.9	ND<1	ND<1	ND<1	ND<1	ND<1	5.99	0.758	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	9.2	0.5	ND<1	ND<1	ND<1	6.0	4.49	0.899	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	8.1	0.7	ND<1	ND<1	ND<1	ND<1	6.79	0.101	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	5.5	ND<1	ND<1	ND<1	ND<1	5.5	5.46	0.0213	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	8.7	ND<1	ND<1	ND<1	ND<1	1.1	5.57	0.207	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	5.4	ND<1	ND<1	ND<1	ND<1	3.9	3.77	0.0748	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	4.9	ND<1	ND<1	ND<1	ND<1	3.3	0.343	0.318	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	4.4	ND<1	ND<1	ND<1	ND<1	2.8	5.59	0.224	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1	
	5-May-04	8.2	ND<1	ND<1	ND<1	ND<1	4.7	4.5	0.691	ND<1	ND<1	ND<1	5.6*	ND<1	ND<1	ND<1	
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	52.5	1.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	6.5	ND<1	ND<1	ND<1	ND<1	1.3	4.88	0.704	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	4.78	0.213	ND<1	ND<1	ND<1	ND<1	2.1	1.5	ND<1	
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
2-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
16-Jun-05	12.0	ND<1	1.0	ND<1	ND<1	ND<1	3.5	0.0511	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	ND<1		
14-Jul-05	7.7	1.1	ND<1	ND<1	ND<1	ND<1	0.28	0.0298	ND<1	ND<1	ND<1	7.3*	ND<1	ND<1	5.6*		

TABLE 4

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	1,1-Dichloroethane	cis-1,2-Dichloroethene	1,1-Dichloroethene	Methylene Chloride	Bromoform	Dibromochloromethane	Acetone	
		(ug/L) 5	(ug/L) 5	(ug/L) 5	(ug/L) NE	(ug/L) 7	(ug/L) NE	(mg/L) 300	(mg/L) 300	(ug/L) 5	(ug/L) 5	(ug/L) 5	(ug/L) 5	(ug/L) NE	(ug/L) NE	(ug/L) NE	
RW-5	23-Jul-03	11	ND<1	ND<1	ND<1	1.1	9.7	6.47	0.068	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	15	ND<1	ND<1	ND<1	0.9	7.3	0.269	0.021	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	18	ND<1	ND<1	ND<1	ND<1	8.1	0.043	0.016	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	18	ND<1	ND<1	ND<1	ND<1	ND<1	13.1	0.0097	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	11	ND<1	ND<1	ND<1	ND<1	7.5	0.0523	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	14	ND<1	ND<1	ND<1	ND<1	0.9	4.0	0.05	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	14	ND<1	ND<1	ND<1	ND<1	1.0	6.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	14	ND<1	ND<1	ND<1	ND<1	5.0	0.0852	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	18	ND<1	1.5	ND<1	ND<1	6.1	0.147	0.015	ND<1	ND<1	ND<1	2*	ND<1	ND<1	ND<1	ND<1
	5-May-04	38	0.8	3.2	ND<1	ND<1	1.5	8.0	0.055	0.015	ND<1	ND<1	ND<1	6.4*	ND<1	ND<1	ND<1
	14-Jun-04	17	ND<1	4.6	ND<1	ND<1	3.9	0.054	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	21	ND<1	4.6	ND<1	ND<1	3.1	0.0254	0.0265	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	24	ND<1	6.5	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.3	ND<1	ND<1	ND<1
	7-Oct-04	16	ND<1	5.2	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	1.8	1.4	ND<1	ND<1
	3-Nov-04	15	ND<1	6.4	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	28	ND<1	28	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
19-Apr-05	9	ND<1	4.1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
2-May-05	13	ND<1	5.7	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
16-Jun-05	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
14-Jul-05	8.2	ND<1	1.6	ND<1	ND<1	ND<1	0.0358	ND<0.02	ND<1	ND<1	ND<1	9.5*	ND<1	ND<1	ND<1	5.6*	
RW-6	23-Jul-03	150	0.6	ND<1	ND<1	ND<1	ND<1	0.186	0.034	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Sep-03	140	2.2	ND<1	ND<1	ND<1	ND<1	0.089	0.018	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Oct-03	140	2.6	ND<1	ND<1	ND<1	ND<1	0.023	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Nov-03	180	3.3	1.0	ND<1	ND<1	ND<1	0.342	0.0083	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Dec-03	120	2.6	ND<1	ND<1	ND<1	ND<1	0.017	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	160	2.4	ND<1	ND<1	ND<1	ND<1	0.015	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	130	3.3	1.1	ND<1	ND<1	1.7	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	110	2.7	ND<1	ND<1	ND<1	1.6	0.077	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	110	2.9	1.3	ND<1	ND<1	2.6	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	1.8*	ND<1	ND<1	ND<1
	5-May-04	210	4.8	ND<1	ND<1	ND<1	3.2	0.719	ND<0.02	ND<1	ND<1	ND<1	5.9*	ND<1	ND<1	ND<1	ND<1
	14-Jun-04	92	3.6	1.3	ND<1	ND<1	2.1	0.151	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	100	2.8	1.2	ND<1	ND<1	1.7	0.437	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1	ND<1
	7-Oct-04	94	ND<1	1.6	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.9	2.0	ND<1	ND<1
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	2.5	0.0111	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	200	3.8	16	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
16-Jun-05	69	1.6	13.0	ND<1	ND<1	ND<1	0.067	0.0195	ND<1	ND<1	ND<1	2.1	ND<1	ND<1	ND<1	ND<1	
14-Jul-05	64	1.6	9.5	ND<1	ND<1	ND<1	0.0406	ND<0.02	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<1	7*	

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	1,1-Dichloroethane	cis-1,2-Dichloroethene	1,1-Dichloroethene	Methylene Chloride	Bromoform	Dibromochloromethane	Acetone	
		(ug/L) 5	(ug/L) 5	(ug/L) 5	(ug/L) NE	(ug/L) 7	(ug/L) NE	(mg/L) 300	(mg/L) 300	(ug/L) 5	(ug/L) 5	(ug/L) 5	(ug/L) 5	(ug/L) NE	(ug/L) NE	(ug/L) NE	
RW-7	23-Jul-03	150	2.1	ND<1	ND<1	ND<1	ND<1	0.024	0.041	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	120	2.3	ND<1	ND<1	ND<1	ND<1	0.011	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	130	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	140	3.4	1.1	ND<1	ND<1	ND<1	0.0464	ND<0.02	ND<1	0.2	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	110	2.8	ND<1	ND<1	ND<1	ND<1	0.0239	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	190	3.7	ND<1	ND<1	ND<1	ND<1	0.0069	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	120	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	100	3.0	ND<1	ND<1	ND<1	ND<1	0.0205	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	79	2.5	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	2.2*	ND<1	ND<1	ND<1	
	5-May-04	130	4.0	ND<1	ND<1	ND<1	ND<1	0.012	ND<0.02	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<1	
	14-Jun-04	59	2.7	ND<1	ND<1	ND<1	ND<1	0.018	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04	55	2.1	ND<1	ND<1	ND<1	ND<1	0.791	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.6	ND<1	ND<1	
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	0.0272	0.00876	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	32	1.0	4.7	ND<1	ND<1	ND<1	0.0753	0.02	1.5	ND<1	1.1	ND<1	ND<1	ND<1	ND<1	
14-Jul-05	32	ND<1	2.2	ND<1	ND<1	ND<1	0.0155	ND<0.02	ND<1	ND<1	ND<1	8.7 *	ND<1	ND<1	7.2 *		
RW-8	23-Jul-03	35	1.9	3.2	ND<1	ND<1	ND<1	10.5	0.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	30	1.7	3.6	ND<1	ND<1	ND<1	11.1	1.18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	28	2.5	4.4	ND<1	ND<1	ND<1	9.93	0.40	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	27	2.3	5.4	ND<1	ND<1	ND<1	13.3	0.21	4.1	0.7	1.3	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	17	2.1	2.6	ND<1	ND<1	ND<1	9.16	0.05	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	16	2.2	4.1	ND<1	ND<1	ND<1	9.73	2.72	3.5	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	15	2.2	4.7	ND<1	ND<1	ND<1	8.74	0.19	4.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Mar-04	22	2.7	4.3	ND<1	ND<1	ND<1	11.9	0.23	3.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Apr-04	14	2.0	6.2	ND<1	ND<1	ND<1	10.7	0.14	5.7	ND<1	ND<1	1.9*	ND<1	ND<1	ND<1	
	5-May-04	27	4.1	8.3	ND<1	ND<1	ND<1	8.77	0.21	8.7	ND<1	ND<1	8.5*	ND<1	ND<1	ND<1	
	14-Jun-04	10	2.4	5.8	ND<1	ND<1	ND<1	9.15	0.10	4.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-04 **	3	1.0	3.7	ND<1	ND<1	ND<1	4.18	0.21	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	28.8	0.2	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	10.6	0.3	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Dec-04	16	ND<1	22	ND<1	ND<1	ND<1	15.6	0.1	15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	7.33	0.07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	2.7	ND<1	5.8	ND<1	ND<1	ND<1	7.06	0.33	2.1	ND<1	ND<1	1.7	ND<1	ND<1	ND<1	
14-Jul-05	2.6	ND<1	3.4	ND<1	ND<1	ND<1	8.33	0.02	ND<1	ND<1	ND<1	8.5 *	ND<1	ND<1	8.2 *		

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	1,1-Dichloroethane	cis-1,2-Dichloroethene	1,1-Dichloroethene	Methylene Chloride	Bromoform	Dibromochloromethane	Acetone	
		(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(mg/L)	(mg/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)
ARAR's	5	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	
RW-9	23-Jul-03	4.7	1.6	7.3	ND<1	ND<1	ND<1	3.60	0.467	3.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Sep-03	25	1.2	3.5	ND<1	ND<1	ND<1	4.05	2.69	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	30-Oct-03	22	2.1	5.8	ND<1	ND<1	ND<1	3.49	2.88	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	25-Nov-03	27	2.2	8.2	ND<1	ND<1	ND<1	5.39	1.72	5.2	ND<1	1.4	ND<1	ND<1	ND<1	ND<1	
	23-Dec-03	11	1.7	5.4	ND<1	ND<1	ND<1	1.94	1.57	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	23-Jan-04	2.3	2.2	13	ND<1	ND<1	ND<1	0.638	0.029	1.8	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	
	11-Feb-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	2.2	12	ND<1	ND<1	ND<1	1.24	0.222	3.7	ND<1	1.3	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	5.6	1.7	10	ND<1	ND<1	ND<1	2.65	1.22	5.9	ND<1	2.0	2.0*	ND<1	ND<1	ND<1	ND<1
	5-May-04	3.7	1.7	13	ND<1	ND<1	ND<1	2.58	1.83	6.7	ND<1	1.7	7.1*	ND<1	ND<1	ND<1	ND<1
	14-Jun-04	1.8	1.9	8.2	ND<1	ND<1	ND<1	3.03	1.11	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	3.4	1.3	5.1	ND<1	ND<1	ND<1	2.6	1.95	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	1.9	ND<1	ND<1	ND<1	ND<1	1.6	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0596	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	5.8	ND<1	ND<1	ND<1	1.38	0.149	0.9	ND<1	ND<1	1.2	ND<1	ND<1	ND<1	ND<1
14-Jul-05	3.4	ND<1	3.1	ND<1	ND<1	ND<1	2.55	0.238	ND<1	ND<1	ND<1	6.9 *	ND<1	ND<1	ND<1	7.3 *	

ND: Not detected

<#: Less than method detection limit

ug/L: Micrograms per liter

-: Not analyzed

PCE: Tetrachloroethylene

TCE: Trichloroethene

TCA: 1,1,1-Trichloroethane

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl Tertiary Butyl Ether

NM: Not Measured

ARAR goal was not established for this compound by the EPA.


*Concentrations with an asterisk following them are due to laboratory contamination.

ARAR's are chemical specific aquifer restoration goals for ground-water at the Former Rowe Industries Superfund Site.
 Bold values indicate an exceedance of the ARAR standard established for the site.

GRAPHS


GRAPH 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
 (July 1, 2005 through July 31, 2005)



GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER



APPENDIX I
JULY 2005 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, July 21, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0507079

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 7/12/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0507079

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0507079-01A	WQ070705:1400 NP2-6	3217	7/7/2005	7/12/2005
0507079-01B	WQ070705:1400 NP2-6	3217	7/7/2005	7/12/2005
0507079-01C	WQ070705:1400 NP2-6	3217	7/7/2005	7/12/2005
0507079-02A	WQ070705:1410 NP2-7	3217	7/7/2005	7/12/2005
0507079-02B	WQ070705:1410 NP2-7	3217	7/7/2005	7/12/2005
0507079-02C	WQ070705:1410 NP2-7	3217	7/7/2005	7/12/2005
0507079-03A	WQ070705:1405 NP2-10	3217	7/7/2005	7/12/2005
0507079-03B	WQ070705:1405 NP2-10	3217	7/7/2005	7/12/2005
0507079-03C	WQ070705:1405 NP2-10	3217	7/7/2005	7/12/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
 (631) 454-6100 • FAX (631) 454-8027

TAG # / COC 3217

NYSDOH 11418
 CTDOH PH-0205
 NJDEP NY050
 PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <i>LBG</i> <i>126 Monroe Turnpike</i> <i>Trumbull, CT 06611</i>	CONTACT: <i>Mark Goldberg</i>	SAMPLER (SIGNATURE): <i>Steve Silvestri (MMG)</i>	SAMPLE(S) SEALED <div style="text-align: right;"><u>YES</u> / NO</div>
		SAMPLER NAME (PRINT): <i>Steve Silvestri</i>	CORRECT CONTAINER(S) <div style="text-align: right;"><u>YES</u> / NO</div>

PROJECT LOCATION: <i>Ronde</i>					ANALYSIS REQUIRED										FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]			
LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	S260	MTRF	Feen 113	Total 113	TSS									
<i>0507079-1ABC</i>	<i>L</i>	<i>4</i>	<i>7/7/05</i>	<i>WQ070705:1400 NP2-6</i>	<i>✓</i>	<i>✓</i>	<i>✓</i>	<i>✓</i>	<i>✓</i>									
<i>2ABC</i>	<i>↓</i>	<i>4</i>	<i>↓</i>	<i>WQ070705:1410 NP2-7</i>	<i>✓</i>	<i>✓</i>	<i>✓</i>	<i>✓</i>	<i>✓</i>									
<i>3ABC</i>	<i>↓</i>	<i>5</i>	<i>↓</i>	<i>WQ070705:1405 NP2-10</i>	<i>✓</i>	<i>✓</i>	<i>✓</i>	<i>✓</i>	<i>✓</i>									

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON			TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY <i>PH</i>			COOLER TEMPERATURE: COMMENTS / INSTRUCTIONS		
RELINQUISHED BY (SIGNATURE) <i>Mark M. Goldberg</i>	DATE/TIME <i>7/12/05</i> <i>17:00</i>	PRINTED NAME <i>Mark M. Goldberg</i>	RECEIVED BY LAB (SIGNATURE) <i>PH</i>	DATE/TIME <i>7/12/05</i> <i>0945</i>	PRINTED NAME <i>P. Arterio</i>			
RELINQUISHED BY (SIGNATURE)	DATE/TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE/TIME	PRINTED NAME			

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ070705:1400 NP2-6
 Lab Order: 0507079 Tag Number: 3217
 Project: Rowe Industries Collection Date: 7/7/2005
 Lab ID: 0507079-01A Date Received: 7/12/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,1,1-Trichloroethane	5.7	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
2-Butanone	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
2-Hexanone	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Acetone	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Benzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Bromobenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Bromoform	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Bromomethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Chloroethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ070705:1400 NP2-6
 Lab Order: 0507079 Tag Number: 3217
 Project: Rowe Industries Collection Date: 7/7/2005
 Lab ID: 0507079-01A Date Received: 7/12/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Chloromethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Dibromomethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/14/2005 3:27:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Methylene chloride	U	1.0	B	µg/L	1	7/14/2005 3:27:00 AM
Naphthalene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
o-Xylene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Styrene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Tetrachloroethene	27	1.0		µg/L	1	7/14/2005 3:27:00 AM
Toluene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Trichloroethene	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/14/2005 3:27:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/14/2005 3:27:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ070705:1400 NP2-6
Lab Order:	0507079	Tag Number:	3217
Project:	Rowe Industries	Collection Date:	7/7/2005
Lab ID:	0507079-01B	Date Received:	7/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	6.38	0.0200		mg/L	1	7/12/2005 12:39:53 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ070705:1400 NP2-6
Lab Order:	0507079	Tag Number:	3217
Project:	Rowe Industries	Collection Date:	7/7/2005
Lab ID:	0507079-01C	Date Received:	7/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	4.48	0.0200		mg/L	1	7/12/2005 12:37:40 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 4 of 12

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ070705:1410 NP2-7
 Lab Order: 0507079 Tag Number: 3217
 Project: Rowe Industries Collection Date: 7/7/2005
 Lab ID: 0507079-02A Date Received: 7/12/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
2-Butanone	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
2-Hexanone	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Acetone	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Benzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Bromobenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Bromoform	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Bromomethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Chloroethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ070705:1410 NP2-7
Lab Order:	0507079	Tag Number:	3217
Project:	Rowe Industries	Collection Date:	7/7/2005
Lab ID:	0507079-02A	Date Received:	7/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Chloromethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Dibromomethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/14/2005 4:02:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Methylene chloride	U	1.0	B	µg/L	1	7/14/2005 4:02:00 AM
Naphthalene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
o-Xylene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Styrene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Tetrachloroethene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Toluene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Trichloroethene	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/14/2005 4:02:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/14/2005 4:02:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ070705:1410 NP2-7
Lab Order:	0507079	Tag Number:	3217
Project:	Rowe Industries	Collection Date:	7/7/2005
Lab ID:	0507079-02B	Date Received:	7/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	3.79	0.0200		mg/L	1	7/12/2005 12:47:55 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ070705:1410 NP2-7
Lab Order:	0507079	Tag Number:	3217
Project:	Rowe Industries	Collection Date:	7/7/2005
Lab ID:	0507079-02C	Date Received:	7/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	3.62	0.0200		mg/L	1	7/12/2005 12:45:02 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: WQ070705:1405 NP2-10
Lab Order: 0507079	Tag Number: 3217
Project: Rowe Industries	Collection Date: 7/7/2005
Lab ID: 0507079-03A	Date Received: 7/12/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						
		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
2-Butanone	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
2-Hexanone	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Acetone	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Benzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Bromobenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Bromoform	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Bromomethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Chloroethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: WQ070705:1405 NP2-10
Lab Order: 0507079	Tag Number: 3217
Project: Rowe Industries	Collection Date: 7/7/2005
Lab ID: 0507079-03A	Date Received: 7/12/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Chloromethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Dibromomethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/14/2005 4:35:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Methylene chloride	U	1.0	B	µg/L	1	7/14/2005 4:35:00 AM
Naphthalene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
o-Xylene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Styrene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Tetrachloroethene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Toluene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Trichloroethene	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/14/2005 4:35:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/14/2005 4:35:00 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 10 of 12

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ070705:1405 NP2-10
Lab Order:	0507079	Tag Number:	3217
Project:	Rowe Industries	Collection Date:	7/7/2005
Lab ID:	0507079-03B	Date Received:	7/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	5.56	0.0200		mg/L	1	7/12/2005 12:53:12 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ070705:1405 NP2-10
Lab Order:	0507079	Tag Number:	3217
Project:	Rowe Industries	Collection Date:	7/7/2005
Lab ID:	0507079-03C	Date Received:	7/12/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	3.53	0.0200		mg/L	1	7/12/2005 12:50:52 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: WN
Total Dissolved Solids (Residue, Filterable)	380	1.0		mg/L	1	7/13/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Friday, July 29, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0507149

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 7/19/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.


Date: 29-Jul-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0507149



Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0507149-01A	WQ071405:945 NP2-6	4624	7/14/2005	7/19/2005
0507149-01B	WQ071405:945 NP2-6	4624	7/14/2005	7/19/2005
0507149-01C	WQ071405:945 NP2-6	4624	7/14/2005	7/19/2005
0507149-02A	WQ071405:950 NP2-7	4624	7/14/2005	7/19/2005
0507149-02B	WQ071405:950 NP2-7	4624	7/14/2005	7/19/2005
0507149-02C	WQ071405:950 NP2-7	4624	7/14/2005	7/19/2005
0507149-03A	WQ071405:955 NP2-10	4624	7/14/2005	7/19/2005
0507149-03B	WQ071405:955 NP2-10	4624	7/14/2005	7/19/2005
0507149-03C	WQ071405:955 NP2-10	4624	7/14/2005	7/19/2005

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBG 126 Monroe Turnpike Trumbull, CT 06611	CONTACT: Mark Goldberg	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED YES / NO YES
		SAMPLER NAME (PRINT) Mark M. Goldberg	CORRECT CONTAINER(S) YES / NO YES

PROJECT LOCATION: Rowe					ANALYSIS REQUIRED	FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]															
LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION																	
OSD 7149-1A ABC	L	4	7/14/05	WR 071405:945 NP-26	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2 ABC	↓	4	↓	↓ : 950 NP-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
3 ABC	↓	5	↓	↓ : 955 NP-10	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON			TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY _____		COOLER TEMPERATURE: _____
RELINQUISHED BY (SIGNATURE) 			DATE 7/18/05 TIME 16:00	PRINTED NAME Mark M. Goldberg	
RELINQUISHED BY (SIGNATURE) _____			DATE _____ TIME _____	PRINTED NAME _____	
RECEIVED BY LAB (SIGNATURE) 			DATE 7/19/05 TIME 10:45	PRINTED NAME P. Artonio	
RECEIVED BY LAB (SIGNATURE) _____			DATE _____ TIME _____	PRINTED NAME _____	

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ071405:945 NP2-6
 Lab Order: 0507149 Tag Number: 4624
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507149-01A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,1,1-Trichloroethane	3.1	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
2-Butanone	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
2-Hexanone	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Acetone	U	1.0	B	µg/L	1	7/22/2005 2:26:00 AM
Benzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Bromobenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Bromoform	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Bromomethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Chloroethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ071405:945 NP2-6
Lab Order: 0507149 **Tag Number:** 4624
Project: Rowe Industries **Collection Date:** 7/14/2005
Lab ID: 0507149-01A **Date Received:** 7/19/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Chloromethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Dibromomethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/22/2005 2:26:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Methylene chloride	5.4	1.0	B	µg/L	1	7/22/2005 2:26:00 AM
Naphthalene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
o-Xylene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Styrene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Tetrachloroethene	12	1.0		µg/L	1	7/22/2005 2:26:00 AM
Toluene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Trichloroethene	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/22/2005 2:26:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/22/2005 2:26:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT:	Leggette Brashcars & Graham Inc.	Client Sample ID:	WQ071405:945 NP2-6
Lab Order:	0507149	Tag Number:	4624
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507149-01B	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	2.43	0.0200		mg/L	1	7/28/2005 11:07:35 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ071405:945 NP2-6
Lab Order: 0507149 **Tag Number:** 4624
Project: Rowe Industries **Collection Date:** 7/14/2005
Lab ID: 0507149-01C **Date Received:** 7/19/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0347	0.0200		mg/L	1	7/28/2005 11:05:09 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ071405:950 NP2-7
Lab Order: 0507149 **Tag Number:** 4624
Project: Rowe Industries **Collection Date:** 7/14/2005
Lab ID: 0507149-02A **Date Received:** 7/19/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
2-Butanone	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
2-Hexanone	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Acetone	U	1.0	B	µg/L	1	7/22/2005 4:24:00 AM
Benzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Bromobenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Bromoform	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Bromomethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Chloroethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ071405:950 NP2-7
Lab Order: 0507149 **Tag Number:** 4624
Project: Rowe Industries **Collection Date:** 7/14/2005
Lab ID: 0507149-02A **Date Received:** 7/19/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Chloromethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Dibromomethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/22/2005 4:24:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Methylene chloride	5.5	1.0	B	µg/L	1	7/22/2005 4:24:00 AM
Naphthalene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
o-Xylene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Styrene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Tetrachloroethene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Toluene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Trichloroethene	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/22/2005 4:24:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/22/2005 4:24:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ071405:950 NP2-7
Lab Order: 0507149 Tag Number: 4624
Project: Rowe Industries Collection Date: 7/14/2005
Lab ID: 0507149-02B Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	7.72	0.0200		mg/L	1	7/28/2005 11:14:29 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
E Value above quantitation range H Holding times for preparation or analysis exceeded
J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ071405:950 NP2-7
 Lab Order: 0507149 Tag Number: 4624
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507149-02C Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0937	0.0200		mg/L	1	7/28/2005 11:11:26 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071405:955 NP2-10
Lab Order:	0507149	Tag Number:	4624
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507149-03A	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						
		SW8260B				Analyst: JMO
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
2-Butanone	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
2-Hexanone	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Acetone	U	1.0	B	µg/L	1	7/22/2005 5:03:00 AM
Benzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Bromobenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Bromoform	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Bromomethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Chloroethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ071405:955 NP2-10
Lab Order: 0507149 **Tag Number:** 4624
Project: Rowe Industries **Collection Date:** 7/14/2005
Lab ID: 0507149-03A **Date Received:** 7/19/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Chloromethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Dibromomethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/22/2005 5:03:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Methylene chloride	5.8	1.0	B	µg/L	1	7/22/2005 5:03:00 AM
Naphthalene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
o-Xylene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Styrene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Tetrachloroethene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Toluene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Trichloroethene	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/22/2005 5:03:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/22/2005 5:03:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071405:955 NP2-10
Lab Order:	0507149	Tag Number:	4624
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507149-03B	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	7.45	0.0200		mg/L	1	7/28/2005 11:19:02 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Jul-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071405:955 NP2-10
Lab Order:	0507149	Tag Number:	4624
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507149-03C	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.121	0.0200		mg/L	1	7/28/2005 11:16:57 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: WN
Total Dissolved Solids (Residue, Filterable)	91	1.0		mg/L	1	7/19/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, August 10, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0507177

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 7/22/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.


Date: 10-Aug-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0507177



Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0507177-01A	WQ071905:1210 NP2-6	4490	7/19/2005	7/22/2005
0507177-01B	WQ071905:1210 NP2-6	4490	7/19/2005	7/22/2005
0507177-01C	WQ071905:1210 NP2-6	4490	7/19/2005	7/22/2005
0507177-02A	WQ071905:1215 NP2-7	4490	7/19/2005	7/22/2005
0507177-02B	WQ071905:1215 NP2-7	4490	7/19/2005	7/22/2005
0507177-02C	WQ071905:1215 NP2-7	4490	7/19/2005	7/22/2005
0507177-03A	WQ071905:1220 NP2-10	4490	7/19/2005	7/22/2005
0507177-03B	WQ071905:1220 NP2-10	4490	7/19/2005	7/22/2005
0507177-03C	WQ071905:1220 NP2-10	4490	7/19/2005	7/22/2005

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBC 124 Monroe Turnpike Trumbull, CT 06611	CONTACT: Mark Goldberg	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED YES/NO YES
		SAMPLER NAME (PRINT) Steve Silvestri / Tunde Samdov	CORRECT CONTAINER(S) YES/NO YES

PROJECT LOCATION:					ANALYSIS REQUIRED							FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]		
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	8210	MTBE	Freon 113	Total Fe	Diss Fe	TDS				
0507177-01A	L	4	7/19/05 12 ¹⁰	WQ071905:1210NP2-6	X	X	X	X	X	X				
0507177-02A	↓	↓	12 ¹⁵	WQ071905:1215NP2-7	X	X	X	X	X					
0507177-03A	↓	5	12 ¹⁰	WQ071905:1220NP2-10	X	X	X	X	X					
Just NP2-10														

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON				TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY / /		COOLER TEMPERATURE: COMMENTS / INSTRUCTIONS	
RELINQUISHED BY (SIGNATURE)	DATE	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE	PRINTED NAME		
	7/21/05 16 ⁰⁰	Steve Silvestri		07-22-05 10:30	J. GRAY		
RELINQUISHED BY (SIGNATURE)	DATE	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE	PRINTED NAME		
	TIME			TIME			

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations, between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ071905:1210 NP2-6
Lab Order: 0507177 **Tag Number:** 4490
Project: Rowe Industries **Collection Date:** 7/19/2005
Lab ID: 0507177-01A **Date Received:** 7/22/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,1,1-Trichloroethane	7.1	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
2-Butanone	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
2-Hexanone	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Acetone	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Benzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Bromobenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Bromoform	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Bromomethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Chloroethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071905:1210 NP2-6
Lab Order:	0507177	Tag Number:	4490
Project:	Rowe Industries	Collection Date:	7/19/2005
Lab ID:	0507177-01A	Date Received:	7/22/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Chloromethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Dibromomethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/23/2005 11:05:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Methylene chloride	7.9	1.0	B	µg/L	1	7/23/2005 11:05:00 AM
Naphthalene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
o-Xylene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Styrene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Tetrachloroethene	14	1.0		µg/L	1	7/23/2005 11:05:00 AM
Toluene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Trichloroethene	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/23/2005 11:05:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/23/2005 11:05:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071905:1210 NP2-6
Lab Order:	0507177	Tag Number:	4490
Project:	Rowe Industries	Collection Date:	7/19/2005
Lab ID:	0507177-01B	Date Received:	7/22/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	4.50	0.0200		mg/L	1	7/28/2005 11:24:01 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 3 of 12

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071905:1210 NP2-6
Lab Order:	0507177	Tag Number:	4490
Project:	Rowe Industries	Collection Date:	7/19/2005
Lab ID:	0507177-01C	Date Received:	7/22/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0476	0.0200		mg/L	1	7/28/2005 11:21:51 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 4 of 12

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ071905:1215 NP2-7
Lab Order: 0507177 **Tag Number:** 4490
Project: Rowe Industries **Collection Date:** 7/19/2005
Lab ID: 0507177-02A **Date Received:** 7/22/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
2-Butanone	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
2-Hexanone	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Acetone	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Benzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Bromobenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Bromoforn	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Bromomethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Chloroethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ071905:1215 NP2-7
Lab Order: 0507177 **Tag Number:** 4490
Project: Rowe Industries **Collection Date:** 7/19/2005
Lab ID: 0507177-02A **Date Received:** 7/22/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Chloromethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Dibromomethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/23/2005 12:44:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Methylene chloride	8.0	1.0	B	µg/L	1	7/23/2005 12:44:00 PM
Naphthalene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
o-Xylene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Styrene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Toluene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Trichloroethene	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/23/2005 12:44:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/23/2005 12:44:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071905:1215 NP2-7
Lab Order:	0507177	Tag Number:	4490
Project:	Rowe Industries	Collection Date:	7/19/2005
Lab ID:	0507177-02B	Date Received:	7/22/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	1.45	0.0200		mg/L	1	7/28/2005 11:37:25 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 7 of 12

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071905:1215 NP2-7
Lab Order:	0507177	Tag Number:	4490
Project:	Rowe Industries	Collection Date:	7/19/2005
Lab ID:	0507177-02C	Date Received:	7/22/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.0975	0.0200		mg/L	1	7/28/2005 11:35:15 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ071905:1220 NP2-10
 Lab Order: 0507177 Tag Number: 4490
 Project: Rowe Industries Collection Date: 7/19/2005
 Lab ID: 0507177-03A Date Received: 7/22/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						Analyst: JMO
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
2-Butanone	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
2-Hexanone	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Acetone	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Benzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Bromobenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Bromoform	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Bromomethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Chloroethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071905:1220 NP2-10
Lab Order:	0507177	Tag Number:	4490
Project:	Rowe Industries	Collection Date:	7/19/2005
Lab ID:	0507177-03A	Date Received:	7/22/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Chloromethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Dibromomethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/23/2005 1:17:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Methylene chloride	7.2	1.0	B	µg/L	1	7/23/2005 1:17:00 PM
Naphthalene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
o-Xylene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Styrene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Toluene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Trichloroethene	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/23/2005 1:17:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/23/2005 1:17:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071905:1220 NP2-10
Lab Order:	0507177	Tag Number:	4490
Project:	Rowe Industries	Collection Date:	7/19/2005
Lab ID:	0507177-03B	Date Received:	7/22/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	2.10	0.0200		mg/L	1	7/28/2005 11:43:39 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 11 of 12

American Analytical Laboratories, LLC.

Date: 10-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ071905:1220 NP2-10
Lab Order:	0507177	Tag Number:	4490
Project:	Rowe Industries	Collection Date:	7/19/2005
Lab ID:	0507177-03C	Date Received:	7/22/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7				Analyst: JP
Iron	0.110	0.0200		mg/L	1	7/28/2005 11:39:49 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: WN
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	7/26/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, August 09, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0508026

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 8/2/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0508026

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0508026-01A	WQ072905:1205 NP2-6	6152	7/29/2005	8/2/2005
0508026-01B	WQ072905:1205 NP2-6	6152	7/29/2005	8/2/2005
0508026-01C	WQ072905:1205 NP2-6	6152	7/29/2005	8/2/2005
0508026-02A	WQ072905:1210 NP2-7	6152	7/29/2005	8/2/2005
0508026-02B	WQ072905:1210 NP2-7	6152	7/29/2005	8/2/2005
0508026-02C	WQ072905:1210 NP2-7	6152	7/29/2005	8/2/2005
0508026-03A	WQ072905:1215 NP2-10	6152	7/29/2005	8/2/2005
0508026-03B	WQ072905:1215 NP2-10	6152	7/29/2005	8/2/2005
0508026-03C	WQ072905:1215 NP2-10	6152	7/29/2005	8/2/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
 (631) 454-6100 • FAX (631) 454-8027

TAG # / COC 6152

NYSDOH 11418
 CTDOH PH-0205
 NJDEP NY050
 PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LDG 126 Monroe Turnpike Trumbull, CT 06611	CONTACT:	SAMPLER (SIGNATURE) <i>Steve Silvestri (MMG)</i>	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
		SAMPLER NAME (PRINT) Steve Silvestri	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO

PROJECT LOCATION:
Rowe

LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED										FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]						
					SP60	MTBE	Form 113	Total Hydrocarbons	Fe												
0508026-1ABC	L	4	7/29/05	WB072905-1205 NP2-6	✓	✓	✓	✓													
2ABC	↓	4	↓	↓ 1210 NP2-7	✓	✓	✓	✓													
3ABC	↓	5	↓	↓ 1215 NP2-10	✓	✓	✓	✓	✓												

COOLER TEMPERATURE:

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON	TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY <i>1 1</i>	COMMENTS / INSTRUCTIONS <i>8/2/05</i>
---	---	---

RELINQUISHED BY (SIGNATURE) <i>Mark M. Goldberg</i>	DATE 8/1/05 TIME 17:00	PRINTED NAME Mark M. Goldberg	RECEIVED BY LAB (SIGNATURE) <i>[Signature]</i>	DATE 8/2/05 TIME 16:00	PRINTED NAME P. Antonio
RELINQUISHED BY (SIGNATURE)	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: WQ072905:1205 NP2-6
Lab Order: 0508026	Tag Number: 6152
Project: Rowe Industries	Collection Date: 7/29/2005
Lab ID: 0508026-01A	Date Received: 8/2/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
2-Butanone	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
2-Hexanone	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Acetone	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Benzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Bromobenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Bromochloromethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Bromodichloromethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Bromoform	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Bromomethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Carbon disulfide	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Chlorobenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Chloroethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1205 NP2-6
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-01A	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Chloromethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Dibromochloromethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Dibromomethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Ethylbenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Isopropylbenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
m,p-Xylene	U	2.0		µg/L	1	8/3/2005 9:58:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Methylene chloride	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Naphthalene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
n-Butylbenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
n-Propylbenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
o-Xylene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Styrene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Tetrachloroethene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Toluene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Trichloroethene	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Vinyl acetate	U	1.0		µg/L	1	8/3/2005 9:58:00 AM
Vinyl chloride	U	1.0		µg/L	1	8/3/2005 9:58:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1205 NP2-6
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-01B	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	6.71	0.0200		mg/L	1	8/9/2005 10:55:57 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1205 NP2-6
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-01C	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0246	0.0200		mg/L	1	8/9/2005 10:52:01 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 4 of 12

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1210 NP2-7
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-02A	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1						
		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
2-Butanone	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
2-Hexanone	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Acetone	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Benzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Bromobenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Bromochloromethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Bromodichloromethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Bromoform	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Bromomethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Carbon disulfide	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Chlorobenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Chloroethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 5 of 12

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ072905:1210 NP2-7
 Lab Order: 0508026 Tag Number: 6152
 Project: Rowe Industries Collection Date: 7/29/2005
 Lab ID: 0508026-02A Date Received: 8/2/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Chloromethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Dibromochloromethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Dibromomethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Ethylbenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Isopropylbenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
m,p-Xylene	U	2.0		µg/L	1	8/3/2005 10:30:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Methylene chloride	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Naphthalene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
n-Butylbenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
n-Propylbenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
o-Xylene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Styrene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Tetrachloroethene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Toluene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Trichloroethene	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Vinyl acetate	U	1.0		µg/L	1	8/3/2005 10:30:00 AM
Vinyl chloride	U	1.0		µg/L	1	8/3/2005 10:30:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1210 NP2-7
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-02B	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	7.87	0.0200		mg/L	1	8/9/2005 11:00:05 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1210 NP2-7
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-02C	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.109	0.0200		mg/L	1	8/9/2005 10:58:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1215 NP2-10
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-03A	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
2-Butanone	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
2-Hexanone	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Acetone	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Benzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Bromobenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Bromochloromethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Bromodichloromethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Bromoform	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Bromomethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Carbon disulfide	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Chlorobenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Chloroethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1215 NP2-10
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-03A	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Chloromethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Dibromochloromethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Dibromomethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Ethylbenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Isopropylbenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
m,p-Xylene	U	2.0		µg/L	1	8/3/2005 11:05:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Methylene chloride	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Naphthalene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
n-Butylbenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
n-Propylbenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
o-Xylene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Styrene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Tetrachloroethene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Toluene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Trichloroethene	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Vinyl acetate	U	1.0		µg/L	1	8/3/2005 11:05:00 AM
Vinyl chloride	U	1.0		µg/L	1	8/3/2005 11:05:00 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1215 NP2-10
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-03B	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	12.3	0.0200		mg/L	1	8/9/2005 11:11:39 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 09-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ072905:1215 NP2-10
Lab Order:	0508026	Tag Number:	6152
Project:	Rowe Industries	Collection Date:	7/29/2005
Lab ID:	0508026-03C	Date Received:	8/2/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.172	0.0200		mg/L	1	8/9/2005 11:02:10 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: WN
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	8/4/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, August 03, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0507151

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 9 sample(s) on 7/19/2005 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0507151

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0507151-01A	GWQ071405:1000 NP1-1-1	6151	7/14/2005	7/19/2005
0507151-01B	GWQ071405:1000 NP1-1-1	6151	7/14/2005	7/19/2005
0507151-01C	GWQ071405:1000 NP1-1-1	6151	7/14/2005	7/19/2005
0507151-01D	GWQ071405:1000 NP1-1-1	6151	7/14/2005	7/19/2005
0507151-02A	GWQ071405:1010 NP1-1-2	6151	7/14/2005	7/19/2005
0507151-02B	GWQ071405:1010 NP1-1-2	6151	7/14/2005	7/19/2005
0507151-02C	GWQ071405:1010 NP1-1-2	6151	7/14/2005	7/19/2005
0507151-02D	GWQ071405:1010 NP1-1-2	6151	7/14/2005	7/19/2005
0507151-03A	GWQ071405:1020 NP1-1-3	6151	7/14/2005	7/19/2005
0507151-03B	GWQ071405:1020 NP1-1-3	6151	7/14/2005	7/19/2005
0507151-03C	GWQ071405:1020 NP1-1-3	6151	7/14/2005	7/19/2005
0507151-03D	GWQ071405:1020 NP1-1-3	6151	7/14/2005	7/19/2005
0507151-04A	GWQ071405:1030 NP1-1-4	6151	7/14/2005	7/19/2005
0507151-04B	GWQ071405:1030 NP1-1-4	6151	7/14/2005	7/19/2005
0507151-04C	GWQ071405:1030 NP1-1-4	6151	7/14/2005	7/19/2005
0507151-04D	GWQ071405:1030 NP1-1-4	6151	7/14/2005	7/19/2005
0507151-05A	GWQ071405:1040 NP1-1-5	6151	7/14/2005	7/19/2005
0507151-05B	GWQ071405:1040 NP1-1-5	6151	7/14/2005	7/19/2005
0507151-05C	GWQ071405:1040 NP1-1-5	6151	7/14/2005	7/19/2005
0507151-05D	GWQ071405:1040 NP1-1-5	6151	7/14/2005	7/19/2005
0507151-06A	GWQ071405:1050 NP1-1-6	6151	7/14/2005	7/19/2005
0507151-06B	GWQ071405:1050 NP1-1-6	6151	7/14/2005	7/19/2005
0507151-06C	GWQ071405:1050 NP1-1-6	6151	7/14/2005	7/19/2005
0507151-06D	GWQ071405:1050 NP1-1-6	6151	7/14/2005	7/19/2005
0507151-07A	GWQ071405:1100 NP1-1-7	6151	7/14/2005	7/19/2005
0507151-07B	GWQ071405:1100 NP1-1-7	6151	7/14/2005	7/19/2005
0507151-07C	GWQ071405:1100 NP1-1-7	6151	7/14/2005	7/19/2005
0507151-07D	GWQ071405:1100 NP1-1-7	6151	7/14/2005	7/19/2005
0507151-08A	GWQ071405:1110 NP1-1-8	6151	7/14/2005	7/19/2005
0507151-08B	GWQ071405:1110 NP1-1-8	6151	7/14/2005	7/19/2005
0507151-08C	GWQ071405:1110 NP1-1-8	6151	7/14/2005	7/19/2005
0507151-08D	GWQ071405:1110 NP1-1-8	6151	7/14/2005	7/19/2005
0507151-09A	GWQ071405:1120 NP1-1-9	6151	7/14/2005	7/19/2005
0507151-09B	GWQ071405:1120 NP1-1-9	6151	7/14/2005	7/19/2005
0507151-09C	GWQ071405:1120 NP1-1-9	6151	7/14/2005	7/19/2005
0507151-09D	GWQ071405:1120 NP1-1-9	6151	7/14/2005	7/19/2005



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
 (631) 454-6100 • FAX (631) 454-8027

TAG # / COC 6151

NYSDOH 11418
 CTDOH PH-0205
 NJDEP NY050
 PADEP 68-573

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBG 126 Monroe Turnpike Trumbull, CT 06621	CONTACT: Mark Goldberg	SAMPLER (SIGNATURE) Mark M. Goldberg	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
		SAMPLER NAME (PRINT) Mark M. Goldberg	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO

PROJECT LOCATION: Rowe					ANALYSIS REQUIRED	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)														
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION																
OSD 7151 7ABCD	L	5	7/14/05	GWR071405:1000 NPI-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
2ABCD				:1010 NPI-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
3ABCD				:1020 NPI-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
4ABCD				:1030 NPI-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
5ABCD				:1040 NPI-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
6ABCD				:1050 NPI-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
7ABCD				:1100 NPI-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
8ABCD				:1110 NPI-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
9ABCD	✓	✓	✓	:1120 NPI-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON			TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY		COOLER TEMPERATURE:
RELINQUISHED BY (SIGNATURE) Mark M. Goldberg			PRINTED NAME Mark M. Goldberg		RECEIVED BY LAB (SIGNATURE) [Signature]
RELINQUISHED BY (SIGNATURE) [Signature]			PRINTED NAME [Name]		RECEIVED BY LAB (SIGNATURE) [Signature]
DATE 7/18/05 TIME 16:00			DATE 7/18/05 TIME 1045		PRINTED NAME [Name]

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0507151

CASE NARRATIVE

Samples were analyzed using the methods outlined throughout the text of the report.

All method blanks, laboratory spikes, and/or matrix spikes met quality assurance objectives.

Due to the time period that elapsed from sample collection to sample receipt, the Turbidity analysis was performed beyond the method required holding time. Sample results have been qualified, "H" as required.

Methylene Chloride and Acetone were detected at acceptable levels in the associated volatile method blanks. These analytes are common lab contaminants. The presence of these analytes in the field samples can be attributed to laboratory contamination and not sample matrix constituents.

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1000 NP1-1-1
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-01A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
2-Butanone	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
2-Hexanone	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Acetone	6.9	1.0	B	µg/L	1	7/20/2005 5:52:00 PM
Benzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Chloroethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1000 NPI-1-1
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-01A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	2.1	1.0		µg/L	1	7/20/2005 5:52:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2005 5:52:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Methylene chloride	8.4	1.0	B	µg/L	1	7/20/2005 5:52:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Styrene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Toluene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2005 5:52:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2005 5:52:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1000 NP1-1-1
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-01B Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0289	0.0200		mg/L	1	7/28/2005 9:56:46 AM
Manganese	0.111	0.0200		mg/L	1	7/28/2005 9:56:46 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1000 NPI-1-1
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-01C Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	U	0.0200		mg/L	1	7/28/2005 9:54:32 AM
Manganese	0.112	0.0200		mg/L	1	7/28/2005 9:54:32 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1000 NP1-1-1
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-01D Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	31.4	M2340 1.00	B	mg/L	1	Analyst: KK 7/28/2005
TURBIDITY Turbidity	2.40	E180.1 1.00	H	NTU	1	Analyst: KK 7/20/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	150	E160.1 1.0		mg/L	1	Analyst: WN 7/19/2005

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1010 NP1-1-2
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-02A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B				Analyst: JMO
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
2-Butanone	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
2-Hexanone	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Acetone	5.6	1.0	B	µg/L	1	7/20/2005 6:24:00 PM
Benzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Chloroethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ071405:1010 NP1-1-2
Lab Order: 0507151 **Tag Number:** 6151
Project: Rowe Industries **Collection Date:** 7/14/2005
Lab ID: 0507151-02A **Date Received:** 7/19/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2005 6:24:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Methylene chloride	7.3	1.0	B	µg/L	1	7/20/2005 6:24:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Styrene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Tetrachloroethene	7.7	1.0		µg/L	1	7/20/2005 6:24:00 PM
Toluene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Trichloroethene	1.1	1.0		µg/L	1	7/20/2005 6:24:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2005 6:24:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2005 6:24:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ071405:1010 NP1-1-2
Lab Order:	0507151	Tag Number:	6151
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507151-02B	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE			E200.7			Analyst: JP
Iron	0.280	0.0200		mg/L	1	7/28/2005 10:01:45 AM
Manganese	0.695	0.0200		mg/L	1	7/28/2005 10:01:45 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1010 NP1-1-2
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-02C Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0298	0.0200		mg/L	1	7/28/2005 9:59:29 AM
Manganese	0.665	0.0200		mg/L	1	7/28/2005 9:59:29 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: GWQ071405:1010 NP1-1-2
Lab Order: 0507151	Tag Number: 6151
Project: Rowe Industries	Collection Date: 7/14/2005
Lab ID: 0507151-02D	Date Received: 7/19/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	44.8	M2340 1.00	B	mg/L	1	Analyst: KK 7/28/2005
TURBIDITY Turbidity	2.10	E180.1 1.00	H	NTU	1	Analyst: KK 7/20/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	150	E160.1 1.0		mg/L	1	Analyst: WN 7/21/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1020 NP1-1-3
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-03A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
2-Butanone	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
2-Hexanone	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Acetone	6.9	1.0	B	µg/L	1	7/20/2005 6:57:00 PM
Benzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Chloroethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1020 NP1-1-3
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-03A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2005 6:57:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Methylene chloride	9.1	1.0	B	µg/L	1	7/20/2005 6:57:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Styrene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Tetrachloroethene	1.6	1.0		µg/L	1	7/20/2005 6:57:00 PM
Toluene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2005 6:57:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2005 6:57:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1020 NP1-I-3
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-03B Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE			E200.7			Analyst: JP
Iron	2.01	0.0200		mg/L	1	7/28/2005 10:06:20 AM
Manganese	0.114	0.0200		mg/L	1	7/28/2005 10:06:20 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1020 NP1-1-3
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-03C Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.649	0.0200		mg/L	1	7/28/2005 10:04:11 AM
Manganese	0.0979	0.0200		mg/L	1	7/28/2005 10:04:11 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1020 NP1-1-3
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-03D Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	37.2	M2340 1.00	B	mg/L	1	Analyst: KK 7/28/2005
TURBIDITY Turbidity	1.80	E180.1 1.00	H	NTU	1	Analyst: KK 7/20/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	94	E160.1 1.0		mg/L	1	Analyst: WN 7/21/2005

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1030 NP1-1-4
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-04A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,1,1-Trichloroethane	8.9	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
2-Butanone	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
2-Hexanone	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Acetone	7.4	1.0	B	µg/L	1	7/20/2005 7:30:00 PM
Benzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Chloroethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: GWQ071405:1030 NP1-1-4
Lab Order: 0507151	Tag Number: 6151
Project: Rowe Industries	Collection Date: 7/14/2005
Lab ID: 0507151-04A	Date Received: 7/19/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2005 7:30:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Methylene chloride	9.4	1.0	B	µg/L	1	7/20/2005 7:30:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Styrene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Tetrachloroethene	37	1.0		µg/L	1	7/20/2005 7:30:00 PM
Toluene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2005 7:30:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2005 7:30:00 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1030 NP1-1-4
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-04B Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7				Analyst: JP
Iron	3.22	0.0200		mg/L	1	7/28/2005 10:20:19 AM
Manganese	1.40	0.0200		mg/L	1	7/28/2005 10:20:19 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1030 NP1-1-4
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-04C Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		Analyst: JP		
Iron	0.0185	0.0200	J	mg/L	1	7/28/2005 10:16:58 AM
Manganese	1.29	0.0200		mg/L	1	7/28/2005 10:16:58 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ071405:1030 NPI-1-4
Lab Order: 0507151 **Tag Number:** 6151
Project: Rowe Industries **Collection Date:** 7/14/2005
Lab ID: 0507151-04D **Date Received:** 7/19/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: KK
Hardness, Calcium/Magnesium (As CaCO3)	34.0	1.00	M2340 B	mg/L	1	7/28/2005
TURBIDITY						Analyst: KK
Turbidity	U	1.00	E180.1 H	NTU	1	7/20/2005
TOTAL DISSOLVED SOLIDS						Analyst: WN
Total Dissolved Solids (Residue, Filterable)	140	1.0	E160.1	mg/L	1	7/21/2005

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1040 NP1-1-5
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-05A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,1,1-Trichloroethane	1.6	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
2-Butanone	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
2-Hexanone	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Acetone	5.6	1.0	B	µg/L	1	7/20/2005 8:02:00 PM
Benzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Chloroethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected
 Page 21 of 45

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1040 NPI-1-5
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-05A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2005 8:02:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Methylene chloride	9.5	1.0	B	µg/L	1	7/20/2005 8:02:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Styrene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Tetrachloroethene	8.2	1.0		µg/L	1	7/20/2005 8:02:00 PM
Toluene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2005 8:02:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2005 8:02:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ071405:1040 NP1-1-5
Lab Order: 0507151 **Tag Number:** 6151
Project: Rowe Industries **Collection Date:** 7/14/2005
Lab ID: 0507151-05B **Date Received:** 7/19/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		Analyst: JP		
Iron	0.0358	0.0200		mg/L	1	7/28/2005 10:30:41 AM
Manganese	0.00753	0.0200	J	mg/L	1	7/28/2005 10:30:41 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1040 NP1-1-5
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-05C Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	U	0.0200		mg/L	1	7/28/2005 10:23:09 AM
Manganese	0.00799	0.0200	J	mg/L	1	7/28/2005 10:23:09 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ071405:1040 NP1-1-5
Lab Order:	0507151	Tag Number:	6151
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507151-05D	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	31.3	M2340 1.00	B	mg/L	1	Analyst: KK 7/28/2005
TURBIDITY Turbidity	U	E180.1 1.00	H	NTU	1	Analyst: KK 7/20/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	130	E160.1 1.0		mg/L	1	Analyst: WN 7/21/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1050 NP1-1-6
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-06A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,1,1-Trichloroethane	9.5	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
2-Butanone	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
2-Hexanone	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Acetone	7.0	1.0	B	µg/L	1	7/20/2005 8:36:00 PM
Benzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Chloroethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1050 NP1-1-6
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-06A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2005 8:36:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Methylene chloride	7.2	1.0	B	µg/L	1	7/20/2005 8:36:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Styrene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Tetrachloroethene	64	1.0		µg/L	1	7/20/2005 8:36:00 PM
Toluene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Trichloroethene	1.6	1.0		µg/L	1	7/20/2005 8:36:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2005 8:36:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2005 8:36:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1050 NPI-1-6
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-06B Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0406	0.0200		mg/L	1	7/28/2005 10:35:49 AM
Manganese	0.194	0.0200		mg/L	1	7/28/2005 10:35:49 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ071405:1050 NP1-1-6
Lab Order:	0507151	Tag Number:	6151
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507151-06C	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	U	0.0200		mg/L	1	7/28/2005 10:33:41 AM
Manganese	0.175	0.0200		mg/L	1	7/28/2005 10:33:41 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1050 NPI-1-6
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-06D Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	30.6	M2340 1.00	B	mg/L	1	Analyst: KK 7/28/2005
TURBIDITY Turbidity	U	E180.1 1.00	H	NTU	1	Analyst: KK 7/20/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	140	E160.1 1.0		mg/L	1	Analyst: WN 7/21/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1100 NP1-1-7
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-07A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,1,1-Trichloroethane	2.2	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
2-Butanone	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
2-Hexanone	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Acetone	7.2	1.0	B	µg/L	1	7/20/2005 9:09:00 PM
Benzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Chloroethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0507151
 Project: Rowe Industries
 Lab ID: 0507151-07A

Client Sample ID: GWQ071405:1100 NP1-1-7
 Tag Number: 6151
 Collection Date: 7/14/2005
 Matrix: LIQUID

Date Received: 7/19/2005

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2005 9:09:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Methylene chloride	8.7	1.0	B	µg/L	1	7/20/2005 9:09:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Styrene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Tetrachloroethene	32	1.0		µg/L	1	7/20/2005 9:09:00 PM
Toluene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2005 9:09:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2005 9:09:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1100 NP1-1-7
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-07B Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		Analyst: JP		
Iron	0.0155	0.0200	J	mg/L	1	7/28/2005 10:40:17 AM
Manganese	0.0555	0.0200		mg/L	1	7/28/2005 10:40:17 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected
 Page 33 of 45

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc.	Client Sample ID: GWQ071405:1100 NP1-I-7
Lab Order: 0507151	Tag Number: 6151
Project: Rowe Industries	Collection Date: 7/14/2005
Lab ID: 0507151-07C	Date Received: 7/19/2005
	Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7				Analyst: JP
Iron	U	0.0200		mg/L	1	7/28/2005 10:38:10 AM
Manganese	0.0499	0.0200		mg/L	1	7/28/2005 10:38:10 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1100 NP1-1-7
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-07D Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	27.4	M2340 1.00	B	mg/L	1	Analyst: KK 7/28/2005
TURBIDITY Turbidity	U	E180.1 1.00	H	NTU	1	Analyst: KK 7/20/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	70	E160.1 1.0		mg/L	1	Analyst: WN 7/21/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1110 NP1-1-8
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-08A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,1,1-Trichloroethane	3.4	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
2-Butanone	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
2-Hexanone	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Acetone	8.2	1.0	B	µg/L	1	7/21/2005 12:29:00 AM
Benzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Bromobenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Bromoform	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Bromomethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Chloroethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected
 Page 36 of 45

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1110 NP1-1-8
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-08A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Chloromethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Dibromomethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/21/2005 12:29:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Methylene chloride	8.5	1.0	B	µg/L	1	7/21/2005 12:29:00 AM
Naphthalene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
o-Xylene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Styrene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Tetrachloroethene	2.6	1.0		µg/L	1	7/21/2005 12:29:00 AM
Toluene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Trichloroethene	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/21/2005 12:29:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/21/2005 12:29:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1110 NP1-1-8
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-08B Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE			E200.7			Analyst: JP
Iron	8.33	0.0200		mg/L	1	7/28/2005 10:45:07 AM
Manganese	0.676	0.0200		mg/L	1	7/28/2005 10:45:07 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ071405:1110 NPI-1-8
Lab Order:	0507151	Tag Number:	6151
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507151-08C	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.0165	0.0200	J	mg/L	1	7/28/2005 10:42:54 AM
Manganese	0.613	0.0200		mg/L	1	7/28/2005 10:42:54 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ071405:1110 NP1-1-8
Lab Order:	0507151	Tag Number:	6151
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507151-08D	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	22.0	M2340 1.00	B	mg/L	1	Analyst: KK 7/28/2005
TURBIDITY Turbidity	1.60	E180.1 1.00	H	NTU	1	Analyst: KK 7/20/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	80	E160.1 1.0		mg/L	1	Analyst: WN 7/21/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1120 NP1-1-9
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-09A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: JMO		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,1,1-Trichloroethane	3.1	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
2-Butanone	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
2-Hexanone	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Acetone	7.3	1.0	B	µg/L	1	7/21/2005 1:38:00 PM
Benzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Bromobenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Bromoform	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Bromomethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Chloroethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1120 NP1-1-9
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-09A Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Chloromethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Dibromomethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/21/2005 1:38:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Methylene chloride	6.9	1.0	B	µg/L	1	7/21/2005 1:38:00 PM
Naphthalene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
o-Xylene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Styrene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Tetrachloroethene	3.4	1.0		µg/L	1	7/21/2005 1:38:00 PM
Toluene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Trichloroethene	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/21/2005 1:38:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/21/2005 1:38:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ071405:1120 NPI-1-9
 Lab Order: 0507151 Tag Number: 6151
 Project: Rowe Industries Collection Date: 7/14/2005
 Lab ID: 0507151-09B Date Received: 7/19/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7				Analyst: JP
Iron	2.55	0.0200		mg/L	1	7/28/2005 11:01:26 AM
Manganese	0.774	0.0200		mg/L	1	7/28/2005 11:01:26 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ071405:1120 NP1-1-9
Lab Order: 0507151 **Tag Number:** 6151
Project: Rowe Industries **Collection Date:** 7/14/2005
Lab ID: 0507151-09C **Date Received:** 7/19/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7				Analyst: JP
Iron	0.238	0.0200		mg/L	1	7/28/2005 10:59:21 AM
Manganese	0.698	0.0200		mg/L	1	7/28/2005 10:59:21 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Aug-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ071405:1120 NP1-1-9
Lab Order:	0507151	Tag Number:	6151
Project:	Rowe Industries	Collection Date:	7/14/2005
Lab ID:	0507151-09D	Date Received:	7/19/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	23.5	M2340 1.00		mg/L	1	Analyst: KK 7/28/2005
TURBIDITY Turbidity	4.20	E180.1 1.00	H	NTU	1	Analyst: KK 7/20/2005
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	86	E160.1 1.0		mg/L	1	Analyst: WN 7/21/2005

Qualifiers:

* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
E Value above quantitation range	H Holding times for preparation or analysis exceeded
J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

ANALYTICAL REPORT

JOB NUMBER: 210136


Prepared For:

LEGGETTE, BRASHEARS & GRAHAM
126 Monroe Turnpike
Trumbull, CT 06611

Project: ROWE INDUSTRIES

Attention: Mark Goldberg

Date: 08/04/2005




Signature

Name: William D. Goodman

Title: Project Manager

E-Mail: wgoodman@stl-inc.com



Date

STL Connecticut
128 Long Hill Cross Road
Shelton, CT 06484

This Report Contains (119) Pages

STL Report : 210136
LEGGETTE, BRASHEARS, & GRAHAM**Case Narrative**

Sample Receipt – All samples were received in good condition.

Volatile Organics – Air volatile organics were determined by purge and trap GC/MS using guidance provided in Method TO-17. The instrumentation used was a Perkin Elmer ATD 50 interfaced with a Hewlett-Packard Model 5972A GC/MS/DS.

The samples in this job were collected in tedlar bags. Samples were transferred by the laboratory to Air Toxic TO-17 tubes and analyzed at sample volumes of 1L. Compound concentrations over the calibration curve were flagged with an "A". Sample AQ070705:1400 NP4-1 was originally analyzed on 7/28/05 with target compounds over the calibration curve. The sample was re-analyzed on 7/28/05 at a sample volume of .25L with a target compound still over the calibration curve. Both analyses were reported for this sample.

Both target compounds, carbon disulfide and methylene chloride, are believed to be laboratory contaminants. These compounds were problematic throughout calibration and quality control check.

Sample Calculation:

Sample ID- AQ070705:1400NP4-1
Compound-Bromomethane

$$\frac{(75264 \text{ area})(25\text{ng})}{(157964 \text{ area})(.486 \text{ area/ng})} = 24.5 = 24 \text{ ng}$$

$$\frac{(24\text{NG})(.08206)(298)}{(1\text{L})(95)(1.0\text{ATM})} = 6.17 = 6.2 \text{ nL/L.}$$

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in the case narrative.

SAMPLE INFORMATION
Date: 08/04/2005

Job Number.: 210136
Customer...: LEGGETTE, BRASHEARS & GRAHAM
Attn.....: Mark Goldberg

Project Number.....: Z0000283
Customer Project ID....: ROWE INDUSTRIES
Project Description....: Rowe Industries

Laboratory Sample ID	Customer Sample ID	Sample Matrix	Date Sampled	Time Sampled	Date Received	Time Received
210136-1	AQ070705:1400 NP4-1	Air	07/07/2005	14:10	07/11/2005	12:30
210136-2	AQ070705:1415 NP4-2	Air	07/07/2005	14:15	07/11/2005	12:30
210136-3	AQ070705:1420 NP4-3	Air	07/07/2005	14:20	07/11/2005	12:30

STL Connecticut		Form 1		Client Sample ID		AQ070705:1400 NP4-1	
Method: TO17		Lab Sample ID		210136-1			
Sample Volume (L)		1.000		Date Sampled		7/7/2005	
Temp (C)		25		Date Analyzed		7/28/2005	
Compound	nL/L (ppbv/v)	Qualifier	RL	mg/M3	Qualifier	RL	
Chloromethane	9.7	U	9.7	0.020	U	0.020	
Vinyl Chloride	7.8	U	7.8	0.020	U	0.020	
Bromomethane	6.2	B	5.1	0.024	B	0.020	
Chloroethane	7.6	U	7.6	0.020	U	0.020	
1,1-Dichloroethene	2.5	U	2.5	0.010	U	0.010	
Carbon Disulfide	163.9	A	3.2	0.510	A	0.010	
Methylene Chloride	54.7		2.9	0.190		0.010	
trans-1,2-Dichloroethene	2.5	U	2.5	0.010	U	0.010	
1,1-Dichloroethane	2.5	U	2.5	0.010	U	0.010	
cis-1,2-Dichloroethene	2.5	U	2.5	0.010	U	0.010	
Chloroform	2.1	U	2.1	0.010	U	0.010	
1,1,1-Trichloroethane	22.1		1.8	0.120		0.010	
Carbon Tetrachloride	1.6	U	1.6	0.010	U	0.010	
Benzene	3.1	U	3.1	0.010	U	0.010	
1,2-Dichloroethane	2.5	U	2.5	0.010	U	0.010	
Trichloroethene	4.9		1.9	0.026		0.010	
1,2-Dichloropropane	2.2	U	2.2	0.010	U	0.010	
Bromodichloromethane	1.5	U	1.5	0.010	U	0.010	
cis-1,3-Dichloropropene	2.2	U	2.2	0.010	U	0.010	
Toluene	11.7		2.7	0.044		0.010	
trans-1,3-Dichloropropene	2.2	U	2.2	0.010	U	0.010	
1,1,2-Trichloroethane	1.8	U	1.8	0.010	U	0.010	
Tetrachloroethene	63.3	A	1.5	0.430	A	0.010	
Dibromochloromethane	1.2	U	1.2	0.010	U	0.010	
Chlorobenzene	2.2	U	2.2	0.010	U	0.010	
Ethylbenzene	0.2	J	2.3	0.001	J	0.010	
m&p-Xylenes	1.4	J	2.3	0.006	J	0.010	
o-Xylene	0.5	J	2.3	0.002	J	0.010	
Styrene	1.4	J	2.4	0.006	J	0.010	
Bromoform	1.0	U	1.0	0.010	U	0.010	
1,1,2,2-Tetrachloroethane	1.5	U	1.5	0.010	U	0.010	

STL Connecticut		Form 1		Client Sample ID		AQ070705:1400 NP4-1DL	
Method: TO17		Lab Sample ID		210136-1DL			
Sample Volume (L)		0.250		Date Sampled		7/7/2005	
Temp (C)		25		Date Analyzed		7/28/2005	
Compound	nL/L	(ppbv/v) Qualifier	RL	mg/M3	Qualifier	RL	
Chloromethane	38.7	U	38.7	0.080	U	0.080	
Vinyl Chloride	31.3	U	31.3	0.080	U	0.080	
Bromomethane	14.4	B	20.6	0.056	B	0.080	
Chloroethane	30.3	U	30.3	0.080	U	0.080	
1,1-Dichloroethene	10.1	U	10.1	0.040	U	0.040	
Carbon Disulfide	604.1	A	12.9	1.880	A	0.040	
Methylene Chloride	56.5		11.5	0.196		0.040	
trans-1,2-Dichloroethene	10.2	U	10.2	0.040	U	0.040	
1,1-Dichloroethane	9.9	U	9.9	0.040	U	0.040	
cis-1,2-Dichloroethene	10.2	U	10.2	0.040	U	0.040	
Chloroform	8.2	U	8.2	0.040	U	0.040	
1,1,1-Trichloroethane	20.6		7.4	0.112		0.040	
Carbon Tetrachloride	6.4	U	6.4	0.040	U	0.040	
Benzene	12.5	U	12.5	0.040	U	0.040	
1,2-Dichloroethane	9.9	U	9.9	0.040	U	0.040	
Trichloroethene	2.2	J	7.5	0.012	J	0.040	
1,2-Dichloropropane	8.7	U	8.7	0.040	U	0.040	
Bromodichloromethane	6.0	U	6.0	0.040	U	0.040	
cis-1,3-Dichloropropene	8.8	U	8.8	0.040	U	0.040	
Toluene	11.7		10.6	0.044		0.040	
trans-1,3-Dichloropropene	8.8	U	8.8	0.040	U	0.040	
1,1,2-Trichloroethane	7.4	U	7.4	0.040	U	0.040	
Tetrachloroethene	45.4		5.9	0.308		0.040	
Dibromochloromethane	4.7	U	4.7	0.040	U	0.040	
Chlorobenzene	8.7	U	8.7	0.040	U	0.040	
Ethylbenzene	9.2	U	9.2	0.040	U	0.040	
m&p-Xylenes	9.2	U	9.2	0.040	U	0.040	
o-Xylene	9.2	U	9.2	0.040	U	0.040	
Styrene	9.4	U	9.4	0.040	U	0.040	
Bromoform	3.9	U	3.9	0.040	U	0.040	
1,1,2,2-Tetrachloroethane	5.8	U	5.8	0.040	U	0.040	

STL Connecticut		Form 1		Client Sample ID		AQ070705:1415 NP4-2	
Method: TO17		Lab Sample ID		210136-2			
Sample Volume (L)		1.000		Date Sampled		7/7/2005	
Temp (C)		25		Date Analyzed		7/28/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3	Qualifier	RL		
Chloromethane	9.7 U	9.7	0.020	U	0.020		
Vinyl Chloride	7.8 U	7.8	0.020	U	0.020		
Bromomethane	28.3 B	5.1	0.110	B	0.020		
Chloroethane	7.6 U	7.6	0.020	U	0.020		
1,1-Dichloroethene	2.5 U	2.5	0.010	U	0.010		
Carbon Disulfide	157.5 A	3.2	0.490	A	0.010		
Methylene Chloride	187.2 A	2.9	0.650	A	0.010		
trans-1,2-Dichloroethene	2.5 U	2.5	0.010	U	0.010		
1,1-Dichloroethane	2.5 U	2.5	0.010	U	0.010		
cis-1,2-Dichloroethene	2.5 U	2.5	0.010	U	0.010		
Chloroform	2.1 U	2.1	0.010	U	0.010		
1,1,1-Trichloroethane	6.6	1.8	0.036		0.010		
Carbon Tetrachloride	1.6 U	1.6	0.010	U	0.010		
Benzene	1.9 J	3.1	0.006	J	0.010		
1,2-Dichloroethane	2.5 U	2.5	0.010	U	0.010		
Trichloroethene	1.9 U	1.9	0.010	U	0.010		
1,2-Dichloropropane	2.2 U	2.2	0.010	U	0.010		
Bromodichloromethane	1.5 U	1.5	0.010	U	0.010		
cis-1,3-Dichloropropene	2.2 U	2.2	0.010	U	0.010		
Toluene	9.6	2.7	0.036		0.010		
trans-1,3-Dichloropropene	2.2 U	2.2	0.010	U	0.010		
1,1,2-Trichloroethane	1.8 U	1.8	0.010	U	0.010		
Tetrachloroethene	1.5 U	1.5	0.010	U	0.010		
Dibromochloromethane	1.2 U	1.2	0.010	U	0.010		
Chlorobenzene	2.2 U	2.2	0.010	U	0.010		
Ethylbenzene	2.3 U	2.3	0.010	U	0.010		
m&p-Xylenes	0.5 J	2.3	0.002	J	0.010		
o-Xylene	2.3 U	2.3	0.010	U	0.010		
Styrene	2.4 U	2.4	0.010	U	0.010		
Bromoform	1.0 U	1.0	0.010	U	0.010		
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.010	U	0.010		

STL Connecticut		Form 1		Client Sample ID		AQ070705:1420 NP4-3	
Method: TO17				Lab Sample ID		210136-3	
Sample Volume (L)		1.000		Date Sampled		7/7/2005	
Temp (C)		25		Date Analyzed		7/28/2005	
Compound	nL/L (ppbv/v)	Qualifier	RL	mg/M3	Qualifier	RL	
Chloromethane	9.7	U	9.7	0.020	U	0.020	
Vinyl Chloride	7.8	U	7.8	0.020	U	0.020	
Bromomethane	11.8	B	5.1	0.046	B	0.020	
Chloroethane	7.6	U	7.6	0.020	U	0.020	
1,1-Dichloroethene	2.5	U	2.5	0.010	U	0.010	
Carbon Disulfide	144.6	A	3.2	0.450	A	0.010	
Methylene Chloride	66.2	A	2.9	0.230	A	0.010	
trans-1,2-Dichloroethene	2.5	U	2.5	0.010	U	0.010	
1,1-Dichloroethane	2.5	U	2.5	0.010	U	0.010	
cis-1,2-Dichloroethene	2.5	U	2.5	0.010	U	0.010	
Chloroform	2.1	U	2.1	0.010	U	0.010	
1,1,1-Trichloroethane	2.6		1.8	0.014		0.010	
Carbon Tetrachloride	1.6	U	1.6	0.010	U	0.010	
Benzene	1.3	J	3.1	0.004	J	0.010	
1,2-Dichloroethane	2.5	U	2.5	0.010	U	0.010	
Trichloroethene	1.9	U	1.9	0.010	U	0.010	
1,2-Dichloropropane	2.2	U	2.2	0.010	U	0.010	
Bromodichloromethane	1.5	U	1.5	0.010	U	0.010	
cis-1,3-Dichloropropene	2.2	U	2.2	0.010	U	0.010	
Toluene	10.1		2.7	0.038		0.010	
trans-1,3-Dichloropropene	2.2	U	2.2	0.010	U	0.010	
1,1,2-Trichloroethane	1.8	U	1.8	0.010	U	0.010	
Tetrachloroethene	1.5	U	1.5	0.010	U	0.010	
Dibromochloromethane	1.2	U	1.2	0.010	U	0.010	
Chlorobenzene	2.2	U	2.2	0.010	U	0.010	
Ethylbenzene	2.3	U	2.3	0.010	U	0.010	
m&p-Xylenes	0.7	J	2.3	0.003	J	0.010	
o-Xylene	2.3	U	2.3	0.010	U	0.010	
Styrene	1.2	J	2.4	0.005	J	0.010	
Bromoform	1.0	U	1.0	0.010	U	0.010	
1,1,2,2-Tetrachloroethane	1.5	U	1.5	0.010	U	0.010	

LABORATORY CHRONICLE

Job Number: 210136

Date: 08/04/2005

CUSTOMER: LEGGETTE, BRASHEARS & GRAHAM

PROJECT: ROWE INDUSTRIES

ATTN: Mark Goldberg

Lab ID:	Client ID:	Date Recvd:	Sample Date:				
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)	DATE/TIME ANALYZED	DILUTION
210136-1	AQ070705:1400 NP4-1	07/11/2005	07/07/2005				
T017	Volatile Organics (Air)	1	52468			07/28/2005 1506	1.00000
T017	Volatile Organics (Air)	1	52468			07/28/2005 1915	1.00000
T017	Volatile Organics (Air)	2	52468			07/28/2005 1506	1.00000
T017	Volatile Organics (Air)	2	52468			07/28/2005 1915	1.00000
210136-2	AQ070705:1415 NP4-2	07/11/2005	07/07/2005				
T017	Volatile Organics (Air)	1	52468			07/28/2005 1559	1.00000
210136-3	AQ070705:1420 NP4-3	07/11/2005	07/07/2005				
T017	Volatile Organics (Air)	1	52468			07/28/2005 1647	1.00000

AK

2A

WATER VOLATILE SYSTEM MONITORING COMPOUND RECOVERY

RM 8/1/03

Lab Name: STL-CT

Contract:

Lab Code: STL-CT

Case No.: 210136 SAS No.:

SDG No.: 210136

	EPA SAMPLE NO.	SMC1 #	SMC2 (DCE) #	SMC3 (TOL) #	OTHER (BFB) #	TOT OUT
01	VBLKT7	114	98	104	94	
02	20NG QCS	112	99	102	92	
03	AQ070705:1400 NP4-	103	89	111	93	
04	AQ070705:1415 NP4-	102	92	109	102	
05	AQ070705:1420 NP4-	102	89	110	98	
06	AQ070705:1400NP41D	107	92	107	90	
07						
08						
09						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

QC LIMITS
 SMC1 = Dibromofluoromethane (70-130)
 SMC2 (DCE) = 1,2-Dichloroethane-d4 (70-130)
 SMC3 (TOL) = Toluene-d8 (70-130)
 OTHER (BFB) = Bromofluorobenzene (70-130)

Column to be used to flag recovery values

* Values outside of contract required QC limits

D System Monitoring Compound diluted out

FORM 3

Data File: \\TARGET1_CT\Files\chem\VOA\mst.i\T055076.b\T5082.D Page 1
 Report Date: 28-Jul-2005 13:32

STL-CT

RECOVERY REPORT

Client Name:	Client SDG: SDGa24843
Sample Matrix: LIQUID	Fraction: VOA
Lab Smp Id: 20ng QCS	Client Smp ID: 20ng QCS
Level: LOW	Operator: B.Kostrzewska
Data Type: MS DATA	SampleType: LCS
SpikeList File: AIRQCS.spk	Quant Type: ISTD
Sublist File: all.sub	
Method File: \\TARGET1_CT\Files\chem\VOA\mst.i\T055076.b\TAIRFULL.m	
Misc Info: : LCS;;; 20ng QCS * 1L* ; AIR	

SPIKE COMPOUND	CONC ADDED ug/L	CONC RECOVERED ug/L	% RECOVERED	LIMITS
4 Vinyl Chloride	20	14	69.43	60-140
5 Bromomethane	20	14	67.74	60-140
6 Chloroethane	20	17	84.04	60-140
12 1,1-Dichloroethene	20	18	92.29	60-140
11 Trichlorotrifluoro	20	26	131.44	60-140
17 Acetone	20	13	63.55	60-140
13 Carbon Disulfide	20	480	2411.18*	60-140
16 Methylene Chloride	20	17	86.40	60-140
18 trans-1,2-Dichloro	20	17	86.49	60-140
28 1,1-Dichloroethane	20	17	85.18	60-140
30 cis-1,2-Dichloroet	20	16	82.38	60-140
40 2-Butanone	20	19	94.79	60-140
33 Chloroform	20	18	89.81	60-140
38 1,1,1-Trichloroeth	20	21	104.54	60-140
39 Carbon Tetrachlori	20	23	116.86	60-140
51 1,2-Dichloroethane	20	20	98.26	60-140
48 Benzene	20	17	82.85	60-140
56 Trichloroethene	20	18	91.11	60-140
63 cis-1,3-Dichloropr	20	16	81.15	60-140
72 4-Methyl-2-Pentano	20	12	60.66	60-140
69 Toluene	20	18	88.32	60-140
66 trans-1,3-Dichloro	20	13	66.60	60-140
67 1,1,2-Trichloroeth	20	17	85.87	60-140
73 Tetrachloroethene	20	19	93.67	60-140
75 Dibromochlorometha	20	19	94.34	60-140
80 Chlorobenzene	20	18	88.04	60-140
82 Ethylbenzene	20	19	95.90	60-140
83 Xylene (total)mp	40	38	94.81	60-140
84 Xylene (total)o	20	19	92.90	60-140
85 Styrene	20	17	83.92	60-140
86 Bromoform	20	19	95.97	60-140
89 1,1,2,2-Tetrachlor	20	17	85.23	60-140
101 1,3-Dichlorobenzen	20	16	80.86	60-140
102 1,4-Dichlorobenzen	20	17	83.38	60-140
103 1,2-Dichlorobenzen	20	17	83.11	60-140

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC. Lab Cert. ID# 10604
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviation

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the reporting limit.
- < Not detected at or above the reporting limit.
- J Result is less than the RL, but greater than or equal to the method detection limit.
- B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
- S Result was determined by the Method of Standard Additions.

Inorganic Flags (Flag Column)

- ICV,CCV,ICB,CCB,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed th upper or lower control limits.
- * LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
- + MSA correlation coefficient is less than 0.995.
- 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
- E SD: Serial dilution exceeds the control limits.
- H MB, EB: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
- N MS, MSD: Spike recovery exceeds the upper or lower control limits.
- W PS: Post-digestion spike was outside 85-115% control limits.

Organic Qualifiers (Q - Column)

- U Analyte was not detected at or above the reporting limit.
- ND Compound not detected.
- J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
- Q Result was qualitatively confirmed, but not quantified.
- C Pesticide identification was confirmed by GC/MS.
- Y The chromatographic response resembles a typical fuel pattern.
- Z The chromatographic response does not resemble a typical fuel pattern.
- E Result exceeded calibration range, secondary dilution required.

Organic Flags (Flags Column)

- MB,EB, MLE: Batch QC is greater than reporting limit.
- * LCS, LCD, CCV, MS, MSD, Surrogate, RS:Batch QC exceeds the upper or lower control limits.
- A Concentration exceeds the instrument calibration range or below the reporting limit.
- B Compound was found in the blank.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is greater than 25%.

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

Abbreviations

Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column
CCB	Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation Analysis
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
Dil Fac	Dilution Factor
DL	Secondary dilution and analysis
DLfac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB	Extraction Blank
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A
ISB	Interference Check Sample B
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group
Lab ID	An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PACK	Packed Column
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PS	Post Spike
PSD	Post Spike Duplicate
RA	Re-analysis
RE	Re-extraction and analysis
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RS	Reference Standard
RT	Retention Time
RTW	Retention Time Window
SampleID	A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB	Seeded Control Blank
SD	Serial Dilution
UCB	Unseeded Control Blank

One or a combination of these data qualifiers and abbreviations may appear in the analytical report.

STL-Connecticut Certification Summary (as of May 2005)

The laboratory identification numbers for the STL-Connecticut laboratory are provided in the following table. Many states certify laboratories for specific parameters or tests within a category (i.e. method 325.2 for wastewater). The information in the following table indicates the lab is certified in a general category of testing such as drinking water or wastewater analysis. The laboratory should be contacted directly if parameter-specific certification information is required.

State	Responsible Agency	Certification	Expiration Date	Lab Number
Connecticut	Department of Health Services	Drinking Water, Wastewater	12/31/06	PH-0497
Maine	Department of Health and Environmental Services	Drinking Water, Wastewater/Solid, Hazardous Waste	04/18/06	CT023
Massachusetts	Department of Environmental Protection	Potable/Non-Potable Water	06/30/05	CT023
New Hampshire	Department of Environmental Services	Drinking Water, Wastewater	08/29/05	2528
New Jersey	Department of Environmental Protection	Drinking Water, Wastewater	06/30/05	CT410
New York	Department of Health	CLP, Drinking Water, Wastewater, Solid/ Hazardous Waste NELAC	04/01/06	10602
Rhode Island	Department of Health	Chemistry...Non-Potable Water and Wastewater	12/30/05	A43
Utah	Department of Health	RCRA	05/31/05	2032614458

MISCELLANEOUS DOCUMENTS

