

LEGGETTE, BRASHEARS & GRAHAM, INC.

PROFESSIONAL GROUND-WATER AND ENVIRONMENTAL ENGINEERING SERVICES

4 RESEARCH DRIVE

SUITE 301

SHELTON, CT 06484

203-929-8555

FAX 203-926-9140

www.lbgweb.com

February 17, 2006

Mr. Jeffery Trad
Project Manager
New York State Department of Environmental Conservation
Division of Environmental Remediation, Construction Services
625 Broadway, 12th floor
Albany, NY 12233-7013

RE: December 2005 Status Report
Ground-Water Remedial Action
Rowe Industries Superfund Site
Sag Harbor, New York

Dear Mr. Trad:

The enclosed letter report details the operation status of the full-scale ground-water pump and treat system at the above-referenced site. Leggette, Brashears & Graham, Inc. has enclosed an additional copy of the report to be forwarded to the Chief of the Operation Maintenance and Support Section.

Should you or the Operation Maintenance and Support Section have any questions, please feel free to contact myself, Paul Jobmann, or Al Kovalik at (203) 929-8555.

Very truly yours,

LEGGETTE, BRASHEARS & GRAHAM, INC.


Mark Goldberg/m.r.

Mark M. Goldberg, P.E.
Senior Environmental Engineer

MG:mr

Enclosures

H:\NABIS\2006\trad_Dec2005_report.doc



-DRAFT-

PROJECT STATUS MEMORANDUM


NO. 12-05

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Alfred N. Kovalik, P.E.

DATE: February 16, 2006

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
December 2005 Status Report
Sag Harbor, New York



LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from December 1, 2005 through December 31, 2005. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(December 1, 2005 through December 31, 2005)

- | | |
|---|-----------------------------------|
| 1. Hours of operation during the reporting period: | 430 hours (58%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 11,035,896 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: | yes, (Graph 1) |
| 6. Mass of VOCs recovered during the reporting period: | 2.0 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 175.8 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.201 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00198 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow (gpm)	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2	749,750	27	26	61.1	0.38
RW-3	368,939	13	23	ND<1 **	0
RW-4	1,003,869	40	13	67.5	0.57
RW-5*	1,435,490	55	42	2.4	0.03
RW-6*	423,300	17	28	122.1	0.43
RW-7	2,569,897	70	54	86.2	1.85
RW-8	1,430,273	49	46	10.6	0.13
RW-9	1,399,815	54	68	2.9	0.03

* The RW-5 and RW-6 totalizers were malfunctioning from December 1, 2005 to December 21, 2005. The volume of water pumped during this time was calculated by multiplying the average flow rate by the operating time for each well. The total volume of water pumped for December was obtained by adding the calculated value above to the totalizer reading from December 21, 2005 to December 31, 2005.

** ND = not detected.

Recovery wells RW-3, RW-6 and RW-9 had average flows below the respective minimum design flows determined to be necessary for capture of the plume. The RW-9 flow rate was below the minimum design flow because the reinstallation of the computer software reset the old setpoints from the last time the computer program was saved. The setpoint for RW-9 was adjusted from 35 gpm to 80 gpm on December 21, 2005.

The pumping rate and specific capacity from RW-3 have both decreased with time. Rehabilitation efforts in 2005 did not improve the specific capacity of this well. This well's performance will be addressed during well rehabilitation activities next year.

The ground-water drawdown at RW-6 is significant and the drawdown is continuing to increase; therefore, the pumping rate at RW-6 will continue to be 15 gpm as long as well conditions allow. This well's performance will be addressed during well rehabilitation activities next year.

The effluent pH values are below the State Pollutant Discharge Elimination System (SPDES) Applicable or Relevant and Appropriate Requirements (ARARs) of 6.5 on a routine basis. December pH values for water samples from the recovery wells were in the range of approximately 5.9 to 7.3. The FSP&T system does not use any chemical treatment processes to alter pH. In addition, the effluent water discharge and the recovery well extraction points are located in the same aquifer. As discussed with the New York State Department of Environmental Conservation

(NYSDEC), because the low pH is naturally occurring, and because of the previously mentioned factors, it is not considered an exceedance of the discharge requirements.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
December 1 to 7	7 of 8 housings used with 600 micron bag filters	7 of 8 housings used with 600 micron bag filters	Not active
December 8 to 31	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

Bag filters with a 600-micron pore size were placed in the bag filter housing during the November 28, 2005 bag filter change and remained in use until December 7, 2005. No other modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in December 2005 include:

- On December 8, 2005, inspection, cleaning and maintenance of the RW-4 pump and pump motor was completed. The existing RW-4 pump motor was damaged because of sediment build-up at the bottom of the well. The pump elevation was raised by 10 feet and a new pump motor was installed.
- On December 8, 2005, ground-water sampling was conducted in the former drum storage area (FDSA).

Future O&M activities scheduled for the winter of 2006 include:

- Clean the flow meters and valves in the building and recovery wells RW-2, RW-8 and RW-9; and,

cc: Phil McAndrew, Kraft Foods, N.A. – .pdf
Lisa Krogman, Kraft Foods, N.A. (Environ) – .pdf
Jeff Trad, NYSDEC
Chief-Operation Maintenance and Support Section, NYSDEC
William Spitz, RWM, R-1, NYSDEC
Eileen A. Powers, Esq., Town of Southampton

MMG:ng
Attachments

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(December 1, 2005 through December 31, 2005)

Date	Time	System Changes/Modifications	Personnel
12/1/2005	7:30 AM	Communication Failure Alarm; system shut down.	
12/8/2005	8:18 AM	Rebooted the computer, reset the alarm and restarted the system.	RD
	12:50 PM	Inspection, cleaning and maintenance of the pump and pump motor was completed. The existing RW-4 pump motor was damaged because of sediment build-up at the bottom of the well. The pump elevation was raised by 10 feet and a new pump motor was installed. The pump was set at 40 gpm and the pump is now operating at 40 gpm at 90% motor speed.	ETL, RD
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	RD
12/9/2005	8:40 AM	Power failure alarm, air stripper blower low pressure alarm, booster blower low pressure alarm, EQ tank low level alarm, RW-2, 3, and 4 pump fault alarms and transfer tank low level alarm; system shut down.	
	12:06 PM	Control Room Temperature Alarm.	
12/12/2005	7:40 AM	Reset the booster blower motor starter, rebooted the computer, reset all alarms and restarted the system.	RD
12/21/2005	9:14 to 9:29 AM	All nonresettable flow totalizers were reset including the EQ TP101, transfer tank, RW-1, 2, 3, 4, 5, 6, 7, 8 and 9.	RD
		Changed flow setpoints on RW-6 and RW-9 from 40 gpm and 35 gpm to 15 gpm and 80 gpm, respectively.	RD
		Changed the transfer tank level alarm settings to 54.4", 50.4", 44.4" and 34.0" for the high/high level alarm, lag pump on, lead pump on and pumps off, respectively, in order to re-establish the existing water level activation points following the computer software malfunction this past fall.	RD
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	RD
12/24/2005	8:30 AM	Communication Failure Alarm; system shut down.	
12/27/2005	10:10 AM	The computer was rebooted, the communication failure alarm was reset and the system was restarted.	SS
		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SS

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{1/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo- chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	6.5 to 8.5	---	1	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
8-Dec-05	5.3	150	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.36	0.0632
12-Dec-05	5.3	280	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	8.85	0.214
21-Dec-05	5.3	100	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	8.0 ^{3/}	ND<1.0	ND<1.0	ND<1.0	ND<1.0	3.02	0.0452
27-Dec-05	5.3	124	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<2.0	ND<1.0	ND<1.0	11 ^{3/}	ND<1.0	16 ^{3/}	ND<1.0	ND<1.0	9.86	0.471

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. pH was measured using litmus paper. Influent pH values from recovery wells, which reflect the pH of natural ground water, are below 6.5 on a regular basis.
2. "Effluent" samples were collected from sample port labeled NP2-10.
3. Methylene chloride and acetone detected in these samples are suspected to be from laboratory contamination.

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																	TOTAL				
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	VOCs	
AQ010405:1145NP4-1	1/4/05	11:45	0.06	0.025	0.0775	ND	ND	ND	0.015	0.005	ND	ND	ND	0.005	0.025	ND	ND	0.04	ND	ND	ND	ND	ND	0.25
AQ020205:1345NP4-1	2/2/05	13:45	0.45	0.0325	0.0675	ND	ND	ND	0.02	0.0075	ND	ND	ND	0.0075	0.0325	ND	ND	0.185	ND	ND	ND	ND	ND	0.80
AQ030205:1105NP4-1	3/2/05	11:05	0.35	0.0325	0.0725	ND	ND	ND	0.0175	0.005	ND	ND	ND	0.005	0.015	ND	ND	0.0825	ND	ND	ND	ND	ND	0.58
AQ040705:1430NP4-1	4/7/05	14:30	0.34	0.027	0.058	0.006	0.02	ND	0.029	0.012	0.003	ND	ND	0.006	0.053	ND	0.015	ND	ND	ND	ND	ND	ND	0.57
AQ050205:1405NP4-1	5/2/05	14:05	0.52	0.032	0.116	ND	ND	ND	0.024	0.008	ND	ND	ND	ND	0.024	ND	ND	0.04	ND	ND	ND	ND	ND	0.76
AQ062405:1240NP4-1	6/24/05	12:40	0.36	0.028	0.1	ND	ND	ND	0.074	0.046	0.004	ND	ND	ND	0.144	ND	0.054	0.16	ND	ND	ND	ND	ND	0.97
AQ070705:1400NP4-1	7/7/05	14:00	0.43	0.026	0.12	ND	ND	ND	0.044	ND	0.006	0.002	0.006	ND	0.19 ^u	ND	0.51 ^u	0.024	ND	0.001	ND	ND	ND	0.86
AQ080205:1400NP4-1	8/2/05	14:00	0.42	0.034	0.15	ND	ND	0.009	0.05	0.008	0.006	ND	0.007	0.006	0.017 ^v	ND	0.66 ^v	0.043	ND	ND	ND	ND	ND	0.93
AQ090805:900NP4-1	9/8/05	9:00	0.27	0.032	0.1	0.011	ND	0.016	0.079	0.039	0.025	0.013	0.003	ND	1.7 ^v	ND	0.021	0.038	0.01	0.004	ND	ND	ND	0.81
AQ100605:1230NP4-1	10/6/05	12:30	0.28	0.022	0.1	0.007	0.025	0.011	0.015	0.004	0.003	ND	0.002	0.005	0.036	ND	ND	0.032	ND	ND	ND	ND	ND	0.54
AQ111605:1130NP4-1	11/16/05	11:30	0.76	0.033	0.11	0.008	0.022	0.054	0.44	0.016	0.012	0.004	0.004	ND	0.05	ND	0.023	0.052	ND	0.002	ND	ND	ND	1.59
AQ120805:930NP4-1	12/8/05	9:30	0.34	0.016	0.079	0.006	0.02	0.032	0.014	0.003	0.003	ND	0.002	0.004	0.008 ^w	0.002	0.038	0.015	ND	0.001	ND	ND	ND	0.58

Midcarbon			Parameters (mg/m3)																	TOTAL VOCs			
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB		EB	VC	CT
AQ010405:1150NP4-2	1/4/05	11:50	0.004	ND	0.045	0.011	0.028	0.003	0.024	0.002	0.001	ND	ND	0.018	0.009	ND	0.015	0.028	ND	ND	ND	ND	ND
AQ020205:1350NP4-2	2/2/05	13:50	ND	ND	0.15	0.011	0.033	0.005	0.019	0.001	ND	ND	ND	0.018	0.019	ND	0.013	0.004	ND	ND	ND	ND	
AQ030205:1110NP4-2	3/2/05	11:10	ND	ND	0.14	0.009	0.022	0.004	0.016	0.002	0.002	ND	ND	0.011	0.01	ND	0.008	0.021	ND	ND	ND	ND	
AQ040705:1432NP4-2	4/7/05	14:32	0.004	ND	0.069	0.005	0.014	0.003	0.012	0.002	ND	ND	ND	0.006	0.05	ND	ND	0.026	ND	ND	ND	ND	
AQ050205:1410NP4-2	5/2/05	14:10	ND	ND	0.085	0.005	ND	0.003	0.016	0.001	ND	ND	ND	0.003	0.006	ND	0.005	0.01	ND	ND	ND	ND	
AQ062405:1241NP4-2	6/24/05	12:41	ND	ND	0.063	ND	ND	ND	0.071	0.023	0.005	ND	ND	0.007	0.096	ND	0.047	ND	ND	ND	ND	ND	
AQ070705:1415NP4-2	7/7/05	14:15	ND	ND	0.036	ND	ND	ND	0.036	0.006	0.002	ND	ND	ND	0.65 ^{1/}	ND	0.49 ^{1/}	0.11	ND	ND	ND	ND	
AQ080205:1405NP4-2	8/2/05	14:05	0.019	ND	0.05	0.019	ND	ND	0.051	0.006	0.007	ND	ND	0.007	0.029 ^{1/}	ND	0.72 ^{1/}	0.048	ND	0.002	ND	ND	
AQ090805:905NP4-2	9/8/05	9:05	0.008	ND	0.039	ND	ND	ND	0.049	0.002	0.024	0.012	ND	0.004	0.10 ^{1/}	ND	0.018	0.013	ND	0.003	ND	ND	
AQ100605:1232NP4-2	10/6/05	12:32	0.007	ND	0.1	0.01	0.028	0.009	0.013	0.001	0.003	ND	0.003	0.01	0.021	ND	ND	0.049	ND	ND	0.001	ND	
AQ111605:1132NP4-2	11/16/05	11:32	0.01	ND	0.058	0.004	0.015	0.004	0.013	0.002	0.002	ND	ND	0.005	0.017	ND	0.021	0.031	ND	ND	0.018	ND	
AQ120805:935NP4-2	12/8/05	9:35	0.003	ND	0.13	0.009	0.023	0.007	0.013	0.002	0.004	0.001	0.003	0.006	0.007 ^{1/}	ND	0.021	0.018	ND	0.001	0.003	ND	

Postcarbon			Parameters (mg/m3)																TOTAL VOCs				
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CT	
AQ010405:1155NP4-3	1/4/05	11:55	0.002	ND	ND	0.007	0.013	0.002	0.023	0.002	0.002	ND	0.001	ND	0.006	ND	0.015	0.008	ND	ND	ND	ND	ND
AQ020205:1355NP4-3	2/2/05	13:55	0.004	ND	ND	ND	ND	ND	0.021	0.002	ND	ND	ND	ND	0.023	ND	0.013	0.008	ND	ND	ND	ND	ND
AQ030205:1115NP4-3	3/2/05	11:15	ND	ND	0.023	0.009	0.031	ND	0.016	0.002	0.002	ND	0.001	0.012	0.008	ND	0.007	0.015	0.009	ND	ND	ND	ND
AQ040705:1434NP4-3	4/7/05	14:34	0.001	ND	0.02	0.006	0.016	ND	0.013	0.002	ND	ND	ND	0.015	0.008	ND	ND	0.015	ND	ND	ND	ND	ND
AQ050205:1415NP4-3	5/2/05	14:15	ND	ND	0.03	0.007	0.016	ND	0.019	0.01	0.0009	ND	ND	0.009	0.007	ND	0.012	0.002	ND	ND	ND	ND	ND
AQ062405:1242NP4-3	6/24/05	12:42	ND	ND	0.012	ND	ND	ND	0.035	0.002	0.002	ND	0.004	0.004	0.063	ND	0.022	0.054	ND	ND	ND	ND	ND
AQ070705:1420NP4-3	7/7/05	14:20	ND	ND	0.014	ND	ND	ND	0.038	0.004	0.003	ND	0.005	ND	0.23 ^{1/}	ND	0.45 ^{1/}	0.046	ND	ND	ND	ND	ND
AQ080205:1410NP4-3	8/2/05	14:10	ND	ND	ND	ND	ND	ND	0.068	0.007	0.007	ND	0.008	0.007	0.019 ^{1/}	ND	0.640 ^{1/}	0.046	ND	ND	ND	ND	ND
AQ090805:910NP4-3	9/8/05	9:10	ND	ND	0.016	ND	ND	ND	0.038	0.002	0.022	0.01	0.004	0.005	0.025 ^{1/}	ND	0.019	0.035	ND	0.002	ND	ND	ND
AQ100605:1234NP4-3	10/6/05	12:34	0.004	ND	0.014	0.004	0.009	0.009	0.012	0.002	0.002	ND	0.002	0.004	0.02	ND	ND	0.084	ND	ND	ND	ND	ND
AQ111605:1134NP4-3	11/16/05	11:34	0.003	ND	0.029	ND	0.014	ND	0.044	0.011	0.009	0.003	0.003	0.005	0.009 ^{2/}	ND	0.022	0.016	ND	0.002	ND	ND	ND
AQ120805:940NP4-3	12/8/05	9:40	ND	ND	0.075	0.009	0.028	0.004	0.013	0.002	0.003	0.0003	0.003	0.009	0.009	ND	0.025	0.02	ND	0.0008	ND	ND	ND

- Notes: 1. Methylene chloride and/or carbon disulfide concentrations in all three air samples collected during the July 7, August 9 and September 8, 2005 sampling events are greatly elevated due to suspected laboratory contamination. The methylene chloride concentration from the June 24, 2005 sampling event was used instead of the July 7, August 9 or September 8, 2005 methylene chloride concentrations to calculate the total VOCs for July, August and September 2005. The carbon disulfide concentration from the June 24, 2005 sampling event was used instead of the July 7 and August 9, 2005 carbon disulfide concentration to calculate the total VOCs for July and August 2005.
2. The methylene chloride concentration in the air samples collected on December 8, 2005 are suspected to be from laboratory contamination.

PCE - Trichloroethane
 TCE - Trichloroethene
 TCA - 1,1,1-Trichloroethane
 DCE - 1,1-Dichloroethane
 DCA - 1,1-Dichloroethane
 cis-DCE - cis-1,2-Dichloroethene
 CT - Carbon Tetrachloride
 BM - Bromomethane
 CB - Chlorobenzene
 EB - Ethylbenzene
 VC - Vinyl Chloride

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethane (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Acetone (ug/L)
	23-Jan-04	ND<1	ND<1	ND<1	NE	4.0	2.2	0.0098	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	NE	NE
	11-Feb-04	ND<1	ND<1	ND<1	ND<1	4.6	5.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	ND<1	ND<1	ND<1	ND<1	4.1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	ND<1	ND<1	ND<1	ND<1	2.9	6.1	0.0240	ND<0.02	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	ND<1	ND<1	ND<1	ND<1	5.6	6.8	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	6.1 *	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	2.0	3.4	0.0454	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	ND<1	ND<1	ND<1	ND<1	ND<1	3.1	0.0190	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	ND<1
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	8.4 *	ND<1	ND<1	6.9 *
	23-Jan-04	8.7	ND<1	ND<1	ND<1	ND<1	1.1	5.57	0.207	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	5.4	ND<1	ND<1	ND<1	ND<1	3.9	3.77	0.0748	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	4.9	ND<1	ND<1	ND<1	ND<1	3.3	0.343	0.318	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	4.4	ND<1	ND<1	ND<1	ND<1	2.8	5.59	0.224	ND<1	ND<1	ND<1	1.8 *	ND<1	ND<1	ND<1
	5-May-04	8.2	ND<1	ND<1	ND<1	ND<1	4.7	4.5	0.681	ND<1	ND<1	ND<1	5.6 *	ND<1	ND<1	ND<1
	14-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	52.5	1.03	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	6.5	ND<1	ND<1	ND<1	ND<1	1.3	4.88	0.704	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	NM
	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	1.5	4.78	0.213	ND<1	ND<1	ND<1	ND<1	2.1	1.5	ND<1
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	12.0	ND<1	1.0	ND<1	ND<1	ND<1	3.5	0.0511	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	7.7	1.1	ND<1	ND<1	ND<1	ND<1	0.28	0.0298	ND<1	ND<1	ND<1	7.3 *	ND<1	ND<1	5.6 *
	9-Aug-05	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	3.74	0.107	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	16	1.8	ND<1	ND<1	ND<1	ND<1	3.57	0.0704	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	15	2.1	ND<1	ND<1	ND<1	ND<1	6.1	0.0269	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	34	2.1	ND<1	ND<1	ND<1	ND<1	4.25	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethane (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Acetone (ug/L)
RW-3	23-Jan-04	2.2	6.9	3.2	ND<1	ND<1	NE	1.96	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	ND<1	3.6	2.2	ND<1	ND<1	ND<1	1.63	1.43	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	1.2	5.0	2.3	ND<1	ND<1	ND<1	3.34	0.542	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	28-Apr-04	1.3	8.8	4.4	ND<1	ND<1	ND<1	3.07	1.32	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	ND<1
	5-May-04	0.9	6.9	3.6	ND<1	ND<1	ND<1	2.07	1.96	ND<1	ND<1	ND<1	5.8*	ND<1	ND<1	ND<1
	30-Jun-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.619	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	2.4	6.1	2.6	ND<1	ND<1	ND<1	2.07	1.79	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	2.7	21	8.7	ND<1	ND<1	ND<1	1.91	0.42	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	2.2	12	5.0	ND<1	ND<1	ND<1	2.09	1.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.5	6.5	2.6	ND<1	ND<1	ND<1	1.87	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.77	0.489	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	3	13	5.0	ND<1	ND<1	ND<1	1.89	1.36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	46.1	0.539	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	2.2	7.7	2.8	ND<1	ND<1	ND<1	1.85	0.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	9.91	10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.01	0.649	ND<1	ND<1	ND<1	9.1*	ND<1	ND<1	6.9*
	9-Aug-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.50	0.973	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	1	3.6	1.2	ND<1	ND<1	ND<1	2.03	0.71	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-4	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	1.83	0.708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.11	0.556	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	270	5.9	ND<1	ND<1	ND<1	ND<1	3.56	0.48	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	170	6.9	14.0	ND<1	ND<1	ND<1	3.28	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	170	5.8	4.5	ND<1	ND<1	ND<1	1.61	0.0691	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.982	0.173	ND<1	ND<1	ND<1	2.1*	ND<1	ND<1	ND<1
	5-May-04	470	6.2	7.8	ND<1	ND<1	ND<1	7.08	2.33	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	ND<1
	30-Jun-04	110	3.8	26	ND<1	ND<1	ND<1	4.44	1.11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	110	3.2	29	ND<1	ND<1	ND<1	5.00	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	120	3.7	18	ND<1	ND<1	ND<1	2.98	ND<0.02	ND<1	ND<1	ND<1	ND<1	3.2	ND<1	ND<1
	7-Oct-04	94	ND<1	14	ND<1	ND<1	ND<1	3.65	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	130	4.2	11	ND<1	ND<1	ND<1	4.75	0.205	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	230	5.7	35	ND<1	ND<1	ND<1	1.90	1.62	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Apr-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	2-May-05	80	2.4	9.8	ND<1	ND<1	ND<1	3.77	0.0687	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Jun-05	74	2.6	ND<1	ND<1	ND<1	ND<1	9.95	0.287	ND<1	ND<1	ND<1	4.5*	ND<1	ND<1	ND<1
	14-Jul-05	37	ND<1	8.9	ND<1	ND<1	ND<1	3.22	0.0185	ND<1	ND<1	ND<1	9.4*	ND<1	ND<1	7.4*
	9-Aug-05	31	ND<1	ND<1	ND<1	ND<1	ND<1	2.49	0.111	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	45	ND<1	6	ND<1	ND<1	ND<1	3.47	0.173	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.0777	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Dec-05	64	2.0	1.5	ND<1	ND<1	ND<1	2.82	0.0302	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAP's	PCE (ug/L) 6	TCE (ug/L) 6	TCA (ug/L) 6	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (mg/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	1,1-Dichloro- ethane (ug/L) 6	cis-1,2-Dichloro- ethane (ug/L) 6	1,1-Dichloro- ethene (ug/L) 6	Methylene Chloride (ug/L) 6	Bromoform (ug/L) NE	Dibromochloro- methane (ug/L) NE	Acetone (ug/L) NE
RW-5	23-Jan-04	14	ND<1	ND<1	ND<1	0.9	4.0	0.05	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	14	ND<1	ND<1	ND<1	1.0	6.2	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	14	ND<1	ND<1	ND<1	ND<1	5.0	0.0852	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	18	ND<1	ND<1	ND<1	ND<1	6.1	0.147	0.015	ND<1	ND<1	ND<1	2*	ND<1	ND<1	ND<1
	5-May-04	38	0.8	3.2	ND<1	1.5	8.0	0.055	0.015	ND<1	ND<1	ND<1	6.4*	ND<1	ND<1	ND<1
	14-Jun-04	17	ND<1	ND<1	ND<1	ND<1	3.9	0.054	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	21	ND<1	ND<1	ND<1	ND<1	3.1	0.0254	0.0265	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	24	ND<1	ND<1	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.3	ND<1	ND<1
	7-Oct-04	16	ND<1	ND<1	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	1.8	1.4	ND<1
	3-Nov-04	18	ND<1	ND<1	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	28	ND<1	ND<1	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	12	ND<1	ND<1	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	14	ND<1	ND<1	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	9	ND<1	ND<1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	13	ND<1	ND<1	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	0.0358	ND<0.02	ND<1	ND<1	ND<1	9.5*	ND<1	ND<1	5.6*
	9-Aug-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0227	0.0303	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	8	ND<1	ND<1	ND<1	ND<1	ND<1	0.0185	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-6	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0482	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	0.0468	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	160	2.4	ND<1	ND<1	ND<1	ND<1	0.015	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	130	3.3	1.1	ND<1	ND<1	1.7	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	110	2.7	ND<1	ND<1	ND<1	1.6	0.077	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	110	2.9	1.3	ND<1	ND<1	2.6	0.016	ND<0.02	ND<1	ND<1	ND<1	1.8*	ND<1	ND<1	ND<1
	5-May-04	210	4.8	ND<1	ND<1	ND<1	3.2	0.719	ND<0.02	ND<1	ND<1	ND<1	5.9*	ND<1	ND<1	ND<1
	14-Jun-04	92	3.6	1.3	ND<1	ND<1	2.1	0.151	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	100	2.8	1.2	ND<1	ND<1	1.7	0.437	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<1
	7-Oct-04	94	ND<1	ND<1	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.9	2.0	ND<1
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	2.5	0.011	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	200	3.8	16	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	69	1.6	13.0	ND<1	ND<1	ND<1	0.087	0.0195	ND<1	ND<1	ND<1	2.1	ND<1	ND<1	ND<1
	14-Jul-05	64	1.6	9.5	ND<1	ND<1	ND<1	0.0406	ND<0.02	ND<1	ND<1	ND<1	7.2*	ND<1	ND<1	7*
	9-Aug-05	49	ND<1	12.0	ND<1	ND<1	ND<1	0.088	0.0366	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	100	1.6	12.0	ND<1	ND<1	ND<1	1.3	0.0143	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	68	ND<1	ND<1	ND<1	ND<1	ND<1	0.144	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	100	2.1	20.0	ND<1	ND<1	ND<1	0.139	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethane (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Acetone (ug/L)
RW-7	23-Jan-04	190	3.7	ND<1	ND<1	ND<1	NE	0.0089	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	100	2.9	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	100	3.0	ND<1	ND<1	ND<1	ND<1	0.0205	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	79	2.5	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	2.2*	ND<1	ND<1	ND<1
	5-May-04	130	4.0	ND<1	ND<1	ND<1	ND<1	0.012	ND<0.02	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<1
	14-Jun-04	59	2.7	ND<1	ND<1	ND<1	ND<1	0.018	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	55	2.1	ND<1	ND<1	ND<1	ND<1	0.791	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.6	ND<1	ND<1
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	0.0272	0.00876	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	22	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	32	1.0	4.7	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	32	ND<1	2.2	ND<1	ND<1	ND<1	0.0753	0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	9-Aug-05	31	ND<1	6.2	ND<1	ND<1	ND<1	0.0155	ND<0.02	ND<1	ND<1	ND<1	8.7*	ND<1	ND<1	7.2*
	8-Sep-05	39	ND<1	3.4	ND<1	ND<1	ND<1	0.0462	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.536	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-8	8-Dec-05	70	ND<1	12.0	ND<1	ND<1	ND<1	0.253	ND<0.02	4.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	23-Jan-04	16	2.2	4.1	ND<1	ND<1	ND<1	9.73	2.72	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	11-Feb-04	15	2.2	4.7	ND<1	ND<1	ND<1	8.74	0.19	4.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-04	22	2.7	4.3	ND<1	ND<1	ND<1	11.9	0.23	3.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	14	2.0	6.2	ND<1	ND<1	ND<1	10.7	0.14	5.7	ND<1	ND<1	1.9*	ND<1	ND<1	ND<1
	5-May-04	27	4.1	8.3	ND<1	ND<1	ND<1	8.77	0.21	8.7	ND<1	ND<1	8.5*	ND<1	ND<1	ND<1
	14-Jun-04	10	2.4	5.8	ND<1	ND<1	ND<1	9.15	0.10	4.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04 **	3	1.0	3.7	ND<1	ND<1	ND<1	4.18	0.21	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	26-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	28.8	0.2	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	10.6	0.3	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	16	ND<1	2.2	ND<1	ND<1	ND<1	15.6	0.1	15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	7.33	0.07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	2.7	ND<1	5.8	ND<1	ND<1	ND<1	7.06	0.33	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	2.6	ND<1	3.4	ND<1	ND<1	ND<1	8.33	0.02	ND<1	ND<1	ND<1	8.5*	ND<1	ND<1	8.2*
	9-Aug-05	1.8	ND<1	2.9	ND<1	ND<1	ND<1	0.24	0.06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	2.9	ND<1	4.2	ND<1	ND<1	ND<1	7.53	0.26	2.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	7.65	0.11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	5.0	ND<1	ND<1	ND<1	5.19	0.02	3.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethane (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Bromoform (ug/L)	Dibromochloromethane (ug/L)	Acetone (ug/L)
RW-9	23-Jan-04	2.3	2.2	13	ND<1	ND<1	NE	0.638	0.029	1.8	ND<1	1.5	ND<1	ND<1	NE	ND<1
	11-Feb-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	ND<1
	8-Mar-04	ND<1	2.2	12	ND<1	ND<1	ND<1	1.24	0.222	3.7	ND<1	1.3	ND<1	ND<1	ND<1	ND<1
	14-Apr-04	5.6	1.7	10	ND<1	ND<1	ND<1	2.65	1.22	5.9	ND<1	2.0	2.0*	ND<1	ND<1	ND<1
	5-May-04	3.7	1.7	13	ND<1	ND<1	ND<1	2.58	1.83	6.7	ND<1	1.7	7.1*	ND<1	ND<1	ND<1
	14-Jun-04	1.8	1.9	8.2	ND<1	ND<1	ND<1	3.03	1.11	3.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-04	3.4	1.3	5.1	ND<1	ND<1	ND<1	2.6	1.95	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	28-Aug-04 ***	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	1.9	ND<1	ND<1	ND<1	1.6	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0596	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	5.8	ND<1	ND<1	ND<1	1.38	0.149	0.9	ND<1	1.2	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	3.4	ND<1	3.1	ND<1	ND<1	ND<1	2.55	0.238	ND<1	ND<1	ND<1	6.9 *	ND<1	ND<1	7.3 *
	9-Aug-05	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	0.994	0.0734	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	1.2	ND<1	2.0	ND<1	ND<1	ND<1	3.64	0.161	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.31	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	2.9	ND<1	ND<1	ND<1	2.01	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

ND: Not detected
 <#: Less than method detection limit
 ug/L: Micrograms per liter
 -: Not analyzed
 ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site.
 Bold values indicate an exceedance of the ARAR standard established for the site.

PCE: Tetrachloroethylene
 TCE: Trichloroethylene
 TCA: 1,1,1-Trichloroethane
 1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene
 1,2-DCE: 1,2-Dichloroethene
 MTBE: Methyl Tertiary Butyl Ether
 NM: Not Measured


ARAR goal was not established for this compound by the EPA.
 *Concentrations with an asterisk following them are due to laboratory contamination.

GRAPHS

GRAPH 1


GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
 (December 1, 2005 through December 31, 2005)



GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK


RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER



GRAPH 3

**GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK**

RECOVERY WELL PCE CONCENTRATION FOR SELECT RECOVERY WELLS



APPENDIX I
DECEMBER 2005 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, December 22, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0512128

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 12/13/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0512128**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0512128-01A	WQ120805:945 NP2-6		12/8/2005	12/13/2005
0512128-01B	WQ120805:945 NP2-6		12/8/2005	12/13/2005
0512128-01C	WQ120805:945 NP2-6		12/8/2005	12/13/2005
0512128-02A	WQ120805:950 NP2-7		12/8/2005	12/13/2005
0512128-02B	WQ120805:950 NP2-7		12/8/2005	12/13/2005
0512128-02C	WQ120805:950 NP2-7		12/8/2005	12/13/2005
0512128-03A	WQ120805:955 NP2-10		12/8/2005	12/13/2005
0512128-03B	WQ120805:955 NP2-10		12/8/2005	12/13/2005
0512128-03C	WQ120805:955 NP2-10		12/8/2005	12/13/2005

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ120805:945 NP2-6
Lab Order: 0512128 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512128-01A **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,1,1-Trichloroethane	5.7	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,1-Dichloroethane	1.8	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
2-Butanone	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
2-Hexanone	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Acetone	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Benzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Bromobenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Bromoform	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Bromomethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Chloroethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM

Qualifiers:
 * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ120805:945 NP2-6
 Lab Order: 0512128 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512128-01A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Chloromethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
cis-1,2-Dichloroethene	3.1	1.0		µg/L	1	12/17/2005 9:51:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Dibromomethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/17/2005 9:51:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Methylene chloride	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Naphthalene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
o-Xylene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Styrene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Tetrachloroethene	29	1.0		µg/L	1	12/17/2005 9:51:00 AM
Toluene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Trichloroethene	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/17/2005 9:51:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/17/2005 9:51:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ120805:945 NP2-6
Lab Order:	0512128	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512128-01B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	1.54	0.0200		mg/L	1	12/21/2005 10:53:01 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ120805:945 NP2-6
Lab Order:	0512128	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512128-01C	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0193	0.0200	J	mg/L	1	12/21/2005 10:37:27 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ120805:950 NP2-7
 Lab Order: 0512128 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512128-02A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
2-Butanone	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
2-Hexanone	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Acetone	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Benzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Bromobenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Bromoform	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Bromomethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Chloroethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ120805:950 NP2-7
Lab Order: 0512128 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512128-02A **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Chloromethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Dibromomethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/17/2005 10:30:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Methylene chloride	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Naphthalene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
o-Xylene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Styrene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Toluene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Trichloroethene	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/17/2005 10:30:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/17/2005 10:30:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ120805:950 NP2-7
Lab Order:	0512128	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512128-02B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	1.93	0.0200		mg/L	1	12/21/2005 10:59:30 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ120805:950 NP2-7
Lab Order:	0512128	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512128-02C	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0491	0.0200		mg/L	1	12/21/2005 10:55:56 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ120805:955 NP2-10
 Lab Order: 0512128 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512128-03A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
2-Butanone	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
2-Hexanone	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Acetone	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Benzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Bromobenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Bromoform	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Bromomethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Chloroethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ120805:955 NP2-10
Lab Order: 0512128 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512128-03A **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Chloromethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Dibromomethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/17/2005 5:47:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Methylene chloride	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Naphthalene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
o-Xylene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Styrene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Toluene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Trichloroethene	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/17/2005 5:47:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/17/2005 5:47:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ120805:955 NP2-10
Lab Order:	0512128	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512128-03B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	1.36	0.0200		mg/L	1	12/21/2005 11:04:40 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ120805:955 NP2-10
Lab Order: 0512128 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512128-03C **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0632	E200.7 0.0200		(SW3005A) mg/L	1	Analyst: JP 12/21/2005 11:02:17 AM
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	150	E160.1 1.0		mg/L	1	Analyst: BP 12/14/2005

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, December 21, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110
FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0512129

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 7 sample(s) on 12/13/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0512129**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0512129-01A	GWQ120805:800 NP1-1-2		12/8/2005	12/13/2005
0512129-01B	GWQ120805:800 NP1-1-2		12/8/2005	12/13/2005
0512129-01C	GWQ120805:800 NP1-1-2		12/8/2005	12/13/2005
0512129-01D	GWQ120805:800 NP1-1-2		12/8/2005	12/13/2005
0512129-02A	GWQ120805:810 NP1-1-3		12/8/2005	12/13/2005
0512129-02B	GWQ120805:810 NP1-1-3		12/8/2005	12/13/2005
0512129-02C	GWQ120805:810 NP1-1-3		12/8/2005	12/13/2005
0512129-02D	GWQ120805:810 NP1-1-3		12/8/2005	12/13/2005
0512129-03A	GWQ120805:830 NP1-1-5		12/8/2005	12/13/2005
0512129-03B	GWQ120805:830 NP1-1-5		12/8/2005	12/13/2005
0512129-03C	GWQ120805:830 NP1-1-5		12/8/2005	12/13/2005
0512129-03D	GWQ120805:830 NP1-1-5		12/8/2005	12/13/2005
0512129-04A	GWQ120805:840 NP1-1-6		12/8/2005	12/13/2005
0512129-04B	GWQ120805:840 NP1-1-6		12/8/2005	12/13/2005
0512129-04C	GWQ120805:840 NP1-1-6		12/8/2005	12/13/2005
0512129-04D	GWQ120805:840 NP1-1-6		12/8/2005	12/13/2005
0512129-05A	GWQ120805:850 NP1-1-7		12/8/2005	12/13/2005
0512129-05B	GWQ120805:850 NP1-1-7		12/8/2005	12/13/2005
0512129-05C	GWQ120805:850 NP1-1-7		12/8/2005	12/13/2005
0512129-05D	GWQ120805:850 NP1-1-7		12/8/2005	12/13/2005
0512129-06A	GWQ120805:900 NP1-1-8		12/8/2005	12/13/2005
0512129-06B	GWQ120805:900 NP1-1-8		12/8/2005	12/13/2005
0512129-06C	GWQ120805:900 NP1-1-8		12/8/2005	12/13/2005
0512129-06D	GWQ120805:900 NP1-1-8		12/8/2005	12/13/2005
0512129-07A	GWQ120805:910 NP1-1-9		12/8/2005	12/13/2005
0512129-07B	GWQ120805:910 NP1-1-9		12/8/2005	12/13/2005
0512129-07C	GWQ120805:910 NP1-1-9		12/8/2005	12/13/2005
0512129-07D	GWQ120805:910 NP1-1-9		12/8/2005	12/13/2005



AMERICAN
ANALYTICAL
LABORATORIES

56 TOLEDO STREET • FARMINGDALE, NY 11735 • (516) 454-6100 • FAX (516) 454-8027

NYSDOH ELAP 11418
AIHA PAT, LPAT 15668
CTDOH PH-0205

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS				CONTACT:		DATE		TIME		SAMPLE(S) SEALED		YES/NO							
LBC 126 Monroe Turnpike Trembul, CT 06611				Mark K Goldberg		Rob Dren		12/2/05		9:30 am		☒							
PROJECT LOCATION:				SAMPLE # - LOCATION		ANALYSIS REQUIRED		SAMPLER (SIGNATURE)		CORRECT CONTAINER(S)		☒							
Rowe								VOC, SVOC METALS FREESTYLE TOTAL + FREE TURBIDITY TDS											
LABORATORY ID #	MATRIX	TYPE	PRES.	SAMPLE # - LOCATION		ANALYSIS REQUIRED		SAMPLER (SIGNATURE)		CORRECT CONTAINER(S)		☒							
0572129-1A2D	L	G	ACL HMB	GWR120805, 800 MPI-1-2				VOC, SVOC METALS FREESTYLE TOTAL + FREE TURBIDITY TDS											
2A2CD				810 MPI-1-3															
3A2CD				830 MPI-1-5															
4A2CD				840 MPI-1-6															
5A2CD				850 MPI-1-7															
6A2CD				900 MPI-1-8															
7A2CD				910 MPI-1-9															
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIFE; P=PAINT CHIPS; B=BULK MATERIAL												COMMENTS / INSTRUCTIONS							
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON												TURNAROUND REQUIRED:							
RELINQUISHED BY (SIGNATURE)												NORMAL ☒ STAT ☐ BY 1 / 1		RECEIVED BY LAB (SIGNATURE)		DATE		PRINTED NAME	
Mark M. Goldberg												12/2/05		17:00		12/2/05		R. Antonio	
RELINQUISHED BY (SIGNATURE)												DATE		TIME		DATE		TIME	
Mark M. Goldberg												12/2/05		17:00		12/2/05		R. Antonio	

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ120805:800 NP1-1-2
Lab Order: 0512129 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512129-01A **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ120805:800 NP1-1-2
 Lab Order: 0512129 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512129-01A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
cis-1,2-Dichloroethene	25	1.0		µg/L	1	12/16/2005 5:12:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 5:12:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Tetrachloroethene	34	1.0		µg/L	1	12/16/2005 5:12:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Trichloroethene	2.1	1.0		µg/L	1	12/16/2005 5:12:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 5:12:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 5:12:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:800 NP1-1-2
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-01B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	4.25	0.0200		mg/L	1	12/20/2005 2:31:18 PM
Manganese	1.00	0.0200		mg/L	1	12/20/2005 2:31:18 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:800 NP1-1-2
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-01C	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	12/20/2005 2:29:11 PM
Manganese	0.921	0.0200		mg/L	1	12/20/2005 2:29:11 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BP
Total Dissolved Solids (Residue, Filterable)	140	1.0		mg/L	1	12/14/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:800 NP1-1-2
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-01D	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	42.1	1.00		mg/L	1	12/20/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00	H	NTU	1	12/15/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ120805:810 NP1-1-3
Lab Order: 0512129 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512129-02A **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ120805:810 NP1-1-3
Lab Order: 0512129 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512129-02A **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 5:47:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Trichloroethene	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 5:47:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 5:47:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:810 NP1-1-3
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-02B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	2.11	0.0200		mg/L	1	12/20/2005 2:43:06 PM
Manganese	0.129	0.0200		mg/L	1	12/20/2005 2:43:06 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:810 NP1-1-3
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-02C	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.556	0.0200		mg/L	1	12/20/2005 2:33:52 PM
Manganese	0.121	0.0200		mg/L	1	12/20/2005 2:33:52 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BP
Total Dissolved Solids (Residue, Filterable)	130	1.0		mg/L	1	12/14/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:810 NP1-1-3
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-02D	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	32.3	1.00		mg/L	1	12/20/2005
TURBIDITY						Analyst: KK
Turbidity	4.60	1.00	H	NTU	1	12/15/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ120805:830 NP1-1-5
 Lab Order: 0512129 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512129-03A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ120805:830 NP1-1-5
Lab Order: 0512129 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512129-03A **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 6:23:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Tetrachloroethene	2.4	1.0		µg/L	1	12/16/2005 6:23:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Trichloroethene	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 6:23:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 6:23:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:830 NP1-1-5
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-03B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.0468	0.0200		mg/L	1	12/20/2005 2:47:58 PM
Manganese	U	0.0200		mg/L	1	12/20/2005 2:47:58 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:830 NP1-1-5
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-03C	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	12/20/2005 2:45:52 PM
Manganese	U	0.0200		mg/L	1	12/20/2005 2:45:52 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BP
Total Dissolved Solids (Residue, Filterable)	72	1.0		mg/L	1	12/14/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:830 NP1-1-5
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-03D	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	28.9	1.00		mg/L	1	12/20/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00	H	NTU	1	12/15/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ120805:840 NP1-1-6
 Lab Order: 0512129 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512129-04A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,1,1-Trichloroethane	20	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ120805:840 NP1-1-6
Lab Order: 0512129 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512129-04A **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 6:59:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Tetrachloroethene	100	1.0		µg/L	1	12/16/2005 6:59:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Trichloroethene	2.1	1.0		µg/L	1	12/16/2005 6:59:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 6:59:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 6:59:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:840 NP1-1-6
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-04B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.139	0.0200		mg/L	1	12/20/2005 2:52:28 PM
Manganese	0.195	0.0200		mg/L	1	12/20/2005 2:52:28 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:840 NP1-1-6
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-04C	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	12/20/2005 2:50:11 PM
Manganese	0.191	0.0200		mg/L	1	12/20/2005 2:50:11 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BP
Total Dissolved Solids (Residue, Filterable)	150	1.0		mg/L	1	12/14/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:840 NP1-1-6
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-04D	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	30.6	1.00		mg/L	1	12/20/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	U	1.00	H	NTU	1	12/15/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ120805:850 NP1-1-7
 Lab Order: 0512129 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512129-05A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,1,1-Trichloroethane	12	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,1-Dichloroethane	4.2	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ120805:850 NP1-1-7
 Lab Order: 0512129 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512129-05A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 7:49:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Tetrachloroethene	70	1.0		µg/L	1	12/16/2005 7:49:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Trichloroethene	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 7:49:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 7:49:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:850 NP1-1-7
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-05B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	0.253	0.0200		mg/L	1	12/20/2005 2:57:04 PM
Manganese	0.0741	0.0200		mg/L	1	12/20/2005 2:57:04 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:850 NP1-1-7
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-05C	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	12/20/2005 2:54:51 PM
Manganese	0.0704	0.0200		mg/L	1	12/20/2005 2:54:51 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BP
Total Dissolved Solids (Residue, Filterable)	120	1.0		mg/L	1	12/14/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:850 NP1-1-7
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-05D	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						
Hardness, Calcium/Magnesium (As CaCO ₃)	35.1	1.00	M2340 B	mg/L	1	Analyst: JP 12/20/2005
TURBIDITY						
Turbidity	U	1.00	E180.1 H	NTU	1	Analyst: KK 12/15/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** GWQ120805:900 NP1-1-8
Lab Order: 0512129 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/8/2005
Lab ID: 0512129-06A **Date Received:** 12/13/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,1,1-Trichloroethane	5.0	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,1-Dichloroethane	3.2	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ120805:900 NP1-1-8
 Lab Order: 0512129 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512129-06A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 8:26:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Tetrachloroethene	2.4	1.0		µg/L	1	12/16/2005 8:26:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Trichloroethene	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 8:26:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 8:26:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:900 NP1-1-8
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-06B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	5.19	0.0200		mg/L	1	12/20/2005 3:04:19 PM
Manganese	0.678	0.0200		mg/L	1	12/20/2005 3:04:19 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:900 NP1-1-8
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-06C	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0211	0.0200		mg/L	1	12/20/2005 2:59:56 PM
Manganese	0.649	0.0200		mg/L	1	12/20/2005 2:59:56 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BP
Total Dissolved Solids (Residue, Filterable)	92	1.0		mg/L	1	12/14/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:900 NP1-1-8
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-06D	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	22.3	1.00		mg/L	1	12/20/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	3.80	1.00	H	NTU	1	12/15/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: GWQ120805:910 NP1-1-9
 Lab Order: 0512129 Tag Number:
 Project: Rowe Industries Collection Date: 12/8/2005
 Lab ID: 0512129-07A Date Received: 12/13/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,1,1-Trichloroethane	2.9	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ120805:910 NP1-1-9

Lab Order: 0512129

Tag Number:

Project: Rowe Industries

Collection Date: 12/8/2005

Lab ID: 0512129-07A

Date Received: 12/13/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 9:04:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Trichloroethene	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 9:04:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 9:04:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:910 NP1-1-9
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-07B	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	2.01	0.0200		mg/L	1	12/20/2005 3:19:38 PM
Manganese	1.09	0.0200		mg/L	1	12/20/2005 3:19:38 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:910 NP1-1-9
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-07C	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0240	0.0200		mg/L	1	12/20/2005 3:09:38 PM
Manganese	1.08	0.0200		mg/L	1	12/20/2005 3:09:38 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BP
Total Dissolved Solids (Residue, Filterable)	80	1.0		mg/L	1	12/14/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 21-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ120805:910 NP1-1-9
Lab Order:	0512129	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/8/2005
Lab ID:	0512129-07D	Date Received:	12/13/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	11.9	1.00		mg/L	1	12/20/2005
TURBIDITY						Analyst: KK
Turbidity	2.50	1.00	H	NTU	1	12/15/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

Page 35 of 35

American Analytical Laboratories, LLC.

REMIT TO: **American Analytical Laboratories, LLC.**
Accounts Receivable
188 Long Island Avenue
Wyandanch, NY 11798
TEL: (631) 586-2000

INVOICE

INV DATE: *December 22, 2005*

Print DATE: *December 22, 2005*

Invoice No: 385605

Invoice TO: **Leggette Brashears & Graham Inc.**
126 Monroe Turnpike
Trumbull, CT 06611

Attn: **Mark Goldberg**
Phone: **(203) 452-3110**

Work Order: **0512149**

Order Name **Rowe**

PO Number:

Date Received **12/14/2005**

Item	Remarks	Matrix	Qty	Unit Price	Mult	Quoted	Test Total
DISSOLVED IRON, MANGANESE		Liquid	1	\$60.00	1	\$60.00	\$60.00
HARDNESS		Liquid	1	\$20.00	1	\$20.00	\$20.00
TOTAL DISSOLVED SOLIDS		Liquid	1	\$15.00	1	\$15.00	\$15.00
TOTAL IRON, MANGANESE		Liquid	1	\$50.00	1	\$50.00	\$50.00
TURBIDITY		Liquid	1	\$15.00	1	\$15.00	\$15.00
VOLATILE SW-846 8260 PLUS MTBE & FREQ		Liquid	1	\$100.00	1	\$100.00	\$100.00

Subtotal: \$260.00

Discount: 0.00%

Surcharge: 0.00%

Misc Charges: \$0.00

Payment Received: \$0.00

INVOICE Total: \$260.00

Interest charge 1.5% per month - 15 days after date on invoice





NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, December 22, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe

Order No.: 0512149

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 1 sample(s) on 12/14/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe**Lab Order:** 0512149**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0512149-01A	GWQ121205:830 NP1-1-4		12/12/2005	12/14/2005
0512149-01B	GWQ121205:830 NP1-1-4		12/12/2005	12/14/2005
0512149-01C	GWQ121205:830 NP1-1-4		12/12/2005	12/14/2005
0512149-01D	GWQ121205:830 NP1-1-4		12/12/2005	12/14/2005

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ121205:830 NP1-1-4

Lab Order: 0512149

Tag Number:

Project: Rowe

Collection Date: 12/12/2005

Lab ID: 0512149-01A

Date Received: 12/14/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1				SW8260B	Analyst: LDS	
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,1,1-Trichloroethane	1.5	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
2-Butanone	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
2-Hexanone	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Acetone	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Benzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Bromobenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Bromoform	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Bromomethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Chloroethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected
 Page 1 of 5

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ121205:830 NP1-1-4

Lab Order: 0512149

Tag Number:

Project: Rowe

Collection Date: 12/12/2005

Lab ID: 0512149-01A

Date Received: 12/14/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Chloromethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Dibromomethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/17/2005 9:15:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Methylene chloride	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Naphthalene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
o-Xylene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Styrene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Tetrachloroethene	64	1.0		µg/L	1	12/17/2005 9:15:00 AM
Toluene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Trichloroethene	2.0	1.0		µg/L	1	12/17/2005 9:15:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/17/2005 9:15:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/17/2005 9:15:00 AM

Qualifiers:

* Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ121205:830 NP1-1-4**Lab Order:** 0512149**Tag Number:****Project:** Rowe**Collection Date:** 12/12/2005**Lab ID:** 0512149-01B**Date Received:** 12/14/2005**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON,MANGANESE		E200.7		(SW3010A)		Analyst: JP
Iron	2.82	0.0200		mg/L	1	12/21/2005 12:44:50 PM
Manganese	1.46	0.0200		mg/L	1	12/21/2005 12:44:50 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ121205:830 NP1-1-4**Lab Order:** 0512149**Tag Number:****Project:** Rowe**Collection Date:** 12/12/2005**Lab ID:** 0512149-01C**Date Received:** 12/14/2005**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON,MANGANESE		E200.7		(SW3005A)		Analyst: JP
Iron	0.0302	0.0200		mg/L	1	12/21/2005 12:42:42 PM
Manganese	1.47	0.0200		mg/L	1	12/21/2005 12:42:42 PM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ121205:830 NP1-1-4**Lab Order:** 0512149**Tag Number:****Project:** Rowe**Collection Date:** 12/12/2005**Lab ID:** 0512149-01D**Date Received:** 12/14/2005**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	38.8	1.00		mg/L	1	12/21/2005
TURBIDITY		E180.1				Analyst: KK
Turbidity	3.90	1.00		NTU	1	12/14/2005
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BP
Total Dissolved Solids (Residue, Filterable)	430	1.0		mg/L	1	12/19/2005

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, December 22, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110
FAX (203) 452-3111

RE: Rowe

Order No.: 0512148

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 12/14/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe**Lab Order:** 0512148**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0512148-01A	WQ121205:800 NP2-6		12/12/2005	12/14/2005
0512148-01B	WQ121205:800 NP2-6		12/12/2005	12/14/2005
0512148-01C	WQ121205:800 NP2-6		12/12/2005	12/14/2005
0512148-02A	WQ121205:805 NP2-7		12/12/2005	12/14/2005
0512148-02B	WQ121205:805 NP2-7		12/12/2005	12/14/2005
0512148-02C	WQ121205:805 NP2-7		12/12/2005	12/14/2005
0512148-03A	WQ121205:810 NP2-10		12/12/2005	12/14/2005
0512148-03B	WQ121205:810 NP2-10		12/12/2005	12/14/2005
0512148-03C	WQ121205:810 NP2-10		12/12/2005	12/14/2005

56 TOLEDO STREET • FARMINGDALE, NY 11735 • (516) 454-6100 • FAX (516) 454-8027

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ121205:800 NP2-6
Lab Order: 0512148 **Tag Number:**
Project: Rowe **Collection Date:** 12/12/2005
Lab ID: 0512148-01A **Date Received:** 12/14/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,1,1-Trichloroethane	5.7	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,1-Dichloroethane	1.5	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ121205:800 NP2-6**Lab Order:** 0512148**Tag Number:****Project:** Rowe**Collection Date:** 12/12/2005**Lab ID:** 0512148-01A**Date Received:** 12/14/2005**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
cis-1,2-Dichloroethene	1.6	1.0		µg/L	1	12/16/2005 9:41:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 9:41:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Tetrachloroethene	30	1.0		µg/L	1	12/16/2005 9:41:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Trichloroethene	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 9:41:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 9:41:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ121205:800 NP2-6
Lab Order:	0512148	Tag Number:	
Project:	Rowe	Collection Date:	12/12/2005
Lab ID:	0512148-01B	Date Received:	12/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	2.04	0.0200		mg/L	1	12/21/2005 12:09:47 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ121205:800 NP2-6
Lab Order:	0512148	Tag Number:	
Project:	Rowe	Collection Date:	12/12/2005
Lab ID:	0512148-01C	Date Received:	12/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0314	0.0200		mg/L	1	12/21/2005 12:07:42 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ121205:805 NP2-7
 Lab Order: 0512148 Tag Number:
 Project: Rowe Collection Date: 12/12/2005
 Lab ID: 0512148-02A Date Received: 12/14/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ121205:805 NP2-7
 Lab Order: 0512148 Tag Number:
 Project: Rowe Collection Date: 12/12/2005
 Lab ID: 0512148-02A Date Received: 12/14/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 10:17:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Trichloroethene	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 10:17:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 10:17:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.**Date:** 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ121205:805 NP2-7
Lab Order:	0512148	Tag Number:	
Project:	Rowe	Collection Date:	12/12/2005
Lab ID:	0512148-02B	Date Received:	12/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	7.17	0.0200		mg/L	1	12/21/2005 12:33:08 PM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ121205:805 NP2-7
Lab Order: 0512148 **Tag Number:**
Project: Rowe **Collection Date:** 12/12/2005
Lab ID: 0512148-02C **Date Received:** 12/14/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.126	0.0200		mg/L	1	12/21/2005 12:12:58 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ121205:810 NP2-10
Lab Order:	0512148	Tag Number:	
Project:	Rowe	Collection Date:	12/12/2005
Lab ID:	0512148-03A	Date Received:	12/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
2-Butanone	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
2-Hexanone	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Acetone	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Benzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Bromobenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Bromoform	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Bromomethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Chloroethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ121205:810 NP2-10
Lab Order:	0512148	Tag Number:	
Project:	Rowe	Collection Date:	12/12/2005
Lab ID:	0512148-03A	Date Received:	12/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Chloromethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Dibromomethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/16/2005 10:54:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Methylene chloride	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Naphthalene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
o-Xylene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Styrene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Toluene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Trichloroethene	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/16/2005 10:54:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/16/2005 10:54:00 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ121205:810 NP2-10
Lab Order:	0512148	Tag Number:	
Project:	Rowe	Collection Date:	12/12/2005
Lab ID:	0512148-03B	Date Received:	12/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		(SW3010A)		Analyst: JP
Iron	8.65	0.0200		mg/L	1	12/21/2005 12:38:43 PM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 22-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ121205:810 NP2-10
Lab Order:	0512148	Tag Number:	
Project:	Rowe	Collection Date:	12/12/2005
Lab ID:	0512148-03C	Date Received:	12/14/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.214	0.0200		mg/L	1	12/21/2005 12:35:46 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: BP
Total Dissolved Solids (Residue, Filterable)	260	1.0		mg/L	1	12/19/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, December 29, 2005

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe

Order No.: 0512250

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 12/23/2005 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe**Lab Order:** 0512250**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0512250-01A	WQ122105:830 NP2-6		12/21/2005	12/23/2005
0512250-01B	WQ122105:830 NP2-6		12/21/2005	12/23/2005
0512250-01C	WQ122105:830 NP2-6		12/21/2005	12/23/2005
0512250-02A	WQ122105:835 NP2-7		12/21/2005	12/23/2005
0512250-02B	WQ122105:835 NP2-7		12/21/2005	12/23/2005
0512250-02C	WQ122105:835 NP2-7		12/21/2005	12/23/2005
0512250-03A	WQ122105:840 NP2-10		12/21/2005	12/23/2005
0512250-03B	WQ122105:840 NP2-10		12/21/2005	12/23/2005
0512250-03C	WQ122105:840 NP2-10		12/21/2005	12/23/2005



AMERICAN
ANALYTICAL
LABORATORY

AMERICAN
ANALYTICAL
LABORATORIES

NYSDOH	ELAP	11418
AIHA	PAT, LPAT	15668
CTDOH	PH-0205	

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT: Leggette Brashears & Graham Inc.

Project: Rowe

Lab Order: 0512250

CASE NARRATIVE

Samples were analyzed using the methods outlined in the following references:

Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW846, 3rd Edition and as defined throughout the text of the report.

All method blanks, laboratory spikes, and/or matrix spikes met quality assurance objectives. The presence of methylene chloride can be attributed to laboratory contamination as denoted by the "B" qualifier.

No analytical problems were encountered.



**AMERICAN
ANALYTICAL
LABORATORIES**

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122105:830 NP2-6
Lab Order: 0512250 **Tag Number:**
Project: Rowe **Collection Date:** 12/21/2005
Lab ID: 0512250-01A **Date Received:** 12/23/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: SB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,1,1-Trichloroethane	5.6	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
2-Butanone	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
2-Hexanone	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Acetone	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Benzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Bromobenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Bromoform	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Bromomethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Chloroethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122105:830 NP2-6
Lab Order: 0512250 **Tag Number:**
Project: Rowe **Collection Date:** 12/21/2005
Lab ID: 0512250-01A **Date Received:** 12/23/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Chloromethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Dibromomethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/24/2005 6:34:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Methylene chloride	9.5	1.0	B	µg/L	1	12/24/2005 6:34:00 AM
Naphthalene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
o-Xylene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Styrene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Tetrachloroethene	21	1.0		µg/L	1	12/24/2005 6:34:00 AM
Toluene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Trichloroethene	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/24/2005 6:34:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/24/2005 6:34:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122105:830 NP2-6
Lab Order:	0512250	Tag Number:	
Project:	Rowe	Collection Date:	12/21/2005
Lab ID:	0512250-01B	Date Received:	12/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	1.85	0.0200		mg/L	1	12/29/2005 10:30:34 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122105:830 NP2-6
Lab Order:	0512250	Tag Number:	
Project:	Rowe	Collection Date:	12/21/2005
Lab ID:	0512250-01C	Date Received:	12/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	U	0.0200		mg/L	1	12/29/2005 10:27:24 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ122105:835 NP2-7
 Lab Order: 0512250 Tag Number:
 Project: Rowe Collection Date: 12/21/2005
 Lab ID: 0512250-02A Date Received: 12/23/2005 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: SB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
2-Butanone	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
2-Hexanone	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Acetone	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Benzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Bromobenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Bromoform	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Bromomethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Chloroethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ122105:835 NP2-7

Lab Order: 0512250

Tag Number:

Project: Rowe

Collection Date: 12/21/2005

Lab ID: 0512250-02A

Date Received: 12/23/2005

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Chloromethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Dibromomethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/24/2005 8:42:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Methylene chloride	15	1.0	B	µg/L	1	12/24/2005 8:42:00 AM
Naphthalene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
o-Xylene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Styrene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Toluene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Trichloroethene	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/24/2005 8:42:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/24/2005 8:42:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122105:835 NP2-7
Lab Order:	0512250	Tag Number:	
Project:	Rowe	Collection Date:	12/21/2005
Lab ID:	0512250-02B	Date Received:	12/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	2.31	0.0200		mg/L	1	12/29/2005 10:36:49 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122105:835 NP2-7
Lab Order:	0512250	Tag Number:	
Project:	Rowe	Collection Date:	12/21/2005
Lab ID:	0512250-02C	Date Received:	12/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0511	0.0200		mg/L	1	12/29/2005 10:34:16 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122105:840 NP2-10
Lab Order:	0512250	Tag Number:	
Project:	Rowe	Collection Date:	12/21/2005
Lab ID:	0512250-03A	Date Received:	12/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: SB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
2-Butanone	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
2-Hexanone	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Acetone	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Benzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Bromobenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Bromoform	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Bromomethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Chloroethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM

Qualifiers:

- * Value exceeds Maximum Contaminant Level
- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122105:840 NP2-10
Lab Order: 0512250 **Tag Number:**
Project: Rowe **Collection Date:** 12/21/2005
Lab ID: 0512250-03A **Date Received:** 12/23/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Chloromethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Dibromomethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/24/2005 9:19:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Methylene chloride	8.0	1.0	B	µg/L	1	12/24/2005 9:19:00 AM
Naphthalene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
o-Xylene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Styrene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Toluene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Trichloroethene	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/24/2005 9:19:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/24/2005 9:19:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122105:840 NP2-10
Lab Order:	0512250	Tag Number:	
Project:	Rowe	Collection Date:	12/21/2005
Lab ID:	0512250-03B	Date Received:	12/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	3.02	0.0200		mg/L	1	12/29/2005 10:41:56 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 29-Dec-05

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122105:840 NP2-10
Lab Order:	0512250	Tag Number:	
Project:	Rowe	Collection Date:	12/21/2005
Lab ID:	0512250-03C	Date Received:	12/23/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.0452	0.0200		mg/L	1	12/29/2005 10:39:26 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: VP
Total Dissolved Solids (Residue, Filterable)	100	1.0		mg/L	1	12/27/2005

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, January 04, 2006

Mark Goldberg
Leggette Brashears & Graham Inc.
126 Monroe Turnpike
Trumbull, CT 06611

TEL: (203) 452-3110

FAX (203) 452-3111

RE: Rowe Industries

Order No.: 0512268

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 12/28/2005 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0512268

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Collection Date	Date Received
0512268-01A	WQ122705:1100 NP2-6		12/27/2005	12/28/2005
0512268-01B	WQ122705:1100 NP2-6		12/27/2005	12/28/2005
0512268-01C	WQ122705:1100 NP2-6		12/27/2005	12/28/2005
0512268-02A	WQ122705:1105 NP2-7		12/27/2005	12/28/2005
0512268-02B	WQ122705:1105 NP2-7		12/27/2005	12/28/2005
0512268-02C	WQ122705:1105 NP2-7		12/27/2005	12/28/2005
0512268-03A	WQ122705:1110 NP2-10		12/27/2005	12/28/2005
0512268-03B	WQ122705:1110 NP2-10		12/27/2005	12/28/2005
0512268-03C	WQ122705:1110 NP2-10		12/27/2005	12/28/2005

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0512268

CASE NARRATIVE

Samples were analyzed using the methods outlined in the following references:

Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW846, 3rd Edition as defined throughout the text of the report.

All method blanks, laboratory spikes, and/or matrix spikes met quality assurance objectives.

Methylene Chloride and Acetone are common lab contaminants and the presence of these constituents in associated field samples are due to lab contamination and not sample matrix constituents.

No analytical problems were encountered.

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122705:1100 NP2-6
Lab Order: 0512268 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/27/2005
Lab ID: 0512268-01A **Date Received:** 12/28/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,1,1-Trichloroethane	3.8	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
2-Butanone	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
2-Hexanone	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Acetone	7.4	1.0		µg/L	1	12/31/2005 2:39:00 AM
Benzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Bromobenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Bromoform	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Bromomethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Chloroethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122705:1100 NP2-6
Lab Order:	0512268	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/27/2005
Lab ID:	0512268-01A	Date Received:	12/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Chloromethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Dibromomethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/31/2005 2:39:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Methylene chloride	8.9	1.0	B	µg/L	1	12/31/2005 2:39:00 AM
Naphthalene	3.8	1.0		µg/L	1	12/31/2005 2:39:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
o-Xylene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Styrene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Tetrachloroethene	17	1.0		µg/L	1	12/31/2005 2:39:00 AM
Toluene	1.3	1.0		µg/L	1	12/31/2005 2:39:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Trichloroethene	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/31/2005 2:39:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/31/2005 2:39:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122705:1100 NP2-6
Lab Order:	0512268	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/27/2005
Lab ID:	0512268-01B	Date Received:	12/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	2.91	0.0200		mg/L	1	12/29/2005 10:46:33 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122705:1100 NP2-6
Lab Order:	0512268	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/27/2005
Lab ID:	0512268-01C	Date Received:	12/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.160	0.0200		mg/L	1	12/29/2005 10:44:25 AM

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122705:1105 NP2-7
Lab Order: 0512268 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/27/2005
Lab ID: 0512268-02A **Date Received:** 12/28/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
2-Butanone	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
2-Hexanone	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Acetone	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Benzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Bromobenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Bromoform	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Bromomethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Chloroethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level B Analyte detected in the associated Method Blank
 E Value above quantitation range H Holding times for preparation or analysis exceeded
 J Analyte detected below quantitation limits ND Not Detected at the Reporting Limit
 S Spike Recovery outside accepted recovery limits U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122705:1105 NP2-7
Lab Order: 0512268 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/27/2005
Lab ID: 0512268-02A **Date Received:** 12/28/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Chloromethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Dibromomethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/29/2005 8:10:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Methylene chloride	11	1.0	B	µg/L	1	12/29/2005 8:10:00 PM
Naphthalene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
o-Xylene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Styrene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Toluene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Trichloroethene	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/29/2005 8:10:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/29/2005 8:10:00 PM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122705:1105 NP2-7
Lab Order:	0512268	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/27/2005
Lab ID:	0512268-02B	Date Received:	12/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	5.25	0.0200		mg/L	1	12/29/2005 11:09:24 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122705:1105 NP2-7
Lab Order:	0512268	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/27/2005
Lab ID:	0512268-02C	Date Received:	12/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.343	0.0200		mg/L	1	12/29/2005 10:48:39 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122705:1110 NP2-10
Lab Order: 0512268 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/27/2005
Lab ID: 0512268-03A **Date Received:** 12/28/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILES SW-846 8260 PLUS MTBE & FREON1		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
2-Butanone	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
2-Hexanone	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Acetone	16	1.0		µg/L	1	12/31/2005 3:18:00 AM
Benzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Bromobenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Bromoform	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Bromomethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Chloroethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122705:1110 NP2-10
Lab Order: 0512268 **Tag Number:**
Project: Rowe Industries **Collection Date:** 12/27/2005
Lab ID: 0512268-03A **Date Received:** 12/28/2005 **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
Chloroform	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Chloromethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Dibromomethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/31/2005 3:18:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Methylene chloride	11	1.0	B	µg/L	1	12/31/2005 3:18:00 AM
Naphthalene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
o-Xylene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Styrene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Toluene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Trichloroethene	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/31/2005 3:18:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/31/2005 3:18:00 AM

Qualifiers: * Value exceeds Maximum Contaminant Level
 E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122705:1110 NP2-10
Lab Order:	0512268	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/27/2005
Lab ID:	0512268-03B	Date Received:	12/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7				Analyst: JP
Iron	9.86	0.0200		mg/L	1	12/29/2005 11:13:39 AM

Qualifiers:	*	Value exceeds Maximum Contaminant Level	B	Analyte detected in the associated Method Blank
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	ND	Not Detected at the Reporting Limit
	S	Spike Recovery outside accepted recovery limits	U	Indicates the compound was analyzed for but not detected

American Analytical Laboratories, LLC.

Date: 04-Jan-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122705:1110 NP2-10
Lab Order:	0512268	Tag Number:	
Project:	Rowe Industries	Collection Date:	12/27/2005
Lab ID:	0512268-03C	Date Received:	12/28/2005
		Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		(SW3005A)		Analyst: JP
Iron	0.471	0.0200		mg/L	1	12/29/2005 11:11:34 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: VP
Total Dissolved Solids (Residue, Filterable)	124	1.00		mg/L	1	12/30/2005

Qualifiers:	* Value exceeds Maximum Contaminant Level	B Analyte detected in the associated Method Blank
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	ND Not Detected at the Reporting Limit
	S Spike Recovery outside accepted recovery limits	U Indicates the compound was analyzed for but not detected

Page 12 of 12

ANALYTICAL REPORT

JOB NUMBER: 211598

Prepared For:

LEGGETTE, BRASHEARS & GRAHAM
126 Monroe Turnpike
Trumbull, CT 06611

Project: ROWE INDUSTRIES

Attention: Mark Goldberg

Date: 01/03/2006



Signature

Name: Erin A. Gaus

Title: Project Manager

E-Mail: egaus@stl-inc.com

01/04/06

Date

STL Connecticut
128 Long Hill Cross Road
Shelton, CT 06484

This Report Contains (126) Pages

STL Report : 211598
LEGGETTE, BRASHEARS & GRAHAM

Case Narrative

Sample Receipt – All samples were received in good condition and at the proper temperature.

Volatile Organics – Air volatile organics were determined by purge and trap GC/MS using guidance provided in Method TO-17. The instrumentation used was a Perkin Elmer ATD 50 interfaced with a Hewlett-Packard Model 5972A GC/MS/DS.

The samples in this job were collected in tedlar bags. Samples were transferred by the laboratory to Air Toxic TO-17 tubes and analyzed at sample volumes of 1L. Compound concentrations over the calibration curve in sample AQ120805:930 NP4-1 were flagged with an "A".

Sample Calculation:

Sample ID- AQ120805:930 NP4-1

Compound-Bromomethane

$$\frac{(44711 \text{ area})(25\text{ng})}{(208345 \text{ area})(.363 \text{ area/ng})} = 14.77 = 15 \text{ ng}$$

$$\frac{(15 \text{ NG})(.08206)(298)}{(1\text{L})(95)(1.0\text{ATM})} = 3.86 = 3.9 \text{ nL/L.}$$

The target compound, methylene chloride, is a suspected laboratory contaminant in the air tubes that were used in this job.

The test results in this report meet all NELAP requirements for parameters for which accreditation is required or available. Any exceptions to NELAP requirements are noted in the case narrative.

Date: 01/03/2006

Project Number.....: 20000283
Customer Project ID....: ROWE INDUSTRIES
Project Description....: Rowe Industries

Page 1

STL Connecticut		Form 1		
		Client Sample ID	AQ120805:930 NP4-1	
Method: TO17		Lab Sample ID	211598-1	
Sample Volume (L)	1.000	Date Sampled	12/8/2005	
Temp (C)	25	Date Analyzed	12/27/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	1.0 J	9.7	0.002 J	0.020
Vinyl Chloride	7.8 U	7.8	0.020 U	0.020
Bromomethane	3.9 JB	5.1	0.015 JB	0.020
Chloroethane	7.6 U	7.6	0.020 U	0.020
1,1-Dichloroethene	1.5 J	2.5	0.006 J	0.010
Carbon Disulfide	12.2	3.2	0.038	0.010
Methylene Chloride	2.3 JB	2.9	0.008 JB	0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.010 U	0.010
1,1-Dichloroethane	4.9	2.5	0.020	0.010
cis-1,2-Dichloroethene	8.2	2.5	0.032	0.010
Chloroform	0.8 J	2.1	0.004 J	0.010
1,1,1-Trichloroethane	14.5	1.8	0.079	0.010
Carbon Tetrachloride	1.6 U	1.6	0.010 U	0.010
Benzene	0.9 JB	3.1	0.003 JB	0.010
1,2-Dichloroethane	2.5 U	2.5	0.010 U	0.010
Trichloroethene	3.0	1.9	0.016	0.010
1,2-Dichloropropane	2.2 U	2.2	0.010 U	0.010
Bromodichloromethane	1.5 U	1.5	0.010 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
Toluene	3.7	2.7	0.014	0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.010 U	0.010
Tetrachloroethene	50.1 A	1.5	0.340 A	0.010
Dibromochloromethane	1.2 U	1.2	0.010 U	0.010
Chlorobenzene	2.2 U	2.2	0.010 U	0.010
Ethylbenzene	0.2 J	2.3	0.001 J	0.010
m&p-Xylenes	0.7 J	2.3	0.003 J	0.010
o-Xylene	2.3 U	2.3	0.010 U	0.010
Styrene	0.5 J	2.4	0.002 J	0.010
Bromoform	1.0 U	1.0	0.010 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.010 U	0.010

STL Connecticut		Form 1		
		Client Sample ID	AQ120805:935 NP4-2	
Method: TO17		Lab Sample ID	211598-2	
Sample Volume (L)	1.000	Date Sampled	12/8/2005	
Temp (C)	25	Date Analyzed	12/27/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	9.7 U	9.7	0.020 U	0.020
Vinyl Chloride	1.2 J	7.8	0.003 J	0.020
Bromomethane	4.6 JB	5.1	0.018 JB	0.020
Chloroethane	7.6 U	7.6	0.020 U	0.020
1,1-Dichloroethene	2.3 J	2.5	0.009 J	0.010
Carbon Disulfide	6.7	3.2	0.021	0.010
Methylene Chloride	2.0 JB	2.9	0.007 JB	0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.010 U	0.010
1,1-Dichloroethane	5.7	2.5	0.023	0.010
cis-1,2-Dichloroethene	1.8 J	2.5	0.007 J	0.010
Chloroform	1.2 J	2.1	0.006 J	0.010
1,1,1-Trichloroethane	23.9	1.8	0.130	0.010
Carbon Tetrachloride	1.6 U	1.6	0.010 U	0.010
Benzene	0.6 JB	3.1	0.002 JB	0.010
1,2-Dichloroethane	2.5 U	2.5	0.010 U	0.010
Trichloroethene	1.9 U	1.9	0.010 U	0.010
1,2-Dichloropropane	2.2 U	2.2	0.010 U	0.010
Bromodichloromethane	1.5 U	1.5	0.010 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
Toluene	3.5	2.7	0.013	0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.010 U	0.010
Tetrachloroethene	0.4 J	1.5	0.003 J	0.010
Dibromochloromethane	1.2 U	1.2	0.010 U	0.010
Chlorobenzene	2.2 U	2.2	0.010 U	0.010
Ethylbenzene	0.2 J	2.3	0.001 J	0.010
m&p-Xylenes	0.9 J	2.3	0.004 J	0.010
o-Xylene	0.2 J	2.3	0.001 J	0.010
Styrene	0.7 J	2.4	0.003 J	0.010
Bromoform	1.0 U	1.0	0.010 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.010 U	0.010

STL Connecticut		Form 1		
		Client Sample ID	AQ120805:940 NP4-3	
Method: TO17		Lab Sample ID	211598-3	
Sample Volume (L)	1.000	Date Sampled	12/8/2005	
Temp (C)	25	Date Analyzed	12/27/2005	
Compound	nL/L (ppbv/v) Qualifier	RL	mg/M3 Qualifier	RL
Chloromethane	9.7 U	9.7	0.020 U	0.020
Vinyl Chloride	7.8 U	7.8	0.020 U	0.020
Bromomethane	5.1 B	5.1	0.020 B	0.020
Chloroethane	7.6 U	7.6	0.020 U	0.020
1,1-Dichloroethene	2.3 J	2.5	0.009 J	0.010
Carbon Disulfide	8.0	3.2	0.025	0.010
Methylene Chloride	2.6 JB	2.9	0.009 JB	0.010
trans-1,2-Dichloroethene	2.5 U	2.5	0.010 U	0.010
1,1-Dichloroethane	6.9	2.5	0.028	0.010
cis-1,2-Dichloroethene	1.0 J	2.5	0.004 J	0.010
Chloroform	1.8 J	2.1	0.009 J	0.010
1,1,1-Trichloroethane	13.8	1.8	0.075	0.010
Carbon Tetrachloride	1.6 U	1.6	0.010 U	0.010
Benzene	0.6 JB	3.1	0.002 JB	0.010
1,2-Dichloroethane	2.5 U	2.5	0.010 U	0.010
Trichloroethene	1.9 U	1.9	0.010 U	0.010
1,2-Dichloropropane	2.2 U	2.2	0.010 U	0.010
Bromodichloromethane	1.5 U	1.5	0.010 U	0.010
cis-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
Toluene	3.5	2.7	0.013	0.010
trans-1,3-Dichloropropene	2.2 U	2.2	0.010 U	0.010
1,1,2-Trichloroethane	1.8 U	1.8	0.010 U	0.010
Tetrachloroethene	1.5 U	1.5	0.010 U	0.010
Dibromochloromethane	1.2 U	1.2	0.010 U	0.010
Chlorobenzene	2.2 U	2.2	0.010 U	0.010
Ethylbenzene	0.2 J	2.3	0.0008 J	0.010
m&p-Xylenes	0.7 J	2.3	0.003 J	0.010
o-Xylene	0.1 J	2.3	0.0003 J	0.010
Styrene	0.7 J	2.4	0.003 J	0.010
Bromoform	1.0 U	1.0	0.010 U	0.010
1,1,2,2-Tetrachloroethane	1.5 U	1.5	0.010 U	0.010

Job Number: 211598

L A B O R A T O R Y C H R O N I C L E

Date: 01/03/2006

CUSTOMER: LEGGETTE, BRASHEARS & GRAHAM

PROJECT: ROWE INDUSTRIES

ATTN: Mark Goldberg

Lab ID: 211598-1	Client ID: AQ120805:930 NP4-1	Date Recvd: 12/12/2005	Sample Date: 12/08/2005		
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)
T017	Volatile Organics (Air)	1	59444		
			DATE/TIME ANALYZED		DILUTION
			12/27/2005 1924		1.00000
Lab ID: 211598-2	Client ID: AQ120805:935 NP4-2	Date Recvd: 12/12/2005	Sample Date: 12/08/2005		
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)
T017	Volatile Organics (Air)	1	59444		
			DATE/TIME ANALYZED		DILUTION
			12/27/2005 2003		1.00000
Lab ID: 211598-3	Client ID: AQ120805:940 NP4-3	Date Recvd: 12/12/2005	Sample Date: 12/08/2005		
METHOD	DESCRIPTION	RUN#	BATCH#	PREP BT	#(S)
T017	Volatile Organics (Air)	1	59444		
			DATE/TIME ANALYZED		DILUTION
			12/27/2005 2042		1.00000

AIR
~~WATER~~ VOLATILE SYSTEM MONITORING COMPOUND RECOVERY
 2A

Rm 12/29/05

Lab Name: STL-CT

Contract:

Lab Code: STL-CT

Case No.: 211598 SAS No.:

SDG No.: 211598

	EPA SAMPLE NO.	SMC1 #	SMC2 (DCE) #	SMC3 (TOL) #	OTHER (BFB) #	TOT OUT
01	VBLKT6	105	92	102	107	
02	VBLKT6LCS	102	101	101	104	
03	AQ120805:930 NP4-1	107	99	104	111	
04	AQ120805:935 NP4-2	105	94	103	110	
05	AQ120805:940 NP4-3	98	90	108	99	
06						
07						
08						
09						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						

QC LIMITS

SMC1 = Dibromofluoromethane (70-130)
 SMC2 (DCE) = 1,2-Dichloroethane-d4 (70-130)
 SMC3 (TOL) = Toluene-d8 (70-130)
 OTHER (BFB) = Bromofluorobenzene (70-130)

Column to be used to flag recovery values

* Values outside of contract required QC limits

D System Monitoring Compound diluted out

Form 3

Data File: \\TARGET1_CT\\Files\\chem\\VOA\\mst.i\\T055691.b\\T5701.D Page 1
Report Date: 28-Dec-2005 07:13

STL-CT

RECOVERY REPORT

Client Name: Client SDG: SDGa24843
Sample Matrix: LIQUID Fraction: VOA
Lab Smp Id: 20ng lcs Operator: L.Decker
Level: LOW SampleType: LCS
Data Type: MS DATA Quant Type: ISTD
SpikeList File: AIRQCS.spk
Sublist File: all.sub
Method File: \\TARGET1_CT\\Files\\chem\\VOA\\mst.i\\T055691.b\\TAIRFULL.m
Misc Info: : LCS;;;20ng LCS; * 1L* ; AIR

SPIKE COMPOUND	CONC ADDED ug/L	CONC RECOVERED ug/L	% RECOVERED	LIMITS
4 Vinyl Chloride	20	17	85.04	60-140
5 Bromomethane	20	12	57.82*	60-140
6 Chloroethane	20	17	86.92	60-140
12 1,1-Dichloroethene	20	15	77.36	60-140
11 Trichlorotrifluoro	20	12	59.50*	60-140
17 Acetone	20	15	75.76	60-140
13 Carbon Disulfide	20	14	71.93	60-140
16 Methylene Chloride	20	13	66.37	60-140
18 trans-1,2-Dichloro	20	16	81.03	60-140
28 1,1-Dichloroethane	20	15	77.14	60-140
30 cis-1,2-Dichloroet	20	15	75.00	60-140
40 2-Butanone	20	19	93.24	60-140
33 Chloroform	20	15	73.67	60-140
38 1,1,1-Trichloroeth	20	18	87.71	60-140
39 Carbon Tetrachlori	20	19	94.24	60-140
51 1,2-Dichloroethane	20	16	81.80	60-140
48 Benzene	20	15	75.04	60-140
56 Trichloroethene	20	15	73.97	60-140
63 cis-1,3-Dichloropr	20	17	83.71	60-140
72 4-Methyl-2-Pentano	20	14	70.68	60-140
69 Toluene	20	14	72.28	60-140
66 trans-1,3-Dichloro	20	15	73.14	60-140
67 1,1,2-Trichloroeth	20	15	73.26	60-140
73 Tetrachloroethene	20	14	69.26	60-140
75 Dibromochlorometha	20	15	76.76	60-140
80 Chlorobenzene	20	14	71.16	60-140
82 Ethylbenzene	20	14	69.99	60-140
83 Xylene (total)mp	40	29	73.73	60-140
84 Xylene (total)o	20	14	69.24	60-140
85 Styrene	20	15	72.57	60-140
86 Bromoform	20	14	68.62	60-140
89 1,1,2,2-Tetrachlor	20	16	79.26	60-140
101 1,3-Dichlorobenzen	20	15	77.13	60-140
102 1,4-Dichlorobenzen	20	15	75.28	60-140
103 1,2-Dichlorobenzen	20	15	76.49	60-140

QUALITY ASSURANCE METHODS

REFERENCES AND NOTES

REPORT COMMENTS

- 1) All pages of this report are integral parts of the analytical data. Therefore, this report should be reproduced only in its entirety.
- 2) Soil, sediment and sludge sample results are reported on a "dry weight" basis except when analyzed for landfill disposal or incineration parameters. All other solid matrix samples are reported on an "as received" basis unless noted differently.
- 3) Reporting limits are adjusted for sample size used, dilutions and moisture content if applicable.
- 4) The test results for the noted analytical method(s) meet the requirements of NELAC Lab Cert. ID# 10604
- 5) According to 40CFR Part 136.3, pH, Chlorine Residual and Dissolved Oxygen analyses are to be performed immediately after aqueous sample collection. When these parameters are not indicated as field (e.g. pH Field) they were not analyzed immediately, but as soon as possible on laboratory receipt.

Glossary of flags, qualifiers and abbreviation

Inorganic Qualifiers (Q-Column)

- U Analyte was not detected at or above the reporting limit.
- < Not detected at or above the reporting limit.
- J Result is less than the RL, but greater than or equal to the method detection limit.
- B Result is less than the CRDL/RL, but greater than or equal to the IDL/MDL.
- S Result was determined by the Method of Standard Additions.

Inorganic Flags (Flag Column)

- ICV,CCV,ICB,CCB,ISA,ISB,CRI,CRA,MRL: Instrument related QC exceed the upper or lower control limits.
- * LCS, LCD, MD: Batch QC exceeds the upper or lower control limits.
- + MSA correlation coefficient is less than 0.995.
- 4 MS, MSD: The analyte present in the original sample is 4 times greater than the matrix spike concentration; therefore, control limits are not applicable.
- E SD: Serial dilution exceeds the control limits.
- H MB, EB: Batch QC is greater than reporting limit or had a negative instrument reading lower than the absolute value of the reporting limit.
- N MS, MSD: Spike recovery exceeds the upper or lower control limits.
- W PS: Post-digestion spike was outside 85-115% control limits.

Organic Qualifiers (Q - Column)

- U Analyte was not detected at or above the reporting limit.
- ND Compound not detected.
- J Result is an estimated value below the reporting limit or a tentatively identified compound (TIC).
- Q Result was qualitatively confirmed, but not quantified.
- C Pesticide identification was confirmed by GC/MS.
- Y The chromatographic response resembles a typical fuel pattern.
- Z The chromatographic response does not resemble a typical fuel pattern.
- E Result exceeded calibration range, secondary dilution required.

Organic Flags (Flags Column)

- MB,EB, MLE: Batch QC is greater than reporting limit.
- * LCS, LCD, CCV, MS, MSD, Surrogate, RS: Batch QC exceeds the upper or lower control limits.
- A Concentration exceeds the instrument calibration range or below the reporting limit.
- B Compound was found in the blank.
- D Surrogate or matrix spike recoveries were not obtained because the extract was diluted for analysis; also compounds analyzed at a dilution will be flagged with a D.
- H Alternate peak selection upon analytical review
- I Indicates the presence of an interference, recovery is not calculated.
- M Manually integrated compound.
- P The lower of the two values is reported when the % difference between the results of two GC columns is greater than 25%.

QUALITY ASSURANCE METHODS REFERENCES AND NOTES

Abbreviations

Batch	Designation given to identify a specific extraction, digestion, preparation set, or analysis set
CAP	Capillary Column
CCB	Continuing Calibration Blank
CCV	Continuing Calibration Verification
CF	Confirmation Analysis
CRA	Low Level Standard Check - GFAA; Mercury
CRI	Low Level Standard Check - ICP
Dil. Fac	Dilution Factor
DL	Secondary dilution and analysis
DLFac	Detection Limit Factor
DSH	Distilled Standard - High Level
DSL	Distilled Standard - Low Level
DSM	Distilled Standard - Medium Level
EB	Extraction Blank
ICB	Initial Calibration Blank
ICV	Initial Calibration Verification
IDL	Instrument Detection Limit
ISA	Interference Check Sample A
ISB	Interference Check Sample B
Job No.	The first six digits of the sample ID which refers to a specific client, project and sample group
Lab ID	An 8 number unique laboratory identification
LCD	Laboratory Control Standard Duplicate
LCS	Laboratory Control Standard with reagent grade water or a matrix free from the analyte of interest
MB	Method Blank or (PB) Preparation Blank
MD	Method Duplicate
MDL	Method Detection Limit
MLE	Medium Level Extraction Blank
MRL	Method Reporting Limit Standard
MSA	Method of Standard Additions
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ND	Not Detected
PACK	Packed Column
PREPF	Preparation factor used by the Laboratory's Information Management System (LIMS)
PS	Post Spike
PSD	Post Spike Duplicate
RA	Re-analysis
RE	Re-extraction and analysis
RL	Reporting Limit
RPD	Relative Percent Difference of duplicate (unrounded) analyses
RRF	Relative Response Factor
RS	Reference Standard
RT	Retention Time
RTW	Retention Time Window
SampleID	A 9 digit number unique for each sample, the first six digits are referred as the job number
SCB	Seeded Control Blank
SD	Serial Dilution
UCB	Unseeded Control Blank

One or a combination of these data qualifiers and abbreviations may appear in the analytical report.

STL-Connecticut

Certification Summary (as of September 2005)


The laboratory identification numbers for the STL-Connecticut laboratory are provided in the following table. Many states certify laboratories for specific parameters or tests within a category (i.e. method 325.2 for wastewater). The information in the following table indicates the lab is certified in a general category of testing such as drinking water or wastewater analysis. The laboratory should be contacted directly if parameter-specific certification information is required.

State	Responsible Agency	Certification	Expiration Date	Lab Number
Connecticut	Department of Health Services	Drinking Water, Wastewater	12/31/06	PH-0497
Maine	Department of Health and Environmental Services	Drinking Water, Wastewater/Solid, Hazardous Waste	04/18/06	CT023
Massachusetts	Department of Environmental Protection	Potable/Non-Potable Water	06/30/06	CT023
New Hampshire	Department of Environmental Services	Drinking Water, Wastewater	08/29/06	2528
New Jersey	Department of Environmental Protection	Drinking Water, Wastewater	06/30/06	CT410
New York	Department of Health	CLP, Drinking Water, Wastewater, Solid/ Hazardous Waste NELAC	04/01/06	10602
Rhode Island	Department of Health	Chemistry...Non- Potable Water and Wastewater	12/30/06	A43
Utah	Department of Health	RCRA	05/31/06	2032614458



STL

MISCELLANEOUS DOCUMENTS

rpjsckl	Job Sample Receipt Checklist Report	V2
Job Number.: 211598	Location.: 57207	Check List Number.: 1
Customer Job ID.....	Job Check List Date.:	Description.:
Project Number.: 20000283	Project Description.: Rowe Industries	Date of the Report...: 12/12/2005
Customer.....: LEGGETTE, BRASHEARS & GRAHAM	Contact.: Mark Goldberg	Project Manager.....: Dag
Questions ?	(Y/N) Comments	
Chain-of-Custody Present?.....	Y	
...If "yes", completed properly?.....	Y	
Custody seal on shipping container?.....	Y	
...If "yes", custody seal intact?.....	Y	
Custody seals on sample containers?.....	N	
...If "yes", custody seal intact?.....		
Samples iced?.....	N	
Temperature of cooler acceptable? (4 deg C +/- 2). Y		
Samples received intact (good condition)?.....	Y	
Volatile samples acceptable? (no headspace).....	Y	
Correct containers used?.....	Y	
Adequate sample volume provided?.....	Y	
Samples preserved correctly?.....	Y	
Samples received within holding-time?.....	Y	
Agreement between COC and sample labels?.....	Y	
Radioactivity at or below background levels?.....	Y	
A Sample Discrepancy Report (SDR) was needed?.....	N	
Comments.....		
If samples were shipped was there an air bill #?..	N	drop off
Sample Custodian Signature/Date.....	Y	 12/12/05