

-DRAFT-

PROJECT STATUS MEMORANDUM

NO. 09-06

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Tunde H. Komuves-Sandor

DATE: November 15, 2006

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
September 2006 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from September 1, 2006 through September 30, 2006. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION
(September 1, 2006 through September 30, 2006)

- | | |
|---|----------------------------------|
| 1. Hours of operation during the reporting period: | 470 hours (65%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 13,261,030 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 2.0 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 190.7 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.08 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00082 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow (gpm)	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2	828,816	27	26	202.8	1.4
RW-3 *	0	0	23	0	0
RW-4	1,657,620	40	13	16.5	0.23
RW-5	1,657,660	50	42	0	0
RW-6	414,409	15	28	73	0.25
RW-7	1,066,300	69	54	43.5	0.39
RW-8	1,657,619	50	46	3.0	0.04
RW-9	1,657,640	80	68	0	0

*Recovery well RW-3 was not operating in September because the new RW-3 drive has to be reprogrammed to account for the two (2) horsepower (HP) pump motor recently installed following well rehabilitation activities (RW-3 formerly had a one (1) HP pump motor).

Recovery well RW-6 had an average flow below the respective minimum design flow determined to be necessary for capture of the plume. The performance of RW-6 will continue to be monitored. The ground-water model for the site will be updated to reflect the current pumping and water quality conditions to determine if the FSP&T system can effectively capture the plume for different degrees of operation of RW-6.

A trend of increasing 1,1,1 Trichloroethane (1,1,1 TCA) concentrations in the groundwater have been detected at RW-2 from June through September 2006. This period coincides with the time that RW-3 was not operating. One hypothesis for the increase in 1,1,1 TCA concentration in the ground water at RW-2 may be that capture zones RW-2 and RW-3 shift depending on which wells (RW-2 and/or RW-3) are operating. A ground-water modeling evaluation will be completed in the near future to try and determine if the above hypothesis is true. A discussion about the ground-water model will be included in the annual report and/or in subsequent monthly status reports.

The effluent pH of the treated water from the FSP&T system is within the acceptable State Pollutant Discharge System (SPDES) criteria for the site as shown on table 2.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
September 1 to 30	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in September 2006 include:

- On September 5, 2006, the air stripper blower and booster blower air flow meter sensors were repaired by the vendor, however, air flow readings are not being transmitted to the local or computer displays. Troubleshooting of the air flow meters will be conducted.
- On September 12, 2006, the malfunctioning RW-3 pressure sensor was replaced.
- On September 13, 2006, cove salinity monitoring and piezometer water level measurements were completed.
- On September 18-20, 2006, semi-annual ground-water sampling was conducted. A complete round of depth-to-water levels was completed while the system was operating.
- On September 26, 2006, a round of static depth-to-water levels was completed after the recovery well as had been shut down for 5 days.

Future O&M activities scheduled for the fall of 2006 include:

- Rehabilitate the recharge basin;
- Reprogram RW-3 drive for compatibility with the new 2 horsepower motor;
- Troubleshoot air flow meters; and
- Clean treatment building influent pipes and RW-2, 4, 8, 9 flow meters, valves and pipes.

cc: Phil McAndrew, Kraft Foods, N.A. – .pdf
Lisa Krogman, Kraft Foods, N.A. (Environ) – .pdf
Jeff Trad, NYSDEC – .pdf
Chief-Operation Maintenance and Support Section, NYSDEC – .pdf
William Spitz, RWM, R-1, NYSDEC
Garrett W. Swensen Jr., Esq., Town of Southampton

MMG:ng
Attachments

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(Septmber 1, 2006 through September 30, 2006)

Date	Time	System Changes/Modifications	Personnel
9/5/2006		System communication failure occurred on 8/30/06 between 5:56AM and 6:56AM	
		Air stripper blower and booster blower air flow meter sensors were repaired by the vendor, however, air flow readings are not being transmitted to the local or computer displays. Troubleshooting of the air flow meters will be conducted.	RD
	8:41 AM	Reset alarms, and restarted system.	RD
	9:09 AM	An RW-7 pump fault alarm occurred. RW-7 did not operate, however the rest of the system continues to operate.	RD
9/12/2006		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	RD
		The malfunctioning RW-3 pressure transducer was replaced.	RD
		The RW-7 pump fault alarm was reset. RW-7 is operating.	RD
9/18/2006		Began semi-annual ground-water sampling of select monitor wells. Measured depth to water of all wells.	MW/TS
9/19/2006		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	RD
9/20/2006		Finished semi-annual ground-water sampling.	MW/TS/PW
9/21/2006		System communication failure occurred between 9:56AM and 10:56AM, system shut down.	
9/26/2006		Measured static depth to water of all wells.	TS
9/27/2006	11:30 AM	Reset alarms and restarted system	RD
		Updated static water levels.	RD

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo-chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	1	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
5-Sep-06	5.1	114	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	3.24	0.538
12-Sep-06	5.3	116	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	3.66	0.173
19-Sep-06	Note 3	70	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.35	0.065
27-Sep-06	5.1	114	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	14.1	0.137

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

----: Not established

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. Based on the new SPDES criteria from an NYSDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5.

The pH was measured using litmus paper. Influent pH values from recovery wells typically range between 5 and 6.

2. "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.

3. The pH was not measured at this time.

TABLE 3

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																					TOTAL VOCs
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE		
AQ090805:900NP4-1	9/8/2005	9:00	0.27	0.032	0.1	0.011	ND	0.016	0.079	0.039	0.025	0.013	0.003	ND	1.7 ^{1/}	ND	0.021	0.038	0.01	0.004	ND	ND	ND	0.81
AQ100605:1230NP4-1	10/6/2005	12:30	0.28	0.022	0.1	0.007	0.025	0.011	0.015	0.004	0.003	ND	0.002	0.005	0.036	ND	ND	0.032	ND	ND	ND	ND	ND	0.54
AQ111605:1130NP4-1	11/16/2005	11:30	0.76	0.033	0.11	0.008	0.022	0.054	0.44	0.016	0.012	0.004	0.004	ND	0.05	ND	0.023	0.052	ND	0.002	ND	ND	ND	1.59
AQ120805:930NP4-1	12/8/2005	9:30	0.34	0.016	0.079	0.006	0.02	0.032	0.014	0.003	0.003	ND	0.002	0.004	0.008 ^{2/}	0.002	0.038	0.015	ND	0.001	ND	ND	ND	0.58
AQ010406:845NP4-1	1/4/2006	8:45	0.24	0.027	0.094	0.007	0.019	0.009	0.031	0.014	0.01	0.004	0.005	0.005	0.018	ND	0.027	0.002	ND	0.003	ND	ND	ND	0.52
AQ020106:745NP4-1	2/1/2006	7:45	0.64	0.03	0.12	0.008	0.028	0.018	0.005	0.009	0.003	ND	ND	0.007	0.024	0.008	0.012	0.018 ^{3/}	ND	ND	ND	ND	ND	0.91
AQ032206:1215NP4-1 ^{4/}	3/22/2006	12:15	0.12	0.018	0.077	0.0042	0.018	0.0062	0.0026	0.00096	0.0016	ND	ND	0.0049	0.0025	0.0017	0.0067	ND	ND	ND	ND	ND	ND	0.26
AQ041206:950NP4-1	4/12/2006	9:50	0.18	0.011	0.038	0.004	0.0087	0.007	0.0014	ND	ND	ND	ND	0.0037	0.0011	0.0018	0.0047	ND	ND	ND	ND	ND	ND	0.26
AQ051706:1000NP4-1	5/17/2006	10:00	0.28	0.017	0.048	0.0035	0.013	0.014	0.0093	0.0026	0.0032	ND	ND	0.0037	0.0019	0.0026	0.0097	ND	ND	0.0016	0.0011	ND	ND	0.41
AQ062106:800NP4-1	6/21/2006	8:00	0.15	0.009	0.074	0.0037	0.014	0.0062	0.0048	0.00092	0.0022	ND	ND	0.0029	0.002	0.0019	0.014	ND	ND	ND	0.00091	ND	ND	0.29
AQ072006:900NP4-1	7/20/2006	9:00	0.095	0.008	0.091	ND	0.0074	0.005	0.0057	ND	0.0069	0.0062	ND	ND	0.0067	0.0022	0.013	ND	ND	ND	ND	ND	ND	0.25
AQ082406:900NP4-1	8/24/2006	9:00	0.28	0.012	0.055	0.0034	0.0083	0.013	0.0043	0.0021	0.0022	ND	ND	0.003	0.0043	ND	0.009	ND	ND	ND	0.0014	ND	ND	0.40
AQ091906:910NP4-1	9/19/2006	9:10	0.21	0.01	0.26	0.006	0.016	0.0046	0.0029	0.001	0.0017	ND	ND	0.0053	0.0012	0.0023	0.013	ND	ND	ND	0.00089	0.0007	ND	0.54
Midcarbon			Parameters (mg/m3)																					TOTAL VOCs
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE		
AQ090805:905NP4-2	9/8/2005	9:05	0.008	ND	0.039	ND	ND	ND	0.049	0.002	0.024	0.012	ND	0.004	0.10 ^{1/}	ND	0.018	0.013	ND	0.003	ND	ND	ND	0.27
AQ100605:1232NP4-2	10/6/2005	12:32	0.007	ND	0.1	0.01	0.028	0.009	0.013	0.001	0.003	ND	0.003	0.01	0.021	ND	ND	0.049	ND	ND	0.001	ND	ND	0.26
AQ111605:1132NP4-2	11/16/2005	11:32	0.01	ND	0.058	0.004	0.015	0.004	0.013	0.002	0.002	ND	ND	0.005	0.017	ND	0.021	0.031	ND	ND	ND	ND	ND	0.18
AQ120805:935NP4-2	12/8/2005	9:35	0.003	ND	0.13	0.009	0.023	0.007	0.013	0.002	0.004	0.001	0.003	0.006	0.007 ^{2/}	ND	0.021	0.018	ND	0.001	0.003	ND	ND	0.24
AQ010406:850NP4-2	1/4/2006	8:50	0.006	ND	0.11	0.005	0.017	0.006	0.018	0.001	0.003	ND	0.003	0.005	0.007	ND	0.022	0.009	ND	0.001	ND	ND	ND	0.21
AQ020106:750NP4-2	2/1/2006	7:50	0.002	ND	0.086	ND	0.013	0.007	0.016	0.012	0.007	0.002	0.002	0.003	0.017	ND	0.01	ND	ND	0.002	ND	ND	ND	0.19
AQ032206:1220NP4-2 ^{4/}	3/22/2006	12:20	0.0014	ND	0.075	0.0044	0.013	0.007	0.0041	ND	0.0025	ND	ND	0.0034	0.0027	ND	0.0062	ND	ND	ND	ND	ND	ND	0.12
AQ041206:955NP4-2	4/12/2006	0:00	0.0012	ND	0.099	0.0076	0.014	0.0087	0.0015	ND	0.0011	ND	ND	0.0047	0.0013	ND	ND	ND	ND	ND	ND	ND	ND	0.14
AQ051706:1005NP4-2	5/17/2006	10:05	0.0028	0.001	0.065	0.0039	0.014	0.0074	0.0045	ND	0.0032	ND	ND	0.0036	0.003	0.0019	0.0088	ND	ND	ND	ND	ND	ND	0.12
AQ062106:805NP4-2	6/21/2006	8:05	ND	ND	0.025	0.0028	0.0081	0.0045	0.0036	ND	0.0014	ND	ND	0.0023	0.0019	0.0026	0.014	ND	ND	ND	0.001	ND	ND	0.07
AQ072006:905NP4-2	7/20/2006	9:05	ND	ND	0.022	ND	0.0078	0.0044	ND	ND	ND	ND	ND	ND	ND	ND	0.013	ND	ND	ND	ND	ND	ND	0.05
AQ082006:902NP4-2	8/24/2006	9:02	ND	ND	0.023	0.0017	0.0054	0.0045	0.0035	ND	0.0018	ND	ND	0.0019	0.0025	ND	0.013	ND	ND	ND	ND	ND	ND	0.06
AQ091906:915NP4-2	9/19/2006	9:15	0.0014	ND	0.045	0.0031	0.006	0.0058	0.0031	ND	0.0016	ND	ND	0.0025	0.0012	ND	0.02	ND	ND	ND	0.00092	0.0065	ND	0.10
Postcarbon			Parameters (mg/m3)																					TOTAL VOCs
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE		
AQ090805:910NP4-3	9/8/2005	9:10	ND	ND	0.016	ND	ND	ND	0.038	0.002	0.022	0.01	0.004	0.005	0.025 ^{1/}	ND	0.019	0.035	ND	0.002	ND	ND	ND	0.22
AQ100605:1234NP4-3	10/6/2005	12:34	0.004	ND	0.014	0.004	0.009	0.009	0.012	0.002	0.002	ND	0.002	0.004	0.02	ND	ND	0.084	ND	ND	ND	ND	ND	0.17
AQ111605:1134NP4-3	11/16/2005	11:34	0.003	ND	0.029	ND	0.014	ND	0.044	0.011	0.009	0.003	ND	0.005	0.03	ND	0.022	0.016	ND	0.002	ND	ND	ND	0.19
AQ120805:940NP4-3	12/8/2005	9:40	ND	ND	0.075	0.009	0.028	0.004	0.013	0.002	0.003	0.0003	0.003	0.009	0.009 ^{2/}	ND	0.025	0.02	ND	0.0008	ND	ND	ND	0.19
AQ010406:855NP4-3	1/4/2006	8:55	0.004	ND	0.096	0.006	0.022	0.003	0.017	0.004	0.004	ND	0.003	0.006	0.014	ND	0.022	ND	ND	0.001	ND	ND	ND	0.20
AQ020106:755NP4-3	2/1/2007	7:55	ND	0.002	0.075	0.004	0.016	0.003	0.004	0.003	0.001	ND	ND	0.005	0.017	ND	0.012	0.11 ^{3/}	ND	ND	ND	ND	ND	0.14
AQ032206:1225NP4-3 ^{4/}	3/22/2006	12:25	ND	ND	0.11	0.0046	0.016	0.0045	0.0029	ND	0.0021	ND	ND	0.0049	0.0025	0.0016	0.0055	ND	ND	ND	ND	ND	ND	0.15
AQ041206:1000NP4-3	4/12/2006	10:00	ND	ND	0.074	0.0065	0.011	0.0051	0.0018	ND	0.0015	ND	ND	0.0051	0.0013	ND	ND	ND	ND	ND	ND	ND	ND	0.11
AQ051706:1010NP4-3	5/17/2006	10:10	0.0046	ND	0.068	0.0045	0.015	0.0048	0.0046	0.00088	0.0025	ND	ND	0.0042	0.0022	0.0026	0.012	ND	ND	ND	0.00075	ND	ND	0.13
AQ062106:810NP4-3	6/21/2006	8:10	ND	ND	0.023	0.0027	0.0066	0.0036	0.0042	0.00075	0.0016	ND	ND	0.0018	0.0018	0.0023	0.015	ND	ND	ND	0.0008	ND	ND	0.06
AQ072006:910NP4-3	7/20/2006	9:10	ND	ND	0.017	ND	0.0058	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.012	ND	ND	ND	ND	ND	ND	0.03
AQ082406:904NP4-3	8/24/2006	9:04	ND	ND	0.025	0.0029	0.0082	0.0046	0.0038	0.00079	0.0018	ND	ND	0.002	0.0022	ND	0.014	ND	ND	ND	ND	ND	ND	0.07
AQ091906:920NP4-3	9/19/2006	9:20	ND	ND	0.035	0.0039	0.011	0.0062	0.0026	0.0011	0.0015	ND	ND	0.0031	0.0012	ND	0.016	ND	ND	ND	0.00092	0.00074	ND	0.08

Notes: 1. Methylene chloride and/or carbon disulfide concentrations in all three air samples collected during the July 7, August 9 and September 8, 2005 sampling events are greatly elevated due to suspected laboratory contamination. The methylene chloride concentration from the June 24, 2005 sampling event was used instead of the July 7, August 9 or September 8, 2005 methylene chloride concentrations to calculate the total VOCs for July, August and September 2005. The carbon disulfide concentration from the June 24, 2005 sampling event was used instead of the July 7 and August 9, 2005 carbon disulfide concentration to calculate the total VOCs for July and August 2005.

2. The methylene chloride concentration in the air samples collected on December 8, 2005 are suspected to be from laboratory contamination.

3. The laboratory procedure for the % bromomethane recovered exceeded the upper limit for quality control, therefore the bromomethane concentration for January 4, 2006 was used to calculate the total VOC concentration in for the February 1, 2006 samples.

4. The air samples from March 2006 and forward were analyzed using the TO-15 method at the Severn Trent Laboratory located in Knoxville, TN. Air sampling using the TO-17 method at the Severn Trent Laboratory in Connecticut is no longer available. The March 2006 air quality results appear to be a little lower or similar to prior air quality results. LBG will continue to monitor the air quality on a monthly basis.

PCE - Tetrachloroethane

TCE - Trichloroethane

TCA - 1,1,1-Trichloroethane

CE - Chloroethane

DCE - 1,1-Dichloroethene

DCA - 1,1-Dichloroethane

cis-DCE - cis-1,2-Dichloroethene

CT - Carbon Tetrachloride

CF - Chloroform

MC - Methylene Chloride

CM - Chloromethane

CD - Carbon Disulfide

BM - Bromomethane

CB - Chlorobenzene

EB - Ethylbenzene

VC - Vinyl Chloride

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE
RW-1	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	8.4*	ND<1	ND<1	6.9*
	7-Mar-06	ND<1	ND<1	ND<1	ND<1	5.2	ND<1	0.1650	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	1.7	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-2	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	1.5	4.78	0.213	ND<1	ND<1	ND<1	ND<1	ND<1	1.5	ND<1
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	12.0	ND<1	1.0	ND<1	ND<1	ND<1	3.5	0.0511	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	7.7	1.1	ND<1	ND<1	ND<1	ND<1	0.28	0.0298	ND<1	ND<1	ND<1	7.3 *	ND<1	ND<1	5.6 *
	9-Aug-05	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	3.74	0.107	ND<1	5.8	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	16	1.8	ND<1	ND<1	ND<1	ND<1	3.57	0.0704	ND<1	11	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	15	2.1	ND<1	ND<1	ND<1	ND<1	6.1	0.0269	ND<1	12	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	34	2.1	ND<1	ND<1	ND<1	ND<1	4.25	ND<0.02	ND<1	25	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	5.2	2.0	ND<1	ND<1	ND<1	ND<1	9.15	0.0696	ND<1	5.0	ND<1	4.8 *	1.0	ND<1	ND<1
	14-Feb-06	6.5	4.3	1.2	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	6.5	3.5	ND<1	ND<1	ND<1	ND<1	4.76	0.0395	ND<1	3.8	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	12.0	3.9	1.2	ND<1	ND<1	ND<1	4.24	0.0522	ND<1	12.0	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	19.0	5.1	ND<1	ND<1	ND<1	ND<1	5.95	0.063	ND<1	14.0	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	13.0	3.0	25	ND<1	ND<1	ND<1	3.57	0.093	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	8.0	3.4	60	ND<1	ND<1	ND<1	4.49	0.177	ND<1	7.5	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	11.0	1.1	25	ND<1	ND<1	ND<1	4.14	0.0172	ND<1	5.7	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	2.8	ND<1	200	ND<1	ND<1	ND<1	13.7	0.0184	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE
RW-3	15-Sep-04	2.7	21	8.7	ND<1	ND<1	ND<1	1.91	0.42	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	2.2	12	5.0	ND<1	ND<1	ND<1	2.09	1.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.5	6.5	2.6	ND<1	ND<1	ND<1	1.87	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.77	0.489	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	3	13	5.0	ND<1	ND<1	ND<1	1.89	1.36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	46.1	0.539	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	2.2	7.7	2.8	ND<1	ND<1	ND<1	1.85	0.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	9.91	10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.01	0.649	ND<1	ND<1	ND<1	9.1 *	ND<1	ND<1	6.9 *
	9-Aug-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.50	0.973	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	1	3.6	1.2	ND<1	ND<1	ND<1	2.03	0.71	ND<1	2.6	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	1.83	0.708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.11	0.556	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	1.7	17	7.9	ND<1	ND<1	ND<1	1.93	0.455	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<1
	14-Feb-06	1.4	8.9	2.5	ND<1	ND<1	ND<1	3.80	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	1.1	3.4	ND<1	ND<1	ND<1	ND<1	1.87	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	0.95	ND<1	ND<1	ND<1	ND<1	ND<1	1.99	0.649	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.06	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06 ^{1/}	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Aug-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Sep-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
RW-4	15-Sep-04	120	3.7	18	ND<1	ND<1	ND<1	2.98	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	94	ND<1	14	ND<1	ND<1	ND<1	3.65	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	130	4.2	11	ND<1	ND<1	ND<1	4.75	0.205	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	230	5.7	35	ND<1	ND<1	ND<1	1.90	1.62	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Apr-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	2-May-05	80	2.4	9.8	ND<1	ND<1	ND<1	3.77	0.0687	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Jun-05	74	2.6	ND<1	ND<1	ND<1	ND<1	9.95	9.28	ND<1	ND<1	ND<1	4.5 *	ND<1	ND<1	ND<1
	14-Jul-05	37	ND<1	8.9	ND<1	ND<1	ND<1	3.22	0.0185	ND<1	ND<1	ND<1	9.4 *	ND<1	ND<1	7.4 *
	9-Aug-05	31	ND<1	ND<1	ND<1	ND<1	ND<1	2.49	0.111	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	45	ND<1	6.0	ND<1	ND<1	ND<1	3.47	0.173	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.0777	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Dec-05	64	2.0	1.5	ND<1	ND<1	ND<1	2.82	0.0302	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	15	ND<1	9.5	ND<1	ND<1	ND<1	7.78	0.0412	ND<1	ND<1	ND<1	5.2 *	ND<1	ND<1	ND<1
	14-Feb-06	24	ND<1	8.7	ND<1	ND<1	ND<1	6.05	0.0627	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	22	ND<1	7.0	ND<1	ND<1	ND<1	3.50	0.0476	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	26	1.5	6.2	ND<1	ND<1	2	4.17	0.0963	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	26	ND<1	ND<1	ND<1	ND<1	ND<1	3.15	0.109	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	23	ND<1	8.4	ND<1	ND<1	ND<1	9.23	0.086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	14	ND<1	9.4	ND<1	ND<1	ND<1	4.10	0.155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	23	ND<1	ND<1	ND<1	ND<1	ND<1	8.60	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	9	ND<1	7.5	ND<1	ND<1	ND<1	5.95	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE
RW-5	15-Sep-04	24	ND<1	6.5	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	16	ND<1	5.2	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	ND<1	1.4	ND<1
	3-Nov-04	15	ND<1	6.4	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	28	ND<1	28	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	9	ND<1	4.1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	13	ND<1	5.7	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	8.2	ND<1	1.6	ND<1	ND<1	ND<1	0.0358	ND<0.02	ND<1	ND<1	ND<1	9.5 *	ND<1	ND<1	5.6 *
	9-Aug-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0227	0.0303	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	8	ND<1	3.8	ND<1	ND<1	ND<1	0.0185	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0482	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	0.0468	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	2.3	ND<1	2.0	ND<1	ND<1	ND<1	0.0558	0.0119	ND<1	ND<1	ND<1	4.6*	ND<1	ND<1	ND<1
	14-Feb-06	2.9	ND<1	3.8	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	2.6	ND<1	3.0	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	1.4	ND<1	ND<1	ND<1	1.5	2.4	0.0786	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	2.4	ND<1	2.6	ND<1	ND<1	ND<1	0.195	0.012	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	1.3	ND<1	3.1	ND<1	ND<1	ND<1	0.184	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.09	0.0116	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.194	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-6	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	94	ND<1	1.6	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	ND<1
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	2.5	0.0111	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	200	3.8	16	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	69	1.6	13	ND<1	ND<1	ND<1	0.067	0.0195	ND<1	ND<1	2.1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	64	1.6	9.5	ND<1	ND<1	ND<1	0.0406	ND<0.02	ND<1	ND<1	ND<1	7.2 *	ND<1	ND<1	7 *
	9-Aug-05	49	ND<1	12	ND<1	ND<1	ND<1	0.088	0.0366	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	100	1.6	12	ND<1	ND<1	ND<1	1.3	0.0143	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	68	ND<1	ND<1	ND<1	ND<1	ND<1	0.144	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	100	2.1	20	ND<1	ND<1	ND<1	0.139	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	41	1.1	16	ND<1	ND<1	ND<1	0.189	ND<0.02	ND<1	ND<1	ND<1	4.6*	ND<1	ND<1	ND<1
	22-Feb-06	63	1.6	15	ND<1	ND<1	ND<1	0.116	0.0155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	65	1.2	17	ND<1	ND<1	ND<1	0.0429	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	62	2.1	22	ND<1	ND<1	2	0.24	0.0137	0.97	ND<1	1.1	ND<1	ND<1	ND<1	ND<1
	17-May-06	68	ND<1	18	ND<1	ND<1	ND<1	0.17	0.019	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	83	ND<1	20	ND<1	ND<1	ND<1	0.075	0.025	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	45	1.5	24	ND<1	ND<1	ND<1	1.01	0.0169	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	30	ND<1	22	ND<1	ND<1	ND<1	5.36	0.0563	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	46	ND<1	27	ND<1	ND<1	ND<1	0.916	0.0078	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE
RW-7	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	0.0272	0.00876	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	32	1.0	4.7	ND<1	ND<1	ND<1	0.0753	0.02	1.5	ND<1	ND<1	1.1	ND<1	ND<1	ND<1
	14-Jul-05	32	ND<1	2.2	ND<1	ND<1	ND<1	0.0155	ND<0.02	ND<1	ND<1	ND<1	8.7 *	ND<1	ND<1	7.2 *
	9-Aug-05	31	ND<1	6.2	ND<1	ND<1	ND<1	0.0903	0.0409	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	39	ND<1	3.4	ND<1	ND<1	ND<1	0.0452	ND<0.02	1.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.536	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	70	ND<1	12.0	ND<1	ND<1	ND<1	0.253	ND<0.02	4.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	26	ND<1	5.0	ND<1	ND<1	ND<1	0.343	ND<0.02	2.2	ND<1	ND<1	5.0 *	ND<1	ND<1	ND<1
	14-Feb-06	36	ND<1	4.1	ND<1	ND<1	ND<1	0.0332	ND<0.02	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	38	ND<1	4.1	ND<1	ND<1	ND<1	0.143	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	49	1.6	7.4	ND<1	ND<1	ND<1	0.0912	0.0175	3.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	59	ND<1	ND<1	ND<1	ND<1	ND<1	0.126	0.026	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	44	ND<1	4.6	ND<1	ND<1	ND<1	0.081	0.013	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Aug-06	39	ND<1	7.9	ND<1	ND<1	ND<1	0.3	0.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	36	ND<1	7.5	ND<1	ND<1	ND<1	0.1	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-8	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	NM
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	28.8	0.235	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	10.6	0.271	3.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	16	ND<1	22	ND<1	ND<1	ND<1	15.6	0.149	15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.075	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.321	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	7.33	0.073	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	2.7	ND<1	5.8	ND<1	ND<1	ND<1	7.06	0.325	2.1	ND<1	ND<1	1.7	ND<1	ND<1	ND<1
	14-Jul-05	2.6	ND<1	3.4	ND<1	ND<1	ND<1	8.33	0.017	ND<1	ND<1	ND<1	8.5 *	ND<1	ND<1	8.2 *
	9-Aug-05	1.8	ND<1	2.9	ND<1	ND<1	ND<1	0.24	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	2.9	ND<1	4.2	ND<1	ND<1	ND<1	7.53	0.255	2.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	7.65	0.106	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	5.0	ND<1	ND<1	ND<1	5.19	0.021	3.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	1.3	ND<1	3.7	ND<1	ND<1	ND<1	7.25	0.097	2.0	ND<1	ND<1	4.9 *	ND<1	ND<1	ND<1
	14-Feb-06	1.5	ND<1	3.0	ND<1	ND<1	ND<1	8.06	ND<0.02	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	2.8	ND<1	ND<1	ND<1	8.33	0.064	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	2.1	0.9	4.5	ND<1	ND<1	ND<1	7.27	0.823	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.03	0.056	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	ND<1	ND<1	2.8	ND<1	ND<1	ND<1	8.40	0.897	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	1.0	ND<1	4.0	ND<1	ND<1	ND<1	10.80	0.175	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	3.2	ND<1	ND<1	ND<1	5.98	1.860	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	3.0	ND<1	ND<1	ND<1	7.44	0.009	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE
RW-9	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	1.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0596	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	5.8	ND<1	ND<1	ND<1	1.38	0.149	0.9	ND<1	1.2	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	3.4	ND<1	3.1	ND<1	ND<1	ND<1	2.55	0.238	ND<1	ND<1	ND<1	6.9 *	ND<1	ND<1	7.3 *
	9-Aug-05	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	0.994	0.0734	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	1.2	ND<1	2.0	ND<1	ND<1	ND<1	3.64	0.161	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.31	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	2.9	ND<1	ND<1	ND<1	2.01	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	2.36	0.0905	ND<1	ND<1	ND<1	4.9 *	ND<1	ND<1	ND<1
	14-Feb-06	2.1	ND<1	1.8	ND<1	ND<1	ND<1	5.23	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.41	0.333	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	1.93	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.054	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-June-06 ^{2/}	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.695	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0165	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND<0.02	ND<1	ND<1	ND<1	18*	ND<1	ND<1	ND<1

ND: Not detected

<#: Less than method detection limit
ug/L: Micrograms per liter

-: Not analyzed

ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site.
Bold values indicate an exceedance of the ARAR standard established for the site.

PCE: Tetrachloroethylene

TCE: Trichloroethene

TCA: 1,1,1-Trichloroethane

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl Tertiary Butyl Ether

NM: Not Measured

NE indicates that the ARAR goal was not established for this compound by the EPA.

*Concentrations with an asterisk following them are due to laboratory contamination.


^{1/} RW-3 is currently non operational weighting for the reprogramming of the drive for the new 4 amp pump.

^{2/} RW-9 was being rehabilitated during this sampling event, thus no water sample was collected.

GRAPHS


GRAPH 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
(September 1, 2006 through September 30, 2006)




GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER




GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION FOR SELECT RECOVERY WELLS



APPENDIX I
SEPTEMBER 2006 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, September 12, 200

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0609038

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 9/7/2006 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0609038

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0609038-01A	WQ090506:800 NP2-6		9/5/2006	9/7/2006
0609038-01B	WQ090506:800 NP2-6		9/5/2006	9/7/2006
0609038-01C	WQ090506:800 NP2-6		9/5/2006	9/7/2006
0609038-02A	WQ090506:805 NP2-7		9/5/2006	9/7/2006
0609038-02B	WQ090506:805 NP2-7		9/5/2006	9/7/2006
0609038-02C	WQ090506:805 NP2-7		9/5/2006	9/7/2006
0609038-03A	WQ090506:810 NP2-10		9/5/2006	9/7/2006
0609038-03B	WQ090506:810 NP2-10		9/5/2006	9/7/2006
0609038-03C	WQ090506:810 NP2-10		9/5/2006	9/7/2006



WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-01A

Client Sample ID: WQ090506:800 NP2-6
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11						
		SW8260B		SW5030A		Analyst: MMR
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
2-Butanone	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
2-Hexanone	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Acetone	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Benzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Bromobenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Bromoform	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Bromomethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-01A

Client Sample ID: WQ090506:800 NP2-6
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
Chloroethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Chloroform	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Chloromethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Dibromomethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/8/2006 1:24:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Methylene chloride	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Naphthalene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
o-Xylene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Styrene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Toluene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Trichloroethene	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/8/2006 1:24:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/8/2006 1:24:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-01B

Client Sample ID: WQ090506:800 NP2-6
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.19	0.0200		mg/L	1	9/7/2006 2:02:41 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-01C

Client Sample ID: WQ090506:800 NP2-6
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.385	0.0200		mg/L	1	9/7/2006 2:00:42 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-02A

Client Sample ID: WQ090506:805 NP2-7
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
2-Butanone	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
2-Hexanone	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Acetone	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Benzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Bromobenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Bromoform	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Bromomethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-02A

Client Sample ID: WQ090506:805 NP2-7
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
Chloroethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Chloroform	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Chloromethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Dibromomethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/8/2006 2:03:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Methylene chloride	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Naphthalene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
o-Xylene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Styrene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Toluene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Trichloroethene	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/8/2006 2:03:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/8/2006 2:03:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-02B

Client Sample ID: WQ090506:805 NP2-7
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.92	0.0200		mg/L	1	9/7/2006 2:06:59 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-02C

Client Sample ID: WQ090506:805 NP2-7
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.323	0.0200		mg/L	1	9/7/2006 2:04:42 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-03A

Client Sample ID: WQ090506:810 NP2-10
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
2-Butanone	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
2-Hexanone	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Acetone	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Benzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Bromobenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Bromoform	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Bromomethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-03A

Client Sample ID: WQ090506:810 NP2-10
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
Chloroethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Chloroform	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Chloromethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Dibromomethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/8/2006 2:40:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Methylene chloride	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Naphthalene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
o-Xylene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Styrene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Toluene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Trichloroethene	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/8/2006 2:40:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/8/2006 2:40:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-03B

Client Sample ID: WQ090506:810 NP2-10
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.24	0.0200		mg/L	1	9/7/2006 2:35:31 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.


Date: 12-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609038
Project: Rowe Industries
Lab ID: 0609038-03C

Client Sample ID: WQ090506:810 NP2-10
Tag Number:
Collection Date: 9/5/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.538	0.0200		mg/L	1	9/7/2006 2:16:17 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	114	1.00		mg/L	1	9/11/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Monday, September 18, 2006

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0609082

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 9/12/2006 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 18-Sep-06**CLIENT:** Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0609082**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0609082-01A	WQ091206:800 NP2-6	11609	9/12/2006 8:00:00 AM	9/12/2006
0609082-01B	WQ091206:800 NP2-6	11609	9/12/2006 8:00:00 AM	9/12/2006
0609082-01C	WQ091206:800 NP2-6	11609	9/12/2006 8:00:00 AM	9/12/2006
0609082-02A	WQ091206:805 NP2-7	11609	9/12/2006 8:05:00 AM	9/12/2006
0609082-02B	WQ091206:805 NP2-7	11609	9/12/2006 8:05:00 AM	9/12/2006
0609082-02C	WQ091206:805 NP2-7	11609	9/12/2006 8:05:00 AM	9/12/2006
0609082-03A	WQ091206:810 NP2-10	11609	9/12/2006 8:10:00 AM	9/12/2006
0609082-03B	WQ091206:810 NP2-10	11609	9/12/2006 8:10:00 AM	9/12/2006
0609082-03C	WQ091206:810 NP2-10	11609	9/12/2006 8:10:00 AM	9/12/2006

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 18-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609082
Project: Rowe Industries
Lab ID: 0609082-01A

Client Sample ID: WQ091206:800 NP2-6
Tag Number: 11609
Collection Date: 9/12/2006 8:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
2-Butanone	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
2-Hexanone	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Acetone	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Benzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609082
Project: Rowe Industries
Lab ID: 0609082-01A

Client Sample ID: WQ091206:800 NP2-6
Tag Number: 11609
Collection Date: 9/12/2006 8:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
Chloroethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2006 3:22:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Styrene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Tetrachloroethene	13	1.0		µg/L	1	9/14/2006 3:22:00 PM
Toluene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2006 3:22:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2006 3:22:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 18-Sep-06**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ091206:800 NP2-6**Lab Order:** 0609082**Tag Number:** 11609**Project:** Rowe Industries**Collection Date:** 9/12/2006 8:00:00 AM**Lab ID:** 0609082-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.31	0.0200		mg/L	1	9/14/2006 1:20:06 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609082
Project: Rowe Industries
Lab ID: 0609082-01C

Client Sample ID: WQ091206:800 NP2-6
Tag Number: 11609
Collection Date: 9/12/2006 8:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0700	0.0200		mg/L	1	9/14/2006 1:17:54 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609082
Project: Rowe Industries
Lab ID: 0609082-02A

Client Sample ID: WQ091206:805 NP2-7
Tag Number: 11609
Collection Date: 9/12/2006 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
2-Butanone	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
2-Hexanone	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Acetone	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Benzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609082
Project: Rowe Industries
Lab ID: 0609082-02A

Client Sample ID: WQ091206:805 NP2-7
Tag Number: 11609
Collection Date: 9/12/2006 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
Chloroethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2006 4:54:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Styrene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Toluene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2006 4:54:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2006 4:54:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 18-Sep-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ091206:805 NP2-7
Lab Order:	0609082	Tag Number:	11609
Project:	Rowe Industries	Collection Date:	9/12/2006 8:05:00 AM
Lab ID:	0609082-02B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.60	0.0200		mg/L	1	9/14/2006 1:27:41 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 18-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609082
Project: Rowe Industries
Lab ID: 0609082-02C

Client Sample ID: WQ091206:805 NP2-7
Tag Number: 11609
Collection Date: 9/12/2006 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.124	0.0200		mg/L	1	9/14/2006 1:25:46 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609082
Project: Rowe Industries
Lab ID: 0609082-03A

Client Sample ID: WQ091206:810 NP2-10
Tag Number: 11609
Collection Date: 9/12/2006 8:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
2-Butanone	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
2-Hexanone	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Acetone	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Benzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609082
Project: Rowe Industries
Lab ID: 0609082-03A

Client Sample ID: WQ091206:810 NP2-10
Tag Number: 11609
Collection Date: 9/12/2006 8:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: MMR
Chloroethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2006 7:34:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Styrene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Toluene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2006 7:34:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2006 7:34:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Sep-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ091206:810 NP2-10
Lab Order:	0609082	Tag Number:	11609
Project:	Rowe Industries	Collection Date:	9/12/2006 8:10:00 AM
Lab ID:	0609082-03B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	3.66	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 9/14/2006 1:30:23 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Sep-06

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ091206:810 NP2-10**Lab Order:** 0609082**Tag Number:** 11609**Project:** Rowe Industries**Collection Date:** 9/12/2006 8:10:00 AM**Lab ID:** 0609082-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.173	0.0200		mg/L	1	9/14/2006 1:32:50 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	116	1.00		mg/L	1	9/14/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Friday, September 29, 2006

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0609178

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 9/21/2006 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0609178

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0609178-01A	WQ091906: 930 NP2-6	10277	9/19/2006	9/21/2006
0609178-01B	WQ091906: 930 NP2-6	10277	9/19/2006	9/21/2006
0609178-02A	WQ091906: 935 NP2-7	10277	9/19/2006	9/21/2006
0609178-02B	WQ091906: 935 NP2-7	10277	9/19/2006	9/21/2006
0609178-03A	WQ091906: 940 NP2-10	10277	9/19/2006	9/21/2006
0609178-03B	Wq091906: 940 NP2-10	10277	9/19/2006	9/21/2006

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609178
Project: Rowe Industries
Lab ID: 0609178-01A

Client Sample ID: WQ091906: 930 NP2-6
Tag Number: 10277
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.99	0.0200		mg/L	1	9/28/2006 1:45:09 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,1,1-Trichloroethane	23	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
2-Butanone	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
2-Hexanone	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Acetone	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Benzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Bromobenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Bromoform	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Bromomethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/25/2006 12:16:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609178
Project: Rowe Industries
Lab ID: 0609178-01A

Client Sample ID: WQ091906: 930 NP2-6
Tag Number: 10277
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: LDS
Carbon tetrachloride	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Chloroethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Chloroform	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Chloromethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Dibromomethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/25/2006 12:16:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Methylene chloride	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Naphthalene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
o-Xylene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Styrene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Tetrachloroethene	9.4	1.0		µg/L	1	9/25/2006 12:16:00 PM
Toluene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Trichloroethene	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/25/2006 12:16:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/25/2006 12:16:00 PM

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ091906: 930 NP2-6**Lab Order:** 0609178**Tag Number:** 10277**Project:** Rowe Industries**Collection Date:** 9/19/2006**Lab ID:** 0609178-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	U	0.0200		mg/L	1	9/28/2006 1:34:44 PM

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609178
Project: Rowe Industries
Lab ID: 0609178-02A

Client Sample ID: WQ091906: 935 NP2-7
Tag Number: 10277
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.32	0.0200		mg/L	1	9/28/2006 1:50:16 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
2-Butanone	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
2-Hexanone	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Acetone	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Benzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Bromobenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Bromoform	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Bromomethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/25/2006 12:53:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609178
Project: Rowe Industries
Lab ID: 0609178-02A

Client Sample ID: WQ091906: 935 NP2-7
Tag Number: 10277
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: LDS
Carbon tetrachloride	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Chloroethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Chloroform	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Chloromethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Dibromomethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/25/2006 12:53:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Methylene chloride	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Naphthalene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
o-Xylene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Styrene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Toluene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Trichloroethene	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/25/2006 12:53:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/25/2006 12:53:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 29-Sep-06**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ091906; 935 NP2-7**Lab Order:** 0609178**Tag Number:** 10277**Project:** Rowe Industries**Collection Date:** 9/19/2006**Lab ID:** 0609178-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0505	0.0200		mg/L	1	9/28/2006 1:47:46 PM

Qualifiers:

B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609178
Project: Rowe Industries
Lab ID: 0609178-03A

Client Sample ID: WQ091906: 940 NP2-10
Tag Number: 10277
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.35	0.0200		mg/L	1	9/28/2006 1:56:09 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
2-Butanone	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
2-Hexanone	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Acetone	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Benzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Bromobenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Bromoform	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Bromomethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/25/2006 1:32:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609178
Project: Rowe Industries
Lab ID: 0609178-03A

Client Sample ID: WQ091906: 940 NP2-10
Tag Number: 10277
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		SW5030A		Analyst: LDS
Carbon tetrachloride	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Chloroethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Chloroform	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Chloromethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Dibromomethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/25/2006 1:32:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Methylene chloride	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Naphthalene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
o-Xylene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Styrene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Toluene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Trichloroethene	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/25/2006 1:32:00 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	70.0	1.00		mg/L	1	9/25/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609178
Project: Rowe Industries
Lab ID: 0609178-03B

Client Sample ID: Wq091906: 940 NP2-10
Tag Number: 10277
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0653	0.0200		mg/L	1	9/28/2006 1:52:51 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Monday, October 09, 2006

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0609275

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 9/29/2006 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 09-Oct-06**CLIENT:** Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0609275**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0609275-01A	WQ092706: 800 NP2-6	10278	9/27/2006	9/29/2006
0609275-01B	WQ092706: 800 NP2-6	10278	9/27/2006	9/29/2006
0609275-02A	WQ092706:805 NP2-7	10278	9/27/2006	9/29/2006
0609275-02B	WQ092706:805 NP2-7	10278	9/27/2006	9/29/2006
0609275-03A	WQ092706:810 NP2-10	10278	9/27/2006	9/29/2006
0609275-03B	WQ092706:810 NP2-10	10278	9/27/2006	9/29/2006

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 09-Oct-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609275
Project: Rowe Industries
Lab ID: 0609275-01A

Client Sample ID: WQ092706: 800 NP2-6
Tag Number: 10278
Collection Date: 9/27/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	6.40	0.0200		mg/L	1	10/3/2006 12:30:18 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,1,1-Trichloroethane	7.8	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
2-Butanone	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
2-Hexanone	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Acetone	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Benzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Bromobenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Bromochloromethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Bromodichloromethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Bromoform	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Bromomethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Carbon disulfide	U	1.0		µg/L	1	10/4/2006 1:46:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 09-Oct-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609275
Project: Rowe Industries
Lab ID: 0609275-01A

Client Sample ID: WQ092706: 800 NP2-6
Tag Number: 10278
Collection Date: 9/27/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Carbon tetrachloride	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Chlorobenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Chloroethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Chloroform	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Chloromethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Dibromochloromethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Dibromomethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Ethylbenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Isopropylbenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
m,p-Xylene	U	2.0		µg/L	1	10/4/2006 1:46:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Methylene chloride	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Naphthalene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
n-Butylbenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
n-Propylbenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
o-Xylene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Styrene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Tetrachloroethene	9.5	1.0		µg/L	1	10/4/2006 1:46:00 AM
Toluene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Trichloroethene	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Vinyl acetate	U	1.0		µg/L	1	10/4/2006 1:46:00 AM
Vinyl chloride	U	1.0		µg/L	1	10/4/2006 1:46:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 09-Oct-06**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ092706: 800 NP2-6**Lab Order:** 0609275**Tag Number:** 10278**Project:** Rowe Industries**Collection Date:** 9/27/2006**Lab ID:** 0609275-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0100	0.0200	J	mg/L	1	10/3/2006 12:32:56 PM

Qualifiers:

B Analyte detected in the associated Method Blank

H Holding times for preparation or analysis exceeded

ND Not Detected at the Reporting Limit

U Indicates the compound was analyzed for but not detected

E Value above quantitation range

J Analyte detected below quantitation limits

S Spike Recovery outside accepted recovery limits

X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 09-Oct-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609275
Project: Rowe Industries
Lab ID: 0609275-02A

Client Sample ID: WQ092706:805 NP2-7
Tag Number: 10278
Collection Date: 9/27/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	5.91	0.0200		mg/L	1	10/3/2006 12:38:43 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
2-Butanone	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
2-Hexanone	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Acetone	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Benzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Bromobenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Bromochloromethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Bromodichloromethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Bromoform	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Bromomethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Carbon disulfide	U	1.0		µg/L	1	10/4/2006 2:24:00 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 09-Oct-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609275
Project: Rowe Industries
Lab ID: 0609275-02A

Client Sample ID: WQ092706:805 NP2-7
Tag Number: 10278
Collection Date: 9/27/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Carbon tetrachloride	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Chlorobenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Chloroethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Chloroform	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Chloromethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Dibromochloromethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Dibromomethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Ethylbenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Isopropylbenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
m,p-Xylene	U	2.0		µg/L	1	10/4/2006 2:24:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Methylene chloride	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Naphthalene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
n-Butylbenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
n-Propylbenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
o-Xylene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Styrene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Tetrachloroethene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Toluene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Trichloroethene	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Vinyl acetate	U	1.0		µg/L	1	10/4/2006 2:24:00 AM
Vinyl chloride	U	1.0		µg/L	1	10/4/2006 2:24:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 09-Oct-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609275
Project: Rowe Industries
Lab ID: 0609275-02B

Client Sample ID: WQ092706:805 NP2-7
Tag Number: 10278
Collection Date: 9/27/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0833	0.0200		mg/L	1	10/3/2006 12:36:11 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 09-Oct-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609275
Project: Rowe Industries
Lab ID: 0609275-03A

Client Sample ID: WQ092706:810 NP2-10
Tag Number: 10278
Collection Date: 9/27/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	14.1	0.0200		mg/L	1	10/3/2006 12:45:25 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
2-Butanone	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
2-Hexanone	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
4-Methyl-2-pentanone	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Acetone	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Benzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Bromobenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Bromochloromethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Bromodichloromethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Bromoform	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Bromomethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Carbon disulfide	U	1.0		µg/L	1	10/4/2006 3:02:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 09-Oct-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609275
Project: Rowe Industries
Lab ID: 0609275-03A

Client Sample ID: WQ092706:810 NP2-10
Tag Number: 10278
Collection Date: 9/27/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Carbon tetrachloride	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Chlorobenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Chloroethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Chloroform	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Chloromethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Dibromochloromethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Dibromomethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Ethylbenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Isopropylbenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
m,p-Xylene	U	2.0		µg/L	1	10/4/2006 3:02:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Methylene chloride	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Naphthalene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
n-Butylbenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
n-Propylbenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
o-Xylene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Styrene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Tetrachloroethene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Toluene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Trichloroethene	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Vinyl acetate	U	1.0		µg/L	1	10/4/2006 3:02:00 AM
Vinyl chloride	U	1.0		µg/L	1	10/4/2006 3:02:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 09-Oct-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609275
Project: Rowe Industries
Lab ID: 0609275-03B

Client Sample ID: WQ092706:810 NP2-10
Tag Number: 10278
Collection Date: 9/27/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.137	0.0200		mg/L	1	10/3/2006 12:41:04 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	114	1.00		mg/L	1	10/2/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Friday, September 29, 2006

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0609177

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 7 sample(s) on 9/21/2006 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 29-Sep-06**CLIENT:** Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0609177**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0609177-01A	GWQ091906: 800 NP1-1-2	10276	9/19/2006	9/21/2006
0609177-01B	GWQ091906: 800 NP1-1-2	10276	9/19/2006	9/21/2006
0609177-02A	GWQ091906: 810 NP1-1-4	10276	9/19/2006	9/21/2006
0609177-02B	GWQ091906: 810 NP1-1-4	10276	9/19/2006	9/21/2006
0609177-03A	GWQ091906: 810 NP1-1-5	10276	9/19/2006	9/21/2006
0609177-03B	GWQ091906: 810 NP1-1-5	10276	9/19/2006	9/21/2006
0609177-04A	GWQ091906: 810 NP1-1-6	10276	9/19/2006	9/21/2006
0609177-04B	GWQ091906: 810 NP1-1-6	10276	9/19/2006	9/21/2006
0609177-05A	GWQ091906: 810 NP1-1-7	10276	9/19/2006	9/21/2006
0609177-05B	GWQ091906: 810 NP1-1-7	10276	9/19/2006	9/21/2006
0609177-06A	GWQ091906: 810 NP1-1-8	10276	9/19/2006	9/21/2006
0609177-06B	GWQ091906: 810 NP1-1-8	10276	9/19/2006	9/21/2006
0609177-07A	GWQ091906: 810 NP1-1-9	10276	9/19/2006	9/21/2006
0609177-07B	GWQ091906: 810 NP1-1-9	10276	9/19/2006	9/21/2006

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-01A

Client Sample ID: GWQ091906: 800 NP-1-2
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						
Hardness, Calcium/Magnesium (As CaCO3)	47.0	M2340 B 1.00		mg/L	1	Analyst: JP 9/28/2006
TOTAL IRON, MANGANESE						
Iron	13.7	E200.7 0.0200		mg/L	1	Analyst: JP 9/28/2006 12:51:36 PM
Manganese	0.573	0.0200		mg/L	1	9/28/2006 12:51:36 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11						
		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,1,1-Trichloroethane	200	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
2-Butanone	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
2-Hexanone	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Acetone	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Benzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Bromobenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-01A

Client Sample ID: GWQ091906: 800 NP-1-2
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Bromodichloromethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Bromoform	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Bromomethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Chloroethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Chloroform	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Chloromethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Dibromomethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/27/2006 7:32:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Methylene chloride	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Naphthalene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
o-Xylene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Styrene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Tetrachloroethene	2.8	1.0		µg/L	1	9/27/2006 7:32:00 PM
Toluene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Trichloroethene	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/27/2006 7:32:00 PM
TURBIDITY		E180.1		Analyst: KK		
Turbidity	4.20	1.00		NTU	1	9/21/2006
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ091906: 800 NP-1-2

Lab Order: 0609177

Tag Number: 10276

Project: Rowe Industries

Collection Date: 9/19/2006

Lab ID: 0609177-01A

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	130	1.00		mg/L	1	9/25/2006

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-01B

Client Sample ID: GWQ091906: 800 NP-1-2
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0184	0.0200	J	mg/L	1	9/28/2006 12:49:39 PM
Manganese	0.578	0.0200		mg/L	1	9/28/2006 12:49:39 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-02A

Client Sample ID: GWQ091906: 810 NP1-1-4
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	32.9	1.00		mg/L	1	9/28/2006
TOTAL IRON, MANGANESE		E200.7				Analyst: JP
Iron	5.95	0.0200		mg/L	1	9/28/2006 12:56:42 PM
Manganese	1.15	0.0200		mg/L	1	9/28/2006 12:56:42 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,1,1-Trichloroethane	7.5	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
2-Butanone	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
2-Hexanone	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Acetone	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Benzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Bromobenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-02A

Client Sample ID: GWQ091906: 810 NP1-1-4
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Bromodichloromethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Bromoform	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Bromomethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Chloroethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Chloroform	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Chloromethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Dibromomethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/27/2006 8:11:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Methylene chloride	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Naphthalene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
o-Xylene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Styrene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Tetrachloroethene	9.0	1.0		µg/L	1	9/27/2006 8:11:00 PM
Toluene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Trichloroethene	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/27/2006 8:11:00 PM
TURBIDITY		E180.1		Analyst: KK		
Turbidity	3.30	1.00		NTU	1	9/21/2006
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ091906: 810 NP1-1-4
Lab Order:	0609177	Tag Number:	10276
Project:	Rowe Industries	Collection Date:	9/19/2006
Lab ID:	0609177-02A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	130	1.00		mg/L	1	9/25/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-02B

Client Sample ID: GWQ091906: 810 NP1-1-4
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	U	0.0200		mg/L	1	9/28/2006 12:54:39 PM
Manganese	1.22	0.0200		mg/L	1	9/28/2006 12:54:39 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-03A

Client Sample ID: GWQ091906: 810 NP1-1-5
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	37.5	1.00		mg/L	1	9/28/2006
TOTAL IRON, MANGANESE		E200.7				Analyst: JP
Iron	0.194	0.0200		mg/L	1	9/28/2006 1:09:57 PM
Manganese	0.00980	0.0200	J	mg/L	1	9/28/2006 1:09:57 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
2-Butanone	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
2-Hexanone	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Acetone	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Benzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Bromobenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-03A

Client Sample ID: GWQ091906: 810 NP1-1-5
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Bromodichloromethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Bromoform	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Bromomethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Chloroethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Chloroform	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Chloromethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Dibromomethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/27/2006 8:48:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Methylene chloride	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Naphthalene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
o-Xylene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Styrene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Toluene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Trichloroethene	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/27/2006 8:48:00 PM
TURBIDITY		E180.1		Analyst: KK		
Turbidity	1.70	1.00		NTU	1	9/21/2006
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-03A

Client Sample ID: GWQ091906: 810 NP1-1-5
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	158	1.00		mg/L	1	9/25/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-03B

Client Sample ID: GWQ091906: 810 NP1-1-5
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	U	0.0200		mg/L	1	9/28/2006 12:58:52 PM
Manganese	0.0103	0.0200	J	mg/L	1	9/28/2006 12:58:52 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-04A

Client Sample ID: GWQ091906: 810 NP1-1-6
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	30.7	1.00		mg/L	1	9/28/2006
TOTAL IRON, MANGANESE		E200.7				Analyst: JP
Iron	0.916	0.0200		mg/L	1	9/28/2006 1:15:19 PM
Manganese	0.156	0.0200		mg/L	1	9/28/2006 1:15:19 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,1,1-Trichloroethane	27	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
2-Butanone	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
2-Hexanone	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Acetone	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Benzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Bromobenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-04A

Client Sample ID: GWQ091906: 810 NP1-1-6
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Bromodichloromethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Bromoform	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Bromomethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Chloroethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Chloroform	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Chloromethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Dibromomethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/27/2006 9:27:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Methylene chloride	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Naphthalene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
o-Xylene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Styrene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Tetrachloroethene	46	1.0		µg/L	1	9/27/2006 9:27:00 PM
Toluene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Trichloroethene	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/27/2006 9:27:00 PM
TURBIDITY		E180.1		Analyst: KK		
Turbidity	U	1.00		NTU	1	9/21/2006
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 29-Sep-06**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ091906: 810 NP1-1-6**Lab Order:** 0609177**Tag Number:** 10276**Project:** Rowe Industries**Collection Date:** 9/19/2006**Lab ID:** 0609177-04A**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	96.0	1.00		mg/L	1	9/25/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-04B

Client Sample ID: GWQ091906: 810 NP1-1-6
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.00780	0.0200	J	mg/L	1	9/28/2006 1:13:21 PM
Manganese	0.149	0.0200		mg/L	1	9/28/2006 1:13:21 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-05A

Client Sample ID: GWQ091906: 810 NP1-1-7
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						
		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	29.2	1.00		mg/L	1	9/28/2006
TOTAL IRON, MANGANESE						
		E200.7				Analyst: JP
Iron	0.116	0.0200		mg/L	1	9/28/2006 1:20:33 PM
Manganese	0.0571	0.0200		mg/L	1	9/28/2006 1:20:33 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11						
		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,1,1-Trichloroethane	7.5	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
2-Butanone	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
2-Hexanone	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Acetone	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Benzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Bromobenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-05A

Client Sample ID: GWQ091906: 810 NP1-1-7
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Bromodichloromethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Bromoform	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Bromomethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Chloroethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Chloroform	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Chloromethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Dibromomethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/27/2006 10:05:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Methylene chloride	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Naphthalene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
o-Xylene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Styrene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Tetrachloroethene	36	1.0		µg/L	1	9/27/2006 10:05:00 PM
Toluene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Trichloroethene	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/27/2006 10:05:00 PM
TURBIDITY		E180.1		Analyst: KK		
Turbidity	U	1.00		NTU	1	9/21/2006
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ091906: 810 NP1-1-7**Lab Order:** 0609177**Tag Number:** 10276**Project:** Rowe Industries**Collection Date:** 9/19/2006**Lab ID:** 0609177-05A**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	88.0	1.00		mg/L	1	9/25/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-05B

Client Sample ID: GWQ091906: 810 NP1-1-7
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	U	0.0200		mg/L	1	9/28/2006 1:17:33 PM
Manganese	0.0526	0.0200		mg/L	1	9/28/2006 1:17:33 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-06A

Client Sample ID: GWQ091906: 810 NP1-1-8
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						
Hardness, Calcium/Magnesium (As CaCO3)	20.7	1.00		mg/L	1	9/28/2006
TOTAL IRON, MANGANESE						
Iron	7.44	0.0200		mg/L	1	9/28/2006 1:25:43 PM
Manganese	0.635	0.0200		mg/L	1	9/28/2006 1:25:43 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11						
						Analyst: JP
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,1,1-Trichloroethane	3.0	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
2-Butanone	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
2-Hexanone	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Acetone	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Benzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Bromobenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-06A

Client Sample ID: GWQ091906: 810 NP1-1-8
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Bromodichloromethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Bromoform	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Bromomethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Chloroethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Chloroform	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Chloromethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Dibromomethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/27/2006 10:43:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Methylene chloride	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Naphthalene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
o-Xylene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Styrene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Toluene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Trichloroethene	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/27/2006 10:43:00 PM
TURBIDITY		E180.1		Analyst: KK		
Turbidity	7.70	1.00		NTU	1	9/21/2006
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ091906: 810 NP1-1-8
Lab Order:	0609177	Tag Number:	10276
Project:	Rowe Industries	Collection Date:	9/19/2006
Lab ID:	0609177-06A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	72.0	1.00		mg/L	1	9/25/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 29-Sep-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ091906: 810 NP1-1-8
Lab Order:	0609177	Tag Number:	10276
Project:	Rowe Industries	Collection Date:	9/19/2006
Lab ID:	0609177-06B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.00906	0.0200	J	mg/L	1	9/28/2006 1:23:39 PM
Manganese	0.629	0.0200		mg/L	1	9/28/2006 1:23:39 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-07A

Client Sample ID: GWQ091906: 810 NP1-1-9
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	25.9	1.00		mg/L	1	9/28/2006
TOTAL IRON, MANGANESE		E200.7				Analyst: JP
Iron	5.16	0.0200		mg/L	1	9/28/2006 1:31:33 PM
Manganese	0.712	0.0200		mg/L	1	9/28/2006 1:31:33 PM
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
2-Butanone	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
2-Hexanone	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
4-Methyl-2-pentanone	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Acetone	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Benzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Bromobenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0609177
Project: Rowe Industries
Lab ID: 0609177-07A

Client Sample ID: GWQ091906: 810 NP1-1-9
Tag Number: 10276
Collection Date: 9/19/2006
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11		SW8260B		Analyst: LDS		
Bromodichloromethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Bromoform	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Bromomethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Chloroethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Chloroform	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Chloromethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Dibromomethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/27/2006 11:21:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Methylene chloride	18	1.0	B	µg/L	1	9/27/2006 11:21:00 PM
Naphthalene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
o-Xylene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Styrene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Toluene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Trichloroethene	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/27/2006 11:21:00 PM
TURBIDITY		E180.1		Analyst: KK		
Turbidity	13.0	1.00		NTU	1	9/21/2006
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Sep-06

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ091906: 810 NP1-1-9
Lab Order:	0609177	Tag Number:	10276
Project:	Rowe Industries	Collection Date:	9/19/2006
Lab ID:	0609177-07A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	70.0	1.00		mg/L	1	9/25/2006

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 29-Sep-06**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ091906: 810 NP1-1-9**Lab Order:** 0609177**Tag Number:** 10276**Project:** Rowe Industries**Collection Date:** 9/19/2006**Lab ID:** 0609177-07B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	U	0.0200		mg/L	1	9/28/2006 1:29:38 PM
Manganese	0.623	0.0200		mg/L	1	9/28/2006 1:29:38 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

H6I210105 Analytical Report.....	1
Sample Receipt Documentation	15
Total Number of Pages	17



STL

STL Knoxville
5815 Middlebrook Pike
Knoxville, TN 37921

Tel: 865 291 3000 Fax: 865 584 4315
www.stl-inc.com

ANALYTICAL REPORT


Rowe-NABSAG 0401

Lot #: H6I210105

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

SEVERN TRENT LABORATORIES, INC.


Jamie A. McKinney
Project Manager

September 28, 2006

ANALYTICAL METHODS SUMMARY

H6I210105

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15

References:

EPA-2 "Compendium of Methods for the Determination of Toxic
Organic Compounds in Ambient Air", EPA-625/R-96/010b,
January 1999.

SAMPLE SUMMARY

H6I210105

WO #	SAMPLE#	CLIENT SAMPLE ID	SAMPLED DATE	SAMP TIME
JEPE2	001	AQ091906:910 NP4-1	09/19/06	09:10
JEPE6	002	AQ091906:915 NP4-2	09/19/06	09:15
JEPE7	003	AQ091906:920 NP4-3	09/19/06	09:20

NOTE (S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

H6I210105

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

There were no problems with the condition of the samples received.

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

Samples were received on 9/21/06 in Tedlar bags and transferred into Summa Canisters within 72 hours of sampling.

STL Knoxville maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. # QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ091906:910 NP4-1
 GC/MS Volatiles

Lot-Sample # H61210105 - 001

Work Order # JEPE21AA

Matrix.....: AIR

Date Sampled...: 9/19/06

Date Received..: 9/21/06

Prep Date.....: 9/21/06

Analysis Date..: 9/21/06

Prep Batch #.....: 6265069

Dilution Factor.: 5

Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	0.32	1.0	1.0 J	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	4.1	2.5	13	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	0.27	1.0	0.70 J	2.6
Chloroform	1.1	1.0	5.3	4.9
Chloromethane	1.1	2.5	2.3 J	5.2
1,1-Dichloroethane	4.0	1.0	16	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	1.2	1.0	4.6	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	1.5	1.0	6.0	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.35	2.5	1.2 J R	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	31	1.0	210	6.8
Toluene	0.76	1.0	2.9 J	3.8
1,1,1-Trichloroethane	48	1.0	260	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	1.9	1.0	10	5.4
Vinyl chloride	0.35	1.0	0.89 J	2.6
m-Xylene & p-Xylene	0.40	1.0	1.7 J	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	99	70 - 130
Toluene-d8	99	70 - 130

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ091906:910 NP4-1
 GC/MS Volatiles

Lot-Sample #	H6I210105 - 001	Work Order #	JEPE21AA	Matrix.....:	AIR
<u>SURROGATE</u>		<u>PERCENT RECOVERY</u>		<u>LABORATORY CONTROL LIMITS (%)</u>	
4-Bromofluorobenzene		98		70 - 130	

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
 J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ091906:915 NP4-2
 GC/MS Volatiles

Lot-Sample # H61210105 - 002

Work Order # JEPE61AA

Matrix.....: AIR

Date Sampled...: 9/19/06

Date Received..: 9/21/06

Prep Date.....: 9/21/06

Analysis Date..: 9/21/06

Prep Batch #.....: 6265069

Dilution Factor.: 5

Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	6.3	2.5	20	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	0.25	1.0	0.65 J	2.6
Chloroform	0.51	1.0	2.5 J	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	1.5	1.0	6.0	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	1.5	1.0	5.8	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.78	1.0	3.1 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.36	2.5	1.2 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	0.20	1.0	1.4 J	6.8
Toluene	0.83	1.0	3.1 J	3.8
1,1,1-Trichloroethane	8.2	1.0	45	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	0.36	1.0	0.92 J	2.6
m-Xylene & p-Xylene	0.37	1.0	1.6 J	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	100	70 - 130
Toluene-d8	99	70 - 130

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ091906:915 NP4-2
 GC/MS Volatiles

Lot-Sample # H61210105 - 002	Work Order # JEPE61AA	Matrix.....: AIR
SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
4-Bromofluorobenzene	98	70 - 130

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
 J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ091906:920 NP4-3
 GC/MS Volatiles

Lot-Sample # H61210105 - 003 Work Order # JEPE71AA Matrix.....: AIR

Date Sampled...: 9/19/06 Date Received...: 9/21/06
 Prep Date.....: 9/21/06 Analysis Date..: 9/21/06
 Prep Batch #.....: 6265069
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	0.34	1.0	1.1 J	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	5.3	2.5	16	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	0.28	1.0	0.74 J	2.6
Chloroform	0.64	1.0	3.1 J	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	2.8	1.0	11	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	1.6	1.0	6.2	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.99	1.0	3.9 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.34	2.5	1.2 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	ND	1.0	ND	6.8
Toluene	0.68	1.0	2.6 J	3.8
1,1,1-Trichloroethane	6.4	1.0	35	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	0.36	1.0	0.92 J	2.6
m-Xylene & p-Xylene	0.35	1.0	1.5 J	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	100	70 - 130
Toluene-d8	99	70 - 130

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ091906:920 NP4-3
 GC/MS Volatiles

Lot-Sample # H6I210105 - 003	Work Order # JEPE71AA	Matrix.....: AIR
<u>SURROGATE</u>	<u>PERCENT RECOVERY</u>	<u>LABORATORY CONTROL LIMITS (%)</u>
4-Bromofluorobenzene	99	70 - 130

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
 J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: INTRA-LAB BLANK
 GC/MS Volatiles

Lot-Sample # H61220000 - 069B

Work Order # JETJ61AA

Matrix.....: AIR

Prep Date.....: 9/21/06

Date Received..: 9/21/06

Prep Batch #.....: 6265069

Analysis Date..: 9/21/06

Dilution Factor.: 1

Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	1.6
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	0.097	0.50	0.34	1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	100	70 - 130

Leggette, Brashears & Graham, Inc.
 Client Sample ID: INTRA-LAB BLANK
 GC/MS Volatiles

Lot-Sample # H6I220000 - 069B	Work Order # JETJ61AA	Matrix.....: AIR
-------------------------------	-----------------------	------------------

<u>SURROGATE</u>	<u>PERCENT RECOVERY</u>	<u>LABORATORY CONTROL LIMITS (%)</u>
Toluene-d8	103	70 - 130
4-Bromofluorobenzene	98	70 - 130

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: CHECK SAMPLE
 GC/MS Volatiles

Lot-Sample # H61220000 - 069C Work Order # JETJ61AC Matrix.....: AIR

Prep Date.....: 9/21/06 Date Received..: 9/21/06
 Prep Batch #.....: 6265069 Analysis Date..: 9/21/06
 Dilution Factor.: 1 Method.....: TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	10.0	10.0	32	32	100	70 - 130
Chlorobenzene	10.0	8.92	46	41	89	70 - 130
1,1-Dichloroethene	10.0	9.94	40	39	99	70 - 130
Toluene	10.0	8.36	38	32	84	70 - 130
Trichloroethene	10.0	9.07	54	49	91	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	100	70 - 130
Toluene-d8	100	70 - 130
4-Bromofluorobenzene	101	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

JTL Knoxville

5815 Middlebrook Pike • Knoxville, TN 37921-5947
Phone: (865) 291-3000 • Fax: (865) 584-4315
Receiving: (865) 291-3031

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD*

Reference Document #
Page 1 of

Project Name/No. 1 Rewe
Sample Team Members 2 Rob Daw
Profit Center No. 3 NABAS 0401
Project Manager 4 Mark Goldberg
Purchase Order No. 5
Required Report Date 11

Samples Shipment Date 7 9-20-06
Lab Destination 8
Lab Contact 9 Scott Harris
Project Contact / Phone 12 203-929-8555
Carrier / Waybill No. 13

Bill to: 5 LBG
4 Research Dr.
Suite 301
Shelton, CT 06484
Report to: 10 Mark Goldberg
HGI 210105

ONE CONTAINER PER LINE

Sample Number	Sample Type	Date/Time Collected	Container Type	Sample Volume	Pre-19 servative	Requested Testing Program	Condition on Receipt Lab use only
AB091006; 910 NP4-1	ARR	9-19-06	Tedlar bag	1L	-	TO-17	Custody seals intact Y/N NA
↓; 915 NP4-2	↓	↓	↓	↓	-	↓	Temperature received at <u>Amh 10/10</u>
↓; 920 NP4-3	↓	↓	↓	↓	-	↓	Received by <u>MW</u> Date <u>9/21/06</u>
							Number of packages <u>1-Febr</u>
							Tracking # <u>7900 7552 9903</u>

Special Instructions: 23

Possible Hazard Identification: 24

Non-Hazard ☒ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐

Turnaround Time Required: 26

Normal ☒ Rush ☐

1. Relinquished by Rob Daw Date: 9-20-06

(Signature / Affiliation)

Sample Disposal: 25

Return to Client ☐ Disposal by Lab ☒ Archive (mos.)

QC Level: 27

I. ☐ II. ☐ III. ☐

1. Received by MW Date: 9/21/06

(Signature / Affiliation)

Project Specific (specify): F011 GA/AC

1. Received by MW Date: 9/21/06

(Signature / Affiliation)

1. Received by MW Date: 9/21/06

(Signature / Affiliation)

Comments: 29

STL KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: LBGProject: LoveLot Number: 46I210105

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)				☐ 1a Do not match COC ☐ 1b Incomplete information ☐ 1c Marking smeared ☐ 1d Label torn ☐ 1e No label ☐ 1f COC not received ☐ 1g Other:	
2. Is the cooler temperature within limits? (> freezing temp. of water to 6°C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6°C)	✓			☐ 2a Temp Blank = _____ ☐ 2b Cooler Temp = _____	
3. Were samples received with correct chemical preservative (excluding Encore)?			✓	☐ 3a Sample preservative =	
4. Were custody seals present/intact on cooler and/or containers?	✓			☐ 4a Not present ☐ 4b Not intact ☐ 4c Other:	
5. Were all of the samples listed on the COC received?	✓			☐ 5a Samples received-not on COC ☐ 5b Samples not received-on COC	
6. Were all of the sample containers received intact?	✓			☐ 6a Leaking ☐ 6b Broken	
7. Were VOA samples received without headspace?			✓	☐ 7a Headspace (VOA only)	
8. Were samples received in appropriate containers?	✓			☐ 8a Improper container	
9. Did you check for residual chlorine, if necessary?			✓	☐ 9a Could not be determined due to matrix interference	
10. Were samples received within holding time?	✓			☐ 10a Holding time expired	
11. For rad samples, was sample activity info. provided?			✓	☐ Incomplete information	
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?			✓	If yes & appears to be >1%, was SOG notified?	
13. Are the shipping containers intact?				☐ 13a Leaking ☐ 13b Other:	
14. Was COC relinquished? (Signed/Dated/Timed)	✓			☐ 14a Not relinquished	
15. Are tests/parameters listed for each sample?	✓			☐ 15a Incomplete information	
16. Is the matrix of the samples noted?	✓			☐ 15a Incomplete information	
17. Is the date/time of sample collection noted?	✓			☐ 15a Incomplete information	
18. Is the client and project name/# identified?	✓			☐ 15a Incomplete information	
19. Was the sampler identified on the COC?	✓			☐ 15a Incomplete information	
Quote #: <u>69610</u> PM Instructions: _____					

Sample Receiving Associate: [Signature] Date: 9/21/06

QA026R18.doc, 1/30/06