

-DRAFT-

PROJECT STATUS MEMORANDUM

NO. 01-07

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Tunde H. Komuves-Sandor

DATE: March 16, 2007

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
January 2007 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from January 1, 2007 through January 31, 2007. The report includes a summary of system performance parameters, system operation parameters, and analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(January 1, 2007 through January 31, 2007)

- | | |
|---|----------------------------------|
| 1. Hours of operation during the reporting period: | 601 hours (81%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 11,625,521 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: | yes, (Graph 1) |
| 6. Mass of VOCs recovered during the reporting period: | 1.2 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 198.9 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.28 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00260 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume Pumped (gal)	Average Flow (gpm)	Minimum Design Flow (gpm)	Total VOC Concentration (mg/L)	VOC Recovery (lbs)
RW-2*	972,429	27	26	74.9	0.61
RW-3	584,018	10	23	12.7	0.062
RW-4*	1,210,560	34	13	17.5	0.18
RW-5*	1,800,738	50	42	21.1	0.32
RW-6	488,112	15	28	84.8	0.35
RW-7**	1,271,900	69	54	38.1	0.40
RW-8	965,150	50	46	21.5	0.17
RW-9	4,199,680	80	68	13.9	.49

*The volume of water pumped from RW-2, RW-4 and RW-5 from January 1, 2007 to January 18, 2007 was estimated based on average pumping rates and calculated operating times because of malfunctioning flow meters at these recovery wells. The flow meters were functioning from January 18, 2007 through January 31, 2007.

**RW-7 was off from December 17, 2006 through January 23, 2007 because of a malfunctioning pump motor. The last available water-quality data from November 2006 was used to calculate total VOCs recovered in January.

Recovery well RW-6 and RW-3 had an average flow below the respective minimum design flow determined to be necessary for capture of the plume. RW-6 will continue to be monitored for performance, including ground-water drawdown, to determine if the submersible pump approaches a dewatered condition.

In June 2006, the 1 HP pump in RW-3 was replaced with a 2 HP pump in an attempt to increase the flow from the well. The buildup of iron bacteria in the below-grade piping from the well has reduced the cross-sectional area of the pipe and, in spite of repeated cleanings, has increased the hydraulic head the pump must overcome to maintain the desired flow rate. The 2 HP pump is capable of pumping a higher flow at an increased hydraulic head. Because the flow rate from RW-3 continues to be lower than the minimum design flow rate, LBG believes that the iron bacteria encrustation in the pipe may be greater than initially anticipated and the below-grade piping may require further cleaning. An attempt will be made to jet clean the iron bacteria encrustation from the below-grade piping to increase the flow from the well. LBG is evaluating other options to increase the flow from RW-3 if the pipe cleaning is not effective.

On January 10, 2007, LBG briefly turned RW-2 off in order to observe the effects of RW-2 on the flow rate, percent motor speed and amperage of RW-3. When both recovery well pumps were running, the flow rate, percent motor speed and amperage at RW-2 were 26.27 gpm, 97% and 3.0 amps respectively, and at RW-3 the readings were 9.27 gpm, 100% and 2.6 amps, respectively. However, when RW-2 was turned off the flow rate at RW-3 increased to 22.35 gpm. The percent motor speed for the RW-3 pump decreased to 63% and the amperage decreased to 2.5 amps, which suggests the flow-carrying capacity of the pipe has been reduced in a location somewhere after the RW-2 and RW-3 flows meet.

The RW-7 pump motor malfunctioned on December 17, 2006. Troubleshooting efforts to diagnose the problem indicate that the pump motor was faulty. A new pump motor was installed on January 23, 2007, and RW-7 resumed operation on January 24, 2007.

On January 18, 2007, a pump motor failure occurred for the pump in RW-8. Initial troubleshooting efforts to correct the problem were unsuccessful and RW-8 remained off. The RW-8 pump will be removed from the well for inspection. A pump motor has been ordered because based on past experience, this is most likely the problem.

The effluent pH of the treated water from the FSP&T system is within the acceptable State Pollutant Discharge System (SPDES) criteria for the site as shown in Table 2.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
January 1 to 31	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in January 2007 include:

- On January 3, 2007, the malfunctioning transfer pump used for bag-filter changes was replaced. The malfunctioning RW-3 flow meter transmitter was replaced.
- The flow meter totalizers for RW-2, RW-4, RW-5 and EQ TP101 were reset because they stopped working.
- On January 23, 2007, the RW-7 pump motor was replaced.
- On January 24, 2007, RW-7 was restarted and the malfunctioning on-site combined flow meter sensor (FI-2-1) was repaired.

Future O&M activities scheduled for the winter and spring of 2007 include:

- Troubleshoot air stripper blower flow meter;
- Clean RW-8 flow meter and replace pump and motor;
- Clean below-grade piping in the location after RW-2 and RW-3 flow combine.
- Conduct semi-annual ground-water sampling;
- Measure depth to water for recovery wells, monitor wells and piezometers for static and dynamic (while FSP&T is operating) conditions.

MMG:kd

Attachments

cc: Jeffery S. Srulovitz, Kraft Foods, Global – .pdf
Lisa Krogman, Kraft Foods, Global (Environ) – .pdf
Jeff Trad, NYSDEC – .pdf
Chief-Operation Maintenance and Support Section, NYSDEC – .pdf
William Spitz, RWM, R-1, NYSDEC
Garrett W. Swensen Jr., Esq., Town of Southampton

H:\Nabsag\2007\Status0107Jan.doc

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(January 1, 2007 through January 31, 2007)

Date	Time	System Changes/Modifications	Personnel
1/3/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	RD/EF
		Changed the discharge pump for the bag filter system.	RD/EF
		Changed the flow rate transmitter for the RW-3 pump.	RD/EF
1/10/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	RD/EF
1/12/2007	9:26 AM	System Communication Failure alarms; system shutdown.	
1/18/2007	9:02 AM	Rebooted computer, reset alarms and restarted system, RW-7 remains off awaiting a new pump motor. Reset RW-5 flow totalizer.	RD
	10:52 AM	Reset TP101 and RW-5 flow totalizers.	RD
	10:54 AM	Reset RW-2 and RW-4 flow totalizers.	RD
		Pump failure alarms occurred at RW-8, RW-8 operation was discontinued. Troubleshooting of RW-8 pump initiated	RD
1/23/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	RD
		Replace RW-7 pump motor.	RD/ETL
1/24/2007	7:40 AM	RW-8 Pump Failure Alarm, RW-8 already off. Acknowledged alarm, but can't reset alarm until the RW-8 pump is removed for inspection.	EF
	7:50 AM	Turned RW-7 on at 70 gallons per minute.	EF
		Repaired the combined onsite flow meter; FI-2-1 still needs to be calibrated.	EF/ETL

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo-chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	1	5	5	5	5	5	---	---	5	---	50	7	---	---	---	
5-Jan-07	5	114	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.21	0.0417
10-Jan-07	5.2	120	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.63	0.0371
18-Jan-07	5	92	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	21.20	0.7560
23-Jan-07	5	102	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.08	0.0547

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethylene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

- Notes:
 1. Based on the new SPDES criteria from an NYSDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5.
 The pH was measured using litmus paper. Influent pH values from recovery wells typically range between 5 and 6.

2. "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.

TABLE 3

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m ³)																				TOTAL VOCs		
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE			
AQ010406:845NP4-1	1/4/2006	8:45	0.24	0.027	0.094	0.007	0.019	0.009	0.031	0.014	0.01	0.004	0.005	0.005	0.018	ND	0.027	0.002	ND	0.003	ND	ND	0.52		
AQ020106:745NP4-1	2/1/2006	7:45	0.64	0.03	0.12	0.008	0.028	0.018	0.005	0.009	0.003	ND	ND	0.007	0.024	0.008	0.012	0.018 ^{3/}	ND	ND	ND	ND	0.91		
AQ032206:1215NP4-1 ^{4/}	3/22/2006	12:15	0.12	0.018	0.077	0.0042	0.018	0.0062	0.0026	0.00096	0.0016	ND	ND	0.0049	0.0025	0.0017	0.0067	ND	ND	ND	ND	ND	0.26		
AQ041206:950NP4-1	4/12/2006	9:50	0.18	0.011	0.038	0.004	0.0087	0.007	0.0014	ND	ND	ND	ND	0.0037	0.0011	0.0018	0.0047	ND	ND	ND	ND	ND	0.26		
AQ051706:1000NP4-1	5/17/2006	10:00	0.28	0.017	0.048	0.0035	0.013	0.014	0.0093	0.0026	0.0032	ND	ND	0.0037	0.0019	0.0026	0.0097	ND	ND	0.0016	0.0011	ND	0.41		
AQ062106:800NP4-1	6/21/2006	8:00	0.15	0.009	0.074	0.0037	0.014	0.0062	0.0048	0.00092	0.0022	ND	ND	0.0029	0.002	0.0019	0.014	ND	ND	0.00091	ND	ND	0.29		
AQ072006:900NP4-1	7/20/2006	9:00	0.095	0.008	0.091	ND	0.0074	0.005	0.0057	ND	0.0069	0.0062	ND	0.0067	0.0022	0.013	ND	ND	ND	ND	ND	ND	0.25		
AQ082406:900NP4-1	8/24/2006	9:00	0.28	0.012	0.055	0.0034	0.0083	0.013	0.0043	0.0021	0.0022	ND	ND	0.003	0.0043	ND	0.009	ND	ND	ND	ND	0.0014	ND	0.40	
AQ091906:910NP4-1	9/19/2006	9:10	0.21	0.01	0.26	0.006	0.016	0.0046	0.0029	0.001	0.0017	ND	ND	0.0053	0.0012	0.0023	0.013	ND	ND	0.00089	0.0007	ND	0.54		
AQ102506:930NP4-1	10/24/2006	9:30	0.014	0.0063	0.2	0.0045	0.013	0.0035	0.0023	ND	0.0018	ND	ND	0.0043	0.001	ND	0.0091	ND	ND	ND	0.0097	ND	0.27		
AQ112906:1000NP4-1	11/29/2006	10:00	0.21	0.0094	0.087	0.003	0.0094	0.0053	0.0028	0.0016	0.0016	ND	ND	0.0045	0.011	0.002	0.0052	ND	ND	ND	ND	0.001	ND	0.35	
AQ122006:815NP4-1	12/20/2006	8:15	0.065	0.013	0.13	0.0026	0.0081	0.0037	0.0052	0.0038	0.0021	ND	ND	0.0041	0.0021	0.0026	0.0071	ND	0.0013	ND	ND	ND	0.25		
AQ011007:1000NP4-1	1/10/2007	10:00	0.06	0.0082	0.08	0.0031	0.0084	ND	0.0016	0.0011	0.0011	ND	ND	0.0051	0.0016	0.003	0.0059	ND	ND	ND	ND	ND	0.18		
Midcarbon			Parameters (mg/m ³)																				TOTAL VOCs		
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE			
AQ010406:850NP4-2	1/4/2006	8:50	0.006	ND	0.11	0.005	0.017	0.006	0.018	0.001	0.003	ND	0.003	0.005	0.007	ND	0.022	0.009	ND	0.001	ND	ND	0.21		
AQ020106:750NP4-2	2/1/2006	7:50	0.002	ND	0.086	ND	0.013	0.007	0.016	0.012	0.007	0.002	0.002	0.003	0.017	ND	0.01	ND	0.002	ND	ND	ND	0.19		
AQ032206:1220NP4-2 ^{4/}	3/22/2006	12:20	0.0014	ND	0.075	0.0044	0.013	0.007	0.0041	ND	0.0025	ND	ND	0.0034	0.0027	ND	0.0062	ND	ND	ND	ND	ND	0.12		
AQ041206:955NP4-2	4/12/2006	0:00	0.0012	ND	0.099	0.0076	0.014	0.0087	0.0015	ND	0.0011	ND	ND	0.0047	0.0013	ND	ND	ND	ND	ND	ND	0.14			
AQ051706:1005NP4-2	5/17/2006	10:05	0.0028	0.001	0.065	0.0039	0.014	0.0074	0.0045	ND	0.0032	ND	ND	0.0036	0.003	0.0019	0.0088	ND	ND	ND	ND	ND	0.12		
AQ062106:805NP4-2	6/21/2006	8:05	ND	ND	0.025	0.0028	0.0081	0.0045	0.0036	ND	0.0014	ND	ND	0.0023	0.0019	0.0026	0.014	ND	ND	ND	0.001	ND	0.07		
AQ072006:905NP4-2	7/20/2006	9:05	ND	ND	0.022	ND	0.0078	0.0044	ND	ND	ND	ND	ND	ND	ND	ND	0.013	ND	ND	ND	ND	ND	0.05		
AQ082006:902NP4-2	8/24/2006	9:02	ND	ND	0.023	0.0017	0.0054	0.0045	0.0035	ND	0.0018	ND	ND	0.0019	0.0025	ND	0.013	ND	ND	ND	ND	ND	0.06		
AQ091906:915NP4-2	9/19/2006	9:15	0.0014	ND	0.045	0.0031	0.006	0.0058	0.0031	ND	0.0016	ND	ND	0.0025	0.0012	ND	0.02	ND	ND	0.00092	0.0065	0.10			
AQ102506:935NP4-2	10/24/2006	9:35	0.0021	ND	0.062	0.0039	0.011	0.0044	0.0018	ND	0.0014	ND	ND	0.0026	0.001	ND	0.0077	ND	ND	ND	0.0009	0.0065	0.10		
AQ112906:1006NP4-2	11/29/2006	10:06	0.0034	ND	0.24	0.0065	0.022	0.0067	0.0017	ND	0.0012	ND	ND	0.0061	0.0012	0.0033	0.012	ND	ND	0.00085	ND	0.30			
AQ122006:820NP4-2	12/20/2006	8:20	0.0054	0.002	0.3	0.0037	0.014	0.0048	0.0017	0.0012	ND	ND	ND	0.0051	0.0015	ND	0.0037	ND	ND	ND	ND	0.34			
AQ011007:1001NP4-2	1/10/2007	10:01	0.0034	0.001	0.32	0.0047	0.012	0.005	0.0013	ND	ND	ND	ND	0.0056	0.0014	0.0032	0.0071	ND	ND	ND	ND	ND	0.36		
Postcarbon			Parameters (mg/m ³)																				TOTAL VOCs		
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE			
AQ010406:855NP4-3	1/4/2006	8:55	0.004	ND	0.096	0.006	0.022	0.003	0.017	0.004	0.004	ND	0.003	0.006	0.014	ND	0.022	ND	ND	0.001	ND	ND	0.20		
AQ020106:775NP4-3	2/1/2007	7:55	ND	0.002	0.075	0.004	0.016	0.003	0.004	0.003	0.001	ND	ND	0.005	0.017	ND	0.012	0.11 ^{3/}	ND	ND	ND	ND	0.14		
AQ032206:1225NP4-3 ^{4/}	3/22/2006	12:25	ND	ND	0.11	0.0046	0.016	0.0045	0.0029	ND	0.0021	ND	ND	0.0049	0.0025	0.0016	0.0055	ND	ND	ND	ND	ND	0.15		
AQ041206:1000NP4-3	4/12/2006	10:00	ND	ND	0.074	0.0065	0.011	0.0051	0.0018	ND	0.0015	ND	ND	0.0051	0.0013	ND	ND	ND	ND	ND	ND	0.11			
AQ051706:1010NP4-3	5/17/2006	10:10	0.0046	ND	0.068	0.0045	0.015	0.0048	0.0046	0.00088	0.0025	ND	ND	0.0042	0.0022	0.0026	0.012	ND	ND	ND	0.00075	ND	0.13		
AQ062106:810NP4-3	6/21/2006	8:10	ND	ND	0.023	0.0027	0.0066	0.0036	0.0042	0.00075	0.0016	ND	ND	0.0018	0.0018	0.0023	0.015	ND	ND	ND	0.0008	ND	0.06		
AQ072006:910NP4-3	7/20/2006	9:10	ND	ND	0.017	ND	0.0058	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.012	ND	ND	ND	ND	ND	0.03		
AQ082406:904NP4-3	8/24/2006	9:04	ND	ND	0.025	0.0029	0.0082	0.0046	0.0038	0.00079	0.0018	ND	ND	0.002	0.0022	ND	0.014	ND	ND	ND	ND	ND	0.07		
AQ091906:920NP4-3	9/19/2006	9:20	ND	ND	0.035	0.0039	0.011	0.0062	0.0026	0.0011	0.0015	ND	ND	0.0031	0.0012	ND	0.016	ND	ND	0.00092	0.0074	0.08			
AQ102506:936NP4-3	10/24/2006	9:36	ND	ND	0.041	0.001	0.0098	0.0048	0.0017	ND	0.0013	ND	ND	0.0028	0.00093	0.00062	0.0087	ND	ND	ND	0.00078	0.0062	0.08		
AQ112906:1010NP4-3	11/29/2006	10:10	ND	0.0011	0.071	0.0033	0.012	0.0053	0.001	ND	ND	ND	ND	0.0032	0.001	ND	0.0084	ND	ND	ND	ND	ND	0.11		
AQ122006:825NP4-3	12/20/2006	8:25	ND	ND	0.14	0.0042	0.018	0.007	0.0024	0.0011	ND	ND	ND	0.0047	0.0012	ND	0.0042	ND	ND	ND	ND	ND	0.18		
AQ011007:1002NP4-3	1/10/2007	10:02	ND	ND	0.23	0.0047	0.018	0.0065	0.0013	ND	ND	ND	ND	0.0053	0.0012	0.0028	0.0048	ND	ND	ND	ND	ND	0.27		

- Notes: 1. Methylene chloride and/or carbon disulfide concentrations in all three air samples collected during the July 7, August 9 and September 8, 2005 sampling events are greatly elevated due to suspected laboratory contamination. The methylene chloride concentration from the June 24, 2005 sampling event was used instead of the July 7, August 9 or September 8, 2005 methylene chloride concentrations to calculate the total VOCs for July, August and September 2005. The carbon disulfide concentration from the June 24, 2005 sampling event was used instead of the July 7 and August 9, 2005 carbon disulfide concentration to calculate the total VOCs for July and August 2005.
2. The methylene chloride concentration in the air samples collected on December 8, 2005 are suspected to be from laboratory contamination.
3. The laboratory procedure for the % bromomethane recovered exceeded the upper limit for quality control, therefore the bromomethane concentration for January 4, 2006 was used to calculate the total VOC concentration in for the February 1, 2006 samples.
4. The air samples from March 2006 and forward were analyzed using the TO-15 method at the Severn Trent Laboratory located in Knoxville, TN. Air sampling using the TO-17 method at the Severn Trent Laboratory in Connecticut is no longer available. The March 2006 air quality results appear to be a little lower or similar to prior air quality results. LBG will continue to monitor the air quality on a monthly basis.

PCE - Tetrachloroethane	DCE - 1,1-Dichloroethene	CF - Chloroform	BM - Bromomethane
TCE - Trichloroethane	DCA - 1,1-Dichloroethane	MC - Methylene Chloride	CB - Chlorobenzene
TCA - 1,1,1-Trichloroethane	cis-DCE - cis-1,2-Dichloroethene	CM - Chloromethane	EB - Ethylbenzene
CE - Chloroethane	CT - Carbon Tetrachloride		

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ¹	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethyl-benzene (ug/L)	Acetone (ug/L) ¹
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	NE
RW-1	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.3	1.3
	7-Mar-06	ND<1	ND<1	ND<1	ND<1	5.2	ND<1	0.1650	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	1.7	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-2	15-Sep-04	12	ND<1	ND<1	ND<1	ND<1	ND<1	3.82	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	1.5	4.78	0.213	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	11	ND<1	ND<1	ND<1	ND<1	ND<1	5.21	0.152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	10	ND<1	ND<1	ND<1	ND<1	ND<1	10.8	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	12.0	ND<1	1.0	ND<1	ND<1	ND<1	3.5	0.0511	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	7.7	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	0.28	0.0298	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.6 *
	9-Aug-05	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.74	0.107	ND<1	5.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	16	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	3.57	0.0704	ND<1	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	15	2.1	ND<1	ND<1	ND<1	ND<1	6.1	0.0269	ND<1	12	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	34	2.1	ND<1	ND<1	ND<1	ND<1	4.25	ND<0.02	ND<1	25	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	5.2	2.0	ND<1	ND<1	ND<1	ND<1	9.15	0.0696	ND<1	5.0	ND<1	4.8 *	1.0	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	6.5	4.3	1.2	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	6.5	3.5	ND<1	ND<1	ND<1	ND<1	4.76	0.0395	ND<1	3.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	12.0	3.9	1.2	ND<1	ND<1	ND<1	4.24	0.0522	ND<1	12.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	19.0	5.1	ND<1	ND<1	ND<1	ND<1	5.95	0.063	ND<1	14.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	13.0	3.0	25	ND<1	ND<1	ND<1	3.57	0.093	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	8.0	3.4	60	ND<1	ND<1	ND<1	4.49	0.177	ND<1	7.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	11.0	1.1	25	ND<1	ND<1	ND<1	4.14	0.0172	ND<1	5.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	2.8	ND<1	200	ND<1	ND<1	ND<1	13.7	0.0184	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	5.0	1.6	160	ND<1	ND<1	ND<1	3.6	0.00756	ND<1	3.6	0.91	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	29-Nov-06	6.0	1.8	36	ND<1	ND<1	ND<1	14.1	0.0148	ND<1	3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-06	2.2	ND<1	110	ND<1	ND<1	ND<1	11.8	0.0197	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	4.2	2.7	68	ND<1	ND<1	ND<1	2.77	0.458	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	
RW-3	15-Sep-04	2.7	21	8.7	ND<1	ND<1	ND<1	1.91	0.42	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	7-Oct-04	2.2	12	5.0	ND<1	ND<1	ND<1	2.09	1.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	3-Nov-04	1.5	6.5	2.6	ND<1	ND<1	ND<1	1.87	1.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.77	0.489	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	15-Mar-05	3	13	5.0	ND<1	ND<1	ND<1	ND<1	1.89	1.36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	46.1	0.539	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	2-May-05	2.2	7.7	2.8	ND<1	ND<1	ND<1	ND<1	1.85	0.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	9.91	10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	14-Jul-05	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.01	0.649	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	6.9 *	
	9-Aug-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.973	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Sep-05	1	3.6	1.2	ND<1	ND<1	ND<1	ND<1	2.03	0.71	ND<1	2.6	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	21-Nov-05	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	1.83	0.708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Dec-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.11	0.556	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Jan-06	1.7	17	7.9	ND<1	ND<1	ND<1	ND<1	1.93	0.455	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	1.4	8.9	2.5	ND<1	ND<1	ND<1	ND<1	3.80	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	1.1	3.4	ND<1	ND<1	ND<1	ND<1	1.87	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Apr-06	0.95	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.99	0.649	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.06	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	21-June-06 ^{1/}	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	24-Aug-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	19-Sep-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	24-Oct-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	29-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.36	0.053	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	20-Dec-06	6.4	ND<1	4.4	ND<1	ND<1	ND<1	ND<1	17.3	0.0112	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	1.2	8	3.5	ND<1	ND<1	ND<1	ND<1	1.87	1.63	ND<1	ND<1	ND<1	ND<1	ND<1	2.1*	ND<1	ND<1	ND<1
RW-4	15-Sep-04	120	3.7	18	ND<1	ND<1	ND<1	2.98	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	7-Oct-04	94	ND<1	14	ND<1	ND<1	ND<1	3.65	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	3-Nov-04	130	4.2	11	ND<1	ND<1	ND<1	4.75	0.205	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	15-Dec-04	230	5.7	35	ND<1	ND<1	ND<1	1.90	1.62	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	4-Jan-05	160	4.1	7.3	ND<1	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	19-Apr-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	2-May-05	80	2.4	9.8	ND<1	ND<1	ND<1	3.77	0.0687	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	30-Jun-05	74	2.6	ND<1	ND<1	ND<1	ND<1	9.95	9.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	14-Jul-05	37	ND<1	8.9	ND<1	ND<1	ND<1	ND<1	3.22	0.0185	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	7.4 *
	9-Aug-05	31	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.49	0.111	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	45	ND<1	6.0	ND<1	ND<1	ND<1	ND<1	3.47	0.173	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	21-Nov-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.0777	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-05	64	2.0	1.5	ND<1	ND<1	ND<1	ND<1	2.82	0.0302	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	15	ND<1	9.5	ND<1	ND<1	ND<1	ND<1	7.78	0.0412	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	24	ND<1	8.7	ND<1	ND<1	ND<1	ND<1	6.05	0.0627	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	22	ND<1	7.0	ND<1	ND<1	ND<1	ND<1	3.50	0.0476	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	26	1.5	6.2	ND<1	ND<1	ND<1	ND<1	2	4.17	0.0963	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1
	17-May-06	26	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.15	0.109	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	23	ND<1	8.4	ND<1	ND<1	ND<1	ND<1	9.23	0.086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	14	ND<1	9.4	ND<1	ND<1	ND<1	ND<1	4.10	0.155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	23	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	8.60	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Sep-06	9	ND<1	7.5	ND<1	ND<1	ND<1	ND<1	5.95	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	24-Oct-06	11	ND<1	5.6	ND<1	ND<1	ND<1	ND<1	7.17	0.0178	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	14	0.9	ND<1	ND<1	ND<1	ND<1	ND<1	2.82	0.00708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	6.4	ND<1	4.4	ND<1	ND<1	ND<1	ND<1	17.30	0.0112	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	12	ND<1	4.6	ND<1	ND<1	ND<1	ND<1	0.91*	3.17	0.0794	ND<1	ND<1	ND<1	ND<1	ND<1	3.0*	ND<1	15*

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloroethane (ug/L)	cis-1,2-Dichloroethene (ug/L)	1,1-Dichloroethene (ug/L)	Methylene Chloride (ug/L) ¹	Toluene	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ¹
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	
RW-5	15-Sep-04	24	ND<1	6.5	ND<1	ND<1	3.2	2.39	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Oct-04	16	ND<1	5.2	ND<1	ND<1	2.4	0.139	0.0163	ND<1	ND<1	ND<1	ND<1	ND<1	1.4	ND<2	ND<1	ND<1	ND<1
	3-Nov-04	15	ND<1	6.4	ND<1	ND<1	2.2	0.0287	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Dec-04	28	ND<1	28	ND<1	ND<1	ND<1	0.0621	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	9	ND<1	4.1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	13	ND<1	5.7	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	8.2	ND<1	1.6	ND<1	ND<1	ND<1	0.0358	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	9.5 *	ND<1	ND<1	ND<1	5.6 *
	9-Aug-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0227	0.0303	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	8	ND<1	3.8	ND<1	ND<1	ND<1	ND<1	0.0185	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	21-Nov-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0482	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	0.0468	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	2.3	ND<1	2.0	ND<1	ND<1	ND<1	0.0558	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	2.9	ND<1	3.8	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	2.6	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	1.4	ND<1	ND<1	ND<1	ND<1	ND<1	1.5	2.4	0.0786	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	2.4	ND<1	2.6	ND<1	ND<1	ND<1	0.195	0.012	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	1.3	ND<1	3.1	ND<1	ND<1	ND<1	0.184	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	0.0116	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.194	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	1.1	ND<1	1.3	ND<1	ND<1	ND<1	0.0683	0.00684	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	6	ND<1	1.3	ND<1	ND<1	ND<1	0.136	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	0.96	ND<1	ND<2	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.508	0.0113	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	1.2*	0.0608	0.0128	ND<1	ND<1	ND<1	ND<1	ND<1	2.8*	ND<1	12*	3.5*
	15-Sep-04	130	3.3	2.2	ND<1	ND<1	ND<1	0.0976	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
RW-6	7-Oct-04	94	ND<1	1.6	ND<1	ND<1	ND<1	0.214	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.0	ND<2	ND<1	ND<1
	3-Nov-04	94	2.1	2.4	ND<1	ND<1	ND<1	2.5	0.0111	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Dec-04	200	3.8	16	ND<1	ND<1	ND<1	4.73	0.117	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	4-Jan-05	86	2.1	3.7	ND<1	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	69	1.6	13	ND<1	ND<1	ND<1	ND<1	0.067	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	64	1.6	9.5	ND<1	ND<1	ND<1	ND<1	0.0406	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	7.2 *	ND<1	ND<1	7 *
	9-Aug-05	49	ND<1	12	ND<1	ND<1	ND<1	0.088	0.0366	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	100	1.6	12	ND<1	ND<1	ND<1	1.3	0.0143	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	68	ND<1	ND<1	ND<1	ND<1	ND<1	0.144	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	100	2.1	20	ND<1	ND<1	ND<1	0.139	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	41	1.1	16	ND<1	ND<1	ND<1	0.189	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<1
	22-Feb-06	63	1.6	15	ND<1	ND<1	ND<1	ND<1	0.116	0.0155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	65	1.2	17	ND<1	ND<1	ND<1	ND<1	0.0429	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	62	2.1	22	ND<1	ND<1	ND<1	2	0.24	0.0137	0.97	ND<1	ND<1	1.1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	68	ND<1	18	ND<1	ND<1	ND<1	0.17	0.019	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	83	ND<1	20	ND<1	ND<1	ND<1	0.075	0.025	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	45	1.5	24	ND<1	ND<1	ND<1	1.01	0.0169	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	30	ND<1	22	ND<1	ND<1	ND<1	ND<1	5.36	0.0563	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	46	ND<1	27	ND<1	ND<1	ND<1	ND<1	0.916	0.0078	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	45	1.2	15	ND<1	ND<1	ND<1	1.84	0.007	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	36	1.0	14	ND<1	ND<1	ND<1	ND<1	0.399	0.137	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	1,1-Dichloroethane	cis-1,2-Dichloroethene	1,1-Dichloroethene	Methylene Chloride	Toluene	Dibromochloromethane	m,p-Xylene	o-Xylene	Ethylbenzene	Acetone	
		(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(mg/L)	(mg/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)
ARAR's		5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	NE	
RW-7	15-Sep-04	59	2.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	7-Oct-04	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0429	0.0126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0214	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	82	ND<1	4.3	ND<1	ND<1	ND<1	0.0272	0.00876	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	2-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	32	1.0	4.7	ND<1	ND<1	ND<1	ND<1	0.0753	0.02	1.5	ND<1	1.1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	32	ND<1	2.2	ND<1	ND<1	ND<1	ND<1	0.0155	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	7.2 *
	9-Aug-05	31	ND<1	6.2	ND<1	ND<1	ND<1	ND<1	0.0903	0.0409	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	39	ND<1	3.4	ND<1	ND<1	ND<1	ND<1	0.0452	ND<0.02	1.7	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	21-Nov-05	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.536	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	70	ND<1	12.0	ND<1	ND<1	ND<1	ND<1	0.253	ND<0.02	4.2	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	26	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	0.343	ND<0.02	2.2	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	36	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	0.0332	ND<0.02	2.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	38	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	0.143	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	49	1.6	7.4	ND<1	ND<1	ND<1	ND<1	0.0912	0.0175	3.4	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	17-May-06	59	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.126	0.026	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	44	ND<1	4.6	ND<1	ND<1	ND<1	ND<1	0.081	0.013	1.6	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	24-Aug-06	39	ND<1	7.9	ND<1	ND<1	ND<1	ND<1	0.307	0.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	36	ND<1	7.5	ND<1	ND<1	ND<1	ND<1	0.116	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	26	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	0.0692	0.00846	2.4	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	9-Nov-06	33	ND<1	4.1	ND<1	ND<1	ND<1	ND<1	0.1910	0.04990	1.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	20-Dec-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	10-Jan-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
RW-8	15-Sep-04	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	ND<1	ND<1	ND<1	ND<1	NM
	27-Oct-04	4.1	1.0	2.2	ND<1	ND<1	ND<1	ND<1	28.8	0.235	1.6	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	5.3	ND<1	4.0	ND<1	ND<1	ND<1	ND<1	10.6	0.271	3.5	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	16	ND<1	22	ND<1	ND<1	ND<1	ND<1	15.6	0.149	15	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	ND<1	8.92	2.85	2.7	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	ND<1	8.24	ND<0.02	4.7	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	ND<1	7.54	0.075	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	ND<1	8.89	0.321	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	ND<1	7.33	0.073	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	2.7	ND<1	5.8	ND<1	ND<1	ND<1	ND<1	7.06	0.325	2.1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	2.6	ND<1	3.4	ND<1	ND<1	ND<1	ND<1	8.33	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	8.2 *
	9-Aug-05	1.8	ND<1	2.9	ND<1	ND<1	ND<1	ND<1	0.24	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	2.9	ND<1	4.2	ND<1	ND<1	ND<1	ND<1	7.53	0.255	2.5	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
	21-Nov-05	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7.65	0.106	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	5.19	0.021	3.2	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	1.3	ND<1	3.7	ND<1	ND<1	ND<1	ND<1	7.25	0.097	2.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	1.5	ND<1	3.0	ND<1	ND<1	ND<1	ND<1	8.06	ND<0.02	1.5	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	8.33	0.064	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	2.1	0.9	4.5	ND<1	ND<1	ND<1	ND<1	7.27	0.823	3.3	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.03	0.056	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	ND<1	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	8.40	0.897	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	1.0	ND<1	4.0	ND<1	ND<1	ND<1	ND<1	10.80	0.175	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	3.2	ND<1	ND<1	ND<1	ND<1	5.98	1.860	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1</td	

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE	TCE	TCA	Vinyl Acetate	Chloroform	MTBE	Total Iron	Dissolved Iron	1,1-Dichloro-ethane	cis-1,2-Dichloro-ethene	1,1-Dichloro-ethene	Methylene Chloride	Toluene	Dibromochloromethane	m,p-Xylene	o-Xylene	Ethyl-benzene	Acetone
		(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(mg/L)	(mg/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)	(ug/L)
ARAR's		5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	NE
RW-9	15-Sep-04	3.7	1.0	6.0	ND<1	ND<1	ND<1	0.049	ND<0.02	1.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Oct-04	3.1	ND<1	5.0	ND<1	ND<1	ND<1	3.12	0.716	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	1.6	ND<1	5.9	ND<1	ND<1	ND<1	2.97	1.41	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Dec-04	1.3	ND<1	31	ND<1	ND<1	ND<1	2.78	0.497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	4.5	ND<1	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0596	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	5.8	ND<1	ND<1	ND<1	1.38	0.149	0.9	ND<1	1.2	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	3.4	ND<1	3.1	ND<1	ND<1	ND<1	2.55	0.238	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	7.3 *
	9-Aug-05	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	0.994	0.0734	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	1.2	ND<1	2.0	ND<1	ND<1	ND<1	3.64	0.161	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.31	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	2.9	ND<1	ND<1	ND<1	2.01	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	2.36	0.0905	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	2.1	ND<1	1.8	ND<1	ND<1	ND<1	5.23	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.41	0.333	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	1.93	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.054	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-June-06 ²⁾	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.695	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0165	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	18*	ND<1	ND<1	ND<1
	24-Oct-06	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	6.96	0.00719	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.54	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	5.08	0.0855	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7*	2*	2.1*	ND<1

ND: Not detected

<#: Less than method detection limit

ug/L: Micrograms per liter

:-: Not analyzed

ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site.

Bold values indicate an exceedance of the ARAR standard established for the site.

PCE: Tetrachloroethylene

TCE: Trichloroethene

TCA: 1,1,1-Trichloroethane

1,1-DCE: 1,1-Dichloroethylene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl Tertiary Butyl Ether

NM: Not Measured

NE indicates that the ARAR goal was not established for this compound by the EPA.

*Concentrations with an asterisk following them are due to laboratory

contamination. Refer to the letter from American Analytical Laboratories in Appendix I.


1/ RW-3 is currently non operational weighting for the reprogramming of the drive for the new 4 amp pump.

2/ RW-9 was being rehabilitated during this sampling event, thus no water sample was collected.

GRAPHS


GRAPH 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA
(January 1, 2007 through January 31, 2007)




GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION IN MICROGRAMS PER LITER



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

RECOVERY WELL PCE CONCENTRATION FOR SELECT RECOVERY WELLS



APPENDIX I
JANUARY 2007 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

February 21, 2007

Mr. Mark Goldberg/P.E.
Leggette Brashears & Graham, Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

Reference: Rowe Industries, AAL Work order 0701095; January 10, 2007 Collection.

Dear Mark,

American Analytical Laboratories has reviewed the Volatile data and reported results for the above referenced report. The raw data supports the lower concentrations of BTEX reported in samples NP1-1-2, NP1-1-3, NP1-1-4, NP1-1-5, NP1-1-6, NP1-1-8 and NP1-1-9.

A Method blank associated with sample analysis does not indicate any contamination and all internal Quality Control analyses are acceptable.

I have thoroughly reviewed the sequences associated with this analysis and I can only conclude that during the sample preparation that there was some laboratory cross contamination from a highly contaminated sample that was prepared at the same time as samples pertaining to this site.

Based on this information and supported by analysis of samples collected in February 2007, there is no BTEX present in the wells from these locations. It is believed that the reported values are a result of laboratory contamination.

On behalf of AAL, I sincerely apologize for any alarm this may have caused you and your client.

Very truly yours,

American Analytical Laboratories, LLC.

Lori Beyer
Laboratory Director

American Analytical Laboratories, LLC.

Date: 20-Feb-07

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0701095
Project: Rowe Industries

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK011607Y	SampType:	MBLK	TestCode:	8260MTBE11	Units:	µg/l	Prep Date:		RunNo:	22625	
Client ID:	PBW	Batch ID:	R22625	TestNo:	SW8260B			Analysis Date:	1/16/2007	SeqNo:	284398	
Analyte		Result	PQL	SPK value	SPK RefVal	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
1,1,1,2-Tetrachloroethane		U	1.0									
1,1,1-Trichloroethane		U	1.0									
1,1,2,2-Tetrachloroethane		U	1.0									
1,1,2-Trichloro-1,2,2-trifluoroethane		U	1.0									
1,1,2-Trichloroethane		U	1.0									
1,1-Dichloroethane		U	1.0									
1,1-Dichloroethene		U	1.0									
1,1-Dichloropropene		U	1.0									
1,2,3-Trichlorobenzene		U	1.0									
1,2,3-Trichloropropane		U	1.0									
1,2,4-Trichloroethene		U	1.0									
1,2,4-Trichlorobenzene		U	1.0									
1,2-Dibromo-3-chloropropane		U	1.0									
1,2-Dibromoethane		U	1.0									
1,2-Dichlorobenzene		U	1.0									
1,2-Dichloroethane		U	1.0									
1,2-Dichloropropane		U	1.0									
1,3,5-Trimethylbenzene		U	1.0									
1,3-Dichlorobenzene		U	1.0									
1,3-dichloropropane		U	1.0									
1,4-Dichlorobenzene		U	1.0									
2,2-Dichloropropane		U	1.0									
2-Chloroethyl vinyl ether		U	3.0									
2-Chlorotoluene		U	1.0									
2-Hexanone		U	2.0									
4-Chlorotoluene		U	1.0									
4-Isopropyltoluene		U	1.0									
4-Methyl-2-pentanone		U	2.0									
Acetone		U	2.0									

Qualifiers: E Value above quantitation range

ND Not Detected at the Reporting Limit

U Indicates the compound was analyzed for but not detected

H Holding times for preparation or analysis exceeded

R RPD outside accepted recovery limits

J Analyte detected below quantitation limit

S Spike Recovery outside accepted recd

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0701095
Project: Rowe Industries

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK011607Y	SampType:	MBLK	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:	
Client ID:	PBW	Batch ID:	R22625	TestNo:	SW8260B			Analysis Date:	1/16/2007
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val
Benzene		U	1.0						
Bromobenzene		U	1.0						
Bromoform		U	1.0						
Bromomethane		U	1.0						
Bromodichloromethane		U	1.0						
Carbon disulfide		U	1.0						
Carbon tetrachloride		U	1.0						
Chlorobenzene		U	1.0						
Chloroethane		U	1.0						
Chloroform		U	1.0						
Chloromethane		U	1.0						
cis-1,2-Dichloroethene		U	1.0						
cis-1,3-Dichloropropene		U	1.0						
Dibromochloromethane		U	1.0						
Dibromomethane		U	1.0						
Dichlorodifluoromethane		U	1.0						
Ethylbenzene		U	1.0						
Hexachlorobutadiene		U	1.0						
Isopropylbenzene		U	1.0						
m,p-Xylene		U	2.0						
Methyl tert-butyl ether		U	1.0						
Methylene chloride		U	5.9						
Naphthalene		U	1.0						
n-Butylbenzene		U	1.0						
n-Propylbenzene		U	1.0						
o-Xylene		U	1.0						
sec-Butylbenzene		U	1.0						
Styrene		U	1.0						
tert-Butylbenzene		U	1.0						
Tetrachloroethene		U	1.0						

Qualifiers:	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limit
	ND	Not Detected at the Reporting Limit	R	RPD outside accepted recovery limits	S	Spike Recovery outside accepted rec
U		Indicates the compound was analyzed for but not detected				

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0701095
Project: Rowe Industries

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK011607Y	SampType:	MBLK	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	22625	
Client ID:	PBW	Batch ID:	R22625	TestNo:	SW8260B			Analysis Date:	1/16/2007	SeqNo:	284398	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Toluene		U	1.0									
trans-1,2-Dichloroethene		U	1.0									
trans-1,3-Dichloropropene		U	1.0									
Trichloroethene		U	1.0									
Trichlorofluoromethane		U	1.0									
Vinyl acetate		U	1.0									
Vinyl chloride		U	1.0									
Surr: 4-Bromofluorobenzene		43		50.00			85.3		54		134	
Surr: Dibromofluoromethane		61		50.00			121		52		132	
Surr: Toluene-d8		51		50.00			103		51		127	

Sample ID	VLCSD011607Y	SampType:	LCS	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	22625	
Client ID:	LCSW	Batch ID:	R22625	TestNo:	SW8260B			Analysis Date:	1/16/2007	SeqNo:	284399	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
1,1-Dichloroethene		64	1.0	50.00	0		128		51		139	
Benzene		67	1.0	50.00	0		133		53		135	
Chlorobenzene		60	1.0	50.00	0		120		58		142	
Toluene		55	1.0	50.00	0		109		50		142	
Trichloroethene		52	1.0	50.00	0		104		53		131	
Surr: 4-Bromofluorobenzene		42		50.00			84.9		54		134	
Surr: Dibromofluoromethane		65		50.00			131		52		132	
Surr: Toluene-d8		50		50.00			99.3		51		127	

Sample ID	0701095-07AMS	SampType:	MS	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	22625	
Client ID:	GWQ011007-900 NP	Batch ID:	R22625	TestNo:	SW8260B			Analysis Date:	1/17/2007	SeqNo:	284411	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
1,1-Dichloroethene		47	1.0	50.00	0		93.9		51		139	
Benzene		49	1.0	50.00	0		97.8		53		135	
Chlorobenzene		48	1.0	50.00	0		96.5		58		142	

Qualifiers: E Value above quantitation range
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

H Holding times for preparation or analysis exceeded
R RPD outside accepted recovery limits

J Analyte detected below quantitation limit
S Spike Recovery outside accepted range

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0701095
Project: Rowe Industries

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	0701095-07AMS	SampType:	MS	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	22625	
Client ID:	GWQ011007:900 NP	Batch ID:	R22625	TestNo:	SW8260B			Analysis Date:	1/17/2007	SeqNo:	284411	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Toluene		44	1.0	50.00	1.420	85.8	50	142				
Trichloroethene		51	1.0	50.00	0	101	53	131				
Surr: 4-Bromofluorobenzene		48		50.00		96.7	54	134				
Surr: Dibromofluoromethane		54		50.00		108	52	132				
Surr: Toluene-d8		43		50.00		85.7	51	127				

Sample ID	0701095-07AMSD	SampType:	MSD	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	22625	
Client ID:	GWQ011007:900 NP	Batch ID:	R22625	TestNo:	SW8260B			Analysis Date:	1/17/2007	SeqNo:	284412	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
1,1-Dichloroethene		48	1.0	50.00	0	96.4	51	139	46.94	2.67	20	
Benzene		53	1.0	50.00	0	105	53	135	48.92	7.48	20	
Chlorobenzene		54	1.0	50.00	0	108	58	142	48.27	11.5	20	
Toluene		54	1.0	50.00	1.420	105	50	142	44.33	19.7	20	
Trichloroethene		53	1.0	50.00	0	106	53	131	50.74	4.79	20	
Surr: 4-Bromofluorobenzene		47		50.00		93.5	54	134		0	0	
Surr: Dibromofluoromethane		61		50.00		123	52	132		0	0	
Surr: Toluene-d8		61		50.00		122	51	127		0	0	

Sample ID	VLC5011707Y	SampType:	LCS	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	22625	
Client ID:	LCSW	Batch ID:	R22625A	TestNo:	SW8260B			Analysis Date:	1/17/2007	SeqNo:	284594	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
1,1-Dichloroethene		47	1.0	50.00	0	94.8	51	139				
Benzene		61	1.0	50.00	0	123	53	135				
Chlorobenzene		50	1.0	50.00	0	101	58	142				
Toluene		47	1.0	50.00	0	93.0	50	142				
Trichloroethene		50	1.0	50.00	0	101	53	131				
Surr: 4-Bromofluorobenzene		38		50.00		76.2	54	134				
Surr: Dibromofluoromethane		66		50.00		133	52	132				
Surr: Toluene-d8		51		50.00		102	51	127				

Qualifiers: E Value above quantitation range
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

H Holding times for preparation or analysis exceeded
 R RPD outside accepted recovery limits
 S Spike Recovery outside accepted recd

J Analyte detected below quantitation l
 S Spike Recovery outside accepted recd

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0701095
Project: Rowe Industries

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK011707Y	SampType	MBLK	TestCode:	8260MTBE11	Units: µg/L	Prep Date:		RunNo:	22625		
Client ID:	PBW	Batch ID:	R22625A	TestNo:	SW8260B		Analysis Date:	1/17/2007	SeqNo:	284595		
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
1,1,1,2-Tetrachloroethane		U	1.0									
1,1,1-Trichloroethane		U	1.0									
1,1,2,2-Tetrachloroethane		U	1.0									
1,1,2-Trichloro-1,2,2-trifluoroethane		U	1.0									
1,1,2-Trichloroethane		U	1.0									
1,1-Dichloroethane		U	1.0									
1,1-Dichloroethene		U	1.0									
1,1-Dichloropropene		U	1.0									
1,2,3-Trichlorobenzene		U	1.0									
1,2,3-Trichloropropane		U	1.0									
1,2,4-Trichlorobenzene		U	1.0									
1,2,4-Trimethylbenzene		U	1.0									
1,2-Dibromo-3-chloropropane		U	1.0									
1,2-Dibromoethane		U	1.0									
1,2-Dichlorobenzene		U	1.0									
1,2-Dichloroethane		U	1.0									
1,2-Dichloropropane		U	1.0									
1,3,5-Trimethylbenzene		U	1.0									
1,3-Dichlorobenzene		U	1.0									
1,3-dichloropropane		U	1.0									
1,4-Dichlorobenzene		U	1.0									
2,2-Dichloropropane		U	1.0									
2-Butanone		U	3.0									
2-Chloroethyl vinyl ether		U	1.0									
2-Chlorotoluene		U	1.0									
2-Hexanone		U	2.0									
4-Chlorotoluene		U	1.0									
4-Isopropyltoluene		U	1.0									
4-Methyl-2-pentanone		U	2.0									
Acetone		U	2.0									
Benzene		U	1.0									

Qualifiers: E Value above quantitation range
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

H Holding times for preparation or analysis exceeded
R RPD outside accepted recovery limits
S Spike Recovery outside accepted limits

J Analyte detected below quantitation limit
S Spike Recovery outside accepted rec

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0701095
Project: Rowe Industries

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK011707Y	SampType:	MBLK	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	22625	
Client ID:	PBW	Batch ID:	R22625A	TestNo:	SW8260B			Analysis Date:	1/17/2007	SeqNo:	284595	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Bromobenzene		U	1.0									
Bromochloromethane		U	1.0									
Bromodichloromethane		U	1.0									
Bromoform		U	1.0									
Bromomethane		U	1.0									
Carbon disulfide		U	1.0									
Carbon tetrachloride		U	1.0									
Chlorobenzene		U	1.0									
Chloroethane		U	1.0									
Chloroform		U	1.0									
Chloromethane		U	1.0									
cis-1,2-Dichloroethene		U	1.0									
cis-1,3-Dichloropropene		U	1.0									
Dibromochloromethane		U	1.0									
Dibromomethane		U	1.0									
Dichlorodifluoromethane		U	1.0									
Ethylbenzene		U	1.0									
Hexachlorobutadiene		U	1.0									
Isopropylbenzene		U	1.0									
m,p-Xylene		U	2.0									
Methyl tert-butyl ether		U	1.0									
Methylene chloride		23	1.0									
Naphthalene		U	1.0									
n-Butylbenzene		U	1.0									
n-Propylbenzene		U	1.0									
o-Xylene		U	1.0									
sec-Butylbenzene		U	1.0									
Styrene		U	1.0									
tert-Butylbenzene		U	1.0									
Tetrachloroethene		U	1.0									
Toluene		U	1.0									

Qualifiers: E Value above quantitation range
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

H Holding times for preparation or analysis exceeded
R RPD outside accepted recovery limits

J Analyte detected below quantitation limit
S Spike Recovery outside accepted range

CLIENT: Leggette Brashears & Graham Inc.
Work Order: 0701095
Project: Rowe Industries

ANALYTICAL QC SUMMARY REPORT

TestCode: 8260MTBE113_W

Sample ID	VBLK011707Y	SampType:	MBLK	TestCode:	8260MTBE11	Units:	µg/L	Prep Date:		RunNo:	22625	
Client ID:	PBW	Batch ID:	R22625A	TestNo:	SW8260B			Analysis Date:	1/17/2007	SeqNo:	284595	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
trans-1,2-Dichloroethene		U	1.0									
trans-1,3-Dichloropropene		U	1.0									
Trichloroethene		U	1.0									
Trichlorofluoromethane		U	1.0									
Vinyl acetate		U	1.0									
Vinyl chloride		U	1.0									
Surr: 4-Bromofluorobenzene	38		50.00		50.00		75.1	54	134			
Surr: Dibromofluoromethane	58		50.00		50.00		117	52	132			
Surr: Toluene-d8	62		50.00		50.00		123	51	127			

Qualifiers: E Value above quantitation range
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

H Holding times for preparation or analysis exceeded
 R RPD outside accepted recovery limits

J Analyte detected below quantitation limit
 S Spike Recovery outside accepted recd



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, January 18, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0701095

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 7 sample(s) on 1/12/2007 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0701095

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0701095-01A	GWQ011007:800 NP1-1-2	10296	1/10/2007	1/12/2007
0701095-01B	GWQ011007:800 NP1-1-2	10296	1/10/2007	1/12/2007
0701095-01C	GWQ011007:800 NP1-1-2	10296	1/10/2007	1/12/2007
0701095-01D	GWQ011007:800 NP1-1-2	10296	1/10/2007	1/12/2007
0701095-02A	GWQ011007:810 NP1-1-3	10296	1/10/2007	1/12/2007
0701095-02B	GWQ011007:810 NP1-1-3	10296	1/10/2007	1/12/2007
0701095-02C	GWQ011007:810 NP1-1-3	10296	1/10/2007	1/12/2007
0701095-02D	GWQ011007:810 NP1-1-3	10296	1/10/2007	1/12/2007
0701095-03A	GWQ011007:820 NP1-1-4	10296	1/10/2007	1/12/2007
0701095-03B	GWQ011007:820 NP1-1-4	10296	1/10/2007	1/12/2007
0701095-03C	GWQ011007:820 NP1-1-4	10296	1/10/2007	1/12/2007
0701095-03D	GWQ011007:820 NP1-1-4	10296	1/10/2007	1/12/2007
0701095-04A	GWQ011007:830 NP1-1-5	10296	1/10/2007	1/12/2007
0701095-04B	GWQ011007:830 NP1-1-5	10296	1/10/2007	1/12/2007
0701095-04C	GWQ011007:830 NP1-1-5	10296	1/10/2007	1/12/2007
0701095-04D	GWQ011007:830 NP1-1-5	10296	1/10/2007	1/12/2007
0701095-05A	GWQ011007:840 NP1-1-6	10296	1/10/2007	1/12/2007
0701095-05B	GWQ011007:840 NP1-1-6	10296	1/10/2007	1/12/2007
0701095-05C	GWQ011007:840 NP1-1-6	10296	1/10/2007	1/12/2007
0701095-05D	GWQ011007:840 NP1-1-6	10296	1/10/2007	1/12/2007
0701095-06A	GWQ011007:850 NP1-1-8	10296	1/10/2007	1/12/2007
0701095-06B	GWQ011007:850 NP1-1-8	10296	1/10/2007	1/12/2007
0701095-06C	GWQ011007:850 NP1-1-8	10296	1/10/2007	1/12/2007
0701095-06D	GWQ011007:850 NP1-1-8	10296	1/10/2007	1/12/2007
0701095-07A	GWQ011007:900 NP1-1-9	10296	1/10/2007	1/12/2007
0701095-07B	GWQ011007:900 NP1-1-9	10296	1/10/2007	1/12/2007
0701095-07C	GWQ011007:900 NP1-1-9	10296	1/10/2007	1/12/2007
0701095-07D	GWQ011007:900 NP1-1-9	10296	1/10/2007	1/12/2007



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

56 TOLEDO STREET • FARMINGDALE
(631) 454-6100 • FAX (631) 454-8027

11418
PH-0205
NY050
68-573

NYSDC
CTDOH
NJDEP
PADEP

10296
TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT						
CLIENT NAME/ADDRESS #B5 4 Research Dr. Shelton, CT		CONTACT: Mark Goldberg		SAMPLER SIGNATURE <i>M. J.</i>	SAMPLER NAME (PRINT) Rob Drew	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES / NO
PROJECT LOCATION: House		ANALYSIS REQUIRED 8/26/0		REQUERED SAMPLES 10/10/07: 800 NPI-1-3 10/10/07: 810 NPI-1-3 10/10/07: 820 NPI-1-4 10/10/07: 830 NPI-1-5 10/10/07: 840 NPI-1-6 10/10/07: 850 NPI-1-8 10/10/07: 900 NPI-1-9		CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES / NO
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION		FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
0701095-01ABC	L	5	10/07	10/07: 800 NPI-1-3		
-01ABC				10/07: 810 NPI-1-3		
-02ABC				10/07: 820 NPI-1-4		
-04ABC				10/07: 830 NPI-1-5		
-05ABC				10/07: 840 NPI-1-6		
-06ABC				10/07: 850 NPI-1-8		
-07ABC				10/07: 900 NPI-1-9		
COOLER TEMPERATURE:						
COMMENTS / INSTRUCTIONS						
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL		TURNAROUND REQUIRED:				
TYPE G=GRAB; C=COMPOSITE; SS=SPLIT SPOON		NORMAL <input checked="" type="checkbox"/>	STAT <input type="checkbox"/>	BY <input type="checkbox"/>	/	/
RELINQUISHED BY (SIGNATURE) <i>M. J.</i>		DATE 10/10/07 TIME 17:00	PRINTED NAME Rob Drew	RECEIVED BY LAB (SIGNATURE) <i>Rob Drew</i>	DATE 10/10/07 TIME 17:00 hrs	PRINTED NAME C. Meiss;
RELINQUISHED BY (SIGNATURE) <i>C. Meiss</i>		DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE	PRINTED NAME

AMERICAN ANALYTICAL LABORATORIES, LLC
56 TOLEDO STREET
FARMINGDALE, NEW YORK 11735
TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:800 NP1-1-2
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-01A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,1,1-Trichloroethane	68	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
2-Butanone	U	3.0		µg/L	1	1/17/2007 9:57:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
2-Hexanone	U	2.0		µg/L	1	1/17/2007 9:57:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/17/2007 9:57:00 PM
Acetone	U	2.0		µg/L	1	1/17/2007 9:57:00 PM
Benzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Bromobenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Bromoform	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Bromomethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:800 NP1-1-2
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-01A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Chloroform	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Chloromethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Dibromomethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
m,p-Xylene	2.3	2.0		µg/L	1	1/17/2007 9:57:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Methylene chloride	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Naphthalene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
o-Xylene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Styrene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Tetrachloroethene	4.2	1.0		µg/L	1	1/17/2007 9:57:00 PM
Toluene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Trichloroethene	2.7	1.0		µg/L	1	1/17/2007 9:57:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/17/2007 9:57:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	1/17/2007 3:00:00 AM
Surr: 4-Bromofluorobenzene	77.5	54-134		%REC	1	1/17/2007 9:57:00 PM
Surr: Dibromofluoromethane	113	52-132		%REC	1	1/17/2007 9:57:00 PM
Surr: Dibromofluoromethane	0	52-132	S	%REC	1	1/17/2007 3:00:00 AM
Surr: Toluene-d8	107	51-127		%REC	1	1/17/2007 9:57:00 PM
Surr: Toluene-d8	243	51-127	S	%REC	1	1/17/2007 3:00:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:800 NP1-1-2
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-01B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	2.77	0.0200		mg/L	1	1/16/2007 9:57:40 AM
Manganese	0.582	0.0200		mg/L	1	1/16/2007 9:57:40 AM

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detected	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:800 NPI-1-2
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-01C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE						
Iron	0.458	0.0200		mg/L	1	1/16/2007 9:55:43 AM
Manganese	0.572	0.0200		mg/L	1	1/16/2007 9:55:43 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:800 NP1-1-2
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-01D	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						
Hardness, Calcium/Magnesium (As CaCO ₃)	51.7	1.00		mg/L	1	1/16/2007
TURBIDITY						
Turbidity	1.70	1.00	H	NTU	1	1/15/2007
TOTAL DISSOLVED SOLIDS						
Total Dissolved Solids (Residue, Filterable)	162	1.00		mg/L	1	1/17/2007

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detected	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:810 NPI-1-3
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-02A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,1,1-Trichloroethane	3.5	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,2-Dichloropropene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
2-Butanone	U	3.0		µg/L	1	1/17/2007 10:55:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
2-Hexanone	U	2.0		µg/L	1	1/17/2007 10:55:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/17/2007 10:55:00 PM
Acetone	U	2.0		µg/L	1	1/17/2007 10:55:00 PM
Benzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Bromobenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Bromoform	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Bromomethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:810 NP1-1-3
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-02A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11				SW8260B		Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Chloroform	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Chloromethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Dibromomethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
m,p-Xylene	2.1	2.0		µg/L	1	1/17/2007 10:55:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Methylene chloride	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Naphthalene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
o-Xylene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Styrene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Tetrachloroethene	1.2	1.0		µg/L	1	1/17/2007 10:55:00 PM
Toluene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Trichloroethene	8.0	1.0		µg/L	1	1/17/2007 10:55:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/17/2007 10:55:00 PM
Surr: 4-Bromofluorobenzene	133	54-134		%REC	1	1/17/2007 4:25:00 AM
Surr: 4-Bromofluorobenzene	84.3	54-134		%REC	1	1/17/2007 10:55:00 PM
Surr: Dibromofluoromethane	117	52-132		%REC	1	1/17/2007 10:55:00 PM
Surr: Dibromofluoromethane	0	52-132	S	%REC	1	1/17/2007 4:25:00 AM
Surr: Toluene-d8	96.9	51-127		%REC	1	1/17/2007 10:55:00 PM
Surr: Toluene-d8	0	51-127	S	%REC	1	1/17/2007 4:25:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701095
Project: Rowe Industries
Lab ID: 0701095-02B

Client Sample ID: GWQ011007:810 NP1-1-3
Tag Number: 10296
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	1.87	0.0200		mg/L	1	1/16/2007 10:05:50 AM
Manganese	0.112	0.0200		mg/L	1	1/16/2007 10:05:50 AM

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detecte	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701095
Project: Rowe Industries
Lab ID: 0701095-02C

Client Sample ID: GWQ011007:810 NPI-1-3
Tag Number: 10296
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	1.63	0.0200		mg/L	1	1/16/2007 10:03:34 AM
Manganese	0.111	0.0200		mg/L	1	1/16/2007 10:03:34 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:810 NP1-1-3
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-02D	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO ₃)	40.9	1.00		mg/L	1	Analyst: JP 1/16/2007
TURBIDITY Turbidity	1.30	1.00	H	NTU	1	Analyst: KK 1/15/2007
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	122	1.00		mg/L	1	Analyst: JC 1/17/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701095
Project: Rowe Industries
Lab ID: 0701095-03A

Client Sample ID: GWQ011007:820 NP1-1-4
Tag Number: 10296
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,1,1-Trichloroethane	4.6	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
2-Butanone	U	3.0		µg/L	1	1/17/2007 5:21:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
2-Hexanone	U	2.0		µg/L	1	1/17/2007 5:21:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/17/2007 5:21:00 AM
Acetone	U	2.0		µg/L	1	1/17/2007 5:21:00 AM
Benzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Bromobenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Bromoform	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Bromomethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701095
Project: Rowe Industries
Lab ID: 0701095-03A

Client Sample ID: GWQ011007:820 NP1-1-4
Tag Number: 10296
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11				SW8260B		Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Chloroform	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Chloromethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Dibromomethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Ethylbenzene	4.3	1.0		µg/L	1	1/17/2007 5:21:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
m,p-Xylene	15	2.0		µg/L	1	1/17/2007 5:21:00 AM
Methyl tert-butyl ether	0.91	1.0	J	µg/L	1	1/17/2007 5:21:00 AM
Methylene chloride	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Naphthalene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
o-Xylene	4.2	1.0		µg/L	1	1/17/2007 5:21:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Styrene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Tetrachloroethene	12	1.0		µg/L	1	1/17/2007 5:21:00 AM
Toluene	3.0	1.0		µg/L	1	1/17/2007 5:21:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Trichloroethene	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/17/2007 5:21:00 AM
Surr: 4-Bromofluorobenzene	99.2	54-134		%REC	1	1/17/2007 5:21:00 AM
Surr: Dibromofluoromethane	103	52-132		%REC	1	1/17/2007 5:21:00 AM
Surr: Toluene-d8	106	51-127		%REC	1	1/17/2007 5:21:00 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detecte

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:820 NP1-1-4
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-03B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	3.17	0.0200		mg/L	1	1/16/2007 10:12:25 AM
Manganese	1.13	0.0200		mg/L	1	1/16/2007 10:12:25 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:820 NP1-1-4
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE						
Iron	0.0794	0.0200		mg/L	1	1/16/2007 10:09:22 AM
Manganese	1.13	0.0200		mg/L	1	1/16/2007 10:09:22 AM

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detecte	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:820 NP1-1-4
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-03D	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO ₃)	39.7	1.00		mg/L	1	Analyst: JP 1/16/2007
TURBIDITY Turbidity	1.20	1.00	H	NTU	1	Analyst: KK 1/15/2007
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	160	1.00		mg/L	1	Analyst: JC 1/17/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701095
Project: Rowe Industries
Lab ID: 0701095-04A

Client Sample ID: GWQ011007:830 NP1-1-5
Tag Number: 10296
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
2-Butanone	U	3.0		µg/L	1	1/17/2007 6:18:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
2-Hexanone	U	2.0		µg/L	1	1/17/2007 6:18:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/17/2007 6:18:00 AM
Acetone	U	2.0		µg/L	1	1/17/2007 6:18:00 AM
Benzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Bromobenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Bromoform	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Bromomethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701095
Project: Rowe Industries
Lab ID: 0701095-04A

Client Sample ID: GWQ011007:830 NP1-1-5
Tag Number: 10296
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Chloroform	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Chloromethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Dibromomethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Ethylbenzene	3.9	1.0		µg/L	1	1/17/2007 6:18:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
m,p-Xylene	12	2.0		µg/L	1	1/17/2007 6:18:00 AM
Methyl tert-butyl ether	1.2	1.0		µg/L	1	1/17/2007 6:18:00 AM
Methylene chloride	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Naphthalene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
o-Xylene	3.5	1.0		µg/L	1	1/17/2007 6:18:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Styrene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Tetrachloroethene	1.2	1.0		µg/L	1	1/17/2007 6:18:00 AM
Toluene	2.8	1.0		µg/L	1	1/17/2007 6:18:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Trichloroethene	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/17/2007 6:18:00 AM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	1/17/2007 6:18:00 AM
Surr: Dibromofluoromethane	110	52-132		%REC	1	1/17/2007 6:18:00 AM
Surr: Toluene-d8	102	51-127		%REC	1	1/17/2007 6:18:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:830 NP1-1-5
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-04B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		
Iron	0.0608	0.0200		mg/L	1	1/16/2007 10:19:37 AM
Manganese	0.00783	0.0200	J	mg/L	1	1/16/2007 10:19:37 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:830 NP1-1-5
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-04C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0128	0.0200	J	mg/L	1	1/16/2007 10:17:42 AM
Manganese	0.00729	0.0200	J	mg/L	1	1/16/2007 10:17:42 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:830 NP1-1-5
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-04D	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO ₃)	37.4	1.00		mg/L	1	1/16/2007
TURBIDITY Turbidity	U	1.00	H	NTU	1	1/15/2007
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	176	1.00		mg/L	1	1/17/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701095
Project: Rowe Industries
Lab ID: 0701095-05A

Client Sample ID: GWQ011007:840 NP1-1-6
Tag Number: 10296
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,1,1-Trichloroethane	16	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
2-Butanone	U	3.0		µg/L	1	1/17/2007 7:19:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
2-Hexanone	U	2.0		µg/L	1	1/17/2007 7:19:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/17/2007 7:19:00 AM
Acetone	U	2.0		µg/L	1	1/17/2007 7:19:00 AM
Benzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Bromobenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Bromoform	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Bromomethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701095
Project: Rowe Industries
Lab ID: 0701095-05A

Client Sample ID: GWQ011007:840 NP1-1-6
Tag Number: 10296
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11				SW8260B		Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Chloroform	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Chloromethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Dibromomethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Ethylbenzene	3.2	1.0		µg/L	1	1/17/2007 7:19:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
m,p-Xylene	11	2.0		µg/L	1	1/17/2007 7:19:00 AM
Methyl tert-butyl ether	2.1	1.0		µg/L	1	1/17/2007 7:19:00 AM
Methylene chloride	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Naphthalene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
o-Xylene	3.3	1.0		µg/L	1	1/17/2007 7:19:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Styrene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Tetrachloroethene	46	1.0		µg/L	1	1/17/2007 7:19:00 AM
Toluene	2.2	1.0		µg/L	1	1/17/2007 7:19:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Trichloroethene	0.96	1.0	J	µg/L	1	1/17/2007 7:19:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/17/2007 7:19:00 AM
Surr: 4-Bromofluorobenzene	99.0	54-134		%REC	1	1/17/2007 7:19:00 AM
Surr: Dibromofluoromethane	95.2	52-132		%REC	1	1/17/2007 7:19:00 AM
Surr: Toluene-d8	104	51-127		%REC	1	1/17/2007 7:19:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:840 NP1-1-6
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-05B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.0348	0.0200		mg/L	1	1/16/2007 10:43:25 AM
Manganese	0.164	0.0200		mg/L	1	1/16/2007 10:43:25 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:840 NP1-1-6
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-05C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	U	0.0200		mg/L	1	1/16/2007 10:40:24 AM
Manganese	0.156	0.0200		mg/L	1	1/16/2007 10:40:24 AM

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detected	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:840 NP1-1-6
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-05D	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS				M2340 B		Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	38.4	1.00		mg/L	1	1/16/2007
TURBIDITY				E180.1		Analyst: KK
Turbidity	U	1.00	H	NTU	1	1/15/2007
TOTAL DISSOLVED SOLIDS				E160.1		Analyst: JC
Total Dissolved Solids (Residue, Filterable)	156	1.00		mg/L	1	1/17/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:850 NP1-1-8
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-06A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,1,1-Trichloroethane	3.5	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
2-Butanone	U	3.0		µg/L	1	1/17/2007 8:18:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
2-Hexanone	U	2.0		µg/L	1	1/17/2007 8:18:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/17/2007 8:18:00 AM
Acetone	U	2.0		µg/L	1	1/17/2007 8:18:00 AM
Benzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Bromobenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Bromoform	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Bromomethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM

Qualifiers:

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits
- X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701095
Project: Rowe Industries
Lab ID: 0701095-06A

Client Sample ID: GWQ011007:850 NP1-1-8
Tag Number: 10296
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Chloroform	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Chloromethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Dibromomethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Ethylbenzene	2.7	1.0		µg/L	1	1/17/2007 8:18:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
m,p-Xylene	9.3	2.0		µg/L	1	1/17/2007 8:18:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Methylene chloride	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Naphthalene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
o-Xylene	2.8	1.0		µg/L	1	1/17/2007 8:18:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Styrene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Tetrachloroethene	1.3	1.0		µg/L	1	1/17/2007 8:18:00 AM
Toluene	1.9	1.0		µg/L	1	1/17/2007 8:18:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Trichloroethene	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/17/2007 8:18:00 AM
Surr: 4-Bromofluorobenzene	97.7	54-134		%REC	1	1/17/2007 8:18:00 AM
Surr: Dibromofluoromethane	121	52-132		%REC	1	1/17/2007 8:18:00 AM
Surr: Toluene-d8	104	51-127		%REC	1	1/17/2007 8:18:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ011007:850 NP1-1-8**Lab Order:** 0701095**Tag Number:** 10296**Project:** Rowe Industries**Collection Date:** 1/10/2007**Lab ID:** 0701095-06B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	6.57	0.0200		mg/L	1	1/16/2007 10:50:37 AM
Manganese	0.678	0.0200		mg/L	1	1/16/2007 10:50:37 AM

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:850 NP1-1-8
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-06C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE						
Iron	0.810	0.0200		mg/L	1	1/16/2007 10:48:45 AM
Manganese	0.604	0.0200		mg/L	1	1/16/2007 10:48:45 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:850 NP1-1-8
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-06D	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS				M2340 B		Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	23.6	1.00		mg/L	1	1/16/2007
TURBIDITY				E180.1		Analyst: KK
Turbidity	1.80	1.00	H	NTU	1	1/15/2007
TOTAL DISSOLVED SOLIDS				E160.1		Analyst: JC
Total Dissolved Solids (Residue, Filterable)	106	1.00		mg/L	1	1/17/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:900 NP1-1-9
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-07A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,1,1-Trichloroethane	1.4	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
2-Butanone	U	3.0		µg/L	1	1/17/2007 9:16:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
2-Hexanone	U	2.0		µg/L	1	1/17/2007 9:16:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/17/2007 9:16:00 AM
Acetone	U	2.0		µg/L	1	1/17/2007 9:16:00 AM
Benzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Bromobenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Bromoform	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Bromomethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM

Qualifiers:

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Reporting Limit
- U Indicates the compound was analyzed for but not detected

- E Value above quantitation range
- J Analyte detected below quantitation limits
- S Spike Recovery outside accepted recovery limits
- X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:900 NP1-1-9
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-07A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Chloroform	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Chloromethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Dibromomethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Ethylbenzene	2.1	1.0		µg/L	1	1/17/2007 9:16:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
m,p-Xylene	7.0	2.0		µg/L	1	1/17/2007 9:16:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Methylene chloride	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Naphthalene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
o-Xylene	2.0	1.0		µg/L	1	1/17/2007 9:16:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Styrene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Toluene	1.4	1.0		µg/L	1	1/17/2007 9:16:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Trichloroethene	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/17/2007 9:16:00 AM
Surr: 4-Bromofluorobenzene	98.2	54-134		%REC	1	1/17/2007 9:16:00 AM
Surr: Dibromofluoromethane	107	52-132		%REC	1	1/17/2007 9:16:00 AM
Surr: Toluene-d8	107	51-127		%REC	1	1/17/2007 9:16:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:900 NP1-1-9
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-07B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE						
Iron	5.08	0.0200		mg/L	1	1/16/2007 10:56:19 AM
Manganese	0.600	0.0200		mg/L	1	1/16/2007 10:56:19 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:900 NP1-1-9
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-07C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0855	0.0200		mg/L	1	1/16/2007 10:54:22 AM
Manganese	0.562	0.0200		mg/L	1	1/16/2007 10:54:22 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ011007:900 NP1-1-9
Lab Order:	0701095	Tag Number:	10296
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701095-07D	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS				M2340 B		
Hardness, Calcium/Magnesium (As CaCO ₃)	24.9	1.00		mg/L	1	Analyst: JP 1/16/2007
TURBIDITY				E180.1		
Turbidity	2.10	1.00	H	NTU	1	Analyst: KK 1/15/2007
TOTAL DISSOLVED SOLIDS				E160.1		
Total Dissolved Solids (Residue, Filterable)	126	1.00		mg/L	1	Analyst: JC 1/17/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Friday, January 12, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0701036

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/5/2007 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0701036

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0701036-01A	WQ010307:800 NP2-6	10292	1/3/2007	1/5/2007
0701036-01B	WQ010307:800 NP2-6	10292	1/3/2007	1/5/2007
0701036-01C	WQ010307:800 NP2-6	10292	1/3/2007	1/5/2007
0701036-02A	WQ010307:805 NP2-7	10292	1/3/2007	1/5/2007
0701036-02B	WQ010307:805 NP2-7	10292	1/3/2007	1/5/2007
0701036-02C	WQ010307:805 NP2-7	10292	1/3/2007	1/5/2007
0701036-03A	WQ010307:810 NP2-10	10292	1/3/2007	1/5/2007
0701036-03B	WQ010307:810 NP2-10	10292	1/3/2007	1/5/2007
0701036-03C	WQ010307:810 NP2-10	10292	1/3/2007	1/5/2007



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

PH-0205
NY050
68-573

0292
TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT					
CLIENT NAME/ADDRESS LBG		CONTACT: Evan Foster		SAMPLER (SIGNATURE) <i>Evee Foster</i>	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES
PROJECT LOCATION: Rowe Industries		SAMPLER NAME (PRINT) Evee Foster		CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION	
C7010316-01ABC	L	4	01-03-07	W0010307:800NP2-6	
-02ABC	L	4	↓	W0010307:805NP2-7	
-03ABC	B	5	↓	W0010307:810NP2-10	
REQUISITIONED BY: TDS 11/13 Total 41.4 lbs					
ANALYSIS BY: BGC 11/13 Total 1.5 lbs					
FEDERAL 11/13 Total 41.4 lbs					
FOR ANALYSIS 11/13 Total 1.5 lbs					
COOLER TEMPERATURE:					
COMMENTS / INSTRUCTIONS		TURNAROUND REQUIRED:			
NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/>		BY / /			
REINQUISITION BY (SIGNATURE) <i>Evee Foster</i>		RECEIVED BY LAB (SIGNATURE) <i>Evee Foster</i>		DATE 11/15/07	PRINTED NAME Evee Foster
RELINQUISHED BY (SIGNATURE) <i>Evee Foster</i>		RECEIVED BY LAB (SIGNATURE) <i>Evee Foster</i>		DATE 11/15/07	PRINTED NAME Evee Foster
REINQUISITION BY (SIGNATURE) <i>Connie Major</i>		RECEIVED BY LAB (SIGNATURE) <i>Connie Major</i>		DATE 11/15/07	PRINTED NAME Connie Major
RELINQUISHED BY (SIGNATURE) <i>Connie Major</i>		RECEIVED BY LAB (SIGNATURE) <i>Connie Major</i>		DATE 11/15/07	PRINTED NAME Connie Major

AMERICAN ANALYTICAL LABORATORIES, LLC
56 TOLEDO STREET
FARMINGDALE, NEW YORK 11735
TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701036
Project: Rowe Industries
Lab ID: 0701036-01A

Client Sample ID: WQ010307:800 NP2-6
Tag Number: 10292
Collection Date: 1/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,1,1-Trichloroethane	8.3	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
2-Butanone	U	3.0		µg/L	1	1/10/2007 7:52:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
2-Hexanone	U	2.0		µg/L	1	1/10/2007 7:52:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/10/2007 7:52:00 AM
Acetone	U	2.0		µg/L	1	1/10/2007 7:52:00 AM
Benzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Bromobenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Bromoform	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Bromomethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detecte

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701036
Project: Rowe Industries
Lab ID: 0701036-01A

Client Sample ID: WQ010307:800 NP2-6
Tag Number: 10292
Collection Date: 1/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
Chloroethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Chloroform	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Chloromethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Dibromomethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/10/2007 7:52:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Methylene chloride	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Naphthalene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
o-Xylene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Styrene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Toluene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Trichloroethene	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/10/2007 7:52:00 AM
Surr: 4-Bromofluorobenzene	104	69-134		%REC	1	1/10/2007 7:52:00 AM
Surr: Dibromofluoromethane	117	70-135		%REC	1	1/10/2007 7:52:00 AM
Surr: Toluene-d8	104	71-123		%REC	1	1/10/2007 7:52:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701036
Project: Rowe Industries
Lab ID: 0701036-01B

Client Sample ID: WQ010307:800 NP2-6
Tag Number: 10292
Collection Date: 1/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	2.57	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 1/11/2007 10:54:05 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701036
Project: Rowe Industries
Lab ID: 0701036-01C

Client Sample ID: WQ010307:800 NP2-6
Tag Number: 10292
Collection Date: 1/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0175	E200.7 0.0200	J	SW3005A mg/L	1	Analyst: JP 1/11/2007 10:51:46 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701036
Project: Rowe Industries
Lab ID: 0701036-02A

Client Sample ID: WQ010307:805 NP2-7
Tag Number: 10292
Collection Date: 1/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
2-Butanone	U	3.0		µg/L	1	1/10/2007 8:30:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
2-Hexanone	U	2.0		µg/L	1	1/10/2007 8:30:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/10/2007 8:30:00 AM
Acetone	U	2.0		µg/L	1	1/10/2007 8:30:00 AM
Benzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Bromobenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Bromoform	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Bromomethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701036
Project: Rowe Industries
Lab ID: 0701036-02A

Client Sample ID: WQ010307:805 NP2-7
Tag Number: 10292
Collection Date: 1/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: KS
Chloroethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Chloroform	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Chloromethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Dibromomethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/10/2007 8:30:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Methylene chloride	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Naphthalene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
o-Xylene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Styrene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Toluene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Trichloroethene	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/10/2007 8:30:00 AM
Surr: 4-Bromofluorobenzene	103	69-134		%REC	1	1/10/2007 8:30:00 AM
Surr: Dibromofluoromethane	116	70-135		%REC	1	1/10/2007 8:30:00 AM
Surr: Toluene-d8	104	71-123		%REC	1	1/10/2007 8:30:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701036
Project: Rowe Industries
Lab ID: 0701036-02B

Client Sample ID: WQ010307:805 NP2-7
Tag Number: 10292
Collection Date: 1/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	1.66	E200.7	0.0200	mg/L	1	Analyst: JP 1/11/2007 11:11:12 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010307:805 NP2-7
Lab Order:	0701036	Tag Number:	10292
Project:	Rowe Industries	Collection Date:	1/3/2007
Lab ID:	0701036-02C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0388	E200.7	0.0200	mg/L	1	Analyst: JP 1/11/2007 10:59:35 AM

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detecte	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701036
Project: Rowe Industries
Lab ID: 0701036-03A

Client Sample ID: WQ010307:810 NP2-10
Tag Number: 10292
Collection Date: 1/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
2-Butanone	U	3.0		µg/L	1	1/10/2007 9:34:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
2-Hexanone	U	2.0		µg/L	1	1/10/2007 9:34:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/10/2007 9:34:00 AM
Acetone	U	2.0		µg/L	1	1/10/2007 9:34:00 AM
Benzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Bromobenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Bromoform	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Bromomethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701036
Project: Rowe Industries
Lab ID: 0701036-03A

Client Sample ID: WQ010307:810 NP2-10
Tag Number: 10292
Collection Date: 1/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
Chloroethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Chloroform	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Chloromethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Dibromomethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/10/2007 9:34:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Methylene chloride	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Naphthalene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
o-Xylene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Styrene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Toluene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Trichloroethene	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/10/2007 9:34:00 AM
Surr: 4-Bromofluorobenzene	107	69-134		%REC	1	1/10/2007 9:34:00 AM
Surr: Dibromofluoromethane	121	70-135		%REC	1	1/10/2007 9:34:00 AM
Surr: Toluene-d8	103	71-123		%REC	1	1/10/2007 9:34:00 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detecte

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ010307:810 NP2-10
Lab Order: 0701036 **Tag Number:** 10292
Project: Rowe Industries **Collection Date:** 1/3/2007
Lab ID: 0701036-03B **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	2.21	E200.7	0.0200	SW3010A mg/L	1	Analyst: JP 1/11/2007 11:16:37 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ010307:810 NP2-10
Lab Order:	0701036	Tag Number:	10292
Project:	Rowe Industries	Collection Date:	1/3/2007
Lab ID:	0701036-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0417	E200.7 0.0200		mg/L	1	Analyst: JP 1/11/2007 11:14:14 AM
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	114	E160.1 1.00		mg/L	1	Analyst: JC 1/10/2007

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detecte	X Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, January 18, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484
TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0701094

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/12/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0701094

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0701094-01A	WQ011007:900NP2-6	10294	1/10/2007	1/12/2007
0701094-01B	WQ011007:900NP2-6	10294	1/10/2007	1/12/2007
0701094-01C	WQ011007:900NP2-6	10294	1/10/2007	1/12/2007
0701094-02A	WQ011007:905 NP2-7	10294	1/10/2007	1/12/2007
0701094-02B	WQ011007:905 NP2-7	10294	1/10/2007	1/12/2007
0701094-02C	WQ011007:905 NP2-7	10294	1/10/2007	1/12/2007
0701094-03A	WQ011007:910 NP2-10	10294	1/10/2007	1/12/2007
0701094-03B	WQ011007:910 NP2-10	10294	1/10/2007	1/12/2007
0701094-03C	WQ011007:910 NP2-10	10294	1/10/2007	1/12/2007



56 TOLEDO STREET • FARMINGDALE, NEW YORK, 11735
(631) 454-6100 • FAX (631) 454-8027

NYSDC 11418
CTDOH PH-0205
NDEP NY-050
PADEP 68-573

TAG # / COC 10294

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <i>166 Seven Dr. 4 Skilton, CT</i>		CONTACT: <i>Mark Goldberg</i>	SAMPLER'S SIGNATURE: <i>MJ</i>	SAMPLE(S) SEALED <i>YES / NO</i>
PROJECT LOCATION:		SAMPLER NAME (PRINT) <i>Robert Drew</i>	CORRECT CONTAINER(S) <i>YES / NO</i>	FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION
0701094-DABE	L	4	1-10-06	WQ011007:900 WQ-6
-DABC	G	4		905 AB-7
-AAC	C	5		910 AAC-10
ANALYSIS RENDURED 8/26/06				
COOLER TEMPERATURE:				
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON		TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY / /		
RELINQUISHED BY (SIGNATURE) <i>J. C.</i>	DATE 1-11-06 TIME 1 PM	PRINTED NAME <i>Robert Drew</i>	RECEIVED BY LAB (SIGNATURE) <i>Aug 11</i>	PRINTED NAME <i>C. Mass.</i>
RELINQUISHED BY (SIGNATURE) <i>J. C.</i>	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	PRINTED NAME

AMERICAN ANALYTICAL LABORATORIES, LLC
56 TOLEDO STREET
FARMINGDALE, NEW YORK 11735
TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701094
Project: Rowe Industries
Lab ID: 0701094-01A

Client Sample ID: WQ011007:900NP2-6
Tag Number: 10294
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,1,1-Trichloroethane	10	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
2-Butanone	U	3.0		µg/L	1	1/16/2007 7:20:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
2-Hexanone	U	2.0		µg/L	1	1/16/2007 7:20:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/16/2007 7:20:00 PM
Acetone	U	2.0		µg/L	1	1/16/2007 7:20:00 PM
Benzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Bromobenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Bromoform	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Bromomethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detecte

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701094
Project: Rowe Industries
Lab ID: 0701094-01A

Client Sample ID: WQ011007:900NP2-6
Tag Number: 10294
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Chloroform	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Chloromethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Dibromomethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/16/2007 7:20:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Methylene chloride	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Naphthalene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
o-Xylene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Styrene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Tetrachloroethene	5.2	1.0		µg/L	1	1/16/2007 7:20:00 PM
Toluene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Trichloroethene	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/16/2007 7:20:00 PM
Surr: 4-Bromofluorobenzene	83.1	54-134		%REC	1	1/16/2007 7:20:00 PM
Surr: Dibromofluoromethane	129	52-132		%REC	1	1/16/2007 7:20:00 PM
Surr: Toluene-d8	101	51-127		%REC	1	1/16/2007 7:20:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011007:900NP2-6
Lab Order:	0701094	Tag Number:	10294
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701094-01B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	2.22	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 1/17/2007 12:52:42 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ011007:900NP2-6**Lab Order:** 0701094**Tag Number:** 10294**Project:** Rowe Industries**Collection Date:** 1/10/2007**Lab ID:** 0701094-01C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	U	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 1/17/2007 12:50:28 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ011007:905 NP2-7
Lab Order: 0701094 **Tag Number:** 10294
Project: Rowe Industries **Collection Date:** 1/10/2007
Lab ID: 0701094-02A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,2,4-Trimethylbenzene	3.6	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
2-Butanone	U	3.0		µg/L	1	1/16/2007 8:14:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
2-Hexanone	U	2.0		µg/L	1	1/16/2007 8:14:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/16/2007 8:14:00 PM
Acetone	U	2.0		µg/L	1	1/16/2007 8:14:00 PM
Benzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Bromobenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Bromoform	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Bromomethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detecte

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701094
Project: Rowe Industries
Lab ID: 0701094-02A

Client Sample ID: WQ011007:905 NP2-7
Tag Number: 10294
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Chloroform	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Chloromethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Dibromomethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/16/2007 8:14:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Methylene chloride	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Naphthalene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
o-Xylene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Styrene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Toluene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Trichloroethene	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/16/2007 8:14:00 PM
Surr: 4-Bromofluorobenzene	86.3	54-134		%REC	1	1/16/2007 8:14:00 PM
Surr: Dibromofluoromethane	122	52-132		%REC	1	1/16/2007 8:14:00 PM
Surr: Toluene-d8	95.1	51-127		%REC	1	1/16/2007 8:14:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011007:905 NP2-7
Lab Order:	0701094	Tag Number:	10294
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701094-02B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	1.35	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 1/17/2007 12:56:54 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011007:905 NP2-7
Lab Order:	0701094	Tag Number:	10294
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701094-02C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0449	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 1/17/2007 12:54:59 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011007:910 NP2-10
Lab Order:	0701094	Tag Number:	10294
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701094-03A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
2-Butanone	U	3.0		µg/L	1	1/16/2007 9:12:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
2-Hexanone	U	2.0		µg/L	1	1/16/2007 9:12:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/16/2007 9:12:00 PM
Acetone	U	2.0		µg/L	1	1/16/2007 9:12:00 PM
Benzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Bromobenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Bromoform	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Bromomethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701094
Project: Rowe Industries
Lab ID: 0701094-03A

Client Sample ID: WQ011007:910 NP2-10
Tag Number: 10294
Collection Date: 1/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: LDS
Chloroethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Chloroform	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Chloromethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Dibromomethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/16/2007 9:12:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Methylene chloride	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Naphthalene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
o-Xylene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Styrene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Toluene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Trichloroethene	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/16/2007 9:12:00 PM
Surr: 4-Bromofluorobenzene	84.4	54-134		%REC	1	1/16/2007 9:12:00 PM
Surr: Dibromofluoromethane	91.8	52-132		%REC	1	1/16/2007 9:12:00 PM
Surr: Toluene-d8	99.7	51-127		%REC	1	1/16/2007 9:12:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011007:910 NP2-10
Lab Order:	0701094	Tag Number:	10294
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701094-03B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	1.63	E200.7	0.0200	mg/L	1	Analyst: JP 1/17/2007 1:00:47 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level


American Analytical Laboratories, LLC.

Date: 18-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011007:910 NP2-10
Lab Order:	0701094	Tag Number:	10294
Project:	Rowe Industries	Collection Date:	1/10/2007
Lab ID:	0701094-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0371	E200.7 0.0200		mg/L	1	Analyst: JP 1/17/2007 12:58:50 PM
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	120	E160.1 1.00		mg/L	1	Analyst: JC 1/17/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Monday, January 29, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0701173

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/23/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0701173

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0701173-01A	WQ011807:800 NP 2-6	12815	1/18/2007	1/23/2007
0701173-01B	WQ011807:800 NP 2-6	12815	1/18/2007	1/23/2007
0701173-01C	WQ011807:800 NP 2-6	12815	1/18/2007	1/23/2007
0701173-02A	WQ011807:805 NP2-7	12815	1/18/2007	1/23/2007
0701173-02B	WQ011807:805 NP2-7	12815	1/18/2007	1/23/2007
0701173-02C	WQ011807:805 NP2-7	12815	1/18/2007	1/23/2007
0701173-03A	WQ011807:810 NP2-10	12815	1/18/2007	1/23/2007
0701173-03B	WQ011807:810 NP2-10	12815	1/18/2007	1/23/2007
0701173-03C	WQ011807:810 NP2-10	12815	1/18/2007	1/23/2007

AMERICAN ANALYTICAL LABORATORIES, LLC
56 TOLEDO STREET
FARMINGDALE, NEW YORK 11735
TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701173
Project: Rowe Industries
Lab ID: 0701173-01A

Client Sample ID: WQ011807:800 NP 2-6
Tag Number: 12815
Collection Date: 1/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,3,5-Timethylbenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
2-Butanone	U	3.0		µg/L	1	1/27/2007 12:12:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
2-Hexanone	U	2.0		µg/L	1	1/27/2007 12:12:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/27/2007 12:12:00 PM
Acetone	U	2.0		µg/L	1	1/27/2007 12:12:00 PM
Benzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Bromobenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Bromoform	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Bromomethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701173
Project: Rowe Industries
Lab ID: 0701173-01A

Client Sample ID: WQ011807:800 NP 2-6
Tag Number: 12815
Collection Date: 1/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11				SW8260B		Analyst: KS
Chloroethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Chloroform	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Chloromethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Dibromomethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/27/2007 12:12:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Methylene chloride	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Naphthalene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
o-Xylene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Styrene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Tetrachloroethene	6.7	1.0		µg/L	1	1/27/2007 12:12:00 PM
Toluene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Trichloroethene	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/27/2007 12:12:00 PM
Surr: 4-Bromofluorobenzene	95.2	54-134		%REC	1	1/27/2007 12:12:00 PM
Surr: Dibromofluoromethane	99.8	52-132		%REC	1	1/27/2007 12:12:00 PM
Surr: Toluene-d8	99.0	51-127		%REC	1	1/27/2007 12:12:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701173
Project: Rowe Industries
Lab ID: 0701173-01B

Client Sample ID: WQ011807:800 NP 2-6
Tag Number: 12815
Collection Date: 1/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	5.44	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 1/24/2007 12:23:45 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011807:800 NP 2-6
Lab Order:	0701173	Tag Number:	12815
Project:	Rowe Industries	Collection Date:	1/18/2007
Lab ID:	0701173-01C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		
Iron	0.0180	0.0200	J	mg/L	1	1/24/2007 12:21:36 PM

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detected	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701173
Project: Rowe Industries
Lab ID: 0701173-02A

Client Sample ID: WQ011807:805 NP2-7
Tag Number: 12815
Collection Date: 1/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
2-Butanone	U	3.0		µg/L	1	1/27/2007 12:51:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
2-Hexanone	U	2.0		µg/L	1	1/27/2007 12:51:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/27/2007 12:51:00 PM
Acetone	U	2.0		µg/L	1	1/27/2007 12:51:00 PM
Benzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Bromobenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Bromoform	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Bromomethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701173
Project: Rowe Industries
Lab ID: 0701173-02A

Client Sample ID: WQ011807:805 NP2-7
Tag Number: I2815
Collection Date: 1/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11				SW8260B		Analyst: KS
Chloroethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Chloroform	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Chloromethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Dibromomethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/27/2007 12:51:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Methylene chloride	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Naphthalene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
o-Xylene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Styrene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Toluene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Trichloroethene	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/27/2007 12:51:00 PM
Surr: 4-Bromofluorobenzene	96.4	54-134		%REC	1	1/27/2007 12:51:00 PM
Surr: Dibromofluoromethane	96.7	52-132		%REC	1	1/27/2007 12:51:00 PM
Surr: Toluene-d8	99.3	51-127		%REC	1	1/27/2007 12:51:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011807:805 NP2-7
Lab Order:	0701173	Tag Number:	12815
Project:	Rowe Industries	Collection Date:	1/18/2007
Lab ID:	0701173-02B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	22.0	E200.7	0.0200	mg/L	1	Analyst: JP 1/24/2007 12:37:07 PM

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detected	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 29-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011807:805 NP2-7
Lab Order:	0701173	Tag Number:	12815
Project:	Rowe Industries	Collection Date:	1/18/2007
Lab ID:	0701173-02C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.442	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 1/24/2007 12:30:55 PM

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detecte	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ011807:810 NP2-10
Lab Order: 0701173 **Tag Number:** 12815
Project: Rowe Industries **Collection Date:** 1/18/2007
Lab ID: 0701173-03A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
2-Butanone	U	3.0		µg/L	1	1/27/2007 1:30:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
2-Hexanone	U	2.0		µg/L	1	1/27/2007 1:30:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/27/2007 1:30:00 PM
Acetone	U	2.0		µg/L	1	1/27/2007 1:30:00 PM
Benzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Bromobenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Bromoform	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Bromomethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701173
Project: Rowe Industries
Lab ID: 0701173-03A

Client Sample ID: WQ011807:810 NP2-10
Tag Number: 12815
Collection Date: 1/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: KS
Chloroethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Chloroform	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Chloromethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Dibromomethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/27/2007 1:30:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Methylene chloride	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Naphthalene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
o-Xylene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Styrene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Toluene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Trichloroethene	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/27/2007 1:30:00 PM
Surr: 4-Bromofluorobenzene	95.5	54-134		%REC	1	1/27/2007 1:30:00 PM
Surr: Dibromofluoromethane	98.7	52-132		%REC	1	1/27/2007 1:30:00 PM
Surr: Toluene-d8	99.5	51-127		%REC	1	1/27/2007 1:30:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0701173
Project: Rowe Industries
Lab ID: 0701173-03B

Client Sample ID: WQ011807:810 NP2-10
Tag Number: 12815
Collection Date: 1/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	21.2	E200.7	0.0200	mg/L	1	Analyst: JP 1/24/2007 12:41:44 PM

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detecte	X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 29-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ011807:810 NP2-10
Lab Order:	0701173	Tag Number:	12815
Project:	Rowe Industries	Collection Date:	1/18/2007
Lab ID:	0701173-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.756	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 1/24/2007 12:39:57 PM
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	92.0	E160.1 1.00		mg/L	1	Analyst: JC 1/25/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, January 31, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0701210

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/26/2007 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0701210

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0701210-01A	WQ012307: 800 NP2-6	10298	1/23/2007	1/26/2007
0701210-01B	WQ012307: 800 NP2-6	10298	1/23/2007	1/26/2007
0701210-01C	WQ012307: 800 NP2-6	10298	1/23/2007	1/26/2007
0701210-02A	WQ012307: 805 NP2-7	10298	1/23/2007	1/26/2007
0701210-02B	WQ012307: 805 NP2-7	10298	1/23/2007	1/26/2007
0701210-02C	WQ012307: 805 NP2-7	10298	1/23/2007	1/26/2007
0701210-03A	WQ012307: 810 NP2-10	10298	1/23/2007	1/26/2007
0701210-03B	WQ012307: 810 NP2-10	10298	1/23/2007	1/26/2007
0701210-03C	WQ012307: 810 NP2-10	10298	1/23/2007	1/26/2007



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

NYSDC 11418
CTDOH PH-0205
NJDEP NY050
PADEP 68-573

TAG # / COC 10298

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <i>of BG 4 Research Dr. Shelfer Ct</i>	CONTACT: <i>M. Goldboog</i>	SAMPLER SIGNATURE: <i>M. Goldboog</i>	SAMPLER NAME (PRINT) <i>Rob Drew</i>	SAMPLE(S) SEALED <input checked="" type="checkbox"/> YES / NO	CORRECT CONTAINER(S) <input checked="" type="checkbox"/> YES / NO	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
PROJECT LOCATION: <i>Rose</i>						
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION		
070110-01ABC	L	4	1-23-07	WQ012307 : 800 NP2-6	P	P
-02ABC	G	4		↓ : 805 NP2-7	P	P
-03ABC	C	5	↓	↓ : 810 NP3-10	P	P
RENUMBERED ANALYSIS BOTTLES						
1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20						
COOLER TEMPERATURE:						
COMMENTS / INSTRUCTIONS						
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL			TURNAROUND REQUIRED:			
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON			<input checked="" type="checkbox"/> NORMAL	<input type="checkbox"/> STAT	<input type="checkbox"/> BY / /	
RELINQUISHED BY (SIGNATURE) <i>Rob Drew</i>	DATE 1/23/07 TIME 1pm	PRINTED NAME <i>Rob Drew</i>	RECEIVED BY LAB (SIGNATURE) <i>Conig Mer</i>	DATE 1/26/07 TIME 10am	PRINTED NAME <i>C. Mer</i>	
RELINQUISHED BY (SIGNATURE) <i>Tom Stoddle</i>	DATE 1/27/07 TIME 17:00	PRINTED NAME <i>Tom Stoddle</i>	RECEIVED BY LAB (SIGNATURE)	DATE	PRINTED NAME	
WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT						

AMERICAN ANALYTICAL LABORATORIES, LLC
56 TOLEDO STREET
FARMINGDALE, NEW YORK 11735
TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 800 NP2-6
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-01A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,1,1-Trichloroethane	9.0	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,2-Dichloropropene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
2,2-Dichloropropene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
2-Butanone	U	3.0		µg/L	1	1/27/2007 5:49:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
2-Hexanone	U	2.0		µg/L	1	1/27/2007 5:49:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/27/2007 5:49:00 PM
Acetone	U	2.0		µg/L	1	1/27/2007 5:49:00 PM
Benzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Bromobenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Bromoform	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Bromomethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 800 NP2-6
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-01A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: KS
Chloroethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Chloroform	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Chloromethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Dibromomethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
m,p-Xylene	15	2.0		µg/L	1	1/27/2007 5:49:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Methylene chloride	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Naphthalene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
o-Xylene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Styrene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Tetrachloroethene	4.7	1.0		µg/L	1	1/27/2007 5:49:00 PM
Toluene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Trichloroethene	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/27/2007 5:49:00 PM
Surr: 4-Bromofluorobenzene	79.3	54-134		%REC	1	1/27/2007 5:49:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	1/27/2007 5:49:00 PM
Surr: Toluene-d8	78.8	51-127		%REC	1	1/27/2007 5:49:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 800 NP2-6
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-01B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	1.77	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 1/30/2007 11:27:24 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 800 NP2-6
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-01C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0111	E200.7 0.0200	J	SW3005A mg/L	1	Analyst: JP 1/30/2007 11:25:21 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 805 NP2-7
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-02A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,2-Dichloropropene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
2-Butanone	U	3.0		µg/L	1	1/27/2007 6:26:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
2-Hexanone	U	2.0		µg/L	1	1/27/2007 6:26:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/27/2007 6:26:00 PM
Acetone	U	2.0		µg/L	1	1/27/2007 6:26:00 PM
Benzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Bromobenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Bromoform	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Bromomethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 805 NP2-7
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-02A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: KS
Chloroethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Chloroform	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Chloromethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Dibromomethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/27/2007 6:26:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Methylene chloride	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Naphthalene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
o-Xylene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Styrene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Toluene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Trichloroethene	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/27/2007 6:26:00 PM
Surr: 4-Bromofluorobenzene	84.8	54-134		%REC	1	1/27/2007 6:26:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	1/27/2007 6:26:00 PM
Surr: Toluene-d8	97.0	51-127		%REC	1	1/27/2007 6:26:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 805 NP2-7
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-02B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	1.06	E200.7		SW3010A mg/L	1	Analyst: JP 1/30/2007 11:32:09 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 805 NP2-7
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-02C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0447	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 1/30/2007 11:30:17 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 810 NP2-10
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-03A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11	SW8260B					Analyst: KS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,2-Dichloropropene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
2-Butanone	U	3.0		µg/L	1	1/27/2007 7:04:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
2-Hexanone	U	2.0		µg/L	1	1/27/2007 7:04:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/27/2007 7:04:00 PM
Acetone	U	2.0		µg/L	1	1/27/2007 7:04:00 PM
Benzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Bromobenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Bromoform	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Bromomethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 810 NP2-10
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-03A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 PLUS MTBE & FREON11			SW8260B			Analyst: KS
Chloroethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Chloroform	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Chloromethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Dibromomethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/27/2007 7:04:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Methylene chloride	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Naphthalene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
o-Xylene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Styrene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Toluene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Trichloroethene	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/27/2007 7:04:00 PM
Surr: 4-Bromofluorobenzene	82.2	54-134		%REC	1	1/27/2007 7:04:00 PM
Surr: Dibromofluoromethane	99.7	52-132		%REC	1	1/27/2007 7:04:00 PM
Surr: Toluene-d8	85.0	51-127		%REC	1	1/27/2007 7:04:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 810 NP2-10
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-03B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	1.08	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 1/30/2007 11:36:36 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ012307: 810 NP2-10
Lab Order:	0701210	Tag Number:	10298
Project:	Rowe Industries	Collection Date:	1/23/2007
Lab ID:	0701210-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0547	E200.7		SW3005A	1	Analyst: JP 1/30/2007 11:34:25 AM
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	102	E160.1		mg/L	1	Analyst: JC 1/29/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

H7A120102 Analytical Report	1
Sample Receipt Documentation	15
Total Number of Pages.....	17



STL

STL Knoxville
5815 Middlebrook Pike
Knoxville, TN 37921

Tel: 865 291 3000 Fax: 865 584 4315
www.stl-inc.com

ANALYTICAL REPORT

Rowe-NABSAG 0401

Lot #: H7A120102

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

SEVERN TRENT LABORATORIES, INC.

A handwritten signature in black ink, appearing to read "Jamie A. McKinney". Below the signature, the letters "fr" are written, likely indicating "for" or "from".

Jamie A. McKinney
Project Manager

January 23, 2007

ANALYTICAL METHODS SUMMARY

H7A120102

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15
References:	
EPA-2	"Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air", EPA-625/R-96/010b, January 1999.

SAMPLE SUMMARY

H7A120102

<u>WO #</u>	<u>SAMPLE#</u>	<u>CLIENT SAMPLE ID</u>	<u>SAMPLED DATE</u>	<u>SAMP TIME</u>
JMQNP	001	AQ011007:1000NP4-1	01/10/07	10:00
JMQNR	002	AQ011007:1001NP4-2	01/10/07	10:01
JMQNT	003	AQ011007:1002NP4-3	01/10/07	10:02

NOTE (S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

H7A120102

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

The date of collection listed on the chain of custody documentation shows 2006. The date should be 2007.

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

The EPA method requires that all target analytes in the continuing calibration verification standard be within 30% difference from the initial calibration. The laboratory standard operating procedure allows up to four analytes in the calibration verification to be $\leq 40\%$ difference from the initial calibration. The calibration verification analyzed on 01/12/07 exhibited a %difference of $>30\%$ but $\leq 40\%$ for vinyl chloride.

Samples were received on 01/12/07 in Tedlar bags and analyzed within 72 hours of sampling.

STL Knoxville maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. # QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ011007:1000NP4-1

GC/MS Volatiles

Lot-Sample #	H7A120102 - 001	Work Order #	JMQNP1AA	Matrix.....:	AIR
--------------	-----------------	--------------	----------	--------------	-----

Date Sampled...:	1/10/07	Date Received..:	1/12/07
Prep Date.....:	1/12/07	Analysis Date..:	1/12/07
Prep Batch #....:	7019461		
Dilution Factor.:	5	Method.....:	TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS ($\mu\text{g}/\text{m}^3$)	REPORTING LIMIT ($\mu\text{g}/\text{m}^3$)
Benzene	0.35	1.0	1.1	J 3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	1.9	2.5	5.9	J 7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.0	1.0	5.1	4.9
Chloromethane	1.5	2.5	3.0	J 5.2
1,1-Dichloroethane	2.1	1.0	8.4	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.79	1.0	3.1	J 4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.45	2.5	1.6	J B 8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	8.8	1.0	60	6.8
Toluene	0.44	1.0	1.6	J 3.8
1,1,1-Trichloroethane	15	1.0	80	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	1.5	1.0	8.2	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	0.26	1.0	1.1	J 4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	120	70 - 130
Toluene-d8	105	70 - 130
4-Bromofluorobenzene	99	70 - 130

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ011007:1000NP4-1

GC/MS Volatiles

Lot-Sample # H7A120102 - 001

Work Order # JMQNP1AA

Matrix.....: AIR

Qualifiers

- B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ011007:1001NP4-2

GC/MS Volatiles

Lot-Sample # H7A120102 - 002 Work Order # JMQNRIAA Matrix.....: AIR

Date Sampled...: 1/10/07 Date Received.: 1/12/07
 Prep Date.....: 1/12/07 Analysis Date..: 1/12/07
 Prep Batch #....: 7019461 Method.....: TO-15
 Dilution Factor.: 5

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	2.3	2.5	7.1	J
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.1	1.0	5.6	4.9
Chloromethane	1.6	2.5	3.2	J
1,1-Dichloroethane	2.9	1.0	12	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	1.3	1.0	5.0	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	1.2	1.0	4.7	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.41	2.5	1.4	J B
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	0.50	1.0	3.4	J
Toluene	0.34	1.0	1.3	J
1,1,1-Trichloroethane	59	1.0	320	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	0.18	1.0	0.98	J
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	117	70 - 130
Toluene-d8	108	70 - 130
4-Bromofluorobenzene	97	70 - 130

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ011007:1001NP4-2

GC/MS Volatiles

Lot-Sample # H7A120102 - 002

Work Order # JMQNR1AA

Matrix.....: AIR

Qualifiers

- B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m³ is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m³ is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ011007:1002NP4-3

GC/MS Volatiles

Lot-Sample # H7A120102 - 003

Work Order # JMQNT1AA

Matrix.....: AIR

Date Sampled...: 1/10/07 Date Received..: 1/12/07
 Prep Date.....: 1/12/07 Analysis Date..: 1/12/07
 Prep Batch #....: 7019461
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	1.5	2.5	4.8 J	7.8
Carbon tetrachloride	0.18	1.0	1.1 J	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.1	1.0	5.3	4.9
Chloromethane	1.4	2.5	2.8 J	5.2
1,1-Dichloroethane	4.4	1.0	18	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	1.6	1.0	6.5	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	1.2	1.0	4.7	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.35	2.5	1.2 JB	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	ND	1.0	ND	6.8
Toluene	0.33	1.0	1.3 J	3.8
1,1,1-Trichloroethane	41	1.0	230	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	120	70 - 130
Toluene-d8	104	70 - 130
4-Bromofluorobenzene	104	70 - 130

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ011007:1002NP4-3

GC/MS Volatiles

Lot-Sample # H7A120102 - 003

Work Order # JMQNT1AA

Matrix.....: AIR

Qualifiers

- B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m³ is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m³ is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.

Client Sample ID: INTRA-LAB BLANK

GC/MS Volatiles

Lot-Sample # H7A190000 - 461B

Work Order # JM43E1AA

Matrix.....: AIR

Prep Date.....: 1/12/07
 Prep Batch #....: 7019461
 Dilution Factor.: 1

Date Received..: 1/12/07
 Analysis Date..: 1/12/07
 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	0.62
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	0.067	0.50	0.23	J 1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	117	70 - 130
Toluene-d8	111	70 - 130
4-Bromofluorobenzene	98	70 - 130

Leggette, Brashears & Graham, Inc.

Client Sample ID: INTRA-LAB BLANK

GC/MS Volatiles

Lot-Sample # H7A190000 - 461B

Work Order # JM43E1AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
Client Sample ID: CHECK SAMPLE
GC/MS Volatiles

Lot-Sample # H7A190000 - 461C **Work Order #** JM43E1AC **Matrix.....:** AIR

Prep Date.....: 1/12/07 **Date Received..:** 1/12/07
Prep Batch #....: 7019461 **Analysis Date..** 1/12/07
Dilution Factor.: 1 **Method.....:** TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	10.0	7.62	32	24	76	70 - 130
Chlorobenzene	10.0	7.82	46	36	78	70 - 130
1,1-Dichloroethene	10.0	9.14	40	36	91	70 - 130
Toluene	10.0	7.83	38	29	78	70 - 130
Trichloroethene	10.0	7.97	54	43	80	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	117	70 - 130
Toluene-d8	104	70 - 130
4-Bromofluorobenzene	110	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

STL KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: LBCProject: R00F-Lot Number: N7A120102

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)	<input checked="" type="checkbox"/>			<input type="checkbox"/> 1a Do not match COC <input type="checkbox"/> 1b Incomplete information <input type="checkbox"/> 1c Marking smeared <input type="checkbox"/> 1d Label torn <input type="checkbox"/> 1e No label <input type="checkbox"/> 1f COC not received <input type="checkbox"/> 1g Other:	<u>16. ALL DATES ON COC SHOW 2006, SHOULD BE 2007</u>
2. Is the cooler temperature within limits? (> freezing temp. of water to 6 °C; NC, 1668, 1613B; 0-4°C; VOST: 10°C; MA: 2-6 °C)	<input checked="" type="checkbox"/>			<input type="checkbox"/> 2a Temp Blank = _____ <input type="checkbox"/> 2b Cooler Temp = _____	
3. Were samples received with correct chemical preservative (excluding Encore)?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 3a Sample preservative = _____	
4. Were custody seals present/intact on cooler and/or containers?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 4a Not present <input type="checkbox"/> 4b Not intact <input type="checkbox"/> 4c Other:	
5. Were all of the samples listed on the COC received?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 5a Samples received-not on COC <input type="checkbox"/> 5b Samples not received-on COC	
6. Were all of the sample containers received intact?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 6a Leaking <input type="checkbox"/> 6b Broken <input type="checkbox"/> 7a Headspace (VOA only)	
7. Were VOA samples received without headspace?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 8a Improper container <input type="checkbox"/> 9a Could not be determined due to matrix interference	
8. Were samples received in appropriate containers?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 10a Holding time expired <input type="checkbox"/> 11a Incomplete information	
9. Did you check for residual chlorine, if necessary?	<input checked="" type="checkbox"/>			<input type="checkbox"/> If yes & appears to be >1%, was SOG notified?	
10. Were samples received within holding time?	<input checked="" type="checkbox"/>				
11. For rad samples, was sample activity info. provided?	<input checked="" type="checkbox"/>				
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?	<input checked="" type="checkbox"/>				
13. Are the shipping containers intact?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 13a Leaking <input type="checkbox"/> 13b Other:	
14. Was COC relinquished? (Signed/Dated/Timed)	<input checked="" type="checkbox"/>			<input type="checkbox"/> 14a Not relinquished	
15. Are tests/parameters listed for each sample?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information	
16. Is the matrix of the samples noted?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information	
17. Is the date/time of sample collection noted?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information	
18. Is the client and project name/# identified?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information	
19. Was the sampler identified on the COC?	<input checked="" type="checkbox"/>				
Quote #: <u>691010</u>	PM Instructions:				<u>Sample Received</u>

Sample Receiving Associate: W. Smith Date: 1-12-07 QA026R18.doc, 1/30/06