

SUMMARY OF SYSTEM OPERATIONS

(April 1, 2007 through April 30, 2007)

<i>Reporting period:</i>	30 days
<i>Volume of contaminated ground water treated:</i>	11,057,210 gallons
<i>Volume of contaminated groundwater treated since 12/17/02:</i>	596,963,433 gallons
<i>Mass of Volatile Organics (VOCS) removed from groundwater:</i>	0.8 pounds
<i>Cumulative mass of VOCs removed from groundwater since 12/17/02:</i>	202.4 pounds
<i>No. hours of operation during reporting period:</i>	483 hours (67 %)*
<i>No. of operating recovery wells:</i>	8 out of 9 recovery wells (RW-1 was shut down on July 13, 2005)

*Downtime includes maintenance periods.

COMMUNITY INVOLVEMENT

EPA will continue to send out this type of update to let the community know how the site cleanup is progressing. A copy of this update and other site-related documents are available at the John Jermain Library for the public's review. If you have any questions about this update or the site in general, please contact:

Pamela Tames, P.E.
U.S. Environmental Protection Agency
290 Broadway, New York, NY 10007
telephone: (212) 637-4255
telefax: (212) 637-3966
e-mail: tames.pam@epa.gov

or

Cecilia Echols
Community Involvement Coordinator
telephone: 1-800-346-5009
e-mail: echols.cecilia@epa.gov

-DRAFT-

PROJECT STATUS MEMORANDUM

NO. 04-07

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Tunde H. Komuves-Sandor

DATE: June 26, 2007

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
April 2007 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from April 1, 2007 through April 30, 2007. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(April 1, 2007 through April 30, 2007)

- | | |
|---|----------------------------------|
| 1. Hours of operation during the reporting period: | 483 hours (67%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 11,057,210 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 0.8 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 202.4 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.09 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00086 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume pumped (gal)	Average Flow (gpm)	Lowest Measured Flow (gpm)*	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2	841,392	27	13	27.7	0.19
RW-3	333,596	8	10	0	0
RW-4	738,466	24	10	10	0.06
RW-5	1,472,448	50	50	0	0
RW-6	404,759	15	15	36.3	0.12
RW-7	3,386,020	70	69	34.0	0.96
RW-8**	1,625,064	55	41	2.2	0.03
RW-9**	2,202,808	77	16	0	0

*Lowest measured flows are based on the lowest average 24-hour pumping rates for each well recorded to date.

** The RW-8 and RW-9 flow meters were not functioning properly for part of the month so the total volume pumped was calculated using the flow totalizer when it was working and using the product of the average flow and the hours of operation when the flow totalizer was malfunctioning.

Based on the results of the updated ground-water model for the site, the plume is not migrating beyond the influence of the FSP&T system if the recovery well pumps operate at or above the “Lowest Measured Flows”. The average monthly pumping rates for all recovery wells except RW-3 are at or above the “Lowest Measured Flows”. Recovery well RW-3 had an average monthly flow below its “Lowest Measured Flow”; however, recent ground-water modeling suggests that the plume does not migrate beyond the influence of the FSP&T system when RW-3 is not operating. The updated ground-water model is discussed in the 2006 Annual Report for the site.

The effluent pH of the treated water from the FSP&T system is within the acceptable State Pollutant Discharge Elimination System (SPDES) criteria for the site as shown in Table 2.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
April 1 to 30	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in April 2007 include:

- On April 3, 2007, the RW-8 flow meter assembly was replaced and the target flow rate of RW-8 was increased from 50 gpm to 55 gpm.
- On April 18, 2007, the malfunctioning flow totalizer for RW-9 was reset. During weekly O&M procedures, unusual noises were heard from the TP1B transfer pump. They will be investigated. The pump was lubricated, which resulted in reduction of the noise.
- On April 24, 2007, the RW-4 flow meter was not recording a flow rate. Troubleshooting efforts indicated that the flow meter may be clogged, so RW-4 was turned off until the flow meter can be checked for obstructions.
- On April 26, 2007, malfunctioning flow totalizers for RW-6 and RW-8 were reset. Additionally, exposed discharge piping was covered with sand. RW-4 was turned on and the RW-4 flow meter was registering a flow so it is believed that the problem corrected itself. Below-grade pipe cleaning is scheduled following the completion of well rehabilitation work.

Future O&M activities scheduled for the summer of 2007 include:

- Troubleshoot the air stripper blower flow meter;
- Troubleshoot the on-site combined flow meter;
- Troubleshoot transfer pump TP1B;
- Clean the RW-4 flow meter during next scheduled well rehabilitation;
- Evaluate the need for a vapor-phase carbon change;
- Conduct recovery well rehabilitation and below grade/building pipe cleaning following well rehabilitation activities.

MMG:etn

Attachments

cc: Jeff Srulovitz - Kraft Foods Global, Inc. - .pdf
Lisa Krogman, Environ – .pdf
Jeff Trad, NYSDEC – .pdf
Chief-Operation Maintenance and Support Section, NYSDEC – .pdf
William Spitz, RWM, R-1, NYSDEC
Garrett W. Swensen Jr., Esq., Town of Southampton

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(April 1, 2007 through April 30, 2007)

Date	Time	System Changes/Modifications	Personnel
4/3/2007	9:36 AM	Reset communication failure alarm and RW-8 pump failure alarm that occurred on 3/30/07 at 2:00 AM, restarted the system.	RD
		Replaced the flow meter assembly in RW-8, and adjusted target flow rate from 50 to 55 gpm.	RD
	1:29 PM	Bag Filter 2 High Pressure Warning, system remains on.	
4/10/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	RD
	8:18 AM	Reset bag filter 2 high pressure warning. Bank 2 bag filter pressure readings returned to normal after bag filter change.	RD
4/16/2007	3:06 AM	Booster Blower Failure Alarm, system shutdown	
4/18/2007		Reset booster blower failure alarm, restarted system.	RD
		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	RD
	8:30 AM	Reset the malfunctioning RW-9 flow totalizer.	RD
4/19/2007	7:26 AM	Communication failure alarm; system shutdown.	
4/24/2007	10:40 AM	Rebooted computer, reset communication failure alarm and restarted system.	MG
		RW-4 flow meter not registering a flow rate, initial troubleshooting suggest an obstruction on RW-4 flow meter; RW-4 remains off.	MG
4/26/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF/RD
	10:03 AM	Reset the malfunctioning RW-8 flow totalizer.	EF/RD
	10:04 AM	Reset the malfunctioning RW-6 flow totalizer.	EF/RD
		Inspected and covered exposed discharge pipe leading to recharge basins with sand.	EF/RD
		Troubleshoot malfunctioning onsite combined flow meter by replacing circuit board and reed switch, however it is still not working properly. Further troubleshooting is required.	EF/RD
		RW-4 was turned on and the RW-4 flow meter was registering a flow. It is believed that t	EF/RD
4/28/2007	2:30 PM	Bag Filter 2 High Pressure Warning, system remains on. Bag filter units will be cleaned during the next building pipe cleaning which is scheduled following well rehabilitation activities.	

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo-chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	5	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
3-Apr-07	Note 3	110	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	5.32	0.0664
10-Apr-07	5.62	154	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	9.160	0.319
18-Apr-07	5.89	130	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.76	0.111
26-Apr-07	5.37	132	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	7.08	0.123

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

----: Not established

J: Analyte detected below quantitation limits

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. Based on the new SPDES criteria from an NYSDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5.

The pH was measured with a new calibrated electronic pH meter. Influent pH values from recovery wells typically range between 5 and 6.

2. "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.

3. The pH was not measured at this time.

TABLE 3

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																					TOTAL
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	VOCs	
AQ041206:950NP4-1	4/12/2006	9:50	0.18	0.011	0.038	0.004	0.0087	0.007	0.0014	ND	ND	ND	ND	0.0037	0.0011	0.0018	0.0047	ND	ND	ND	ND	ND	ND	0.26
AQ051706:1000NP4-1	5/17/2006	10:00	0.28	0.017	0.048	0.0035	0.013	0.014	0.0093	0.0026	0.0032	ND	ND	0.0037	0.0019	0.0026	0.0097	ND	ND	0.0016	0.0011	ND	ND	0.41
AQ062106:800NP4-1	6/21/2006	8:00	0.15	0.009	0.074	0.0037	0.014	0.0062	0.0048	0.00092	0.0022	ND	ND	0.0029	0.002	0.0019	0.014	ND	ND	ND	0.00091	ND	ND	0.29
AQ072006:900NP4-1	7/20/2006	9:00	0.095	0.008	0.091	ND	0.0074	0.005	0.0057	ND	0.0069	0.0062	ND	ND	0.0067	0.0022	0.013	ND	ND	ND	ND	ND	ND	0.25
AQ082406:900NP4-1	8/24/2006	9:00	0.28	0.012	0.055	0.0034	0.0083	0.013	0.0043	0.0021	0.0022	ND	ND	0.003	0.0043	ND	0.009	ND	ND	ND	0.0014	ND	ND	0.40
AQ091906:910NP4-1	9/19/2006	9:10	0.21	0.01	0.26	0.006	0.016	0.0046	0.0029	0.001	0.0017	ND	ND	0.0053	0.0012	0.0023	0.013	ND	ND	ND	0.00089	0.0007	ND	0.54
AQ102506:930NP4-1	10/24/2006	9:30	0.014	0.0063	0.2	0.0045	0.013	0.0035	0.0023	ND	0.0018	ND	ND	0.0043	0.001	ND	0.0091	ND	ND	ND	0.0097	ND	ND	0.27
AQ112906:1000NP4-1	11/29/2006	10:00	0.21	0.0094	0.087	0.003	0.0094	0.0053	0.0028	0.0016	0.0016	ND	ND	0.0045	0.011	0.002	0.0052	ND	ND	ND	0.001	ND	ND	0.35
AQ122006:815NP4-1	12/20/2006	8:15	0.065	0.013	0.13	0.0026	0.0081	0.0037	0.0052	0.0038	0.0021	ND	ND	0.0041	0.0021	0.0026	0.0071	ND	0.0013	ND	ND	ND	ND	0.25
AQ011007:1000NP4-1	1/10/2007	10:00	0.06	0.0082	0.08	0.0031	0.0084	ND	0.0016	0.0011	0.0011	ND	ND	0.0051	0.0016	0.003	0.0059	ND	ND	ND	ND	ND	ND	0.18
AQ020807:1000NP4-1	2/8/2007	10:00	0.22	0.012	0.13	0.0041	0.011	0.0027	0.003	0.002	0.0018	ND	ND	0.0059	0.0038	0.0047	0.0059	ND	ND	ND	ND	ND	ND	0.41
AQ030707:900NP4-1	3/7/2007	9:00	0.11	0.0049	0.05	0.002	0.0066	ND	0.0022	0.0011	ND	ND	ND	0.0031	0.0016	ND	0.0019	ND	ND	ND	ND	ND	ND	0.18
AQ040307:800NP4-1	4/3/2007	8:00	0.19	0.0085	0.047	0.0025	0.0096	0.0026	0.0013	ND	ND	ND	ND	0.0045	0.0014	0.0025	0.0031	ND	ND	ND	ND	ND	ND	0.27
Midcarbon			Parameters (mg/m3)																					TOTAL
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	VOCs	
AQ041206:955NP4-2	4/12/2006	0:00	0.0012	ND	0.099	0.0076	0.014	0.0087	0.0015	ND	0.0011	ND	ND	0.0047	0.0013	ND	ND	ND	ND	ND	ND	ND	ND	0.14
AQ051706:1005NP4-2	5/17/2006	10:05	0.0028	0.001	0.065	0.0039	0.014	0.0074	0.0045	ND	0.0032	ND	ND	0.0036	0.003	0.0019	0.0088	ND	ND	ND	ND	ND	ND	0.12
AQ062106:805NP4-2	6/21/2006	8:05	ND	ND	0.025	0.0028	0.0081	0.0045	0.0036	ND	0.0014	ND	ND	0.0023	0.0019	0.0026	0.014	ND	ND	ND	0.001	ND	ND	0.07
AQ072006:905NP4-2	7/20/2006	9:05	ND	ND	0.022	ND	0.0078	0.0044	ND	ND	ND	ND	ND	ND	ND	ND	0.013	ND	ND	ND	ND	ND	ND	0.05
AQ082006:902NP4-2	8/24/2006	9:02	ND	ND	0.023	0.0017	0.0054	0.0045	0.0035	ND	0.0018	ND	ND	0.0019	0.0025	ND	0.013	ND	ND	ND	ND	ND	ND	0.06
AQ091906:915NP4-2	9/19/2006	9:15	0.0014	ND	0.045	0.0031	0.006	0.0058	0.0031	ND	0.0016	ND	ND	0.0025	0.0012	ND	0.02	ND	ND	ND	0.00092	0.0065	ND	0.10
AQ102506:935NP4-2	10/24/2006	9:35	0.0021	ND	0.062	0.0039	0.011	0.0044	0.0018	ND	0.0014	ND	ND	0.0026	0.001	ND	0.0077	ND	ND	ND	0.0009	0.00065	ND	0.10
AQ112906:1006NP4-2	11/29/2006	10:06	0.0034	ND	0.24	0.0065	0.022	0.0067	0.0017	ND	0.0012	ND	ND	0.0061	0.0012	0.0033	0.012	ND	ND	ND	0.00085	ND	ND	0.30
AQ122006:820NP4-2	12/20/2006	8:20	0.0054	0.002	0.3	0.0037	0.014	0.0048	0.0017	0.0012	ND	ND	ND	0.0051	0.0015	ND	0.0037	ND	ND	ND	ND	ND	ND	0.34
AQ011007:1001NP4-2	1/10/2007	10:01	0.0034	0.001	0.32	0.0047	0.012	0.005	0.0013	ND	ND	ND	ND	0.0056	0.0014	0.0032	0.0071	ND	ND	ND	ND	ND	ND	0.36
AQ020807:1002NP4-2	2/8/2007	10:02	0.0092	0.004	0.32	0.0042	0.011	0.0063	0.0019	0.0011	ND	ND	ND	0.0067	0.0032	ND	0.0043	ND	ND	ND	ND	ND	ND	0.37
AQ030707:902NP4-2	3/7/2007	9:02	0.0058	0.002	0.17	0.0031	0.0081	0.0037	0.0013	ND	ND	ND	ND	0.0048	0.001	0.0026	0.0038	ND	ND	ND	ND	ND	ND	0.21
AQ040307:802NP4-2	4/3/2007	8:02	0.003	0.001	0.091	0.002	0.0063	0.0025	ND	ND	ND	ND	ND	ND	0.0012	ND	0.0029	ND	ND	ND	ND	ND	ND	0.11
Postcarbon			Parameters (mg/m3)																					TOTAL
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	VOCs	
AQ041206:1000NP4-3	4/12/2006	10:00	ND	ND	0.074	0.0065	0.011	0.0051	0.0018	ND	0.0015	ND	ND	0.0051	0.0013	ND	ND	ND	ND	ND	ND	ND	ND	0.11
AQ051706:1010NP4-3	5/17/2006	10:10	0.0046	ND	0.068	0.0045	0.015	0.0048	0.0046	0.00088	0.0025	ND	ND	0.0042	0.0022	0.0026	0.012	ND	ND	ND	0.00075	ND	ND	0.13
AQ062106:810NP4-3	6/21/2006	8:10	ND	ND	0.023	0.0027	0.0066	0.0036	0.0042	0.00075	0.0016	ND	ND	0.0018	0.0018	0.0023	0.015	ND	ND	ND	0.0008	ND	ND	0.06
AQ072006:910NP4-3	7/20/2006	9:10	ND	ND	0.017	ND	0.0058	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.012	ND	ND	ND	ND	ND	ND	0.03
AQ082406:904NP4-3	8/24/2006	9:04	ND	ND	0.025	0.0029	0.0082	0.0046	0.0038	0.00079	0.0018	ND	ND	0.002	0.0022	ND	0.014	ND	ND	ND	ND	ND	ND	0.07
AQ091906:920NP4-3	9/19/2006	9:20	ND	ND	0.035	0.0039	0.011	0.0062	0.0026	0.0011	0.0015	ND	ND	0.0031	0.0012	ND	0.016	ND	ND	ND	0.00092	0.00074	ND	0.08
AQ102506:936NP4-3	10/24/2006	9:36	ND	ND	0.041	0.001	0.0098	0.0048	0.0017	ND	0.0013	ND	ND	0.0028	0.00093	0.00062	0.0087	ND	ND	ND	0.00078	0.0062	ND	0.08
AQ112906:1010NP4-3	11/29/2006	10:10	ND	0.0011	0.071	0.0033	0.012	0.0053	0.001	ND	ND	ND	ND	0.0032	0.001	ND	0.0084	ND	ND	ND	ND	ND	ND	0.11
AQ122006:825NP4-3	12/20/2006	8:25	ND	ND	0.14	0.0042	0.018	0.007	0.0024	0.0011	ND	ND	ND	0.0047	0.0012	ND	0.0042	ND	ND	ND	ND	ND	ND	0.18
AQ011007:1002NP4-3	1/10/2007	10:02	ND	ND	0.23	0.0047	0.018	0.0065	0.0013	ND	ND	ND	ND	0.0053	0.0012	0.0028	0.0048	ND	ND	ND	ND	ND	ND	0.27
AQ020807:1005NP4-3	2/8/2007	10:05	0.0039	ND	0.57	0.0069	0.028	0.012	0.0027	0.002	ND	ND	ND	0.0093	0.0044	0.0018	0.0046	ND	ND	ND	ND	0.0065	ND	0.65
AQ030707:904NP4-3	3/7/2007	9:04	ND	ND	0.21	0.0028	0.0087	0.0056	ND	ND	ND	ND	ND	0.0043	0.00096	ND	0.0029	ND	ND	ND	ND	ND	ND	0.24
AQ040307:804NP4-3	4/3/2007	8:04	ND	ND	0.075	0.002	0.0037	0.0034	0.0011	ND	ND	ND	ND	ND	0.0015	0.0025	0.002	ND	ND	ND	ND	ND	ND	0.09

PCE - Tetrachloroethane
TCE - Trichloroethane
TCA - 1,1,1-Trichloroethane
CE - Chloroethane

DCE - 1,1-Dichloroethane
DCA - 1,1-Dichloroethane
cis-DCE - cis-1,2-Dichloroethane
CT - Carbon Tetrachloride

CF - Chloroform
MC - Methylene Chloride
CM - Chloromethane
CD - Carbon Disulfide

BM - Bromomethane
CB - Chlorobenzene
EB - Ethylbenzene
VC - Vinyl Chloride

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE				NE
RW-1	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	2.2	ND<1	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	8.4*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	ND<1	ND<1	ND<1	ND<1	5.2	ND<1	0.1650	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	1.7	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
RW-2	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	12.0	ND<1	1.0	ND<1	ND<1	ND<1	3.5	0.0511	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	7.7	1.1	ND<1	ND<1	ND<1	ND<1	0.28	0.0298	ND<1	ND<1	ND<1	7.3*	ND<1	ND<1	ND<2	ND<1	ND<1	5.6*
	9-Aug-05	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	3.74	0.107	ND<1	5.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	16	1.8	ND<1	ND<1	ND<1	ND<1	3.57	0.0704	ND<1	11	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	15	2.1	ND<1	ND<1	ND<1	ND<1	6.1	0.0269	ND<1	12	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	34	2.1	ND<1	ND<1	ND<1	ND<1	4.25	ND<0.02	ND<1	25	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	5.2	2.0	ND<1	ND<1	ND<1	ND<1	9.15	0.0696	ND<1	5.0	ND<1	4.8*	1.0	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	6.5	4.3	1.2	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	6.5	3.5	ND<1	ND<1	ND<1	ND<1	4.76	0.0395	ND<1	3.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	12.0	3.9	1.2	ND<1	ND<1	ND<1	4.24	0.0522	ND<1	12.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	19.0	5.1	ND<1	ND<1	ND<1	ND<1	5.95	0.063	ND<1	14.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	13.0	3.0	25	ND<1	ND<1	ND<1	3.57	0.093	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	8.0	3.4	60	ND<1	ND<1	ND<1	4.49	0.177	ND<1	7.5	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	11.0	1.1	25	ND<1	ND<1	ND<1	4.14	0.0172	ND<1	5.7	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	2.8	ND<1	200	ND<1	ND<1	ND<1	13.7	0.0184	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	5.0	1.6	160	ND<1	ND<1	ND<1	3.6	0.00756	ND<1	3.6	0.91	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	6.0	1.8	36	ND<1	ND<1	ND<1	14.1	0.0148	ND<1	3	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	2.2	ND<1	110	ND<1	ND<1	ND<1	11.8	0.0197	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	4.2	2.7	68	ND<1	ND<1	ND<1	2.77	0.458	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-07	3.4	2.4	62	ND<1	ND<1	ND<1	8.72	0.00829	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	31	ND<1	ND<1	ND<1	4.28	0.107	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	3	1.7	23	ND<1	ND<1	ND<1	3.81	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE				NE
RW-3	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	3	13	5.0	ND<1	ND<1	ND<1	1.89	1.36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	46.1	0.539	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	2.2	7.7	2.8	ND<1	ND<1	ND<1	1.85	0.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	9.91	10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.01	0.649	ND<1	ND<1	ND<1	9.1 *	ND<1	ND<1	ND<2	ND<1	ND<1	6.9 *
	9-Aug-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.50	0.973	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	1	3.6	1.2	ND<1	ND<1	ND<1	2.03	0.71	ND<1	2.6	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	1.83	0.708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.11	0.556	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	1.7	17	7.9	ND<1	ND<1	ND<1	1.93	0.455	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	1.4	8.9	2.5	ND<1	ND<1	ND<1	3.80	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	1.1	3.4	ND<1	ND<1	ND<1	ND<1	1.87	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	0.95	ND<1	ND<1	ND<1	ND<1	ND<1	1.99	0.649	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.06	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-June-06 ^{1/}	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Aug-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Sep-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Oct-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	29-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.36	0.053	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	6.4	ND<1	4.4	ND<1	ND<1	ND<1	17.3	0.0112	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	1.2	8	3.5	ND<1	ND<1	ND<1	1.87	1.63	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-07	ND<1	3.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	2.16	0.954	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.09	1.65	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.24	0.761	ND<1	ND<1	ND<1	6.1 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
RW-4	4-Jan-05	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Apr-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	2-May-05	80	2.4	9.8	ND<1	ND<1	ND<1	3.77	0.0687	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	30-Jun-05	74	2.6	ND<1	ND<1	ND<1	ND<1	9.95	9.28	ND<1	ND<1	ND<1	4.5 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	37	ND<1	8.9	ND<1	ND<1	ND<1	3.22	0.0185	ND<1	ND<1	ND<1	9.4 *	ND<1	ND<1	ND<2	ND<1	ND<1	7.4 *
	9-Aug-05	31	ND<1	ND<1	ND<1	ND<1	ND<1	2.49	0.111	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	45	ND<1	6.0	ND<1	ND<1	ND<1	3.47	0.173	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.0777	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-05	64	2.0	1.5	ND<1	ND<1	ND<1	2.82	0.0302	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	15	ND<1	9.5	ND<1	ND<1	ND<1	7.78	0.0412	ND<1	ND<1	ND<1	5.2 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	24	ND<1	8.7	ND<1	ND<1	ND<1	6.05	0.0627	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	22	ND<1	7.0	ND<1	ND<1	ND<1	3.50	0.0476	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	26	1.5	6.2	ND<1	ND<1	2	4.17	0.0963	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	26	ND<1	ND<1	ND<1	ND<1	ND<1	3.15	0.109	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	23	ND<1	8.4	ND<1	ND<1	ND<1	9.23	0.086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	14	ND<1	9.4	ND<1	ND<1	ND<1	4.10	0.155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	23	ND<1	ND<1	ND<1	ND<1	ND<1	8.60	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	9	ND<1	7.5	ND<1	ND<1	ND<1	5.95	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	11	ND<1	5.6	ND<1	ND<1	ND<1	7.17	0.0178	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	14	0.9	ND<1	ND<1	ND<1	ND<1	2.82	0.00708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	6.4	ND<1	4.4	ND<1	ND<1	ND<1	17.30	0.0112	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	12	ND<1	4.6	ND<1	ND<1	0.91	3.17	0.0794	ND<1	ND<1	ND<1	ND<1	3	ND<1	15	ND<1	4.2	ND<1
	8-Feb-07	13	ND<1	3.3	ND<1	ND<1	ND<1	3.64	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	7.3	ND<1	2.1	ND<1	ND<1	ND<1	3.85	0.0767	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	10	ND<1	ND<1	ND<1	ND<1	ND<1	4.46	0.251	ND<1	ND<1	ND<1	7.2 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE				NE
RW-5	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	9	ND<1	4.1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	13	ND<1	5.7	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	8.2	ND<1	1.6	ND<1	ND<1	ND<1	0.0358	ND<0.02	ND<1	ND<1	ND<1	9.5 *	ND<1	ND<1	ND<2	ND<1	ND<1	5.6 *
	9-Aug-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0227	0.0303	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	8	ND<1	3.8	ND<1	ND<1	ND<1	0.0185	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0482	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	0.0468	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	2.3	ND<1	2.0	ND<1	ND<1	ND<1	0.0558	0.0119	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	2.9	ND<1	3.8	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	2.6	ND<1	3.0	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	1.4	ND<1	ND<1	ND<1	1.5	2.4	0.0786	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	2.4	ND<1	2.6	ND<1	ND<1	ND<1	0.195	0.012	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	1.3	ND<1	3.1	ND<1	ND<1	ND<1	0.184	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.09	0.0116	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.194	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	1.1	ND<1	1.3	ND<1	ND<1	ND<1	0.0683	0.00684	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	6	ND<1	1.3	ND<1	ND<1	ND<1	0.136	0.0195	ND<1	ND<1	ND<1	ND<1	0.96	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.508	0.0113	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	0.0608	0.0128	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	12	ND<1	3.9	ND<1
	8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.327	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0655	0.00722	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.973	0.0106	ND<1	ND<1	ND<1	8.1 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
RW-6	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	69	1.6	13	ND<1	ND<1	ND<1	0.067	0.0195	ND<1	ND<1	ND<1	2.1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	64	1.6	9.5	ND<1	ND<1	ND<1	0.0406	ND<0.02	ND<1	ND<1	ND<1	7.2 *	ND<1	ND<1	ND<2	ND<1	ND<1	7 *
	9-Aug-05	49	ND<1	12	ND<1	ND<1	ND<1	0.088	0.0366	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	100	1.6	12	ND<1	ND<1	ND<1	1.3	0.0143	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	68	ND<1	ND<1	ND<1	ND<1	ND<1	0.144	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	100	2.1	20	ND<1	ND<1	ND<1	0.139	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	41	1.1	16	ND<1	ND<1	ND<1	0.189	ND<0.02	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	22-Feb-06	63	1.6	15	ND<1	ND<1	ND<1	0.116	0.0155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	65	1.2	17	ND<1	ND<1	ND<1	0.0429	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	62	2.1	22	ND<1	ND<1	2	0.24	0.0137	0.97	ND<1	ND<1	1.1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	68	ND<1	18	ND<1	ND<1	ND<1	0.17	0.019	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	83	ND<1	20	ND<1	ND<1	ND<1	0.075	0.025	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	45	1.5	24	ND<1	ND<1	ND<1	1.01	0.0169	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	30	ND<1	22	ND<1	ND<1	ND<1	5.36	0.0563	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	46	ND<1	27	ND<1	ND<1	ND<1	0.916	0.0078	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	45	1.2	15	ND<1	ND<1	ND<1	1.84	0.007	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	36	1.0	14	ND<1	ND<1	ND<1	0.399	0.137	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	31	ND<1	13	ND<1	ND<1	ND<1	2.43	0.00877	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	46	0.96	16	ND<1	ND<1	2.1	0.0348	ND<0.02	ND<1	ND<1	ND<1	ND<1	2.2	ND<1	11	3.3	3.2	ND<1
	8-Feb-07	42	ND<1	13	ND<1	ND<1	ND<1	0.0928	0.00453	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	29	ND<1	8.4	ND<1	ND<1	ND<1	0.153	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	28	ND<1	8.3	ND<1	ND<1	ND<1	0.554	0.0316	ND<1	ND<1	ND<1	7.2 *	ND<1	ND<1	ND<2	NDN	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE				NE
RW-7	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	ND<1	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	32	1.0	4.7	ND<1	ND<1	ND<1	0.0753	0.02	1.5	ND<1	1.1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	32	ND<1	2.2	ND<1	ND<1	ND<1	0.0155	ND<0.02	ND<1	ND<1	ND<1	8.7 *	ND<1	ND<1	ND<2	ND<1	ND<1	7.2 *
	9-Aug-05	31	ND<1	6.2	ND<1	ND<1	ND<1	0.0903	0.0409	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	39	ND<1	3.4	ND<1	ND<1	ND<1	0.0452	ND<0.02	1.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.536	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	70	ND<1	12.0	ND<1	ND<1	ND<1	0.253	ND<0.02	4.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	26	ND<1	5.0	ND<1	ND<1	ND<1	0.343	ND<0.02	2.2	ND<1	ND<1	5.0 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	36	ND<1	4.1	ND<1	ND<1	ND<1	0.0332	ND<0.02	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	38	ND<1	4.1	ND<1	ND<1	ND<1	0.143	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	49	1.6	7.4	ND<1	ND<1	ND<1	0.0912	0.0175	3.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	59	ND<1	ND<1	ND<1	ND<1	ND<1	0.126	0.026	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	44	ND<1	4.6	ND<1	ND<1	ND<1	0.081	0.013	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Aug-06	39	ND<1	7.9	ND<1	ND<1	ND<1	0.307	0.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	36	ND<1	7.5	ND<1	ND<1	ND<1	0.116	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	26	ND<1	3.5	ND<1	ND<1	ND<1	0.0692	0.00846	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	9-Nov-06	33	ND<1	4.1	ND<1	ND<1	ND<1	0.1910	0.04990	1.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	10-Jan-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	8-Feb-07	43	ND<1	4.4	ND<1	ND<1	ND<1	0.131	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	23	ND<1	2.7	ND<1	ND<1	ND<1	0.0492	0.0221	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	34	ND<1	ND<1	ND<1	ND<1	ND<1	0.138	0.0438	ND<1	ND<1	ND<1	6.5*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
RW-8	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.075	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.321	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	7.33	0.073	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	2.7	ND<1	5.8	ND<1	ND<1	ND<1	7.06	0.325	2.1	ND<1	1.7	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	2.6	ND<1	3.4	ND<1	ND<1	ND<1	8.33	0.017	ND<1	ND<1	ND<1	8.5 *	ND<1	ND<1	ND<2	ND<1	ND<1	8.2 *
	9-Aug-05	1.8	ND<1	2.9	ND<1	ND<1	ND<1	0.24	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	2.9	ND<1	4.2	ND<1	ND<1	ND<1	7.53	0.255	2.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	7.65	0.106	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	5.0	ND<1	ND<1	ND<1	5.19	0.021	3.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	1.3	ND<1	3.7	ND<1	ND<1	ND<1	7.25	0.097	2.0	ND<1	ND<1	4.9 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	1.5	ND<1	3.0	ND<1	ND<1	ND<1	8.06	ND<0.02	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	2.8	ND<1	ND<1	ND<1	8.33	0.064	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	2.1	0.9	4.5	ND<1	ND<1	ND<1	7.27	0.823	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.03	0.056	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	ND<1	ND<1	2.8	ND<1	ND<1	ND<1	8.40	0.897	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	1.0	ND<1	4.0	ND<1	ND<1	ND<1	10.80	0.175	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	3.2	ND<1	ND<1	ND<1	5.98	1.860	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	3.0	ND<1	ND<1	ND<1	7.44	0.009	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	0.9	ND<1	3.1	ND<1	ND<1	ND<1	8.32	0.0605	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	1.0	ND<1	3.4	ND<1	ND<1	ND<1	3.87	0.0091	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	3.5	ND<1	ND<1	ND<1	62.80	0.0346	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	1.3	ND<1	3.5	ND<1	ND<1	ND<1	6.57	0.8100	ND<1	ND<1	ND<1	ND<1	1.9	ND<1	9.3	2.8	2.7	ND<1
	8-Feb-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	7-Mar-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	18-Apr-07	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	9.13	0.3820	ND<1	ND<1	ND<1	6.7*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L) ^{1/}	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L) ^{1/}
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE				NE
RW-9	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	2.35	1.72	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0596	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	5.8	ND<1	ND<1	ND<1	1.38	0.149	0.9	ND<1	1.2	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	3.4	ND<1	3.1	ND<1	ND<1	ND<1	2.55	0.238	ND<1	ND<1	ND<1	6.9 *	ND<1	ND<1	ND<2	ND<1	ND<1	7.3 *
	9-Aug-05	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	0.994	0.0734	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	1.2	ND<1	2.0	ND<1	ND<1	ND<1	3.64	0.161	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.31	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	2.9	ND<1	ND<1	ND<1	2.01	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	2.36	0.0905	ND<1	ND<1	ND<1	4.9 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	2.1	ND<1	1.8	ND<1	ND<1	ND<1	5.23	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.41	0.333	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	1.93	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.054	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-June-06 ^{2/}	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.695	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0165	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND<0.02	ND<1	ND<1	ND<1	18*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	6.96	0.00719	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.54	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	5.08	0.0855	ND<1	ND<1	ND<1	ND<1	1.4	ND<1	7	2	2.1	ND<1
	8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.96	0.0076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	8.03	0.399	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.232	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<2	ND	ND<1	ND<1

ND: Not detected

PCE: Tetrachloroethylene

1,1-DCE: 1,1-Dichloroethene

NE indicates that the ARAR goal was not established for this compound by the EPA

<#: Less than method detection limit

TCE: Trichloroethene

1,2-DCE: 1,2-Dichloroethene

*Concentrations with an asterisk following them are due to laboratory

ug/L: Micrograms per liter

TCA: 1,1,1-Trichloroethane

MTBE: Methyl Tertiary Butyl Ether

contamination.

-: Not analyzed

1,1-DCA: 1,1-Dichloroethane

NM: Not Measured

^{1/} RW-3 is currently non operational weighting for the reprogramming of the drive for the new 4 amp pump;

ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site


^{2/} RW-9 was being rehabilitated during this sampling event, thus no water sample was collected

Bold values indicate an exceedance of the ARAR standard established for the site


GRAPHS

GRAPH 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK


EFFLUENT FLOW DATA
(April 1, 2007 through April 30, 2007)




GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
APRIL 2007 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, April 10, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0704043

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 4/5/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

TAG # / COC 12834

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-01A

Client Sample ID: WQ040307: 800 NP-2-6
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
2-Butanone	U	3.0		µg/L	1	4/5/2007 9:43:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
2-Hexanone	U	2.0		µg/L	1	4/5/2007 9:43:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/5/2007 9:43:00 PM
Acetone	U	2.0		µg/L	1	4/5/2007 9:43:00 PM
Benzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Bromobenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Bromoform	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Bromomethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-01A

Client Sample ID: WQ040307: 800 NP-2-6
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Chloroform	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Chloromethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
cis-1,2-Dichloroethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Dibromomethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/5/2007 9:43:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Methylene chloride	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Naphthalene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
o-Xylene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Styrene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Tetrachloroethene	9.8	1.0		µg/L	1	4/5/2007 9:43:00 PM
Toluene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Trichloroethene	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/5/2007 9:43:00 PM
Surr: 4-Bromofluorobenzene	104	54-134		%REC	1	4/5/2007 9:43:00 PM
Surr: Dibromofluoromethane	104	52-132		%REC	1	4/5/2007 9:43:00 PM
Surr: Toluene-d8	96.3	51-127		%REC	1	4/5/2007 9:43:00 PM

Qualifiers:
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-01B

Client Sample ID: WQ040307: 800 NP-2-6
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3005A		Analyst: JP
Iron	5.31	0.0200		mg/L	1	4/9/2007 11:54:14 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-01C

Client Sample ID: WQ040307: 800 NP-2-6
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.00822	0.0200	J	mg/L	1	4/9/2007 11:50:21 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-02A

Client Sample ID: WQ040307: 805 NP-2-7
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
2-Butanone	U	3.0		µg/L	1	4/5/2007 10:31:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
2-Hexanone	U	2.0		µg/L	1	4/5/2007 10:31:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
4-isopropyltoluene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/5/2007 10:31:00 PM
Acetone	U	2.0		µg/L	1	4/5/2007 10:31:00 PM
Benzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Bromobenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Bromoform	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Bromomethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-02A

Client Sample ID: WQ040307: 805 NP-2-7
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Chloroform	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Chloromethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Dibromomethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/5/2007 10:31:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Methylene chloride	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Naphthalene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
o-Xylene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Styrene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Toluene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Trichloroethene	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/5/2007 10:31:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	4/5/2007 10:31:00 PM
Surr: Dibromofluoromethane	106	52-132		%REC	1	4/5/2007 10:31:00 PM
Surr: Toluene-d8	94.9	51-127		%REC	1	4/5/2007 10:31:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-02B

Client Sample ID: WQ040307: 805 NP-2-7
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3005A		Analyst: JP
Iron	6.16	0.0200		mg/L	1	4/9/2007 11:58:28 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-02C

Client Sample ID: WQ040307: 805 NP-2-7
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0522	0.0200		mg/L	1	4/9/2007 11:56:22 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-03A

Client Sample ID: WQ040307: 810 NP-2-10
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
2-Butanone	U	3.0		µg/L	1	4/5/2007 11:18:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
2-Hexanone	U	2.0		µg/L	1	4/5/2007 11:18:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/5/2007 11:18:00 PM
Acetone	U	2.0		µg/L	1	4/5/2007 11:18:00 PM
Benzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Bromobenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Bromoform	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Bromomethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM

Qualifiers:
B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704043
Project: Rowe Industries
Lab ID: 0704043-03A

Client Sample ID: WQ040307: 810 NP-2-10
Tag Number: 12834
Collection Date: 4/3/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Chloroform	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Chloromethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Dibromomethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/5/2007 11:18:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Methylene chloride	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Naphthalene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
o-Xylene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Styrene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Toluene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Trichloroethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/5/2007 11:18:00 PM
Surr: 4-Bromofluorobenzene	99.2	54-134		%REC	1	4/5/2007 11:18:00 PM
Surr: Dibromofluoromethane	106	52-132		%REC	1	4/5/2007 11:18:00 PM
Surr: Toluene-d8	97.8	51-127		%REC	1	4/5/2007 11:18:00 PM

Qualifiers:
B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ040307: 810 NP-2-10**Lab Order:** 0704043**Tag Number:** 12834**Project:** Rowe Industries**Collection Date:** 4/3/2007**Lab ID:** 0704043-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3005A		Analyst: JP
Iron	5.32	0.0200		mg/L	1	4/9/2007 12:02:44 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 10-Apr-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ040307: 810 NP-2-10
Lab Order:	0704043	Tag Number:	12834
Project:	Rowe Industries	Collection Date:	4/3/2007
Lab ID:	0704043-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0664	0.0200		mg/L	1	4/9/2007 12:00:37 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	110	1.00		mg/L	1	4/9/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, April 17, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0704109

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 4/12/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 17-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0704109**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0704109-01A	WQ041007:800 NP2-6	10301	4/10/2007	4/12/2007
0704109-01B	WQ041007:800 NP2-6	10301	4/10/2007	4/12/2007
0704109-01C	WQ041007:800 NP2-6	10301	4/10/2007	4/12/2007
0704109-02B	WQ041007:805 NP2-7	10301	4/10/2007	4/12/2007
0704109-02C	WQ041007:805 NP2-7	10301	4/10/2007	4/12/2007
0704109-03A	WQ041007:810 NP2-10	10301	4/10/2007	4/12/2007
0704109-03B	WQ041007:810 NP2-10	10301	4/10/2007	4/12/2007
0704109-03C	WQ041007:810 NP2-10	10301	4/10/2007	4/12/2007

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 12-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0704109

CASE NARRATIVE

Samples were analyzed using the methods outlined in the following references:

Test Methods for Evaluating Solid Waste, Physical/Chemical Methods, SW846, 3rd Edition via Method 8260.

All method blanks, laboratory spikes, and/or matrix spikes met quality assurance objectives.

Both sample vials for WQ041007:805 NP2-7 were received broken at the laboratory. Analysis for VOA could not be conducted.

American Analytical Laboratories, LLC.

Date: 17-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704109
Project: Rowe Industries
Lab ID: 0704109-01A

Client Sample ID: WQ041007:800 NP2-6
Tag Number: 10301
Collection Date: 4/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,1,1-Trichloroethane	4.2	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
2-Butanone	U	3.0		µg/L	1	4/12/2007 7:28:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
2-Hexanone	U	2.0		µg/L	1	4/12/2007 7:28:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/12/2007 7:28:00 PM
Acetone	U	2.0		µg/L	1	4/12/2007 7:28:00 PM
Benzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Bromobenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Bromoform	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Bromomethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704109
Project: Rowe Industries
Lab ID: 0704109-01A

Client Sample ID: WQ041007:800 NP2-6
Tag Number: 10301
Collection Date: 4/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Chloroform	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Chloromethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Dibromomethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/12/2007 7:28:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Methylene chloride	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Naphthalene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
o-Xylene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Styrene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Tetrachloroethene	5.9	1.0		µg/L	1	4/12/2007 7:28:00 PM
Toluene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Trichloroethene	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/12/2007 7:28:00 PM
Surr: 4-Bromofluorobenzene	107	54-134		%REC	1	4/12/2007 7:28:00 PM
Surr: Dibromofluoromethane	103	52-132		%REC	1	4/12/2007 7:28:00 PM
Surr: Toluene-d8	97.5	51-127		%REC	1	4/12/2007 7:28:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Apr-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ041007:800 NP2-6**Lab Order:** 0704109**Tag Number:** 10301**Project:** Rowe Industries**Collection Date:** 4/10/2007**Lab ID:** 0704109-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.17	0.0200		mg/L	1	4/17/2007 1:44:12 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704109
Project: Rowe Industries
Lab ID: 0704109-01C

Client Sample ID: WQ041007:800 NP2-6
Tag Number: 10301
Collection Date: 4/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0528	0.0200		mg/L	1	4/17/2007 1:41:37 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Apr-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ041007:805 NP2-7

Lab Order: 0704109

Tag Number: 10301

Project: Rowe Industries

Collection Date: 4/10/2007

Lab ID: 0704109-02B

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.01	0.0200		mg/L	1	4/17/2007 1:48:26 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704109
Project: Rowe Industries
Lab ID: 0704109-02C

Client Sample ID: WQ041007:805 NP2-7
Tag Number: 10301
Collection Date: 4/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.115	0.0200		mg/L	1	4/17/2007 1:46:25 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704109
Project: Rowe Industries
Lab ID: 0704109-03A

Client Sample ID: WQ041007:810 NP2-10
Tag Number: 10301
Collection Date: 4/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
2-Butanone	U	3.0		µg/L	1	4/12/2007 7:52:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
2-Hexanone	U	2.0		µg/L	1	4/12/2007 7:52:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/12/2007 7:52:00 PM
Acetone	U	2.0		µg/L	1	4/12/2007 7:52:00 PM
Benzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Bromobenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Bromoform	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Bromomethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Apr-07

CLIENT: Leggett Brashears & Graham Inc.
Lab Order: 0704109
Project: Rowe Industries
Lab ID: 0704109-03A

Client Sample ID: WQ041007:810 NP2-10
Tag Number: 10301
Collection Date: 4/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Chloroform	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Chloromethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Dibromomethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/12/2007 7:52:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Methylene chloride	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Naphthalene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
o-Xylene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Styrene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Toluene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Trichloroethene	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/12/2007 7:52:00 PM
Surr: 4-Bromofluorobenzene	110	54-134		%REC	1	4/12/2007 7:52:00 PM
Surr: Dibromofluoromethane	104	52-132		%REC	1	4/12/2007 7:52:00 PM
Surr: Toluene-d8	95.9	51-127		%REC	1	4/12/2007 7:52:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Apr-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ041007:810 NP2-10
Lab Order:	0704109	Tag Number:	10301
Project:	Rowe Industries	Collection Date:	4/10/2007
Lab ID:	0704109-03B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	9.16	0.0200		mg/L	1	4/17/2007 1:53:02 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level


American Analytical Laboratories, LLC.**Date:** 17-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704109
Project: Rowe Industries
Lab ID: 0704109-03C

Client Sample ID: WQ041007:810 NP2-10
Tag Number: 10301
Collection Date: 4/10/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		
Iron	0.319	0.0200		mg/L	1	Analyst: JP 4/17/2007 1:50:46 PM
TOTAL DISSOLVED SOLIDS		E160.1				
Total Dissolved Solids (Residue, Filterable)	154	1.00		mg/L	1	Analyst: JC 4/13/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, April 26, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0704170

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 4/20/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 26-Apr-07**CLIENT:** Leggette Brashears & Graham Inc.**Project:** Rowe Industries**Lab Order:** 0704170**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0704170-01A	WQ041807:1000NP2-6		4/18/2007	4/20/2007
0704170-01B	WQ041807:1000NP2-6		4/18/2007	4/20/2007
0704170-02A	WQ041807:1005NP2-7		4/18/2007	4/20/2007
0704170-02B	WQ041807:1005NP2-7		4/18/2007	4/20/2007
0704170-03A	WQ041807:1010NP2-10		4/18/2007	4/20/2007
0704170-03B	WQ041807:1010NP2-10		4/18/2007	4/20/2007

TAG #1 COC.

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS				CONTACT:		SAMPLER (SIGNATURE)		SAMPLE(S) SEALED		YES/NO	
4 Research Drive, Suite 301 Shelton, CT 06611				Mark Goldberg		Rob Diew				YES/NO	
PROJECT LOCATION:						SAMPLER NAME (PRINT)		CORRECT CONTAINER(S)		YES/NO	
Rove						Rob Diew				YES/NO	
LABORATORY ID #	MATRIX	# CON- TAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION		FOR METHANOL PRESERVED SAMPLES [VOLATILE VIAL #]					
0104170-01A	L	4	04/18/07	WQ 041807:1000 NP2-6							
0104170-01B	L	4	04/18/07	:1005 NP2-7							
0104170-01C	L	5	04/18/07	:1010 NP2-10							
0104170-01D	L										
0104170-01E	L										
0104170-01F	L										
0104170-01G	L										
0104170-01H	L										
0104170-01I	L										
0104170-01J	L										
0104170-01K	L										
0104170-01L	L										
0104170-01M	L										
0104170-01N	L										
0104170-01O	L										
0104170-01P	L										
0104170-01Q	L										
0104170-01R	L										
0104170-01S	L										
0104170-01T	L										
0104170-01U	L										
0104170-01V	L										
0104170-01W	L										
0104170-01X	L										
0104170-01Y	L										
0104170-01Z	L										
0104170-02A	L										
0104170-02B	L										
0104170-02C	L										
0104170-02D	L										
0104170-02E	L										
0104170-02F	L										
0104170-02G	L										
0104170-02H	L										
0104170-02I	L										
0104170-02J	L										
0104170-02K	L										
0104170-02L	L										
0104170-02M	L										
0104170-02N	L										
0104170-02O	L										
0104170-02P	L										
0104170-02Q	L										
0104170-02R	L										
0104170-02S	L										
0104170-02T	L										
0104170-02U	L										
0104170-02V	L										
0104170-02W	L										
0104170-02X	L										
0104170-02Y	L										
0104170-02Z	L										
0104170-03A	L										
0104170-03B	L										
0104170-03C	L										
0104170-03D	L										
0104170-03E	L										
0104170-03F	L										
0104170-03G	L										
0104170-03H	L										
0104170-03I	L										
0104170-03J	L										
0104170-03K	L										
0104170-03L	L										
0104170-03M	L										
0104170-03N	L										
0104170-03O	L										
0104170-03P	L										
0104170-03Q	L										
0104170-03R	L										
0104170-03S	L										
0104170-03T	L										
0104170-03U	L										
0104170-03V	L										
0104170-03W	L										
0104170-03X	L										
0104170-03Y	L										
0104170-03Z	L										
0104170-04A											

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704170
Project: Rowe Industries
Lab ID: 0704170-01A

Client Sample ID: WQ041807:1000NP2-6
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.34	0.0200		mg/L	1	4/24/2007 1:43:47 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,1,1-Trichloroethane	3.7	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
2-Butanone	U	3.0		µg/L	1	4/23/2007 10:37:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
2-Hexanone	U	2.0		µg/L	1	4/23/2007 10:37:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 10:37:00 AM
Acetone	U	2.0		µg/L	1	4/23/2007 10:37:00 AM
Benzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Bromoform	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Bromomethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 10:37:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704170
Project: Rowe Industries
Lab ID: 0704170-01A

Client Sample ID: WQ041807:1000NP2-6
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Chloroethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Chloroform	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Chloromethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 10:37:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Methylene chloride	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Naphthalene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
o-Xylene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Styrene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Tetrachloroethene	7.9	1.0		µg/L	1	4/23/2007 10:37:00 AM
Toluene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 10:37:00 AM
Surr: 4-Bromofluorobenzene	95.9	54-134		%REC	1	4/23/2007 10:37:00 AM
Surr: Dibromofluoromethane	102	52-132		%REC	1	4/23/2007 10:37:00 AM
Surr: Toluene-d8	95.9	51-127		%REC	1	4/23/2007 10:37:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ041807:1000NP2-6
Lab Order:	0704170	Tag Number:	
Project:	Rowe Industries	Collection Date:	4/18/2007
Lab ID:	0704170-01B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0977	0.0200		mg/L	1	4/24/2007 1:40:52 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggett Brashears & Graham Inc.
Lab Order: 0704170
Project: Rowe Industries
Lab ID: 0704170-02A

Client Sample ID: WQ041807:1005NP2-7
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.24	0.0200		mg/L	1	4/24/2007 3:40:34 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
2-Butanone	U	3.0		µg/L	1	4/23/2007 11:02:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
2-Hexanone	U	2.0		µg/L	1	4/23/2007 11:02:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 11:02:00 AM
Acetone	U	2.0		µg/L	1	4/23/2007 11:02:00 AM
Benzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Bromoform	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Bromomethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 11:02:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704170
Project: Rowe Industries
Lab ID: 0704170-02A

Client Sample ID: WQ041807:1005NP2-7
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Chloroethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Chloroform	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Chloromethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 11:02:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Methylene chloride	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Naphthalene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
o-Xylene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Styrene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Tetrachloroethene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Toluene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 11:02:00 AM
Surr: 4-Bromofluorobenzene	98.6	54-134		%REC	1	4/23/2007 11:02:00 AM
Surr: Dibromofluoromethane	101	52-132		%REC	1	4/23/2007 11:02:00 AM
Surr: Toluene-d8	99.4	51-127		%REC	1	4/23/2007 11:02:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ041807:1005NP2-7
Lab Order:	0704170	Tag Number:	
Project:	Rowe Industries	Collection Date:	4/18/2007
Lab ID:	0704170-02B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.120	0.0200		mg/L	1	4/24/2007 3:38:38 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704170
Project: Rowe Industries
Lab ID: 0704170-03A

Client Sample ID: WQ041807:1010NP2-10
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.76	0.0200		mg/L	1	4/24/2007 3:45:13 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
2-Butanone	U	3.0		µg/L	1	4/23/2007 11:49:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
2-Hexanone	U	2.0		µg/L	1	4/23/2007 11:49:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 11:49:00 AM
Acetone	U	2.0		µg/L	1	4/23/2007 11:49:00 AM
Benzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Bromoform	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Bromomethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 11:49:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggett Brashears & Graham Inc.
Lab Order: 0704170
Project: Rowe Industries
Lab ID: 0704170-03A

Client Sample ID: WQ041807:1010NP2-10
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Chloroethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Chloroform	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Chloromethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 11:49:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Methylene chloride	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Naphthalene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
o-Xylene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Styrene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Tetrachloroethene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Toluene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 11:49:00 AM
Surr: 4-Bromofluorobenzene	99.7	54-134		%REC	1	4/23/2007 11:49:00 AM
Surr: Dibromofluoromethane	101	52-132		%REC	1	4/23/2007 11:49:00 AM
Surr: Toluene-d8	92.0	51-127		%REC	1	4/23/2007 11:49:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704170
Project: Rowe Industries
Lab ID: 0704170-03B

Client Sample ID: WQ041807:1010NP2-10
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.111	0.0200		mg/L	1	4/24/2007 3:43:19 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	130	1.00		mg/L	1	4/25/2007

Qualifiers:	B Analyte detected in the associated Method Blank	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	J Analyte detected below quantitation limits
	ND Not Detected at the Reporting Limit	S Spike Recovery outside accepted recovery limits
	U Indicates the compound was analyzed for but not detected	X Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, May 02, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0704244

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 4/27/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0704244

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0704244-01A	WQ042607 1000 NP2-6	08705	4/26/2007 10:00:00 AM	4/27/2007
0704244-01B	WQ042607 1000 NP2-6	08705	4/26/2007 10:00:00 AM	4/27/2007
0704244-01C	WQ042607 1000 NP2-6	08705	4/26/2007 10:00:00 AM	4/27/2007
0704244-02A	WQ042607 1005 NP2-7	08705	4/26/2007 10:05:00 AM	4/27/2007
0704244-02B	WQ042607 1005 NP2-7	08705	4/26/2007 10:05:00 AM	4/27/2007
0704244-02C	WQ042607 1005 NP2-7	08705	4/26/2007 10:05:00 AM	4/27/2007
0704244-03A	WQ042607 1010 NP2-10	08705	4/26/2007 10:10:00 AM	4/27/2007
0704244-03B	WQ042607 1010 NP2-10	08705	4/26/2007 10:10:00 AM	4/27/2007
0704244-03C	WQ042607 1010 NP2-10	08705	4/26/2007 10:10:00 AM	4/27/2007

56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC 08705

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704244
Project: Rowe Industries
Lab ID: 0704244-01A

Client Sample ID: WQ042607 1000 NP2-6
Tag Number: 08705
Collection Date: 4/26/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,1,1-Trichloroethane	2.4	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
2-Butanone	U	3.0		µg/L	1	5/1/2007 11:53:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
2-Hexanone	U	2.0		µg/L	1	5/1/2007 11:53:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/1/2007 11:53:00 PM
Acetone	U	2.0		µg/L	1	5/1/2007 11:53:00 PM
Benzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Bromobenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Bromochloromethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Bromodichloromethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Bromoform	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Bromomethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Carbon disulfide	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Chlorobenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704244
Project: Rowe Industries
Lab ID: 0704244-01A

Client Sample ID: WQ042607 1000 NP2-6
Tag Number: 08705
Collection Date: 4/26/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Chloroform	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Chloromethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Dibromochloromethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Dibromomethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Ethylbenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Isopropylbenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
m,p-Xylene	U	2.0		µg/L	1	5/1/2007 11:53:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Methylene chloride	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Naphthalene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
n-Butylbenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
n-Propylbenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
o-Xylene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Styrene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Tetrachloroethene	8.4	1.0		µg/L	1	5/1/2007 11:53:00 PM
Toluene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Trichloroethene	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Vinyl acetate	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Vinyl chloride	U	1.0		µg/L	1	5/1/2007 11:53:00 PM
Surr: 4-Bromofluorobenzene	90.9	54-134		%REC	1	5/1/2007 11:53:00 PM
Surr: Dibromofluoromethane	98.7	52-132		%REC	1	5/1/2007 11:53:00 PM
Surr: Toluene-d8	98.4	51-127		%REC	1	5/1/2007 11:53:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ042607 1000 NP2-6
Lab Order:	0704244	Tag Number:	08705
Project:	Rowe Industries	Collection Date:	4/26/2007 10:00:00 AM
Lab ID:	0704244-01B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	22.2	0.0200		mg/L	1	5/1/2007 1:21:09 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 02-May-07**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ042607 1000 NP2-6**Lab Order:** 0704244**Tag Number:** 08705**Project:** Rowe Industries**Collection Date:** 4/26/2007 10:00:00 AM**Lab ID:** 0704244-01C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0872	0.0200		mg/L	1	5/1/2007 1:15:20 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704244
Project: Rowe Industries
Lab ID: 0704244-02A

Client Sample ID: WQ042607 1005 NP2-7
Tag Number: 08705
Collection Date: 4/26/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
2-Butanone	U	3.0		µg/L	1	5/2/2007 12:31:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
2-Hexanone	U	2.0		µg/L	1	5/2/2007 12:31:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	5/2/2007 12:31:00 AM
Acetone	U	2.0		µg/L	1	5/2/2007 12:31:00 AM
Benzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Bromobenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Bromochloromethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Bromodichloromethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Bromoform	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Bromomethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Carbon disulfide	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Chlorobenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704244
Project: Rowe Industries
Lab ID: 0704244-02A

Client Sample ID: WQ042607 1005 NP2-7
Tag Number: 08705
Collection Date: 4/26/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Chloroform	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Chloromethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Dibromochloromethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Dibromomethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Ethylbenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Isopropylbenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
m,p-Xylene	U	2.0		µg/L	1	5/2/2007 12:31:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Methylene chloride	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Naphthalene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
n-Butylbenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
n-Propylbenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
o-Xylene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Styrene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Tetrachloroethene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Toluene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Trichloroethene	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Vinyl acetate	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Vinyl chloride	U	1.0		µg/L	1	5/2/2007 12:31:00 AM
Surr: 4-Bromofluorobenzene	88.5	54-134		%REC	1	5/2/2007 12:31:00 AM
Surr: Dibromofluoromethane	102	52-132		%REC	1	5/2/2007 12:31:00 AM
Surr: Toluene-d8	99.2	51-127		%REC	1	5/2/2007 12:31:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ042607 1005 NP2-7**Lab Order:** 0704244**Tag Number:** 08705**Project:** Rowe Industries**Collection Date:** 4/26/2007 10:05:00 AM**Lab ID:** 0704244-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	21.7	0.0200		mg/L	1	5/1/2007 1:25:39 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704244
Project: Rowe Industries
Lab ID: 0704244-02C

Client Sample ID: WQ042607 1005 NP2-7
Tag Number: 08705
Collection Date: 4/26/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.233	0.0200		mg/L	1	5/1/2007 1:23:38 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704244
Project: Rowe Industries
Lab ID: 0704244-03A

Client Sample ID: WQ042607 1010 NP2-10
Tag Number: 08705
Collection Date: 4/26/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
2-Butanone	U	3.0		µg/L	1	4/30/2007 5:57:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
2-Hexanone	U	2.0		µg/L	1	4/30/2007 5:57:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/30/2007 5:57:00 PM
Acetone	U	2.0		µg/L	1	4/30/2007 5:57:00 PM
Benzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Bromobenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Bromoform	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Bromomethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Carbon disulfide	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704244
Project: Rowe Industries
Lab ID: 0704244-03A

Client Sample ID: WQ042607 1010 NP2-10
Tag Number: 08705
Collection Date: 4/26/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Chloroform	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Chloromethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Dibromomethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/30/2007 5:57:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Methylene chloride	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Naphthalene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
o-Xylene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Styrene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Toluene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Trichloroethene	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/30/2007 5:57:00 PM
Surr: 4-Bromofluorobenzene	110	54-134		%REC	1	4/30/2007 5:57:00 PM
Surr: Dibromofluoromethane	97.6	52-132		%REC	1	4/30/2007 5:57:00 PM
Surr: Toluene-d8	106	51-127		%REC	1	4/30/2007 5:57:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ042607 1010 NP2-10

Lab Order: 0704244

Tag Number: 08705

Project: Rowe Industries

Collection Date: 4/26/2007 10:10:00 AM

Lab ID: 0704244-03B

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	7.08	0.0200		mg/L	1	5/1/2007 1:31:43 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.


Date: 02-May-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704244
Project: Rowe Industries
Lab ID: 0704244-03C

Client Sample ID: WQ042607 1010 NP2-10
Tag Number: 08705
Collection Date: 4/26/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		
Iron	0.123	0.0200		mg/L	1	Analyst: JP 5/1/2007 1:29:19 PM
TOTAL DISSOLVED SOLIDS		E160.1				
Total Dissolved Solids (Residue, Filterable)	132	1.00		mg/L	1	Analyst: JC 5/1/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, April 26, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0704169

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 4/20/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0704169

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0704169-01A	GWQ041807:0900NP1-1-2		4/18/2007	4/20/2007
0704169-01B	GWQ041807:0900NP1-1-2		4/18/2007	4/20/2007
0704169-01C	GWQ041807:0900NP1-1-2		4/18/2007	4/20/2007
0704169-02A	GWQ041807:0905NP1-1-3		4/18/2007	4/20/2007
0704169-02B	GWQ041807:0905NP1-1-3		4/18/2007	4/20/2007
0704169-02C	GWQ041807:0905NP1-1-3		4/18/2007	4/20/2007
0704169-03A	GWQ041807:0910NP1-1-4		4/18/2007	4/20/2007
0704169-03B	GWQ041807:0910NP1-1-4		4/18/2007	4/20/2007
0704169-03C	GWQ041807:0910NP1-1-4		4/18/2007	4/20/2007
0704169-04A	GWQ041807:0915NP1-1-5		4/18/2007	4/20/2007
0704169-04B	GWQ041807:0915NP1-1-5		4/18/2007	4/20/2007
0704169-04C	GWQ041807:0915NP1-1-5		4/18/2007	4/20/2007
0704169-05A	GWQ041807:0920NP1-1-6		4/18/2007	4/20/2007
0704169-05B	GWQ041807:0920NP1-1-6		4/18/2007	4/20/2007
0704169-05C	GWQ041807:0920NP1-1-6		4/18/2007	4/20/2007
0704169-06A	GWQ041807:0925NP1-1-7		4/18/2007	4/20/2007
0704169-06B	GWQ041807:0925NP1-1-7		4/18/2007	4/20/2007
0704169-06C	GWQ041807:0925NP1-1-7		4/18/2007	4/20/2007
0704169-07A	GWQ041807:0930NP1-1-8		4/18/2007	4/20/2007
0704169-07B	GWQ041807:0930NP1-1-8		4/18/2007	4/20/2007
0704169-07C	GWQ041807:0930NP1-1-8		4/18/2007	4/20/2007
0704169-08A	GWQ041807:0935NP1-1-9		4/18/2007	4/20/2007
0704169-08B	GWQ041807:0935NP1-1-9		4/18/2007	4/20/2007
0704169-08C	GWQ041807:0935NP1-1-9		4/18/2007	4/20/2007



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

NYSDOH 11418
CTDOH PH-0205
NJDEP NY050
PADEP 68-573

TAG # / COC _____

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS 4 Research Drive, Suite 301 Shelton, CT 06611				CONTACT: Mark Goldberg		SAMPLER (SIGNATURE) Rob Dren		SAMPLE(S) SEALED YES / NO
PROJECT LOCATION: Rove				SAMPLER NAME (PRINT) Rob Dren		CORRECT CONTAINER(S)		YES / NO
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	8260	HTBE	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
0704169-01	01A-	5	04/18/07	6WQ 041801 : 900 NPI-1-2	✓	✓	✓	
-02A-2C		5		: 905 NPI-1-3	✓	✓	✓	
-03A-3C		5		: 910 NPI-1-4	✓	✓	✓	
-04A-4C		5		: 915 NPI-1-5	✓	✓	✓	
-05A-5C		5		: 920 NPI-1-6	✓	✓	✓	
-06A-6C		5		: 925 NPI-1-7	✓	✓	✓	
-07A-7C		5		: 930 NPI-1-8	✓	✓	✓	
-08A-8C		5		: 935 NPI-1-9	✓	✓	✓	
COOLER TEMPERATURE:								
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIFE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON					TURNAROUND REQUIRED: NORMAL ☒ STAT ☐ BY / /			
RELINQUISHED BY (SIGNATURE) Kitti Deak		DATE 04/19/07 TIME 17:00		PRINTED NAME Kitti Deak		RECEIVED BY LAB (SIGNATURE) 		DATE 04/20/07 TIME 3:30
RELINQUISHED BY (SIGNATURE)		DATE TIME		PRINTED NAME		RECEIVED BY LAB (SIGNATURE) 		DATE TIME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ041807:0900NP1-1-2
Lab Order:	0704169	Tag Number:	
Project:	Rowe Industries	Collection Date:	4/18/2007
Lab ID:	0704169-01A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	3.81	0.0200		mg/L	1	4/24/2007 12:52:16 PM
Manganese	0.719	0.0200		mg/L	1	4/24/2007 12:52:16 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		SW5030A		Analyst: MB
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,1,1-Trichloroethane	23	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
2-Butanone	U	3.0		µg/L	1	4/24/2007 7:16:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
2-Hexanone	U	2.0		µg/L	1	4/24/2007 7:16:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/24/2007 7:16:00 PM
Acetone	U	2.0		µg/L	1	4/24/2007 7:16:00 PM
Benzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Bromobenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Bromoform	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Bromomethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggett Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-01A

Client Sample ID: GWQ041807:0900NP1-1-2
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		SW5030A		Analyst: MB
Carbon disulfide	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Chloroethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Chloroform	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Chloromethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Dibromomethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/24/2007 7:16:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Methylene chloride	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Naphthalene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
o-Xylene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Styrene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Tetrachloroethene	3.0	1.0		µg/L	1	4/24/2007 7:16:00 PM
Toluene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Trichloroethene	1.7	1.0		µg/L	1	4/24/2007 7:16:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/24/2007 7:16:00 PM
Surr: 4-Bromofluorobenzene	103	54-134		%REC	1	4/24/2007 7:16:00 PM
Surr: Dibromofluoromethane	103	52-132		%REC	1	4/24/2007 7:16:00 PM
Surr: Toluene-d8	103	51-127		%REC	1	4/24/2007 7:16:00 PM
TURBIDITY		E180.1				Analyst: JP
Turbidity	4.50	1.00		NTU	1	4/20/2007
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-01A

Client Sample ID: GWQ041807:0900NP1-1-2
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	126	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-01B

Client Sample ID: GWQ041807:0900NP1-1-2
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.320	0.0200		mg/L	1	4/24/2007 12:50:25 PM
Manganese	0.671	0.0200		mg/L	1	4/24/2007 12:50:25 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-01C

Client Sample ID: GWQ041807:0900NP1-1-2
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS			M2340 B			Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	54.2	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-02A

Client Sample ID: GWQ041807:0905NP1-1-3
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	2.42	0.0200		mg/L	1	4/24/2007 12:59:20 PM
Manganese	0.253	0.0200		mg/L	1	4/24/2007 12:59:20 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: MB
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
2-Butanone	U	3.0		µg/L	1	4/23/2007 12:19:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
2-Hexanone	U	2.0		µg/L	1	4/23/2007 12:19:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 12:19:00 PM
Acetone	U	2.0		µg/L	1	4/23/2007 12:19:00 PM
Benzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Bromoform	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Bromomethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-02A

Client Sample ID: GWQ041807:0905NP1-1-3
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Chloroethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Chloroform	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Chloromethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 12:19:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Methylene chloride	6.1	1.0	B	µg/L	1	4/23/2007 12:19:00 PM
Naphthalene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
o-Xylene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Styrene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Toluene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 12:19:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	4/23/2007 12:19:00 PM
Surr: Dibromofluoromethane	97.6	52-132		%REC	1	4/23/2007 12:19:00 PM
Surr: Toluene-d8	102	51-127		%REC	1	4/23/2007 12:19:00 PM
TURBIDITY		E180.1		Analyst: JP		
Turbidity	3.20	1.00		NTU	1	4/20/2007
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-02A

Client Sample ID: GWQ041807:0905NP1-1-3
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	122	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-02B

Client Sample ID: GWQ041807:0905NP1-1-3
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.761	0.0200		mg/L	1	4/24/2007 12:57:24 PM
Manganese	0.230	0.0200		mg/L	1	4/24/2007 12:57:24 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-02C

Client Sample ID: GWQ041807:0905NP1-1-3
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	61.5	1.00	M2340 B	mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-03A

Client Sample ID: GWQ041807:0910NP1-1-4
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7	SW3010A	Analyst: JP		
Iron	4.46	0.0200		mg/L	1	4/24/2007 1:03:49 PM
Manganese	1.52	0.0200		mg/L	1	4/24/2007 1:03:49 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
2-Butanone	U	3.0		µg/L	1	4/23/2007 12:56:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
2-Hexanone	U	2.0		µg/L	1	4/23/2007 12:56:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 12:56:00 PM
Acetone	U	2.0		µg/L	1	4/23/2007 12:56:00 PM
Benzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Bromoform	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Bromomethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-03A

Client Sample ID: GWQ041807:0910NP1-1-4
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Chloroethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Chloroform	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Chloromethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 12:56:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Methylene chloride	7.2	1.0	B	µg/L	1	4/23/2007 12:56:00 PM
Naphthalene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
o-Xylene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Styrene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Tetrachloroethene	10	1.0		µg/L	1	4/23/2007 12:56:00 PM
Toluene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 12:56:00 PM
Surr: 4-Bromofluorobenzene	98.2	54-134		%REC	1	4/23/2007 12:56:00 PM
Surr: Dibromofluoromethane	98.7	52-132		%REC	1	4/23/2007 12:56:00 PM
Surr: Toluene-d8	99.5	51-127		%REC	1	4/23/2007 12:56:00 PM
TURBIDITY		E180.1		Analyst: JP		
Turbidity	7.00	1.00		NTU	1	4/20/2007
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-03A

Client Sample ID: GWQ041807:0910NP1-1-4
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	134	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-03B

Client Sample ID: GWQ041807:0910NP1-1-4
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.251	0.0200		mg/L	1	4/24/2007 1:01:47 PM
Manganese	1.42	0.0200		mg/L	1	4/24/2007 1:01:47 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ041807:0910NP1-1-4
Lab Order:	0704169	Tag Number:	
Project:	Rowe Industries	Collection Date:	4/18/2007
Lab ID:	0704169-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	48.3	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-04A

Client Sample ID: GWQ041807:0915NP1-1-5
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.973	0.0200		mg/L	1	4/24/2007 1:08:19 PM
Manganese	0.00523	0.0200	J	mg/L	1	4/24/2007 1:08:19 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: MB
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
2-Butanone	U	3.0		µg/L	1	4/23/2007 1:34:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
2-Hexanone	U	2.0		µg/L	1	4/23/2007 1:34:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 1:34:00 PM
Acetone	U	2.0		µg/L	1	4/23/2007 1:34:00 PM
Benzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Bromoform	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Bromomethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-04A

Client Sample ID: GWQ041807:0915NP1-1-5
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Chloroethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Chloroform	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Chloromethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 1:34:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Methylene chloride	8.1	1.0	B	µg/L	1	4/23/2007 1:34:00 PM
Naphthalene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
o-Xylene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Styrene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Toluene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 1:34:00 PM
Surr: 4-Bromofluorobenzene	99.2	54-134		%REC	1	4/23/2007 1:34:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	4/23/2007 1:34:00 PM
Surr: Toluene-d8	103	51-127		%REC	1	4/23/2007 1:34:00 PM
TURBIDITY		E180.1		Analyst: JP		
Turbidity	U	1.00		NTU	1	4/20/2007
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-04A

Client Sample ID: GWQ041807:0915NP1-1-5
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	172	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-04B

Client Sample ID: GWQ041807:0915NP1-1-5
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0106	0.0200	J	mg/L	1	4/24/2007 1:06:08 PM
Manganese	U	0.0200		mg/L	1	4/24/2007 1:06:08 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-04C

Client Sample ID: GWQ041807:0915NP1-1-5
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO3)	47.1	1.00	M2340 B	mg/L	1	4/24/2007

Analyst: JP

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-05A

Client Sample ID: GWQ041807:0920NP1-1-6
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.554	0.0200		mg/L	1	4/24/2007 1:21:18 PM
Manganese	0.259	0.0200		mg/L	1	4/24/2007 1:21:18 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: MB
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,1,1-Trichloroethane	8.3	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
2-Butanone	U	3.0		µg/L	1	4/23/2007 2:12:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
2-Hexanone	U	2.0		µg/L	1	4/23/2007 2:12:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 2:12:00 PM
Acetone	U	2.0		µg/L	1	4/23/2007 2:12:00 PM
Benzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Bromoform	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Bromomethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-05A

Client Sample ID: GWQ041807:0920NP1-1-6
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Chloroethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Chloroform	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Chloromethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 2:12:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Methylene chloride	7.2	1.0	B	µg/L	1	4/23/2007 2:12:00 PM
Naphthalene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
o-Xylene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Styrene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Tetrachloroethene	28	1.0		µg/L	1	4/23/2007 2:12:00 PM
Toluene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 2:12:00 PM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	4/23/2007 2:12:00 PM
Surr: Dibromofluoromethane	96.4	52-132		%REC	1	4/23/2007 2:12:00 PM
Surr: Toluene-d8	101	51-127		%REC	1	4/23/2007 2:12:00 PM
TURBIDITY		E180.1		Analyst: JP		
Turbidity	U	1.00		NTU	1	4/20/2007
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-05A

Client Sample ID: GWQ041807:0920NP1-1-6
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	134	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-05B

Client Sample ID: GWQ041807:0920NP1-1-6
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0316	0.0200		mg/L	1	4/24/2007 1:19:19 PM
Manganese	0.241	0.0200		mg/L	1	4/24/2007 1:19:19 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-05C

Client Sample ID: GWQ041807:0920NP1-1-6
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS						Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	46.0	1.00	M2340 B	mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-06A

Client Sample ID: GWQ041807:0925NP1-1-7
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7	SW3010A	Analyst: JP		
Iron	0.138	0.0200		mg/L	1	4/24/2007 1:25:45 PM
Manganese	0.0864	0.0200		mg/L	1	4/24/2007 1:25:45 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
2,2-Dichloropropane	U	3.0		µg/L	1	4/23/2007 2:50:00 PM
2-Butanone	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
2-Chlorotoluene	U	2.0		µg/L	1	4/23/2007 2:50:00 PM
2-Hexanone	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
4-Isopropyltoluene	U	2.0		µg/L	1	4/23/2007 2:50:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 2:50:00 PM
Acetone	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Benzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Bromoform	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Bromomethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-06A

Client Sample ID: GWQ041807:0925NP1-1-7
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Chloroethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Chloroform	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Chloromethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 2:50:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Methylene chloride	6.5	1.0	B	µg/L	1	4/23/2007 2:50:00 PM
Naphthalene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
o-Xylene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Styrene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Tetrachloroethene	34	1.0		µg/L	1	4/23/2007 2:50:00 PM
Toluene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 2:50:00 PM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	4/23/2007 2:50:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	4/23/2007 2:50:00 PM
Surr: Toluene-d8	101	51-127		%REC	1	4/23/2007 2:50:00 PM
TURBIDITY		E180.1		Analyst: JP		
Turbidity	U	1.00		NTU	1	4/20/2007
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-06A

Client Sample ID: GWQ041807:0925NP1-1-7
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	94.0	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-06B

Client Sample ID: GWQ041807:0925NP1-1-7
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0438	0.0200		mg/L	1	4/24/2007 1:23:45 PM
Manganese	0.0803	0.0200		mg/L	1	4/24/2007 1:23:45 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-06C

Client Sample ID: GWQ041807:0925NP1-1-7
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS Hardness, Calcium/Magnesium (As CaCO ₃)	36.1	M2340 B 1.00		mg/L	1	Analyst: JP 4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-07A

Client Sample ID: GWQ041807:0930NP1-1-8
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	9.13	0.0200		mg/L	1	4/24/2007 1:31:23 PM
Manganese	0.830	0.0200		mg/L	1	4/24/2007 1:31:23 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: MB
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,1,1-Trichloroethane	2.2	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
2-Butanone	U	3.0		µg/L	1	4/23/2007 3:28:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
2-Hexanone	U	2.0		µg/L	1	4/23/2007 3:28:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 3:28:00 PM
Acetone	U	2.0		µg/L	1	4/23/2007 3:28:00 PM
Benzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Bromoform	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Bromomethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-07A

Client Sample ID: GWQ041807:0930NP1-1-8
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Chloroethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Chloroform	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Chloromethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 3:28:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Methylene chloride	6.7	1.0	B	µg/L	1	4/23/2007 3:28:00 PM
Naphthalene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
o-Xylene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Styrene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Toluene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 3:28:00 PM
Surr: 4-Bromofluorobenzene	104	54-134		%REC	1	4/23/2007 3:28:00 PM
Surr: Dibromofluoromethane	101	52-132		%REC	1	4/23/2007 3:28:00 PM
Surr: Toluene-d8	102	51-127		%REC	1	4/23/2007 3:28:00 PM
TURBIDITY		E180.1		Analyst: JP		
Turbidity	5.60	1.00		NTU	1	4/20/2007
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-07A

Client Sample ID: GWQ041807:0930NP1-1-8
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	78.0	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-07B

Client Sample ID: GWQ041807:0930NP1-1-8
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.382	0.0200		mg/L	1	4/24/2007 1:28:31 PM
Manganese	0.763	0.0200		mg/L	1	4/24/2007 1:28:31 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-07C

Client Sample ID: GWQ041807:0930NP1-1-8
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS		M2340 B				Analyst: JP
Hardness, Calcium/Magnesium (As CaCO3)	25.6	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	GWQ041807:0935NP1-1-9
Lab Order:	0704169	Tag Number:	
Project:	Rowe Industries	Collection Date:	4/18/2007
Lab ID:	0704169-08A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	2.77	0.0200		mg/L	1	4/24/2007 1:37:53 PM
Manganese	0.802	0.0200		mg/L	1	4/24/2007 1:37:53 PM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: MB
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,1-Dichloropropane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
2-Butanone	U	3.0		µg/L	1	4/23/2007 4:05:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
2-Hexanone	U	2.0		µg/L	1	4/23/2007 4:05:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	4/23/2007 4:05:00 PM
Acetone	U	2.0		µg/L	1	4/23/2007 4:05:00 PM
Benzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Bromobenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Bromochloromethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Bromodichloromethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Bromoform	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Bromomethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-08A

Client Sample ID: GWQ041807:0935NP1-1-9
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon disulfide	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Chlorobenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Chloroethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Chloroform	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Chloromethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Dibromochloromethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Dibromomethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Ethylbenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Isopropylbenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
m,p-Xylene	U	2.0		µg/L	1	4/23/2007 4:05:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Methylene chloride	6.2	1.0	B	µg/L	1	4/23/2007 4:05:00 PM
Naphthalene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
n-Butylbenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
n-Propylbenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
o-Xylene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Styrene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Tetrachloroethene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Toluene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Trichloroethene	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Vinyl acetate	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Vinyl chloride	U	1.0		µg/L	1	4/23/2007 4:05:00 PM
Surr: 4-Bromofluorobenzene	104	54-134		%REC	1	4/23/2007 4:05:00 PM
Surr: Dibromofluoromethane	97.2	52-132		%REC	1	4/23/2007 4:05:00 PM
Surr: Toluene-d8	103	51-127		%REC	1	4/23/2007 4:05:00 PM
TURBIDITY		E180.1		Analyst: JP		
Turbidity	4.10	1.00		NTU	1	4/20/2007
TOTAL DISSOLVED SOLIDS		E160.1		Analyst: JC		

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-08A

Client Sample ID: GWQ041807:0935NP1-1-9
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	96.0	1.00		mg/L	1	4/25/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-08B

Client Sample ID: GWQ041807:0935NP1-1-9
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.232	0.0200		mg/L	1	4/24/2007 1:33:56 PM
Manganese	0.769	0.0200		mg/L	1	4/24/2007 1:33:56 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 26-Apr-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0704169
Project: Rowe Industries
Lab ID: 0704169-08C

Client Sample ID: GWQ041807:0935NP1-1-9
Tag Number:
Collection Date: 4/18/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
HARDNESS			M2340 B			Analyst: JP
Hardness, Calcium/Magnesium (As CaCO ₃)	28.3	1.00		mg/L	1	4/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

H7D050106 Analytical Report	1
Sample Receipt Documentation	15
Total Number of Pages	17

**STL**

STL Knoxville
5815 Middlebrook Pike
Knoxville, TN 37921

Tel: 865 291 3000 Fax: 865 584 4315
www.stl-inc.com

ANALYTICAL REPORT

Rowe-NABSAG 0401

Lot #: H7D050106

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

SEVERN TRENT LABORATORIES, INC.

A handwritten signature in black ink, appearing to read "J - A McKinney".

Jamie A. McKinney
Project Manager

April 17, 2007

ANALYTICAL METHODS SUMMARY

H7D050106

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15

References:

EPA-2 "Compendium of Methods for the Determination of Toxic
Organic Compounds in Ambient Air", EPA-625/R-96/010b,
January 1999.

SAMPLE SUMMARY

H7D050106

WO #	SAMPLE#	CLIENT SAMPLE ID	SAMPLED DATE	SAMP TIME
JTDNW	001	AQ040307:800NP4-1	04/03/07	08:00
JTDN0	002	AQ040307:802NP4-2	04/03/07	08:02
JTDN1	003	AQ040307:804NP4-3	04/03/07	08:04

NOTE(S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

H7D050106

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

The chain of custody documentation did not list a date/time of collection for the samples..

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

The EPA method requires that all target analytes in the continuing calibration verification standard be within 30% difference from the initial calibration. The laboratory standard operating procedure allows up to four analytes in the calibration verification to be $\leq 40\%$ difference from the initial calibration. The calibration verification analyzed on 04/05/07 exhibited a %difference of $>30\%$ but $\leq 40\%$ for chloromethane. Also the same daily standard exhibited a %difference of $>40\%$ for vinyl chloride. However since the percent difference was high and this analyte was not detected in any of the associated samples, the data is not affected.

The samples were received on 04/05/07 in Tedlar bags and analyzed within 72 hours of sampling.

STL Knoxville maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. # QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ040307:800NP4-1
GC/MS Volatiles

Lot-Sample # H7D050106 - 001

Work Order # JTDNW1AA

Matrix.....: AIR

Date Sampled...: 4/3/07
 Prep Date.....: 4/5/07
 Prep Batch #.....: 7096100
 Dilution Factor.: 5

Date Received..: 4/5/07
 Analysis Date..: 4/5/07
 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	0.99	2.5	3.1 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	0.92	1.0	4.5 J	4.9
Chloromethane	1.2	2.5	2.5 J	5.2
1,1-Dichloroethane	2.4	1.0	9.6	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	0.66	1.0	2.6 J	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.63	1.0	2.5 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.42	2.5	1.4 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	29	1.0	190	6.8
Toluene	0.35	1.0	1.3 J	3.8
1,1,1-Trichloroethane	8.6	1.0	47	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	1.6	1.0	8.5	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	110	70 - 130
Toluene-d8	107	70 - 130
4-Bromofluorobenzene	98	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ040307:800NP4-1
GC/MS Volatiles

Lot-Sample # H7D050106 - 001

Work Order # JTDNW1AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: $\text{Amount Found (before rounding)} \times (\text{Molecular Weight} / 24.45)$

The 'Reporting Limit' in ug/m3 is calculated using the following equation: $(\text{Reporting Limit (before rounding)} \times \text{Dilution Factor}) \times (\text{Molecular Weight} / 24.45)$

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ040307:802NP4-2
GC/MS Volatiles

Lot-Sample # H7D050106 - 002

Work Order # JTDN01AA

Matrix.....: AIR

Date Sampled...: 4/3/07
Prep Date.....: 4/5/07
Prep Batch #.....: 7096100
Dilution Factor..: 5

Date Received..: 4/5/07
Analysis Date..: 4/5/07
Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	0.93	2.5	2.9 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	ND	1.0	ND	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	1.6	1.0	6.3	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	0.63	1.0	2.5 J	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.51	1.0	2.0 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.35	2.5	1.2 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	0.44	1.0	3.0 J	6.8
Toluene	ND	1.0	ND	3.8
1,1,1-Trichloroethane	17	1.0	91	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	0.23	1.0	1.2 J	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	116	70 - 130
Toluene-d8	114	70 - 130
4-Bromofluorobenzene	96	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ040307:802NP4-2
GC/MS Volatiles

Lot-Sample # H7D050106 - 002

Work Order # JTDN01AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: $\text{Amount Found}(\text{before rounding}) \times (\text{Molecular Weight}/24.45)$

The 'Reporting Limit' in ug/m3 is calculated using the following equation: $(\text{Reporting Limit}(\text{before rounding}) \times \text{Dilution Factor}) \times (\text{Molecular Weight}/24.45)$

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ040307:804NP4-3
GC/MS Volatiles

Lot-Sample # H7D050106 - 003

Work Order # JTDN11AA

Matrix.....: AIR

Date Sampled...: 4/3/07
 Prep Date.....: 4/5/07
 Prep Batch #....: 7096100
 Dilution Factor.: 5

Date Received..: 4/5/07
 Analysis Date..: 4/5/07
 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	0.64	2.5	2.0 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	ND	1.0	ND	4.9
Chloromethane	1.2	2.5	2.5 J	5.2
1,1-Dichloroethane	0.93	1.0	3.7 J	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	0.86	1.0	3.4 J	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.50	1.0	2.0 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.42	2.5	1.5 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	ND	1.0	ND	6.8
Toluene	0.30	1.0	1.1 J	3.8
1,1,1-Trichloroethane	14	1.0	75	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	114	70 - 130
Toluene-d8	110	70 - 130
4-Bromofluorobenzene	97	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ040307:804NP4-3
GC/MS Volatiles

Lot-Sample # H7D050106 - 003

Work Order # JTDN11AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggett, Brashears & Graham, Inc.
Client Sample ID: INTRA-LAB BLANK
GC/MS Volatiles

Lot-Sample # H7D060000 - 100B

Work Order # JTF191AA

Matrix.....: AIR

Prep Date.....: 4/5/07
 Prep Batch #.....: 7096100
 Dilution Factor.: 1

Date Received...: 4/5/07
 Analysis Date..: 4/5/07
 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	1.6
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	0.080	0.50	0.28 J	1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	115	70 - 130
Toluene-d8	108	70 - 130
4-Bromofluorobenzene	97	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: INTRA-LAB BLANK
GC/MS Volatiles

Lot-Sample # H7D060000 - 100B

Work Order # JTF191AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
Client Sample ID: CHECK SAMPLE
GC/MS Volatiles

Lot-Sample # H7D060000 - 100C

Work Order # JTF191AC

Matrix.....: AIR

Prep Date.....: 4/5/07

Date Received..: 4/5/07

Prep Batch #.....: 7096100

Analysis Date..: 4/5/07

Dilution Factor..: 1

Method.....: TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	10.0	9.74	32	31	97	70 - 130
Chlorobenzene	10.0	9.66	46	44	97	70 - 130
1,1-Dichloroethene	10.0	11.4	40	45	114	70 - 130
Toluene	10.0	10.5	38	39	105	70 - 130
Trichloroethene	10.0	10.5	54	56	105	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	107	70 - 130
Toluene-d8	108	70 - 130
4-Bromofluorobenzene	102	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

STL Knoxville

5815 Middlebrook Pike • Knoxville, TN 37921-5947
Phone: (865) 291-3000 • Fax: (865) 584-4315
Receiving: (865) 291-3031

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD*

Reference Document No.

Page 1 of 1 H70030106

Project Name/No. 1 LOUVE

Sample Team Members 2 Rob Drew

Profit Center No. 3 Mark Goldberg

Project Manager 4 Mark Goldberg

Purchase Order No. 5 NABSA 0401

Required Report Date 11 04/04/07

Samples Shipment Date 7 04/04/07

Lab Destination 8 Jamie Mc Kinney

Lab Contact 9 203-929-8555

Project Contact / Phone 12 203-929-8555

Carrier / Waybill No. 13 Mark Goldberg

Bill to: 5 LBG

4 Research Drive

Suite 301

Shelton CT 06484

Report to: 10 Mark Goldberg

Mark Goldberg

ONE CONTAINER PER LINE

Sample Number	Sample Type	Date/Time Collected	Container Type	Sample Volume	Pre-19 servative	Requested Testing Program	Condition on Receipt Lab use only
AQ 040307:800NP4-1	Air		Tedlar bag	1 L	-	T0-15	Custody seals intact N NA
AQ 040307:802NP4-2					-		Temperature received at <u>Hubert</u>
AQ 040307:804NP4-3					-		Received by <u>ALF#</u> Date <u>4/5/07</u>
							Number of packages <u>1</u>
							Tracking # <u>7916 6390977</u>

Special Instructions: 23

Possible Hazard Identification: 24

Non-Hazard ☒ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐

Turnaround Time Required: 25

Normal ☒ Rush ☐

1. Relinquished by 28 Liti Dor Date: 04/04/07

(Signature / Affiliation) Liti Dor Time: 17:00

1. Relinquished by (Signature / Affiliation) _____ Date: _____

1. Received by (Signature / Affiliation) _____ Date: _____

1. Received by (Signature / Affiliation) _____ Date: _____

Comments: 29

Sample Disposal: 25

Return to Client: ☐ Disposal by Lab ☒ Archive (mos.)

QC Level: 27

I. ☐ II. ☐ III. ☐

Project Specific (specify): Full QA/QC

1. Received by 28 Matthew Howard Date: 4/5/07

(Signature / Affiliation) Matthew Howard Time: 09:45

1. Received by (Signature / Affiliation) _____ Date: _____

1. Received by (Signature / Affiliation) _____ Date: _____

Comments: 29

STL KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: L36Project: LOWELot Number: HTD05000

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)	☒			☐ 1a Do not match COC ☐ 1b Incomplete information ☐ 1c Marking smeared ☐ 1d Label torn ☐ 1e No label ☐ 1f COC not received ☐ 1g Other:	15a The date and time of collection is not listed on COC for all samples.
2. Is the cooler temperature within limits? (> freezing temp. of water to 6°C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6°C)			☒	☐ 2a Temp Blank = _____ ☐ 2b Cooler Temp = _____	
3. Were samples received with correct chemical preservative (excluding Encore)?			☒	☐ 3a Sample preservative = _____	
4. Were custody seals present/intact on cooler and/or containers?	☒			☐ 4a Not present ☐ 4b Not intact ☐ 4c Other:	
5. Were all of the samples listed on the COC received?	☒			☐ 5a Samples received-not on COC ☐ 5b Samples not received-on COC	
6. Were all of the sample containers received intact?	☒			☐ 6a Leaking ☐ 6b Broken	
7. Were VOA samples received without headspace?			☒	☐ 7a Headspace (VOA only)	
8. Were samples received in appropriate containers?	☒			☐ 8a Improper container	
9. Did you check for residual chlorine, if necessary?			☒	☐ 9a Could not be determined due to matrix interference	
10. Were samples received within holding time?	☒			☐ 10a Holding time expired	
11. For rad samples, was sample activity info. provided?			☒	☐ Incomplete information	
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?			☒	If yes & appears to be > 1%, was SOG notified?	
13. Are the shipping containers intact?	☒			☐ 13a Leaking ☐ 13b Other:	
14. Was COC relinquished? (Signed/Dated/Timed)	☒			☐ 14a Not relinquished	
15. Are tests/parameters listed for each sample?	☒			☐ 15a Incomplete information	
16. Is the matrix of the samples noted?	☒			☐ 15a Incomplete information	
17. Is the date/time of sample collection noted?	☒			☐ 15a Incomplete information	
18. Is the client and project name/# identified?	☒			☐ 15a Incomplete information	
19. Was the sampler identified on the COC?	☒			☐ 15a Incomplete information	
Quote #: <u>69610</u> PM Instructions: _____					

Sample Receiving Associate: Matthew Howard Date: 4/5/07

QA026R18.doc, 1/30/06