

-DRAFT-

PROJECT STATUS MEMORANDUM

NO. 07-07

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Tunde H. Komuves-Sandor

DATE: September 27, 2007

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
July 2007 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from July 1, 2007 through July 31, 2007. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(July 1, 2007 through July 31, 2007)

- | | |
|---|----------------------------------|
| 1. Hours of operation during the reporting period: | 400 hours (58%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 11,966,260 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 0.6 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 204.7 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.09 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00127 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume pumped (gal)	Average Flow (gpm)	Lowest Measured Flow (gpm)*	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2	748,164	27	13	19.0	0.12
RW-3	393,614	23	10	4.0	0.013
RW-4	919,748	40	10	10.2	0.08
RW-5	1,496,691	50	50	0	0
RW-6	374,138	15	15	26.8	0.08
RW-7**	1,824,884	69	69	20.2	0.31
RW-8	1,502,200	55	41	2.8	0.04
RW-9	1,887,865	75	16	0	0

*Lowest measured flows are based on the lowest average 24-hour pumping rates for each well recorded to date.

** The RW-7 flow meters were not functioning properly so the total volume pumped was calculated using the product of the average flow and the hours of operation for the month.

Based on the results of the updated ground-water model for the site, the plume is not migrating beyond the influence of the FSP&T system if the recovery well pumps operate at or above the “Lowest Measured Flows”. The average monthly pumping rates for all recovery wells are at or above the “Lowest Measured Flows”. The updated ground-water model is discussed in the 2006 Annual Report for the site. Comprehensive pipe cleaning was completed following rehabilitation of the recovery well resulting in an increased flow from RW-3; average monthly flow is now above the “Lowest Measured Flow”.

Between July 9 and 13, 2007, annual maintenance on the FSP&T system was completed. Maintenance activities consisted of pressure washing the below grade piping from RW-9 to the treatment system utilizing pre-existing cleanout ports and recovery well vaults. In addition, building pipes, fittings, tanks, the air strip sump and bag filter housings were cleaned.

Numerous bag filter high pressure warnings and alarms have occurred throughout the month of July, because of the material loosened during the pipe cleaning. The 400 micron bag filters continue to be changed on a weekly basis and the influent and effluent pressures will continue to be monitored.

The effluent pH of the treated water from the FSP&T system is within the acceptable State Pollutant Discharge Elimination System (SPDES) criteria for the site as shown in Table 2.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
July 1 to 30	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in July 2007 include:

- On July 9, 2007, cleaned/power washed below-grade piping along Noyack Road, between RW-9 and RW-8;
- On July 10, 2007, cleaned/power washed below-grade piping along Carol Street, and cleaned and inspected flow meters for RW-6 and RW-7;
- On July 11, 2007, maintained/cleaned equalization tank and bag-filter housing;
- On July 12, 2007, maintained/cleaned transfer tank;
- On July 13, 2007, maintained/cleaned all flow meter valves and piping, and air-stripper sump;
- On July 20, 2007, conducted cove and piezometer monitoring;
- On July 25, 2007, transfer pump maintenance conducted by Barish Pump Technicians consisting of the replacement of TP2B, and dismantling TP2A .

Future O&M activities scheduled for the summer and fall of 2007 include:

- Troubleshoot the air-stripper blower flow meter;
- Troubleshoot the onsite combined flow meter;
- Conduct cove and piezometer monitoring;
- Conduct semi-annual monitor well sampling;
- Maintain the recharge basin maintenance;
- Repair transfer pump TP2A.

MMG:etn

Attachments

cc: Jeff Srulovitz - Kraft Foods Global, Inc. - .pdf
Lisa Krogman, Environ – .pdf
Jeff Trad, NYSDEC – .pdf
Chief-Operation Maintenance and Support Section, NYSDEC – .pdf
William Spitz, RWM, R-1, NYSDEC
Garrett W. Swensen Jr., Esq., Town of Southampton

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(July 1, 2007 through July 31, 2007)

Date	Time	System Changes/Modifications	Personnel
7/5/2007	11:51 AM	System off from 6/25/07 to 7/5/07 because of a high/high water level alarm for the Equalization tank. System Communication Failure occurred on 6/30/07 but system was already off. Rebooted computer, reset alarms and restarted system.	EF
7/6/2007	8:49 PM	Bag Filter 2 High Pressure Warning Alarm. System still operating. Loosened material from cleaning on-site below-grade piping from the prior week is the most likely cause of the high pressure warning. More extensive pipe and tank cleaning is scheduled for the week of July 9.	
7/7/2007	9:41 PM	Booster Blower Failure Alarm. System shut down.	
7/8/2007	2:05 PM	Bag Filter 3 High Pressure Warning and alarm. Bag Filter 3 is inactive so pressure differential should be minimal. Bag Filter 3 pressure sensors will be investigated.	
7/9/2007	9:34 AM	Reset Alarms, system remains off for cleaning below-grade piping for the system.	PW
		Cleaned/Power Washed below grade piping along Noyac Rd. between RW-9 and RW-8.	PW/ETL
7/10/2007	2:19 PM	Control Room Temperature Low Alarm. Warm temperatures so thermostat controls will be investigated.	
		Cleaned/Power Washed below grade piping along Carrol Street, and cleaned out flow meters for RW-6 and RW-7.	PW/ETL
7/11/2007	9:59 AM	Control Room Temperature Low Alarm.	
	2:55 PM	Equalization tank low level alarm, associated with system maintenance/cleanout activities.	
		Building pipes/fittings, Equalization tank and bag filter housings are cleaned. Replaced bag filters in bank 3.	PW/ETL
7/12/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	PW/ETL
		Building pipe/fittings and transfer tank are cleaned.	PW/ETL
	11:02 AM	Transfer tank low level alarm, associated with system maintenance/cleanout activities.	PW/ETL
7/13/2007	8:22 AM	Finished cleaning the below-grade piping and building piping. Alarms associated with system cleaning/maintenance activities were reset then the system was restarted.	PW/ETL
7/15/2007	12:24 AM	Bag Filter 2 High Pressure Warning, system remains on. Loosened material from cleaning the pipes is the most likely cause of the high pressure warning. Bag filters changed and warning notification reset.	
7/16/2007	12:31 PM	Bag Filter 1 High Pressure Warning, system remains on. Loosened material from cleaning the pipes is the most likely cause of the high pressure warning. Bag filters changed and warning notification reset.	
7/18/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
	9:05 AM	Booster Blower Failure Alarm, system shut down.	
	10:33 AM	Reset Alarms and restarted system.	EF
	11:08 AM	Power Failure Alarm caused by storm. System shut down.	
	11:36 AM	Reboot computer and restart system.	EF
7/20/2007	4:09 AM	System Communication Failure, system shut down	
	12:15 PM	Reboot computer and restart system.	TS
		Cove and Piezometer monitoring conducted.	TS/AD
7/21/2007	3:59 PM	Bag Filter 2 High Pressure Warning, system remains on. Loosened material from cleaning the pipes is the most likely cause of the high pressure warning. Bag filters changed and warning notification reset.	

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(July 1, 2007 through July 31, 2007)

Date	Time	System Changes/Modifications	Personnel
7/24/2007	11:33 PM	Bag Filter 1 High Pressure Warning, system remains on. Loosened material from cleaning the pipes is the most likely cause of the high pressure warning. Bag filters changed and warning notification reset.	
7/25/2007	11:04 AM	System shut down, for transfer pump maintenance. Transfer pump TP-2B repaired and re-installed in the system. Transfer pump TP-2A was disassembled and taken back to the vendor's shop for evaluation and repair.	EF/Barish Pump Technician
		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
	2:30 PM	Clear alarms resulting from transfer pump maintenance and restart system.	EF
7/26/2007	5:34 AM	Filter Bank 2 High Pressure Warning, system remains on. Loosened material from cleaning the pipes is the most likely cause of the high pressure warning. Bag filters changed and warning notification reset.	
7/27/2007	9:26 AM	Filter Bank 1 High Pressure Warning, system remains on. Loosened material from cleaning the pipes is the most likely cause of the high pressure warning. Bag filters changed and warning notification reset .	
7/28/2007	7:58 PM	Filter Bank 2 High Pressure Alarm, system shut down.	
7/31/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
	10:00 AM	Lead pump switched from TP-1B to TP-1A.	EF
	10:03 AM	Reset alarms, restart system	EF

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo-chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	5	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
5-Jul-07	5.43	122	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	12.60	0.115
13-Jul-07	3 ^{1/}	70	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	4.510	0.137
18-Jul-07	5.38	164	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	4.15	0.090
25-Jul-07	5.82	110	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.67	0.463
31-Jul-07	5.46	134	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	10.6	0.142

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

J: Analyte detected below quantitation limits

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethylene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

- Based on the new SPDES criteria from an NYSDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5.
- The pH was measured with a calibrated electronic pH meter. Influent pH values from recovery wells typically range between 5 and 6.
- "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.
- The pH was not measured at this time.

TABLE 3

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon																									Midcarbon																									Postcarbon																								
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	TOTAL VOCs	Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	TOTAL VOCs																											
AQ072006:900NP4-1	7/20/2006	9:00	0.095	0.008	0.091	ND	0.0074	0.005	0.0057	ND	0.0069	0.0062	ND	0.0067	0.0022	0.0022	0.013	ND	ND	ND	ND	ND	0.25	AQ072006:905NP4-2	7/20/2006	9:05	ND	ND	0.022	0.0017	0.0078	0.0044	0.0035	0.0043	ND	0.0018	ND	0.0019	ND	0.013	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.05																								
AQ082406:900NP4-1	8/24/2006	9:00	0.28	0.012	0.055	0.0034	0.0083	0.013	0.0043	0.0021	0.0022	ND	ND	0.003	0.0043	ND	0.013	ND	ND	ND	ND	ND	0.40	AQ082006:902NP4-2	8/24/2006	9:02	ND	ND	0.023	0.0017	0.0054	0.0045	0.0035	0.0043	ND	0.0018	ND	0.0025	ND	0.013	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.06																								
AQ091906:910NP4-1	9/19/2006	9:10	0.21	0.01	0.26	0.006	0.016	0.0046	0.0029	0.001	0.0017	ND	ND	0.0053	0.0012	0.0023	0.009	ND	ND	ND	ND	ND	0.54	AQ091906:915NP4-2	9/19/2006	9:15	0.0014	ND	0.045	0.0031	0.006	0.0058	0.0031	0.0023	ND	0.0016	ND	0.0026	ND	0.0077	ND	0.0092	ND	ND	ND	ND	ND	ND	ND	0.10																								
AQ102506:930NP4-1	10/24/2006	9:30	0.014	0.063	0.2	0.0045	0.013	0.0035	0.0023	ND	0.0018	ND	ND	0.0043	0.001	0.002	0.0091	ND	ND	ND	ND	ND	0.27	AQ102506:935NP4-2	10/24/2006	9:35	0.0021	ND	0.062	0.0039	0.011	0.0044	0.0018	0.0044	ND	0.0014	ND	0.0026	ND	0.0077	ND	0.0092	ND	ND	ND	ND	ND	0.10																										
AQ112906:1000NP4-1	11/29/2006	10:00	0.21	0.0094	0.087	0.003	0.0094	0.0053	0.0028	0.0016	0.0016	ND	ND	0.0045	0.011	0.002	0.0052	ND	ND	ND	ND	ND	0.35	AQ112906:1006NP4-2	11/29/2006	10:06	0.0034	ND	0.24	0.0065	0.022	0.0067	0.0017	0.0012	ND	0.0012	ND	0.0061	ND	0.012	ND	0.0033	ND	0.0085	ND	0.30																												
AQ122006:815NP4-1	12/20/2006	8:15	0.065	0.013	0.13	0.0026	0.0081	0.0037	0.0052	0.0038	0.0021	ND	ND	0.0041	0.0021	0.0028	0.0071	ND	0.0013	ND	ND	ND	0.25	AQ122006:820NP4-2	12/20/2006	8:20	0.0054	0.002	0.3	0.0037	0.014	0.0048	0.0017	0.0012	ND	0.0012	ND	0.0051	ND	0.015	ND	0.037	ND	ND	ND	ND	ND	0.34																										
AQ011007:1000NP4-1	1/10/2007	10:00	0.06	0.082	0.08	0.0031	0.0084	ND	0.0016	0.0011	0.0011	ND	ND	0.0051	0.0016	0.003	0.0059	ND	ND	ND	ND	ND	0.18	AQ011007:1001NP4-2	1/10/2007	10:01	0.0034	0.001	0.32	0.0047	0.012	0.005	0.0013	0.0013	ND	ND	0.0056	ND	0.014	ND	0.032	ND	0.071	ND	ND	ND	0.36																											
AQ020807:1000NP4-1	2/8/2007	10:00	0.22	0.012	0.13	0.0041	0.011	0.0027	0.003	0.002	0.0018	ND	ND	0.0059	0.0038	0.0047	0.0059	ND	ND	ND	ND	ND	0.41	AQ020807:1002NP4-2	2/8/2007	10:02	0.0092	0.004	0.32	0.0042	0.011	0.0063	0.0019	0.0011	ND	ND	0.0067	ND	0.032	ND	0.043	ND	0.037	ND	ND	ND	0.21																											
AQ030707:900NP4-1	3/7/2007	9:00	0.11	0.049	0.05	0.002	0.0066	ND	0.0022	0.0011	ND	ND	ND	0.0031	0.0016	0.0025	0.0019	ND	ND	ND	ND	ND	0.18	AQ030707:902NP4-2	3/7/2007	9:02	0.0058	0.002	0.17	0.0031	0.0081	0.0037	0.0013	0.0013	ND	ND	0.0048	ND	0.001	0.0026	ND	0.038	ND	ND	ND	ND	0.21																											
AQ040307:800NP4-1	4/3/2007	8:00	0.19	0.0085	0.047	0.0025	0.0096	0.0026	0.0013	0.0013	ND	ND	ND	0.0045	0.0014	0.0025	0.0031	ND	ND	ND	ND	ND	0.27	AQ040307:802NP4-2	4/3/2007	8:02	0.003	0.001	0.091	0.002	0.0063	0.0025	ND	ND	ND	ND	0.0047	ND	0.012	ND	0.029	ND	0.036	ND	ND	ND	0.11																											
AQ050107:1100NP4-1	5/1/2007	11:00	0.13	0.0065	0.082	0.0033	0.017	ND	0.002	0.0088	ND	ND	ND	0.0055	0.0021	0.0025	0.0046	ND	ND	ND	ND	ND	0.26	AQ050107:1105NP4-2	5/1/2007	11:05	0.0036	0.001	0.083	0.003	0.013	0.003	0.0017	ND	ND	ND	0.0047	ND	0.002 ^B	0.0027	ND	0.036	ND	ND	ND	ND	ND	0.12																										
AQ060707:1030NP4-1	6/7/2007	10:30	0.1	0.0048	0.046	ND	0.0075	ND	0.0023	ND	ND	ND	ND	0.0045	0.0012	0.0018	0.0054	ND	ND	ND	ND	ND	0.17	AQ060707:1055NP4-2	6/7/2007	10:55	0.0052	0.002	0.058	ND	0.0096	ND	0.0023	ND	ND	ND	0.004	ND	0.0014	ND	0.006	ND	ND	ND	ND	ND	ND	0.09																										
AQ070507:1100NP4-1	7/5/2007	11:00	0.18	0.0067	0.044	0.0021	0.0094	ND	0.0027	ND	ND	ND	ND	0.0046	0.0019	0.0018	0.0064	ND	ND	ND	ND	ND	0.26	AQ070507:1105NP4-2	7/5/2007	11:05	0.0018	0.0012	0.066	ND	0.0084	ND	0.0018	ND	ND	ND	0.0038	ND	0.0019 ^B	ND	0.0071	ND	ND	ND	ND	ND	ND	ND	0.09																									

Note: B Method blank contamination. The associated method blank contains the target analyte at a reportable level.

PCE - Tetrachloroethane
 TCE - Trichloroethane
 TCA - 1,1,1-Trichloroethane
 CE - Chloroethane
 DCE - 1,1-Dichloroethane
 DCA - 1,1-Dichloroethane
 cis-DCE - cis-1,2-Dichloroethane
 CT - Carbon Tetrachloride
 CF - Chloroform
 MC - Methylene Chloride
 CM - Chloromethane
 CD - Carbon Disulfide
 BM - Bromomethane
 CB - Chlorobenzene
 EB - Ethylbenzene
 VC - Vinyl Chloride

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-1	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	NE
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0665	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	6-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	ND<1	ND<1	ND<1	ND<1	5.2	ND<1	0.1650	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	1.7	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	12.0	ND<1	1.0	ND<1	ND<1	ND<1	3.5	0.0511	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	7.7	1.1	ND<1	ND<1	ND<1	ND<1	0.28	0.0286	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
RW-2	9-Aug-05	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	3.74	0.107	ND<1	5.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	16	1.8	ND<1	ND<1	ND<1	ND<1	3.57	0.0704	ND<1	11	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<2	ND<1	NM	NM
	21-Nov-05	15	2.1	ND<1	ND<1	ND<1	ND<1	6.1	0.0269	ND<1	12	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	34	2.1	ND<1	ND<1	ND<1	ND<1	4.25	ND<0.02	ND<1	25	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	5.2	2.0	ND<1	ND<1	ND<1	ND<1	9.15	0.0696	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	6.5	4.3	1.2	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	6.5	3.5	ND<1	ND<1	ND<1	ND<1	4.76	0.0395	ND<1	3.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	12.0	3.9	1.2	ND<1	ND<1	ND<1	4.24	0.0522	ND<1	12.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	19.0	5.1	ND<1	ND<1	ND<1	ND<1	3.95	0.063	ND<1	14.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	13.0	3.0	25	ND<1	ND<1	ND<1	3.57	0.093	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	8.0	3.4	60	ND<1	ND<1	ND<1	4.49	0.177	ND<1	7.5	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	11.0	1.1	25	ND<1	ND<1	ND<1	4.14	0.0772	ND<1	5.7	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	2.8	ND<1	200	ND<1	ND<1	ND<1	13.7	0.0184	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	5.0	1.6	160	ND<1	ND<1	ND<1	3.6	0.00756	ND<1	3.6	0.91	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	6.0	1.8	36	ND<1	ND<1	ND<1	14.1	0.0148	ND<1	3	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	2.2	ND<1	110	ND<1	ND<1	ND<1	11.8	0.0197	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	4.2	2.7	68	ND<1	ND<1	ND<1	2.77	0.458	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-07	3.4	2.4	62	ND<1	ND<1	ND<1	8.72	0.0829	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	31	ND<1	ND<1	ND<1	4.28	0.107	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	3	1.7	23	ND<1	ND<1	ND<1	3.81	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	26	ND<1	ND<1	ND<1	3.04	0.0589	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Jun-07	1.1	1.2	ND<1	ND<1	ND<1	ND<1	2.7	0.0392	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	1.2	0.76	17	ND<1	ND<1	ND<1	2.26	0.198	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-3	4-Jan-05	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	ND-2	ND-1	ND-1	NE
	8-Feb-05	1.6	1.3	ND-1	ND-1	ND-1	ND-1	2.60	2.24	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1
	15-Mar-05	3	13	ND-1	ND-1	ND-1	ND-1	2.10	1.15	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1
	19-Apr-05	2.0	ND-1	5.0	ND-1	ND-1	ND-1	1.89	1.36	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	2-May-05	2.2	7.7	ND-1	ND-1	ND-1	ND-1	46.1	0.539	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	16-Jun-05	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.85	0.82	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	14-Jul-05	1.6	ND-1	ND-1	ND-1	ND-1	ND-1	9.91	10	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	9-Aug-05	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	2.01	0.649	ND-1	ND-1	ND-1	9.1*	ND-1	ND-1	ND-2	ND-1	ND-1	6.9*
	8-Sep-05	1	3.6	ND-1	ND-1	ND-1	ND-1	2.50	0.973	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	19-Oct-05	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	2.03	0.71	ND-1	2.6	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	21-Nov-05	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.83	0.708	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	8-Dec-05	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	2.11	0.556	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	12-Jan-06	1.7	17	7.9	ND-1	ND-1	ND-1	1.93	0.455	ND-1	ND-1	ND-1	4.6*	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	14-Feb-06	1.4	8.9	2.5	ND-1	ND-1	ND-1	3.80	0.157	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	7-Mar-06	1.1	3.4	ND-1	ND-1	ND-1	ND-1	1.87	0.297	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	12-Apr-06	0.95	ND-1	ND-1	ND-1	ND-1	ND-1	1.99	0.649	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	17-May-06	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.06	0.353	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	21-Jun-06	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.06	0.353	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	20-Jul-06	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.06	0.353	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	24-Aug-06	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.06	0.353	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	19-Sep-06	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.06	0.353	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	24-Oct-06	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.06	0.353	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	29-Nov-06	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.06	0.353	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	20-Dec-06	6.4	8	4.4	ND-1	ND-1	ND-1	1.73	0.0112	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	10-Jan-07	1.2	8	3.5	ND-1	ND-1	ND-1	1.87	1.63	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	8-Feb-07	ND-1	3.2	ND-1	ND-1	ND-1	ND-1	ND<0.02	2.16	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	7-Mar-07	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	2.09	1.65	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	18-Apr-07	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	2.24	0.761	ND-1	ND-1	ND-1	6.1*	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	10-May-07	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	1.89	1.02	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	25-Jun-07	0.91	8.5	ND-1	ND-1	ND-1	ND-1	2.48	0.19	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	18-Jul-07	ND-1	2.8	1.2	ND-1	ND-1	ND-1	2.36	0.0414	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
RW-4	4-Jan-05	160	4.1	7.3	ND-1	ND-1	ND-1	6.11	3.28	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Apr-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	2-May-05	80	2.4	9.8	ND-1	ND-1	ND-1	3.77	0.0687	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	30-Jun-05	74	2.6	ND-1	ND-1	ND-1	ND-1	9.95	9.28	ND-1	ND-1	ND-1	4.5*	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	14-Jul-05	37	ND-1	8.9	ND-1	ND-1	ND-1	3.22	0.0185	ND-1	ND-1	ND-1	9.4*	ND-1	ND-1	ND-2	ND-1	ND-1	7.4*
	9-Aug-05	31	ND-1	ND-1	ND-1	ND-1	ND-1	2.49	0.111	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	8-Sep-05	45	ND-1	6.0	ND-1	ND-1	ND-1	3.47	0.173	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	30	ND-1	ND-1	ND-1	ND-1	ND-1	3.69	0.0777	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	12-Dec-05	64	2.0	1.5	ND-1	ND-1	ND-1	2.82	0.0302	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	12-Jan-06	15	ND-1	9.5	ND-1	ND-1	ND-1	7.78	0.0412	ND-1	ND-1	ND-1	5.2*	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	14-Feb-06	24	ND-1	8.7	ND-1	ND-1	ND-1	6.05	0.0627	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	7-Mar-06	22	ND-1	7.0	ND-1	ND-1	ND-1	3.50	0.0476	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	12-Apr-06	26	1.5	6.2	ND-1	ND-1	2	4.17	0.0863	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	17-May-06	26	ND-1	ND-1	ND-1	ND-1	ND-1	3.15	0.109	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	21-Jun-06	23	ND-1	8.4	ND-1	ND-1	ND-1	4.23	0.086	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	20-Jul-06	14	ND-1	9.4	ND-1	ND-1	ND-1	4.10	0.155	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	24-Aug-06	23	ND-1	ND-1	ND-1	ND-1	ND-1	6.00	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	19-Sep-06	9	ND-1	7.5	ND-1	ND-1	ND-1	5.95	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	24-Oct-06	11	ND-1	5.6	ND-1	ND-1	ND-1	7.17	0.0778	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	29-Nov-06	14	0.9	ND-1	ND-1	ND-1	ND-1	2.82	0.00708	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	10-Jan-07	12	ND-1	4.4	ND-1	ND-1	ND-1	17.30	0.0112	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	8-Feb-07	13	ND-1	4.6	ND-1	ND-1	ND-1	3.17	0.0794	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	15	ND-1	4.2	ND-1
	7-Mar-07	7.3	ND-1	3.3	ND-1	ND-1	ND-1	3.64	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	18-Apr-07	10	ND-1	2.1	ND-1	ND-1	ND-1	3.85	0.0767	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	10-May-07	11	ND-1	ND-1	ND-1	ND-1	ND-1	4.46	0.251	ND-1	ND-1	ND-1	7.2*	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	20-Jun-07	5.3	ND-1	0.89	ND-1	ND-1	ND-1	3.67	0.0422	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1
	25-Jul-07	6.9	ND-1	3.3	ND-1	ND-1	ND-1	6.68	3.37	ND-1	ND-1	ND-1	ND-1	ND-1	ND-1	ND-2	ND-1	ND-1	ND-1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloro-methane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethyl-benzene (ug/L)	Acetone (ug/L)	
RW-5	4-Jan-05	12	ND<1	5.6	NE	7	NE	300	300	5	5	5	5	NE	NE	ND<2	ND<1	ND<1	NE	ND<1
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	2.0	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	9	ND<1	4.1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	13	ND<1	5.7	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-05	8.2	ND<1	1.6	ND<1	ND<1	ND<1	0.0358	ND<0.02	ND<1	ND<1	ND<1	9.5 *	ND<1	ND<1	ND<1	ND<1	ND<1	5.6 *	
	9-Aug-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0227	0.0303	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Sep-05	8	ND<1	3.8	ND<1	ND<1	ND<1	0.0185	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0482	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Dec-05	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	0.0468	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Jan-06	2.3	ND<1	2.0	ND<1	ND<1	ND<1	0.0558	0.0119	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Feb-06	2.9	ND<1	3.8	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Mar-06	2.6	ND<1	3.0	ND<1	ND<1	2.4	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Apr-06	1.4	ND<1	ND<1	ND<1	1.5	ND<1	0.0786	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	21-Jun-06	2.4	ND<1	2.6	ND<1	ND<1	ND<1	0.195	0.012	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Jul-06	1.3	ND<1	3.1	ND<1	ND<1	ND<1	0.184	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.09	0.0116	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.194	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	24-Oct-06	1.1	ND<1	1.3	ND<1	ND<1	ND<1	0.0683	0.00884	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
29-Nov-06	6	ND<1	ND<1	1.3	ND<1	ND<1	ND<1	0.136	0.0195	ND<1	ND<1	ND<1	ND<1	0.96	ND<1	ND<1	ND<1	ND<1	ND<1	
20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.508	0.0113	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
10-Jan-07	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	1.2	0.0608	0.0128	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<1	
8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.327	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0655	0.00722	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.973	0.0106	ND<1	ND<1	ND<1	8.1 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0763	0.00469	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
20-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.118	0.00747	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.395	0.0889	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-6	4-Jan-05	86	2.1	3.7	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	0.0502	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	2.7	0.0284	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	0.0599	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	69	1.6	1.3	ND<1	ND<1	ND<1	0.097	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-05	64	1.8	9.5	ND<1	ND<1	ND<1	0.0466	ND<0.02	ND<1	ND<1	ND<1	7.2 *	ND<1	ND<1	ND<1	ND<1	ND<1	7 *	
	9-Aug-05	46	ND<1	12	ND<1	ND<1	ND<1	0.088	0.0366	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Sep-05	100	1.6	12	ND<1	ND<1	ND<1	1.3	0.0143	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	68	ND<1	ND<1	ND<1	ND<1	ND<1	0.144	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Dec-05	100	2.1	20	ND<1	ND<1	ND<1	0.139	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Jan-06	41	1.1	16	ND<1	ND<1	ND<1	0.189	ND<0.02	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	22-Feb-06	63	1.6	15	ND<1	ND<1	ND<1	0.116	0.0155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Mar-06	65	1.2	17	ND<1	ND<1	ND<1	0.0429	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Apr-06	62	2.1	22	ND<1	ND<1	ND<1	0.24	0.0137	0.97	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	17-May-06	83	ND<1	18	ND<1	ND<1	ND<1	0.17	0.019	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	21-Jun-06	88	ND<1	20	ND<1	ND<1	ND<1	0.075	0.025	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Jul-06	45	1.5	24	ND<1	ND<1	ND<1	1.01	0.0669	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	24-Aug-06	30	ND<1	22	ND<1	ND<1	ND<1	5.36	0.0563	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Sep-06	46	ND<1	27	ND<1	ND<1	ND<1	0.916	0.0078	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	24-Oct-06	45	1.2	15	ND<1	ND<1	ND<1	1.84	0.007	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
29-Nov-06	36	1.0	14	ND<1	ND<1	ND<1	0.399	0.0137	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
20-Dec-06	31	ND<1	13	ND<1	ND<1	ND<1	0.243	0.00677	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
10-Jan-07	46	0.96	16	ND<1	ND<1	ND<1	0.0348	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
8-Feb-07	42	ND<1	13	ND<1	ND<1	ND<1	0.0928	0.00453	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
7-Mar-07	29	ND<1	8.4	ND<1	ND<1	ND<1	0.153	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
18-Apr-07	28	ND<1	8.3	ND<1	ND<1	ND<1	0.554	0.0316	ND<1	ND<1	ND<1	ND<1	7.2 *	ND<1	ND<1	ND<1	ND<1	ND<1		
10-May-07	31	ND<1	7.7	ND<1	ND<1	ND<1	0.206	0.00708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
20-Jun-07	19	ND<1	6.6	ND<1	ND<1	ND<1	0.127	0.0139	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1			

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-7	4-Jan-05	37	1.1	5	NE	7	NE	300	300	5	5	5	5	NE	NE	ND<1	ND<1	ND<1	NE
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	32	1.0	4.7	ND<1	ND<1	ND<1	0.0753	0.02	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	32	ND<1	2.2	ND<1	ND<1	ND<1	0.0155	ND<0.02	ND<1	ND<1	ND<1	8.7 *	ND<1	ND<1	ND<1	ND<1	ND<1	7.2 *
	9-Aug-05	31	ND<1	6.2	ND<1	ND<1	ND<1	0.0603	0.0409	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	39	ND<1	3.4	ND<1	ND<1	ND<1	0.0452	ND<0.02	1.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.536	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	70	ND<1	12.0	ND<1	ND<1	ND<1	0.253	ND<0.02	4.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	26	ND<1	5.0	ND<1	ND<1	ND<1	0.343	ND<0.02	2.2	ND<1	ND<1	5.0 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	36	ND<1	4.1	ND<1	ND<1	ND<1	0.0332	ND<0.02	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	38	ND<1	4.1	ND<1	ND<1	ND<1	0.143	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	49	1.6	7.4	ND<1	ND<1	ND<1	0.0912	0.0175	3.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	59	ND<1	ND<1	ND<1	ND<1	ND<1	0.126	0.026	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	44	ND<1	4.6	ND<1	ND<1	ND<1	0.081	0.013	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Aug-06	39	ND<1	7.9	ND<1	ND<1	ND<1	0.307	0.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	36	ND<1	7.5	ND<1	ND<1	ND<1	0.116	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-8	24-Oct-06	33	ND<1	4.1	ND<1	ND<1	ND<1	0.0692	0.0046	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	9-Nov-06	33	ND<1	NM	NM	NM	NM	0.1910	0.0490	1.0	ND<1	ND<1	NM	NM	NM	ND<1	ND<1	NM	NM
	20-Dec-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	10-Jan-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	8-Feb-07	43	ND<1	4.4	ND<1	ND<1	ND<1	0.131	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	23	ND<1	2.7	ND<1	ND<1	ND<1	0.0492	0.0221	ND<1	ND<1	ND<1	6.5 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-07	34	ND<1	ND<1	ND<1	ND<1	ND<1	0.138	0.0438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	22	ND<1	2.3	ND<1	ND<1	ND<1	0.111	0.0271	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jun-07	14	ND<1	1.7	ND<1	ND<1	ND<1	0.136	0.0165	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jul-07	17	ND<1	2.0	ND<1	ND<1	ND<1	0.434	0.0548	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.94	0.075	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.321	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	7.33	0.073	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	2.7	ND<1	5.8	ND<1	ND<1	ND<1	7.06	0.325	2.1	ND<1	ND<1	1.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	2.6	ND<1	3.4	ND<1	ND<1	ND<1	8.33	0.017	ND<1	ND<1	ND<1	8.5 *	ND<1	ND<1	ND<1	ND<1	ND<1	8.2 *
	9-Aug-05	1.8	ND<1	2.9	ND<1	ND<1	ND<1	0.24	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	2.9	ND<1	4.2	ND<1	ND<1	ND<1	7.53	0.255	2.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	27-Nov-05	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	7.65	0.106	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	5.0	ND<1	ND<1	ND<1	5.19	0.021	3.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	1.3	ND<1	3.7	ND<1	ND<1	ND<1	7.25	0.097	2.0	ND<1	ND<1	4.9 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	1.5	ND<1	3.0	ND<1	ND<1	ND<1	3.06	ND<0.02	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	2.8	ND<1	ND<1	ND<1	5.93	0.064	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	2.1	0.9	4.5	ND<1	ND<1	ND<1	7.27	0.823	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.03	0.056	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	8.40	0.897	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	1.0	ND<1	4.0	ND<1	ND<1	ND<1	10.80	0.175	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	3.2	ND<1	ND<1	ND<1	5.98	1.860	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	3.0	ND<1	ND<1	ND<1	7.44	0.009	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	0.9	ND<1	3.1	ND<1	ND<1	ND<1	8.32	0.0605	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	29-Nov-06	1.0	ND<1	3.4	ND<1	ND<1	ND<1	3.67	0.0091	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	3.5	ND<1	ND<1	ND<1	62.80	0.0346	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	1.3	ND<1	3.5	ND<1	ND<1	ND<1	6.57	0.8100	ND<1	ND<1	ND<1	ND<1	1.9	ND<1	9.3	2.8	2.7	ND<1
	8-Feb-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	7-Mar-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	18-Apr-07	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	9.13	0.3820	ND<1	ND<1	ND<1	6.7 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	24.70	0.0129	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jun-07	ND<1	ND<1	1.7	ND<1	ND<1	ND<1	6.67	0.0341	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	8.16	0.0505	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	1.6	5	5	5	NE	NE	NE	NE	NE	NE
	4-Jan-05	ND<1	10	6.4	ND<1	ND<1	ND<1	2.35	1.72	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0566	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	9.8	ND<1	ND<1	ND<1	1.38	0.149	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Jun-05	3.4	ND<1	3.1	ND<1	ND<1	ND<1	2.95	0.238	ND<1	ND<1	ND<1	6.9	ND<1	ND<1	ND<1	ND<1	ND<1	7.3
	9-Aug-05	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	0.994	0.0754	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	1.2	ND<1	2.0	ND<1	ND<1	ND<1	3.64	0.161	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.31	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	2.9	ND<1	ND<1	ND<1	2.01	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	2.36	0.0905	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	2.1	ND<1	1.8	ND<1	ND<1	ND<1	5.23	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.41	0.333	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	1.93	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.054	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-June-06 ^{2/}	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.695	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0165	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND<0.02	ND<1	ND<1	ND<1	18	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	6.96	0.00719	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	28-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.54	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	5.08	0.0855	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.96	0.0076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	8.03	0.399	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.232	ND<1	ND<1	ND<1	6.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.888	0.04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.59	0.0227	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

ND: Not detected
 <MFL: Less than method detection limit
 ug/L: Micrograms per liter
 -: Not analyzed
 ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site
 Bold values indicate an exceedance of the ARAR standard established for the site

PCE: Tetrachloroethylene
 TCE: Trichloroethylene
 TCA: 1,1,1-Trichloroethane
 1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene
 1,2-DCE: 1,2-Dichloroethene
 MTBE: Methyl Tertiary Butyl Ether
 NM: Not Measured


NE indicates that the ARAR goal was not established for this compound by the EPA
 * Concentrations with an asterisk following them are due to laboratory error
^{2/} RW-3 is currently non operational weighting for the reprogramming of the drive for the new 4 amp pump;
^{4/} RW-9 was being rehabilitated during this sampling event, thus no water sample was collected.

GRAPHS


GRAPH 1

GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK


EFFLUENT FLOW DATA
(July 1, 2007 through July 31, 2007)



GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
JULY 2007 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, July 17, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries

Order No.: 0707090

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 7/12/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries
Lab Order: 0707090

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0707090-01A	WQ070507:1000 NP2-6	11795	7/5/2007 10:00:00 AM	7/12/2007
0707090-01B	WQ070507:1000 NP2-6	11795	7/5/2007 10:00:00 AM	7/12/2007
0707090-01C	WQ070507:1000 NP2-6	11795	7/5/2007 10:00:00 AM	7/12/2007
0707090-02A	WQ070507:1005 NP2-7	11795	7/5/2007 10:05:00 AM	7/12/2007
0707090-02B	WQ070507:1005 NP2-7	11795	7/5/2007 10:05:00 AM	7/12/2007
0707090-02C	WQ070507:1005 NP2-7	11795	7/5/2007 10:05:00 AM	7/12/2007
0707090-03A	WQ070507:1010 NP2-10	11795	7/5/2007 10:10:00 AM	7/12/2007
0707090-03B	WQ070507:1010 NP2-10	11795	7/5/2007 10:10:00 AM	7/12/2007
0707090-03C	WQ070507:1010 NP2-10	11795	7/5/2007 10:10:00 AM	7/12/2007

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-01A

Client Sample ID: WQ070507:1000 NP2-6
Tag Number: 11795
Collection Date: 7/5/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,1,1-Trichloroethane	2.2	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
2-Butanone	U	3.0		µg/L	1	7/12/2007 11:59:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
2-Hexanone	U	2.0		µg/L	1	7/12/2007 11:59:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/12/2007 11:59:00 AM
Acetone	U	2.0		µg/L	1	7/12/2007 11:59:00 AM
Benzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Bromobenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Bromochloromethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Bromodichloromethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Bromoform	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Bromomethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Carbon disulfide	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Chlorobenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-01A

Client Sample ID: WQ070507:1000 NP2-6
Tag Number: 11795
Collection Date: 7/5/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Chloroform	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Chloromethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Dibromochloromethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Dibromomethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Ethylbenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Isopropylbenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
m,p-Xylene	U	2.0		µg/L	1	7/12/2007 11:59:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Methylene chloride	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Naphthalene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
n-Butylbenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
n-Propylbenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
o-Xylene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Styrene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Tetrachloroethene	6.4	1.0		µg/L	1	7/12/2007 11:59:00 AM
Toluene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Trichloroethene	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Vinyl acetate	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Vinyl chloride	U	1.0		µg/L	1	7/12/2007 11:59:00 AM
Surr: 4-Bromofluorobenzene	84.7	54-134		%REC	1	7/12/2007 11:59:00 AM
Surr: Dibromofluoromethane	96.8	52-132		%REC	1	7/12/2007 11:59:00 AM
Surr: Toluene-d8	97.4	51-127		%REC	1	7/12/2007 11:59:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 17-Jul-07**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ070507:1000 NP2-6**Lab Order:** 0707090**Tag Number:** 11795**Project:** Rowe Industries**Collection Date:** 7/5/2007 10:00:00 AM**Lab ID:** 0707090-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	7.18	0.0200		mg/L	1	7/17/2007 9:38:10 AM

Qualifiers:

B	Analyte detected in the associated Method Blank
H	Holding times for preparation or analysis exceeded
ND	Not Detected at the Reporting Limit
U	Indicates the compound was analyzed for but not detected

E	Value above quantitation range
J	Analyte detected below quantitation limits
S	Spike Recovery outside accepted recovery limits
X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 17-Jul-07**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ070507:1000 NP2-6**Lab Order:** 0707090**Tag Number:** 11795**Project:** Rowe Industries**Collection Date:** 7/5/2007 10:00:00 AM**Lab ID:** 0707090-01C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.00738	0.0200	J	mg/L	1	7/17/2007 10:22:05 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-02A

Client Sample ID: WQ070507:1005 NP2-7
Tag Number: 11795
Collection Date: 7/5/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
2-Butanone	U	3.0		µg/L	1	7/12/2007 12:36:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
2-Hexanone	U	2.0		µg/L	1	7/12/2007 12:36:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/12/2007 12:36:00 PM
Acetone	U	2.0		µg/L	1	7/12/2007 12:36:00 PM
Benzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Bromobenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Bromoform	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Bromomethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM

Qualifiers:
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-02A

Client Sample ID: WQ070507:1005 NP2-7
Tag Number: 11795
Collection Date: 7/5/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Chloroform	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Chloromethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Dibromomethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/12/2007 12:36:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Methylene chloride	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Naphthalene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
o-Xylene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Styrene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Toluene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Trichloroethene	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/12/2007 12:36:00 PM
Surr: 4-Bromofluorobenzene	86.0	54-134		%REC	1	7/12/2007 12:36:00 PM
Surr: Dibromofluoromethane	99.5	52-132		%REC	1	7/12/2007 12:36:00 PM
Surr: Toluene-d8	98.9	51-127		%REC	1	7/12/2007 12:36:00 PM

Qualifiers:
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-02B

Client Sample ID: WQ070507:1005 NP2-7
Tag Number: 11795
Collection Date: 7/5/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	15.1	0.0200		mg/L	1	7/17/2007 9:40:09 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-02C

Client Sample ID: WQ070507:1005 NP2-7
Tag Number: 11795
Collection Date: 7/5/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0938	0.0200		mg/L	1	7/17/2007 10:26:10 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-03A

Client Sample ID: WQ070507:1010 NP2-10
Tag Number: 11795
Collection Date: 7/5/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
2-Butanone	U	3.0		µg/L	1	7/12/2007 1:14:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
2-Hexanone	U	2.0		µg/L	1	7/12/2007 1:14:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/12/2007 1:14:00 PM
Acetone	U	2.0		µg/L	1	7/12/2007 1:14:00 PM
Benzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Bromobenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Bromoform	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Bromomethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-03A

Client Sample ID: WQ070507:1010 NP2-10
Tag Number: 11795
Collection Date: 7/5/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Chloroform	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Chloromethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Dibromomethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/12/2007 1:14:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Methylene chloride	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Naphthalene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
o-Xylene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Styrene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Toluene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Trichloroethene	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/12/2007 1:14:00 PM
Surr: 4-Bromofluorobenzene	86.1	54-134		%REC	1	7/12/2007 1:14:00 PM
Surr: Dibromofluoromethane	89.6	52-132		%REC	1	7/12/2007 1:14:00 PM
Surr: Toluene-d8	97.4	51-127		%REC	1	7/12/2007 1:14:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-03B

Client Sample ID: WQ070507:1010 NP2-10
Tag Number: 11795
Collection Date: 7/5/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	12.6	0.0200		mg/L	1	7/17/2007 9:42:16 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 17-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707090
Project: Rowe Industries
Lab ID: 0707090-03C

Client Sample ID: WQ070507:1010 NP2-10
Tag Number: 11795
Collection Date: 7/5/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.115	0.0200		mg/L	1	7/17/2007 10:36:46 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: JC
Total Dissolved Solids (Residue, Filterable)	122	1.00		mg/L	1	7/12/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Monday, July 23, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Industries Sag Harbor

Order No.: 0707129

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 7/17/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries Sag Harbor
Lab Order: 0707129

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0707129-01A	WQ071307:0920 NP2-6		7/13/2007	7/17/2007
0707129-01B	WQ071307:0920 NP2-6		7/13/2007	7/17/2007
0707129-02A	WQ071307:0925 NP2-7		7/13/2007	7/17/2007
0707129-02B	WQ071307:0925 NP2-7		7/13/2007	7/17/2007
0707129-03A	WQ071307:0930 NP2-10		7/13/2007	7/17/2007
0707129-03B	WQ071307:0930 NP2-10		7/13/2007	7/17/2007

TAG # / COC _____

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707129
Project: Rowe Industries Sag Harbor
Lab ID: 0707129-01A

Client Sample ID: WQ071307:0920 NP2-6
Tag Number:
Collection Date: 7/13/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	5.49	0.0200		mg/L	1	7/19/2007 11:09:52 AM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: MB
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
2-Butanone	U	3.0		µg/L	1	7/18/2007 5:26:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
2-Hexanone	U	2.0		µg/L	1	7/18/2007 5:26:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/18/2007 5:26:00 PM
Acetone	U	2.0		µg/L	1	7/18/2007 5:26:00 PM
Benzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Bromobenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Bromoform	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Bromomethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/18/2007 5:26:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707129
Project: Rowe Industries Sag Harbor
Lab ID: 0707129-01A

Client Sample ID: WQ071307:0920 NP2-6
Tag Number:
Collection Date: 7/13/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon tetrachloride	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Chloroethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Chloroform	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Chloromethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Dibromomethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/18/2007 5:26:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Methylene chloride	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Naphthalene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
o-Xylene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Styrene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Tetrachloroethene	6.6	1.0		µg/L	1	7/18/2007 5:26:00 PM
Toluene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Trichloroethene	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/18/2007 5:26:00 PM
Surr: 4-Bromofluorobenzene	105	54-134		%REC	1	7/18/2007 5:26:00 PM
Surr: Dibromofluoromethane	127	52-132		%REC	1	7/18/2007 5:26:00 PM
Surr: Toluene-d8	111	51-127		%REC	1	7/18/2007 5:26:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ071307:0920 NP2-6**Lab Order:** 0707129**Tag Number:****Project:** Rowe Industries Sag Harbor**Collection Date:** 7/13/2007**Lab ID:** 0707129-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.0107	0.0200	J	mg/L	1	7/19/2007 11:07:42 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707129
Project: Rowe Industries Sag Harbor
Lab ID: 0707129-02A

Client Sample ID: WQ071307:0925 NP2-7
Tag Number:
Collection Date: 7/13/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.39	0.0200		mg/L	1	7/19/2007 11:15:10 AM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: MB
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
2-Butanone	U	3.0		µg/L	1	7/18/2007 6:03:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
2-Hexanone	U	2.0		µg/L	1	7/18/2007 6:03:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/18/2007 6:03:00 PM
Acetone	U	2.0		µg/L	1	7/18/2007 6:03:00 PM
Benzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Bromobenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Bromoform	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Bromomethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/18/2007 6:03:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707129
Project: Rowe Industries Sag Harbor
Lab ID: 0707129-02A

Client Sample ID: WQ071307:0925 NP2-7
Tag Number:
Collection Date: 7/13/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon tetrachloride	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Chloroethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Chloroform	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Chloromethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Dibromomethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/18/2007 6:03:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Methylene chloride	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Naphthalene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
o-Xylene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Styrene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Toluene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Trichloroethene	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/18/2007 6:03:00 PM
Surr: 4-Bromofluorobenzene	110	54-134		%REC	1	7/18/2007 6:03:00 PM
Surr: Dibromofluoromethane	125	52-132		%REC	1	7/18/2007 6:03:00 PM
Surr: Toluene-d8	115	51-127		%REC	1	7/18/2007 6:03:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ071307:0925 NP2-7**Lab Order:** 0707129**Tag Number:****Project:** Rowe Industries Sag Harbor**Collection Date:** 7/13/2007**Lab ID:** 0707129-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.132	0.0200		mg/L	1	7/19/2007 11:13:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707129
Project: Rowe Industries Sag Harbor
Lab ID: 0707129-03A

Client Sample ID: WQ071307:0930 NP2-10
Tag Number:
Collection Date: 7/13/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.51	0.0200		mg/L	1	7/19/2007 11:17:03 AM
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: MB
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
2-Butanone	U	3.0		µg/L	1	7/18/2007 6:41:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
2-Hexanone	U	2.0		µg/L	1	7/18/2007 6:41:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/18/2007 6:41:00 PM
Acetone	U	2.0		µg/L	1	7/18/2007 6:41:00 PM
Benzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Bromobenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Bromoform	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Bromomethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/18/2007 6:41:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707129
Project: Rowe Industries Sag Harbor
Lab ID: 0707129-03A

Client Sample ID: WQ071307:0930 NP2-10
Tag Number:
Collection Date: 7/13/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Carbon tetrachloride	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Chloroethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Chloroform	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Chloromethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Dibromomethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/18/2007 6:41:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Methylene chloride	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Naphthalene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
o-Xylene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Styrene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Toluene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Trichloroethene	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/18/2007 6:41:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	7/18/2007 6:41:00 PM
Surr: Dibromofluoromethane	130	52-132		%REC	1	7/18/2007 6:41:00 PM
Surr: Toluene-d8	104	51-127		%REC	1	7/18/2007 6:41:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707129
Project: Rowe Industries Sag Harbor
Lab ID: 0707129-03B

Client Sample ID: WQ071307:0930 NP2-10
Tag Number:
Collection Date: 7/13/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.137	0.0200		mg/L	1	7/19/2007 11:21:28 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	70.0	1.00		mg/L	1	7/19/2007

Qualifiers:

B	Analyte detected in the associated Method Blank
H	Holding times for preparation or analysis exceeded
ND	Not Detected at the Reporting Limit
U	Indicates the compound was analyzed for but not detected

E	Value above quantitation range
J	Analyte detected below quantitation limits
S	Spike Recovery outside accepted recovery limits
X	Value exceeds Maximum Contaminant Level

Wednesday, July 25, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries Sag Harbor, N.Y.

Order No.: 0707175

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 7/20/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries Sag Harbor, N.Y.**Lab Order:** 0707175**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0707175-01A	WQ071807:900 NP2-6	10264	7/18/2007 9:00:00 AM	7/20/2007
0707175-01B	WQ071807:900 NP2-6	10264	7/18/2007 9:00:00 AM	7/20/2007
0707175-01C	WQ071807:900 NP2-6	10264	7/18/2007 9:00:00 AM	7/20/2007
0707175-02A	WQ071807:905 NP2-7	10264	7/18/2007 9:05:00 AM	7/20/2007
0707175-02B	WQ071807:905 NP2-7	10264	7/18/2007 9:05:00 AM	7/20/2007
0707175-02C	WQ071807:905 NP2-7	10264	7/18/2007 9:05:00 AM	7/20/2007
0707175-03A	WQ071807:910 NP2-10	10264	7/18/2007 9:10:00 AM	7/20/2007
0707175-03B	WQ071807:910 NP2-10	10264	7/18/2007 9:10:00 AM	7/20/2007
0707175-03C	WQ071807:910 NP2-10	10264	7/18/2007 9:10:00 AM	7/20/2007

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-01A

Client Sample ID: WQ071807:900 NP2-6
Tag Number: 10264
Collection Date: 7/18/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,1,1-Trichloroethane	2.2	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 6:21:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 6:21:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 6:21:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 6:21:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-01A

Client Sample ID: WQ071807:900 NP2-6
Tag Number: 10264
Collection Date: 7/18/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 6:21:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Tetrachloroethene	4.2	1.0		µg/L	1	7/20/2007 6:21:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Trichloroethene	0.51	1.0	J	µg/L	1	7/20/2007 6:21:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 6:21:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	7/20/2007 6:21:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	7/20/2007 6:21:00 PM
Surr: Toluene-d8	93.2	51-127		%REC	1	7/20/2007 6:21:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-01B

Client Sample ID: WQ071807:900 NP2-6
Tag Number: 10264
Collection Date: 7/18/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.76	0.0200		mg/L	1	7/25/2007 9:28:02 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-01C

Client Sample ID: WQ071807:900 NP2-6
Tag Number: 10264
Collection Date: 7/18/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0106	0.0200	J	mg/L	1	7/25/2007 9:25:39 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-02A

Client Sample ID: WQ071807:905 NP2-7
Tag Number: 10264
Collection Date: 7/18/2007 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 6:44:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 6:44:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 6:44:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 6:44:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-02A

Client Sample ID: WQ071807:905 NP2-7
Tag Number: 10264
Collection Date: 7/18/2007 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 6:44:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 6:44:00 PM
Surr: 4-Bromofluorobenzene	97.9	54-134		%REC	1	7/20/2007 6:44:00 PM
Surr: Dibromofluoromethane	101	52-132		%REC	1	7/20/2007 6:44:00 PM
Surr: Toluene-d8	92.5	51-127		%REC	1	7/20/2007 6:44:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-02B

Client Sample ID: WQ071807:905 NP2-7
Tag Number: 10264
Collection Date: 7/18/2007 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.44	0.0200		mg/L	1	7/25/2007 9:41:40 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-02C

Client Sample ID: WQ071807:905 NP2-7
Tag Number: 10264
Collection Date: 7/18/2007 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.175	0.0200		mg/L	1	7/25/2007 9:39:05 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-03A

Client Sample ID: WQ071807:910 NP2-10
Tag Number: 10264
Collection Date: 7/18/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 7:08:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 7:08:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 7:08:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 7:08:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-03A

Client Sample ID: WQ071807:910 NP2-10
Tag Number: 10264
Collection Date: 7/18/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 7:08:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 7:08:00 PM
Surr: 4-Bromofluorobenzene	104	54-134		%REC	1	7/20/2007 7:08:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	7/20/2007 7:08:00 PM
Surr: Toluene-d8	92.7	51-127		%REC	1	7/20/2007 7:08:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-03B

Client Sample ID: WQ071807:910 NP2-10
Tag Number: 10264
Collection Date: 7/18/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.15	0.0200		mg/L	1	7/25/2007 9:45:53 AM

Qualifiers:

B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.


Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707175
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707175-03C

Client Sample ID: WQ071807:910 NP2-10
Tag Number: 10264
Collection Date: 7/18/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0900	0.0200		mg/L	1	7/25/2007 9:43:51 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	164	1.00		mg/L	1	7/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, August 02, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Industries Sag Harbor N.Y.

Order No.: 0707239

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 7/27/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries Sag Harbor N.Y.
Lab Order: 0707239

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0707239-01A	WQ072507:1000 NP2-6		7/25/2007 10:00:00 AM	7/27/2007
0707239-01B	WQ072507:1000 NP2-6		7/25/2007 10:00:00 AM	7/27/2007
0707239-01C	WQ072507:1000 NP2-6		7/25/2007 10:00:00 AM	7/27/2007
0707239-02A	WQ072507:1005 NP2-10		7/25/2007 10:05:00 AM	7/27/2007
0707239-02B	WQ072507:1005 NP2-10		7/25/2007 10:05:00 AM	7/27/2007
0707239-02C	WQ072507:1005 NP2-10		7/25/2007 10:05:00 AM	7/27/2007
0707239-03A	WQ072507:1010 NP2-7		7/25/2007 10:10:00 AM	7/27/2007
0707239-03B	WQ072507:1010 NP2-7		7/25/2007 10:10:00 AM	7/27/2007
0707239-03C	WQ072507:1010 NP2-7		7/25/2007 10:10:00 AM	7/27/2007

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-01A

Client Sample ID: WQ072507:1000 NP2-6
Tag Number:
Collection Date: 7/25/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,1,1-Trichloroethane	2.4	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
2-Butanone	U	3.0		µg/L	1	8/1/2007 5:18:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
2-Hexanone	U	2.0		µg/L	1	8/1/2007 5:18:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	8/1/2007 5:18:00 AM
Acetone	U	2.0		µg/L	1	8/1/2007 5:18:00 AM
Benzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Bromobenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Bromochloromethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Bromodichloromethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Bromoform	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Bromomethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Carbon disulfide	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Chlorobenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM

Qualifiers:
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-01A

Client Sample ID: WQ072507:1000 NP2-6
Tag Number:
Collection Date: 7/25/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Chloroform	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Chloromethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Dibromochloromethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Dibromomethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Ethylbenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Isopropylbenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
m,p-Xylene	U	2.0		µg/L	1	8/1/2007 5:18:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Methylene chloride	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Naphthalene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
n-Butylbenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
n-Propylbenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
o-Xylene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Styrene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Tetrachloroethene	4.7	1.0		µg/L	1	8/1/2007 5:18:00 AM
Toluene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Trichloroethene	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Vinyl acetate	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Vinyl chloride	U	1.0		µg/L	1	8/1/2007 5:18:00 AM
Surr: 4-Bromofluorobenzene	105	54-134		%REC	1	8/1/2007 5:18:00 AM
Surr: Dibromofluoromethane	95.1	52-132		%REC	1	8/1/2007 5:18:00 AM
Surr: Toluene-d8	91.5	51-127		%REC	1	8/1/2007 5:18:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-01B

Client Sample ID: WQ072507:1000 NP2-6
Tag Number:
Collection Date: 7/25/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.99	0.0200		mg/L	1	7/27/2007 12:46:22 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-01C

Client Sample ID: WQ072507:1000 NP2-6
Tag Number:
Collection Date: 7/25/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.661	0.0200		mg/L	1	7/27/2007 12:44:03 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-02A

Client Sample ID: WQ072507:1005 NP2-10
Tag Number:
Collection Date: 7/25/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
2-Butanone	U	3.0		µg/L	1	8/1/2007 5:46:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
2-Hexanone	U	2.0		µg/L	1	8/1/2007 5:46:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	8/1/2007 5:46:00 AM
Acetone	U	2.0		µg/L	1	8/1/2007 5:46:00 AM
Benzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Bromobenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Bromochloromethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Bromodichloromethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Bromoform	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Bromomethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Carbon disulfide	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Chlorobenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-02A

Client Sample ID: WQ072507:1005 NP2-10
Tag Number:
Collection Date: 7/25/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Chloroform	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Chloromethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Dibromochloromethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Dibromomethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Ethylbenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Isopropylbenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
m,p-Xylene	U	2.0		µg/L	1	8/1/2007 5:46:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Methylene chloride	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Naphthalene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
n-Butylbenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
n-Propylbenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
o-Xylene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Styrene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Tetrachloroethene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Toluene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Trichloroethene	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Vinyl acetate	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Vinyl chloride	U	1.0		µg/L	1	8/1/2007 5:46:00 AM
Surr: 4-Bromofluorobenzene	108	54-134		%REC	1	8/1/2007 5:46:00 AM
Surr: Dibromofluoromethane	99.8	52-132		%REC	1	8/1/2007 5:46:00 AM
Surr: Toluene-d8	96.0	51-127		%REC	1	8/1/2007 5:46:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-02B

Client Sample ID: WQ072507:1005 NP2-10
Tag Number:
Collection Date: 7/25/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.67	0.0200		mg/L	1	7/27/2007 12:50:48 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-02C

Client Sample ID: WQ072507:1005 NP2-10
Tag Number:
Collection Date: 7/25/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.463	0.0200		mg/L	1	7/27/2007 12:48:43 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	110	1.00		mg/L	1	7/31/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-03A

Client Sample ID: WQ072507:1010 NP2-7
Tag Number:
Collection Date: 7/25/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
2-Butanone	U	3.0		µg/L	1	8/1/2007 6:12:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
2-Hexanone	U	2.0		µg/L	1	8/1/2007 6:12:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	8/1/2007 6:12:00 AM
Acetone	U	2.0		µg/L	1	8/1/2007 6:12:00 AM
Benzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Bromobenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Bromochloromethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Bromodichloromethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Bromoform	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Bromomethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Carbon disulfide	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Chlorobenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-03A

Client Sample ID: WQ072507:1010 NP2-7
Tag Number:
Collection Date: 7/25/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Chloroform	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Chloromethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Dibromochloromethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Dibromomethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Ethylbenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Isopropylbenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
m,p-Xylene	U	2.0		µg/L	1	8/1/2007 6:12:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Methylene chloride	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Naphthalene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
n-Butylbenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
n-Propylbenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
o-Xylene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Styrene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Tetrachloroethene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Toluene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Trichloroethene	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Vinyl acetate	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Vinyl chloride	U	1.0		µg/L	1	8/1/2007 6:12:00 AM
Surr: 4-Bromofluorobenzene	104	54-134		%REC	1	8/1/2007 6:12:00 AM
Surr: Dibromofluoromethane	96.0	52-132		%REC	1	8/1/2007 6:12:00 AM
Surr: Toluene-d8	93.3	51-127		%REC	1	8/1/2007 6:12:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707239
Project: Rowe Industries Sag Harbor N.Y.
Lab ID: 0707239-03B

Client Sample ID: WQ072507:1010 NP2-7
Tag Number:
Collection Date: 7/25/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.82	0.0200		mg/L	1	7/27/2007 12:55:26 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ072507:1010 NP2-7**Lab Order:** 0707239**Tag Number:****Project:** Rowe Industries Sag Harbor N.Y.**Collection Date:** 7/25/2007 10:10:00 AM**Lab ID:** 0707239-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.414	0.0200		mg/L	1	7/27/2007 12:53:16 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Monday, August 13, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Industries Sag Harbor, N.Y.

Order No.: 0708020

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 8/2/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries Sag Harbor, N.Y.
Lab Order: 0708020

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0708020-01A	WQ073107:1000 NP2-6	11892	7/31/2007 10:00:00 AM	8/2/2007
0708020-01B	WQ073107:1000 NP2-6	11892	7/31/2007 10:00:00 AM	8/2/2007
0708020-01C	WQ073107:1000 NP2-6	11892	7/31/2007 10:00:00 AM	8/2/2007
0708020-02A	WQ073107:1005 NP2-7	11892	7/31/2007 10:05:00 AM	8/2/2007
0708020-02B	WQ073107:1005 NP2-7	11892	7/31/2007 10:05:00 AM	8/2/2007
0708020-02C	WQ073107:1005 NP2-7	11892	7/31/2007 10:05:00 AM	8/2/2007
0708020-03A	WQ073107:1010 NP2-10	11892	7/31/2007 10:10:00 AM	8/2/2007
0708020-03B	WQ073107:1010 NP2-10	11892	7/31/2007 10:10:00 AM	8/2/2007
0708020-03C	WQ073107:1010 NP2-10	11892	7/31/2007 10:10:00 AM	8/2/2007

CLIENT NAME/ADDRESS LB6 Inc. 4 Research dr. Shelton, Ct 06484	CONTACT: mark goldberg 203 944 5000	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED	YES/NO ☒ YES ☐ NO
		SAMPLER NAME (PRINT) Evan Foster	CORRECT CONTAINER(S)	YES/NO ☒ YES ☐ NO

PROJECT LOCATION:			
LABORATORY ID #	MATRIX	# CON- TAINERS	SAMPLING DATE/
Rowe Industries Sag Harbor, NY			
			SAMPLE # - LOCATION

[illegible]

COMMENTS / INSTRUCTIONS

NORMAL ☒ STAT ☐ BY ☐ / ☐ / ☐

TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

RELINQUISHED BY (SIGNATURE)	DATE 8/11/07 TIME 17:00	PRINTED NAME TUNDE WAKVES-SANDOK	RECEIVED BY LAB (SIGNATURE)	DATE 8/14/07 TIME 10:30	PRINTED NAME WILL BAYL
RELINQUISHED BY (SIGNATURE)	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0708020
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0708020-01A

Client Sample ID: WQ073107:1000 NP2-6
Tag Number: 11892
Collection Date: 7/31/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,1,1-Trichloroethane	1.7	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
2-Butanone	U	3.0		µg/L	1	8/2/2007 11:47:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
2-Hexanone	U	2.0		µg/L	1	8/2/2007 11:47:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	8/2/2007 11:47:00 PM
Acetone	U	2.0		µg/L	1	8/2/2007 11:47:00 PM
Benzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Bromobenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Bromochloromethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Bromodichloromethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Bromoform	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Bromomethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Carbon disulfide	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Chlorobenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0708020
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0708020-01A

Client Sample ID: WQ073107:1000 NP2-6
Tag Number: 11892
Collection Date: 7/31/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Chloroform	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Chloromethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Dibromochloromethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Dibromomethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Ethylbenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Isopropylbenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
m,p-Xylene	U	2.0		µg/L	1	8/2/2007 11:47:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Methylene chloride	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Naphthalene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
n-Butylbenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
n-Propylbenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
o-Xylene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Styrene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Tetrachloroethene	3.6	1.0		µg/L	1	8/2/2007 11:47:00 PM
Toluene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Trichloroethene	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Vinyl acetate	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Vinyl chloride	U	1.0		µg/L	1	8/2/2007 11:47:00 PM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	8/2/2007 11:47:00 PM
Surr: Dibromofluoromethane	98.3	52-132		%REC	1	8/2/2007 11:47:00 PM
Surr: Toluene-d8	95.3	51-127		%REC	1	8/2/2007 11:47:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ073107:1000 NP2-6
Lab Order:	0708020	Tag Number:	11892
Project:	Rowe Industries Sag Harbor, N.Y.	Collection Date:	7/31/2007 10:00:00 AM
Lab ID:	0708020-01B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.16	0.0200		mg/L	1	8/3/2007 1:14:13 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ073107:1000 NP2-6
Lab Order:	0708020	Tag Number:	11892
Project:	Rowe Industries Sag Harbor, N.Y.	Collection Date:	7/31/2007 10:00:00 AM
Lab ID:	0708020-01C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	U	0.0200		mg/L	1	8/10/2007 11:29:11 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0708020
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0708020-02A

Client Sample ID: WQ073107:1005 NP2-7
Tag Number: 11892
Collection Date: 7/31/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
2-Butanone	U	3.0		µg/L	1	8/3/2007 12:11:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
2-Hexanone	U	2.0		µg/L	1	8/3/2007 12:11:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	8/3/2007 12:11:00 AM
Acetone	U	2.0		µg/L	1	8/3/2007 12:11:00 AM
Benzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Bromobenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Bromochloromethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Bromodichloromethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Bromoform	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Bromomethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Carbon disulfide	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Chlorobenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0708020
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0708020-02A

Client Sample ID: WQ073107:1005 NP2-7
Tag Number: 11892
Collection Date: 7/31/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Chloroform	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Chloromethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Dibromochloromethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Dibromomethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Ethylbenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Isopropylbenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
m,p-Xylene	U	2.0		µg/L	1	8/3/2007 12:11:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Methylene chloride	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Naphthalene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
n-Butylbenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
n-Propylbenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
o-Xylene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Styrene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Tetrachloroethene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Toluene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Trichloroethene	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Vinyl acetate	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Vinyl chloride	U	1.0		µg/L	1	8/3/2007 12:11:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	8/3/2007 12:11:00 AM
Surr: Dibromofluoromethane	96.9	52-132		%REC	1	8/3/2007 12:11:00 AM
Surr: Toluene-d8	92.8	51-127		%REC	1	8/3/2007 12:11:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0708020
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0708020-02B

Client Sample ID: WQ073107:1005 NP2-7
Tag Number: 11892
Collection Date: 7/31/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.34	0.0200		mg/L	1	8/3/2007 1:15:29 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0708020
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0708020-02C

Client Sample ID: WQ073107:1005 NP2-7
Tag Number: 11892
Collection Date: 7/31/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0600	0.0200		mg/L	1	8/10/2007 11:30:38 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ073107:1010 NP2-10

Lab Order: 0708020

Tag Number: 11892

Project: Rowe Industries Sag Harbor, N.Y.

Collection Date: 7/31/2007 10:10:00 AM

Lab ID: 0708020-03A

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
2-Butanone	U	3.0		µg/L	1	8/3/2007 12:35:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
2-Hexanone	U	2.0		µg/L	1	8/3/2007 12:35:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	8/3/2007 12:35:00 AM
Acetone	U	2.0		µg/L	1	8/3/2007 12:35:00 AM
Benzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Bromobenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Bromochloromethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Bromodichloromethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Bromoform	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Bromomethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Carbon disulfide	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Chlorobenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0708020
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0708020-03A

Client Sample ID: WQ073107:1010 NP2-10
Tag Number: 11892
Collection Date: 7/31/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Chloroform	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Chloromethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Dibromochloromethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Dibromomethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Ethylbenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Isopropylbenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
m,p-Xylene	U	2.0		µg/L	1	8/3/2007 12:35:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Methylene chloride	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Naphthalene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
n-Butylbenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
n-Propylbenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
o-Xylene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Styrene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Tetrachloroethene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Toluene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Trichloroethene	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Vinyl acetate	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Vinyl chloride	U	1.0		µg/L	1	8/3/2007 12:35:00 AM
Surr: 4-Bromofluorobenzene	105	54-134		%REC	1	8/3/2007 12:35:00 AM
Surr: Dibromofluoromethane	93.7	52-132		%REC	1	8/3/2007 12:35:00 AM
Surr: Toluene-d8	94.9	51-127		%REC	1	8/3/2007 12:35:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ073107:1010 NP2-10**Lab Order:** 0708020**Tag Number:** 11892**Project:** Rowe Industries Sag Harbor, N.Y.**Collection Date:** 7/31/2007 10:10:00 AM**Lab ID:** 0708020-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	10.6	0.0200		mg/L	1	8/3/2007 1:16:45 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level


American Analytical Laboratories, LLC.**Date:** 13-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0708020
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0708020-03C

Client Sample ID: WQ073107:1010 NP2-10
Tag Number: 11892
Collection Date: 7/31/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.142	0.0200		mg/L	1	8/10/2007 11:32:05 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	134	1.00		mg/L	1	8/3/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, August 02, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries Sag Harbor, N.Y.

Order No.: 0707240

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 1 sample(s) on 7/27/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Industries Sag Harbor, N.Y.
Lab Order: 0707240

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0707240-01A	GWQ072507: 900 NP1-1-4	09837	7/25/2007 9:00:00 AM	7/27/2007
0707240-01B	GWQ072507: 900 NP1-1-4	09837	7/25/2007 9:00:00 AM	7/27/2007
0707240-01C	GWQ072507: 900 NP1-1-4	09837	7/25/2007 9:00:00 AM	7/27/2007

56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-I AB / PINK-SAMPLE E CUSTODIAN / GOLDENBOD-CIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100

FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707240
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707240-01A

Client Sample ID: GWQ072507: 900 NP1-1-4
Tag Number: 09837
Collection Date: 7/25/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,1,1-Trichloroethane	3.3	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
2-Butanone	U	3.0		µg/L	1	7/27/2007 5:14:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
2-Hexanone	U	2.0		µg/L	1	7/27/2007 5:14:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/27/2007 5:14:00 PM
Acetone	U	2.0		µg/L	1	7/27/2007 5:14:00 PM
Benzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Bromobenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Bromoform	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Bromomethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707240
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707240-01A

Client Sample ID: GWQ072507: 900 NP1-1-4
Tag Number: 09837
Collection Date: 7/25/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: MB		
Chloroethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Chloroform	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Chloromethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Dibromomethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/27/2007 5:14:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Methylene chloride	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Naphthalene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
o-Xylene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Styrene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Tetrachloroethene	6.9	1.0		µg/L	1	7/27/2007 5:14:00 PM
Toluene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Trichloroethene	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/27/2007 5:14:00 PM
Surr: 4-Bromofluorobenzene	88.1	54-134		%REC	1	7/27/2007 5:14:00 PM
Surr: Dibromofluoromethane	101	52-132		%REC	1	7/27/2007 5:14:00 PM
Surr: Toluene-d8	110	51-127		%REC	1	7/27/2007 5:14:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707240
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707240-01B

Client Sample ID: GWQ072507: 900 NP1-1-4
Tag Number: 09837
Collection Date: 7/25/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	6.58	0.0200		mg/L	1	7/27/2007 1:06:26 PM
Manganese	1.25	0.0200		mg/L	1	7/27/2007 1:06:26 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 02-Aug-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707240
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707240-01C

Client Sample ID: GWQ072507: 900 NP1-I-4
Tag Number: 09837
Collection Date: 7/25/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	3.37	0.0200		mg/L	1	7/27/2007 1:04:24 PM
Manganese	1.26	0.0200		mg/L	1	7/27/2007 1:04:24 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	158	1.00		mg/L	1	7/31/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, July 25, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe Industries Sag Harbor, N.Y.

Order No.: 0707174

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 7 sample(s) on 7/20/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe Industries Sag Harbor, N.Y.**Lab Order:** 0707174**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0707174-01A	GWQ071807:1000 NP1-1-5		7/18/2007 10:00:00 AM	7/20/2007
0707174-01B	GWQ071807:1000 NP1-1-5		7/18/2007 10:00:00 AM	7/20/2007
0707174-01C	GWQ071807:1000 NP1-1-5		7/18/2007 10:00:00 AM	7/20/2007
0707174-02A	GWQ071807:1005 NP1-1-7		7/18/2007 10:05:00 AM	7/20/2007
0707174-02B	GWQ071807:1005 NP1-1-7		7/18/2007 10:05:00 AM	7/20/2007
0707174-02C	GWQ071807:1005 NP1-1-7		7/18/2007 10:05:00 AM	7/20/2007
0707174-03A	GWQ071807:1010 NP1-1-6		7/18/2007 10:10:00 AM	7/20/2007
0707174-03B	GWQ071807:1010 NP1-1-6		7/18/2007 10:10:00 AM	7/20/2007
0707174-03C	GWQ071807:1010 NP1-1-6		7/18/2007 10:10:00 AM	7/20/2007
0707174-04A	GWQ071807:1015 NP1-1-8		7/18/2007 10:15:00 AM	7/20/2007
0707174-04B	GWQ071807:1015 NP1-1-8		7/18/2007 10:15:00 AM	7/20/2007
0707174-04C	GWQ071807:1015 NP1-1-8		7/18/2007 10:15:00 AM	7/20/2007
0707174-05A	GWQ071807:1020 NP1-1-9		7/18/2007 10:20:00 AM	7/20/2007
0707174-05B	GWQ071807:1020 NP1-1-9		7/18/2007 10:20:00 AM	7/20/2007
0707174-05C	GWQ071807:1020 NP1-1-9		7/18/2007 10:20:00 AM	7/20/2007
0707174-06A	GWQ071807:1030 NP1-1-2		7/18/2007 10:30:00 AM	7/20/2007
0707174-06B	GWQ071807:1030 NP1-1-2		7/18/2007 10:30:00 AM	7/20/2007
0707174-06C	GWQ071807:1030 NP1-1-2		7/18/2007 10:30:00 AM	7/20/2007
0707174-07A	GWQ071807:1035 NP1-1-3		7/18/2007 10:35:00 AM	7/20/2007
0707174-07B	GWQ071807:1035 NP1-1-3		7/18/2007 10:35:00 AM	7/20/2007
0707174-07C	GWQ071807:1035 NP1-1-3		7/18/2007 10:35:00 AM	7/20/2007

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-01A

Client Sample ID: GWQ071807:1000 NP1-1-5
Tag Number:
Collection Date: 7/18/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 7:31:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 7:31:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 7:31:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 7:31:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ071807:1000 NP1-1-5

Lab Order: 0707174

Tag Number:

Project: Rowe Industries Sag Harbor, N.Y.

Collection Date: 7/18/2007 10:00:00 AM

Lab ID: 0707174-01A

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 7:31:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 7:31:00 PM
Surr: 4-Bromofluorobenzene	99.2	54-134		%REC	1	7/20/2007 7:31:00 PM
Surr: Dibromofluoromethane	101	52-132		%REC	1	7/20/2007 7:31:00 PM
Surr: Toluene-d8	91.4	51-127		%REC	1	7/20/2007 7:31:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-01B

Client Sample ID: GWQ071807:1000 NP1-1-5
Tag Number:
Collection Date: 7/18/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.395	0.0200		mg/L	1	7/25/2007 8:36:01 AM
Manganese	0.0430	0.0200		mg/L	1	7/25/2007 8:36:01 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-01C

Client Sample ID: GWQ071807:1000 NP1-1-5
Tag Number:
Collection Date: 7/18/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0889	0.0200		mg/L	1	7/25/2007 8:34:04 AM
Manganese	0.0131	0.0200	J	mg/L	1	7/25/2007 8:34:04 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	194	1.00		mg/L	1	7/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-02A

Client Sample ID: GWQ071807:1005 NP1-1-7
Tag Number:
Collection Date: 7/18/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,1,1-Trichloroethane	2.0	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,1-Dichloroethane	1.2	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 7:55:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 7:55:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 7:55:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 7:55:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-02A

Client Sample ID: GWQ071807:1005 NP1-1-7
Tag Number:
Collection Date: 7/18/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 7:55:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Tetrachloroethene	17	1.0		µg/L	1	7/20/2007 7:55:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 7:55:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	7/20/2007 7:55:00 PM
Surr: Dibromofluoromethane	104	52-132		%REC	1	7/20/2007 7:55:00 PM
Surr: Toluene-d8	92.8	51-127		%REC	1	7/20/2007 7:55:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-02B

Client Sample ID: GWQ071807:1005 NP1-1-7
Tag Number:
Collection Date: 7/18/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.434	0.0200		mg/L	1	7/25/2007 8:43:39 AM
Manganese	0.178	0.0200		mg/L	1	7/25/2007 8:43:39 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-02C

Client Sample ID: GWQ071807:1005 NP1-1-7
Tag Number:
Collection Date: 7/18/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0548	0.0200		mg/L	1	7/25/2007 8:38:52 AM
Manganese	0.188	0.0200		mg/L	1	7/25/2007 8:38:52 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	184	1.00		mg/L	1	7/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-03A

Client Sample ID: GWQ071807:1010 NP1-1-6
Tag Number:
Collection Date: 7/18/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,1,1-Trichloroethane	6.8	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 8:18:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 8:18:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 8:18:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 8:18:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-03A

Client Sample ID: GWQ071807:1010 NP1-1-6
Tag Number:
Collection Date: 7/18/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 8:18:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Tetrachloroethene	20	1.0		µg/L	1	7/20/2007 8:18:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 8:18:00 PM
Surr: 4-Bromofluorobenzene	96.7	54-134		%REC	1	7/20/2007 8:18:00 PM
Surr: Dibromofluoromethane	105	52-132		%REC	1	7/20/2007 8:18:00 PM
Surr: Toluene-d8	91.8	51-127		%REC	1	7/20/2007 8:18:00 PM

Qualifiers:
 B Analyte detected in the associated Method Blank
 H Holding times for preparation or analysis exceeded
 ND Not Detected at the Reporting Limit
 U Indicates the compound was analyzed for but not detected

E Value above quantitation range
 J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits
 X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-03B

Client Sample ID: GWQ071807:1010 NP1-1-6
Tag Number:
Collection Date: 7/18/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.595	0.0200		mg/L	1	7/25/2007 8:50:25 AM
Manganese	0.0875	0.0200		mg/L	1	7/25/2007 8:50:25 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-03C

Client Sample ID: GWQ071807:1010 NP1-1-6
Tag Number:
Collection Date: 7/18/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.597	0.0200		mg/L	1	7/25/2007 8:48:16 AM
Manganese	0.0696	0.0200		mg/L	1	7/25/2007 8:48:16 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	136	1.00		mg/L	1	7/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-04A

Client Sample ID: GWQ071807:1015 NP1-1-8
Tag Number:
Collection Date: 7/18/2007 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,1,1-Trichloroethane	1.5	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,1-Dichloroethane	1.3	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 8:41:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 8:41:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 8:41:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 8:41:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-04A

Client Sample ID: GWQ071807:1015 NP1-1-8
Tag Number:
Collection Date: 7/18/2007 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 8:41:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 8:41:00 PM
Surr: 4-Bromofluorobenzene	99.5	54-134		%REC	1	7/20/2007 8:41:00 PM
Surr: Dibromofluoromethane	107	52-132		%REC	1	7/20/2007 8:41:00 PM
Surr: Toluene-d8	92.7	51-127		%REC	1	7/20/2007 8:41:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-04B

Client Sample ID: GWQ071807:1015 NP1-1-8
Tag Number:
Collection Date: 7/18/2007 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	8.16	0.0200		mg/L	1	7/25/2007 9:01:42 AM
Manganese	0.644	0.0200		mg/L	1	7/25/2007 9:01:42 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-04C

Client Sample ID: GWQ071807:1015 NP1-1-8
Tag Number:
Collection Date: 7/18/2007 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0505	0.0200		mg/L	1	7/25/2007 8:59:41 AM
Manganese	0.686	0.0200		mg/L	1	7/25/2007 8:59:41 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	142	1.00		mg/L	1	7/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-05A

Client Sample ID: GWQ071807:1020 NP1-1-9
Tag Number:
Collection Date: 7/18/2007 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 9:04:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 9:04:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 9:04:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 9:04:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-05A

Client Sample ID: GWQ071807:1020 NP1-1-9
Tag Number:
Collection Date: 7/18/2007 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 9:04:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Trichloroethene	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 9:04:00 PM
Surr: 4-Bromofluorobenzene	95.9	54-134		%REC	1	7/20/2007 9:04:00 PM
Surr: Dibromofluoromethane	107	52-132		%REC	1	7/20/2007 9:04:00 PM
Surr: Toluene-d8	93.6	51-127		%REC	1	7/20/2007 9:04:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-05B

Client Sample ID: GWQ071807:1020 NP1-1-9
Tag Number:
Collection Date: 7/18/2007 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	2.59	0.0200		mg/L	1	7/25/2007 9:11:35 AM
Manganese	0.646	0.0200		mg/L	1	7/25/2007 9:11:35 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-05C

Client Sample ID: GWQ071807:1020 NP1-1-9
Tag Number:
Collection Date: 7/18/2007 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0227	0.0200		mg/L	1	7/25/2007 9:09:01 AM
Manganese	0.676	0.0200		mg/L	1	7/25/2007 9:09:01 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	132	1.00		mg/L	1	7/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-06A

Client Sample ID: GWQ071807:1030 NP1-1-2
Tag Number:
Collection Date: 7/18/2007 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,1,1-Trichloroethane	17	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 9:28:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 9:28:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 9:28:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 9:28:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-06A

Client Sample ID: GWQ071807:1030 NP1-1-2
Tag Number:
Collection Date: 7/18/2007 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 9:28:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Tetrachloroethene	1.2	1.0		µg/L	1	7/20/2007 9:28:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Trichloroethene	0.78	1.0	J	µg/L	1	7/20/2007 9:28:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 9:28:00 PM
Surr: 4-Bromofluorobenzene	95.4	54-134		%REC	1	7/20/2007 9:28:00 PM
Surr: Dibromofluoromethane	104	52-132		%REC	1	7/20/2007 9:28:00 PM
Surr: Toluene-d8	91.1	51-127		%REC	1	7/20/2007 9:28:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-06B

Client Sample ID: GWQ071807:1030 NP1-1-2
Tag Number:
Collection Date: 7/18/2007 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	2.26	0.0200		mg/L	1	7/25/2007 9:16:35 AM
Manganese	0.525	0.0200		mg/L	1	7/25/2007 9:16:35 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-06C

Client Sample ID: GWQ071807:1030 NP1-1-2
Tag Number:
Collection Date: 7/18/2007 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.198	0.0200		mg/L	1	7/25/2007 9:14:04 AM
Manganese	0.00739	0.0200	J	mg/L	1	7/25/2007 9:14:04 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	226	1.00		mg/L	1	7/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-07A

Client Sample ID: GWQ071807:1035 NP1-1-3
Tag Number:
Collection Date: 7/18/2007 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,1,1-Trichloroethane	1.2	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
2-Butanone	U	3.0		µg/L	1	7/20/2007 9:51:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
2-Hexanone	U	2.0		µg/L	1	7/20/2007 9:51:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	7/20/2007 9:51:00 PM
Acetone	U	2.0		µg/L	1	7/20/2007 9:51:00 PM
Benzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Bromobenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Bromochloromethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Bromodichloromethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Bromoform	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Bromomethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Carbon disulfide	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Chlorobenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-07A

Client Sample ID: GWQ071807:1035 NP1-1-3
Tag Number:
Collection Date: 7/18/2007 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Chloroform	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Chloromethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Dibromochloromethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Dibromomethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Ethylbenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Isopropylbenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
m,p-Xylene	U	2.0		µg/L	1	7/20/2007 9:51:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Methylene chloride	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Naphthalene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
n-Butylbenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
n-Propylbenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
o-Xylene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Styrene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Tetrachloroethene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Toluene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Trichloroethene	2.8	1.0		µg/L	1	7/20/2007 9:51:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Vinyl acetate	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Vinyl chloride	U	1.0		µg/L	1	7/20/2007 9:51:00 PM
Surr: 4-Bromofluorobenzene	94.7	54-134		%REC	1	7/20/2007 9:51:00 PM
Surr: Dibromofluoromethane	103	52-132		%REC	1	7/20/2007 9:51:00 PM
Surr: Toluene-d8	88.9	51-127		%REC	1	7/20/2007 9:51:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-07B

Client Sample ID: GWQ071807:1035 NP1-1-3
Tag Number:
Collection Date: 7/18/2007 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	2.36	0.0200		mg/L	1	7/25/2007 9:22:46 AM
Manganese	0.245	0.0200		mg/L	1	7/25/2007 9:22:46 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Jul-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0707174
Project: Rowe Industries Sag Harbor, N.Y.
Lab ID: 0707174-07C

Client Sample ID: GWQ071807:1035 NP1-1-3
Tag Number:
Collection Date: 7/18/2007 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0414	0.0200		mg/L	1	7/25/2007 9:20:38 AM
Manganese	0.183	0.0200		mg/L	1	7/25/2007 9:20:38 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: AH
Total Dissolved Solids (Residue, Filterable)	132	1.00		mg/L	1	7/24/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

H7G060105 Analytical Report	1
Sample Receipt Documentation	15
Total Number of Pages	17



STL

STL Knoxville
5815 Middlebrook Pike
Knoxville, TN 37921

Tel: 865 291 3000 Fax: 865 584 4315
www.stl-inc.com

ANALYTICAL REPORT

Rowe-NABSAG 0401

Lot #: H7G060105

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

TESTAMERICA LABORATORIES, INC. (FKA STL)

A handwritten signature in black ink, appearing to read "J. A. McKinney".

Jamie A. McKinney
Project Manager

July 17, 2007

ANALYTICAL METHODS SUMMARY

H7G060105

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15

References:

EPA-2 "Compendium of Methods for the Determination of Toxic
Organic Compounds in Ambient Air", EPA-625/R-96/010b,
January 1999.

SAMPLE SUMMARY

H7G060105

WO #	SAMPLE#	CLIENT SAMPLE ID	SAMPLED DATE	SAMP TIME
J2D64	001	AQ070507:1100NP4-1	07/05/07	11:00
J2D69	002	AQ070507:1105NP4-2	07/05/07	11:05
J2D7A	003	AQ070507:1110NP4-3	07/05/07	11:10

NOTE (S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

H7G060105

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

There were no problems with the condition of the samples received.

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

The samples were received on 7/6/07 in Tedlar bags and analyzed within 72 hours of sampling.

TestAmerica Knoxville (formerly STL Knoxville) maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. # QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ070507:1100NP4-1
 GC/MS Volatiles

Lot-Sample # H7G060105 - 001

Work Order # J2D641AA

Matrix.....: AIR

Date Sampled...: 7/5/07

Date Received...: 7/6/07

Prep Date.....: 7/6/07

Analysis Date.. 7/6/07

Prep Batch #.....: 7190286

Dilution Factor.: 5

Method..... TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	2.1	2.5	6.4	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	0.95	1.0	4.6	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	2.3	1.0	9.4	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.52	1.0	2.1	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.55	2.5	1.9	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	26	1.0	180	6.8
Toluene	0.71	1.0	2.7	3.8
1,1,1-Trichloroethane	8.0	1.0	44	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	1.2	1.0	6.7	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	104	70 - 130
Toluene-d8	102	70 - 130
4-Bromofluorobenzene	93	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ070507:1100NP4-1
GC/MS Volatiles

Lot-Sample # H7G060105 - 001

Work Order # J2D641AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting
Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.

Client Sample ID: AQ070507:1105NP4-2

GC/MS Volatiles

Lot-Sample # H7G060105 - 002

Work Order # J2D691AA

Matrix.....: AIR

Date Sampled...: 7/5/07

Date Received..: 7/6/07

Prep Date.....: 7/6/07

Analysis Date..: 7/6/07

Prep Batch #....: 7190286

Dilution Factor.: 5

Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	2.3	2.5	7.1 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	0.78	1.0	3.8 J	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	2.1	1.0	8.4	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	ND	1.0	ND	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.54	2.5	1.9 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	0.26	1.0	1.8 J	6.8
Toluene	0.47	1.0	1.8 J	3.8
1,1,1-Trichloroethane	12	1.0	66	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	0.22	1.0	1.2 J	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	104	70 - 130
Toluene-d8	104	70 - 130
4-Bromofluorobenzene	95	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ070507:1105NP4-2
GC/MS Volatiles

Lot-Sample # H7G060105 - 002

Work Order # J2D691AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ070507:1110NP4-3
 GC/MS Volatiles

Lot-Sample # H7G060105 - 003 Work Order # J2D7A1AA Matrix.....: AIR

Date Sampled...: 7/5/07 Date Received...: 7/6/07
 Prep Date.....: 7/6/07 Analysis Date.. 7/6/07
 Prep Batch #.....: 7190286
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	2.0	2.5	6.2 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.2	1.0	6.0	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	3.8	1.0	15	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	1.6	1.0	6.4	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.82	1.0	3.3 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.55	2.5	1.9 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	ND	1.0	ND	6.8
Toluene	0.43	1.0	1.6 J	3.8
1,1,1-Trichloroethane	20	1.0	110	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	104	70 - 130
Toluene-d8	105	70 - 130
4-Bromofluorobenzene	96	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ070507:1110NP4-3
GC/MS Volatiles

Lot-Sample # H7G060105 - 003

Work Order # J2D7A1AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: $\text{Amount Found}(\text{before rounding}) \times (\text{Molecular Weight}/24.45)$

The 'Reporting Limit' in ug/m3 is calculated using the following equation: $(\text{Reporting Limit}(\text{before rounding}) \times \text{Dilution Factor}) \times (\text{Molecular Weight}/24.45)$

Leggette, Brashears & Graham, Inc.
 Client Sample ID: INTRA-LAB BLANK
 GC/MS Volatiles

Lot-Sample # H7G090000 - 286B

Work Order # J2HX21AA

Matrix.....: AIR

Prep Date.....: 7/6/07

Date Received..: 7/6/07

Prep Batch #.....: 7190286

Analysis Date.. 7/6/07

Dilution Factor.: 1

Method..... TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	1.6
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	0.070	0.50	0.24 J	1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	104	70 - 130
Toluene-d8	105	70 - 130
4-Bromofluorobenzene	92	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: INTRA-LAB BLANK
GC/MS Volatiles

Lot-Sample # H7G090000 - 286B

Work Order # J2HX21AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: CHECK SAMPLE
 GC/MS Volatiles

Lot-Sample # H7G090000 - 286C Work Order # J2HX21AC Matrix.....: AIR

Prep Date.....: 7/6/07 Date Received..: 7/6/07
 Prep Batch #.....: 7190286 Analysis Date..: 7/6/07
 Dilution Factor.: 1 Method.....: TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	10.0	8.78	32	28	88	70 - 130
Chlorobenzene	10.0	9.91	46	46	99	70 - 130
1,1-Dichloroethene	10.0	7.01	40	28	70	70 - 130
Toluene	10.0	9.80	38	37	98	70 - 130
Trichloroethene	10.0	8.69	54	47	87	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	114	70 - 130
Toluene-d8	98	70 - 130
4-Bromofluorobenzene	97	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

STL Knoxville

5815 Middlebrook Pike • Knoxville, TN 37921-5947
Phone: (865) 291-3000 • Fax: (865) 584-4315
Receiving: (865) 291-3031

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD*

Reference Document No.
Page 1 of 1 1760601DS

Project Name/No. ¹ Rowe
Sample Team Members ² Evann Foster
Profit Center No. ³ _____
Project Manager ⁴ Mark Goldberg
Purchase Order No. ⁵ Nabsego401
Required Report Date ¹¹ _____

Samples Shipment Date ⁷ _____
Lab Destination ⁸ STL Knoxville
Lab Contact ⁹ Jamie McKinney
Project Contact / Phone ¹² 203-944-3000
Carrier / Waybill No. ¹³ _____

Bill to: ⁵ Mark Goldberg
LBO Inc.
4 Research dr
Stelton, Ct
Report to: ¹⁰ Mark Goldberg
mgoldberg@lbgct.com

ONE CONTAINER PER LINE

Sample ¹⁴ Number	Sample ¹⁵ Type	Date/Time ¹⁶ Collected	Container ¹⁷ Type	Sample ¹⁸ Volume	Pre- ¹⁹ servative	Requested Testing ²⁰ Program	Condition on Receipt ²¹ Lab use only
A0070507:1100NP4-1	Air	7-5-07/ 1100	Tedlar	1 litre	cool	To-15	Custody seals intact (Y) N NA
A0070507:1105NP4-2	Air	" 1105	Tedlar	1 litre	cool	To-15	Temperature received at <u>ambient</u>
A0070507:1110NP4-3	Air	" 1110	Tedlar	1 litre	cool	To-15	Received by <u>NAB</u> Date <u>7-16-07</u>
							Number of packages <u>1 container</u>
							Tracking # <u>FEDX#</u>
							<u>7987 1229 0781</u>

Special Instructions: ²³ _____

Possible Hazard Identification: ²⁴ _____

Non-Hazard ☒ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐

Turnaround Time Required: ²⁶ _____

Normal ☒ Rush ☐

1. Relinquished by ²⁸ _____

(Signature / Affiliation) Mark M. Goldberg

1. Relinquished by _____

(Signature / Affiliation) _____

Comments: ²⁹ _____

Sample Disposal: ²⁵ _____

Return to Client ☐ Disposal by Lab ☒ Archive (mos.)

QC Level: ²⁷ _____

I. ☐ II. ☐ III. ☐

Date: 7-5-07

Time: 17:00

Date: _____

Time: _____

Project Specific (specify): full QA/QC

Date: 7-16-07

Time: 09:30

Date: _____

Time: _____

STL KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: LBG INC. Project: ROWF Lot Number: H76060105

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)	☒			☐ 1a Do not match COC ☐ 1b Incomplete information ☐ 1c Marking smeared ☐ 1d Label torn ☐ 1e No label ☐ 1f COC not received ☐ 1g Other:	
2. Is the cooler temperature within limits? (> freezing temp. of water to 6°C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6 °C)		☒		☐ 2a Temp Blank = ☐ 2b Cooler Temp =	
3. Were samples received with correct chemical preservative (excluding Encore)?		☒		☐ 3a Sample preservative =	
4. Were custody seals present/intact on cooler and/or containers?		☒		☐ 4a Not present ☐ 4b Not intact ☐ 4c Other:	
5. Were all of the samples listed on the COC received?		☒		☐ 5a Samples received-not on COC ☐ 5b Samples not received-on COC	
6. Were all of the sample containers received intact?		☒		☐ 6a Leaking ☐ 6b Broken	
7. Were VOA samples received without headspace?		☒		☐ 7a Headspace (VOA only)	
8. Were samples received in appropriate containers?		☒		☐ 8a Improper container	
9. Did you check for residual chlorine, if necessary?		☒		☐ 9a Could not be determined due to matrix interference	
10. Were samples received within holding time?		☒		☐ 10a Holding time expired	
11. For rad samples, was sample activity info. provided?		☒		☐ Incomplete information	
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?		☒		If yes & appears to be > 1%, was SOG notified?	
13. Are the shipping containers intact?		☒		☐ 13a Leaking ☐ 13b Other:	
14. Was COC relinquished? (Signed/Dated/Timed)		☒		☐ 14a Not relinquished	
15. Are tests/parameters listed for each sample?		☒		☐ 15a Incomplete information	
16. Is the matrix of the samples noted?		☒		☐ 15a Incomplete information	
17. Is the date/time of sample collection noted?		☒		☐ 15a Incomplete information	
18. Is the client and project name/# identified?		☒		☐ 15a Incomplete information	
19. Was the sampler identified on the COC?		☒		☐ 15a Incomplete information	

Quote #: 69610 PM Instructions:Sample Receiving Associate: *[Signature]* Date: 7-6-07 QA026R18.doc, 1/30/06