

**PROJECT STATUS MEMORANDUM**

**NO. 09-07**

**TO:** Pamela Tames, USEPA

**FROM:** Mark M. Goldberg, P.E.  
Tunde H. Komuves-Sandor

**DATE:** November 16, 2007

**PROJECT:** Rowe Industries Superfund Site  
Ground-Water Recovery and Treatment System  
September 2007 Status Report  
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from September 1, 2007 through September 30, 2007. The report includes a summary of system performance parameters, system operation parameters, analytical results for ground water, system effluent samples, and air quality results.

**SUMMARY OF SYSTEM PERFORMANCE AND OPERATION**

*(September 1, 2007 through September 30, 2007)*

- |   |                                  |
|---|----------------------------------|
| 1. Hours of operation during the reporting period:  | 318 hours (44%)                  |
| 2. Alarm conditions during the reporting period:  | See Table 1                      |
| 3. Was the SPDES VOC discharge permit criteria achieved:  | yes, (Table 2)                   |
| 4. Total volume of water pumped during the reporting period:  | 8,959,040 gal.                   |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1)                          |                                  |
| 6. Mass of VOCs recovered during the reporting period:  | 0.4 pounds                       |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:<br>(calculations can be provided upon request)  | 205.8 pounds                     |
| 8. Effluent VOC vapor concentration for the reporting period:   | 0.06 mg/m <sup>3</sup> (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:<br>(calculations can be provided upon request) | yes (0.00037 lbs/hr)             |

## GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume pumped (gal)	Average Flow (gpm)	Lowest Measured Flow (gpm)*	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2	559,843	27	13	2.8	0.01
RW-3	559,845	26	10	1.6	0.007
RW-4**	634,280	38	10	13.3	0.07
RW-5	1,119,890	50	50	0.6	0.01
RW-6	279,986	15	15	28.0	0.07
RW-7**	1,320,751	70	69	26.8	0.29
RW-8**	2,168,745	54	41	1.5	0.03
RW-9	1,120,389	73	16	0	0

\*Lowest measured flows are based on the lowest average 24-hour pumping rates for each well recorded to date.

\*\* The RW-4, RW-7 and RW-8 flow meters were not functioning properly so the total volume pumped was calculated using the product of the average flow and the hours of operation for the month.

Based on the results of the updated ground-water model for the site, the plume is not migrating beyond the influence of the FSP&T system if the recovery well pumps operate at or above the “Lowest Measured Flows”. The average monthly pumping rates for all recovery wells are at or above the “Lowest Measured Flows”. The updated ground-water model is discussed in the 2006 Annual Report for the site.

The number of Bag Filter High Pressure Warnings and Alarms has decreased slightly during the month of September, likely due to a decrease in the amount of loosened material from the pipe cleaning activities conducted in July. The 400 micron bag filters continue to be changed on a weekly basis and the influent and effluent pressures will continue to be monitored.

The effluent pH of 7.05 measured in the treated water from the FSP&T system during the September 26<sup>th</sup> sampling event is higher than normal; however, the pH is near neutral and within the acceptable State Pollutant Discharge Elimination System (SPDES) criteria for the site as shown in Table 2.

### BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
September 1 to 30	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

### **OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES**

Other O&M activities conducted in September 2007 include:

- On September 6, 2007, the RW-7 Flow Totalizer was reset;
- On September 12, 2007, Barish pump technicians replaced a bolt that was damaged during the last service visit. A spent bag-filter sample was collected for the purpose of updating the waste profile characterization to determine if the spent bag filters should still be disposed of as hazardous waste. The lab results for the sample were below hazardous waste concentrations thresholds so a second sample will be collected to verify the results;
- On September 18, 2007, cove and piezometer monitoring was conducted;
- On September 26, 2007, a second spent bag-filter sample was collected for waste profile characterization.

Future O&M activities scheduled for the fall of 2007 include:

- troubleshoot the air stripper blower flow meter;
- troubleshoot the on-site and off-site combined flow meters;
- troubleshoot the RW-4 and RW-8 flow meters;
- conduct semi-annual ground-water monitoring; and
- complete recharge basin maintenance.

MMG:nv

Attachments

cc: Jeff Srulovitz - Kraft Foods Global, Inc. - .pdf  
 Lisa Krogman, Environ – .pdf  
 Jeff Trad, NYSDEC – .pdf  
 Chief-Operation Maintenance and Support Section, NYSDEC – .pdf  
 William Spitz, RWM, R-1, NYSDEC  
 Garrett W. Swensen Jr., Esq., Town of Southampton

## **TABLES**

**TABLE 1**  
**GROUND-WATER REMEDIAL ACTION**  
**ROWE INDUSTRIES SUPERFUND SITE**  
**SAG HARBOR, NEW YORK**

**MAINTENANCE LOG**  
(September 1, 2007 through September 30, 2007)

<b>Date</b>	<b>Time</b>	<b>System Changes/Modifications</b>	<b>Personnel</b>
9/6/2007		Changed multi-bag filter bags (400 um) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
	10:32 AM	Reset RW-7 flow totalizer.	EF
	7:23 PM	Bag Filter 2 High Pressure Warning. System still operating.	
9/8/2007		Communication Failure Alarm, system shutdown some time between 3:56 AM and 4:56 AM.	
9/12/2007	9:22 AM	Rebooted Computer, numerous alarms related to computer reboot.	EF
		The Barish Pump technician replaced a bolt that was damaged during last month's re-installation of transfer pump TP2B.	EF/Barish Pump Technician
		A spent bag-filter sample was collected for the purpose of updating the waste profile characterization to determine if the spent bag filters should still be disposed of as hazardous waste.	EF
	11:15 AM	Restarted System.	EF
	2:48 PM	System shut down due to an air stripper blower low pressure alarm.	
9/18/2007	8:48 AM	Cleared alarms and restarted system.	EF
		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
		Cove and piezometer monitoring conducted.	EF/TS
9/21/2007	1:26 PM	Power Failure Alarm, and numerous other alarms associated with power failure, system shut down	
9/26/2007	10:13 AM	Rebooted computer, reset alarms and restarted system.	RD
		Did not change multi-bag filter bags because the system only operated for two days prior to the power failure.	RD
		A second spent bag-filter sample was collected for waste profile characterization to determine if the spent bag filters should still be disposed of hazardous waste.	RD
9/29/2007	4:31 AM	Air stripper blower low pressure alarm, system shut down.	

TABLE 2

GROUND-WATER REMEDIAL ACTION  
 ROWE INDUSTRIES SUPERFUND SITE  
 SAG HARBOR, NEW YORK

EFFLUENT WATER QUALITY RESULTS

Date Sampled <sup>2/</sup>	pH <sup>1/</sup>	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo-chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	5	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
6-Sep-07	5.81	140	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	0.18	0.145
12-Sep-07	5.37	58	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	66.00	0.529
18-Sep-07	5.37	138	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	8.21	1.250
26-Sep-07	7.05 <sup>4/</sup>	108	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.93	0.217

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

J: Analyte detected below quantitation limits

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

- Based on the new SPDES criteria from an NY SDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5. The pH was measured with a new calibrated electronic pH meter. Influent pH values from recovery wells typically range between 5 and 6.
- "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.
- The pH was not measured at this time.
- pH is higher than normal for the site, but is near neutral and within SPDES discharge criteria; therefore it is not a concern.













TABLE 4

GROUND-WATER REMEDIAL ACTION  
 ROWE INDUSTRIES SUPERFUND SITE  
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)	
RW-9	4-Jan-05	ND<1	10	6.4	NE	7	NE	300	172	1.6	5	5	5	NE	NE	ND<2	ND<1	ND<1	NE	
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0586	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<2	ND<1	ND<1	ND<1	
	16-Jun-05	ND<1	ND<1	9.8	ND<1	ND<1	ND<1	1.38	0.149	0.9	ND<1	ND<1	1.2	ND<1	ND<2	ND<2	ND<1	ND<1	ND<1	7.3
	14-Jul-05	3.4	ND<1	3.1	ND<1	ND<1	ND<1	2.95	0.238	ND<1	ND<1	ND<1	6.9	ND<1	ND<2	ND<2	ND<1	ND<1	ND<1	
	9-Aug-05	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	0.994	0.0754	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Sep-05	1.2	ND<1	2.0	ND<1	ND<1	ND<1	3.64	0.161	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.31	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Dec-05	ND<1	ND<1	2.9	ND<1	ND<1	ND<1	2.01	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Jan-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	2.36	0.0905	ND<1	ND<1	ND<1	4.9	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	14-Feb-06	2.1	ND<1	1.8	ND<1	ND<1	ND<1	5.23	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	7-Mar-06	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.41	0.333	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Apr-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	1.93	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.054	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	21-June-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.095	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0185	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND<0.02	ND<1	ND<1	ND<1	18	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
24-Oct-06	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	6.96	0.00719	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
28-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.54	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
10-Jan-07	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	5.08	0.0855	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.96	0.0076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	8.03	0.399	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
25-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.888	0.04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.99	0.0227	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.39	0.0250	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.33	0.4040	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		

ND: Not detected  
 4#: Less than method detection limit  
 ug/L: Micrograms per liter  
 Not analyzed  
 ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site  
 Bold values indicate an exceedance of the ARAR standard established for the site


PCE: Tetrachloroethylene  
 TCE: Trichloroethene  
 TCA: 1,1,1-trichloroethane  
 1,1-DCE: 1,1-Dichloroethane  
 1,2-DCE: 1,2-Dichloroethane  
 MTBE: Methyl tertiary Butyl Ether  
 NM: Not Measured

NE indicates that the ARAR goal was not established for this compound by the EPA  
 \*Concentrations with an asterisk following them are due to laboratory contamination.  
 † RW-9 is currently non operational weighting for the reprogramming of the drive for the new 4 amp pump;  
 ‡ RW-9 was being rehabilitated during this sampling event, thus no water sample was collected.

## **GRAPHS**


**GRAPH 1**  
**GROUND-WATER REMEDIAL ACTION**  
**ROWE INDUSTRIES SUPERFUND SITE**  
**SAG HARBOR, NEW YORK**

**EFFLUENT FLOW DATA**  
 (September 1, 2007 through September 30, 2007)




Legend:  
 - Daily Flow Total (Blue line with diamond markers)  
 - Max Allowable (1,023,000 gpd) (Horizontal pink line)

**GRAPH 2**  
**GROUND-WATER REMEDIAL ACTION**  
**ROWE INDUSTRIES SUPERFUND SITE**  
**SAG HARBOR, NEW YORK**



**GRAPH 3**  
 GROUND-WATER REMEDIAL ACTION  
 ROWE INDUSTRIES SUPERFUND SITE  
 SAG HARBOR, NEW YORK





**APPENDIX I**  
**SEPTEMBER 2007 LABORATORY ANALYTICAL REPORTS**

Thursday, September 13, 2007 (pm)

Mark Goldberg  
Leggette Brashears & Graham Inc.  
4 Research Drive  
Suite 301  
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Industries, 1668 Sag Harbor Tpke, Sa

Order No.: 0709077

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 9/12/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at [lbeyer@american-analytical.com](mailto:lbeyer@american-analytical.com).

Sincerely,

  
Lori Beyer  
Lab Director

**CLIENT:** Leggette Brashears & Graham Inc.  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha  
**Lab Order:** 0709077

**Work Order Sample Summary**

---

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Tag Number</b>	<b>Date Collected</b>	<b>Date Received</b>
0709077-01A	WQ090607:1000NP2-6		9/6/2007 10:00:00 AM	9/12/2007
0709077-01B	WQ090607:1000NP2-6		9/6/2007 10:00:00 AM	9/12/2007
0709077-01C	WQ090607:1000NP2-6		9/6/2007 10:00:00 AM	9/12/2007
0709077-02A	WQ090607:1005NP2-7		9/6/2007 10:05:00 AM	9/12/2007
0709077-02B	WQ090607:1005NP2-7		9/6/2007 10:05:00 AM	9/12/2007
0709077-02C	WQ090607:1005NP2-7		9/6/2007 10:05:00 AM	9/12/2007
0709077-03A	WQ090607:1010NP2-10		9/6/2007 10:10:00 AM	9/12/2007
0709077-03B	WQ090607:1010NP2-10		9/6/2007 10:10:00 AM	9/12/2007
0709077-03C	WQ090607:1010NP2-10		9/6/2007 10:10:00 AM	9/12/2007

# CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS  
 LBG Inc.  
 4 Research Dr Suite 301  
 Shelton, Ct 06484

CONTACT: Mark Goldberg  
 mgoldberg@lbgct.com

SAMPLER (SIGNATURE)  


SAMPLER NAME (PRINT)  
 MARK GOLDBERG

SAMPLE(S) SEALED  YES  NO

CORRECT CONTAINER(S)  YES  NO

PROJECT LOCATION:  
 Route 1668 Sag Harbor TPSE Sag Harbor, NY

ANALYSIS REQUIRED:  8260  TDS  FORMALIN  METALS



FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)

LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	8260	TDS	FORMALIN	METALS
c709077-01ADL	L	4	9/16/07 1006	WQ090607.1000 NP2-6	X	X	X	X	X
-03ABC	L	4	" 1005	WQ090607.1005 NP2-7	X	X	X	X	X
-03ABC	L	5	" 1010	WQ090607.1010 NP2-10	X	X	X	X	X

COOLER TEMPERATURE: \_\_\_\_\_

COMMENTS / INSTRUCTIONS: \_\_\_\_\_

TURNAROUND REQUIRED:  NORMAL  STAT BY / /

RELINQUISHED BY (SIGNATURE)	DATE/TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE/TIME	PRINTED NAME
	09/16/07 17:00	Kithi Deank		9/16/07 1000	Gary Splich
RELINQUISHED BY (SIGNATURE)	DATE/TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE/TIME	PRINTED NAME

**AMERICAN ANALYTICAL LABORATORIES, LLC**

**56 TOLEDO STREET**

**FARMINGDALE, NEW YORK 11735**

**TELEPHONE: (631) 454-6100      FAX: (631) 454-8027**

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: <ol style="list-style-type: none"><li>(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)</li><li>(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.</li></ol>
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

# American Analytical Laboratories, LLC.

Date: 13-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ090607:1000NP2-6
<b>Lab Order:</b>	0709077	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/6/2007 10:00:00 AM
<b>Lab ID:</b>	0709077-01A	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,1,1-Trichloroethane	2.3	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
2-Butanone	U	3.0		µg/L	1	9/12/2007 6:05:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
2-Hexanone	U	2.0		µg/L	1	9/12/2007 6:05:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/12/2007 6:05:00 PM
Acetone	U	2.0		µg/L	1	9/12/2007 6:05:00 PM
Benzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Bromobenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Bromoform	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Bromomethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 13-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc. **Client Sample ID:** WQ090607:1000NP2-6  
**Lab Order:** 0709077 **Tag Number:**  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha **Collection Date:** 9/6/2007 10:00:00 AM  
**Lab ID:** 0709077-01A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Chloroform	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Chloromethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Dibromomethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/12/2007 6:05:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Methylene chloride	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Naphthalene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
o-Xylene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Styrene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Tetrachloroethene	1.8	1.0		µg/L	1	9/12/2007 6:05:00 PM
Toluene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Trichloroethene	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/12/2007 6:05:00 PM
Surr: 4-Bromofluorobenzene	103	54-134		%REC	1	9/12/2007 6:05:00 PM
Surr: Dibromofluoromethane	121	52-132		%REC	1	9/12/2007 6:05:00 PM
Surr: Toluene-d8	99.3	51-127		%REC	1	9/12/2007 6:05:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 13-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ090607:1000NP2-6
<b>Lab Order:</b>	0709077	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/6/2007 10:00:00 AM
<b>Lab ID:</b>	0709077-01B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	8.53	0.0200		mg/L	1	9/13/2007 10:48:53 AM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 13-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ090607:1000NP2-6
<b>Lab Order:</b>	0709077	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/6/2007 10:00:00 AM
<b>Lab ID:</b>	0709077-01C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.104	0.0200		mg/L	1	9/13/2007 10:46:52 AM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

# American Analytical Laboratories, LLC.

Date: 13-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc. **Client Sample ID:** WQ090607:1005NP2-7  
**Lab Order:** 0709077 **Tag Number:**  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha **Collection Date:** 9/6/2007 10:05:00 AM  
**Lab ID:** 0709077-02A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
2-Butanone	U	3.0		µg/L	1	9/12/2007 6:45:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
2-Hexanone	U	2.0		µg/L	1	9/12/2007 6:45:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/12/2007 6:45:00 PM
Acetone	U	2.0		µg/L	1	9/12/2007 6:45:00 PM
Benzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Bromobenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Bromoform	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Bromomethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

# American Analytical Laboratories, LLC.

Date: 13-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ090607:1005NP2-7
<b>Lab Order:</b>	0709077	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/6/2007 10:05:00 AM
<b>Lab ID:</b>	0709077-02A	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Chloroform	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Chloromethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Dibromomethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/12/2007 6:45:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Methylene chloride	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Naphthalene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
o-Xylene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Styrene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Toluene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Trichloroethene	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/12/2007 6:45:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	9/12/2007 6:45:00 PM
Surr: Dibromofluoromethane	104	52-132		%REC	1	9/12/2007 6:45:00 PM
Surr: Toluene-d8	95.3	51-127		%REC	1	9/12/2007 6:45:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 13-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ090607:1005NP2-7
<b>Lab Order:</b>	0709077	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/6/2007 10:05:00 AM
<b>Lab ID:</b>	0709077-02B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.49	0.0200		mg/L	1	9/13/2007 10:52:06 AM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 13-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ090607:1005NP2-7
<b>Lab Order:</b>	0709077	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/6/2007 10:05:00 AM
<b>Lab ID:</b>	0709077-02C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.115	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 9/13/2007 10:50:30 AM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

# American Analytical Laboratories, LLC.

Date: 13-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc. **Client Sample ID:** WQ090607:1010NP2-10  
**Lab Order:** 0709077 **Tag Number:**  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha **Collection Date:** 9/6/2007 10:10:00 AM  
**Lab ID:** 0709077-03A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
2-Butanone	U	3.0		µg/L	1	9/12/2007 5:26:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
2-Hexanone	U	2.0		µg/L	1	9/12/2007 5:26:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/12/2007 5:26:00 PM
Acetone	U	2.0		µg/L	1	9/12/2007 5:26:00 PM
Benzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Bromobenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Bromoform	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Bromomethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 13-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc. **Client Sample ID:** WQ090607:1010NP2-10  
**Lab Order:** 0709077 **Tag Number:**  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha **Collection Date:** 9/6/2007 10:10:00 AM  
**Lab ID:** 0709077-03A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>						
		<b>SW8260B</b>				<b>Analyst: LDS</b>
Chloroethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Chloroform	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Chloromethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Dibromomethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/12/2007 5:26:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Methylene chloride	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Naphthalene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
o-Xylene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Styrene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Toluene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Trichloroethene	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/12/2007 5:26:00 PM
Surr: 4-Bromofluorobenzene	108	54-134		%REC	1	9/12/2007 5:26:00 PM
Surr: Dibromofluoromethane	120	52-132		%REC	1	9/12/2007 5:26:00 PM
Surr: Toluene-d8	97.9	51-127		%REC	1	9/12/2007 5:26:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 13-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ090607:1010NP2-10
<b>Lab Order:</b>	0709077	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/6/2007 10:10:00 AM
<b>Lab ID:</b>	0709077-03B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	0.182	0.0200		mg/L	1	9/13/2007 10:55:18 AM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level




**American Analytical Laboratories, LLC.**

Date: 13-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ090607:1010NP2-10
<b>Lab Order:</b>	0709077	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/6/2007 10:10:00 AM
<b>Lab ID:</b>	0709077-03C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	0.145	0.0200		mg/L	1	9/13/2007 10:53:42 AM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	140	1.00		mg/L	1	9/13/2007

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Tuesday, September 18, 2007 

Mark Goldberg  
Leggette Brashears & Graham Inc.  
4 Research Drive  
Suite 301  
Shelton, CT 06484

TEL: (203) 929-8555  
FAX (203) 926-9140

RE: Rowe Industries, 1668 Sag Harbor Tpke, Sa

Order No.: 0709111

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 9/14/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer  
Lab Director

---

**CLIENT:** Leggette Brashears & Graham Inc.  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha  
**Lab Order:** 0709111

---

**Work Order Sample Summary**

---

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Tag Number</b>	<b>Date Collected</b>	<b>Date Received</b>
0709111-01A	WQ091207:900NP2-6		9/12/2007 9:00:00 AM	9/14/2007
0709111-01B	WQ091207:900NP2-6		9/12/2007 9:00:00 AM	9/14/2007
0709111-01C	WQ091207:900NP2-6		9/12/2007 9:00:00 AM	9/14/2007
0709111-02A	WQ091207:905NP2-7		9/12/2007 9:05:00 AM	9/14/2007
0709111-02B	WQ091207:905NP2-7		9/12/2007 9:05:00 AM	9/14/2007
0709111-02C	WQ091207:905NP2-7		9/12/2007 9:05:00 AM	9/14/2007
0709111-03A	WQ091207:910NP2-10		9/12/2007 9:10:00 AM	9/14/2007
0709111-03B	WQ091207:910NP2-10		9/12/2007 9:10:00 AM	9/14/2007
0709111-03C	WQ091207:910NP2-10		9/12/2007 9:10:00 AM	9/14/2007

---

# CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS  
LGB Inc.  
4 Research Dr. Suite 301  
SHELTON, CT 06484

CONTACT:  
Mark Goldberg

SAMPLER (SIGNATURE)  
*Mark Goldberg*

CORRECT CONTAINER(S)  
YES NO  
YES NO

PROJECT LOCATION:  
1668 Sag Harbor TPK Sag Harbor, NY.

LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
0769111-01ABC	W	4	9/12/07 900	W0891207: 900 NP2-6	X X X X	
-02ABC	W	4	905	905 NP2-7	X X X X	
-03ABC	W	5	910	910 NP2-10	X X X X X	

COOLER TEMPERATURE:

MATRIX	TYPE	RELINQUISHED BY (SIGNATURE)	DATE/TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE/TIME	PRINTED NAME	COMMENTS / INSTRUCTIONS
S-SOIL; L-LIQUID; SL-SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL	G=GRAB; C=COMPOSITE, SS=SPLIT SPOON	<i>Kithi Deak</i>	09/13/07 17:00	Kithi Deak	<i>[Signature]</i>	9/14/07 1645	Gary Zpich	

**AMERICAN ANALYTICAL LABORATORIES, LLC**  
**56 TOLEDO STREET**  
**FARMINGDALE, NEW YORK 11735**  
**TELEPHONE: (631) 454-6100      FAX: (631) 454-8027**

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: <ol style="list-style-type: none"><li>(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)</li><li>(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.</li></ol>
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc. **Client Sample ID:** WQ091207:900NP2-6  
**Lab Order:** 0709111 **Tag Number:**  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha **Collection Date:** 9/12/2007 9:00:00 AM  
**Lab ID:** 0709111-01A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		<b>Analyst: LDS</b>		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,1,1-Trichloroethane	2.6	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 4:03:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 4:03:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 4:03:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 4:03:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM

**Qualifiers:** B Analyte detected in the associated Method Blank E Value above quantitation range  
 H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits  
 ND Not Detected at the Reporting Limit S Spike Recovery outside accepted recovery limits  
 U Indicates the compound was analyzed for but not detected X Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc. **Client Sample ID:** WQ091207:900NP2-6  
**Lab Order:** 0709111 **Tag Number:**  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha **Collection Date:** 9/12/2007 9:00:00 AM  
**Lab ID:** 0709111-01A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		<b>Analyst: LDS</b>		
Chloroethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 4:03:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Tetrachloroethene	5.3	1.0		µg/L	1	9/14/2007 4:03:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 4:03:00 PM
Surr: 4-Bromofluorobenzene	103	54-134		%REC	1	9/14/2007 4:03:00 PM
Surr: Dibromofluoromethane	94.9	52-132		%REC	1	9/14/2007 4:03:00 PM
Surr: Toluene-d8	91.0	51-127		%REC	1	9/14/2007 4:03:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ091207:900NP2-6
<b>Lab Order:</b>	0709111	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/12/2007 9:00:00 AM
<b>Lab ID:</b>	0709111-01B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	59.0	0.0200		mg/L	1	9/17/2007 12:24:12 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ091207:900NP2-6
<b>Lab Order:</b>	0709111	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/12/2007 9:00:00 AM
<b>Lab ID:</b>	0709111-01C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0230	0.0200		mg/L	1	9/17/2007 12:22:34 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

CLIENT: Leggette Brashears & Graham Inc. Client Sample ID: WQ091207:905NP2-7  
 Lab Order: 0709111 Tag Number:  
 Project: Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha Collection Date: 9/12/2007 9:05:00 AM  
 Lab ID: 0709111-02A Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 6:31:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 6:31:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 6:31:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 6:31:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM

Qualifiers: B Analyte detected in the associated Method Blank E Value above quantitation range  
 H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits  
 ND Not Detected at the Reporting Limit S Spike Recovery outside accepted recovery limits  
 U Indicates the compound was analyzed for but not detected X Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc. **Client Sample ID:** WQ091207:905NP2-7  
**Lab Order:** 0709111 **Tag Number:**  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha **Collection Date:** 9/12/2007 9:05:00 AM  
**Lab ID:** 0709111-02A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 6:31:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 6:31:00 PM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	9/14/2007 6:31:00 PM
Surr: Dibromofluoromethane	94.1	52-132		%REC	1	9/14/2007 6:31:00 PM
Surr: Toluene-d8	93.5	51-127		%REC	1	9/14/2007 6:31:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ091207:905NP2-7
<b>Lab Order:</b>	0709111	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/12/2007 9:05:00 AM
<b>Lab ID:</b>	0709111-02B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	40.4	0.0200		mg/L	1	9/17/2007 12:27:25 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ091207:905NP2-7
<b>Lab Order:</b>	0709111	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/12/2007 9:05:00 AM
<b>Lab ID:</b>	0709111-02C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.361	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 9/17/2007 12:25:48 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc. **Client Sample ID:** WQ091207:910NP2-10  
**Lab Order:** 0709111 **Tag Number:**  
**Project:** Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha **Collection Date:** 9/12/2007 9:10:00 AM  
**Lab ID:** 0709111-03A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		<b>Analyst: LDS</b>		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 7:21:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 7:21:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 7:21:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 7:21:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM

**Qualifiers:** B Analyte detected in the associated Method Blank E Value above quantitation range  
H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit S Spike Recovery outside accepted recovery limits  
U Indicates the compound was analyzed for but not detected X Value exceeds Maximum Contaminant Level

# American Analytical Laboratories, LLC.

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ091207:910NP2-10
<b>Lab Order:</b>	0709111	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/12/2007 9:10:00 AM
<b>Lab ID:</b>	0709111-03A	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 7:21:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 7:21:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	9/14/2007 7:21:00 PM
Surr: Dibromofluoromethane	94.0	52-132		%REC	1	9/14/2007 7:21:00 PM
Surr: Toluene-d8	93.8	51-127		%REC	1	9/14/2007 7:21:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

# American Analytical Laboratories, LLC.

Date: 18-Sep-07

---

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ091207:910NP2-10
<b>Lab Order:</b>	0709111	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/12/2007 9:10:00 AM
<b>Lab ID:</b>	0709111-03B	<b>Matrix:</b>	LIQUID

---

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	66.0	0.0200		mg/L	1	9/17/2007 12:30:37 PM

---

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ091207:910NP2-10
<b>Lab Order:</b>	0709111	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, 1668 Sag Harbor Tpke, Sag Ha	<b>Collection Date:</b>	9/12/2007 9:10:00 AM
<b>Lab ID:</b>	0709111-03C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON</b>		<b>E200.7</b>		<b>SW3005A</b>		Analyst: <b>JP</b>
Iron	0.529	0.0200		mg/L	1	9/17/2007 12:29:01 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: <b>SAP</b>
Total Dissolved Solids (Residue, Filterable)	58.0	1.00		mg/L	1	9/17/2007

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Wednesday, September 26, 2007 <sup>(pm)</sup>

Mark Goldberg  
Leggette Brashears & Graham Inc.  
4 Research Drive  
Suite 301  
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: 1668 Sag Harbor Tpke, Sag Harbor, NY

Order No.: 0709181

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 9/21/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at [lbeyer@american-analytical.com](mailto:lbeyer@american-analytical.com).

Sincerely,

  
Lori Beyer  
Lab Director

**CLIENT:** Leggette Brashears & Graham Inc.  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab Order:** 0709181

**Work Order Sample Summary**

---

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Tag Number</b>	<b>Date Collected</b>	<b>Date Received</b>
0709181-01A	WQ091807:1000NP2-6		9/18/2007 10:00:00 AM	9/21/2007
0709181-01B	WQ091807:1000NP2-6		9/18/2007 10:00:00 AM	9/21/2007
0709181-01C	WQ091807:1000NP2-6		9/18/2007 10:00:00 AM	9/21/2007
0709181-02A	WQ091807:1005NP2-7		9/18/2007 10:05:00 AM	9/21/2007
0709181-02B	WQ091807:1005NP2-7		9/18/2007 10:05:00 AM	9/21/2007
0709181-02C	WQ091807:1005NP2-7		9/18/2007 10:05:00 AM	9/21/2007
0709181-03A	WQ091807:1010NP2-10		9/18/2007 10:10:00 AM	9/21/2007
0709181-03B	WQ091807:1010NP2-10		9/18/2007 10:10:00 AM	9/21/2007
0709181-03C	WQ091807:1010NP2-10		9/18/2007 10:10:00 AM	9/21/2007



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735  
(631) 454-6100 • FAX (631) 454-8027

NYSDOH 11418  
CTDOH PH-0205  
NJDEP NY050  
PADEP 68-573

TAG # / COC \_\_\_\_\_

# CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <b>LBG Inc.</b> 4 Research dr. Suite 301 Shelton, Ct 06484		CONTACT: <b>Mark Goldberg</b>		SAMPLER (SIGNATURE) <i>[Signature]</i>	SAMPLE(S) SEALED <b>YES/NO</b>
PROJECT LOCATION: <b>1668 Sag Harbor Take Bag Harbor NY</b>				SAMPLER NAME (PRINT) <b>EVAN FOSTER</b>	CORRECT CONTAINER(S) <b>YES/NO</b>
LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
0709181-01ABC	L	4	9/18/07 1000	W0091807:1000 NP2-6	
-02ABC	L	4	1005	W0091807:1005 NP2-7	
-03ABC	L	5	1010	W0091807:1010 NP2-10	

ANALYSIS REQUIRED  
8260  
MTBF  
FROM 113  
TDS  
FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)

COOLER TEMPERATURE:

COMMENTS / INSTRUCTIONS

TURNAROUND REQUIRED:  
NORMAL  STAT  BY / /

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL  
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

RELINQUISHED BY (SIGNATURE) <i>Mark M. Goldberg</i>	DATE 9/18/07 TIME 1700	PRINTED NAME <i>Mark M. Goldberg</i>	RECEIVED BY LAB (SIGNATURE) <i>[Signature]</i>	DATE 9/20/07 TIME 1022	PRINTED NAME <i>Gary Eppich</i>
RELINQUISHED BY (SIGNATURE)	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME

**AMERICAN ANALYTICAL LABORATORIES, LLC**

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: <ol style="list-style-type: none"><li>(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)</li><li>(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.</li></ol>
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

# American Analytical Laboratories, LLC.

Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-01A

**Client Sample ID:** WQ091807:1000NP2-6  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:00:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,1,1-Trichloroethane	2.0	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
2-Butanone	U	3.0		µg/L	1	9/21/2007 9:33:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
2-Hexanone	U	2.0		µg/L	1	9/21/2007 9:33:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/21/2007 9:33:00 PM
Acetone	U	2.0		µg/L	1	9/21/2007 9:33:00 PM
Benzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Bromobenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Bromoform	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Bromomethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-01A

**Client Sample ID:** WQ091807:1000NP2-6  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:00:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Chloroform	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Chloromethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Dibromomethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/21/2007 9:33:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Methylene chloride	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Naphthalene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
o-Xylene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Styrene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Tetrachloroethene	6.8	1.0		µg/L	1	9/21/2007 9:33:00 PM
Toluene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Trichloroethene	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/21/2007 9:33:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	9/21/2007 9:33:00 PM
Surr: Dibromofluoromethane	89.9	52-132		%REC	1	9/21/2007 9:33:00 PM
Surr: Toluene-d8	92.6	51-127		%REC	1	9/21/2007 9:33:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 26-Sep-07

---

**CLIENT:** Leggette Brashears & Graham Inc. **Client Sample ID:** WQ091807:1000NP2-6  
**Lab Order:** 0709181 **Tag Number:**  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY **Collection Date:** 9/18/2007 10:00:00 AM  
**Lab ID:** 0709181-01B **Matrix:** LIQUID

---

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	8.91	0.0200		mg/L	1	9/21/2007 1:36:42 PM

---

**Qualifiers:** B Analyte detected in the associated Method Blank E Value above quantitation range  
H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits  
ND Not Detected at the Reporting Limit S Spike Recovery outside accepted recovery limits  
U Indicates the compound was analyzed for but not detected X Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-01C

**Client Sample ID:** WQ091807:1000NP2-6  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:00:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	1.05	0.0200		mg/L	1	9/21/2007 1:29:26 PM

Qualifiers:					
B	Analyte detected in the associated Method Blank	E	Value above quantitation range		
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits		
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits		
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level		

# American Analytical Laboratories, LLC.

Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-02A

**Client Sample ID:** WQ091807:1005NP2-7  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:05:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
2-Butanone	U	3.0		µg/L	1	9/21/2007 9:58:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
2-Hexanone	U	2.0		µg/L	1	9/21/2007 9:58:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
4-isopropyltoluene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/21/2007 9:58:00 PM
Acetone	U	2.0		µg/L	1	9/21/2007 9:58:00 PM
Benzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Bromobenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Bromoform	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Bromomethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

# American Analytical Laboratories, LLC.

Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-02A

**Client Sample ID:** WQ091807:1005NP2-7  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:05:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Chloroform	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Chloromethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Dibromomethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/21/2007 9:58:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Methylene chloride	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Naphthalene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
o-Xylene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Styrene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Toluene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Trichloroethene	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/21/2007 9:58:00 PM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	9/21/2007 9:58:00 PM
Surr: Dibromofluoromethane	92.9	52-132		%REC	1	9/21/2007 9:58:00 PM
Surr: Toluene-d8	94.2	51-127		%REC	1	9/21/2007 9:58:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 26-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ091807:1005NP2-7
<b>Lab Order:</b>	0709181	<b>Tag Number:</b>	
<b>Project:</b>	1668 Sag Harbor Tpke, Sag Harbor, NY	<b>Collection Date:</b>	9/18/2007 10:05:00 AM
<b>Lab ID:</b>	0709181-02B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	8.35	0.0200		mg/L	1	9/21/2007 1:39:56 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-02C

**Client Sample ID:** WQ091807:1005NP2-7  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:05:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	1.33	0.0200		mg/L	1	9/21/2007 1:38:19 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-03A

**Client Sample ID:** WQ091807:1010NP2-10  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:10:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
2-Butanone	U	3.0		µg/L	1	9/21/2007 10:22:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
2-Hexanone	U	2.0		µg/L	1	9/21/2007 10:22:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/21/2007 10:22:00 PM
Acetone	U	2.0		µg/L	1	9/21/2007 10:22:00 PM
Benzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Bromobenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Bromofom	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Bromomethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

# American Analytical Laboratories, LLC.

Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-03A

**Client Sample ID:** WQ091807:1010NP2-10  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:10:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>				Analyst: LDS
Chloroethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Chloroform	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Chloromethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Dibromomethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/21/2007 10:22:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Methylene chloride	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Naphthalene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
o-Xylene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Styrene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Toluene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Trichloroethene	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/21/2007 10:22:00 PM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	9/21/2007 10:22:00 PM
Surr: Dibromofluoromethane	93.4	52-132		%REC	1	9/21/2007 10:22:00 PM
Surr: Toluene-d8	94.2	51-127		%REC	1	9/21/2007 10:22:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-03B

**Client Sample ID:** WQ091807:1010NP2-10  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:10:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	8.21	0.0200		mg/L	1	9/21/2007 1:43:08 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**


Date: 26-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709181  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709181-03C

**Client Sample ID:** WQ091807:1010NP2-10  
**Tag Number:**  
**Collection Date:** 9/18/2007 10:10:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON</b> Iron	1.25	E200.7 0.0200		mg/L	1	Analyst: JP 9/21/2007 1:41:32 PM
<b>TOTAL DISSOLVED SOLIDS</b> Total Dissolved Solids (Residue, Filterable)	138	E160.1 1.00		mg/L	1	Analyst: SAP 9/24/2007

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Wednesday, October 03, 2007 

Mark Goldberg  
Leggette Brashears & Graham Inc.  
4 Research Drive  
Suite 301  
Shelton, CT 06484

TEL: (203) 929-8555  
FAX (203) 926-9140

RE: 1668 Sag Harbor Tpke, Sag Harbor, NY

Order No.: 0709239

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 9/28/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at [lbeyer@american-analytical.com](mailto:lbeyer@american-analytical.com).

Sincerely,

  
Lori Beyer  
Lab Director

**CLIENT:** Leggette Brashears & Graham Inc.  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab Order:** 0709239

**Work Order Sample Summary**

---

<b>Lab Sample ID</b>	<b>Client Sample ID</b>	<b>Tag Number</b>	<b>Date Collected</b>	<b>Date Received</b>
0709239-01A	WQ092607:900NP2-6		9/26/2007 9:00:00 AM	9/28/2007
0709239-01B	WQ092607:900NP2-6		9/26/2007 9:00:00 AM	9/28/2007
0709239-01C	WQ092607:900NP2-6		9/26/2007 9:00:00 AM	9/28/2007
0709239-02A	WQ092607:905NP2-7		9/26/2007 9:05:00 AM	9/28/2007
0709239-02B	WQ092607:905NP2-7		9/26/2007 9:05:00 AM	9/28/2007
0709239-02C	WQ092607:905NP2-7		9/26/2007 9:05:00 AM	9/28/2007
0709239-03A	WQ092607:910NP2-10		9/26/2007 9:10:00 AM	9/28/2007
0709239-03B	WQ092607:910NP2-10		9/26/2007 9:10:00 AM	9/28/2007
0709239-03C	WQ092607:910NP2-10		9/26/2007 9:10:00 AM	9/28/2007

TAG # / COC 10315

# CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS: **LSG**  
**H Research Dr.**  
**Shelton, CT**

CONTACT: **Mark Goldberg**

SAMPLER(S) SEALED: **(YES) / NO**

CORRECT CONTAINER(S): **(YES) / NO**

SAMPLER (SIGNATURE): *Rob Drew*

SAMPLER NAME (PRINT): **Rob Drew**

PROJECT LOCATION: **Rowe**

LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	HTBE	Tot + Dis	TDS	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
0709237-01A04	W	4	9/26-07 9:00	WQ 092607: 900 NP2-6	✓	✓	✓	✓	
-02A9C	↓	4	9:05	:905 NP2-7	✓	✓	✓		
-03A9C	↓	5	9:10	:910 NP2-10	✓	✓	✓		

RELINQUISHED BY (SIGNATURE) <i>Kathi Bell</i>		DATE TIME 9/27/07 17:00	PRINTED NAME <b>Kathi Deak</b>	RECEIVED BY LAB (SIGNATURE) <i>[Signature]</i>		DATE TIME 9/28/07 1605	PRINTED NAME <b>Gary Eppich</b>
RELINQUISHED BY (SIGNATURE)		DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)		DATE TIME	PRINTED NAME

TURNAROUND REQUIRED:  NORMAL  STAT BY / /

COOLER TEMPERATURE:

COMMENTS / INSTRUCTIONS

**AMERICAN ANALYTICAL LABORATORIES, LLC**  
56 TOLEDO STREET  
FARMINGDALE, NEW YORK 11735  
TELEPHONE: (631) 454-6100      FAX: (631) 454-8027

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: <ol style="list-style-type: none"><li>(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)</li><li>(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.</li></ol>
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709239  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709239-01A

**Client Sample ID:** WQ092607:900NP2-6  
**Tag Number:**  
**Collection Date:** 9/26/2007 9:00:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,1,1-Trichloroethane	1.9	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
2-Butanone	U	3.0		µg/L	1	9/28/2007 10:03:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
2-Hexanone	U	2.0		µg/L	1	9/28/2007 10:03:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/28/2007 10:03:00 PM
Acetone	U	2.0		µg/L	1	9/28/2007 10:03:00 PM
Benzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Bromobenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Bromoform	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Bromomethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709239  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709239-01A

**Client Sample ID:** WQ092607:900NP2-6  
**Tag Number:**  
**Collection Date:** 9/26/2007 9:00:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Chloroform	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Chloromethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Dibromomethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/28/2007 10:03:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Methylene chloride	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Naphthalene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
o-Xylene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Styrene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Tetrachloroethene	5.5	1.0		µg/L	1	9/28/2007 10:03:00 PM
Toluene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Trichloroethene	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/28/2007 10:03:00 PM
Surr: 4-Bromofluorobenzene	98.1	54-134		%REC	1	9/28/2007 10:03:00 PM
Surr: Dibromofluoromethane	105	52-132		%REC	1	9/28/2007 10:03:00 PM
Surr: Toluene-d8	94.0	51-127		%REC	1	9/28/2007 10:03:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

---

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ092607:900NP2-6
<b>Lab Order:</b>	0709239	<b>Tag Number:</b>	
<b>Project:</b>	1668 Sag Harbor Tpke, Sag Harbor, NY	<b>Collection Date:</b>	9/26/2007 9:00:00 AM
<b>Lab ID:</b>	0709239-01B	<b>Matrix:</b>	LIQUID

---

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	4.92	0.0200		mg/L	1	10/1/2007 11:56:03 AM

---

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709239  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709239-01C

**Client Sample ID:** WQ092607:900NP2-6  
**Tag Number:**  
**Collection Date:** 9/26/2007 9:00:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.107	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 10/1/2007 11:54:15 AM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709239  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709239-02A

**Client Sample ID:** WQ092607:905NP2-7  
**Tag Number:**  
**Collection Date:** 9/26/2007 9:05:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		<b>Analyst: LDS</b>		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
2-Butanone	U	3.0		µg/L	1	9/28/2007 10:41:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
2-Hexanone	U	2.0		µg/L	1	9/28/2007 10:41:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/28/2007 10:41:00 PM
Acetone	U	2.0		µg/L	1	9/28/2007 10:41:00 PM
Benzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Bromobenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Bromoform	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Bromomethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709239  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709239-02A

**Client Sample ID:** WQ092607:905NP2-7  
**Tag Number:**  
**Collection Date:** 9/26/2007 9:05:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		<b>Analyst: LDS</b>		
Chloroethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Chloroform	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Chloromethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Dibromomethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/28/2007 10:41:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Methylene chloride	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Naphthalene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
o-Xylene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Styrene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Toluene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Trichloroethene	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/28/2007 10:41:00 PM
Surr: 4-Bromofluorobenzene	98.9	54-134		%REC	1	9/28/2007 10:41:00 PM
Surr: Dibromofluoromethane	105	52-132		%REC	1	9/28/2007 10:41:00 PM
Surr: Toluene-d8	94.6	51-127		%REC	1	9/28/2007 10:41:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709239  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709239-02B

**Client Sample ID:** WQ092607:905NP2-7  
**Tag Number:**  
**Collection Date:** 9/26/2007 9:05:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	12.6	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 10/1/2007 12:04:09 PM

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709239  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709239-02C

**Client Sample ID:** WQ092607:905NP2-7  
**Tag Number:**  
**Collection Date:** 9/26/2007 9:05:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.174	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 10/1/2007 12:02:21 PM

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709239  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709239-03A

**Client Sample ID:** WQ092607:910NP2-10  
**Tag Number:**  
**Collection Date:** 9/26/2007 9:10:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>						
		<b>SW8260B</b>				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
2-Butanone	U	3.0		µg/L	1	9/28/2007 11:18:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
2-Hexanone	U	2.0		µg/L	1	9/28/2007 11:18:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/28/2007 11:18:00 PM
Acetone	U	2.0		µg/L	1	9/28/2007 11:18:00 PM
Benzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Bromobenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Bromoform	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Bromomethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709239  
**Project:** 1668 Sag Harbor Tpke, Sag Harbor, NY  
**Lab ID:** 0709239-03A

**Client Sample ID:** WQ092607:910NP2-10  
**Tag Number:**  
**Collection Date:** 9/26/2007 9:10:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		<b>Analyst: LDS</b>		
Chloroethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Chloroform	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Chloromethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Dibromomethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/28/2007 11:18:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Methylene chloride	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Naphthalene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
o-Xylene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Styrene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Toluene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Trichloroethene	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/28/2007 11:18:00 PM
Surr: 4-Bromofluorobenzene	96.8	54-134		%REC	1	9/28/2007 11:18:00 PM
Surr: Dibromofluoromethane	114	52-132		%REC	1	9/28/2007 11:18:00 PM
Surr: Toluene-d8	96.9	51-127		%REC	1	9/28/2007 11:18:00 PM

Qualifiers:				
B	Analyte detected in the associated Method Blank	E	Value above quantitation range	
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits	
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits	
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level	

**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ092607:910NP2-10
<b>Lab Order:</b>	0709239	<b>Tag Number:</b>	
<b>Project:</b>	1668 Sag Harbor Tpke, Sag Harbor, NY	<b>Collection Date:</b>	9/26/2007 9:10:00 AM
<b>Lab ID:</b>	0709239-03B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.93	0.0200		mg/L	1	10/1/2007 12:07:46 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 03-Oct-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	WQ092607:910NP2-10
<b>Lab Order:</b>	0709239	<b>Tag Number:</b>	
<b>Project:</b>	1668 Sag Harbor Tpke, Sag Harbor, NY	<b>Collection Date:</b>	9/26/2007 9:10:00 AM
<b>Lab ID:</b>	0709239-03C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON</b>		<b>E200.7</b>		<b>SW3005A</b>		Analyst: JP
Iron	0.217	0.0200		mg/L	1	10/1/2007 12:05:58 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	108	1.00		mg/L	1	10/2/2007

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Tuesday, September 18, 2007 (pm)

Mark Goldberg  
Leggette Brashears & Graham Inc.  
4 Research Drive  
Suite 301  
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Industries, Sag Harbor, NY

Dear Mark Goldberg:

Order No.: 0709112

American Analytical Laboratories, LLC. received 8 sample(s) on 9/14/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at [lbeyer@american-analytical.com](mailto:lbeyer@american-analytical.com).

Sincerely,

  
Lori Beyer  
Lab Director

CLIENT: Leggette Brashears & Graham Inc.  
Project: Rowe Industries, Sag Harbor, NY  
Lab Order: 0709112

**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0709112-01A	GWQ091207:1000NP1-1-5		9/12/2007 10:00:00 AM	9/14/2007
0709112-01B	GWQ091207:1000NP1-1-5		9/12/2007 10:00:00 AM	9/14/2007
0709112-01C	GWQ091207:1000NP1-1-5		9/12/2007 10:00:00 AM	9/14/2007
0709112-02A	GWQ091207:1005NP1-1-6		9/12/2007 10:05:00 AM	9/14/2007
0709112-02B	GWQ091207:1005NP1-1-6		9/12/2007 10:05:00 AM	9/14/2007
0709112-02C	GWQ091207:1005NP1-1-6		9/12/2007 10:05:00 AM	9/14/2007
0709112-03A	GWQ091207:1010NP1-1-7		9/12/2007 10:10:00 AM	9/14/2007
0709112-03B	GWQ091207:1010NP1-1-7		9/12/2007 10:10:00 AM	9/14/2007
0709112-03C	GWQ091207:1010NP1-1-7		9/12/2007 10:10:00 AM	9/14/2007
0709112-04A	GWQ091207:1015NP1-1-8		9/12/2007 10:15:00 AM	9/14/2007
0709112-04B	GWQ091207:1015NP1-1-8		9/12/2007 10:15:00 AM	9/14/2007
0709112-04C	GWQ091207:1015NP1-1-8		9/12/2007 10:15:00 AM	9/14/2007
0709112-05A	GWQ091207:1020NP1-1-9		9/12/2007 10:20:00 AM	9/14/2007
0709112-05B	GWQ091207:1020NP1-1-9		9/12/2007 10:20:00 AM	9/14/2007
0709112-05C	GWQ091207:1020NP1-1-9		9/12/2007 10:20:00 AM	9/14/2007
0709112-06A	GWQ091207:1025NP1-1-4		9/12/2007 10:25:00 AM	9/14/2007
0709112-06B	GWQ091207:1025NP1-1-4		9/12/2007 10:25:00 AM	9/14/2007
0709112-06C	GWQ091207:1025NP1-1-4		9/12/2007 10:25:00 AM	9/14/2007
0709112-07A	GWQ091207:1030NP1-1-2		9/12/2007 10:30:00 AM	9/14/2007
0709112-07B	GWQ091207:1030NP1-1-2		9/12/2007 10:30:00 AM	9/14/2007
0709112-07C	GWQ091207:1030NP1-1-2		9/12/2007 10:30:00 AM	9/14/2007
0709112-08A	GWQ091207:1035NP1-1-3		9/12/2007 10:35:00 AM	9/14/2007
0709112-08B	GWQ091207:1035NP1-1-3		9/12/2007 10:35:00 AM	9/14/2007
0709112-08C	GWQ091207:1035NP1-1-3		9/12/2007 10:35:00 AM	9/14/2007



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735  
 (631) 454-6100 • FAX (631) 454-8027

NYSDOH 11418  
 CTDOH PH-0205  
 NJDEP NY050  
 PADEP 68-573

TAG # / COC 11184

# CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS: **LBG 4 Research Dr. Suite 301**  
 Shelton, Ct 06484

CONTACT: **MARK Goldberg**

SAMPLER (SIGNATURE): *[Signature]*

SAMPLER NAME (PRINT): **EVAN FOSTER**

SAMPLE(S) SEALED: **YES/NO**

CORRECT CONTAINER(S): **YES/NO**

PROJECT LOCATION: **1668 Sag Harbor TPK, Sag Harbor, NY**

LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
0709112-01ABC	W	5	9/12/07 1000	GW091207.1000 NPI-1-5	X	
-02ABC			1005	GW091207.1005 NPI-1-6		
-03ABC			1010	:1010 NPI-1-7		
-04ABC			1015	:1015 NPI-1-8		
-05ABC			1020	:1020 NPI-1-9		
-06ABC			1025	:1025 NPI-1-4		
-07ABC			1030	:1030 NPI-1-2		
-08ABC			1035	:1035 NPI-1-3		

COOLER TEMPERATURE:

COMMENTS / INSTRUCTIONS:

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIFE; P=PAINT CHIPS; B=BULK MATERIAL  
 TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

TURNAROUND REQUIRED: NORMAL  STAT  BY / /

RELINQUISHED BY (SIGNATURE): <i>[Signature]</i>	DATE/TIME: 05/13/07 17:00	PRINTED NAME: <b>Kitti Deak</b>	RECEIVED BY LAB (SIGNATURE): <i>[Signature]</i>	DATE/TIME: 9/14/07 1045	PRINTED NAME: <b>Gary Eppich</b>
RELINQUISHED BY (SIGNATURE):	DATE/TIME:	PRINTED NAME:	RECEIVED BY LAB (SIGNATURE):	DATE/TIME:	PRINTED NAME:

**AMERICAN ANALYTICAL LABORATORIES, LLC**

**56 TOLEDO STREET**

**FARMINGDALE, NEW YORK 11735**

**TELEPHONE: (631) 454-6100      FAX: (631) 454-8027**

**DATA REPORTING QUALIFIERS**

For reporting results, the following "Results Qualifiers" are used:

<b>Value</b>	If the result is greater than or equal to the detection limit, report the value
<b>U</b>	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
<b>J</b>	Indicates an estimated value. The flag is used: <ol style="list-style-type: none"><li>(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)</li><li>(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.</li></ol>
<b>B</b>	Indicates the analyte was found in the blank as well as the sample report "10B".
<b>E</b>	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
<b>D</b>	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
<b>P</b>	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
<b>N</b>	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
<b>H</b>	Indicates sample was received and/or analyzed outside of The method allowable holding time

# American Analytical Laboratories, LLC.

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-01A

**Client Sample ID:** GWQ091207:1000NP1-1-5  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:00:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>				Analyst: LDS
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 7:46:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 7:46:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 7:46:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 7:46:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-01A

**Client Sample ID:** GWQ091207:1000NP1-1-5  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:00:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Chloroform	0.60	1.0	J	µg/L	1	9/14/2007 7:46:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 7:46:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 7:46:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	9/14/2007 7:46:00 PM
Surr: Dibromofluoromethane	97.3	52-132		%REC	1	9/14/2007 7:46:00 PM
Surr: Toluene-d8	94.8	51-127		%REC	1	9/14/2007 7:46:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ091207:1000NP1-1-5
<b>Lab Order:</b>	0709112	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, Sag Harbor, NY	<b>Collection Date:</b>	9/12/2007 10:00:00 AM
<b>Lab ID:</b>	0709112-01B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	0.0460	0.0200		mg/L	1	9/17/2007 12:45:54 PM
Manganese	U	0.0200		mg/L	1	9/17/2007 12:45:54 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ091207:1000NP1-1-5
<b>Lab Order:</b>	0709112	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, Sag Harbor, NY	<b>Collection Date:</b>	9/12/2007 10:00:00 AM
<b>Lab ID:</b>	0709112-01C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3005A</b>		Analyst: JP
Iron	0.00800	0.0200	J	mg/L	1	9/17/2007 12:44:17 PM
Manganese	U	0.0200		mg/L	1	9/17/2007 12:44:17 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	186	1.00		mg/L	1	9/17/2007

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-02A

**Client Sample ID:** GWQ091207:1005NPI-1-6  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:05:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,1,1-Trichloroethane	7.0	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 8:10:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 8:10:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 8:10:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 8:10:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-02A

**Client Sample ID:** GWQ091207:1005NP1-1-6  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:05:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>				Analyst: LDS
Chloroethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 8:10:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Tetrachloroethene	21	1.0		µg/L	1	9/14/2007 8:10:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 8:10:00 PM
Surr: 4-Bromofluorobenzene	105	54-134		%REC	1	9/14/2007 8:10:00 PM
Surr: Dibromofluoromethane	94.0	52-132		%REC	1	9/14/2007 8:10:00 PM
Surr: Toluene-d8	94.0	51-127		%REC	1	9/14/2007 8:10:00 PM

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ091207:1005NP1-1-6
<b>Lab Order:</b>	0709112	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, Sag Harbor, NY	<b>Collection Date:</b>	9/12/2007 10:05:00 AM
<b>Lab ID:</b>	0709112-02B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	0.199	0.0200		mg/L	1	9/17/2007 12:49:07 PM
Manganese	0.248	0.0200		mg/L	1	9/17/2007 12:49:07 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ091207:1005NP1-1-6
<b>Lab Order:</b>	0709112	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, Sag Harbor, NY	<b>Collection Date:</b>	9/12/2007 10:05:00 AM
<b>Lab ID:</b>	0709112-02C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3005A</b>		Analyst: JP
Iron	0.0330	0.0200		mg/L	1	9/17/2007 12:47:30 PM
Manganese	0.227	0.0200		mg/L	1	9/17/2007 12:47:30 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	148	1.00		mg/L	1	9/17/2007

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-03A

**Client Sample ID:** GWQ091207:1010NP1-1-7  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:10:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,1,1-Trichloroethane	2.0	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,1-Dichloroethane	0.68	1.0	J	µg/L	1	9/14/2007 8:34:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 8:34:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 8:34:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 8:34:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 8:34:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-03A

**Client Sample ID:** GWQ091207:1010NP1-1-7  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:10:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 8:34:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Tetrachloroethene	24	1.0		µg/L	1	9/14/2007 8:34:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 8:34:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	9/14/2007 8:34:00 PM
Surr: Dibromofluoromethane	95.9	52-132		%REC	1	9/14/2007 8:34:00 PM
Surr: Toluene-d8	92.4	51-127		%REC	1	9/14/2007 8:34:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ091207:1010NP1-1-7
<b>Lab Order:</b>	0709112	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, Sag Harbor, NY	<b>Collection Date:</b>	9/12/2007 10:10:00 AM
<b>Lab ID:</b>	0709112-03B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	0.170	0.0200		mg/L	1	9/17/2007 12:52:20 PM
Manganese	0.0700	0.0200		mg/L	1	9/17/2007 12:52:20 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ091207:1010NPI-1-7
<b>Lab Order:</b>	0709112	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, Sag Harbor, NY	<b>Collection Date:</b>	9/12/2007 10:10:00 AM
<b>Lab ID:</b>	0709112-03C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3005A</b>		Analyst: JP
Iron	0.0800	0.0200		mg/L	1	9/17/2007 12:50:43 PM
Manganese	0.0700	0.0200		mg/L	1	9/17/2007 12:50:43 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	102	1.00		mg/L	1	9/17/2007

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-04A

**Client Sample ID:** GWQ091207:1015NP1-1-8  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:15:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,1,1-Trichloroethane	1.5	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 8:57:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 8:57:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 8:57:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 8:57:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-04A

**Client Sample ID:** GWQ091207:1015NP1-1-8  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:15:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 8:57:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 8:57:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	9/14/2007 8:57:00 PM
Surr: Dibromofluoromethane	94.0	52-132		%REC	1	9/14/2007 8:57:00 PM
Surr: Toluene-d8	93.2	51-127		%REC	1	9/14/2007 8:57:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ091207:1015NP1-1-8
<b>Lab Order:</b>	0709112	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, Sag Harbor, NY	<b>Collection Date:</b>	9/12/2007 10:15:00 AM
<b>Lab ID:</b>	0709112-04B	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	8.67	0.0200		mg/L	1	9/17/2007 12:55:33 PM
Manganese	0.723	0.0200		mg/L	1	9/17/2007 12:55:33 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

<b>CLIENT:</b>	Leggette Brashears & Graham Inc.	<b>Client Sample ID:</b>	GWQ091207:1015NPI-1-8
<b>Lab Order:</b>	0709112	<b>Tag Number:</b>	
<b>Project:</b>	Rowe Industries, Sag Harbor, NY	<b>Collection Date:</b>	9/12/2007 10:15:00 AM
<b>Lab ID:</b>	0709112-04C	<b>Matrix:</b>	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3005A</b>		Analyst: JP
Iron	0.386	0.0200		mg/L	1	9/17/2007 12:53:56 PM
Manganese	0.705	0.0200		mg/L	1	9/17/2007 12:53:56 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	80.0	1.00		mg/L	1	9/17/2007

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-05A

**Client Sample ID:** GWQ091207:1020NPI-1-9  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:20:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 9:21:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 9:21:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 9:21:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 9:21:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-05A

**Client Sample ID:** GWQ091207:1020NP1-1-9  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:20:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 9:21:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Tetrachloroethene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 9:21:00 PM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	9/14/2007 9:21:00 PM
Surr: Dibromofluoromethane	93.1	52-132		%REC	1	9/14/2007 9:21:00 PM
Surr: Toluene-d8	96.2	51-127		%REC	1	9/14/2007 9:21:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-05B

**Client Sample ID:** GWQ091207:1020NP1-1-9  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:20:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	4.33	0.0200		mg/L	1	9/17/2007 12:58:44 PM
Manganese	0.727	0.0200		mg/L	1	9/17/2007 12:58:44 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-05C

**Client Sample ID:** GWQ091207:1020NP1-1-9  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:20:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3005A</b>		Analyst: JP
Iron	0.404	0.0200		mg/L	1	9/17/2007 12:57:08 PM
Manganese	0.687	0.0200		mg/L	1	9/17/2007 12:57:08 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	78.0	1.00		mg/L	1	9/17/2007

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-06A

**Client Sample ID:** GWQ091207:1025NPI-1-4  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:25:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,1,1-Trichloroethane	6.3	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 9:45:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 9:45:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 9:45:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 9:45:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-06A

**Client Sample ID:** GWQ091207:1025NPI-1-4  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:25:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 9:45:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Tetrachloroethene	7.0	1.0		µg/L	1	9/14/2007 9:45:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 9:45:00 PM
Surr: 4-Bromofluorobenzene	99.4	54-134		%REC	1	9/14/2007 9:45:00 PM
Surr: Dibromofluoromethane	94.6	52-132		%REC	1	9/14/2007 9:45:00 PM
Surr: Toluene-d8	93.9	51-127		%REC	1	9/14/2007 9:45:00 PM

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-06B

**Client Sample ID:** GWQ091207:1025NP1-1-4  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:25:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	4.02	0.0200		mg/L	1	9/17/2007 1:05:28 PM
Manganese	1.20	0.0200		mg/L	1	9/17/2007 1:05:28 PM

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-06C

**Client Sample ID:** GWQ091207:1025NP1-1-4  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:25:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3005A</b>		<b>Analyst: JP</b>
Iron	1.73	0.0200		mg/L	1	9/17/2007 1:03:51 PM
Manganese	1.22	0.0200		mg/L	1	9/17/2007 1:03:51 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				<b>Analyst: SAP</b>
Total Dissolved Solids (Residue, Filterable)	146	1.00		mg/L	1	9/17/2007

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-07A

**Client Sample ID:** GWQ091207:1030NP1-1-2  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:30:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,1,1-Trichloroethane	1.2	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
2-Butanone	U	3.0		µg/L	1	9/14/2007 10:09:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
2-Hexanone	U	2.0		µg/L	1	9/14/2007 10:09:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/14/2007 10:09:00 PM
Acetone	U	2.0		µg/L	1	9/14/2007 10:09:00 PM
Benzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Bromobenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Bromochloromethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Bromodichloromethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Bromoform	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Bromomethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Carbon disulfide	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Chlorobenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-07A

**Client Sample ID:** GWQ091207:1030NPI-1-2  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:30:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Chloroform	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Chloromethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Dibromochloromethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Dibromomethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Ethylbenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Isopropylbenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
m,p-Xylene	U	2.0		µg/L	1	9/14/2007 10:09:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Methylene chloride	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Naphthalene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
n-Butylbenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
n-Propylbenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
o-Xylene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Styrene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Tetrachloroethene	1.6	1.0		µg/L	1	9/14/2007 10:09:00 PM
Toluene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Trichloroethene	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Vinyl acetate	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Vinyl chloride	U	1.0		µg/L	1	9/14/2007 10:09:00 PM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	9/14/2007 10:09:00 PM
Surr: Dibromofluoromethane	98.6	52-132		%REC	1	9/14/2007 10:09:00 PM
Surr: Toluene-d8	94.2	51-127		%REC	1	9/14/2007 10:09:00 PM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-07B

**Client Sample ID:** GWQ091207:1030NP1-1-2  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:30:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	1.76	0.0200		mg/L	1	9/17/2007 1:08:41 PM
Manganese	0.512	0.0200		mg/L	1	9/17/2007 1:08:41 PM

**Qualifiers:**

B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-07C

**Client Sample ID:** GWQ091207:1030NP1-1-2  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:30:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3005A</b>		Analyst: JP
Iron	0.232	0.0200		mg/L	1	9/17/2007 1:07:04 PM
Manganese	0.520	0.0200		mg/L	1	9/17/2007 1:07:04 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	192	1.00		mg/L	1	9/17/2007

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-08A

**Client Sample ID:** GWQ091207:1035NP1-1-3  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:35:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>		<b>SW8260B</b>		<b>SW5030A</b>		<b>Analyst: LDS</b>
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
2-Butanone	U	3.0		µg/L	1	9/15/2007 1:54:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
2-Hexanone	U	2.0		µg/L	1	9/15/2007 1:54:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	9/15/2007 1:54:00 AM
Acetone	U	2.0		µg/L	1	9/15/2007 1:54:00 AM
Benzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Bromobenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Bromochloromethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Bromodichloromethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Bromoform	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Bromomethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Carbon disulfide	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Chlorobenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-08A

**Client Sample ID:** GWQ091207:1035NP1-1-3  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:35:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>VOLATILE SW-846 8260 + MTBE &amp; FREON113</b>						Analyst: LDS
		<b>SW8260B</b>		<b>SW5030A</b>		
Chloroethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Chloroform	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Chloromethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Dibromochloromethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Dibromomethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Ethylbenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Isopropylbenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
m,p-Xylene	U	2.0		µg/L	1	9/15/2007 1:54:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Methylene chloride	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Naphthalene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
n-Butylbenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
n-Propylbenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
o-Xylene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Styrene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Tetrachloroethene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Toluene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Trichloroethene	1.6	1.0		µg/L	1	9/15/2007 1:54:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Vinyl acetate	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Vinyl chloride	U	1.0		µg/L	1	9/15/2007 1:54:00 AM
Surr: 4-Bromofluorobenzene	96.4	54-134		%REC	1	9/15/2007 1:54:00 AM
Surr: Dibromofluoromethane	90.5	52-132		%REC	1	9/15/2007 1:54:00 AM
Surr: Toluene-d8	95.0	51-127		%REC	1	9/15/2007 1:54:00 AM

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-08B

**Client Sample ID:** GWQ091207:1035NP1-1-3  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:35:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>TOTAL IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3010A</b>		Analyst: JP
Iron	2.20	0.0200		mg/L	1	9/17/2007 1:11:54 PM
Manganese	0.118	0.0200		mg/L	1	9/17/2007 1:11:54 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**American Analytical Laboratories, LLC.**

Date: 18-Sep-07

**CLIENT:** Leggette Brashears & Graham Inc.  
**Lab Order:** 0709112  
**Project:** Rowe Industries, Sag Harbor, NY  
**Lab ID:** 0709112-08C

**Client Sample ID:** GWQ091207:1035NP1-1-3  
**Tag Number:**  
**Collection Date:** 9/12/2007 10:35:00 AM  
**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
<b>DISSOLVED IRON, MANGANESE</b>		<b>E200.7</b>		<b>SW3005A</b>		Analyst: JP
Iron	1.49	0.0200		mg/L	1	9/17/2007 1:10:18 PM
Manganese	0.118	0.0200		mg/L	1	9/17/2007 1:10:18 PM
<b>TOTAL DISSOLVED SOLIDS</b>		<b>E160.1</b>				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	102	1.00		mg/L	1	9/17/2007

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

**H7I140104 Analytical Report..... 1**  
**Sample Receipt Documentation ..... 15**  
**Total Number of Pages ..... 17**

# STL

STL Knoxville  
5815 Middlebrook Pike  
Knoxville, TN 37921

Tel: 865 291 3000 Fax: 865 584 4315  
www.stl-inc.com

## ANALYTICAL REPORT


Rowe-NABSAG 0401

Lot #: H7I140104

Mark Goldberg

Leggette, Brashears & Graham,  
4 Research Drive  
Suite #301  
Shelton, CT 06484

TESTAMERICA LABORATORIES, INC.



Jamie A. McKinney  
Project Manager

September 25, 2007

# ANALYTICAL METHODS SUMMARY

H7I140104

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15

## References:

EPA-2 "Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air", EPA-625/R-96/010b, January 1999.



**SAMPLE SUMMARY**

H7I140104

<u>WO #</u>	<u>SAMPLE#</u>	<u>CLIENT SAMPLE ID</u>	<u>SAMPLED DATE</u>	<u>SAMP TIME</u>
J6TK8	001	AQ091207:1100NP4-1	09/12/07	11:08
J6TK9	002	AQ091207:1105NP4-2	09/12/07	11:05
J6TLA	003	AQ091207:1110NP4-3	09/12/07	11:10

**NOTE(S) :**

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

## **PROJECT NARRATIVE**

### **H71140104**

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

**The original chain of custody documentation is included with this report.**

#### **Sample Receipt**

The collection times listed on the chain of custody documentation did not list the collection times listed on the sample container labels.

#### **Quality Control and Data Interpretation**

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

The samples were received on 9/14/07 in Tedlar bags and transferred into Summa Canisters within 72 hours of sampling.

TestAmerica Knoxville (formerly STL Knoxville) maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. #QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

# Sample Data Summary

Leggette, Brashears & Graham, Inc.  
 Client Sample ID: AQ091207:1100NP4-1  
 GC/MS Volatiles

Lot-Sample # H71140104 - 001      Work Order # J6TK81AA      Matrix.....: AIR

Date Sampled...: 9/12/07      Date Received...: 9/14/07  
 Prep Date.....: 9/18/07      Analysis Date..: 9/19/07  
 Prep Batch #....: 7262592  
 Dilution Factor.: 5      Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)		REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND		3.2
Bromodichloromethane	ND	1.0	ND		6.7
Bromoform	ND	1.0	ND		10
Bromomethane	ND	1.0	ND		3.9
<b>Carbon disulfide</b>	<b>35</b>	<b>2.5</b>	<b>110</b>		<b>7.8</b>
Carbon tetrachloride	ND	1.0	ND		6.3
Chlorobenzene	ND	1.0	ND		4.6
Dibromochloromethane	ND	1.0	ND		8.5
Chloroethane	ND	1.0	ND		2.6
<b>Chloroform</b>	<b>0.97</b>	<b>1.0</b>	<b>4.7</b>	<b>J</b>	<b>4.9</b>
<b>Chloromethane</b>	<b>0.96</b>	<b>2.5</b>	<b>2.0</b>	<b>J</b>	<b>5.2</b>
<b>1,1-Dichloroethane</b>	<b>1.9</b>	<b>1.0</b>	<b>7.7</b>		<b>4.0</b>
1,2-Dichloroethane	ND	1.0	ND		4.0
cis-1,2-Dichloroethene	ND	1.0	ND		4.0
trans-1,2-Dichloroethene	ND	1.0	ND		4.0
1,1-Dichloroethene	ND	1.0	ND		4.0
1,2-Dichloropropane	ND	1.0	ND		4.6
cis-1,3-Dichloropropene	ND	1.0	ND		4.5
trans-1,3-Dichloropropene	ND	1.0	ND		4.5
Ethylbenzene	ND	1.0	ND		4.3
<b>Methylene chloride</b>	<b>0.90</b>	<b>2.5</b>	<b>3.1</b>	<b>J</b>	<b>8.7</b>
Styrene	ND	1.0	ND		4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND		6.9
<b>Tetrachloroethene</b>	<b>55</b>	<b>1.0</b>	<b>370</b>		<b>6.8</b>
<b>Toluene</b>	<b>29</b>	<b>1.0</b>	<b>110</b>		<b>3.8</b>
<b>1,1,1-Trichloroethane</b>	<b>4.9</b>	<b>1.0</b>	<b>27</b>		<b>5.5</b>
1,1,2-Trichloroethane	ND	1.0	ND		5.5
<b>Trichloroethene</b>	<b>0.59</b>	<b>1.0</b>	<b>3.1</b>	<b>J</b>	<b>5.4</b>
Vinyl chloride	ND	1.0	ND		2.6
m-Xylene & p-Xylene	ND	1.0	ND		4.3
o-Xylene	ND	1.0	ND		4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	99	70 - 130
Toluene-d8	104	70 - 130
4-Bromofluorobenzene	103	70 - 130

Leggette, Brashears & Graham, Inc.  
Client Sample ID: AQ091207:1100NP4-1  
GC/MS Volatiles

Lot-Sample # H71140104 - 001

Work Order # J6TK81AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)\*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) \* Dilution Factor) \* (Molecular Weight/24.45)

## Leggette, Brashears &amp; Graham, Inc.

Client Sample ID: AQ091207:1105NP4-2

## GC/MS Volatiles

Lot-Sample # H7I140104 - 002      Work Order # J6TK91AA      Matrix.....: AIR

Date Sampled...: 9/12/07      Date Received..: 9/14/07  
 Prep Date.....: 9/18/07      Analysis Date..: 9/19/07  
 Prep Batch #.....: 7262592  
 Dilution Factor.: 5      Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
<b>Benzene</b>	<b>1.1</b>	<b>1.0</b>	<b>3.5</b>	<b>3.2</b>
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
<b>Carbon disulfide</b>	<b>8.1</b>	<b>2.5</b>	<b>25</b>	<b>7.8</b>
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
<b>Chloroform</b>	<b>1.5</b>	<b>1.0</b>	<b>7.5</b>	<b>4.9</b>
<b>Chloromethane</b>	<b>1.4</b>	<b>2.5</b>	<b>2.9</b>	<b>5.2</b>
<b>1,1-Dichloroethane</b>	<b>5.1</b>	<b>1.0</b>	<b>20</b>	<b>4.0</b>
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
<b>1,1-Dichloroethene</b>	<b>1.0</b>	<b>1.0</b>	<b>4.0</b>	<b>4.0</b>
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
<b>Methylene chloride</b>	<b>1.2</b>	<b>2.5</b>	<b>4.2</b>	<b>8.7</b>
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
<b>Tetrachloroethene</b>	<b>270</b>	<b>1.0</b>	<b>1800</b>	<b>6.8</b>
<b>Toluene</b>	<b>7.6</b>	<b>1.0</b>	<b>29</b>	<b>3.8</b>
<b>1,1,1-Trichloroethane</b>	<b>19</b>	<b>1.0</b>	<b>100</b>	<b>5.5</b>
1,1,2-Trichloroethane	ND	1.0	ND	5.5
<b>Trichloroethene</b>	<b>9.4</b>	<b>1.0</b>	<b>51</b>	<b>5.4</b>
<b>Vinyl chloride</b>	<b>0.41</b>	<b>1.0</b>	<b>1.1</b>	<b>2.6</b>
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	100	70 - 130
Toluene-d8	100	70 - 130
4-Bromofluorobenzene	97	70 - 130

Leggette, Brashears & Graham, Inc.  
Client Sample ID: AQ091207:1105NP4-2  
GC/MS Volatiles

Lot-Sample # H71140104 - 002

Work Order # J6TK91AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)\*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) \* Dilution Factor) \* (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.  
 Client Sample ID: AQ091207:1110NP4-3  
 GC/MS Volatiles

Lot-Sample # H71140104 - 003      Work Order # J6TLA1AA      Matrix.....: AIR

Date Sampled...: 9/12/07      Date Received...: 9/14/07  
 Prep Date.....: 9/18/07      Analysis Date..: 9/19/07  
 Prep Batch #....: 7262592  
 Dilution Factor.: 5      Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
<b>Carbon disulfide</b>	<b>3.2</b>	<b>2.5</b>	<b>9.9</b>	<b>7.8</b>
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
<b>Chloroform</b>	<b>0.57</b>	<b>1.0</b>	<b>2.8</b>	<b>4.9</b>
Chloromethane	ND	2.5	ND	5.2
<b>1,1-Dichloroethane</b>	<b>1.5</b>	<b>1.0</b>	<b>6.1</b>	<b>4.0</b>
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	ND	1.0	ND	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
<b>Methylene chloride</b>	<b>0.37</b>	<b>2.5</b>	<b>1.3</b>	<b>8.7</b>
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	ND	1.0	ND	6.8
<b>Toluene</b>	<b>0.75</b>	<b>1.0</b>	<b>2.8</b>	<b>3.8</b>
<b>1,1,1-Trichloroethane</b>	<b>6.1</b>	<b>1.0</b>	<b>33</b>	<b>5.5</b>
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
<b>Vinyl chloride</b>	<b>0.36</b>	<b>1.0</b>	<b>0.92</b>	<b>2.6</b>
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	98	70 - 130
Toluene-d8	99	70 - 130
4-Bromofluorobenzene	97	70 - 130



Leggette, Brashears & Graham, Inc.  
Client Sample ID: AQ091207:1110NP4-3  
GC/MS Volatiles

Lot-Sample # H71140104 - 003

Work Order # J6TLA1AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)\*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) \* Dilution Factor) \* (Molecular Weight/24.45)

**Leggette, Brashears & Graham, Inc.**  
**Client Sample ID: INTRA-LAB BLANK**  
**GC/MS Volatiles**

Lot-Sample # H71190000 - 592B      Work Order # J68C31AA      Matrix.....: AIR

Prep Date.....: 9/18/07      Date Received..: 9/14/07  
 Prep Batch #.....: 7262592      Analysis Date..: 9/18/07  
 Dilution Factor.: 1      Method.....: TO-15

<u>PARAMETER</u>	<u>RESULTS</u> (ppb(v/v))	<u>REPORTING</u> <u>LIMIT (ppb(v/v))</u>	<u>RESULTS</u> (ug/m3)	<u>REPORTING</u> <u>LIMIT (ug/m3)</u>
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	1.6
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	ND	0.50	ND	1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

<u>SURROGATE</u>	<u>PERCENT</u> <u>RECOVERY</u>	<u>LABORATORY</u> <u>CONTROL</u> <u>LIMITS (%)</u>
1,2-Dichloroethane-d4	96	70 - 130
Toluene-d8	108	70 - 130
4-Bromofluorobenzene	104	70 - 130

Legette, Brashears & Graham, Inc.  
Client Sample ID: INTRA-LAB BLANK  
GC/MS Volatiles

Lot-Sample # H71190000 - 592B

Work Order # J68C31AA

Matrix.....: AIR

---

The 'Result' in ug/m3 is calculated using the following equation:  $\text{Amount Found}(\text{before rounding}) \times (\text{Molecular Weight}/24.45)$

The 'Reporting Limit' in ug/m3 is calculated using the following equation:  $(\text{Reporting Limit}(\text{before rounding}) \times \text{Dilution Factor}) \times (\text{Molecular Weight}/24.45)$

Leggette, Brashears & Graham, Inc.  
 Client Sample ID: CHECK SAMPLE  
 GC/MS Volatiles

Lot-Sample # H71190000 - 592C      Work Order # J68C31AC      Matrix.....: AIR

Prep Date.....: 9/18/07      Date Received..: 9/14/07  
 Prep Batch #.....: 7262592      Analysis Date..: 9/18/07  
 Dilution Factor.: 1      Method.....: TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	10.0	8.94	32	29	89	70 - 130
Chlorobenzene	10.0	7.92	46	36	79	70 - 130
1,1-Dichloroethene	10.0	12.9	40	51	129	70 - 130
Toluene	10.0	7.63	38	29	76	70 - 130
Trichloroethene	10.0	9.36	54	50	94	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	98	70 - 130
Toluene-d8	106	70 - 130
4-Bromofluorobenzene	103	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)\*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) \* Dilution Factor) \* (Molecular Weight/24.45)

# Sample Receipt Documentation

**STL Knoxville**

5815 Middlebrook Pike • Knoxville, TN 37921-5947  
 Phone: (865) 291-3000 • Fax: (865) 584-4315  
 Receiving: (865) 291-3031

**ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD\***

Project Name/No. 1 ROWE Samples Shipment Date 7 9/13/07  
 Sample Team Members 2 EJAN FOSTER Lab Destination 8 STL Knoxville  
 Profit Center No. 3 \_\_\_\_\_ Lab Contact 9 Jamie McKinney  
 Project Manager 4 MARK GOLDBERG Project Contact / Phone 12 203-929-8955  
 Purchase Order No. 5 NAB546-0401 Carrier / Waybill No. 13 \_\_\_\_\_

177140104  
 Reference Document No.  
 Page 1 of 1

Bill to: 5 MARK GOLDBERG  
LBG Inc.  
4 Research Dr. Suite 301  
Skelton, CT 06484  
 Report to: 10 same

**ONE CONTAINER PER LINE**

Sample 14 Number	Sample 15 Type	Date/Time 16 Collected	Container 17 Type	Sample 18 Volume	Pre- 19 servative	Requested Testing 20 Program	Condition on Receipt 21 Lab use only
A0091207:1100NP4-1	Air	9/12/07 1109	Redlar	1 liter	COOL	To-15	Custody seals intact <input checked="" type="checkbox"/> N NA
A0091207:1105NP4-2	I	1105	I	I	I	I	Temperature received at <u>AMBER</u>
A0091207:1110NP4-3	I	1110	I	I	I	I	Received by <u>RH</u> Date <u>9/4/07</u>
							Number of packages <u>1</u>
							Tracking # <u>797762278666</u>
							<u>FED EX</u>

**Special Instructions: 23**

Possible Hazard Identification: 24  
 Non-Hazard  Flammable  Skin Irritant  Poison B  Unknown   
 Turnaround Time Required: 26  
 Normal  Rush  QC Level: 27  
 I.  II.  III.  Project Specific (specify): Full QA/QC  
 1. Relinquished by 28 Lith' Bear Date: 09/13/07  
 (Signature / Affiliation) Time: 17:00  
 1. Relinquished by 28 Ryan Henry Date: 9/14/07  
 (Signature / Affiliation) Time: 1:00  
 1. Received by \_\_\_\_\_ Date: \_\_\_\_\_  
 (Signature / Affiliation) Time: \_\_\_\_\_

Comments: 29

# STL KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: \_\_\_\_\_ Project: \_\_\_\_\_ Lot Number: HT11410104

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)		<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/> 1a Do not match COC <input type="checkbox"/> 1b Incomplete information <input type="checkbox"/> 1c Marking smeared <input type="checkbox"/> 1d Label torn <input type="checkbox"/> 1e No label <input type="checkbox"/> 1f COC not received <input type="checkbox"/> 1g Other: _____	<u>1a - COC LISTS SAMPLES WITH TIME AS 1100, 1105, 1110. SAMPLE LABELS SHOW 1200, 1205, 1210.</u>
2. Is the cooler temperature within limits? (> freezing temp. of water to 6 °C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6 °C)			<input checked="" type="checkbox"/>	<input type="checkbox"/> 2a Temp Blank = _____ <input type="checkbox"/> 2b Cooler Temp = _____	
3. Were samples received with correct chemical preservative (excluding Encore)?			<input checked="" type="checkbox"/>	<input type="checkbox"/> 3a Sample preservative = _____	
4. Were custody seals present/intact on cooler and/or containers?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 4a Not present <input type="checkbox"/> 4b Not intact <input type="checkbox"/> 4c Other: _____	
5. Were all of the samples listed on the COC received?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 5a Samples received-not on COC <input type="checkbox"/> 5b Samples not received-on COC	
6. Were all of the sample containers received intact?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 6a Leaking <input type="checkbox"/> 6b Broken	
7. Were VOA samples received without headspace?			<input checked="" type="checkbox"/>	<input type="checkbox"/> 7a Headspace (VOA only)	
8. Were samples received in appropriate containers?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 8a Improper container	
9. Did you check for residual chlorine, if necessary?			<input checked="" type="checkbox"/>	<input type="checkbox"/> 9a Could not be determined due to matrix interference <input type="checkbox"/> 10a Holding time expired	
10. Were samples received within holding time?	<input checked="" type="checkbox"/>			<input type="checkbox"/> Incomplete information	
11. For rad samples, was sample activity info. provided?			<input checked="" type="checkbox"/>	If yes & appears to be >1%, was SOG notified?	
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?			<input checked="" type="checkbox"/>	<input type="checkbox"/> 13a Leaking <input type="checkbox"/> 13b Other: _____ <input type="checkbox"/> 14a Not relinquished	
13. Are the shipping containers intact?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information <input type="checkbox"/> 15a Incomplete information	
14. Was COC relinquished? (Signed/Dated/Timed)	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information	
15. Are tests/parameters listed for each sample?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information	
16. Is the matrix of the samples noted?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information	
17. Is the date/time of sample collection noted?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information	
18. Is the client and project name/# identified?	<input checked="" type="checkbox"/>			<input type="checkbox"/> 15a Incomplete information	
19. Was the sampler identified on the COC?	<input checked="" type="checkbox"/>				

Quote #: 61610 PM Instructions: \_\_\_\_\_

Sample Receiving Associate: Ryan Henry Date: 9/4/07