

-DRAFT-

PROJECT STATUS MEMORANDUM

NO. 11-07

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Tunde H. Komuves-Sandor

DATE: January 11, 2008

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
November 2007 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from November 1, 2007 through November 30, 2007. The report includes a summary of system performance parameters, system operation parameters, and analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(November 1, 2007 through November 30, 2007)

- | | |
|---|----------------------------------|
| 1. Hours of operation during the reporting period: | 243 hours (34%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 6,876,600 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 0.60 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 206.9 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.14 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.0009 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume pumped (gal)	Average Flow (gpm)	Lowest Measured Flow (gpm)*	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2	429,788	27	13	7.2	0.03
RW-3	429,757	26	10	0	0
RW-4**	418,384	29	10	24.5	0.09
RW-5	860,070	50	50	0	0
RW-6	214,986	15	15	33.1	0.06
RW-7	1,074,103	70	69	12.1	0.11
RW-8	859,521	55	41	1.9	0.01
RW-9**	953,206	65	16	0	0

*Lowest measured flows are based on the lowest average 24-hour pumping rates for each well recorded to date.

** The RW-4 and RW-9 flow meters were not functioning properly so the total volume pumped was calculated using the product of the average flow and the hours of operation for the month. The average flows are reasonable compared to historical data.

Based on the results of the updated ground-water model for the site, the plume is not migrating beyond the influence of the FSP&T system if the recovery well pumps operate at or above the “Lowest Measured Flows”. The average monthly pumping rates for all recovery wells are at or above the “Lowest Measured Flows”. The updated ground-water model is discussed in the 2006 Annual Report for the site.

On October 19, 2007, the AC unit for the control panel was not working. A contractor was contacted, to evaluate and repair the AC unit. The control panel doors were left open for ventilation and the system was restarted. The AC unit was removed by Alpine Environmental and Absolute Control tested the AC unit. Testing revealed that the motor of the AC unit needed to be replaced. A replacement motor was ordered and the FSP&T system was left off until a new motor could be delivered and installed. On November 19, 2007, the AC unit with new motor was reinstalled by Alpine Environmental and Absolute Control, and the FSP&T system was restarted.

On November 7, 2007, LBG assessed the accuracy of all of the flow meters in the FSP&T system using an ultrasonic flow meter. The ultrasonic flow meter was attached to the exterior of the system piping at several locations. The flow measured by the ultrasonic flow meter was compared to that measured by the existing system flow meters. The evaluation identified several

flow meters that were not accurately measuring the flow. The inaccuracy is believed to be the result of installing electronic transmitters in the flow meter displays that were not properly calibrated at the factory. The electronic transmitter counts the revolutions of the flow meter impeller and transmits that number to the FSP&T system PLC to calculate a flow rate. The manufacturer indicated that the transmitters that have been installed in the flow meter during previous repairs were likely not properly set up and thus the flow meters are not accurately measuring the flow through the meters. The manufacturer was contacted and a technician will be scheduled to properly program the electronic transmitters to provide accurate measurements. Once the problem is identified, any retroactive correction required in volume of water pumped or contaminant mass recovered will be completed.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
November 1 to 30	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in November 2007 include:

- On November 7, 2007, the PLC battery was replaced, the RW-3 flow set point was changed from 21 gpm to 25 gpm, and the FSP&T system flow meters were evaluated;
- On November 12 to 14, 2007, flow meters for RW-2, 4, 8, and 9 were cleaned/serviced, as was the well head piping and the on and off site combined flow meters were cleaned/serviced. The parking lot near MW-46A and MW-46B was re-stabilized, MW-98-05A, 5B, 1A, FRW-1 through 4 and MW-49A were re-developed, the recharge basin maintenance was completed, the RW-4 flow meter board and switch were replaced, and the malfunctioning auto dialer was troubleshooted; and
- On November 19, 2007, the booster blower belt was replaced, and the technician from Verizon repaired a defective autodialer plume line wire. The control panel AC unit was reinstalled and the system was restarted;

Future O&M activities scheduled for the winter of 2007 include:

- Evaluate options of repairing/recalibrating existing air flow meter or purchasing a new hand held air flow meter;
- Evaluate accuracy of water meter flow readings in the system by comparing to readings from an ultrasonic flow meter;

- Shut down RW-3 in order to evaluate the effect on contaminant concentrations in RW-2 if RW-3 is not operating; and
- Trouble shoot RW-9 flow meter.

MMG:nv

Attachments

cc: Jeff Srulovitz - Kraft Foods Global, Inc. - .pdf
Lisa Krogman, Environ – .pdf
Jeff Trad, NYSDEC – .pdf
Chief-Operation Maintenance and Support Section, NYSDEC – .pdf
William Spitz, RWM, R-1, NYSDEC
Garrett W. Swensen Jr., Esq., Town of Southampton

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(November 1, 2007 through November 30, 2007)

Date	Time	System Changes/Modifications	Personnel
11/7/2007		Changed RW-3 flow set point from 21 gpm to 25 gpm.	RD/PJ
		Replaced PLC battery.	RD/PJ
		Cycled system on and off during day for flow meter assessment	RD/PJ
	2:33 PM	Restarted System.	RD/PJ
11/9/2007	8:01 AM	Power Failure and Booster Blower Failure alarms, system shutdown.	
11/12/2007		Start below grade pipe cleaning, flow meter maintenance, restabalizing slope of parking area.	MW/Alpine
11/13/2007		Continue below grade pipe cleaning, flow meter maintenance, restabalizing slope of parking area.	MW/Alpine
11/14/2007	10:20 AM	Clear alarms, restart system.	RD
		Discharge basin rehabilitation	TS/Alpine
		Troubleshoot auto dialer phone line	RD
	11:35 AM	Replace RW-4 flow meter curcuit board and switch, Start RW-4	RD/TS
11/15/2007	1:02 PM	Booster Blower low pressure alarm, system shut down.	
11/19/2007		Replaced Booster Blower belt.	RD
		Technician from Verizon repaired defective wire for auto dialer.	RD/Verizon
		AC unit repaired and reinstalled.	RD/Alpine /Absolute Control
	12:07 PM	Restarted system.	RD
11/24/2007	6:54 AM	System Communication Failure, system shut down.	
11/28/2007		Reboot computer, restart system.	RD

TABLE 2

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo- chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	5	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
7-Nov-07	5.73	126	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	7.88	0.186
15-Nov-07	6.54	212	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	11.40	0.409
19-Nov-07	6.26	96	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	0.844	0.116
28-Nov-07	³	60	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	5.54	0.091

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

J: Analyte detected below quantitation limits

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

- Based on the new SPDES criteria from an NYSDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5. The pH was measured with a new calibrated electronic pH meter. Influent pH values from recovery wells typically range between 5 and 6.
- "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.
- The pH was not measured at this time.

TABLE 3

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m3)																							TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP	VOCs		
AQ112906:1000NP4-1	11/29/2006	10:00	0.21	0.0094	0.087	0.003	0.0094	0.0053	0.0028	0.0016	0.0016	ND	ND	0.0045	0.011	0.002	0.0052	ND	ND	ND	0.001	ND	ND	ND	ND	0.35	
AQ122006:815NP4-1	12/20/2006	8:15	0.065	0.013	0.13	0.0026	0.0081	0.0037	0.0052	0.0038	0.0021	ND	ND	0.0041	0.0021	0.0026	0.0071	ND	ND	0.0013	ND	ND	ND	ND	ND	0.25	
AQ011007:1000NP4-1	1/10/2007	10:00	0.06	0.082	0.08	0.0031	0.0084	ND	0.0016	0.0011	0.0011	ND	ND	0.0051	0.0016	0.003	0.0059	ND	ND	ND	ND	ND	ND	ND	ND	0.18	
AQ020807:1000NP4-1	2/8/2007	10:00	0.22	0.012	0.13	0.0041	0.011	0.0027	0.003	0.002	0.0018	ND	ND	0.0059	0.0038	0.0047	0.0059	ND	ND	ND	ND	ND	ND	ND	ND	0.41	
AQ030707:900NP4-1	3/7/2007	9:00	0.11	0.049	0.05	0.002	0.0066	0.0026	0.0022	0.0011	ND	ND	ND	0.0031	0.0016	0.0025	0.0019	ND	ND	ND	ND	ND	ND	ND	ND	0.18	
AQ040307:900NP4-1	4/3/2007	8:00	0.19	0.085	0.047	0.0025	0.0096	0.0026	0.0022	0.0011	ND	ND	ND	0.0045	0.0014	0.0025	0.0031	ND	ND	ND	ND	ND	ND	ND	ND	0.27	
AQ050107:1100NP4-1	5/1/2007	11:00	0.13	0.065	0.082	0.0033	0.017	ND	0.002	0.00088	ND	ND	ND	0.0055	0.0021	0.003	0.0046	ND	ND	ND	ND	ND	ND	ND	ND	0.26	
AQ060707:1030NP4-1	6/7/2007	10:30	0.1	0.048	0.046	0.0045	0.0075	ND	0.0023	ND	ND	ND	ND	0.0045	0.0012	0.0018	0.0054	ND	ND	ND	ND	ND	ND	ND	ND	0.17	
AQ070507:1100NP4-1	7/5/2007	11:00	0.18	0.067	0.044	0.0021	0.0094	ND	0.0027	ND	ND	ND	ND	0.0046	0.0019	ND	0.0064	ND	ND	ND	ND	ND	ND	ND	ND	0.26	
AQ080807:1100NP4-1	8/8/2007	11:00	0.0028 ^B	0.0072	ND	ND	ND	ND	0.0027	0.0029	ND	ND	ND	ND	0.0028 ^B	0.0025	0.021	ND	ND	ND	ND	ND	ND	ND	ND	0.04	
AQ091207:1100NP4-1	9/12/2007	11:00	0.370	0.0031	0.027	ND	0.0077	ND	0.11	ND	ND	ND	ND	0.0047	0.0031	0.002	0.11	ND	ND	ND	ND	ND	ND	ND	ND	0.64	
AQ100307:900NP4-1	10/3/2007	9:00	0.200	0.008	0.05	0.004	0.016	ND	0.0026	0.0012	ND	ND	ND	0.0061	ND	ND	0.0074	ND	ND	ND	0.0015 ^B	ND	ND	ND	ND	0.30	
AQ112807:900NP4-1	11/28/2007	9:00	0.110	0.0046	0.034	0.0037	0.013	0.0023	0.0022	0.001	ND	ND	ND	0.0062	0.018 ^B	0.002	0.0061	ND	ND	ND	ND	ND	ND	ND	ND	0.19	

Midcarbon			Parameters (mg/m3)																							TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP	VOCs		
AQ112906:1006NP4-2	11/29/2006	10:06	0.0034	ND	0.24	0.0065	0.022	0.0067	0.0017	ND	0.0012	ND	ND	0.0061	0.0012	0.0033	0.012	ND	ND	ND	0.00085	ND	ND	ND	ND	0.30	
AQ122006:820NP4-2	12/20/2006	8:20	0.0054	0.002	0.3	0.0037	0.014	0.0048	0.0017	0.0012	ND	ND	ND	0.0051	0.0015	0.0032	0.0037	ND	ND	ND	ND	ND	ND	ND	ND	0.34	
AQ011007:1001NP4-2	1/10/2007	10:01	0.0034	0.001	0.32	0.0047	0.012	0.005	0.0013	ND	ND	ND	ND	0.0056	0.0014	0.0032	0.0071	ND	ND	ND	ND	ND	ND	ND	ND	0.36	
AQ020807:1002NP4-2	2/8/2007	10:02	0.0092	0.004	0.32	0.0042	0.011	0.0063	0.0019	0.0011	ND	ND	ND	0.0067	0.0032	0.0026	0.0043	ND	ND	ND	ND	ND	ND	ND	ND	0.37	
AQ030707:902NP4-2	3/7/2007	9:02	0.0058	0.002	0.17	0.0031	0.0081	0.0037	0.0013	ND	ND	ND	ND	0.0048	0.001	0.0026	0.0038	ND	ND	ND	ND	ND	ND	ND	ND	0.21	
AQ040307:802NP4-2	4/3/2007	8:02	0.003	0.001	0.091	0.002	0.0063	0.0025	ND	ND	ND	ND	ND	0.0012	0.0012	ND	0.0029	ND	ND	ND	ND	ND	ND	ND	ND	0.11	
AQ050107:1105NP4-2	5/1/2007	11:05	0.0036	0.001	0.083	0.003	0.013	0.003	0.0017	ND	0.0047	ND	ND	0.0047	0.002 ^B	0.0027	0.0036	ND	ND	ND	ND	ND	ND	ND	ND	0.12	
AQ060707:1055NP4-2	6/7/2007	10:55	0.0052	0.002	0.058	0.006	0.0096	0.0013	0.0023	ND	0.0013	ND	ND	0.004	0.0014	ND	0.006	ND	ND	ND	ND	ND	ND	ND	ND	0.09	
AQ070507:1105NP4-2	7/5/2007	11:05	0.0018	0.001	0.066	0.006	0.0084	ND	0.0018	ND	ND	ND	ND	0.0038	0.0019 ^B	ND	0.0071	ND	ND	ND	ND	ND	ND	ND	ND	0.09	
AQ080807:1105NP4-2	8/8/2007	11:05	1.3 ^B	0.120	0.33	0.0053	0.035	0.0068	0.0092	0.0049	0.0028	ND	ND	0.016	0.0026 ^B	0.0018	0.02	ND	ND	ND	ND	ND	0.0028	0.0012	ND	0.56	
AQ091207:1105NP4-2	9/12/2007	11:05	1.8 ^B	0.051	0.100	0.004	0.020	ND	0.029	0.0035	ND	ND	ND	0.0075	0.0042	0.0029	0.025	ND	ND	ND	0.0011	ND	ND	ND	ND	2.05	
AQ100307:905NP4-2	10/3/2007	9:05	0.220	0.018	0.054	0.0017	0.015	ND	0.0093	ND	ND	ND	ND	0.0053	0.0014	ND	0.01	ND	ND	ND	0.0012 ^B	ND	ND	ND	ND	0.33	
AQ112807:905NP4-2	11/28/2007	9:05	0.086	0.011	0.072	0.0038	0.015	ND	0.0014	ND	ND	ND	ND	0.0056	0.0019 ^B	ND	0.0051	ND	ND	ND	ND	ND	ND	ND	ND	0.20	

Postcarbon			Parameters (mg/m3)																							TOTAL	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP	VOCs		
AQ112906:1010NP4-3	11/29/2006	10:10	ND	0.0011	0.071	0.0033	0.012	0.0053	0.001	ND	ND	ND	ND	0.0032	0.001	ND	0.0084	ND	ND	ND	ND	ND	ND	ND	ND	0.11	
AQ122006:825NP4-3	12/20/2006	8:25	ND	ND	0.14	0.0042	0.018	0.007	0.0024	0.0011	ND	ND	ND	0.0047	0.0012	ND	0.0042	ND	ND	ND	ND	ND	ND	ND	ND	0.18	
AQ011007:1002NP4-3	1/10/2007	10:02	ND	ND	0.23	0.0047	0.018	0.0065	0.0013	ND	ND	ND	ND	0.0053	0.0012	0.0028	0.0048	ND	ND	ND	ND	ND	ND	ND	ND	0.27	
AQ020807:1005NP4-3	2/8/2007	10:05	0.0039	ND	0.57	0.0069	0.028	0.012	0.0027	0.002	ND	ND	ND	0.0093	0.0044	0.0018	0.0046	ND	ND	ND	ND	0.0065	ND	ND	ND	0.65	
AQ030707:904NP4-3	3/7/2007	9:04	ND	ND	0.21	0.0028	0.0087	0.0056	ND	ND	ND	ND	ND	0.0043	0.00096	ND	0.0029	ND	ND	ND	ND	ND	ND	ND	ND	0.24	
AQ040307:904NP4-3	4/3/2007	8:04	ND	0.075	0.002	0.0037	0.0034	0.0034	0.0011	ND	ND	ND	ND	0.0047	0.0015	0.0025	0.002	ND	ND	ND	ND	ND	ND	ND	ND	0.09	
AQ050107:1110NP4-3	5/1/2007	11:10	ND	0.12	0.0026	0.0078	0.007	0.007	0.0089	ND	ND	ND	ND	0.005 ^B	0.003	0.0038	0.0038	ND	ND	ND	ND	ND	ND	ND	ND	0.16	
AQ060707:1100NP4-3	6/7/2007	11:00	ND	ND	0.067	0.002	0.0092	0.0045	0.002	ND	0.0023	ND	ND	0.0035	0.0011	ND	0.0052	ND	ND	ND	ND	ND	ND	ND	ND	0.10	
AQ070507:1110NP4-3	7/5/2007	11:10	ND	ND	0.110	0.0033	0.015	0.0064	0.0016	0.0018	ND	ND	ND	0.006	0.0019 ^B	ND	0.0062	ND	ND	ND	ND	ND	ND	ND	ND	0.15	
AQ080807:1110NP4-3	8/8/2007	11:10	0.013 ^B	0.0015	0.190	0.0063	0.029	0.011	0.41	0.0018	ND	ND	ND	0.011	0.0047 ^B	0.0037	0.019	ND	ND	ND	ND	ND	ND	ND	ND	0.68	
AQ091207:1110NP4-3	9/12/2007	11:10	ND	0.033	ND	0.0033	0.061	0.0061	0.0028	ND	ND	ND	ND	0.0028	0.0013	ND	0.0099	ND	ND	ND	0.00092	ND	ND	ND	ND	0.06	
AQ100307:910NP4-3	10/3/2007	9:10	ND	ND	0.044	0.004	0.0076	0.0021	0.0033	ND	ND	ND	ND	0.003	0.0012	ND	0.008	ND	ND	ND	ND	ND	ND	ND	ND	0.07	
AQ112807:910NP4-3	11/28/2007	9:10	ND	ND	0.110	0.003	0.014	0.0022	0.0015	ND	ND	ND	ND	0.0045	0.0018 ^B	ND	0.0061	ND	ND	ND	ND	ND	ND	ND	ND	0.14	

Note: B Method blank contamination. The associated method blank contains the target analyte at a reportable level.

PCE - Tetrachloroethane
TCE - Trichloroethane
TCA - 1,1,1-Trichloroethane
CE - Chloroethane

DCE - 1,1-Dichloroethane
DCA - 1,1-Dichloroethane
dis-DCE - cis-1,2-Dichloroethane
CT - Carbon Tetrachloride

CF - Chloroform
MC - Methylene Chloride
CM - Chloromethane
CD - Carbon Disulfide

BM - Bromomethane
CB - Chlorobenzene
EB - Ethylbenzene
VC - Vinyl Chloride

DCP - 1,2-Dichloropropane

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-1	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	NE
	15-Sep-04	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	0.0665	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	ND<1	2.2	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	ND<1	0.0475	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	6-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	ND<1	ND<1	ND<1	ND<1	5.2	ND<1	0.1650	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	1.7	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
RW-2	4-Jan-05	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.81	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0816	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	9.0	ND<1	ND<1	ND<1	ND<1	ND<1	4.51	0.128	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	12.0	ND<1	1.0	ND<1	ND<1	ND<1	3.5	0.0511	ND<1	2.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	7.7	1.1	ND<1	ND<1	ND<1	ND<1	0.28	0.0288	ND<1	ND<1	ND<1	7.3	ND<1	ND<1	ND<2	ND<1	ND<1	5.6
	9-Aug-05	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	3.74	0.107	ND<1	5.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	16	1.8	ND<1	ND<1	ND<1	ND<1	3.57	0.0704	ND<1	11	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	15	2.1	ND<1	ND<1	ND<1	ND<1	6.1	0.0269	ND<1	12	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	34	2.1	ND<1	ND<1	ND<1	ND<1	4.25	ND<0.02	ND<1	25	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	5.2	2.0	ND<1	ND<1	ND<1	ND<1	9.15	0.0696	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	6.5	4.3	1.2	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	6.5	3.5	ND<1	ND<1	ND<1	ND<1	4.76	0.0395	ND<1	3.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	12.0	3.9	1.2	ND<1	ND<1	ND<1	4.24	0.0522	ND<1	12.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	19.0	5.1	ND<1	ND<1	ND<1	ND<1	5.95	0.063	ND<1	14.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-Jun-06	13.0	3.0	25	ND<1	ND<1	ND<1	3.57	0.093	ND<1	9.0	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Jul-06	8.0	3.4	60	ND<1	ND<1	ND<1	4.49	0.177	ND<1	7.5	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	11.0	1.1	25	ND<1	ND<1	ND<1	4.14	0.0172	ND<1	5.7	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	2.8	ND<1	200	ND<1	ND<1	ND<1	13.7	0.0184	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	5.0	1.6	160	ND<1	ND<1	ND<1	3.6	0.00756	ND<1	3.6	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	6.0	1.8	36	ND<1	ND<1	ND<1	14.1	0.0148	ND<1	3	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	2.2	ND<1	110	ND<1	ND<1	ND<1	11.8	0.0197	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	4.2	2.7	68	ND<1	ND<1	ND<1	2.77	0.458	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-07	3.4	2.4	62	ND<1	ND<1	ND<1	8.72	0.06239	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	31	ND<1	ND<1	ND<1	4.28	0.107	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	3	1.7	23	ND<1	ND<1	ND<1	3.81	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	26	ND<1	ND<1	ND<1	3.04	0.0589	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Jun-07	1.1	1.2	ND<1	ND<1	ND<1	ND<1	2.7	0.0392	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	1.2	0.78	17	ND<1	ND<1	ND<1	2.26	0.198	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	0.75	ND<1	10	ND<1	ND<1	ND<1	3.92	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	1.2	ND<1	1.6	ND<1	ND<1	ND<1	1.76	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	1.4	ND<1	1.2	ND<1	ND<1	ND<1	1.9	1.28	ND<1	0.85	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	5.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.18	0.0132	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)	
RW-3	4-Jan-05	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	ND<1	ND<1	ND<1	NE	
	8-Feb-05	1.6	1.3	ND<1	ND<1	ND<1	ND<1	2.60	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	3	13	5.0	ND<1	ND<1	ND<1	2.10	1.15	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	46.1	0.539	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	2.2	7.7	2.8	ND<1	ND<1	ND<1	1.85	0.82	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	9.91	10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.9 *	
	14-Jul-05	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.01	0.649	ND<1	ND<1	ND<1	9.1 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	9-Aug-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.50	0.973	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Sep-05	1	3.6	1.2	ND<1	ND<1	ND<1	2.03	0.71	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	1.83	0.708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Dec-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.11	0.556	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Jan-06	1.7	17	7.9	ND<1	ND<1	ND<1	1.93	0.455	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Feb-06	1.4	8.9	2.5	ND<1	ND<1	ND<1	3.80	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Mar-06	1.1	3.4	ND<1	ND<1	ND<1	ND<1	1.87	0.297	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Apr-06	0.95	ND<1	ND<1	ND<1	ND<1	ND<1	1.99	0.649	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.06	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	21-June-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Aug-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Sep-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Oct-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	29-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.36	0.053	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-07	ND<1	3.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	2.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.24	0.761	ND<1	ND<1	ND<1	ND<1	6.1 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.89	1.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.48	0.19	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
25-Jun-07	0.91	8.5	ND<1	ND<1	ND<1	ND<1	2.36	0.0414	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
18-Jul-07	ND<1	2.8	1.2	ND<1	ND<1	ND<1	2.95	1.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
16-Aug-07	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	2.20	1.49	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.46	2.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.70	0.971	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-4	4-Jan-05	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Mar-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Apr-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	2-May-05	80	2.4	9.8	ND<1	ND<1	ND<1	3.77	0.0687	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Jun-05	74	2.6	ND<1	ND<1	ND<1	ND<1	9.95	9.28	ND<1	ND<1	ND<1	4.5 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	37	ND<1	8.9	ND<1	ND<1	ND<1	3.22	0.0185	ND<1	ND<1	ND<1	9.4 *	ND<1	ND<1	ND<1	ND<1	ND<1	7.4 *	ND<1
	9-Aug-05	31	ND<1	ND<1	ND<1	ND<1	ND<1	2.49	0.111	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	45	ND<1	6.0	ND<1	ND<1	ND<1	3.47	0.173	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.0777	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Dec-05	64	2.0	1.5	ND<1	ND<1	ND<1	2.82	0.0302	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	15	ND<1	9.5	ND<1	ND<1	ND<1	7.78	0.0412	ND<1	ND<1	ND<1	5.2 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	24	ND<1	8.7	ND<1	ND<1	ND<1	6.05	0.0627	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	22	ND<1	7.0	ND<1	ND<1	ND<1	3.50	0.0476	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	26	1.5	6.2	ND<1	ND<1	2	4.17	0.0963	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	26	ND<1	ND<1	ND<1	ND<1	ND<1	3.15	0.109	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	23	ND<1	8.4	ND<1	ND<1	ND<1	9.23	0.086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	14	ND<1	9.4	ND<1	ND<1	ND<1	4.10	0.155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	23	ND<1	ND<1	ND<1	ND<1	ND<1	8.60	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	9	ND<1	7.5	ND<1	ND<1	ND<1	5.95	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	11	ND<1	5.6	ND<1	ND<1	ND<1	7.17	0.0178	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	29-Nov-06	14	0.9	ND<1	ND<1	ND<1	ND<1	2.82	0.00708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-06	6.4	ND<1	4.4	ND<1	ND<1	ND<1	17.30	0.0112	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	12	ND<1	4.6	ND<1	ND<1	ND<1	3.17	0.0794	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-07	13	ND<1	3.3	ND<1	ND<1	ND<1	3.64	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	7.3	ND<1	2.1	ND<1	ND<1	ND<1	3.65	0.0767	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
18-Apr-07	10	ND<1	ND<1	ND<1	ND<1	ND<1	4.46	0.251	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<			

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)		
RW-5	ARAR-05	12	5	5.6	NE	7	2.0	300	300	5	5	5	5	NE	NE	ND<1	ND<1	ND<1	NE	ND<1	
	4-Jan-05	12	ND<1	5	ND<1	ND<1	NE	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NE	
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	9	ND<1	4.1	ND<1	ND<1	ND<1	0.0887	0.0187	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	13	ND<1	5.7	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-05	8.2	ND<1	1.6	ND<1	ND<1	ND<1	0.0358	ND<0.02	ND<1	ND<1	ND<1	ND<1	9.5 *	ND<1	ND<1	ND<1	ND<1	ND<1	5.6 *	
	9-Aug-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0227	0.0303	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Sep-05	8	ND<1	3.8	ND<1	ND<1	ND<1	0.0185	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	ND<1	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0492	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Dec-05	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	0.0468	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Jan-06	2.3	ND<1	2.0	ND<1	ND<1	ND<1	0.0568	0.0119	ND<1	ND<1	ND<1	ND<1	4.6 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Feb-06	2.9	ND<1	3.8	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Mar-06	2.6	ND<1	3.0	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Apr-06	1.4	ND<1	ND<1	ND<1	ND<1	1.5	2.4	0.0786	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	21-Jun-06	2.4	ND<1	2.6	ND<1	ND<1	ND<1	0.195	0.012	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Jul-06	1.3	ND<1	3.1	ND<1	ND<1	ND<1	0.184	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.09	0.0116	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.194	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
24-Oct-06	1.1	ND<1	1.3	ND<1	ND<1	ND<1	0.0683	0.0084	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
29-Nov-06	6	ND<1	ND<1	1.3	ND<1	ND<1	0.136	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	0.96	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.508	0.0113	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
10-Jan-07	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	1.2	0.0606	0.0128	ND<1	ND<1	ND<1	ND<1	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.327	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0655	0.00722	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.973	0.0106	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0763	0.00469	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
20-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.118	0.00747	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.395	0.0889	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0450	0.008	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	0.6	ND<1	0.0460	0.008	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	0.81	0.7	0.0600	0.350	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.1330	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
4-Jan-05	86	2.1	3.7	ND<1	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-6	8-Feb-05	110	2.4	7.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	120	2.3	6.6	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	74	ND<1	7.0	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	69	1.6	13	ND<1	ND<1	ND<1	0.067	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-05	64	1.6	9.5	ND<1	ND<1	ND<1	0.0406	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7 *	
	9-Aug-05	49	ND<1	12	ND<1	ND<1	ND<1	0.088	0.0366	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Sep-05	100	1.6	12	ND<1	ND<1	ND<1	1.3	0.0143	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	ND<1	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	68	ND<1	ND<1	ND<1	ND<1	ND<1	0.144	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Dec-05	100	2.1	20	ND<1	ND<1	ND<1	0.139	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Jan-06	41	1.1	16	ND<1	ND<1	ND<1	0.189	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	22-Feb-06	63	1.6	15	ND<1	ND<1	ND<1	0.116	0.0155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Mar-06	65	1.2	17	ND<1	ND<1	ND<1	0.0429	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Apr-06	62	2.1	22	ND<1	ND<1	2	0.24	0.0137	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	17-May-06	68	ND<1	18	ND<1	ND<1	ND<1	0.17	0.019	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	21-Jun-06	83	ND<1	20	ND<1	ND<1	ND<1	0.075	0.025	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Jul-06	45	1.5	24	ND<1	ND<1	ND<1	1.01	0.0169	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	24-Aug-06	30	ND<1	ND<1	ND<1	ND<1	ND<1	5.36	0.0563	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Sep-06	46																			

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)	
RW-7	4-Jan-05	37	1.1	5	NE	7	NE	300	300	5	5	5	5	NE	NE	ND<2	ND<1	ND<1	NE	
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Jun-05	32	1.0	4.7	ND<1	ND<1	ND<1	0.0753	0.02	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-05	32	ND<1	2.2	ND<1	ND<1	ND<1	0.0155	ND<0.02	ND<1	ND<1	ND<1	8.7 *	ND<1	ND<1	ND<1	ND<1	ND<1	7.2 *	
	9-Aug-05	31	ND<1	6.2	ND<1	ND<1	ND<1	0.0903	0.0409	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Sep-05	39	ND<1	3.4	ND<1	ND<1	ND<1	0.0452	ND<0.02	1.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.536	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Dec-05	70	ND<1	12.0	ND<1	ND<1	ND<1	0.263	ND<0.02	4.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Jan-06	26	ND<1	5.0	ND<1	ND<1	ND<1	0.343	ND<0.02	2.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Feb-06	36	ND<1	4.1	ND<1	ND<1	ND<1	0.0332	ND<0.02	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Mar-06	38	ND<1	4.1	ND<1	ND<1	ND<1	0.143	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Apr-06	49	1.6	7.4	ND<1	ND<1	ND<1	0.0912	0.0175	3.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	17-May-06	59	ND<1	ND<1	ND<1	ND<1	ND<1	0.126	0.026	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	21-Jun-06	44	ND<1	4.6	ND<1	ND<1	ND<1	0.081	0.013	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Aug-06	39	ND<1	7.9	ND<1	ND<1	ND<1	0.307	0.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
RW-8	19-Sep-06	36	ND<1	7.5	ND<1	ND<1	0.116	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	24-Oct-06	35	ND<1	3.5	ND<1	ND<1	0.0692	0.00946	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	9-Nov-06	33	ND<1	4.1	ND<1	ND<1	0.1910	0.04960	1.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Dec-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	10-Jan-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	8-Feb-07	43	ND<1	4.4	ND<1	ND<1	ND<1	0.131	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Mar-07	23	ND<1	2.7	ND<1	ND<1	ND<1	0.0492	0.0221	ND<1	ND<1	ND<1	6.5 *	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	18-Apr-07	34	ND<1	ND<1	ND<1	ND<1	ND<1	0.138	0.0438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	10-May-07	22	ND<1	2.3	ND<1	ND<1	ND<1	0.111	0.0271	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Jun-07	14	ND<1	1.7	ND<1	ND<1	ND<1	0.136	0.0165	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	18-Jul-07	17	ND<1	2	ND<1	ND<1	ND<1	0.434	0.0548	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	16-Aug-07	14	ND<1	1.6	ND<1	ND<1	ND<1	0.239	0.0250	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Sep-07	24	ND<1	2	ND<1	ND<1	ND<1	0.17	0.0800	0.68	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Oct-07	25	0.73	2.8	ND<1	ND<1	ND<1	0.194	0.2090	0.95	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Nov-07	11	ND<1	1.1	ND<1	ND<1	ND<1	0.163	0.0259	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.075	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.321	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	7.33	0.073	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
16-Jun-05	2.7	ND<1	5.8	ND<1	ND<1	ND<1	7.06	0.325	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
14-Jul-05	2.6	ND<1	3.4	ND<1	ND<1	ND<1	8.33	0.017	ND<1	ND<1	ND<1	8.5 *	ND<1	ND<1	ND<1	ND<1	ND<1	8.2 *		
9-Aug-05	1.8	ND<1	2.9	ND<1	ND<1	ND<1	0.24	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
8-Sep-05	2.9	ND<1	4.2	ND<1	ND<1	ND<1	7.53	0.255	2.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
21-Nov-05	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	7.65	0.106	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
8-Dec-05	2.4	ND<1	5.0	ND<1	ND<1	ND<1	5.19	0.021	3.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
12-Jan-06	1.3	ND<1	3.7	ND<1	ND<1	ND<1	7.25	0.097	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
14-Feb-06	1.5	ND<1	3.0	ND<1	ND<1	ND<1	8.06	ND<0.02	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
7-Mar-06	1.3	ND<1	2.8	ND<1	ND<1	ND<1	8.33	0.064	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
12-Apr-06	2.1	0.9	4.5	ND<1	ND<1	ND<1	7.27	0.823	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.03	0.056	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
21-Jun-06	ND<1	ND<1	2.8	ND<1	ND<1	ND<1	8.40	0.897	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
20-Jul-06	1.0	ND<1	4.0	ND<1	ND<1	ND<1	10.80	0.175	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
24-Aug-06	ND<1	ND<1	3.2	ND<1	ND<1	ND<1	5.98	1.860	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7.44	0.009	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
24-Oct-06	0.9	ND<1	3.1	ND<1	ND<1	ND<1	8.32	0.0605	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
26-Nov-06	1.0	ND<1	3.4	ND<1	ND<1	ND<1	3.67	0.0091	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
20-Dec-06	ND<1	ND<1	3.5	ND<1	ND<1	ND<1	62.80	0.0346	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
10-Jan-07	1.3	ND<1	3.5	ND<1	ND<1	ND<1	6.57	0.8100	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	9.3	2.8	2.7	ND<1	
8-Feb-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	
7-Mar-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM</									

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE	NE	NE	NE	NE
	4-Jan-05	ND<1	10	6.4	ND<1	ND<1	ND<1	2.35	1.72	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.507	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	4.5	ND<1	ND<1	ND<1	0.991	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0566	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	9.8	ND<1	ND<1	ND<1	1.38	0.149	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Jun-05	3.4	ND<1	3.1	ND<1	ND<1	ND<1	2.95	0.238	ND<1	ND<1	ND<1	6.9 *	ND<1	ND<1	ND<2	ND<1	ND<1	7.3 *
	9-Aug-05	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	0.994	0.0754	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	1.2	ND<1	2.0	ND<1	ND<1	ND<1	3.64	0.161	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.31	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	2.9	ND<1	ND<1	ND<1	2.01	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	2.36	0.0905	ND<1	ND<1	ND<1	4.9 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	2.1	ND<1	1.8	ND<1	ND<1	ND<1	5.23	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.41	0.333	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	1.93	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.054	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-June-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.095	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0165	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND<0.02	ND<1	ND<1	ND<1	18 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	6.96	0.00719	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	28-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.54	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	5.08	0.0855	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.96	0.0076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	8.03	0.399	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.232	ND<1	ND<1	ND<1	6.2 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	25-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.888	0.04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.99	0.0227	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.39	0.0250	ND<1	ND<1	ND<1	13 *	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.33	0.0400	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.18	0.180	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.704	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

NE indicates that the ARAR goal was not established for this compound by the EPA
 *Concentrations with an asterisk following them are due to laboratory contamination.
 ** RW-3 is currently non operational. weighting for the reprogramming of the drive for the new 4 amp pump;
 ** RW-9 was being rehabilitated during this sampling event, thus no water sample was collected.


GRAPHS

GRAPH 1


GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA


(November 1, 2007 through November 30, 2007)




GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
NOVEMBER 2007 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, November 14, 2007

(pm)

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 0711146

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 11/9/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0711146

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0711146-01A	WQ110707:1000NP2-6	12820	11/7/2007 10:00:00 AM	11/9/2007
0711146-01B	WQ110707:1000NP2-6	12820	11/7/2007 10:00:00 AM	11/9/2007
0711146-01C	WQ110707:1000NP2-6	12820	11/7/2007 10:00:00 AM	11/9/2007
0711146-02A	WQ110707:1005NP2-7	12820	11/7/2007 10:05:00 AM	11/9/2007
0711146-02B	WQ110707:1005NP2-7	12820	11/7/2007 10:05:00 AM	11/9/2007
0711146-02C	WQ110707:1005NP2-7	12820	11/7/2007 10:05:00 AM	11/9/2007
0711146-03A	WQ110707:1010NP2-10	12820	11/7/2007 10:10:00 AM	11/9/2007
0711146-03B	WQ110707:1010NP2-10	12820	11/7/2007 10:10:00 AM	11/9/2007
0711146-03C	WQ110707:1010NP2-10	12820	11/7/2007 10:10:00 AM	11/9/2007

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-01A

Client Sample ID: WQ110707:1000NP2-6
Tag Number: 12820
Collection Date: 11/7/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,1,1-Trichloroethane	2.1	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
2-Butanone	U	3.0		µg/L	1	11/9/2007 2:19:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
2-Hexanone	U	2.0		µg/L	1	11/9/2007 2:19:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/9/2007 2:19:00 PM
Acetone	U	2.0		µg/L	1	11/9/2007 2:19:00 PM
Benzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Bromobenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Bromoform	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Bromomethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-01A

Client Sample ID: WQ110707:1000NP2-6
Tag Number: 12820
Collection Date: 11/7/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Chloroform	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Chloromethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Dibromomethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/9/2007 2:19:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Methylene chloride	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Naphthalene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
o-Xylene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Styrene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Tetrachloroethene	6.7	1.0		µg/L	1	11/9/2007 2:19:00 PM
Toluene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Trichloroethene	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/9/2007 2:19:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	11/9/2007 2:19:00 PM
Surr: Dibromofluoromethane	113	52-132		%REC	1	11/9/2007 2:19:00 PM
Surr: Toluene-d8	78.4	51-127		%REC	1	11/9/2007 2:19:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-01B

Client Sample ID: WQ110707:1000NP2-6
Tag Number: 12820
Collection Date: 11/7/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.90	0.0200		mg/L	1	11/12/2007 1:10:31 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-01C

Client Sample ID: WQ110707:1000NP2-6
Tag Number: 12820
Collection Date: 11/7/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.0716	0.0200		mg/L	1	11/12/2007 1:08:28 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-02A

Client Sample ID: WQ110707:1005NP2-7
Tag Number: 12820
Collection Date: 11/7/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
2-Butanone	U	3.0		µg/L	1	11/9/2007 2:56:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
2-Hexanone	U	2.0		µg/L	1	11/9/2007 2:56:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/9/2007 2:56:00 PM
Acetone	U	2.0		µg/L	1	11/9/2007 2:56:00 PM
Benzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Bromobenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Bromoform	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Bromomethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-02A

Client Sample ID: WQ110707:1005NP2-7
Tag Number: 12820
Collection Date: 11/7/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Chloroform	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Chloromethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Dibromomethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/9/2007 2:56:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Methylene chloride	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Naphthalene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
o-Xylene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Styrene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Tetrachloroethene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Toluene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Trichloroethene	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/9/2007 2:56:00 PM
Surr: 4-Bromofluorobenzene	109	54-134		%REC	1	11/9/2007 2:56:00 PM
Surr: Dibromofluoromethane	103	52-132		%REC	1	11/9/2007 2:56:00 PM
Surr: Toluene-d8	90.5	51-127		%REC	1	11/9/2007 2:56:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-02B

Client Sample ID: WQ110707:1005NP2-7
Tag Number: 12820
Collection Date: 11/7/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.80	0.0200		mg/L	1	11/12/2007 1:14:37 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-02C

Client Sample ID: WQ110707:1005NP2-7
Tag Number: 12820
Collection Date: 11/7/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.167	0.0200		mg/L	1	11/12/2007 1:12:34 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-03A

Client Sample ID: WQ110707:1010NP2-10
Tag Number: 12820
Collection Date: 11/7/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
2-Butanone	U	3.0		µg/L	1	11/9/2007 3:32:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
2-Hexanone	U	2.0		µg/L	1	11/9/2007 3:32:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/9/2007 3:32:00 PM
Acetone	U	2.0		µg/L	1	11/9/2007 3:32:00 PM
Benzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Bromobenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Bromoform	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Bromomethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-03A

Client Sample ID: WQ110707:1010NP2-10
Tag Number: 12820
Collection Date: 11/7/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Chloroform	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Chloromethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Dibromomethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/9/2007 3:32:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Methylene chloride	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Naphthalene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
o-Xylene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Styrene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Tetrachloroethene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Toluene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Trichloroethene	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/9/2007 3:32:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	11/9/2007 3:32:00 PM
Surr: Dibromofluoromethane	100	52-132		%REC	1	11/9/2007 3:32:00 PM
Surr: Toluene-d8	87.5	51-127		%REC	1	11/9/2007 3:32:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-03B

Client Sample ID: WQ110707:1010NP2-10
Tag Number: 12820
Collection Date: 11/7/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	7.88	0.0200		mg/L	1	11/12/2007 1:18:41 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 14-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711146
Project: Rowe
Lab ID: 0711146-03C

Client Sample ID: WQ110707:1010NP2-10
Tag Number: 12820
Collection Date: 11/7/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.186	0.0200		mg/L	1	11/12/2007 1:16:39 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	126	1.00		mg/L	1	11/13/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Monday, November 26, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0711239

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 11/16/2007 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0711239

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0711239-01A	WQ111507:900NP2-6	12813	11/15/2007 9:00:00 AM	11/16/2007
0711239-01B	WQ111507:900NP2-6	12813	11/15/2007 9:00:00 AM	11/16/2007
0711239-01C	WQ111507:900NP2-6	12813	11/15/2007 9:00:00 AM	11/16/2007
0711239-02A	WQ111507:905NP2-7	12813	11/15/2007 9:05:00 AM	11/16/2007
0711239-02B	WQ111507:905NP2-7	12813	11/15/2007 9:05:00 AM	11/16/2007
0711239-02C	WQ111507:905NP2-7	12813	11/15/2007 9:05:00 AM	11/16/2007
0711239-03A	WQ111507:910NP2-10	12813	11/15/2007 9:10:00 AM	11/16/2007
0711239-03B	WQ111507:910NP2-10	12813	11/15/2007 9:10:00 AM	11/16/2007
0711239-03C	WQ111507:910NP2-10	12813	11/15/2007 9:10:00 AM	11/16/2007

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-01A

Client Sample ID: WQ111507:900NP2-6
Tag Number: 12813
Collection Date: 11/15/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,1,1-Trichloroethane	2.5	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
2-Butanone	U	3.0		µg/L	1	11/16/2007 3:52:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
2-Hexanone	U	2.0		µg/L	1	11/16/2007 3:52:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/16/2007 3:52:00 PM
Acetone	U	2.0		µg/L	1	11/16/2007 3:52:00 PM
Benzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Bromobenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Bromoform	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Bromomethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-01A

Client Sample ID: WQ111507:900NP2-6
Tag Number: 12813
Collection Date: 11/15/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Chloroform	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Chloromethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Dibromomethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/16/2007 3:52:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Methylene chloride	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Naphthalene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
o-Xylene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Styrene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Tetrachloroethene	5.8	1.0		µg/L	1	11/16/2007 3:52:00 PM
Toluene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Trichloroethene	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/16/2007 3:52:00 PM
Surr: 4-Bromofluorobenzene	103	54-134		%REC	1	11/16/2007 3:52:00 PM
Surr: Dibromofluoromethane	99.3	52-132		%REC	1	11/16/2007 3:52:00 PM
Surr: Toluene-d8	97.5	51-127		%REC	1	11/16/2007 3:52:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ111507:900NP2-6**Lab Order:** 0711239**Tag Number:** 12813**Project:** Rowe**Collection Date:** 11/15/2007 9:00:00 AM**Lab ID:** 0711239-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	15.2	0.0200		mg/L	1	11/21/2007 11:28:30 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-01C

Client Sample ID: WQ111507:900NP2-6
Tag Number: 12813
Collection Date: 11/15/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.127	0.0200		mg/L	1	11/21/2007 11:26:26 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-02A

Client Sample ID: WQ111507:905NP2-7
Tag Number: 12813
Collection Date: 11/15/2007 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
2-Butanone	U	3.0		µg/L	1	11/16/2007 4:27:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
2-Hexanone	U	2.0		µg/L	1	11/16/2007 4:27:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/16/2007 4:27:00 PM
Acetone	U	2.0		µg/L	1	11/16/2007 4:27:00 PM
Benzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Bromobenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Bromoform	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Bromomethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-02A

Client Sample ID: WQ111507:905NP2-7
Tag Number: 12813
Collection Date: 11/15/2007 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Chloroform	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Chloromethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Dibromomethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/16/2007 4:27:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Methylene chloride	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Naphthalene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
o-Xylene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Styrene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Tetrachloroethene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Toluene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Trichloroethene	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/16/2007 4:27:00 PM
Surr: 4-Bromofluorobenzene	96.8	54-134		%REC	1	11/16/2007 4:27:00 PM
Surr: Dibromofluoromethane	107	52-132		%REC	1	11/16/2007 4:27:00 PM
Surr: Toluene-d8	93.2	51-127		%REC	1	11/16/2007 4:27:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-02B

Client Sample ID: WQ111507:905NP2-7
Tag Number: 12813
Collection Date: 11/15/2007 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	8.95	0.0200		mg/L	1	11/21/2007 11:32:37 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-02C

Client Sample ID: WQ111507:905NP2-7
Tag Number: 12813
Collection Date: 11/15/2007 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.203	0.0200		mg/L	1	11/21/2007 11:30:34 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-03A

Client Sample ID: WQ111507:910NP2-10
Tag Number: 12813
Collection Date: 11/15/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
2-Butanone	U	3.0		µg/L	1	11/16/2007 5:01:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
2-Hexanone	U	2.0		µg/L	1	11/16/2007 5:01:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/16/2007 5:01:00 PM
Acetone	U	2.0		µg/L	1	11/16/2007 5:01:00 PM
Benzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Bromobenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Bromoform	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Bromomethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-03A

Client Sample ID: WQ111507:910NP2-10
Tag Number: 12813
Collection Date: 11/15/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Chloroform	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Chloromethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Dibromomethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/16/2007 5:01:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Methylene chloride	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Naphthalene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
o-Xylene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Styrene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Tetrachloroethene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Toluene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Trichloroethene	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/16/2007 5:01:00 PM
Surr: 4-Bromofluorobenzene	100	54-134		%REC	1	11/16/2007 5:01:00 PM
Surr: Dibromofluoromethane	98.8	52-132		%REC	1	11/16/2007 5:01:00 PM
Surr: Toluene-d8	97.3	51-127		%REC	1	11/16/2007 5:01:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-03B

Client Sample ID: WQ111507:910NP2-10
Tag Number: 12813
Collection Date: 11/15/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	11.4	0.0200		mg/L	1	11/21/2007 11:36:43 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 26-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711239
Project: Rowe
Lab ID: 0711239-03C

Client Sample ID: WQ111507:910NP2-10
Tag Number: 12813
Collection Date: 11/15/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3010A		Analyst: JP
Iron	0.409	0.0200		mg/L	1	11/21/2007 11:34:40 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	212	1.00		mg/L	1	11/20/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Tuesday, November 27, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0711323

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 11/21/2007 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0711323

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0711323-01A	WQ111907:800NP2-6	12821	11/19/2007 8:00:00 AM	11/21/2007
0711323-01B	WQ111907:800NP2-6	12821	11/19/2007 8:00:00 AM	11/21/2007
0711323-01C	WQ111907:800NP2-6	12821	11/19/2007 8:00:00 AM	11/21/2007
0711323-02A	WQ111907:805NP2-7	12821	11/19/2007 8:05:00 AM	11/21/2007
0711323-02B	WQ111907:805NP2-7	12821	11/19/2007 8:05:00 AM	11/21/2007
0711323-02C	WQ111907:805NP2-7	12821	11/19/2007 8:05:00 AM	11/21/2007
0711323-03A	WQ111907:810NP2-10	12821	11/19/2007 8:10:00 AM	11/21/2007
0711323-03B	WQ111907:810NP2-10	12821	11/19/2007 8:10:00 AM	11/21/2007
0711323-03C	WQ111907:810NP2-10	12821	11/19/2007 8:10:00 AM	11/21/2007



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

NYSDOH 11418
CTDOH PH-0205
NJDEP NY050
PADEP 68-573

TAG # / COC 12821

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LAB 4 Research Drive Helton, UT		CONTACT: Mark Goldberg		SAMPLER (SIGNATURE) Rob Drew		SAMPLE(S) SEALED YES / NO		
PROJECT LOCATION: Dove		SAMPLER NAME (PRINT) Rob Drew		CORRECT CONTAINER(S) YES / NO				
LABORATORY ID #		MATRIX	# CON- TAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION			FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
0711323-01A3C	SL	4	11/19/07 8:00	WQ111907: 800 NP2-6				
-02A3C	SL	4	3:05	805 NP2-7				
-03A3C	SL	5	8:10	810 NP2-10				
COOLER TEMPERATURE:								
MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A=AIR; W=WIFE; P=PAINT CHIPS; B=BULK MATERIAL TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON				TURNAROUND REQUIRED: NORMAL ☒ STAT ☐ BY / /		COMMENTS / INSTRUCTIONS		
RELINQUISHED BY (SIGNATURE) 	DATE 11/20/07 TIME 17:00	PRINTED NAME Kiti Deak	RECEIVED BY LAB (SIGNATURE) 	DATE 11/21/07 TIME 1248	PRINTED NAME GARY EPPICH			
RELINQUISHED BY (SIGNATURE)	DATE TIME	PRINTED NAME	RECEIVED BY LAB (SIGNATURE)	DATE TIME	PRINTED NAME			

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-01A

Client Sample ID: WQ111907:800NP2-6
Tag Number: 12821
Collection Date: 11/19/2007 8:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,1,1-Trichloroethane	0.78	1.0	J	µg/L	1	11/22/2007 4:20:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
2-Butanone	U	3.0		µg/L	1	11/22/2007 4:20:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 4:20:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 4:20:00 AM
Acetone	U	2.0		µg/L	1	11/22/2007 4:20:00 AM
Benzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Bromoform	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Bromomethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-01A

Client Sample ID: WQ111907:800NP2-6
Tag Number: 12821
Collection Date: 11/19/2007 8:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Chloroform	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Chloromethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 4:20:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Naphthalene	3.1	1.0		µg/L	1	11/22/2007 4:20:00 AM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
o-Xylene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Styrene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Tetrachloroethene	3.7	1.0		µg/L	1	11/22/2007 4:20:00 AM
Toluene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 4:20:00 AM
Surr: 4-Bromofluorobenzene	100	54-134		%REC	1	11/22/2007 4:20:00 AM
Surr: Dibromofluoromethane	95.1	52-132		%REC	1	11/22/2007 4:20:00 AM
Surr: Toluene-d8	97.3	51-127		%REC	1	11/22/2007 4:20:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-01B

Client Sample ID: WQ111907:800NP2-6
Tag Number: 12821
Collection Date: 11/19/2007 8:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.72	0.0200		mg/L	1	11/26/2007 12:49:05 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-01C

Client Sample ID: WQ111907:800NP2-6
Tag Number: 12821
Collection Date: 11/19/2007 8:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0247	0.0200		mg/L	1	11/26/2007 12:47:01 PM

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-02A

Client Sample ID: WQ111907:805NP2-7
Tag Number: 12821
Collection Date: 11/19/2007 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
2-Butanone	U	3.0		µg/L	1	11/22/2007 4:53:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 4:53:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 4:53:00 AM
Acetone	U	2.0		µg/L	1	11/22/2007 4:53:00 AM
Benzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Bromoform	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Bromomethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-02A

Client Sample ID: WQ111907:805NP2-7
Tag Number: 12821
Collection Date: 11/19/2007 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Chloroform	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Chloromethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 4:53:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Naphthalene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
o-Xylene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Styrene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Tetrachloroethene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Toluene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 4:53:00 AM
Surr: 4-Bromofluorobenzene	89.8	54-134		%REC	1	11/22/2007 4:53:00 AM
Surr: Dibromofluoromethane	102	52-132		%REC	1	11/22/2007 4:53:00 AM
Surr: Toluene-d8	90.5	51-127		%REC	1	11/22/2007 4:53:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-02B

Client Sample ID: WQ111907:805NP2-7
Tag Number: 12821
Collection Date: 11/19/2007 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	7.81	0.0200		mg/L	1	11/26/2007 12:53:10 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-02C

Client Sample ID: WQ111907:805NP2-7
Tag Number: 12821
Collection Date: 11/19/2007 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0927	0.0200		mg/L	1	11/26/2007 12:51:07 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-03A

Client Sample ID: WQ111907:810NP2-10
Tag Number: 12821
Collection Date: 11/19/2007 8:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
2-Butanone	U	3.0		µg/L	1	11/22/2007 5:27:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 5:27:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 5:27:00 AM
Acetone	U	2.0		µg/L	1	11/22/2007 5:27:00 AM
Benzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Bromoform	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Bromomethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-03A

Client Sample ID: WQ111907:810NP2-10
Tag Number: 12821
Collection Date: 11/19/2007 8:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Chloroform	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Chloromethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 5:27:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Naphthalene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
o-Xylene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Styrene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Tetrachloroethene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Toluene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 5:27:00 AM
Surr: 4-Bromofluorobenzene	105	54-134		%REC	1	11/22/2007 5:27:00 AM
Surr: Dibromofluoromethane	96.7	52-132		%REC	1	11/22/2007 5:27:00 AM
Surr: Toluene-d8	96.0	51-127		%REC	1	11/22/2007 5:27:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711323
Project: Rowe
Lab ID: 0711323-03B

Client Sample ID: WQ111907:810NP2-10
Tag Number: 12821
Collection Date: 11/19/2007 8:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	0.844	0.0200		mg/L	1	11/26/2007 12:57:15 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ111907:810NP2-10
Lab Order:	0711323	Tag Number:	12821
Project:	Rowe	Collection Date:	11/19/2007 8:10:00 AM
Lab ID:	0711323-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
----------	--------	-------	------	-------	----	---------------

DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.116	0.0200		mg/L	1	11/26/2007 12:55:13 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	96.0	1.00		mg/L	1	11/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, December 05, 2007

pm

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0711419

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 11/30/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0711419

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0711419-01A	WQ112807:800NP2-6	12831	11/28/2007 8:00:00 AM	11/30/2007
0711419-01B	WQ112807:800NP2-6	12831	11/28/2007 8:00:00 AM	11/30/2007
0711419-01C	WQ112807:800NP2-6	12831	11/28/2007 8:00:00 AM	11/30/2007
0711419-02A	WQ112807:805NP2-7	12831	11/28/2007 8:05:00 AM	11/30/2007
0711419-02B	WQ112807:805NP2-7	12831	11/28/2007 8:05:00 AM	11/30/2007
0711419-02C	WQ112807:805NP2-7	12831	11/28/2007 8:05:00 AM	11/30/2007
0711419-03A	WQ112807:810NP2-10	12831	11/28/2007 8:10:00 AM	11/30/2007
0711419-03B	WQ112807:810NP2-10	12831	11/28/2007 8:10:00 AM	11/30/2007
0711419-03C	WQ112807:810NP2-10	12831	11/28/2007 8:10:00 AM	11/30/2007

56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-01A

Client Sample ID: WQ112807:800NP2-6
Tag Number: 12831
Collection Date: 11/28/2007 8:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,1,1-Trichloroethane	1.3	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
2-Butanone	U	3.0		µg/L	1	11/30/2007 3:56:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
2-Hexanone	U	2.0		µg/L	1	11/30/2007 3:56:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/30/2007 3:56:00 PM
Acetone	U	2.0		µg/L	1	11/30/2007 3:56:00 PM
Benzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Bromobenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Bromoform	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Bromomethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-01A

Client Sample ID: WQ112807:800NP2-6
Tag Number: 12831
Collection Date: 11/28/2007 8:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Chloroform	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Chloromethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Dibromomethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/30/2007 3:56:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Methylene chloride	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Naphthalene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
o-Xylene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Styrene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Tetrachloroethene	6.7	1.0		µg/L	1	11/30/2007 3:56:00 PM
Toluene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Trichloroethene	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/30/2007 3:56:00 PM
Surr: 4-Bromofluorobenzene	96.0	54-134		%REC	1	11/30/2007 3:56:00 PM
Surr: Dibromofluoromethane	101	52-132		%REC	1	11/30/2007 3:56:00 PM
Surr: Toluene-d8	101	51-127		%REC	1	11/30/2007 3:56:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ112807:800NP2-6

Lab Order: 0711419

Tag Number: 12831

Project: Rowe

Collection Date: 11/28/2007 8:00:00 AM

Lab ID: 0711419-01B

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	8.54	0.0200		mg/L	1	12/4/2007 12:08:49 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ112807:800NP2-6**Lab Order:** 0711419**Tag Number:** 12831**Project:** Rowe**Collection Date:** 11/28/2007 8:00:00 AM**Lab ID:** 0711419-01C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0149	0.0200	J	mg/L	1	12/4/2007 12:06:45 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-02A

Client Sample ID: WQ112807:805NP2-7
Tag Number: 12831
Collection Date: 11/28/2007 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
2-Butanone	U	3.0		µg/L	1	11/30/2007 4:21:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
2-Hexanone	U	2.0		µg/L	1	11/30/2007 4:21:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/30/2007 4:21:00 PM
Acetone	U	2.0		µg/L	1	11/30/2007 4:21:00 PM
Benzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Bromobenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Bromoform	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Bromomethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-02A

Client Sample ID: WQ112807:805NP2-7
Tag Number: 12831
Collection Date: 11/28/2007 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Chloroform	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Chloromethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Dibromomethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/30/2007 4:21:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Methylene chloride	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Naphthalene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
o-Xylene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Styrene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Tetrachloroethene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Toluene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Trichloroethene	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/30/2007 4:21:00 PM
Surr: 4-Bromofluorobenzene	107	54-134		%REC	1	11/30/2007 4:21:00 PM
Surr: Dibromofluoromethane	108	52-132		%REC	1	11/30/2007 4:21:00 PM
Surr: Toluene-d8	95.1	51-127		%REC	1	11/30/2007 4:21:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-02B

Client Sample ID: WQ112807:805NP2-7
Tag Number: 12831
Collection Date: 11/28/2007 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	13.3	0.0200		mg/L	1	12/4/2007 12:12:55 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-02C

Client Sample ID: WQ112807:805NP2-7
Tag Number: 12831
Collection Date: 11/28/2007 8:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0787	0.0200		mg/L	1	12/4/2007 12:10:52 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-03A

Client Sample ID: WQ112807:810NP2-10
Tag Number: 12831
Collection Date: 11/28/2007 8:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
2-Butanone	U	3.0		µg/L	1	11/30/2007 4:48:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
2-Hexanone	U	2.0		µg/L	1	11/30/2007 4:48:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/30/2007 4:48:00 PM
Acetone	U	2.0		µg/L	1	11/30/2007 4:48:00 PM
Benzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Bromobenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Bromoform	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Bromomethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-03A

Client Sample ID: WQ112807:810NP2-10
Tag Number: 12831
Collection Date: 11/28/2007 8:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Chloroform	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Chloromethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Dibromomethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/30/2007 4:48:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Methylene chloride	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Naphthalene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
o-Xylene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Styrene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Tetrachloroethene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Toluene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Trichloroethene	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/30/2007 4:48:00 PM
Surr: 4-Bromofluorobenzene	97.0	54-134		%REC	1	11/30/2007 4:48:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	11/30/2007 4:48:00 PM
Surr: Toluene-d8	96.0	51-127		%REC	1	11/30/2007 4:48:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-03B

Client Sample ID: WQ112807:810NP2-10
Tag Number: 12831
Collection Date: 11/28/2007 8:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	5.54	0.0200		mg/L	1	12/4/2007 12:17:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 05-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711419
Project: Rowe
Lab ID: 0711419-03C

Client Sample ID: WQ112807:810NP2-10
Tag Number: 12831
Collection Date: 11/28/2007 8:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0914	0.0200		mg/L	1	12/4/2007 12:14:58 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	60.0	1.00		mg/L	1	12/4/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Tuesday, November 27, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 0711324

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 11/21/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe**Lab Order:** 0711324**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0711324-01A	GW111907:900NP1-1-2	12822	11/19/2007 9:00:00 AM	11/21/2007
0711324-01B	GW111907:900NP1-1-2	12822	11/19/2007 9:00:00 AM	11/21/2007
0711324-01C	GW111907:900NP1-1-2	12822	11/19/2007 9:00:00 AM	11/21/2007
0711324-02A	GW111907:910NP1-1-3	12822	11/19/2007 9:10:00 AM	11/21/2007
0711324-02B	GW111907:910NP1-1-3	12822	11/19/2007 9:10:00 AM	11/21/2007
0711324-02C	GW111907:910NP1-1-3	12822	11/19/2007 9:10:00 AM	11/21/2007
0711324-03A	GW111907:920NP1-1-4	12822	11/19/2007 9:20:00 AM	11/21/2007
0711324-03B	GW111907:920NP1-1-4	12822	11/19/2007 9:20:00 AM	11/21/2007
0711324-03C	GW111907:920NP1-1-4	12822	11/19/2007 9:20:00 AM	11/21/2007
0711324-04A	GW111907:930NP1-1-5	12822	11/19/2007 9:30:00 AM	11/21/2007
0711324-04B	GW111907:930NP1-1-5	12822	11/19/2007 9:30:00 AM	11/21/2007
0711324-04C	GW111907:930NP1-1-5	12822	11/19/2007 9:30:00 AM	11/21/2007
0711324-05A	GW111907:940NP1-1-6	12822	11/19/2007 9:40:00 AM	11/21/2007
0711324-05B	GW111907:940NP1-1-6	12822	11/19/2007 9:40:00 AM	11/21/2007
0711324-05C	GW111907:940NP1-1-6	12822	11/19/2007 9:40:00 AM	11/21/2007
0711324-06A	GW111907:950NP1-1-7	12822	11/19/2007 9:50:00 AM	11/21/2007
0711324-06B	GW111907:950NP1-1-7	12822	11/19/2007 9:50:00 AM	11/21/2007
0711324-06C	GW111907:950NP1-1-7	12822	11/19/2007 9:50:00 AM	11/21/2007
0711324-07A	GW111907:1000NP1-1-8	12822	11/19/2007 10:00:00 AM	11/21/2007
0711324-07B	GW111907:1000NP1-1-8	12822	11/19/2007 10:00:00 AM	11/21/2007
0711324-07C	GW111907:1000NP1-1-8	12822	11/19/2007 10:00:00 AM	11/21/2007
0711324-08A	GW111907:1010NP1-1-9	12822	11/19/2007 10:10:00 AM	11/21/2007
0711324-08B	GW111907:1010NP1-1-9	12822	11/19/2007 10:10:00 AM	11/21/2007
0711324-08C	GW111907:1010NP1-1-9	12822	11/19/2007 10:10:00 AM	11/21/2007

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-01A

Client Sample ID: GW111907:900NP1-1-2
Tag Number: 12822
Collection Date: 11/19/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
2-Butanone	U	3.0		µg/L	1	11/22/2007 10:19:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 10:19:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 10:19:00 AM
Acetone	U	2.0		µg/L	1	11/22/2007 10:19:00 AM
Benzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Bromoform	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Bromomethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-01A

Client Sample ID: GW111907:900NPI-1-2
Tag Number: 12822
Collection Date: 11/19/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Chloroform	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Chloromethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
cis-1,2-Dichloroethene	1.6	1.0		µg/L	1	11/22/2007 10:19:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 10:19:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Naphthalene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
o-Xylene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Styrene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Tetrachloroethene	5.6	1.0		µg/L	1	11/22/2007 10:19:00 AM
Toluene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 10:19:00 AM
Surr: 4-Bromofluorobenzene	91.8	54-134		%REC	1	11/22/2007 10:19:00 AM
Surr: Dibromofluoromethane	102	52-132		%REC	1	11/22/2007 10:19:00 AM
Surr: Toluene-d8	89.8	51-127		%REC	1	11/22/2007 10:19:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-01B

Client Sample ID: GW111907:900NP1-1-2
Tag Number: 12822
Collection Date: 11/19/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	2.18	0.0200		mg/L	1	11/26/2007 1:01:21 PM
Manganese	0.389	0.0200		mg/L	1	11/26/2007 1:01:21 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-01C

Client Sample ID: GW111907:900NP1-1-2
Tag Number: 12822
Collection Date: 11/19/2007 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0132	0.0200	J	mg/L	1	11/26/2007 12:59:18 PM
Manganese	0.463	0.0200		mg/L	1	11/26/2007 12:59:18 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	126	1.00		mg/L	1	11/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-02A

Client Sample ID: GW111907:910NP1-1-3
Tag Number: 12822
Collection Date: 11/19/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
2-Butanone	U	3.0		µg/L	1	11/22/2007 10:49:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 10:49:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 10:49:00 AM
Acetone	U	2.0		µg/L	1	11/22/2007 10:49:00 AM
Benzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Bromoform	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Bromomethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-02A

Client Sample ID: GW111907:910NP1-1-3
Tag Number: 12822
Collection Date: 11/19/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Chloroform	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Chloromethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 10:49:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Naphthalene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
o-Xylene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Styrene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Tetrachloroethene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Toluene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 10:49:00 AM
Surr: 4-Bromofluorobenzene	96.2	54-134		%REC	1	11/22/2007 10:49:00 AM
Surr: Dibromofluoromethane	99.3	52-132		%REC	1	11/22/2007 10:49:00 AM
Surr: Toluene-d8	96.9	51-127		%REC	1	11/22/2007 10:49:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-02B

Client Sample ID: GW111907:910NP1-1-3
Tag Number: 12822
Collection Date: 11/19/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	2.70	0.0200		mg/L	1	11/26/2007 1:16:41 PM
Manganese	0.0895	0.0200		mg/L	1	11/26/2007 1:16:41 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-02C

Client Sample ID: GW111907:910NP1-1-3
Tag Number: 12822
Collection Date: 11/19/2007 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.971	0.0200		mg/L	1	11/26/2007 1:14:37 PM
Manganese	0.0998	0.0200		mg/L	1	11/26/2007 1:14:37 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	84.0	1.00		mg/L	1	11/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-03A

Client Sample ID: GW111907:920NP1-1-4
Tag Number: 12822
Collection Date: 11/19/2007 9:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,1,1-Trichloroethane	8.2	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
2-Butanone	U	3.0		µg/L	1	11/22/2007 11:18:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 11:18:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 11:18:00 AM
Acetone	U	2.0		µg/L	1	11/22/2007 11:18:00 AM
Benzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Bromoform	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Bromomethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-03A

Client Sample ID: GW111907:920NP1-I-4
Tag Number: 12822
Collection Date: 11/19/2007 9:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Chloroform	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Chloromethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 11:18:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Naphthalene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
o-Xylene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Styrene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Tetrachloroethene	15	1.0		µg/L	1	11/22/2007 11:18:00 AM
Toluene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Trichloroethene	1.3	1.0		µg/L	1	11/22/2007 11:18:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 11:18:00 AM
Surr: 4-Bromofluorobenzene	93.9	54-134		%REC	1	11/22/2007 11:18:00 AM
Surr: Dibromofluoromethane	106	52-132		%REC	1	11/22/2007 11:18:00 AM
Surr: Toluene-d8	92.0	51-127		%REC	1	11/22/2007 11:18:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GW111907:920NPI-1-4

Lab Order: 0711324

Tag Number: 12822

Project: Rowe

Collection Date: 11/19/2007 9:20:00 AM

Lab ID: 0711324-03B

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	3.73	0.0200		mg/L	1	11/26/2007 1:20:48 PM
Manganese	0.900	0.0200		mg/L	1	11/26/2007 1:20:48 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-03C

Client Sample ID: GW111907:920NP1-1-4
Tag Number: 12822
Collection Date: 11/19/2007 9:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0317	0.0200		mg/L	1	11/26/2007 1:18:45 PM
Manganese	1.14	0.0200		mg/L	1	11/26/2007 1:18:45 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	122	1.00		mg/L	1	11/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-04A

Client Sample ID: GW111907:930NPI-1-5
Tag Number: 12822
Collection Date: 11/19/2007 9:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
2-Butanone	U	3.0		µg/L	1	11/22/2007 11:47:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 11:47:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 11:47:00 AM
Acetone	U	2.0		µg/L	1	11/22/2007 11:47:00 AM
Benzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Bromoform	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Bromomethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-04A

Client Sample ID: GW111907:930NP1-1-5
Tag Number: 12822
Collection Date: 11/19/2007 9:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Chloroform	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Chloromethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 11:47:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Naphthalene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
o-Xylene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Styrene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Tetrachloroethene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Toluene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 11:47:00 AM
Surr: 4-Bromofluorobenzene	93.6	54-134		%REC	1	11/22/2007 11:47:00 AM
Surr: Dibromofluoromethane	99.1	52-132		%REC	1	11/22/2007 11:47:00 AM
Surr: Toluene-d8	94.4	51-127		%REC	1	11/22/2007 11:47:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GW111907:930NP1-1-5

Lab Order: 0711324

Tag Number: 12822

Project: Rowe

Collection Date: 11/19/2007 9:30:00 AM

Lab ID: 0711324-04B

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.133	0.0200		mg/L	1	11/26/2007 1:24:53 PM
Manganese	U	0.0200		mg/L	1	11/26/2007 1:24:53 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-04C

Client Sample ID: GW111907:930NP1-1-5
Tag Number: 12822
Collection Date: 11/19/2007 9:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0215	0.0200		mg/L	1	11/26/2007 1:22:51 PM
Manganese	0.00420	0.0200	J	mg/L	1	11/26/2007 1:22:51 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	162	1.00		mg/L	1	11/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-05A

Client Sample ID: GW111907:940NPI-1-6
Tag Number: 12822
Collection Date: 11/19/2007 9:40:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,1,1-Trichloroethane	12	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,1-Dichloroethane	1.1	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
2-Butanone	U	3.0		µg/L	1	11/22/2007 12:16:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 12:16:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 12:16:00 PM
Acetone	U	2.0		µg/L	1	11/22/2007 12:16:00 PM
Benzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Bromoform	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Bromomethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-05A

Client Sample ID: GW111907:940NP1-1-6
Tag Number: 12822
Collection Date: 11/19/2007 9:40:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Chloroform	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Chloromethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 12:16:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Naphthalene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
o-Xylene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Styrene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Tetrachloroethene	20	1.0		µg/L	1	11/22/2007 12:16:00 PM
Toluene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 12:16:00 PM
Surr: 4-Bromofluorobenzene	94.5	54-134		%REC	1	11/22/2007 12:16:00 PM
Surr: Dibromofluoromethane	106	52-132		%REC	1	11/22/2007 12:16:00 PM
Surr: Toluene-d8	89.5	51-127		%REC	1	11/22/2007 12:16:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GW111907:940NP1-1-6**Lab Order:** 0711324**Tag Number:** 12822**Project:** Rowe**Collection Date:** 11/19/2007 9:40:00 AM**Lab ID:** 0711324-05B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.262	0.0200		mg/L	1	11/26/2007 1:28:58 PM
Manganese	0.132	0.0200		mg/L	1	11/26/2007 1:28:58 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-05C

Client Sample ID: GW111907:940NP1-1-6
Tag Number: 12822
Collection Date: 11/19/2007 9:40:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0317	0.0200		mg/L	1	11/26/2007 1:26:56 PM
Manganese	0.178	0.0200		mg/L	1	11/26/2007 1:26:56 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	144	1.00		mg/L	1	11/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-06A

Client Sample ID: GW111907:950NP1-1-7
Tag Number: 12822
Collection Date: 11/19/2007 9:50:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,1,1-Trichloroethane	1.1	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
2-Butanone	U	3.0		µg/L	1	11/22/2007 12:50:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 12:50:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 12:50:00 PM
Acetone	U	2.0		µg/L	1	11/22/2007 12:50:00 PM
Benzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Bromoform	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Bromomethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-06A

Client Sample ID: GW111907:950NP1-1-7
Tag Number: 12822
Collection Date: 11/19/2007 9:50:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Chloroform	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Chloromethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 12:50:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Naphthalene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
o-Xylene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Styrene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Tetrachloroethene	11	1.0		µg/L	1	11/22/2007 12:50:00 PM
Toluene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 12:50:00 PM
Surr: 4-Bromofluorobenzene	98.8	54-134		%REC	1	11/22/2007 12:50:00 PM
Surr: Dibromofluoromethane	94.0	52-132		%REC	1	11/22/2007 12:50:00 PM
Surr: Toluene-d8	95.9	51-127		%REC	1	11/22/2007 12:50:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GW111907:950NP1-1-7**Lab Order:** 0711324**Tag Number:** 12822**Project:** Rowe**Collection Date:** 11/19/2007 9:50:00 AM**Lab ID:** 0711324-06B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.163	0.0200		mg/L	1	11/26/2007 1:33:04 PM
Manganese	0.0533	0.0200		mg/L	1	11/26/2007 1:33:04 PM

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GW111907:950NP1-1-7**Lab Order:** 0711324**Tag Number:** 12822**Project:** Rowe**Collection Date:** 11/19/2007 9:50:00 AM**Lab ID:** 0711324-06C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0259	0.0200		mg/L	1	11/26/2007 1:31:00 PM
Manganese	0.0659	0.0200		mg/L	1	11/26/2007 1:31:00 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	112	1.00		mg/L	1	11/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-07A

Client Sample ID: GW111907:1000NP1-1-8
Tag Number: 12822
Collection Date: 11/19/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,1-Dichloroethane	1.3	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
2-Butanone	U	3.0		µg/L	1	11/22/2007 1:22:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 1:22:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 1:22:00 PM
Acetone	U	2.0		µg/L	1	11/22/2007 1:22:00 PM
Benzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Bromoform	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Bromomethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-07A

Client Sample ID: GW111907:1000NP1-1-8
Tag Number: 12822
Collection Date: 11/19/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Chloroform	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Chloromethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 1:22:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Naphthalene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
o-Xylene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Styrene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Tetrachloroethene	0.56	1.0	J	µg/L	1	11/22/2007 1:22:00 PM
Toluene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 1:22:00 PM
Surr: 4-Bromofluorobenzene	92.3	54-134		%REC	1	11/22/2007 1:22:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	11/22/2007 1:22:00 PM
Surr: Toluene-d8	93.2	51-127		%REC	1	11/22/2007 1:22:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GW111907:1000NP1-1-8**Lab Order:** 0711324**Tag Number:** 12822**Project:** Rowe**Collection Date:** 11/19/2007 10:00:00 AM**Lab ID:** 0711324-07B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	11.2	0.0200		mg/L	1	11/26/2007 1:46:25 PM
Manganese	0.464	0.0200		mg/L	1	11/26/2007 1:46:25 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GW111907:1000NP1-1-8**Lab Order:** 0711324**Tag Number:** 12822**Project:** Rowe**Collection Date:** 11/19/2007 10:00:00 AM**Lab ID:** 0711324-07C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0442	0.0200		mg/L	1	11/26/2007 1:44:21 PM
Manganese	0.649	0.0200		mg/L	1	11/26/2007 1:44:21 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	80.0	1.00		mg/L	1	11/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-08A

Client Sample ID: GW111907:1010NPI-1-9
Tag Number: 12822
Collection Date: 11/19/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
2-Butanone	U	3.0		µg/L	1	11/22/2007 1:52:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
2-Hexanone	U	2.0		µg/L	1	11/22/2007 1:52:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	11/22/2007 1:52:00 PM
Acetone	U	2.0		µg/L	1	11/22/2007 1:52:00 PM
Benzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Bromobenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Bromochloromethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Bromodichloromethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Bromoform	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Bromomethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Carbon disulfide	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Chlorobenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-08A

Client Sample ID: GW111907:1010NP1-1-9
Tag Number: 12822
Collection Date: 11/19/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Chloroform	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Chloromethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Dibromochloromethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Dibromomethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Ethylbenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Isopropylbenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
m,p-Xylene	U	2.0		µg/L	1	11/22/2007 1:52:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Methylene chloride	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Naphthalene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
n-Butylbenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
n-Propylbenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
o-Xylene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Styrene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Tetrachloroethene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Toluene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Trichloroethene	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Vinyl acetate	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Vinyl chloride	U	1.0		µg/L	1	11/22/2007 1:52:00 PM
Surr: 4-Bromofluorobenzene	98.7	54-134		%REC	1	11/22/2007 1:52:00 PM
Surr: Dibromofluoromethane	96.4	52-132		%REC	1	11/22/2007 1:52:00 PM
Surr: Toluene-d8	96.0	51-127		%REC	1	11/22/2007 1:52:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GW111907:1010NP1-1-9**Lab Order:** 0711324**Tag Number:** 12822**Project:** Rowe**Collection Date:** 11/19/2007 10:10:00 AM**Lab ID:** 0711324-08B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.704	0.0200		mg/L	1	11/26/2007 1:55:49 PM
Manganese	0.604	0.0200		mg/L	1	11/26/2007 1:55:49 PM

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Nov-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0711324
Project: Rowe
Lab ID: 0711324-08C

Client Sample ID: GW111907:1010NP1-1-9
Tag Number: 12822
Collection Date: 11/19/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0653	0.0200		mg/L	1	11/26/2007 1:48:28 PM
Manganese	0.601	0.0200		mg/L	1	11/26/2007 1:48:28 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	98.0	1.00		mg/L	1	11/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

H7K300112 Analytical Report	1
Sample Receipt Documentation	15
Total Number of Pages	17

ANALYTICAL REPORT

Rowe-NABSAG 0401

Lot #: H7K300112

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

TESTAMERICA LABORATORIES, INC.



Jamie A. McKinney
Project Manager

December 6, 2007

ANALYTICAL METHODS SUMMARY

H7K300112

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15

References:

EPA-2 "Compendium of Methods for the Determination of Toxic
Organic Compounds in Ambient Air", EPA-625/R-96/010b,
January 1999.

SAMPLE SUMMARY

H7K300112

WO #	SAMPLE#	CLIENT SAMPLE ID	SAMPLED DATE	SAMP TIME
KC6J9	001	AQ112807:900NP4-1	11/28/07	09:00
KC6KA	002	AQ112807:905NP4-2	11/28/07	09:05
KC6KC	003	AQ112807:910NP4-3	11/28/07	09:10

NOTE (S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

H7K300112

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

One of the two containers for sample AQ112807:905NP4-2 was received deflated.

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

The samples were received on 11/30/07 in Tedlar bags and analyzed within 72 hours of sampling.

TestAmerica Knoxville maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. #QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ112807:900NP4-1
 GC/MS Volatiles

Lot-Sample # H7K300112 - 001 Work Order # KC6J91AA Matrix.....: AIR

Date Sampled...: 11/28/07 Date Received...: 11/30/07
 Prep Date.....: 11/30/07 Analysis Date..: 11/30/07
 Prep Batch #.....: 7334225
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)		REPORTING LIMIT (ug/m3)
Benzene	0.32	1.0	1.0	J	3.2
Bromodichloromethane	ND	1.0	ND		6.7
Bromoform	ND	1.0	ND		10
Bromomethane	ND	1.0	ND		3.9
Carbon disulfide	2.0	2.5	6.1	J	7.8
Carbon tetrachloride	ND	1.0	ND		6.3
Chlorobenzene	ND	1.0	ND		4.6
Dibromochloromethane	ND	1.0	ND		8.5
Chloroethane	ND	1.0	ND		2.6
Chloroform	1.3	1.0	6.2		4.9
Chloromethane	0.98	2.5	2.0	J	5.2
1,1-Dichloroethane	3.1	1.0	13		4.0
1,2-Dichloroethane	ND	1.0	ND		4.0
cis-1,2-Dichloroethene	0.58	1.0	2.3	J	4.0
trans-1,2-Dichloroethene	ND	1.0	ND		4.0
1,1-Dichloroethene	0.93	1.0	3.7	J	4.0
1,2-Dichloropropane	ND	1.0	ND		4.6
cis-1,3-Dichloropropene	ND	1.0	ND		4.5
trans-1,3-Dichloropropene	ND	1.0	ND		4.5
Ethylbenzene	ND	1.0	ND		4.3
Methylene chloride	0.52	2.5	1.8	J B	8.7
Styrene	ND	1.0	ND		4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND		6.9
Tetrachloroethene	16	1.0	110		6.8
Toluene	0.59	1.0	2.2	J	3.8
1,1,1-Trichloroethane	6.2	1.0	34		5.5
1,1,2-Trichloroethane	ND	1.0	ND		5.5
Trichloroethene	0.86	1.0	4.6	J	5.4
Vinyl chloride	ND	1.0	ND		2.6
m-Xylene & p-Xylene	ND	1.0	ND		4.3
o-Xylene	ND	1.0	ND		4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	111	70 - 130
Toluene-d8	105	70 - 130
4-Bromofluorobenzene	108	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ112807:900NP4-1
GC/MS Volatiles

Lot-Sample # H7K300112 - 001

Work Order # KC6J91AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: $\text{Amount Found}(\text{before rounding}) * (\text{Molecular Weight}/24.45)$

The 'Reporting Limit' in ug/m3 is calculated using the following equation: $(\text{Reporting Limit}(\text{before rounding}) * \text{Dilution Factor}) * (\text{Molecular Weight}/24.45)$

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ112807:905NP4-2
 GC/MS Volatiles

Lot-Sample # H7K300112 - 002

Work Order # KC6KA1AA

Matrix.....: AIR

Date Sampled...: 11/28/07

Date Received..: 11/30/07

Prep Date.....: 11/30/07

Analysis Date..: 11/30/07

Prep Batch #.....: 7334225

Dilution Factor.: 5

Method..... TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	1.6	2.5	5.1	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.2	1.0	5.6	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	3.7	1.0	15	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.96	1.0	3.8	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.54	2.5	1.9	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	13	1.0	86	6.8
Toluene	0.36	1.0	1.4	3.8
1,1,1-Trichloroethane	13	1.0	72	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	2.0	1.0	11	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	116	70 - 130
Toluene-d8	110	70 - 130
4-Bromofluorobenzene	106	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ112807:905NP4-2
GC/MS Volatiles

Lot-Sample # H7K300112 - 002

Work Order # KC6KA1AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: $\text{Amount Found}(\text{before rounding}) * (\text{Molecular Weight}/24.45)$

The 'Reporting Limit' in ug/m3 is calculated using the following equation: $(\text{Reporting Limit}(\text{before rounding}) * \text{Dilution Factor}) * (\text{Molecular Weight}/24.45)$

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ112807:910NP4-3
 GC/MS Volatiles

Lot-Sample # H7K300112 - 003

Work Order # KC6KC1AA

Matrix.....: AIR

Date Sampled...: 11/28/07

Date Received...: 11/30/07

Prep Date.....: 11/30/07

Analysis Date..: 11/30/07

Prep Batch #.....: 7334225

Dilution Factor.: 5

Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	1.9	2.5	6.1	J 7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	0.91	1.0	4.5	J 4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	3.4	1.0	14	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	0.55	1.0	2.2	J 4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.75	1.0	3.0	J 4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.51	2.5	1.8	J B 8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	ND	1.0	ND	6.8
Toluene	0.40	1.0	1.5	J 3.8
1,1,1-Trichloroethane	20	1.0	110	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	120	70 - 130
Toluene-d8	106	70 - 130
4-Bromofluorobenzene	108	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ112807:910NP4-3
GC/MS Volatiles

Lot-Sample # H7K300112 - 003

Work Order # KC6KC1AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting
Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: INTRA-LAB BLANK
 GC/MS Volatiles

Lot-Sample # H7K300000 - 225B

Work Order # KC60H1AA

Matrix.....: AIR

Prep Date.....: 11/30/07

Date Received..: 11/28/07

Prep Batch #.....: 7334225

Analysis Date..: 11/30/07

Dilution Factor.: 1

Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	1.6
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	0.10	0.50	0.35 J	1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

SURROGATE

PERCENT
RECOVERYLABORATORY
CONTROL
LIMITS (%)

1,2-Dichloroethane-d4
 Toluene-d8
 4-Bromofluorobenzene

108
 105
 102

70 - 130
 70 - 130
 70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: INTRA-LAB BLANK
GC/MS Volatiles

Lot-Sample # H7K300000 - 225B

Work Order # KC60H1AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: CHECK SAMPLE
 GC/MS Volatiles

Lot-Sample # H7K300000 - 225C Work Order # KC60H1AC Matrix.....: AIR

Prep Date.....: 11/30/07 Date Received..: 11/28/07
 Prep Batch #.....: 7334225 Analysis Date..: 11/30/07
 Dilution Factor.: 1 Method.....: TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	10.0	9.59	32	31	96	70 - 130
Chlorobenzene	10.0	8.20	46	38	82	70 - 130
1,1-Dichloroethene	10.0	10.5	40	42	105	70 - 130
Toluene	10.0	7.68	38	29	77	70 - 130
Trichloroethene	10.0	10.6	54	57	106	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	114	70 - 130
Toluene-d8	99	70 - 130
4-Bromofluorobenzene	117	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

STL Knoxville

5815 Middlebrook Pike • Knoxville, TN 37921-5947
Phone: (865) 291-3000 • Fax: (865) 584-4315
Receiving: (865) 291-3031

Project Name/No. 1 NABSA 0401
Sample Team Members 2 Rob Prael
Profit Center No. 3
Project Manager 4 Mark C. Goldberg
Purchase Order No. 6

Required Report Date 11 Standard TAT

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD*

Samples Shipment Date 7 11/30/07
Lab Destination 8
Lab Contact 9 Jamie McKinney
Project Contact / Phone 12
Carrier / Waybill No. 13

147K-300112

Reference Document No.
Page 1 of

Bill to: 5 Mark C. Goldberg
Leggett Park Blvd. & Graham Ave.
4 Riverchase Pl., Suite 300
Shelton, CT 06484
Report to: 10 Same

ONE CONTAINER PER LINE

Sample 14 Number	Sample 15 Type	Date/Time 16 Collected	Container 17 Type	Sample 18 Volume	Pre- 19 servative	Requested Testing 20 Program	Condition on Receipt 21 Lab use only
AQ 112507-9001P4-1	A.C.	11/28/07 9:00 am	Tedlar Bag	1L	None	TD-15	Custody seals intact ☒ Y ☐ N NA
1 9051P4-2		9:05 am					Temperature received at <u>AMBIENT</u>
1 9101P4-3		9:10 am					Received by <u>RH</u> Date <u>11/30/07</u>
							Number of packages <u>1</u>
							Tracking # <u>799759262341</u>
							<u>FED EX</u>
Note: 1 NP4-2 bag de Gated							

Special Instructions: 23

Possible Hazard Identification: 24

Non-Hazard ☒ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐

Turnaround Time Required: 26

Normal ☒ Rush ☐

1. Relinquished by 28

(Signature / Affiliation) Mark M. Goldberg Date: 11/30/07
Time: 17:00

1. Relinquished by

(Signature / Affiliation) Date: _____
Time: _____

Comments: 29

Sample Disposal: 25

Return to Client ☐ Disposal by Lab ☒ Archive (mos.)

QC Level: 27

I. ☐ II. ☐ III. ☐

Project Specific (specify): Full CAC

1. Received by 28

(Signature / Affiliation) Ryan Henry Date: 11/30/07
Time: 0930

1. Received by

(Signature / Affiliation) Date: _____
Time: _____

TESTAMERICA KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: _____ Project: _____ Lot Number: 47K300112

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)	☒			☐ 1a Do not match COC ☐ 1b Incomplete information ☐ 1c Marking smeared ☐ 1d Label torn ☐ 1e No label ☐ 1f COC not received ☐ 1g Other: _____	<u>6a - NPH-2 1 of 2 RECEIVED</u> <u>DEFLATED</u>
2. Is the cooler temperature within limits? (> freezing temp. of water to 6°C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6°C)	☒		☒	☐ 2a Temp Blank = _____ ☐ 2b Cooler Temp = _____	
3. Were samples received with correct chemical preservative (excluding Encore)?	☒		☒	☐ 3a Sample preservative = _____	
4. Were custody seals present/intact on cooler and/or containers?	☒			☐ 4a Not present ☐ 4b Not intact ☐ 4c Other: _____	
5. Were all of the samples listed on the COC received?	☒			☐ 5a Samples received-not on COC ☐ 5b Samples not received-on COC	
6. Were all of the sample containers received intact?	☒			☒ 6a Leaking ☐ 6b Broken	
7. Were VOA samples received without headspace?	☒		☒	☐ 7a Headspace (VOA only)	
8. Were samples received in appropriate containers?	☒			☐ 8a Improper container	
9. Did you check for residual chlorine, if necessary?	☒		☒	☐ 9a Could not be determined due to matrix interference	
10. Were samples received within holding time?	☒			☐ 10a Holding time expired	
11. For rad samples, was sample activity info. provided?	☒		☒	☐ Incomplete information	
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?	☒		☒	If yes & appears to be >1%, was SOG notified?	
13. Are the shipping containers intact?	☒			☐ 13a Leaking ☐ 13b Other: _____	
14. Was COC relinquished? (Signed/Dated/Timed)	☒			☐ 14a Not relinquished	
15. Are tests/parameters listed for each sample?	☒			☐ 15a Incomplete information	
16. Is the matrix of the samples noted?	☒			☐ 15a Incomplete information	
17. Is the date/time of sample collection noted?	☒			☐ 15a Incomplete information	
18. Is the client and project name/# identified?	☒			☐ 15a Incomplete information	
19. Was the sampler identified on the COC?	☒			☐ 15a Incomplete information	
Quote #: <u>65610</u> PM Instructions: _____					

Sample Receiving Associate: Ryan Henry Date: 11/30/07 QA026R19.doc, 080707