

-DRAFT-

PROJECT STATUS MEMORANDUM

NO. 12-07

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Tunde H. Komuves-Sandor

DATE: January 25, 2008

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
December 2007 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from December 1, 2007 through December 31, 2007. The report includes a summary of system performance parameters, system operation parameters, and analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(December 1, 2007 through December 31, 2007)

- | | |
|---|----------------------------------|
| 1. Hours of operation during the reporting period: | 492 hours (66%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 13,894,100 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 0.80 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 207.7 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.20 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.0015 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume pumped (gal)	Average Flow (gpm)	Lowest Measured Flow (gpm)*	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2**	797,094	27	13	12	0.08
RW-3***	186,403	26	10	***	***
RW-4	847,149	22	10	12.3	0.09
RW-5**	1,476,100	50	50	1.3	0.02
RW-6	434,225	15	15	33.2	0.12
RW-7	1,841,839	70	69	14.7	0.23
RW-8	1,736,910	55	41	2.6	0.04
RW-9**	1,918,930	65	16	0	0

*Lowest measured flows are based on the lowest average 24-hour pumping rates for each well recorded to date.

** The RW-2, RW-5 and RW-9 flow meter was not functioning properly so the total volume pumped was calculated using the product of the last reliable average flow reading and the hours of operation for the month.

*** RW-3 was shut down on December 5, 2007 and was not sampled in December 2007.

Based on the results of the updated ground-water model for the site, the plume is not migrating beyond the influence of the FSP&T system if the recovery well pumps operate at or above the “Lowest Measured Flows”. The average monthly pumping rates for all recovery wells are at or above the “Lowest Measured Flows”. The updated ground-water model is discussed in the 2006 Annual Report for the site.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
December 1 to 31	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in December 2007 include:

- On December 5, 2007, RW-3 was shut down for a planned three month period in order to evaluate the effect on contaminant concentrations in the ground-water recovered by RW-2.

Future O&M activities scheduled for the winter and spring of 2008 include:

- Evaluate option of repair/recalibrating existing air flow meter compared to purchasing a new hand held air flow meter;
- Evaluate accuracy of flow meter readings in the system;
- Evaluate the effect on contaminant concentrations in RW-2 if RW-3 is not operating;
- Trouble shoot the RW-9 flow meter;
- Conduct semi-annual sampling;
- Measure static and pumping depth-to-water levels in all recovery and monitor wells.

MMG:nv

Attachments

cc: Jeff Srulovitz - Kraft Foods Global, Inc. - .pdf
Lisa Krogman, Environ – .pdf
Jeff Trad, NYSDEC – .pdf
Chief-Operation Maintenance and Support Section, NYSDEC – .pdf
William Spitz, RWM, R-1, NYSDEC
Garrett W. Swensen Jr., Esq., Town of Southampton

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(December 1, 2007 through December 31, 2007)

Date	Time	System Changes/Modifications	Personnel
12/5/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
		Shut down RW-3 in order to evaluate the effect on contaminant concentrations in water at RW-2 if RW-3 is not operating.	EF
12/12/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
12/14/2007		PC Communication Failure, no alarm recorded, system shutdown between 8:56 AM and 9:56 AM	
12/20/2007	10:02 AM	Reboot computer, clear alarms, restart system.	EF
12/27/2007		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
	12:38 PM	EQ tank high level alarm, system shutdown.	

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo- chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	5	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
5-Dec-07	5.91	138	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.29	0.173
12-Dec-07	5.85	126	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.21	0.104
20-Dec-07	5.83	114	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	55.1	1.65
27-Dec-07	5.86	128	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.08	0.104

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

J: Analyte detected below quantitation limits

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethylene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

1. Based on the new SPDES criteria from an NY SDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5.

The pH was measured with a new calibrated electronic pH meter. Influent pH values from recovery wells typically range between 5 and 6.

2. "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.

TABLE 3

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon			Parameters (mg/m ³)																				TOTAL VOCs	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP
AQ122006:815NP4-1	12/20/2006	8:15	0.065	0.0130	0.13	0.0026	0.0081	0.0037	0.0052	0.0038	0.0021	ND	ND	0.0041	0.0021	0.0026	0.0071	ND	0.0013	ND	ND	ND	ND	ND
AQ011007:1000NP4-1	1/10/2007	10:00	0.06	0.0082	0.08	0.0031	0.0084	ND	0.0016	0.0011	0.0011	ND	ND	0.0051	0.0016	0.003	0.0059	ND	ND	ND	ND	ND	ND	ND
AQ020807:1000NP4-1	2/8/2007	10:00	0.22	0.0120	0.13	0.0041	0.011	0.0027	0.003	0.002	0.0018	ND	ND	0.0059	0.0038	0.0047	0.0059	ND	ND	ND	ND	ND	ND	ND
AQ030707:900NP4-1	3/7/2007	9:00	0.11	0.0049	0.05	0.002	0.0066	ND	0.0022	0.0011	ND	ND	ND	0.0031	0.0016	ND	0.0019	ND	ND	ND	ND	ND	ND	ND
AQ040307:800NP4-1	4/3/2007	8:00	0.19	0.0085	0.07	0.0025	0.0096	0.0026	0.0013	ND	ND	ND	ND	0.0045	0.0014	0.0025	0.0031	ND	ND	ND	ND	ND	ND	ND
AQ050107:1100NP4-1	5/1/2007	11:00	0.13	0.0065	0.082	0.0033	0.017	ND	0.002	0.00088	ND	ND	ND	0.0055	0.0021	0.003	0.0046	ND	ND	ND	ND	ND	ND	ND
AQ060707:1030NP4-1	6/7/2007	10:30	0.1	0.0048	0.046	ND	0.0075	ND	0.0023	ND	ND	ND	ND	0.0045	0.0012	0.0018	0.0054	ND	ND	ND	ND	ND	ND	ND
AQ070507:1100NP4-1	7/5/2007	11:00	0.18	0.0067	0.044	0.0021	0.0094	ND	0.0027	0.0029	ND	ND	ND	0.0046	0.0019	0.0064	0.0064	ND	ND	ND	ND	ND	ND	ND
AQ080807:1100NP4-1	8/8/2007	11:00	0.0028 ^a	0.0072	ND	ND	ND	ND	0.0027	0.0029	ND	ND	ND	ND	0.0028 ^a	0.0025	0.021	ND	ND	ND	ND	ND	ND	ND
AQ091207:1100NP4-1	9/12/2007	11:00	0.370	0.0031	0.027	ND	0.0077	ND	0.11	ND	ND	ND	ND	0.0047	0.0031	0.002	0.11	ND	ND	ND	ND	ND	ND	ND
AQ100307:900NP4-1	10/3/2007	9:00	0.200	0.0080	0.05	0.004	0.016	ND	0.0026	0.0012	ND	ND	ND	0.0061	0.0031	0.002	0.0074	ND	ND	ND	0.0015 ^b	ND	ND	ND
AQ112807:900NP4-1	11/28/2007	9:00	0.110	0.0046	0.034	0.0037	0.013	0.0023	0.0022	0.001	ND	ND	ND	0.0062	0.018 ^a	0.002	0.0061	ND	ND	ND	ND	ND	ND	ND
AQ121207:900NP4-1	12/12/2007	9:00	0.090	0.0047	0.040	0.0021	0.015	ND	0.0023	ND	ND	ND	ND	0.0058	0.0011	ND	0.0022	ND	ND	ND	ND	ND	ND	ND
Midcarbon			Parameters (mg/m ³)																				TOTAL VOCs	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP
AQ122006:820NP4-2	12/20/2006	8:20	0.0054	0.002	0.3	0.0037	0.014	0.0048	0.0017	0.0012	ND	ND	ND	0.0051	0.0015	ND	0.0037	ND	ND	ND	ND	ND	ND	ND
AQ011007:1001NP4-2	1/10/2007	10:01	0.0034	0.001	0.32	0.0047	0.012	0.005	0.0019	0.0011	ND	ND	ND	0.0056	0.0014	0.0032	0.0071	ND	ND	ND	ND	ND	ND	ND
AQ020807:1002NP4-2	2/8/2007	10:02	0.0092	0.004	0.32	0.0042	0.011	0.0063	0.0013	0.0011	ND	ND	ND	0.0067	0.0032	0.0043	0.0043	ND	ND	ND	ND	ND	ND	ND
AQ030707:902NP4-2	3/7/2007	9:02	0.0058	0.002	0.17	0.0031	0.0081	0.0037	0.0013	ND	ND	ND	ND	0.0048	0.001	0.0026	0.0038	ND	ND	ND	ND	ND	ND	ND
AQ040307:802NP4-2	4/3/2007	8:02	0.003	0.001	0.091	0.0020	0.0063	0.0025	0.0017	ND	ND	ND	ND	0.0047	0.0012	0.0027	0.0036	ND	ND	ND	ND	ND	ND	ND
AQ050107:1105NP4-2	5/1/2007	11:05	0.0036	0.001	0.083	0.0030	0.013	0.003	0.0017	ND	ND	ND	ND	0.0047	0.002 ^a	0.0027	0.0036	ND	ND	ND	ND	ND	ND	ND
AQ060707:1055NP4-2	6/7/2007	10:55	0.0052	0.002	0.058	0.0096	0.011	ND	0.0023	ND	0.0013	ND	ND	0.004	0.0014	ND	0.006	ND	ND	ND	ND	ND	ND	ND
AQ070507:1105NP4-2	7/5/2007	11:05	0.0018	0.001	0.066	0.006	0.0084	ND	0.0018	ND	ND	ND	ND	0.0038	0.0019 ^a	0.0071	0.0071	ND	ND	ND	ND	ND	ND	ND
AQ080807:1105NP4-2	8/8/2007	11:05	1.3 ^a	0.120	0.33	0.0053	0.035	0.0068	0.0092	0.0049	0.0028	ND	ND	0.016	0.0026 ^a	0.0018	0.02	ND	ND	ND	ND	0.0028	0.0012	0.0012
AQ091207:1105NP4-2	9/12/2007	11:05	1.8	0.051	1.00	0.0040	0.020	ND	0.0029	0.0035	ND	ND	ND	0.0075	0.0042	0.0029	0.025	ND	ND	ND	0.0011	ND	ND	ND
AQ100307:905NP4-2	10/3/2007	9:05	0.220	0.018	0.054	0.0017	0.015	ND	ND	0.00093	ND	ND	ND	0.0053	0.0014	ND	0.01	ND	ND	ND	0.0012 ^b	ND	ND	ND
AQ112807:905NP4-2	11/28/2007	9:05	0.086	0.011	0.072	0.0038	0.015	ND	0.0014	ND	ND	ND	ND	0.0056	0.0019 ^a	ND	0.0051	ND	ND	ND	ND	ND	ND	ND
AQ121207:905NP4-2	12/12/2007	9:05	0.250	0.025	0.086	0.0023	0.017	ND	0.0010	0.00095	ND	ND	ND	0.0064	0.0014	ND	0.0024	ND	ND	ND	ND	ND	ND	ND
Postcarbon			Parameters (mg/m ³)																				TOTAL VOCs	
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP
AQ122006:825NP4-3	12/20/2006	8:25	ND	ND	0.14	0.0042	0.018	0.007	0.0024	0.0011	ND	ND	ND	0.0047	0.0012	0.0028	0.0042	ND	ND	ND	ND	ND	ND	ND
AQ011007:1002NP4-3	1/10/2007	10:02	ND	ND	0.23	0.0047	0.018	0.0065	0.0013	ND	ND	ND	ND	0.0053	0.0012	0.0028	0.0048	ND	ND	ND	ND	ND	ND	ND
AQ020807:1005NP4-3	2/8/2007	10:05	0.0039	ND	0.57	0.0069	0.028	0.012	0.0027	0.002	ND	ND	ND	0.0093	0.0044	0.0018	0.0046	ND	ND	ND	0.0065	ND	ND	ND
AQ030707:904NP4-3	3/7/2007	9:04	ND	ND	0.21	0.0028	0.0087	0.0056	ND	ND	ND	ND	ND	0.0043	0.00096	0.0029	0.0029	ND	ND	ND	ND	ND	ND	ND
AQ040307:804NP4-3	4/3/2007	8:04	ND	ND	0.075	0.0020	0.0037	0.0034	0.0011	ND	ND	ND	ND	0.0047	0.0015	0.0025	0.002	ND	ND	ND	ND	ND	ND	ND
AQ050107:1101NP4-3	5/1/2007	11:10	ND	ND	0.12	0.0026	0.0078	0.007	0.0089	ND	ND	ND	ND	0.0047	0.005 ^a	0.003	0.0038	ND	ND	ND	ND	ND	ND	ND
AQ060707:1100NP4-3	6/7/2007	11:00	ND	ND	0.067	0.0020	0.0092	0.0045	0.002	ND	0.0023	ND	ND	0.0035	0.0011	ND	0.0052	ND	ND	ND	ND	ND	ND	ND
AQ070507:1101NP4-3	7/5/2007	11:10	ND	ND	0.110	0.0033	0.015	0.0064	0.0016	ND	ND	ND	ND	0.006	0.0019 ^a	0.0037	0.0062	ND	ND	ND	ND	ND	ND	ND
AQ080807:1101NP4-3	8/8/2007	11:10	0.013 ^a	0.0015	0.190	0.0063	0.029	0.011	0.41	0.0018	ND	ND	ND	0.011	0.0047 ^a	0.0037	0.019	ND	ND	ND	ND	ND	ND	ND
AQ091207:1101NP4-3	9/12/2007	11:10	ND	ND	0.033	ND	0.0061	ND	0.0028	ND	ND	ND	ND	0.0028	0.0013	ND	0.0099	ND	ND	ND	0.00092	ND	ND	ND
AQ100307:910NP4-3	10/3/2007	9:10	ND	ND	0.044	ND	0.0076	0.0021	0.0033	ND	ND	ND	ND	0.0045	0.0018 ^a	0.0012	0.008	ND	ND	ND	ND	ND	ND	ND
AQ112807:910NP4-3	11/28/2007	9:10	ND	ND	0.110	0.0030	0.014	0.0022	0.0015	ND	ND	ND	ND	0.0045	0.0018 ^a	0.0012	0.0061	ND	ND	ND	ND	ND	ND	ND
AQ121207:910NP4-3	12/12/2007	9:10	ND	ND	0.160	0.0033	0.025	0.003	0.0012	ND	ND	ND	ND	0.007	ND	ND	0.0028	ND	ND	ND	ND	ND	ND	ND

Note: B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
 PCE - Tetrachloroethane
 TCE - Trichloroethane
 TCA - 1,1,1-Trichloroethane
 DCE - 1,1-Dichloroethane
 DCA - 1,1-Dichloroethane
 dis-DCE - cis-1,2-Dichloroethane
 CT - Carbon Tetrachloride
 CF - Chloroform
 MC - Methylene Chloride
 CM - Chloromethane
 CD - Carbon Disulfide
 BM - Bromomethane
 CB - Chlorobenzene
 EB - Ethylbenzene
 VC - Vinyl Chloride
 DCP - 1,2-Dichloropropane

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethane (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-1 ³	ADAX's 7-Oct-04	ND<1	ND<1	ND<1	NE	2.8	NE	300	ND<0.02	ND<1	ND<1	ND<1	ND<1	NE	NE	ND<1	ND<1	ND<1	NE
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	2.5	2.0	0.0392	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	2.1	0.0433	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.3	1.3	1	6.9
	7-Mar-06	ND<1	ND<1	ND<1	ND<1	5.2	ND<1	0.1650	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Mar-06	ND<1	ND<1	ND<1	ND<1	7.1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-08	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.91	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-08	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-2	15-Mar-05	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0916	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	5.0	ND<1	ND<1	ND<1	ND<1	ND<1	3.50	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-May-05	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.141	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jun-05	12.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0988	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	7.7	1.1	ND<1	ND<1	ND<1	ND<1	0.228	0.0288	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	9-Aug-05	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	3.74	0.107	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	16	1.8	ND<1	ND<1	ND<1	ND<1	3.57	0.074	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	16	ND	ND	ND	ND	ND	6.1	0.0669	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Nov-05	13	2.1	ND<1	ND<1	ND<1	ND<1	6.1	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	3.1	2.1	ND<1	ND<1	ND<1	ND<1	9.45	0.0962	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	5.2	2.0	ND<1	ND<1	ND<1	ND<1	9.15	0.0962	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	6.5	4.3	ND<1	ND<1	ND<1	ND<1	3.99	0.0302	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	6.5	3.9	ND<1	ND<1	ND<1	ND<1	2.6	0.0355	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	13.0	3.9	ND<1	ND<1	ND<1	ND<1	2.6	0.0222	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	13.0	5.1	ND<1	ND<1	ND<1	ND<1	5.65	0.063	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	13.0	3.0	25	ND<1	ND<1	ND<1	3.57	0.093	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	8.0	3.4	25	ND<1	ND<1	ND<1	4.49	0.172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	1.0	1.1	25	ND<1	ND<1	ND<1	4.37	0.076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Sep-06	2.5	ND<1	200	ND<1	ND<1	ND<1	3.6	0.0756	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	6.0	1.8	160	ND<1	ND<1	ND<1	1.9	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	29-Nov-06	2.2	ND<1	110	ND<1	ND<1	ND<1	2.79	0.0497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Dec-06	4.2	ND<1	89	ND<1	ND<1	ND<1	6.72	0.0829	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-07	3.2	2.7	62	ND<1	ND<1	ND<1	4.26	0.17	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	31	ND<1	ND<1	ND<1	3.81	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-07	3	1.7	23	ND<1	ND<1	ND<1	3.04	0.0669	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	26	ND<1	ND<1	ND<1	3.94	0.0362	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Jun-07	1.1	1.2	ND<1	ND<1	ND<1	ND<1	2.74	0.0362	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jul-07	1.2	0.78	17	ND<1	ND<1	ND<1	2.26	0.196	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Aug-07	0.75	ND<1	10	ND<1	ND<1	ND<1	3.92	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Sep-07	1.6	ND<1	1.2	ND<1	ND<1	ND<1	1.76	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Oct-07	1.4	ND<1	1.2	ND<1	ND<1	ND<1	1.28	1.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Nov-07	5.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.16	0.0132	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Dec-07	2.2	0.86	8.3	ND<1	ND<1	ND<1	5.55	0.0186	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

[illegible]

TABLE 4

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARARs	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) 5	Chloroform (ug/L) 7	MTBE (ug/L) 2.0	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	1,1-Dichloro- ethane (ug/L) 5	cis-1,2-Dichloro- ethane (ug/L) 5	1,1-Dichloro- ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Toluene (ug/L) NE	Dibromochloro- methane (ug/L) NE	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethyl- benzene (ug/L)	Acetone (ug/L) NE	
RW-5	4-Jan-05	12	ND<1	5.6	ND<1	ND<1	NE	0.0269	0.0172	ND<1	ND<1	ND<1	ND<1	NE	NE	ND<1	ND<1	ND<1	ND<1	
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	2.6	0.0318	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	15-Mar-05	14	ND<1	4.3	ND<1	ND<1	2.6	0.0887	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	22-Feb-06	9	ND<1	4.1	ND<1	ND<1	4.1	0.0187	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	27-Mar-05	13	ND<1	5.7	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-05	11	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Jul-05	8.2	ND<1	1.6	ND<1	ND<1	ND<1	0.0358	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.6*	
	9-Aug-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0227	0.0303	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Sep-05	8	ND<1	3.8	ND<1	ND<1	ND<1	0.0185	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1
	21-Nov-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0482	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Dec-05	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	0.0468	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Jan-06	2.3	ND<1	2.0	ND<1	ND<1	ND<1	0.0558	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	14-Feb-06	2.9	ND<1	3.8	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Mar-06	2.6	ND<1	3.0	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Apr-06	1.4	ND<1	ND<1	ND<1	1.5	2.4	0.0786	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	21-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	21-Jun-06	2.4	ND<1	2.6	ND<1	ND<1	ND<1	0.195	0.012	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Jul-06	1.3	ND<1	3.1	ND<1	ND<1	ND<1	0.184	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.09	0.0116	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.194	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
24-Oct-06	1.1	ND<1	ND<1	1.3	ND<1	ND<1	0.0683	0.00684	ND<1	ND<1	ND<1	ND<1	ND<1	0.96	ND<1	ND<1	ND<1	ND<1		
29-Nov-06	6	ND<1	ND<1	1.3	ND<1	ND<1	0.136	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.508	0.0113	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
10-Jan-07	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	1.2	0.0608	0.0128	ND<1	ND<1	ND<1	ND<1	2.8	ND<1	ND<1	ND<1	ND<1		
8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.327	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0655	0.00722	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.073	0.0106	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0763	0.00469	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
20-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.118	0.0747	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.395	0.0889	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0450	0.008	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.81	0.0460	0.008	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
12-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.7	0.0600	0.350	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
19-Dec-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.022	0.01330	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
4-Jan-05	88	2.1	2.4	7.7	ND<1	0.65	ND<1	0.0368	0.014	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
8-Feb-05	110	2.4	2.4	3.6	ND<1	ND<1	2.4	0.0279	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
15-Mar-05	120	2.3	6.0	6.6	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
19-Apr-05	74	ND<1	ND<1	7.0	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
16-Jun-05	69	1.6	13	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
14-Jul-05	64	1.6	9.5	ND<1	ND<1	ND<1	ND<1	0.067	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7*	
9-Aug-05	49	ND<1	12	ND<1	ND<1	ND<1	ND<1	0.0406	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
8-Sep-05	100	1.6	12	ND<1	ND<1	ND<1	ND<1	0.068	0.0366	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
19-Oct-05	NM	NM	NM	12	ND<1	ND<1	ND<1	1.3	0.0743	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
21-Nov-05	68	ND<1	ND<1	ND<1	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	
8-Dec-05	100	2.1	20	ND<1	ND<1	ND<1	ND<1	0.144	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
12-Jan-06	41	1.1	16	ND<1	ND<1	ND<1	ND<1	0.139	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
22-Feb-06	63	1.6	15	ND<1	ND<1	ND<1	ND<1	0.169	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
7-Mar-06	65	1.2	17	ND<1	ND<1	ND<1	ND<1	0.116	0.0155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
12-Apr-06	62	2.1	22	ND<1	ND<1	ND<1	2	0.0429	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
17-May-06	68	ND<1	18	ND<1	ND<1	ND<1	ND<1	0.24	0.0137	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
21-Jun-06	83	ND<1	20	ND<1	ND<1	ND<1	ND<1	0.17	0.019	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
20-Jul-06	45	1.5	24	ND<1	ND<1	ND<1	ND<1	0.075	0.025	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
24-Aug-06	30	ND<1	22	ND<1	ND<1	ND<1	ND<1	1.01	0.0169	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
19-Sep-06	46	ND<1	27	ND<1	ND<1	ND<1	ND<1	5.36	0.0563	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
24-Oct-06	45	1.2	15	ND<1	ND<1	ND<1	ND<1	0.916	0.0078	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
29-Nov-06	36	1.0	14	ND<1	ND<1	ND<1	ND<1	0.007	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
20-Dec-06	31	ND<1	13	ND<1	ND<1	ND<1	ND<1													

TABLE 4

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled ARAR's	PCE (ug/L) 5	TCE (ug/L) 5	TCA (ug/L) 5	Vinyl Acetate (ug/L) NE	Chloroform (ug/L) 7	MTBE (ug/L) NE	Total Iron (mg/L) 300	Dissolved Iron (mg/L) 300	1,1-Dichloro- ethane (ug/L) 5	cis-1,2-Dichloro- ethane (ug/L) 5	1,1-Dichloro- ethene (ug/L) 5	Methylene Chloride (ug/L) 5	Toluene (ug/L) NE	Dibromochloro- methane (ug/L) NE	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethyl- benzene (ug/L)	Acetone (ug/L) NE	
RW-7	4-Jan-05	37	1.1	ND<1	ND<1	ND<1	NE	0.0343	ND<0.02	ND<1	ND<1	ND<1	ND<1	NE	NE	ND<2	ND<1	ND<1	ND<1	
	8-Feb-05	45	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Apr-05	22	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	16-May-05	30	ND<1	ND<1	ND<1	ND<1	ND<1	0.023	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	16-Jun-05	32	ND<1	ND<1	ND<1	ND<1	ND<1	0.033	0.0152	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	7.2*	
	14-Jul-05	31	ND<1	ND<1	ND<1	ND<1	ND<1	0.0185	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	9-Aug-05	32	ND<1	ND<1	ND<1	ND<1	ND<1	0.0903	0.0409	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Sep-05	39	ND<1	ND<1	ND<1	ND<1	ND<1	0.0452	ND<0.02	1.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1
	21-Nov-05	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.536	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Dec-05	70	ND<1	12.0	ND<1	ND<1	ND<1	0.253	ND<0.02	4.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Jan-06	26	ND<1	5.0	ND<1	ND<1	ND<1	0.343	ND<0.02	2.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	14-Feb-06	36	ND<1	4.1	ND<1	ND<1	ND<1	0.0332	ND<0.02	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	7-Mar-06	38	ND<1	4.1	ND<1	ND<1	ND<1	0.143	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Apr-06	49	1.6	7.4	ND<1	ND<1	ND<1	0.0912	0.0175	3.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	17-May-06	59	ND<1	ND<1	ND<1	ND<1	ND<1	0.126	0.026	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	21-Jun-06	44	ND<1	4.6	ND<1	ND<1	ND<1	0.081	0.013	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1
	24-Aug-06	39	ND<1	7.9	ND<1	ND<1	ND<1	0.307	0.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
18-Sep-06	36	ND<1	7.5	ND<1	ND<1	ND<1	0.116	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
24-Oct-06	26	ND<1	3.5	ND<1	ND<1	ND<1	0.0692	0.0046	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
9-Nov-06	33	ND<1	4.1	ND<1	ND<1	ND<1	0.1910	0.04990	1.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
20-Dec-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	
10-Jan-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1	
8-Feb-07	43	ND<1	4.4	ND<1	ND<1	ND<1	ND<1	0.131	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
7-Mar-07	23	ND<1	2.7	ND<1	ND<1	ND<1	ND<1	0.0492	0.0221	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
18-Apr-07	34	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.138	0.0438	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
10-May-07	22	ND<1	2.3	ND<1	ND<1	ND<1	ND<1	0.111	0.0271	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
20-Jun-07	14	ND<1	1.7	ND<1	ND<1	ND<1	ND<1	0.136	0.0165	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
18-Jul-07	17	ND<1	2	ND<1	ND<1	ND<1	ND<1	0.434	0.0548	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
16-Aug-07	14	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	0.239	0.0250	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
12-Sep-07	24	ND<1	2	ND<1	ND<1	ND<1	ND<1	0.17	0.0800	0.68	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
3-Oct-07	25	0.73	2.8	ND<1	ND<1	ND<1	ND<1	0.194	0.2090	0.95	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
19-Nov-07	11	ND<1	1.1	ND<1	ND<1	ND<1	ND<1	0.163	0.0259	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
12-Dec-07	12	ND<1	1.4	ND<1	ND<1	ND<1	ND<1	0.172	0.0538	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
RW-8	4-Jan-05	6.9	1.3	3.9	ND<1	ND<1	ND<1	8.92	2.85	2.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Feb-05	7.4	ND<1	7.2	ND<1	ND<1	ND<1	8.24	ND<0.02	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	15-Mar-05	9.0	1.3	4.2	ND<1	ND<1	ND<1	7.54	0.075	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Apr-05	3.5	ND<1	3.5	ND<1	ND<1	ND<1	8.89	0.321	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	2-May-05	5.6	ND<1	5.2	ND<1	ND<1	ND<1	7.33	0.073	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	16-Jun-05	2.7	ND<1	5.8	ND<1	ND<1	ND<1	7.06	0.325	2.1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	14-Jul-05	2.6	ND<1	3.4	ND<1	ND<1	ND<1	8.33	0.017	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	8.2*	
	9-Aug-05	1.8	ND<1	2.9	ND<1	ND<1	ND<1	0.24	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Sep-05	2.9	ND<1	4.2	ND<1	ND<1	ND<1	7.53	0.255	2.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	ND<1
	21-Nov-05	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	7.65	0.106	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	8-Dec-05	2.4	ND<1	5.0	ND<1	ND<1	ND<1	5.19	0.021	3.2	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Jan-06	1.3	ND<1	3.7	ND<1	ND<1	ND<1	7.25	0.097	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	14-Feb-06	1.5	ND<1	3.0	ND<1	ND<1	ND<1	8.06	ND<0.02	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	7-Mar-06	1.3	ND<1	2.8	ND<1	ND<1	ND<1	8.33	0.064	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	12-Apr-06	2.1	0.9	4.5	ND<1	ND<1	ND<1	7.27	0.823	3.3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.03	0.056	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	21-Jun-06	ND<1	ND<1	2.8	ND<1	ND<1	ND<1	8.40	0.897	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	20-Jul-06	1.0	ND<1	4.0	ND<1	ND<1	ND<1	10.80	0.175	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
	24-Aug-06	ND<1	ND<1	3.2	ND<1	ND<1	ND<1	5.98	1.860	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1	
19-Sep-06	ND<1	ND<1	3.0	ND<1	ND<1	ND<1	7.44	0.009	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
24-Oct-06	0.9	ND<1	3.1	ND<1	ND<1	ND<1	8.32	0.0605	2.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
29-Nov-06	1.0	ND<1	3.4	ND<1	ND<1	ND<1	3.87	0.0091	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
20-Dec-06	ND<1	ND<1	3.5	ND<1	ND<1	ND<1	62.80	0.0346	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1		
10-Jan-07	1.3	ND<1	3.5	ND<1	ND<1	ND<1	6.57	0.8100	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	9.3	2.8	2.7	ND<1		
8-Feb-07	NM																			

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethane (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloroethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-9	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	NE	300	1.72	1.6	ND<1	ND<1	ND<1	NE	NE	ND<2	ND<1	ND<1	NE
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	1.55	0.307	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-06	ND<1	4.5	ND<1	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-06	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0966	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-06	ND<1	5.8	ND<1	ND<1	ND<1	ND<1	1.38	0.149	0.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-06	3.4	ND<1	ND<1	ND<1	ND<1	ND<1	2.95	0.238	ND<1	ND<1	ND<1	6.9*	ND<1	ND<1	ND<2	ND<1	ND<1	7.3*
	8-Aug-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	0.994	0.0734	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	9-Sep-06	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.64	0.161	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	9-Oct-06	NM	NM	NM	NM	NM	NM	1.31	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.31	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-06	ND<1	2.9	ND<1	ND<1	ND<1	ND<1	2.01	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	2.36	0.0605	ND<1	ND<1	ND<1	4.9*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	2.1	ND<1	1.8	ND<1	ND<1	ND<1	5.23	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.41	0.333	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	1.93	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.054	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-June-06	NM	NM	NM	NM	NM	NM	1.64	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.665	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0165	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND<0.02	ND<1	ND<1	ND<1	18*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	ND<1	1.5	ND<1	ND<1	ND<1	ND<1	6.96	0.00719	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	28-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.54	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	5.08	0.0655	ND<1	ND<1	ND<1	ND<1	1.4	ND<1	ND<2	ND<1	2.1	ND<1
	9-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.96	0.0076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	8.03	0.399	ND<1	ND<1	ND<1	6.2*	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	25-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.868	0.04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.59	0.0227	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.39	0.0250	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.33	0.4040	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.18	0.180	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.704	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.2	1.92	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

ND: Not detected
 <M: Less than method detection limit
 ug/L: Micrograms per liter
 -: Not analyzed
 ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site
 Bold values indicate an exceedance of the ARAR standard established for the site

PCE: Tetrachloroethylene
 TCE: Trichloroethene
 TCA: 1,1,1-Trichloroethane
 1,1-DCA: 1,1-Dichloroethane
 1,1-DCE: 1,1-Dichloroethene
 1,2-DCE: 1,2-Dichloroethene
 MTBE: Methyl Tertiary Butyl Ether
 NM: Not Measured

NE indicates that the ARAR goal was not established for this compound by the EPA
 *Concentrations with an asterisk following them are due to laboratory contamination
 -: RW-3 shutdown on December 5, 2007 to test response of water quality of RW-2.
 -: RW-9 was being rehabilitated during this sampling event, thus no water sample was collected
 -: RW-1 was shutdown on July 13, 2005 because water quality consistently met applicable quality criteria
 -: RW-3 was not operational during this time because drive programming was required to run the larger (2HP) motor that was installed following well rehabilitation in 2006.


GRAPHS

GRAPH 1

GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK


EFFLUENT FLOW DATA

(December 1, 2007 through December 31, 2007)




—◆— Daily Flow Total — Max Allowable (1,023,000 gpd)

GRAPH 2 GROUND-WATER REMEDIAL ACTION ROWE INDUSTRIES SUPERFUND SITE SAG HARBOR, NEW YORK



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
DECEMBER 2007 LABORATORY ANALYTICAL REPORTS

Thursday, December 13, 2007 (PM)

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe, Sag Harbor, NY

Order No.: 0712124

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 12/7/2007 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe, Sag Harbor, NY**Lab Order:** 0712124**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0712124-01A	WQ120507:1000NP2-6		12/5/2007 10:00:00 AM	12/7/2007
0712124-01B	WQ120507:1000NP2-6		12/5/2007 10:00:00 AM	12/7/2007
0712124-01C	WQ120507:1000NP2-6		12/5/2007 10:00:00 AM	12/7/2007
0712124-02A	WQ120507:1005NP2-7		12/5/2007 10:05:00 AM	12/7/2007
0712124-02B	WQ120507:1005NP2-7		12/5/2007 10:05:00 AM	12/7/2007
0712124-02C	WQ120507:1005NP2-7		12/5/2007 10:05:00 AM	12/7/2007
0712124-03A	WQ120507:1010NP2-10		12/5/2007 10:10:00 AM	12/7/2007
0712124-03B	WQ120507:1010NP2-10		12/5/2007 10:10:00 AM	12/7/2007
0712124-03C	WQ120507:1010NP2-10		12/5/2007 10:10:00 AM	12/7/2007



56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

NYS DOH 11418
CT DOH PH-0205
NJ DEP NY050
PA DEP 68-573

TAG # / COC _____

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS LBC, Inc. 4 Research Dr, Suite 301 Shelton, Ct 06484			CONTACT: MARK GOLDBERG			SAMPLER(S) SIGNATURE <i>Mark Goldberg</i>	SAMPLE(S) SEALED ☒ YES ☐ NO	
PROJECT LOCATION: Rte 1, Sag Harbor NY			ANALYSIS REQUIRED			SAMPLER NAME (PRINT) EVAN FOSTER	CORRECT CONTAINER(S) ☒ YES ☐ NO	
LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION				FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
0712124-01ABC	L	4	12.5.07 1000	1000NP2-6				
02349C	L	4	11 1005	1005NP2-7				
03349C	L	5	11 1010	1010NP2-10				
COOLER TEMPERATURE:								
COMMENTS / INSTRUCTIONS								
TURNAROUND REQUIRED: NORMAL ☒ STAT ☐ BY / /								
RELINQUISHED BY (SIGNATURE) <i>Kiffi Deak</i>		DATE/TIME 12/10/07 17:00		PRINTED NAME Kiffi Deak		RECEIVED BY LAB (SIGNATURE) <i>[Signature]</i>		
RELINQUISHED BY (SIGNATURE)		DATE/TIME		PRINTED NAME		RECEIVED BY LAB (SIGNATURE)		
						DATE/TIME 12/17/07 1030		
						PRINTED NAME Gary Eppich		
						DATE/TIME		
						PRINTED NAME		

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-01A

Client Sample ID: WQ120507:1000NP2-6
Tag Number:
Collection Date: 12/5/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,1,1-Trichloroethane	2.5	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
2-Butanone	U	3.0		µg/L	1	12/7/2007 8:31:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
2-Hexanone	U	2.0		µg/L	1	12/7/2007 8:31:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/7/2007 8:31:00 PM
Acetone	U	2.0		µg/L	1	12/7/2007 8:31:00 PM
Benzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Bromobenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Bromoform	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Bromomethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-01A

Client Sample ID: WQ120507:1000NP2-6
Tag Number:
Collection Date: 12/5/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Chloroform	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Chloromethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Dibromomethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/7/2007 8:31:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Methylene chloride	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Naphthalene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
o-Xylene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Styrene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Tetrachloroethene	3.8	1.0		µg/L	1	12/7/2007 8:31:00 PM
Toluene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Trichloroethene	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/7/2007 8:31:00 PM
Surr: 4-Bromofluorobenzene	88.3	54-134		%REC	1	12/7/2007 8:31:00 PM
Surr: Dibromofluoromethane	124	52-132		%REC	1	12/7/2007 8:31:00 PM
Surr: Toluene-d8	95.0	51-127		%REC	1	12/7/2007 8:31:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-01B

Client Sample ID: WQ120507:1000NP2-6
Tag Number:
Collection Date: 12/5/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.55	0.0200		mg/L	1	12/7/2007 2:21:01 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ120507:1000NP2-6

Lab Order: 0712124

Tag Number:

Project: Rowe, Sag Harbor, NY

Collection Date: 12/5/2007 10:00:00 AM

Lab ID: 0712124-01C

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0556	0.0200		mg/L	1	12/7/2007 2:18:57 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-02A

Client Sample ID: WQ120507:1005NP2-7
Tag Number:
Collection Date: 12/5/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
2-Butanone	U	3.0		µg/L	1	12/7/2007 9:00:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
2-Hexanone	U	2.0		µg/L	1	12/7/2007 9:00:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/7/2007 9:00:00 PM
Acetone	U	2.0		µg/L	1	12/7/2007 9:00:00 PM
Benzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Bromobenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Bromoform	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Bromomethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-02A

Client Sample ID: WQ120507:1005NP2-7
Tag Number:
Collection Date: 12/5/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Chloroform	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Chloromethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Dibromomethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/7/2007 9:00:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Methylene chloride	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Naphthalene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
o-Xylene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Styrene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Toluene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Trichloroethene	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/7/2007 9:00:00 PM
Surr: 4-Bromofluorobenzene	93.0	54-134		%REC	1	12/7/2007 9:00:00 PM
Surr: Dibromofluoromethane	123	52-132		%REC	1	12/7/2007 9:00:00 PM
Surr: Toluene-d8	97.5	51-127		%REC	1	12/7/2007 9:00:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-02B

Client Sample ID: WQ120507:1005NP2-7
Tag Number:
Collection Date: 12/5/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.05	0.0200		mg/L	1	12/7/2007 2:25:07 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-02C

Client Sample ID: WQ120507:1005NP2-7
Tag Number:
Collection Date: 12/5/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0913	0.0200		mg/L	1	12/7/2007 2:23:04 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-03A

Client Sample ID: WQ120507:1010NP2-10
Tag Number:
Collection Date: 12/5/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
2-Butanone	U	3.0		µg/L	1	12/7/2007 9:27:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
2-Hexanone	U	2.0		µg/L	1	12/7/2007 9:27:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/7/2007 9:27:00 PM
Acetone	U	2.0		µg/L	1	12/7/2007 9:27:00 PM
Benzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Bromobenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Bromoform	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Bromomethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-03A

Client Sample ID: WQ120507:1010NP2-10
Tag Number:
Collection Date: 12/5/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Chloroform	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Chloromethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Dibromomethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/7/2007 9:27:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Methylene chloride	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Naphthalene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
o-Xylene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Styrene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Toluene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Trichloroethene	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/7/2007 9:27:00 PM
Surr: 4-Bromofluorobenzene	87.0	54-134		%REC	1	12/7/2007 9:27:00 PM
Surr: Dibromofluoromethane	129	52-132		%REC	1	12/7/2007 9:27:00 PM
Surr: Toluene-d8	95.7	51-127		%REC	1	12/7/2007 9:27:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-03B

Client Sample ID: WQ120507:1010NP2-10
Tag Number:
Collection Date: 12/5/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.29	0.0200		mg/L	1	12/7/2007 2:29:12 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712124
Project: Rowe, Sag Harbor, NY
Lab ID: 0712124-03C

Client Sample ID: WQ120507:1010NP2-10
Tag Number:
Collection Date: 12/5/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.173	0.0200		mg/L	1	12/7/2007 2:27:10 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	138	1.00		mg/L	1	12/11/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, December 19, 2007 *pm*

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe, Sag Harbor, NY

Order No.: 0712290

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 12/14/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Project:** Rowe, Sag Harbor, NY**Lab Order:** 0712290**Work Order Sample Summary**

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0712290-01A	WQ121207:NP2-6		12/12/2007	12/14/2007
0712290-01B	WQ121207:NP2-6		12/12/2007	12/14/2007
0712290-01C	WQ121207:NP2-6		12/12/2007	12/14/2007
0712290-02A	WQ121207:NP2-7		12/12/2007	12/14/2007
0712290-02B	WQ121207:NP2-7		12/12/2007	12/14/2007
0712290-02C	WQ121207:NP2-7		12/12/2007	12/14/2007
0712290-03A	WQ121207:NP2-10		12/12/2007	12/14/2007
0712290-03B	WQ121207:NP2-10		12/12/2007	12/14/2007
0712290-03C	WQ121207:NP2-10		12/12/2007	12/14/2007

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712290
Project: Rowe, Sag Harbor, NY
Lab ID: 0712290-01A

Client Sample ID: WQ121207:NP2-6
Tag Number:
Collection Date: 12/12/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,1,1-Trichloroethane	2.2	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,1-Dichloroethane	0.61	1.0	J	µg/L	1	12/15/2007 7:27:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
2-Butanone	U	3.0		µg/L	1	12/15/2007 7:27:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 7:27:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 7:27:00 AM
Acetone	U	2.0		µg/L	1	12/15/2007 7:27:00 AM
Benzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Bromoform	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Bromomethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712290
Project: Rowe, Sag Harbor, NY
Lab ID: 0712290-01A

Client Sample ID: WQ121207:NP2-6
Tag Number:
Collection Date: 12/12/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Chloroform	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Chloromethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 7:27:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Naphthalene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
o-Xylene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Styrene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Tetrachloroethene	5.1	1.0		µg/L	1	12/15/2007 7:27:00 AM
Toluene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Trichloroethene	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 7:27:00 AM
Surr: 4-Bromofluorobenzene	91.5	54-134		%REC	1	12/15/2007 7:27:00 AM
Surr: Dibromofluoromethane	87.1	52-132		%REC	1	12/15/2007 7:27:00 AM
Surr: Toluene-d8	98.6	51-127		%REC	1	12/15/2007 7:27:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ121207:NP2-6**Lab Order:** 0712290**Tag Number:****Project:** Rowe, Sag Harbor, NY**Collection Date:** 12/12/2007**Lab ID:** 0712290-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.98	0.0200		mg/L	1	12/17/2007 11:02:54 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ121207:NP2-6**Lab Order:** 0712290**Tag Number:****Project:** Rowe, Sag Harbor, NY**Collection Date:** 12/12/2007**Lab ID:** 0712290-01C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0720	0.0200		mg/L	1	12/17/2007 11:00:51 AM

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712290
Project: Rowe, Sag Harbor, NY
Lab ID: 0712290-02A

Client Sample ID: WQ121207:NP2-7
Tag Number:
Collection Date: 12/12/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
2-Butanone	U	3.0		µg/L	1	12/15/2007 7:55:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 7:55:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 7:55:00 AM
Acetone	U	2.0		µg/L	1	12/15/2007 7:55:00 AM
Benzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Bromoform	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Bromomethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712290
Project: Rowe, Sag Harbor, NY
Lab ID: 0712290-02A

Client Sample ID: WQ121207:NP2-7
Tag Number:
Collection Date: 12/12/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Chloroform	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Chloromethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 7:55:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Naphthalene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
o-Xylene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Styrene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Toluene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Trichloroethene	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 7:55:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	12/15/2007 7:55:00 AM
Surr: Dibromofluoromethane	106	52-132		%REC	1	12/15/2007 7:55:00 AM
Surr: Toluene-d8	93.4	51-127		%REC	1	12/15/2007 7:55:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ121207:NP2-7**Lab Order:** 0712290**Tag Number:****Project:** Rowe, Sag Harbor, NY**Collection Date:** 12/12/2007**Lab ID:** 0712290-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	0.994	0.0200		mg/L	1	12/17/2007 11:07:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ121207:NP2-7**Lab Order:** 0712290**Tag Number:****Project:** Rowe, Sag Harbor, NY**Collection Date:** 12/12/2007**Lab ID:** 0712290-02C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0986	0.0200		mg/L	1	12/17/2007 11:04:58 AM

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712290
Project: Rowe, Sag Harbor, NY
Lab ID: 0712290-03A

Client Sample ID: WQ121207:NP2-10
Tag Number:
Collection Date: 12/12/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
2-Butanone	U	3.0		µg/L	1	12/15/2007 8:23:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 8:23:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 8:23:00 AM
Acetone	U	2.0		µg/L	1	12/15/2007 8:23:00 AM
Benzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Bromoform	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Bromomethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712290
Project: Rowe, Sag Harbor, NY
Lab ID: 0712290-03A

Client Sample ID: WQ121207:NP2-10
Tag Number:
Collection Date: 12/12/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Chloroform	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Chloromethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 8:23:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Naphthalene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
o-Xylene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Styrene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Toluene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Trichloroethene	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 8:23:00 AM
Surr: 4-Bromofluorobenzene	96.4	54-134		%REC	1	12/15/2007 8:23:00 AM
Surr: Dibromofluoromethane	88.8	52-132		%REC	1	12/15/2007 8:23:00 AM
Surr: Toluene-d8	96.7	51-127		%REC	1	12/15/2007 8:23:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712290
Project: Rowe, Sag Harbor, NY
Lab ID: 0712290-03B

Client Sample ID: WQ121207:NP2-10
Tag Number:
Collection Date: 12/12/2007
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.21	0.0200		mg/L	1	12/17/2007 11:11:07 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ121207:NP2-10**Lab Order:** 0712290**Tag Number:****Project:** Rowe, Sag Harbor, NY**Collection Date:** 12/12/2007**Lab ID:** 0712290-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.104	0.0200		mg/L	1	12/17/2007 11:09:03 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	126	1.00		mg/L	1	12/19/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, December 27, 2007 (pm)

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: 1668 B Hampton, Sag Harbor Tpke, Sag Ha

Order No.: 0712363

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 12/20/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.**Date:** 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Project: 1668 B Hampton, Sag Harbor Tpke, Sag Harbor,
Lab Order: 0712363

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0712363-01A	WQ122007:1000NP2-6		12/20/2007 10:00:00 AM	12/20/2007
0712363-01B	WQ122007:1000NP2-6		12/20/2007 10:00:00 AM	12/20/2007
0712363-01C	WQ122007:1000NP2-6		12/20/2007 10:00:00 AM	12/20/2007
0712363-02A	WQ122007:1005NP2-7		12/20/2007 10:05:00 AM	12/20/2007
0712363-02B	WQ122007:1005NP2-7		12/20/2007 10:05:00 AM	12/20/2007
0712363-02C	WQ122007:1005NP2-7		12/20/2007 10:05:00 AM	12/20/2007
0712363-03A	WQ122007:1010NP2-10		12/20/2007 10:10:00 AM	12/20/2007
0712363-03B	WQ122007:1010NP2-10		12/20/2007 10:10:00 AM	12/20/2007
0712363-03C	WQ122007:1010NP2-10		12/20/2007 10:10:00 AM	12/20/2007

56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122007:1000NP2-6
Lab Order: 0712363 **Tag Number:**
Project: 1668 B Hampton, Sag Harbor Tpke, Sag Harbor, **Collection Date:** 12/20/2007 10:00:00 AM
Lab ID: 0712363-01A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
2-Butanone	U	3.0		µg/L	1	12/21/2007 6:44:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
2-Hexanone	U	2.0		µg/L	1	12/21/2007 6:44:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/21/2007 6:44:00 PM
Acetone	U	2.0		µg/L	1	12/21/2007 6:44:00 PM
Benzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Bromobenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Bromoform	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Bromomethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122007:1000NP2-6
Lab Order: 0712363 **Tag Number:**
Project: 1668 B Hampton, Sag Harbor Tpke, Sag Harbor, **Collection Date:** 12/20/2007 10:00:00 AM
Lab ID: 0712363-01A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Chloroform	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Chloromethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Dibromomethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/21/2007 6:44:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Methylene chloride	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Naphthalene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
o-Xylene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Styrene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Tetrachloroethene	3.6	1.0		µg/L	1	12/21/2007 6:44:00 PM
Toluene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Trichloroethene	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/21/2007 6:44:00 PM
Surr: 4-Bromofluorobenzene	105	54-134		%REC	1	12/21/2007 6:44:00 PM
Surr: Dibromofluoromethane	91.8	52-132		%REC	1	12/21/2007 6:44:00 PM
Surr: Toluene-d8	98.2	51-127		%REC	1	12/21/2007 6:44:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122007:1000NP2-6
Lab Order:	0712363	Tag Number:	
Project:	1668 B Hampton, Sag Harbor Tpke, Sag Harbor,	Collection Date:	12/20/2007 10:00:00 AM
Lab ID:	0712363-01B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	85.2	0.0200		mg/L	1	12/26/2007 11:20:44 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ122007:1000NP2-6**Lab Order:** 0712363**Tag Number:****Project:** 1668 B Hampton, Sag Harbor Tpke, Sag Harbor,**Collection Date:** 12/20/2007 10:00:00 AM**Lab ID:** 0712363-01C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.676	0.0200		mg/L	1	12/26/2007 11:18:40 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122007:1005NP2-7
Lab Order:	0712363	Tag Number:	
Project:	1668 B Hampton, Sag Harbor Tpke, Sag Harbor,	Collection Date:	12/20/2007 10:05:00 AM
Lab ID:	0712363-02A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
2-Butanone	U	3.0		µg/L	1	12/21/2007 7:19:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
2-Hexanone	U	2.0		µg/L	1	12/21/2007 7:19:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/21/2007 7:19:00 PM
Acetone	U	2.0		µg/L	1	12/21/2007 7:19:00 PM
Benzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Bromobenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Bromoform	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Bromomethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122007:1005NP2-7
Lab Order: 0712363 **Tag Number:**
Project: 1668 B Hampton, Sag Harbor Tpke, Sag Harbor, **Collection Date:** 12/20/2007 10:05:00 AM
Lab ID: 0712363-02A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Chloroform	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Chloromethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Dibromomethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/21/2007 7:19:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Methylene chloride	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Naphthalene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
o-Xylene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Styrene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Toluene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Trichloroethene	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/21/2007 7:19:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	12/21/2007 7:19:00 PM
Surr: Dibromofluoromethane	92.9	52-132		%REC	1	12/21/2007 7:19:00 PM
Surr: Toluene-d8	100	51-127		%REC	1	12/21/2007 7:19:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ122007:1005NP2-7**Lab Order:** 0712363**Tag Number:****Project:** 1668 B Hampton, Sag Harbor Tpke, Sag Harbor,**Collection Date:** 12/20/2007 10:05:00 AM**Lab ID:** 0712363-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	21.7	0.0200		mg/L	1	12/26/2007 11:24:50 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ122007:1005NP2-7**Lab Order:** 0712363**Tag Number:****Project:** 1668 B Hampton, Sag Harbor Tpke, Sag Harbor,**Collection Date:** 12/20/2007 10:05:00 AM**Lab ID:** 0712363-02C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.467	0.0200		mg/L	1	12/26/2007 11:22:47 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ122007:1010NP2-10
Lab Order:	0712363	Tag Number:	
Project:	1668 B Hampton, Sag Harbor Tpke, Sag Harbor,	Collection Date:	12/20/2007 10:10:00 AM
Lab ID:	0712363-03A	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
2-Butanone	U	3.0		µg/L	1	12/21/2007 7:54:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
2-Hexanone	U	2.0		µg/L	1	12/21/2007 7:54:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/21/2007 7:54:00 PM
Acetone	U	2.0		µg/L	1	12/21/2007 7:54:00 PM
Benzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Bromobenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Bromoform	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Bromomethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc. **Client Sample ID:** WQ122007:1010NP2-10
Lab Order: 0712363 **Tag Number:**
Project: 1668 B Hampton, Sag Harbor Tpke, Sag Harbor, **Collection Date:** 12/20/2007 10:10:00 AM
Lab ID: 0712363-03A **Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Chloroform	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Chloromethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Dibromomethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/21/2007 7:54:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Methylene chloride	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Naphthalene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
o-Xylene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Styrene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Tetrachloroethene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Toluene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Trichloroethene	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/21/2007 7:54:00 PM
Surr: 4-Bromofluorobenzene	103	54-134		%REC	1	12/21/2007 7:54:00 PM
Surr: Dibromofluoromethane	93.3	52-132		%REC	1	12/21/2007 7:54:00 PM
Surr: Toluene-d8	100	51-127		%REC	1	12/21/2007 7:54:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ122007:1010NP2-10**Lab Order:** 0712363**Tag Number:****Project:** 1668 B Hampton, Sag Harbor Tpke, Sag Harbor,**Collection Date:** 12/20/2007 10:10:00 AM**Lab ID:** 0712363-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	55.1	0.0200		mg/L	1	12/26/2007 11:28:54 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level


American Analytical Laboratories, LLC.

Date: 27-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ122007:1010NP2-10**Lab Order:** 0712363**Tag Number:****Project:** 1668 B Hampton, Sag Harbor Tpke, Sag Harbor,**Collection Date:** 12/20/2007 10:10:00 AM**Lab ID:** 0712363-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	1.65	0.0200		mg/L	1	12/26/2007 11:26:53 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	114	1.00		mg/L	1	12/26/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, January 03, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe Sag Harbor, NY

Order No.: 0712418

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 12/28/2007 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe Sag Harbor, NY
Lab Order: 0712418

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0712418-01A	WQ122707:1000NP2-6		12/27/2007 10:00:00 AM	12/28/2007
0712418-01B	WQ122707:1000NP2-6		12/27/2007 10:00:00 AM	12/28/2007
0712418-01C	WQ122707:1000NP2-6		12/27/2007 10:00:00 AM	12/28/2007
0712418-02A	WQ122707:1005NP2-7		12/27/2007 10:05:00 AM	12/28/2007
0712418-02B	WQ122707:1005NP2-7		12/27/2007 10:05:00 AM	12/28/2007
0712418-02C	WQ122707:1005NP2-7		12/27/2007 10:05:00 AM	12/28/2007
0712418-03A	WQ122707:1010NP2-10		12/27/2007 10:10:00 AM	12/28/2007
0712418-03B	WQ122707:1010NP2-10		12/27/2007 10:10:00 AM	12/28/2007
0712418-03C	WQ122707:1010NP2-10		12/27/2007 10:10:00 AM	12/28/2007

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712418
Project: Rowe Sag Harbor, NY
Lab ID: 0712418-01A

Client Sample ID: WQ122707:1000NP2-6
Tag Number:
Collection Date: 12/27/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,1,1-Trichloroethane	1.5	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
2-Butanone	U	3.0		µg/L	1	12/29/2007 4:21:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
2-Hexanone	U	2.0		µg/L	1	12/29/2007 4:21:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/29/2007 4:21:00 AM
Acetone	U	2.0		µg/L	1	12/29/2007 4:21:00 AM
Benzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Bromobenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Bromoform	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Bromomethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712418
Project: Rowe Sag Harbor, NY
Lab ID: 0712418-01A

Client Sample ID: WQ122707:1000NP2-6
Tag Number:
Collection Date: 12/27/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Chloroform	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Chloromethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Dibromomethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/29/2007 4:21:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Methylene chloride	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Naphthalene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
o-Xylene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Styrene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Tetrachloroethene	3.8	1.0		µg/L	1	12/29/2007 4:21:00 AM
Toluene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Trichloroethene	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/29/2007 4:21:00 AM
Surr: 4-Bromofluorobenzene	98.1	54-134		%REC	1	12/29/2007 4:21:00 AM
Surr: Dibromofluoromethane	99.4	52-132		%REC	1	12/29/2007 4:21:00 AM
Surr: Toluene-d8	95.0	51-127		%REC	1	12/29/2007 4:21:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ122707:1000NP2-6

Lab Order: 0712418

Tag Number:

Project: Rowe Sag Harbor, NY

Collection Date: 12/27/2007 10:00:00 AM

Lab ID: 0712418-01B

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.36	0.0200		mg/L	1	1/3/2008 10:28:27 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712418
Project: Rowe Sag Harbor, NY
Lab ID: 0712418-01C

Client Sample ID: WQ122707:1000NP2-6
Tag Number:
Collection Date: 12/27/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0700	0.0200		mg/L	1	1/3/2008 10:26:23 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712418
Project: Rowe Sag Harbor, NY
Lab ID: 0712418-02A

Client Sample ID: WQ122707:1005NP2-7
Tag Number:
Collection Date: 12/27/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
2-Butanone	U	3.0		µg/L	1	12/29/2007 4:48:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
2-Hexanone	U	2.0		µg/L	1	12/29/2007 4:48:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/29/2007 4:48:00 AM
Acetone	U	2.0		µg/L	1	12/29/2007 4:48:00 AM
Benzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Bromobenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Bromoform	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Bromomethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712418
Project: Rowe Sag Harbor, NY
Lab ID: 0712418-02A

Client Sample ID: WQ122707:1005NP2-7
Tag Number:
Collection Date: 12/27/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Chloroform	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Chloromethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Dibromomethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/29/2007 4:48:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Methylene chloride	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Naphthalene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
o-Xylene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Styrene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Toluene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Trichloroethene	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/29/2007 4:48:00 AM
Surr: 4-Bromofluorobenzene	94.6	54-134		%REC	1	12/29/2007 4:48:00 AM
Surr: Dibromofluoromethane	103	52-132		%REC	1	12/29/2007 4:48:00 AM
Surr: Toluene-d8	93.5	51-127		%REC	1	12/29/2007 4:48:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ122707:1005NP2-7**Lab Order:** 0712418**Tag Number:****Project:** Rowe Sag Harbor, NY**Collection Date:** 12/27/2007 10:05:00 AM**Lab ID:** 0712418-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.36	0.0200		mg/L	1	1/3/2008 10:32:32 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ122707:1005NP2-7**Lab Order:** 0712418**Tag Number:****Project:** Rowe Sag Harbor, NY**Collection Date:** 12/27/2007 10:05:00 AM**Lab ID:** 0712418-02C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.154	0.0200		mg/L	1	1/3/2008 10:30:29 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712418
Project: Rowe Sag Harbor, NY
Lab ID: 0712418-03A

Client Sample ID: WQ122707:1010NP2-10
Tag Number:
Collection Date: 12/27/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
2-Butanone	U	3.0		µg/L	1	12/29/2007 5:14:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
2-Hexanone	U	2.0		µg/L	1	12/29/2007 5:14:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/29/2007 5:14:00 AM
Acetone	U	2.0		µg/L	1	12/29/2007 5:14:00 AM
Benzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Bromobenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Bromoform	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Bromomethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712418
Project: Rowe Sag Harbor, NY
Lab ID: 0712418-03A

Client Sample ID: WQ122707:1010NP2-10
Tag Number:
Collection Date: 12/27/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Chloroform	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Chloromethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Dibromomethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/29/2007 5:14:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Methylene chloride	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Naphthalene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
o-Xylene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Styrene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Toluene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Trichloroethene	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/29/2007 5:14:00 AM
Surr: 4-Bromofluorobenzene	100	54-134		%REC	1	12/29/2007 5:14:00 AM
Surr: Dibromofluoromethane	107	52-132		%REC	1	12/29/2007 5:14:00 AM
Surr: Toluene-d8	91.0	51-127		%REC	1	12/29/2007 5:14:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ122707:1010NP2-10**Lab Order:** 0712418**Tag Number:****Project:** Rowe Sag Harbor, NY**Collection Date:** 12/27/2007 10:10:00 AM**Lab ID:** 0712418-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.08	0.0200		mg/L	1	1/3/2008 10:36:37 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712418
Project: Rowe Sag Harbor, NY
Lab ID: 0712418-03C

Client Sample ID: WQ122707:1010NP2-10
Tag Number:
Collection Date: 12/27/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.104	0.0200		mg/L	1	1/3/2008 10:34:35 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	128	1.00		mg/L	1	1/3/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, December 19, 2007

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe, Sag Harbor

Order No.: 0712291

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 7 sample(s) on 12/14/2007 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe, Sag Harbor
Lab Order: 0712291

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0712291-01A	GWQ121207:1000NP1-1-5		12/12/2007 10:00:00 AM	12/14/2007
0712291-01B	GWQ121207:1000NP1-1-5		12/12/2007 10:00:00 AM	12/14/2007
0712291-01C	GWQ121207:1000NP1-1-5		12/12/2007 10:00:00 AM	12/14/2007
0712291-02A	GWQ121207:1005NP1-1-6		12/12/2007 10:05:00 AM	12/14/2007
0712291-02B	GWQ121207:1005NP1-1-6		12/12/2007 10:05:00 AM	12/14/2007
0712291-02C	GWQ121207:1005NP1-1-6		12/12/2007 10:05:00 AM	12/14/2007
0712291-03A	GWQ121207:1010NP1-1-7		12/12/2007 10:10:00 AM	12/14/2007
0712291-03B	GWQ121207:1010NP1-1-7		12/12/2007 10:10:00 AM	12/14/2007
0712291-03C	GWQ121207:1010NP1-1-7		12/12/2007 10:10:00 AM	12/14/2007
0712291-04A	GWQ121207:1015NP1-1-8		12/12/2007 10:15:00 AM	12/14/2007
0712291-04B	GWQ121207:1015NP1-1-8		12/12/2007 10:15:00 AM	12/14/2007
0712291-04C	GWQ121207:1015NP1-1-8		12/12/2007 10:15:00 AM	12/14/2007
0712291-05A	GWQ121207:1020NP1-1-9		12/12/2007 10:20:00 AM	12/14/2007
0712291-05B	GWQ121207:1020NP1-1-9		12/12/2007 10:20:00 AM	12/14/2007
0712291-05C	GWQ121207:1020NP1-1-9		12/12/2007 10:20:00 AM	12/14/2007
0712291-06A	GWQ121207:1025NP1-1-4		12/12/2007 10:25:00 AM	12/14/2007
0712291-06B	GWQ121207:1025NP1-1-4		12/12/2007 10:25:00 AM	12/14/2007
0712291-06C	GWQ121207:1025NP1-1-4		12/12/2007 10:25:00 AM	12/14/2007
0712291-07A	GWQ121207:1030NP1-1-2		12/12/2007 10:30:00 AM	12/14/2007
0712291-07B	GWQ121207:1030NP1-1-2		12/12/2007 10:30:00 AM	12/14/2007
0712291-07C	GWQ121207:1030NP1-1-2		12/12/2007 10:30:00 AM	12/14/2007

56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027 • email: AAL20000@

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-01A

Client Sample ID: GWQ121207:1000NP1-1-5
Tag Number:
Collection Date: 12/12/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,1,1-Trichloroethane	0.61	1.0	J	µg/L	1	12/15/2007 9:47:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
2-Butanone	U	3.0		µg/L	1	12/15/2007 9:47:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 9:47:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 9:47:00 AM
Acetone	U	2.0		µg/L	1	12/15/2007 9:47:00 AM
Benzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Bromoform	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Bromomethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-01A

Client Sample ID: GWQ121207:1000NP1-1-5
Tag Number:
Collection Date: 12/12/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Chloroform	0.65	1.0	J	µg/L	1	12/15/2007 9:47:00 AM
Chloromethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 9:47:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Naphthalene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
o-Xylene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Styrene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Toluene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Trichloroethene	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 9:47:00 AM
Surr: 4-Bromofluorobenzene	96.9	54-134		%REC	1	12/15/2007 9:47:00 AM
Surr: Dibromofluoromethane	109	52-132		%REC	1	12/15/2007 9:47:00 AM
Surr: Toluene-d8	92.3	51-127		%REC	1	12/15/2007 9:47:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-01B

Client Sample ID: GWQ121207:1000NP1-1-5
Tag Number:
Collection Date: 12/12/2007 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.0368	0.0200		mg/L	1	12/17/2007 11:23:20 AM
Manganese	0.00836	0.0200	J	mg/L	1	12/17/2007 11:23:20 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ121207:1000NP1-1-5

Lab Order: 0712291

Tag Number:

Project: Rowe, Sag Harbor

Collection Date: 12/12/2007 10:00:00 AM

Lab ID: 0712291-01C

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0140	0.0200	J	mg/L	1	12/17/2007 11:21:16 AM
Manganese	0.00685	0.0200	J	mg/L	1	12/17/2007 11:21:16 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	192	1.00		mg/L	1	12/19/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-02A

Client Sample ID: GWQ121207:1005NP1-1-6
Tag Number:
Collection Date: 12/12/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,1,1-Trichloroethane	7.5	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,1-Dichloroethane	0.68	1.0	J	µg/L	1	12/15/2007 10:14:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
2-Butanone	U	3.0		µg/L	1	12/15/2007 10:14:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 10:14:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 10:14:00 AM
Acetone	U	2.0		µg/L	1	12/15/2007 10:14:00 AM
Benzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Bromoform	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Bromomethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-02A

Client Sample ID: GWQ121207:1005NP1-1-6
Tag Number:
Collection Date: 12/12/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Chloroform	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Chloromethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 10:14:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Naphthalene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
o-Xylene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Styrene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Tetrachloroethene	25	1.0		µg/L	1	12/15/2007 10:14:00 AM
Toluene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Trichloroethene	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 10:14:00 AM
Surr: 4-Bromofluorobenzene	94.0	54-134		%REC	1	12/15/2007 10:14:00 AM
Surr: Dibromofluoromethane	89.8	52-132		%REC	1	12/15/2007 10:14:00 AM
Surr: Toluene-d8	95.3	51-127		%REC	1	12/15/2007 10:14:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-02B

Client Sample ID: GWQ121207:1005NP1-1-6
Tag Number:
Collection Date: 12/12/2007 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.0567	0.0200		mg/L	1	12/17/2007 11:27:27 AM
Manganese	0.178	0.0200		mg/L	1	12/17/2007 11:27:27 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ121207:1005NP1-1-6

Lab Order: 0712291

Tag Number:

Project: Rowe, Sag Harbor

Collection Date: 12/12/2007 10:05:00 AM

Lab ID: 0712291-02C

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0282	0.0200		mg/L	1	12/17/2007 11:25:23 AM
Manganese	0.148	0.0200		mg/L	1	12/17/2007 11:25:23 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	152	1.00		mg/L	1	12/19/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-03A

Client Sample ID: GWQ121207:1010NP1-1-7
Tag Number:
Collection Date: 12/12/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,1,1-Trichloroethane	1.4	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,1-Dichloroethane	1.3	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
2-Butanone	U	3.0		µg/L	1	12/15/2007 10:43:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 10:43:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 10:43:00 AM
Acetone	U	2.0		µg/L	1	12/15/2007 10:43:00 AM
Benzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Bromoform	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Bromomethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-03A

Client Sample ID: GWQ121207:1010NP1-1-7
Tag Number:
Collection Date: 12/12/2007 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Chloroform	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Chloromethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 10:43:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Naphthalene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
o-Xylene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Styrene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Tetrachloroethene	12	1.0		µg/L	1	12/15/2007 10:43:00 AM
Toluene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Trichloroethene	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 10:43:00 AM
Surr: 4-Bromofluorobenzene	100	54-134		%REC	1	12/15/2007 10:43:00 AM
Surr: Dibromofluoromethane	107	52-132		%REC	1	12/15/2007 10:43:00 AM
Surr: Toluene-d8	92.8	51-127		%REC	1	12/15/2007 10:43:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ121207:1010NP1-1-7**Lab Order:** 0712291**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 12/12/2007 10:10:00 AM**Lab ID:** 0712291-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.172	0.0200		mg/L	1	12/17/2007 11:31:33 AM
Manganese	0.0901	0.0200		mg/L	1	12/17/2007 11:31:33 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 19-Dec-07**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ121207:1010NP1-1-7**Lab Order:** 0712291**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 12/12/2007 10:10:00 AM**Lab ID:** 0712291-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0538	0.0200		mg/L	1	12/17/2007 11:29:30 AM
Manganese	0.0562	0.0200		mg/L	1	12/17/2007 11:29:30 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	134	1.00		mg/L	1	12/19/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-04A

Client Sample ID: GWQ121207:1015NP1-1-8
Tag Number:
Collection Date: 12/12/2007 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,1,1-Trichloroethane	1.3	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,1-Dichloroethane	1.3	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
2-Butanone	U	3.0		µg/L	1	12/15/2007 11:10:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 11:10:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 11:10:00 AM
Acetone	U	2.0		µg/L	1	12/15/2007 11:10:00 AM
Benzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Bromoform	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Bromomethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-04A

Client Sample ID: GWQ121207:1015NP1-1-8
Tag Number:
Collection Date: 12/12/2007 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Chloroform	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Chloromethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 11:10:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Naphthalene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
o-Xylene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Styrene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Toluene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Trichloroethene	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 11:10:00 AM
Surr: 4-Bromofluorobenzene	97.4	54-134		%REC	1	12/15/2007 11:10:00 AM
Surr: Dibromofluoromethane	90.7	52-132		%REC	1	12/15/2007 11:10:00 AM
Surr: Toluene-d8	96.0	51-127		%REC	1	12/15/2007 11:10:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-04B

Client Sample ID: GWQ121207:1015NP1-1-8
Tag Number:
Collection Date: 12/12/2007 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	7.87	0.0200		mg/L	1	12/17/2007 11:35:39 AM
Manganese	0.706	0.0200		mg/L	1	12/17/2007 11:35:39 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ121207:1015NP1-I-8**Lab Order:** 0712291**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 12/12/2007 10:15:00 AM**Lab ID:** 0712291-04C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	3.02	0.0200		mg/L	1	12/17/2007 11:33:36 AM
Manganese	0.602	0.0200		mg/L	1	12/17/2007 11:33:36 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	116	1.00		mg/L	1	12/19/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-05A

Client Sample ID: GWQ121207:1020NP1-1-9
Tag Number:
Collection Date: 12/12/2007 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
2-Butanone	U	3.0		µg/L	1	12/15/2007 11:37:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 11:37:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 11:37:00 AM
Acetone	U	2.0		µg/L	1	12/15/2007 11:37:00 AM
Benzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Bromoform	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Bromomethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-05A

Client Sample ID: GWQ121207:1020NP1-1-9
Tag Number:
Collection Date: 12/12/2007 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Chloroform	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Chloromethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 11:37:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Naphthalene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
o-Xylene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Styrene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Tetrachloroethene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Toluene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Trichloroethene	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 11:37:00 AM
Surr: 4-Bromofluorobenzene	100	54-134		%REC	1	12/15/2007 11:37:00 AM
Surr: Dibromofluoromethane	106	52-132		%REC	1	12/15/2007 11:37:00 AM
Surr: Toluene-d8	91.4	51-127		%REC	1	12/15/2007 11:37:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ121207:1020NP1-1-9

Lab Order: 0712291

Tag Number:

Project: Rowe, Sag Harbor

Collection Date: 12/12/2007 10:20:00 AM

Lab ID: 0712291-05B

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	3.20	0.0200		mg/L	1	12/17/2007 11:39:46 AM
Manganese	0.622	0.0200		mg/L	1	12/17/2007 11:39:46 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-05C

Client Sample ID: GWQ121207:1020NP1-1-9
Tag Number:
Collection Date: 12/12/2007 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	1.92	0.0200		mg/L	1	12/17/2007 11:37:42 AM
Manganese	0.532	0.0200		mg/L	1	12/17/2007 11:37:42 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	118	1.00		mg/L	1	12/19/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-06A

Client Sample ID: GWQ121207:1025NP1-1-4
Tag Number:
Collection Date: 12/12/2007 10:25:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,1,1-Trichloroethane	4.6	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
2-Butanone	U	3.0		µg/L	1	12/15/2007 12:06:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 12:06:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 12:06:00 PM
Acetone	U	2.0		µg/L	1	12/15/2007 12:06:00 PM
Benzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Bromoform	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Bromomethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-06A

Client Sample ID: GWQ121207:1025NPI-1-4
Tag Number:
Collection Date: 12/12/2007 10:25:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Chloroform	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Chloromethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 12:06:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Naphthalene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
o-Xylene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Styrene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Tetrachloroethene	7.7	1.0		µg/L	1	12/15/2007 12:06:00 PM
Toluene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Trichloroethene	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 12:06:00 PM
Surr: 4-Bromofluorobenzene	91.4	54-134		%REC	1	12/15/2007 12:06:00 PM
Surr: Dibromofluoromethane	89.8	52-132		%REC	1	12/15/2007 12:06:00 PM
Surr: Toluene-d8	97.4	51-127		%REC	1	12/15/2007 12:06:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: GWQ121207:1025NP1-1-4

Lab Order: 0712291

Tag Number:

Project: Rowe, Sag Harbor

Collection Date: 12/12/2007 10:25:00 AM

Lab ID: 0712291-06B

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	4.47	0.0200		mg/L	1	12/17/2007 11:51:22 AM
Manganese	1.28	0.0200		mg/L	1	12/17/2007 11:51:22 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ121207:1025NP1-I-4**Lab Order:** 0712291**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 12/12/2007 10:25:00 AM**Lab ID:** 0712291-06C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	2.34	0.0200		mg/L	1	12/17/2007 11:49:18 AM
Manganese	1.09	0.0200		mg/L	1	12/17/2007 11:49:18 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	180	1.00		mg/L	1	12/19/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-07A

Client Sample ID: GWQ121207:1030NP1-1-2
Tag Number:
Collection Date: 12/12/2007 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,1,1-Trichloroethane	8.3	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
2-Butanone	U	3.0		µg/L	1	12/15/2007 12:33:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
2-Hexanone	U	2.0		µg/L	1	12/15/2007 12:33:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	12/15/2007 12:33:00 PM
Acetone	U	2.0		µg/L	1	12/15/2007 12:33:00 PM
Benzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Bromobenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Bromochloromethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Bromodichloromethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Bromoform	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Bromomethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Carbon disulfide	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Chlorobenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-07A

Client Sample ID: GWQ121207:1030NP1-1-2
Tag Number:
Collection Date: 12/12/2007 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Chloroform	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Chloromethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
cis-1,2-Dichloroethene	0.61	1.0	J	µg/L	1	12/15/2007 12:33:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Dibromochloromethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Dibromomethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Ethylbenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Isopropylbenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
m,p-Xylene	U	2.0		µg/L	1	12/15/2007 12:33:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Methylene chloride	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Naphthalene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
n-Butylbenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
n-Propylbenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
o-Xylene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Styrene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Tetrachloroethene	2.2	1.0		µg/L	1	12/15/2007 12:33:00 PM
Toluene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Trichloroethene	0.86	1.0	J	µg/L	1	12/15/2007 12:33:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Vinyl acetate	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Vinyl chloride	U	1.0		µg/L	1	12/15/2007 12:33:00 PM
Surr: 4-Bromofluorobenzene	100	54-134		%REC	1	12/15/2007 12:33:00 PM
Surr: Dibromofluoromethane	107	52-132		%REC	1	12/15/2007 12:33:00 PM
Surr: Toluene-d8	93.2	51-127		%REC	1	12/15/2007 12:33:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** GWQ121207:1030NP1-1-2**Lab Order:** 0712291**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 12/12/2007 10:30:00 AM**Lab ID:** 0712291-07B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	5.55	0.0200		mg/L	1	12/17/2007 12:00:07 PM
Manganese	0.689	0.0200		mg/L	1	12/17/2007 12:00:07 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 19-Dec-07

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0712291
Project: Rowe, Sag Harbor
Lab ID: 0712291-07C

Client Sample ID: GWQ121207:1030NP1-1-2
Tag Number:
Collection Date: 12/12/2007 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0186	0.0200	J	mg/L	1	12/17/2007 11:53:26 AM
Manganese	0.632	0.0200		mg/L	1	12/17/2007 11:53:26 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	214	1.00		mg/L	1	12/19/2007

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

H7L140104 Analytical Report.....	1
Sample Receipt Documentation	15
Volatiles	18
Raw Sample Data	19
Standards Data	72
Raw QC Data.....	160
Miscellaneous Data.....	176
Sample Receipt Documentation	180
Total Number of Pages	182

ANALYTICAL REPORT


Rowe-NABSAG 0401

Lot #: H7L140104

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

TESTAMERICA LABORATORIES, INC.



Jamie A. McKinney
Project Manager

December 20, 2007

ANALYTICAL METHODS SUMMARY

H7L140104

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15

References:

EPA-2 "Compendium of Methods for the Determination of Toxic
Organic Compounds in Ambient Air", EPA-625/R-96/010b,
January 1999.

SAMPLE SUMMARY

H7L140104

WO #	SAMPLE#	CLIENT SAMPLE ID	SAMPLED DATE	SAMP TIME
KD5TF	001	AQ121207:900NP4-1	12/12/07	09:00
KD5TH	002	AQ121207:905NP4-2	12/12/07	09:05
KD5TL	003	AQ121207:910NP4-3	12/12/07	09:10

NOTE(S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

H7L140104

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

There were no problems with the condition of the samples received.

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

The samples were received on 12/14/07 in Tedlar bags and analyzed within 72 hours of sampling.

TestAmerica Knoxville maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. #QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ121207:900NP4-1
GC/MS Volatiles

Lot-Sample # H7L140104 - 001 Work Order # KD5TF1AA Matrix.....: AIR

Date Sampled...: 12/12/07 Date Received...: 12/14/07
Prep Date.....: 12/14/07 Analysis Date..: 12/14/07
Prep Batch #.....: 7351120
Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	0.70	2.5	2.2 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.2	1.0	5.8	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	3.6	1.0	15	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.54	1.0	2.1 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.32	2.5	1.1 J	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	13	1.0	90	6.8
Toluene	0.60	1.0	2.3 J	3.8
1,1,1-Trichloroethane	7.3	1.0	40	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	0.87	1.0	4.7 J	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	95	70 - 130
Toluene-d8	101	70 - 130
4-Bromofluorobenzene	104	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ121207:900NP4-1
GC/MS Volatiles

Lot-Sample # H7L140104 - 001

Work Order # KD5TF1AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ121207:905NP4-2
 GC/MS Volatiles

Lot-Sample # H7L140104 - 002 Work Order # KD5TH1AA Matrix.....: AIR

Date Sampled...: 12/12/07 Date Received...: 12/14/07
 Prep Date.....: 12/14/07 Analysis Date..: 12/14/07
 Prep Batch #.....: 7351120
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	0.30	1.0	0.95 J	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	0.77	2.5	2.4 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.3	1.0	6.4	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	4.1	1.0	17	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.59	1.0	2.3 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.39	2.5	1.4 J	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	36	1.0	250	6.8
Toluene	2.7	1.0	10	3.8
1,1,1-Trichloroethane	16	1.0	86	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	4.6	1.0	25	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	99	70 - 130
Toluene-d8	100	70 - 130
4-Bromofluorobenzene	100	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ121207:905NP4-2
GC/MS Volatiles

Lot-Sample # H7L140104 - 002

Work Order # KD5TH1AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting
Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ121207:910NP4-3
 GC/MS Volatiles

Lot-Sample # H7L140104 - 003 Work Order # KD5TL1AA Matrix.....: AIR

Date Sampled...: 12/12/07 Date Received..: 12/14/07
 Prep Date.....: 12/14/07 Analysis Date..: 12/14/07
 Prep Batch #....: 7351120
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	0.90	2.5	2.8 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.4	1.0	7.0	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	6.2	1.0	25	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	0.74	1.0	3.0 J	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.82	1.0	3.3 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	ND	2.5	ND	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	ND	1.0	ND	6.8
Toluene	0.32	1.0	1.2 J	3.8
1,1,1-Trichloroethane	30	1.0	160	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	97	70 - 130
Toluene-d8	103	70 - 130
4-Bromofluorobenzene	104	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ121207:910NP4-3
GC/MS Volatiles

Lot-Sample # H7L140104 - 003

Work Order # KD5TL1AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting
Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: INTRA-LAB BLANK
 GC/MS Volatiles

Lot-Sample # H7L170000 - 120B

Work Order # KD95Q1AA

Matrix.....: AIR

Prep Date.....: 12/14/07

Date Received..: 12/13/07

Prep Batch #.....: 7351120

Analysis Date..: 12/14/07

Dilution Factor.: 1

Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	1.6
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	ND	0.50	ND	1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	100	70 - 130
Toluene-d8	105	70 - 130
4-Bromofluorobenzene	93	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: INTRA-LAB BLANK
GC/MS Volatiles

Lot-Sample # H7L170000 - 120B

Work Order # KD95Q1AA

Matrix.....: AIR

The 'Result' in ug/m3 is calculated using the following equation: $\text{Amount Found}(\text{before rounding}) \times (\text{Molecular Weight}/24.45)$

The 'Reporting Limit' in ug/m3 is calculated using the following equation: $(\text{Reporting Limit}(\text{before rounding}) \times \text{Dilution Factor}) \times (\text{Molecular Weight}/24.45)$

Leggette, Brashears & Graham, Inc.
 Client Sample ID: CHECK SAMPLE
 GC/MS Volatiles

Lot-Sample # H7L170000 - 120C Work Order # KD95Q1AC Matrix.....: AIR

Prep Date.....: 12/14/07 Date Received..: 12/13/07
 Prep Batch #.....: 7351120 Analysis Date..: 12/14/07
 Dilution Factor.: 1 Method.....: TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	10.0	7.47	32	24	75	70 - 130
Chlorobenzene	10.0	8.02	46	37	80	70 - 130
1,1-Dichloroethene	10.0	8.47	40	34	85	70 - 130
Toluene	10.0	6.99	38	26	70	70 - 130
Trichloroethene	10.0	7.96	54	43	80	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	97	70 - 130
Toluene-d8	100	70 - 130
4-Bromofluorobenzene	103	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting
 Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

STL Knoxville

5815 Middlebrook Pike • Knoxville, TN 37921-5947
Phone: (865) 291-3000 • Fax: (865) 584-4315
Receiving: (865) 291-3031

Project Name/No. 1 NABSA6 0401
Sample Team Members 2 Evon Foster
Profit Center No. 3
Project Manager 4 Mark Goldberg
Purchase Order No. 6
Required Report Date 11 Standard TAT

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD*

Samples Shipment Date 7 12/13/07
Lab Destination 8
Lab Contact 9 Jamie McKinney
Project Contact / Phone 12
Carrier / Waybill No. 13

Reference Document No.
Page 1 of

Bill to: 5 Mark Goldberg, UBC
4 Bleach Drive, Suite 307
Skelton CT 06434
Report to: 10 Same

ONE CONTAINER PER LINE

Sample ¹⁴ Number	Sample ¹⁵ Type	Date/Time ¹⁶ Collected	Container ¹⁷ Type	Sample ¹⁸ Volume	Pre- ¹⁹ servative	Requested Testing ²⁰ Program	Condition on Receipt ²¹ Lab use only
AQ121207:900N4-1	Air	12/12/07 8:00	Tedlar	1L	None	TO-15	Custody seals intact <u>YN</u> NA
.905N4-2	↓	8:05	↓	↓	↓	↓	Temperature received at <u>20 °C</u>
:910N4-3	↓	8:10	↓	↓	↓	↓	Received by <u>RH</u> Date <u>12/14/07</u>
							Number of packages <u>1</u>
							Tracking # <u>799829635629</u>
							<u>FED EX</u>

Special Instructions: ²³

Possible Hazard Identification: ²⁴
 Non-Hazard ☒ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐
 Turnaround Time Required: ²⁶
 Normal ☒ Rush ☐
 Relinquished by ²⁸ GAH Date: 12/13/07
 (Signature / Affiliation) (Signature / Affiliation) Time: 17:30
 Relinquished by Date: _____
 (Signature / Affiliation) (Signature / Affiliation) Time: _____

Sample Disposal: ²⁵
 Return to Client ☐ Disposal by Lab ☒ Archive (mos.)
 Project Specific (specify): Fun QA/QC
 Received by ²⁸ Ryan Henry Date: 12/14/07
 (Signature / Affiliation) (Signature / Affiliation) Time: 0930
 Received by Date: _____
 (Signature / Affiliation) (Signature / Affiliation) Time: _____

Comments: ²⁹

TESTAMERICA KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: _____ Project: _____ Lot Number: H7L14D104

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)				☐ 1a Do not match COC ☐ 1b Incomplete information ☐ 1c Marking smeared ☐ 1d Label torn ☐ 1e No label ☐ 1f COC not received ☐ 1g Other: _____	
2. Is the cooler temperature within limits? (> freezing temp. of water to 6°C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6°C)	✓			☐ 2a Temp Blank = _____ ☐ 2b Cooler Temp = _____	
3. Were samples received with correct chemical preservative (excluding Encore)?			✓	☐ 3a Sample preservative = _____	
4. Were custody seals present/intact on cooler and/or containers?	✓			☐ 4a Not present ☐ 4b Not intact ☐ 4c Other: _____	
5. Were all of the samples listed on the COC received?	✓			☐ 5a Samples received-not on COC ☐ 5b Samples not received-on COC	
6. Were all of the sample containers received intact?	✓			☐ 6a Leaking ☐ 6b Broken	
7. Were VOA samples received without headspace?			✓	☐ 7a Headspace (VOA only)	
8. Were samples received in appropriate containers?	✓			☐ 8a Improper container	
9. Did you check for residual chlorine, if necessary?			✓	☐ 9a Could not be determined due to matrix interference ☐ 10a Holding time expired	
10. Were samples received within holding time?	✓			☐ Incomplete information	
11. For rad samples, was sample activity info. provided?			✓	If yes & appears to be > 1%, was SOG notified?	
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?			✓	☐ 13a Leaking ☐ 13b Other: _____	
13. Are the shipping containers intact?	✓			☐ 14a Not relinquished	
14. Was COC relinquished? (Signed/Dated/Timed)	✓			☐ 15a Incomplete information	
15. Are tests/parameters listed for each sample?	✓			☐ 15a Incomplete information	
16. Is the matrix of the samples noted?	✓			☐ 15a Incomplete information	
17. Is the date/time of sample collection noted?	✓			☐ 15a Incomplete information	
18. Is the client and project name/# identified?	✓			☐ 15a Incomplete information	
19. Was the sampler identified on the COC?	✓				
Quote #: <u>641610</u> PM Instructions: _____					

Sample Receiving Associate: Ryan Henry Date: 12/14/07 QA026R19.doc, 080707