

-DRAFT-

PROJECT STATUS MEMORANDUM

NO. 01-08

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Tunde H. Komuves-Sandor

DATE: March 5, 2008

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
January 2008 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from January 1, 2008 through January 31, 2008. The report includes a summary of system performance parameters, system operation parameters, and analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(January 1, 2008 through January 31, 2008)

- | | |
|---|----------------------------------|
| 1. Hours of operation during the reporting period: | 569 hours (76%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 13,899,591 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 0.9 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 208.6 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.18 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00135 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume pumped (gal)	Average Flow (gpm)	Lowest Measured Flow (gpm) ¹	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2 ²	919,506	27	13	8.5	0.07
RW-3 ³	0	0	10	0	0
RW-4	985,841	19	10	12.1	0.10
RW-5 ²	1,704,489	50	50	0	0
RW-6	494,206	15	15	28.9	0.12
RW-7	1,975,950	70	69	10.0	0.16
RW-8	1,976,840	55	41	0	0
RW-9 ²	2,217,381	65	16	0	0

¹Lowest measured flows are based on the lowest average 24-hour pumping rates for each well recorded to date.

²The RW-2, RW-5 and RW-9 flow meters were not functioning properly so the total volume pumped was calculated using the product of the last reliable average flow reading and the hours of operation for the month.

³ RW-3 was shut down on December 5, 2007 and was off during the month of January as part of a planned three month period in order to evaluate the effect on contaminant concentrations in the ground-water recovered by RW-2.

Based on the results of the updated ground-water model for the site, the plume is not migrating beyond the influence of the FSP&T system if the recovery well pumps operate at or above the “Lowest Measured Flows”. The average monthly pumping rates for all recovery wells in operation are at or above the “Lowest Measured Flows”. The updated ground-water model is discussed in the 2006 Annual Report for the site.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
January 1 to 31	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in January 2008 include:

- On January 9, 2008, the reed switch and disk chamber in the RW-9 flow meter were replaced. Transfer Pump 1B was making a grinding noise, the bearings were lubricated; and
- On January 24, 2008, the RW-2 and RW-5 flow totalizers were reset; the RW-9 flow meter transmitter was replaced, however the RW-9 flow meter was still not registering a reading. Badger Meter was contacted to continue troubleshooting the RW-9 flow meter. It was observed that the exterior man-way cover, near the top of the air-stripper tower, is cracked, however, it is not leaking water at this time.

Future O&M activities scheduled for the winter and spring of 2008 include:

- Troubleshoot the RW-1 low level alarm;
- Replace the malfunctioning pressure transducer in RW-8;
- Reset equalizer tank flow meter totalizer;
- Replace air-stripper tower man-way cover;
- As part of routine maintenance, clean out well head piping and flow meters for RW-2, 4, 8 and 9; clean influent onsite and offsite pipes including basket strainers, check valves and flow meters;
- Evaluate option of repairing/recalibrating existing air flow meter compared to purchasing a new hand held air flow meter;
- Evaluate accuracy of flow meter readings in the system;
- Evaluate the effect on contaminant concentrations in RW-2 if RW-3 is not operating;
- Trouble shoot the RW-9 flow meter;
- Conduct semi-annual ground-water quality monitoring; and
- Measure static and pumping depth-to-water levels in all recovery and monitor wells.

MMG:nv

Attachments

cc: Jeff Srulovitz - Kraft Foods Global, Inc. - .pdf
Lisa Krogman, Environ – .pdf
Jeff Trad, NYSDEC – .pdf
Chief-Operation Maintenance and Support Section, NYSDEC – .pdf
William Spitz, RWM, R-1, NYSDEC
Garrett W. Swensen Jr., Esq., Town of Southampton

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(January 1, 2008 through January 31, 2008)

Date	Time	System Changes/Modifications	Personnel
1/3/2008	11:10 AM	Reset 12/27/07 high EQ tank alarm; caused by valves mistakenly left closed following a bag filter change, restarted system.	EF
		Was not able to reset RW-1 low level alarm; RW-1 was shut down on July 13, 2005. A faulty pressure transducer may be the cause of the alarm.	EF
1/7/2008		RW-8 pressure transducer malfunctioned.	
1/9/2008		Changed multi-bag filter bags (400 mm) in Banks 1 and 2; seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
		Troubleshooting RW-9 flow meter, replaced reed switch and disk chamber assembly, flow meter still not registering a reading. Continue troubleshooting.	EF
		Greased bearings on Transfer Pump 1B (TP1B) and TP1A.	EF
1/16/2008		Changed multi-bag filter bags (400 mm) in Banks 1 and 2; seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
1/21/2008		Communication Failure Alarm, system shutdown some time between 6:56 AM and 7:56 AM.	
1/24/2008		Changed multi-bag filter bags (400 mm) in Banks 1 and 2; seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	MG/EF/SH
	11:00 AM	Rebooted computer, reset alarms and restarted system.	MG/EF/SH
		Reset the malfunctioning flow totalizer for RW-2 and RW-5.	MG/SH
		Replaced the flow meter transmitter in RW-9, but still no flow reading. Continue troubleshooting with Badger Meter.	EF/SH
	1:04 PM	Communication PC Failure Alarm, system shutdown.	MG/EF/SH
	1:17 PM	Rebooted computer, reset alarms and restarted system.	MG/EF/SH
1/25/2008	4:13 PM	RW-1 Low level alarm (disregarded, RW-1 not operating), system remains running.	
1/28/2008	3:52 PM	Booster Blower failure alarm, system shut down.	
1/30/2008		Changed multi-bag filter bags (400 mm) in Banks 1 and 2; seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	EF
	8:51 AM	Reset alarm, restarted system.	EF

TABLE 2

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo- chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	5	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
3-Jan-08	5.87	126	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	124	2.07
9-Jan-08	5.82	80	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.70	0.126
16-Jan-08	5.54	64	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.96	0.160
24-Jan-08	6.02	112	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	4.87	0.192
30-Jan-08	6.30	125	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	2.55	0.0925

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

J: Analyte detected below quantitation limits

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethylene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

- Based on the new SPDES criteria from an NY SDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5. The pH was measured with a new calibrated electronic pH meter. Influent pH values from recovery wells typically range between 5 and 6.
- "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.

TABLE 3

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

CARBON UNIT SYSTEM AIR QUALITY RESULTS

Precarbon		Parameters (mg/m ³)														TOTAL									
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP	VOCs
AQ011007:1000NP4-1	1/10/2007	10:00	0.06	0.082	0.08	0.0031	0.0084	ND	0.0016	0.0011	0.0011	ND	ND	0.0051	0.0016	0.003	0.0059	ND	ND	ND	ND	ND	ND	ND	0.18
AQ020807:1000NP4-1	2/8/2007	10:00	0.22	0.0120	0.13	0.0041	0.011	0.0027	0.003	0.002	0.0018	ND	ND	0.0059	0.0038	0.0047	0.0059	ND	ND	ND	ND	ND	ND	ND	0.41
AQ030707:900NP4-1	3/7/2007	9:00	0.11	0.0049	0.05	0.002	0.0066	0.0026	0.0022	0.0011	ND	ND	ND	0.0031	0.0016	ND	0.0019	ND	ND	ND	ND	ND	ND	ND	0.18
AQ040307:800NP4-1	4/3/2007	8:00	0.19	0.0085	0.047	0.0025	0.0096	0.0026	0.0013	ND	ND	ND	ND	0.0045	0.0014	0.0025	0.0031	ND	ND	ND	ND	ND	ND	ND	0.27
AQ050107:1100NP4-1	5/12/2007	11:00	0.13	0.0065	0.082	0.0033	0.017	ND	0.002	0.00088	ND	ND	ND	0.0055	0.0021	0.0025	0.0046	ND	ND	ND	ND	ND	ND	ND	0.26
AQ060707:1030NP4-1	6/7/2007	10:30	0.1	0.0048	0.046	0.0075	0.017	ND	0.0023	ND	ND	ND	ND	0.0045	0.0012	0.0018	0.0054	ND	ND	ND	ND	ND	ND	ND	0.17
AQ070507:1100NP4-1	7/5/2007	11:00	0.18	0.0067	0.044	0.0021	0.0094	ND	0.0027	ND	ND	ND	ND	0.0046	0.0019	0.0019	0.0064	ND	ND	ND	ND	ND	ND	ND	0.26
AQ080807:1100NP4-1	8/8/2007	11:00	0.0028 ^a	0.0072	ND	ND	ND	0.0028 ^a	0.0027	0.0029	ND	ND	ND	ND	0.0028 ^a	0.0025	0.021	ND	ND	ND	ND	ND	ND	ND	0.04
AQ091207:1100NP4-1	9/12/2007	11:00	0.370	0.0031	0.027	ND	0.0077	ND	0.11	ND	ND	ND	ND	0.0047	0.0031	0.002	0.11	ND	ND	ND	ND	ND	ND	ND	0.64
AQ100307:900NP4-1	10/3/2007	9:00	0.200	0.0080	0.05	0.004	0.016	ND	0.0026	0.0012	ND	ND	ND	0.0061	ND	0.0074	0.0074	ND	ND	ND	0.0015 ^a	ND	ND	ND	0.30
AQ112807:900NP4-1	11/28/2007	9:00	0.110	0.0046	0.034	0.0037	0.013	0.0023	0.0022	0.001	ND	ND	ND	0.0062	0.0018 ^a	0.002	0.0061	ND	ND	ND	ND	ND	ND	ND	0.19
AQ121207:900NP4-1	12/12/2007	9:00	0.090	0.0047	0.040	0.0021	0.015	ND	0.0023	ND	ND	ND	ND	0.0058	0.0011	ND	0.0022	ND	ND	ND	ND	ND	ND	ND	0.16
AQ11608:900NP4-1	1/16/2008	9:00	0.032	ND	0.022	ND	0.0079	ND	ND	ND	ND	ND	ND	0.0025	0.04	ND	0.0013	ND	ND	ND	ND	ND	ND	ND	0.11

Midcarbon		Parameters (mg/m ³)														TOTAL									
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP	VOCs
AQ011007:1001NP4-2	1/10/2007	10:01	0.0034	0.001	0.32	0.0047	0.012	0.005	0.0013	ND	ND	ND	ND	0.0056	0.0014	0.0032	0.0071	ND	ND	ND	ND	ND	ND	ND	0.36
AQ020807:1002NP4-2	2/8/2007	10:02	0.0092	0.004	0.32	0.0042	0.011	0.0063	0.0019	0.0011	ND	ND	ND	0.0067	0.0032	ND	0.0043	ND	ND	ND	ND	ND	ND	ND	0.37
AQ030707:902NP4-2	3/7/2007	9:02	0.0058	0.002	0.17	0.0031	0.0081	0.0037	0.0013	ND	ND	ND	ND	0.0048	0.001	0.0026	0.0038	ND	ND	ND	ND	ND	ND	ND	0.21
AQ040307:802NP4-2	4/3/2007	8:02	0.003	0.001	0.091	0.0020	0.0063	0.0025	ND	ND	ND	ND	ND	0.0012	ND	0.0029	0.0029	ND	ND	ND	ND	ND	ND	ND	0.11
AQ050107:1105NP4-2	5/12/2007	11:05	0.0036	0.001	0.083	0.0030	0.013	0.003	0.0017	ND	ND	ND	ND	0.0047	0.002 ^a	0.0027	0.0036	ND	ND	ND	ND	ND	ND	ND	0.12
AQ060707:1055NP4-2	6/7/2007	10:55	0.0052	0.002	0.058	0.0096	0.013	ND	0.0023	ND	0.0013	ND	ND	0.004	0.0014	ND	0.006	ND	ND	ND	ND	ND	ND	ND	0.09
AQ070507:1105NP4-2	7/5/2007	11:05	0.0018	0.001	0.066	0.006	0.0084	ND	0.0018	ND	ND	ND	ND	0.0038	0.0026 ^a	0.0018	0.0071	ND	ND	ND	ND	ND	ND	ND	0.09
AQ080807:1105NP4-2	8/8/2007	11:05	1.3 ^a	0.120	0.33	0.0053	0.035	0.0068	0.0092	0.0049	0.0028	ND	ND	0.016	0.0026 ^a	0.0018	0.02	ND	ND	ND	ND	0.0028	0.0012	ND	0.56
AQ091207:1105NP4-2	9/12/2007	11:05	1.8	0.051	0.100	0.0040	0.020	ND	0.029	0.0035	ND	ND	ND	0.0075	0.0042	0.0029	0.025	ND	ND	ND	0.0011	ND	ND	ND	2.05
AQ100307:905NP4-2	10/3/2007	9:05	0.220	0.018	0.054	0.0017	0.015	ND	ND	0.00093	ND	ND	ND	0.0056	0.0014	ND	0.01	ND	ND	ND	0.0012 ^a	ND	ND	ND	0.33
AQ112807:905NP4-2	11/28/2007	9:05	0.086	0.011	0.072	0.0038	0.015	ND	0.0014	ND	ND	ND	ND	0.0051	0.0019 ^a	ND	0.0051	ND	ND	ND	ND	ND	ND	ND	0.20
AQ121207:905NP4-2	12/12/2007	9:05	0.250	0.025	0.086	0.0023	0.017	ND	0.010	0.00095	ND	ND	ND	0.0064	0.0014	ND	0.0024	ND	ND	ND	ND	ND	ND	ND	0.40
AQ11608:905NP4-2	1/16/2008	9:05	0.210	0.007	0.079	ND	0.015	ND	ND	ND	ND	ND	ND	0.0066	ND	ND	0.0024	ND	ND	ND	ND	ND	ND	ND	0.32

Postcarbon		Parameters (mg/m ³)														TOTAL									
Sample Name	Date	Time	PCE	TCE	TCA	DCE	DCA	cis-DCE	Toluene	Benzene	m&p-Xylenes	o-Xylene	Styrene	CF	MC	CM	CD	BM	CB	EB	VC	CE	CT	DCP	VOCs
AQ011007:1002NP4-3	1/10/2007	10:02	ND	ND	0.23	0.0047	0.018	0.0065	0.0013	ND	ND	ND	ND	0.0053	0.0012	0.0028	0.0048	ND	ND	ND	ND	ND	ND	ND	0.27
AQ020807:1005NP4-3	2/8/2007	10:05	0.0039	ND	0.57	0.0069	0.028	0.012	0.0027	0.002	ND	ND	ND	0.0093	0.0044	0.0018	0.0046	ND	ND	ND	ND	0.0065	ND	ND	0.65
AQ030707:904NP4-3	3/7/2007	9:04	ND	ND	0.21	0.0028	0.0087	0.0056	ND	ND	ND	ND	ND	0.0043	0.00096	ND	0.0029	ND	ND	ND	ND	ND	ND	ND	0.24
AQ040307:804NP4-3	4/3/2007	8:04	ND	ND	0.075	0.0020	0.0037	0.0034	0.0011	ND	ND	ND	ND	0.0047	0.0015	0.0025	0.002	ND	ND	ND	ND	ND	ND	ND	0.09
AQ050107:1101NP4-3	5/12/2007	11:10	ND	ND	0.12	0.0026	0.0078	0.007	0.0089	ND	ND	ND	ND	0.0047	0.005 ^a	0.003	0.0038	ND	ND	ND	ND	ND	ND	ND	0.16
AQ060707:1100NP4-3	6/7/2007	11:00	ND	ND	0.067	0.0020	0.0092	0.0045	0.002	0.0023	ND	ND	ND	0.0035	0.0011	ND	0.0052	ND	ND	ND	ND	ND	ND	ND	0.10
AQ070507:1110NP4-3	7/5/2007	11:10	ND	ND	0.110	0.0033	0.015	0.0064	0.0016	ND	ND	ND	ND	0.006	0.0019 ^a	ND	0.0062	ND	ND	ND	ND	ND	ND	ND	0.15
AQ080807:1110NP4-3	8/8/2007	11:10	0.013 ^a	0.0015	0.190	0.0063	0.029	0.011	0.41	0.0018	ND	ND	ND	0.011	0.0047 ^a	0.0037	0.019	ND	ND	ND	0.00092	ND	ND	ND	0.68
AQ091207:1110NP4-3	9/12/2007	11:10	ND	ND	0.033	ND	0.0061	0.0021	0.0028	ND	ND	ND	ND	0.0028	0.0013	ND	0.0099	ND	ND	ND	ND	ND	ND	ND	0.06
AQ100307:910NP4-3	10/3/2007	9:10	ND	ND	0.044	ND	0.0076	0.0021	0.0033	ND	ND	ND	ND	0.003	0.0012	ND	0.008	ND	ND	ND	ND	ND	ND	ND	0.07
AQ112807:910NP4-3	11/28/2007	9:10	ND	ND	0.11	0.0030	0.014	0.0022	0.0033	ND	ND	ND	ND	0.0045	0.0018 ^a	ND	0.0061	ND	ND	ND	ND	ND	ND	ND	0.14
AQ121207:910NP4-3	12/12/2007	9:10	ND	ND	0.16	0.0033	0.025	0.003	0.0012	ND	ND	ND	ND	0.007	ND	ND	0.0028	ND	ND	ND	ND	ND	ND	ND	0.20
AQ11608:910NP4-3	1/16/2008	9:10	ND	ND	0.14	0.0025	0.022	ND	0.0032	ND	ND	ND	ND	0.0082	ND	ND	0.0034	ND	ND	ND	0.0011	ND	ND	ND	0.18

Note: B Method blank contamination. The associated method blank contains the target analyte at a reportable level.

PCE - Tetrachloroethane
TCE - Trichloroethane
TCA - 1,1,1-Trichloroethane
CE - Chloroethane

DCE - 1,1-Dichloroethane
DCA - 1,1-Dichloroethane
cis-DCE - cis-1,2-Dichloroethane
CT - Carbon Tetrachloride

CF - Chloroform
MC - Methylene Chloride
CM - Chloromethane
CD - Carbon Disulfide

BM - Bromomethane
CB - Chlorobenzene
EB - Ethylbenzene
VC - Vinyl Chloride

DCP - 1,2-Dichloropropane

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethane (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-1 ^{3/}	ADAR-04	ND<1	ND<1	ND<1	NE	NE	NE	300	300	ND<0.02	ND<1	ND<1	ND<1	NE	NE	ND<1	ND<1	ND<1	NE
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	2.6	2.5	0.0392	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0133	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	9.8	2.1	0.0473	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-06	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.3	1.3	1	6.9
	7-Mar-06	ND<1	ND<1	ND<1	ND<1	5.2	ND<1	0.1650	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Mar-06	ND<1	ND<1	ND<1	ND<1	7.1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-08	25	ND<1	ND<1	ND<1	ND<1	ND<1	4.91	1.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-2	8-Feb-08	18	ND<1	ND<1	ND<1	ND<1	ND<1	5.01	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-08	20	1.1	ND<1	ND<1	ND<1	ND<1	5.28	0.0916	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-08	5.0	ND<1	ND<1	ND<1	ND<1	ND<1	3.50	0.126	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-May-08	8.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.50	0.141	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jun-08	12.0	ND<1	ND<1	ND<1	ND<1	ND<1	0.28	0.0988	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-08	7.7	1.1	ND<1	ND<1	ND<1	ND<1	0.28	0.0988	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	9-Aug-08	5.4	ND<1	ND<1	ND<1	ND<1	ND<1	3.74	0.107	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-08	16	1.8	ND<1	ND<1	ND<1	ND<1	3.57	0.074	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-08	NM	ND<1	ND<1	ND<1	ND<1	ND<1	6.1	0.0669	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Nov-08	13	2.1	ND<1	ND<1	ND<1	ND<1	5.1	0.0869	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-08	3.1	2.1	ND<1	ND<1	ND<1	ND<1	4.25	0.0502	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-09	5.2	2.0	ND<1	ND<1	ND<1	ND<1	9.15	0.0966	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Feb-09	6.5	4.3	ND<1	ND<1	ND<1	ND<1	3.99	0.0502	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-09	6.5	3.9	ND<1	ND<1	ND<1	ND<1	2.6	0.0355	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-09	13.0	3.9	ND<1	ND<1	ND<1	ND<1	2.6	0.0355	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-09	13.0	5.1	ND<1	ND<1	ND<1	ND<1	5.25	0.0622	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-09	13.0	3.0	25	ND<1	ND<1	ND<1	3.55	0.063	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-09	8.0	3.4	25	ND<1	ND<1	ND<1	3.55	0.093	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-09	1.0	1.1	25	ND<1	ND<1	ND<1	4.49	0.172	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Sep-09	2.5	ND<1	200	ND<1	ND<1	ND<1	4.37	0.076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-09	6.0	1.8	160	ND<1	ND<1	ND<1	3.6	0.0756	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	29-Nov-09	6.0	1.8	160	ND<1	ND<1	ND<1	1.9	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-09	2.2	ND<1	110	ND<1	ND<1	ND<1	2.79	0.0497	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	4.2	ND<1	89	ND<1	ND<1	ND<1	4.72	0.0829	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-07	3.2	2.7	89	ND<1	ND<1	ND<1	4.72	0.0829	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	31	ND<1	ND<1	ND<1	4.26	0.177	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-07	3	1.7	23	ND<1	ND<1	ND<1	3.81	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	26	ND<1	ND<1	ND<1	3.94	0.0669	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Jun-07	1.1	1.2	ND<1	ND<1	ND<1	ND<1	3.74	0.0362	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jul-07	1.2	0.78	17	ND<1	ND<1	ND<1	2.26	0.196	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Aug-07	0.75	ND<1	10	ND<1	ND<1	ND<1	3.92	0.157	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Sep-07	1.6	ND<1	1.2	ND<1	ND<1	ND<1	1.76	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Oct-07	1.4	ND<1	1.2	ND<1	ND<1	ND<1	2.19	1.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Nov-07	5.6	ND<1	8.3	ND<1	ND<1	ND<1	2.19	0.0132	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Dec-07	2.2	0.86	ND<1	ND<1	ND<1	ND<1	5.55	0.0166	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jan-08	2	ND<1	5.3	ND<1	ND<1	ND<1	3.09	0.155	0.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro ethane (ug/L)	cis-1,2-Dichloro ethane (ug/L)	1,1-Dichloro ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromomethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-3	4-Jan-05	ND<1	ND<1	ND<1	NE	ND<1	NE	300	300	ND<1	ND<1	ND<1	ND<1	NE	NE	ND<1	ND<1	ND<1	NE
	4-Jan-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.24	2.24	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	1.6	3	3	ND<1	ND<1	ND<1	1.89	1.36	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	1.6	13	6.0	ND<1	ND<1	ND<1	46.1	0.539	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.85	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	2.2	7.7	2.8	ND<1	ND<1	ND<1	9.91	10	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.01	0.649	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.9 *
	14-Jul-05	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.50	0.973	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	9-Aug-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.03	0.71	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	1	3.6	1.2	ND<1	ND<1	ND<1	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	1.83	0.708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.11	0.566	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	1.7	17	7.9	ND<1	ND<1	ND<1	1.93	0.455	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Feb-06	1.4	8.9	2.3	ND<1	ND<1	ND<1	3.87	0.897	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	1.4	ND<1	ND<1	ND<1	ND<1	ND<1	1.97	0.397	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	0.96	ND<1	ND<1	ND<1	ND<1	ND<1	1.99	0.649	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.06	0.353	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Aug-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Sep-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	24-Oct-06	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	29-Nov-06	6.4	ND<1	4.4	ND<1	ND<1	ND<1	17.3	0.0112	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-4	20-Dec-06	1.2	8	3.5	ND<1	ND<1	ND<1	ND<0.02	2.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	1.2	3.2	ND<1	ND<1	ND<1	ND<1	ND<0.02	2.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.24	0.397	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.24	0.397	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.89	1.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Jun-07	0.91	8.5	ND<1	ND<1	ND<1	ND<1	2.48	0.19	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	2.8	1.2	ND<1	ND<1	ND<1	2.36	0.0414	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	1.2	0.72	ND<1	ND<1	ND<1	2.95	1.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	2.20	1.49	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.46	2.16	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.70	0.971	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Dec-07	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	16-Jan-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.73	0.229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	4-Jan-08	160	4.1	7.3	ND<1	ND<1	ND<1	6.11	3.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-08	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	15-Mar-08	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	19-Apr-08	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	2-May-08	80	2.4	9.8	ND<1	ND<1	ND<1	3.77	0.0687	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	30-Jun-08	74	2.6	ND<1	ND<1	ND<1	ND<1	9.95	9.28	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-08	37	ND<1	8.9	ND<1	ND<1	ND<1	3.22	0.0185	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7.4 *
	9-Aug-08	31	ND<1	ND<1	ND<1	ND<1	ND<1	2.49	0.111	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-08	45	ND<1	6.0	ND<1	ND<1	ND<1	3.47	0.173	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-08	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-08	30	ND<1	ND<1	ND<1	ND<1	ND<1	3.69	0.0777	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Dec-08	64	2.0	1.5	ND<1	ND<1	ND<1	2.82	0.0302	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-09	15	ND<1	9.5	ND<1	ND<1	ND<1	7.78	0.0412	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Feb-09	24	ND<1	8.7	ND<1	ND<1	ND<1	6.05	0.0627	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-09	22	ND<1	7.0	ND<1	ND<1	ND<1	3.50	0.0476	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-09	26	1.5	6.2	ND<1	ND<1	ND<1	4.17	0.0963	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-09	26	ND<1	ND<1	ND<1	ND<1	ND<1	3.15	0.109	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-09	23	ND<1	8.4	ND<1	ND<1	ND<1	9.23	0.086	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-09	14	ND<1	9.4	ND<1	ND<1	ND<1	4.10	0.155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-09	23	ND<1	ND<1	ND<1	ND<1	ND<1	8.60	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-09	9	ND<1	7.5	ND<1	ND<1	ND<1	5.95	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-09	11	ND<1	5.6	ND<1	ND<1	ND<1	7.17	0.0178	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	29-Nov-09	14	ND<1	ND<1	ND<1	ND<1	ND<1	2.82	0.00708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-09	6.4	ND<1	4.4	ND<1	ND<1	ND<1	17.30	0.0112	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-10	12	ND<1	4.6	ND<1	ND<1	ND<1	3.17	0.0794	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-10	13	ND<1	3.3	ND<1	ND<1	ND<1	3.64	0.0767	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-10	7.3	ND<1	2.1	ND<1	ND<1	ND<1	3.85	0.0767	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-10	10	ND<1	ND<1	ND<1	ND<1	ND<1	4.46	0.251	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-10	5.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.67	0.0422	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jun-10	6.9	ND<1	0.89	ND<1	ND<1	ND<1	3.73	0.048	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	25-Jul-10	5.8	ND<1	3.3	ND<1	ND<1	ND<1	6.58	3.37	ND<1	ND<1	ND<1	ND<1						

TABLE 4

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethane (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-5	14-Jan-05	12	ND<1	5.6	ND<1	ND<1	NE	300	0.0172	ND<1	ND<1	ND<1	NE	NE	NE	ND<1	ND<1	ND<1	NE
	8-Feb-05	11	ND<1	ND<1	ND<1	ND<1	2.0	0.0269	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	9	ND<1	ND<1	ND<1	ND<1	9	0.0887	0.0182	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	13	ND<1	5.7	ND<1	ND<1	ND<1	0.0223	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	4.7	ND<1	ND<1	ND<1	ND<1	ND<1	0.0177	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	8.2	ND<1	1.6	ND<1	ND<1	ND<1	0.0358	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.6*
	9-Aug-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0227	0.0303	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Sep-05	8	ND<1	3.8	ND<1	ND<1	ND<1	0.0185	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-05	2.6	ND<1	ND<1	ND<1	ND<1	ND<1	0.0482	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	2.4	ND<1	ND<1	ND<1	ND<1	ND<1	0.0468	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	2.3	ND<1	2.0	ND<1	ND<1	ND<1	0.0598	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Feb-06	2.9	ND<1	3.8	ND<1	ND<1	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	2.6	ND<1	3.0	ND<1	ND<1	2.4	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	1.4	ND<1	ND<1	ND<1	1.5	ND<1	0.0786	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.016	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	2.4	ND<1	2.6	ND<1	ND<1	ND<1	0.195	0.012	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jul-06	1.3	ND<1	3.1	ND<1	ND<1	ND<1	0.184	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.194	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.09	0.0116	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	1.1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0683	0.0684	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	28-Nov-06	6	ND<1	1.3	ND<1	ND<1	ND<1	0.508	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.136	0.0113	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	1.2	ND<1	ND<1	ND<1	ND<1	1.2	0.0608	0.028	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	9-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.327	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0655	0.0722	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.973	0.0706	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0763	0.0469	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.118	0.0747	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.395	0.0889	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0450	0.008	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	0.8	0.0460	0.008	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	0.7	0.0600	0.350	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.1330	0.022	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jan-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0368	0.014	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-6	24-Feb-05	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.0442	0.0442	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Mar-05	10	2.1	7.7	ND<1	ND<1	ND<1	0.0732	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Apr-05	10	2.3	6.8	ND<1	ND<1	ND<1	0.0512	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-May-05	74	ND<1	7.8	ND<1	ND<1	2.7	0.0294	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	96	2.8	8.5	ND<1	ND<1	ND<1	0.0509	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jun-05	69	1.8	13	ND<1	ND<1	ND<1	0.067	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	64	1.6	9.5	ND<1	ND<1	ND<1	0.087	0.0195	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	9-Aug-05	49	ND<1	12	ND<1	ND<1	ND<1	0.0406	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7*
	8-Sep-05	100	1.6	12	ND<1	ND<1	ND<1	0.088	0.0366	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Oct-05	NM	NM	NM	NM	NM	NM	1.3	0.0143	ND<1	ND<1	ND<1	ND<1	NM	NM	NM	NM	NM	NM
	21-Nov-05	68	ND<1	ND<1	ND<1	ND<1	ND<1	0.144	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Dec-05	100	2.1	20	ND<1	ND<1	ND<1	0.139	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Jan-06	41	1.1	16	ND<1	ND<1	ND<1	0.186	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	22-Feb-06	63	1.6	15	ND<1	ND<1	ND<1	0.119	0.0155	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	65	1.2	17	ND<1	ND<1	ND<1	0.0429	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	12-Apr-06	62	2.1	22	ND<1	ND<1	2	0.24	0.0137	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	17-May-06	68	ND<1	18	ND<1	ND<1	ND<1	0.17	0.019	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	21-Jun-06	83	ND<1	20	ND<1	ND<1	ND<1	0.075	0.025	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Jul-06	45	1.5	24	ND<1	ND<1	ND<1	1.01	0.0169	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Sep-06	46	ND<1	27	ND<1	ND<1	ND<1	0.916	0.0078	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	24-Oct-06	45	1.2	15	ND<1	ND<1	ND<1	0.399	0.137	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	29-Nov-06	36	1.0	14	ND<1	ND<1	ND<1	0.0877	0.037	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Dec-06	31	ND<1	13	ND<1	ND<1	ND<1	2.43	0.00877	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-Jan-07	46	0.96	16	ND<1	ND<1	ND<1	0.0928	0.00463	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-07	42	ND<1	ND<1	ND<1	ND<1	ND<1	0.153	0.0108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	29	ND<1	8.4	ND<1	ND<1	ND<1	0.054	0.0316	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Apr-07	28	ND<1	8.3	ND<1	ND<1	ND<1	0.127	0.00708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	10-May-07	31	ND<1	7.7	ND<1	ND<1	ND<1	0.206	0.0708	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	20-Jun-07	19	ND<1	6.6	ND<1	ND<1	ND<1	0.127	0.0139	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	18-Jul-07	20	ND<1																

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TOA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethane (ug/L)	Toluene Chloride (ug/L)	Dibromochloroethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
RW-7	1-Jan-06	31	5	5	NE	NE	NE	300	ND<0.02	ND<0.02	ND<0.02	NE	NE	ND<2	ND<1	ND<1	NE
	8-Jan-06	15	ND<1	ND<1	ND<1	ND<1	ND<1	0.0432	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	42	1.5	1.7	ND<1	ND<1	ND<1	0.0356	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Apr-05	23	ND<1	ND<1	ND<1	ND<1	ND<1	0.107	0.0152	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-05	32	ND<1	ND<1	ND<1	ND<1	ND<1	0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-05	32	1.0	4.7	ND<1	ND<1	ND<1	0.0753	0.02	ND<1	1.1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-05	31	ND<1	2.2	ND<1	ND<1	ND<1	0.0755	ND<0.02	ND<1	ND<1	8.7 *	ND<1	ND<2	ND<1	ND<1	7.2 *
	9-Aug-05	37	ND<1	6.2	ND<1	ND<1	ND<1	0.0803	0.0409	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-05	39	ND<1	3.4	ND<1	ND<1	ND<1	0.0452	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Oct-05	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0452	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-Nov-05	38	ND<1	ND<1	ND<1	ND<1	ND<1	0.0338	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Nov-05	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.0338	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	36	ND<1	ND<1	ND<1	ND<1	ND<1	0.343	ND<0.02	ND<1	ND<1	5.0 *	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	38	ND<1	4.1	ND<1	ND<1	ND<1	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	38	ND<1	4.1	ND<1	ND<1	ND<1	0.143	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	RW-8	12-Apr-06	49	1.6	7.4	ND<1	ND<1	ND<1	0.0912	0.0175	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1
17-May-06		59	ND<1	ND<1	ND<1	ND<1	ND<1	0.126	0.026	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
21-Jun-06		44	ND<1	4.6	ND<1	ND<1	ND<1	0.081	0.013	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
20-Jul-06		36	ND<1	ND<1	ND<1	ND<1	ND<1	0.307	0.1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
19-Sep-06		39	ND<1	7.9	ND<1	ND<1	ND<1	0.116	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
24-Oct-06		36	ND<1	3.5	ND<1	ND<1	ND<1	0.0692	2.4	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
9-Nov-06		33	ND<1	4.1	ND<1	ND<1	ND<1	0.1910	0.04960	1.0	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
20-Dec-06		NM	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
10-Jan-07		NM	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
8-Feb-07		43	ND<1	4.4	ND<1	ND<1											

TABLE 4

**GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK**

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	1.72	1.6	ND<1	ND<1	ND<1	NE	NE	ND<2	ND<1	ND<1	NE
	4-Jan-05	ND<1	1.0	6.4	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	10	ND<1	ND<1	ND<1	0.0974	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	1.4	5.9	ND<1	ND<1	ND<1	0.155	0.307	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Apr-06	ND<1	4.5	ND<1	ND<1	ND<1	ND<1	1.59	0.091	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	2-May-06	ND<1	2.9	9.0	ND<1	ND<1	ND<1	2.89	0.0966	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jun-06	ND<1	5.8	ND<1	ND<1	ND<1	ND<1	1.38	0.149	0.9	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Jul-06	3.4	ND<1	ND<1	ND<1	ND<1	ND<1	2.95	0.238	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	7.3
	8-Aug-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	0.994	0.0734	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Sep-06	1.2	ND<1	ND<1	ND<1	ND<1	ND<1	3.64	0.161	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	9-Oct-06	NM	NM	NM	NM	NM	NM	1.31	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	21-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.31	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Dec-06	ND<1	ND<1	2.9	ND<1	ND<1	ND<1	2.01	0.024	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Jan-06	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	2.36	0.0605	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	14-Feb-06	2.1	ND<1	1.8	ND<1	ND<1	ND<1	5.23	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-06	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.41	0.333	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	1.93	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.054	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-June-06	NM	NM	NM	NM	NM	NM	1.64	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.665	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0165	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	6.96	0.00719	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	28-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.54	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	5.08	0.0655	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	9-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.96	0.0076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	8.03	0.399	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	25-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.868	0.04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.59	0.0227	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.39	0.0250	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.33	0.4040	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.18	0.180	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.704	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.2	1.92	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jan-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.85	1.46	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

ND: Not detected
 <M: Less than method detection limit
 ug/L: Micrograms per liter
 ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site
 Bold values indicate an exceedance of the ARAR standard established for the site

PCE: Tetrachloroethylene
 TCE: Trichloroethylene
 TCA: 1,1,1-Trichloroethane
 1,1-DCA: 1,1-Dichloroethane
 1,1-DCE: 1,1-Dichloroethene
 1,2-DCE: 1,2-Dichloroethene
 MTBE: Methyl Tertiary Butyl Ether
 NM: Not Measured

NE indicates that the ARAR goal was not established for this compound by the EPA
 *Concentrations with an asterisk following them are due to laboratory contamination
 ** RW-9 is currently non operational waiting for the reprogramming of the drive for the new 4 amp pump
 *** RW-9 was being rehabilitated during this sampling event, thus no water sample was collected
 *** RW-1 was shut down with EPA approval, on July 13, 2005 because no contaminants of concern had been detected for over a year


GRAPHS

GRAPH 1


GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA


(January 1, 2008 through January 31, 2008)



GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



GRAPH 3
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



APPENDIX I
JANUARY 2008 LABORATORY ANALYTICAL REPORTS



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Thursday, January 24, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe, Sag Harbor

Order No.: 0801215

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 8 sample(s) on 1/18/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe, Sag Harbor
Lab Order: 0801215

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0801215-01A	ROWEGWQ011608:NP1-1-		1/16/2008 10:00:00 AM	1/18/2008
0801215-01B	ROWEGWQ011608:NP1-1-		1/16/2008 10:00:00 AM	1/18/2008
0801215-01C	ROWEGWQ011608:NP1-1-		1/16/2008 10:00:00 AM	1/18/2008
0801215-02A	ROWEGWQ011608:NP1-1-		1/16/2008 10:05:00 AM	1/18/2008
0801215-02B	ROWEGWQ011608:NP1-1-		1/16/2008 10:05:00 AM	1/18/2008
0801215-02C	ROWEGWQ011608:NP1-1-		1/16/2008 10:05:00 AM	1/18/2008
0801215-03A	ROWEGWQ011608:NP1-1-		1/16/2008 10:10:00 AM	1/18/2008
0801215-03B	ROWEGWQ011608:NP1-1-		1/16/2008 10:10:00 AM	1/18/2008
0801215-03C	ROWEGWQ011608:NP1-1-		1/16/2008 10:10:00 AM	1/18/2008
0801215-04A	ROWEGWQ011608:NP1-1-		1/16/2008 10:15:00 AM	1/18/2008
0801215-04B	ROWEGWQ011608:NP1-1-		1/16/2008 10:15:00 AM	1/18/2008
0801215-04C	ROWEGWQ011608:NP1-1-		1/16/2008 10:15:00 AM	1/18/2008
0801215-05A	ROWEGWQ011608:NP1-1-		1/16/2008 10:20:00 AM	1/18/2008
0801215-05B	ROWEGWQ011608:NP1-1-		1/16/2008 10:20:00 AM	1/18/2008
0801215-05C	ROWEGWQ011608:NP1-1-		1/16/2008 10:20:00 AM	1/18/2008
0801215-06A	ROWEGWQ011608:NP1-1-		1/16/2008 10:25:00 AM	1/18/2008
0801215-06B	ROWEGWQ011608:NP1-1-		1/16/2008 10:25:00 AM	1/18/2008
0801215-06C	ROWEGWQ011608:NP1-1-		1/16/2008 10:25:00 AM	1/18/2008
0801215-07A	ROWEGWQ011608:NP1-1-		1/16/2008 10:30:00 AM	1/18/2008
0801215-07B	ROWEGWQ011608:NP1-1-		1/16/2008 10:30:00 AM	1/18/2008
0801215-07C	ROWEGWQ011608:NP1-1-		1/16/2008 10:30:00 AM	1/18/2008
0801215-08A	ROWEGWQ011608:NP1-1-		1/16/2008 10:35:00 AM	1/18/2008
0801215-08B	ROWEGWQ011608:NP1-1-		1/16/2008 10:35:00 AM	1/18/2008
0801215-08C	ROWEGWQ011608:NP1-1-		1/16/2008 10:35:00 AM	1/18/2008

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-01A

Client Sample ID: ROWEGWQ011608:NP1-1-5
Tag Number:
Collection Date: 1/16/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
2-Butanone	U	3.0		µg/L	1	1/22/2008 4:35:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
2-Hexanone	U	2.0		µg/L	1	1/22/2008 4:35:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/22/2008 4:35:00 AM
Acetone	U	2.0		µg/L	1	1/22/2008 4:35:00 AM
Benzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Bromobenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Bromoform	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Bromomethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-01A

Client Sample ID: ROWEGWQ011608:NP1-1-5
Tag Number:
Collection Date: 1/16/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Chloroform	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Chloromethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Dibromomethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/22/2008 4:35:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Methylene chloride	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Naphthalene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
o-Xylene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Styrene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Toluene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Trichloroethene	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/22/2008 4:35:00 AM
Surr: 4-Bromofluorobenzene	97.4	54-134		%REC	1	1/22/2008 4:35:00 AM
Surr: Dibromofluoromethane	97.9	52-132		%REC	1	1/22/2008 4:35:00 AM
Surr: Toluene-d8	96.4	51-127		%REC	1	1/22/2008 4:35:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** ROWEGWQ011608:NP1-1-5**Lab Order:** 0801215**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 1/16/2008 10:00:00 AM**Lab ID:** 0801215-01B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.0732	0.0200		mg/L	1	1/22/2008 10:37:09 AM
Manganese	0.0106	0.0200	J	mg/L	1	1/22/2008 10:37:09 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-01C

Client Sample ID: ROWEGWQ011608:NP1-1-5
Tag Number:
Collection Date: 1/16/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0441	0.0200		mg/L	1	1/22/2008 10:35:05 AM
Manganese	0.00676	0.0200	J	mg/L	1	1/22/2008 10:35:05 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	126	1.00		mg/L	1	1/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-02A

Client Sample ID: ROWEGWQ011608:NP1-1-6
Tag Number:
Collection Date: 1/16/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,1,1-Trichloroethane	6.9	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
2-Butanone	U	3.0		µg/L	1	1/24/2008 1:05:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
2-Hexanone	U	2.0		µg/L	1	1/24/2008 1:05:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/24/2008 1:05:00 AM
Acetone	U	2.0		µg/L	1	1/24/2008 1:05:00 AM
Benzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Bromobenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Bromoform	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Bromomethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-02A

Client Sample ID: ROWEGWQ011608:NP1-1-6
Tag Number:
Collection Date: 1/16/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Chloroform	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Chloromethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Dibromomethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/24/2008 1:05:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Methylene chloride	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Naphthalene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
o-Xylene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Styrene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Tetrachloroethene	22	1.0		µg/L	1	1/24/2008 1:05:00 AM
Toluene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Trichloroethene	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/24/2008 1:05:00 AM
Surr: 4-Bromofluorobenzene	104	54-134		%REC	1	1/24/2008 1:05:00 AM
Surr: Dibromofluoromethane	108	52-132		%REC	1	1/24/2008 1:05:00 AM
Surr: Toluene-d8	99.5	51-127		%REC	1	1/24/2008 1:05:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-02B

Client Sample ID: ROWEGWQ011608:NP1-1-6
Tag Number:
Collection Date: 1/16/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.0815	0.0200		mg/L	1	1/22/2008 10:41:15 AM
Manganese	0.175	0.0200		mg/L	1	1/22/2008 10:41:15 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** ROWEGWQ011608:NP1-1-6**Lab Order:** 0801215**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 1/16/2008 10:05:00 AM**Lab ID:** 0801215-02C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0453	0.0200		mg/L	1	1/22/2008 10:39:12 AM
Manganese	0.158	0.0200		mg/L	1	1/22/2008 10:39:12 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	90.0	1.00		mg/L	1	1/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-03A

Client Sample ID: ROWEGWQ011608:NP1-1-7
Tag Number:
Collection Date: 1/16/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,1,1-Trichloroethane	0.73	1.0	J	µg/L	1	1/22/2008 5:27:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,1-Dichloroethane	0.82	1.0	J	µg/L	1	1/22/2008 5:27:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
2-Butanone	U	3.0		µg/L	1	1/22/2008 5:27:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
2-Hexanone	U	2.0		µg/L	1	1/22/2008 5:27:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/22/2008 5:27:00 AM
Acetone	U	2.0		µg/L	1	1/22/2008 5:27:00 AM
Benzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Bromobenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Bromoform	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Bromomethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-03A

Client Sample ID: ROWEGWQ011608:NP1-1-7
Tag Number:
Collection Date: 1/16/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Chloroform	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Chloromethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Dibromomethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/22/2008 5:27:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Methylene chloride	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Naphthalene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
o-Xylene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Styrene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Tetrachloroethene	8.4	1.0		µg/L	1	1/22/2008 5:27:00 AM
Toluene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Trichloroethene	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/22/2008 5:27:00 AM
Surr: 4-Bromofluorobenzene	95.4	54-134		%REC	1	1/22/2008 5:27:00 AM
Surr: Dibromofluoromethane	96.5	52-132		%REC	1	1/22/2008 5:27:00 AM
Surr: Toluene-d8	93.7	51-127		%REC	1	1/22/2008 5:27:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** ROWEGWQ011608:NP1-1-7**Lab Order:** 0801215**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 1/16/2008 10:10:00 AM**Lab ID:** 0801215-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.125	0.0200		mg/L	1	1/22/2008 10:45:20 AM
Manganese	0.0758	0.0200		mg/L	1	1/22/2008 10:45:20 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** ROWEGWQ011608:NP1-1-7**Lab Order:** 0801215**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 1/16/2008 10:10:00 AM**Lab ID:** 0801215-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0499	0.0200		mg/L	1	1/22/2008 10:43:17 AM
Manganese	0.0593	0.0200		mg/L	1	1/22/2008 10:43:17 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	88.0	1.00		mg/L	1	1/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-04A

Client Sample ID: ROWEGWQ011608:NP1-I-8
Tag Number:
Collection Date: 1/16/2008 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
2-Butanone	U	3.0		µg/L	1	1/24/2008 1:41:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
2-Hexanone	U	2.0		µg/L	1	1/24/2008 1:41:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/24/2008 1:41:00 AM
Acetone	U	2.0		µg/L	1	1/24/2008 1:41:00 AM
Benzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Bromobenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Bromoform	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Bromomethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-04A

Client Sample ID: ROWEGWQ011608:NP1-1-8
Tag Number:
Collection Date: 1/16/2008 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Chloroform	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Chloromethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Dibromomethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/24/2008 1:41:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Methylene chloride	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Naphthalene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
o-Xylene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Styrene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Toluene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Trichloroethene	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/24/2008 1:41:00 AM
Surr: 4-Bromofluorobenzene	108	54-134		%REC	1	1/24/2008 1:41:00 AM
Surr: Dibromofluoromethane	105	52-132		%REC	1	1/24/2008 1:41:00 AM
Surr: Toluene-d8	96.0	51-127		%REC	1	1/24/2008 1:41:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** ROWEGWQ011608:NP1-1-8**Lab Order:** 0801215**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 1/16/2008 10:15:00 AM**Lab ID:** 0801215-04B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	7.19	0.0200		mg/L	1	1/22/2008 10:49:26 AM
Manganese	0.713	0.0200		mg/L	1	1/22/2008 10:49:26 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-04C

Client Sample ID: ROWEGWQ011608:NP1-1-8
Tag Number:
Collection Date: 1/16/2008 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	1.00	0.0200		mg/L	1	1/22/2008 10:47:22 AM
Manganese	0.569	0.0200		mg/L	1	1/22/2008 10:47:22 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	22.0	1.00		mg/L	1	1/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-05A

Client Sample ID: ROWEGWQ011608:NP1-1-9
Tag Number:
Collection Date: 1/16/2008 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
2-Butanone	U	3.0		µg/L	1	1/22/2008 6:17:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
2-Hexanone	U	2.0		µg/L	1	1/22/2008 6:17:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/22/2008 6:17:00 AM
Acetone	U	2.0		µg/L	1	1/22/2008 6:17:00 AM
Benzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Bromobenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Bromoform	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Bromomethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-05A

Client Sample ID: ROWEGWQ011608:NP1-1-9
Tag Number:
Collection Date: 1/16/2008 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Chloroform	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Chloromethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Dibromomethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/22/2008 6:17:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Methylene chloride	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Naphthalene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
o-Xylene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Styrene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Toluene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Trichloroethene	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/22/2008 6:17:00 AM
Surr: 4-Bromofluorobenzene	98.1	54-134		%REC	1	1/22/2008 6:17:00 AM
Surr: Dibromofluoromethane	97.0	52-132		%REC	1	1/22/2008 6:17:00 AM
Surr: Toluene-d8	94.9	51-127		%REC	1	1/22/2008 6:17:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-05B

Client Sample ID: ROWEGWQ011608:NP1-1-9
Tag Number:
Collection Date: 1/16/2008 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	3.85	0.0200		mg/L	1	1/22/2008 11:05:57 AM
Manganese	0.583	0.0200		mg/L	1	1/22/2008 11:05:57 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** ROWEGWQ011608:NP1-1-9**Lab Order:** 0801215**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 1/16/2008 10:20:00 AM**Lab ID:** 0801215-05C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	1.46	0.0200		mg/L	1	1/22/2008 11:03:53 AM
Manganese	0.537	0.0200		mg/L	1	1/22/2008 11:03:53 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	48.0	1.00		mg/L	1	1/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-06A

Client Sample ID: ROWEGWQ011608:NP1-1-4
Tag Number:
Collection Date: 1/16/2008 10:25:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,1,1-Trichloroethane	4.2	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
2-Butanone	U	3.0		µg/L	1	1/24/2008 2:22:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
2-Hexanone	U	2.0		µg/L	1	1/24/2008 2:22:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/24/2008 2:22:00 AM
Acetone	U	2.0		µg/L	1	1/24/2008 2:22:00 AM
Benzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Bromobenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Bromoform	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Bromomethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-06A

Client Sample ID: ROWEGWQ011608:NPI-1-4
Tag Number:
Collection Date: 1/16/2008 10:25:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Chloroform	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Chloromethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Dibromomethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/24/2008 2:22:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Methylene chloride	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Naphthalene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
o-Xylene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Styrene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Tetrachloroethene	7.9	1.0		µg/L	1	1/24/2008 2:22:00 AM
Toluene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Trichloroethene	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/24/2008 2:22:00 AM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	1/24/2008 2:22:00 AM
Surr: Dibromofluoromethane	100	52-132		%REC	1	1/24/2008 2:22:00 AM
Surr: Toluene-d8	97.0	51-127		%REC	1	1/24/2008 2:22:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** ROWEGWQ011608:NP1-1-4**Lab Order:** 0801215**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 1/16/2008 10:25:00 AM**Lab ID:** 0801215-06B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	4.67	0.0200		mg/L	1	1/22/2008 11:10:04 AM
Manganese	1.32	0.0200		mg/L	1	1/22/2008 11:10:04 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** ROWEGWQ011608:NP1-1-4**Lab Order:** 0801215**Tag Number:****Project:** Rowe, Sag Harbor**Collection Date:** 1/16/2008 10:25:00 AM**Lab ID:** 0801215-06C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.954	0.0200		mg/L	1	1/22/2008 11:08:00 AM
Manganese	1.17	0.0200		mg/L	1	1/22/2008 11:08:00 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	86.0	1.00		mg/L	1	1/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-07A

Client Sample ID: ROWEGWQ011608:NP1-1-2
Tag Number:
Collection Date: 1/16/2008 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,1,1-Trichloroethane	5.9	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,1-Dichloroethane	0.60	1.0	J	µg/L	1	1/22/2008 7:11:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
2-Butanone	U	3.0		µg/L	1	1/22/2008 7:11:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
2-Hexanone	U	2.0		µg/L	1	1/22/2008 7:11:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/22/2008 7:11:00 AM
Acetone	U	2.0		µg/L	1	1/22/2008 7:11:00 AM
Benzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Bromobenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Bromoform	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Bromomethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-07A

Client Sample ID: ROWEGWQ011608:NP1-1-2
Tag Number:
Collection Date: 1/16/2008 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Chloroform	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Chloromethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Dibromomethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/22/2008 7:11:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Methylene chloride	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Naphthalene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
o-Xylene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Styrene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Tetrachloroethene	2.0	1.0		µg/L	1	1/22/2008 7:11:00 AM
Toluene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Trichloroethene	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/22/2008 7:11:00 AM
Surr: 4-Bromofluorobenzene	93.0	54-134		%REC	1	1/22/2008 7:11:00 AM
Surr: Dibromofluoromethane	100	52-132		%REC	1	1/22/2008 7:11:00 AM
Surr: Toluene-d8	92.3	51-127		%REC	1	1/22/2008 7:11:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-07B

Client Sample ID: ROWEGWQ011608:NP1-1-2
Tag Number:
Collection Date: 1/16/2008 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	3.09	0.0200		mg/L	1	1/22/2008 11:14:10 AM
Manganese	0.597	0.0200		mg/L	1	1/22/2008 11:14:10 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-07C

Client Sample ID: ROWEGWQ011608:NPI-1-2
Tag Number:
Collection Date: 1/16/2008 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.185	0.0200		mg/L	1	1/22/2008 11:12:07 AM
Manganese	0.552	0.0200		mg/L	1	1/22/2008 11:12:07 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	124	1.00		mg/L	1	1/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-08A

Client Sample ID: ROWEGWQ011608:NP1-1-3
Tag Number:
Collection Date: 1/16/2008 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
2-Butanone	U	3.0		µg/L	1	1/24/2008 3:00:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
2-Hexanone	U	2.0		µg/L	1	1/24/2008 3:00:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/24/2008 3:00:00 AM
Acetone	U	2.0		µg/L	1	1/24/2008 3:00:00 AM
Benzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Bromobenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Bromoform	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Bromomethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-08A

Client Sample ID: ROWEGWQ011608:NPI-1-3
Tag Number:
Collection Date: 1/16/2008 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Chloroform	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Chloromethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Dibromomethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/24/2008 3:00:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Methylene chloride	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Naphthalene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
o-Xylene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Styrene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Toluene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Trichloroethene	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/24/2008 3:00:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	1/24/2008 3:00:00 AM
Surr: Dibromofluoromethane	107	52-132		%REC	1	1/24/2008 3:00:00 AM
Surr: Toluene-d8	97.6	51-127		%REC	1	1/24/2008 3:00:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-08B

Client Sample ID: ROWEGWQ011608:NP1-1-3
Tag Number:
Collection Date: 1/16/2008 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	3.73	0.0200		mg/L	1	1/22/2008 11:18:16 AM
Manganese	0.0547	0.0200		mg/L	1	1/22/2008 11:18:16 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.


Date: 24-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801215
Project: Rowe, Sag Harbor
Lab ID: 0801215-08C

Client Sample ID: ROWEGWQ011608:NP1-1-3
Tag Number:
Collection Date: 1/16/2008 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.229	0.0200		mg/L	1	1/22/2008 11:16:13 AM
Manganese	0.0416	0.0200		mg/L	1	1/22/2008 11:16:13 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	60.0	1.00		mg/L	1	1/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Tuesday, January 15, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe 1668 B.Hampton, Sag Harbor, NY

Order No.: 0801065

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/8/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab Order: 0801065

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0801065-01A	WQ1308:1000NP2-6		1/3/2008 10:00:00 AM	1/8/2008
0801065-01B	WQ1308:1000NP2-6		1/3/2008 10:00:00 AM	1/8/2008
0801065-01C	WQ1308:1000NP2-6		1/3/2008 10:00:00 AM	1/8/2008
0801065-02A	WQ1308:1005NP2-7		1/3/2008 10:05:00 AM	1/8/2008
0801065-02B	WQ1308:1005NP2-7		1/3/2008 10:05:00 AM	1/8/2008
0801065-02C	WQ1308:1005NP2-7		1/3/2008 10:05:00 AM	1/8/2008
0801065-03A	WQ1308:1010NP2-10		1/3/2008 10:10:00 AM	1/8/2008
0801065-03B	WQ1308:1010NP2-10		1/3/2008 10:10:00 AM	1/8/2008
0801065-03C	WQ1308:1010NP2-10		1/3/2008 10:10:00 AM	1/8/2008

TAG # / COC _____

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.

Client Sample ID: WQ1308:1000NP2-6

Lab Order: 0801065

Tag Number:

Project: Rowe 1668 B.Hampton, Sag Harbor, NY

Collection Date: 1/3/2008 10:00:00 AM

Lab ID: 0801065-01A

Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
2-Butanone	U	3.0		µg/L	1	1/8/2008 7:24:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
2-Hexanone	U	2.0		µg/L	1	1/8/2008 7:24:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/8/2008 7:24:00 PM
Acetone	U	2.0		µg/L	1	1/8/2008 7:24:00 PM
Benzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Bromobenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Bromoform	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Bromomethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-01A

Client Sample ID: WQ1308:1000NP2-6
Tag Number:
Collection Date: 1/3/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Chloroform	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Chloromethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Dibromomethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/8/2008 7:24:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Methylene chloride	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Naphthalene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
o-Xylene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Styrene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Tetrachloroethene	5.7	1.0		µg/L	1	1/8/2008 7:24:00 PM
Toluene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Trichloroethene	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/8/2008 7:24:00 PM
Surr: 4-Bromofluorobenzene	104	54-134		%REC	1	1/8/2008 7:24:00 PM
Surr: Dibromofluoromethane	98.6	52-132		%REC	1	1/8/2008 7:24:00 PM
Surr: Toluene-d8	98.2	51-127		%REC	1	1/8/2008 7:24:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-01B

Client Sample ID: WQ1308:1000NP2-6
Tag Number:
Collection Date: 1/3/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	20.3	0.0200		mg/L	1	1/14/2008 12:27:49 PM

Qualifiers:

B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-01C

Client Sample ID: WQ1308:1000NP2-6
Tag Number:
Collection Date: 1/3/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0303	0.0200		mg/L	1	1/14/2008 12:25:46 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-02A

Client Sample ID: WQ1308:1005NP2-7
Tag Number:
Collection Date: 1/3/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
2-Butanone	U	3.0		µg/L	1	1/8/2008 8:00:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
2-Hexanone	U	2.0		µg/L	1	1/8/2008 8:00:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/8/2008 8:00:00 PM
Acetone	U	2.0		µg/L	1	1/8/2008 8:00:00 PM
Benzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Bromobenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Bromoform	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Bromomethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-02A

Client Sample ID: WQ1308:1005NP2-7
Tag Number:
Collection Date: 1/3/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Chloroform	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Chloromethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Dibromomethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/8/2008 8:00:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Methylene chloride	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Naphthalene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
o-Xylene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Styrene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Toluene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Trichloroethene	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/8/2008 8:00:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	1/8/2008 8:00:00 PM
Surr: Dibromofluoromethane	99.7	52-132		%REC	1	1/8/2008 8:00:00 PM
Surr: Toluene-d8	98.2	51-127		%REC	1	1/8/2008 8:00:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-02B

Client Sample ID: WQ1308:1005NP2-7
Tag Number:
Collection Date: 1/3/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	83.3	0.0200		mg/L	1	1/14/2008 12:58:04 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-02C

Client Sample ID: WQ1308:1005NP2-7
Tag Number:
Collection Date: 1/3/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	1.53	0.0200		mg/L	1	1/14/2008 12:56:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-03A

Client Sample ID: WQ1308:1010NP2-10
Tag Number:
Collection Date: 1/3/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
2-Butanone	U	3.0		µg/L	1	1/8/2008 8:35:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
2-Hexanone	U	2.0		µg/L	1	1/8/2008 8:35:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/8/2008 8:35:00 PM
Acetone	U	2.0		µg/L	1	1/8/2008 8:35:00 PM
Benzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Bromobenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Bromoform	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Bromomethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-03A

Client Sample ID: WQ1308:1010NP2-10
Tag Number:
Collection Date: 1/3/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Chloroform	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Chloromethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Dibromomethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/8/2008 8:35:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Methylene chloride	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Naphthalene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
o-Xylene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Styrene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Toluene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Trichloroethene	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/8/2008 8:35:00 PM
Surr: 4-Bromofluorobenzene	100	54-134		%REC	1	1/8/2008 8:35:00 PM
Surr: Dibromofluoromethane	97.9	52-132		%REC	1	1/8/2008 8:35:00 PM
Surr: Toluene-d8	99.4	51-127		%REC	1	1/8/2008 8:35:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.**Date:** 15-Jan-08**CLIENT:** Leggette Brashears & Graham Inc.**Client Sample ID:** WQ1308:1010NP2-10**Lab Order:** 0801065**Tag Number:****Project:** Rowe 1668 B.Hampton, Sag Harbor, NY**Collection Date:** 1/3/2008 10:10:00 AM**Lab ID:** 0801065-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	124	0.0200		mg/L	1	1/14/2008 1:02:11 PM

Qualifiers:

B Analyte detected in the associated Method Blank

H Holding times for preparation or analysis exceeded

ND Not Detected at the Reporting Limit

U Indicates the compound was analyzed for but not detected

E Value above quantitation range

J Analyte detected below quantitation limits

S Spike Recovery outside accepted recovery limits

X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 15-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801065
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801065-03C

Client Sample ID: WQ1308:1010NP2-10
Tag Number:
Collection Date: 1/3/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	2.07	0.0200		mg/L	1	1/14/2008 1:00:07 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	126	1.00		mg/L	1	1/9/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, January 16, 2008 (pr)

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe 1668 B.Hampton, Sag Harbor, NY

Order No.: 0801121

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/11/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab Order: 0801121

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0801121-01A	WQ010908:1000NP2-6		1/9/2008 10:00:00 AM	1/11/2008
0801121-01B	WQ010908:1000NP2-6		1/9/2008 10:00:00 AM	1/11/2008
0801121-01C	WQ010908:1000NP2-6		1/9/2008 10:00:00 AM	1/11/2008
0801121-02A	WQ010908:1005NP2-7		1/9/2008 10:05:00 AM	1/11/2008
0801121-02B	WQ010908:1005NP2-7		1/9/2008 10:05:00 AM	1/11/2008
0801121-02C	WQ010908:1005NP2-7		1/9/2008 10:05:00 AM	1/11/2008
0801121-03A	WQ010908:1010NP2-10		1/9/2008 10:10:00 AM	1/11/2008
0801121-03B	WQ010908:1010NP2-10		1/9/2008 10:10:00 AM	1/11/2008
0801121-03C	WQ010908:1010NP2-10		1/9/2008 10:10:00 AM	1/11/2008

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0801121
 Project: Rowe 1668 B.Hampton, Sag Harbor, NY
 Lab ID: 0801121-01A

Client Sample ID: WQ010908:1000NP2-6
 Tag Number:
 Collection Date: 1/9/2008 10:00:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,1,1-Trichloroethane	1.8	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
2-Butanone	U	3.0		µg/L	1	1/12/2008 10:52:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
2-Hexanone	U	2.0		µg/L	1	1/12/2008 10:52:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/12/2008 10:52:00 AM
Acetone	U	2.0		µg/L	1	1/12/2008 10:52:00 AM
Benzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Bromobenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Bromoform	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Bromomethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-01A

Client Sample ID: WQ010908:1000NP2-6
Tag Number:
Collection Date: 1/9/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Chloroform	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Chloromethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Dibromomethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/12/2008 10:52:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Methylene chloride	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Naphthalene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
o-Xylene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Styrene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Tetrachloroethene	5.6	1.0		µg/L	1	1/12/2008 10:52:00 AM
Toluene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Trichloroethene	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/12/2008 10:52:00 AM
Surr: 4-Bromofluorobenzene	107	54-134		%REC	1	1/12/2008 10:52:00 AM
Surr: Dibromofluoromethane	95.5	52-132		%REC	1	1/12/2008 10:52:00 AM
Surr: Toluene-d8	100	51-127		%REC	1	1/12/2008 10:52:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-01B

Client Sample ID: WQ010908:1000NP2-6
Tag Number:
Collection Date: 1/9/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	7.98	0.0200		mg/L	1	1/14/2008 1:06:17 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-01C

Client Sample ID: WQ010908:1000NP2-6
Tag Number:
Collection Date: 1/9/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.104	0.0200		mg/L	1	1/14/2008 1:04:13 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-02A

Client Sample ID: WQ010908:1005NP2-7
Tag Number:
Collection Date: 1/9/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
2-Butanone	U	3.0		µg/L	1	1/12/2008 11:28:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
2-Hexanone	U	2.0		µg/L	1	1/12/2008 11:28:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/12/2008 11:28:00 AM
Acetone	U	2.0		µg/L	1	1/12/2008 11:28:00 AM
Benzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Bromobenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Bromoform	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Bromomethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-02A

Client Sample ID: WQ010908:1005NP2-7
Tag Number:
Collection Date: 1/9/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Chloroform	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Chloromethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Dibromomethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/12/2008 11:28:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Methylene chloride	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Naphthalene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
o-Xylene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Styrene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Toluene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Trichloroethene	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/12/2008 11:28:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	1/12/2008 11:28:00 AM
Surr: Dibromofluoromethane	96.5	52-132		%REC	1	1/12/2008 11:28:00 AM
Surr: Toluene-d8	101	51-127		%REC	1	1/12/2008 11:28:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-02B

Client Sample ID: WQ010908:1005NP2-7
Tag Number:
Collection Date: 1/9/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.30	0.0200		mg/L	1	1/14/2008 1:10:23 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-02C

Client Sample ID: WQ010908:1005NP2-7
Tag Number:
Collection Date: 1/9/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.159	0.0200		mg/L	1	1/14/2008 1:08:20 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-03A

Client Sample ID: WQ010908:1010NP2-10
Tag Number:
Collection Date: 1/9/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
2-Butanone	U	3.0		µg/L	1	1/12/2008 12:04:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
2-Hexanone	U	2.0		µg/L	1	1/12/2008 12:04:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/12/2008 12:04:00 PM
Acetone	U	2.0		µg/L	1	1/12/2008 12:04:00 PM
Benzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Bromobenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Bromoform	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Bromomethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-03A

Client Sample ID: WQ010908:1010NP2-10
Tag Number:
Collection Date: 1/9/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Chloroform	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Chloromethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Dibromomethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/12/2008 12:04:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Methylene chloride	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Naphthalene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
o-Xylene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Styrene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Toluene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Trichloroethene	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/12/2008 12:04:00 PM
Surr: 4-Bromofluorobenzene	105	54-134		%REC	1	1/12/2008 12:04:00 PM
Surr: Dibromofluoromethane	91.5	52-132		%REC	1	1/12/2008 12:04:00 PM
Surr: Toluene-d8	101	51-127		%REC	1	1/12/2008 12:04:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-03B

Client Sample ID: WQ010908:1010NP2-10
Tag Number:
Collection Date: 1/9/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.70	0.0200		mg/L	1	1/14/2008 1:14:28 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.


Date: 16-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801121
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801121-03C

Client Sample ID: WQ010908:1010NP2-10
Tag Number:
Collection Date: 1/9/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.126	0.0200		mg/L	1	1/14/2008 1:12:26 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	80.0	1.00		mg/L	1	1/15/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, January 23, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484
TEL: (203) 929-8555
FAX (203) 926-9140
RE: Rowe 1668 B.Hampton, Sag Harbor, NY

Order No.: 0801213

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/18/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab Order: 0801213

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0801213-01A	ROWEWQ011608:900NP2-		1/16/2008 9:00:00 AM	1/18/2008
0801213-01B	ROWEWQ011608:900NP2-		1/16/2008 9:00:00 AM	1/18/2008
0801213-01C	ROWEWQ011608:900NP2-		1/16/2008 9:00:00 AM	1/18/2008
0801213-02A	ROWEWQ011608:905NP2-		1/16/2008 9:05:00 AM	1/18/2008
0801213-02B	ROWEWQ011608:905NP2-		1/16/2008 9:05:00 AM	1/18/2008
0801213-02C	ROWEWQ011608:905NP2-		1/16/2008 9:05:00 AM	1/18/2008
0801213-03A	ROWEWQ011608:910NP2-		1/16/2008 9:10:00 AM	1/18/2008
0801213-03B	ROWEWQ011608:910NP2-		1/16/2008 9:10:00 AM	1/18/2008
0801213-03C	ROWEWQ011608:910NP2-		1/16/2008 9:10:00 AM	1/18/2008

56 TOLEDO STREET • FARMINGDALE, NEW YORK 11735
(631) 454-6100 • FAX (631) 454-8027

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801213
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801213-01A

Client Sample ID: ROWEWQ011608:900NP2-6
Tag Number:
Collection Date: 1/16/2008 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,1,1-Trichloroethane	1.4	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
2-Butanone	U	3.0		µg/L	1	1/21/2008 8:46:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
2-Hexanone	U	2.0		µg/L	1	1/21/2008 8:46:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/21/2008 8:46:00 PM
Acetone	U	2.0		µg/L	1	1/21/2008 8:46:00 PM
Benzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Bromobenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Bromoform	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Bromomethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801213
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801213-01A

Client Sample ID: ROWEWQ011608:900NP2-6
Tag Number:
Collection Date: 1/16/2008 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Chloroform	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Chloromethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Dibromomethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/21/2008 8:46:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Methylene chloride	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Naphthalene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
o-Xylene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Styrene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Tetrachloroethene	4.1	1.0		µg/L	1	1/21/2008 8:46:00 PM
Toluene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Trichloroethene	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/21/2008 8:46:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	1/21/2008 8:46:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	1/21/2008 8:46:00 PM
Surr: Toluene-d8	100	51-127		%REC	1	1/21/2008 8:46:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801213
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801213-01B

Client Sample ID: ROWEWQ011608:900NP2-6
Tag Number:
Collection Date: 1/16/2008 9:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.10	0.0200		mg/L	1	1/22/2008 9:49:48 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	ROWEWQ011608:900NP2-6
Lab Order:	0801213	Tag Number:	
Project:	Rowe 1668 B.Hampton, Sag Harbor, NY	Collection Date:	1/16/2008 9:00:00 AM
Lab ID:	0801213-01C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0503	0.0200		mg/L	1	1/22/2008 9:47:45 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801213
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801213-02A

Client Sample ID: ROWEWQ011608:905NP2-7
Tag Number:
Collection Date: 1/16/2008 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
2-Butanone	U	3.0		µg/L	1	1/21/2008 9:22:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
2-Hexanone	U	2.0		µg/L	1	1/21/2008 9:22:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/21/2008 9:22:00 PM
Acetone	U	2.0		µg/L	1	1/21/2008 9:22:00 PM
Benzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Bromobenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Bromoform	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Bromomethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0801213
 Project: Rowe 1668 B.Hampton, Sag Harbor, NY
 Lab ID: 0801213-02A

Client Sample ID: ROWEWQ011608:905NP2-7
 Tag Number:
 Collection Date: 1/16/2008 9:05:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Chloroform	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Chloromethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Dibromomethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/21/2008 9:22:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Methylene chloride	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Naphthalene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
o-Xylene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Styrene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Toluene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Trichloroethene	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/21/2008 9:22:00 PM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	1/21/2008 9:22:00 PM
Surr: Dibromofluoromethane	108	52-132		%REC	1	1/21/2008 9:22:00 PM
Surr: Toluene-d8	97.4	51-127		%REC	1	1/21/2008 9:22:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801213
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801213-02B

Client Sample ID: ROWEWQ011608:905NP2-7
Tag Number:
Collection Date: 1/16/2008 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	3.11	0.0200		mg/L	1	1/22/2008 9:53:54 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801213
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801213-02C

Client Sample ID: ROWEWQ011608:905NP2-7
Tag Number:
Collection Date: 1/16/2008 9:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.160	0.0200		mg/L	1	1/22/2008 9:51:51 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801213
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801213-03A

Client Sample ID: ROWEWQ011608:910NP2-10
Tag Number:
Collection Date: 1/16/2008 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
2-Butanone	U	3.0		µg/L	1	1/21/2008 9:57:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
2-Hexanone	U	2.0		µg/L	1	1/21/2008 9:57:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/21/2008 9:57:00 PM
Acetone	U	2.0		µg/L	1	1/21/2008 9:57:00 PM
Benzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Bromobenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Bromochloromethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Bromodichloromethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Bromoform	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Bromomethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Carbon disulfide	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Chlorobenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801213
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801213-03A

Client Sample ID: ROWEWQ011608:910NP2-10
Tag Number:
Collection Date: 1/16/2008 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Chloroform	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Chloromethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Dibromochloromethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Dibromomethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Ethylbenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Isopropylbenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
m,p-Xylene	U	2.0		µg/L	1	1/21/2008 9:57:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Methylene chloride	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Naphthalene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
n-Butylbenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
n-Propylbenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
o-Xylene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Styrene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Tetrachloroethene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Toluene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Trichloroethene	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Vinyl acetate	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Vinyl chloride	U	1.0		µg/L	1	1/21/2008 9:57:00 PM
Surr: 4-Bromofluorobenzene	108	54-134		%REC	1	1/21/2008 9:57:00 PM
Surr: Dibromofluoromethane	104	52-132		%REC	1	1/21/2008 9:57:00 PM
Surr: Toluene-d8	96.2	51-127		%REC	1	1/21/2008 9:57:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** ROWEWQ011608:910NP2-10**Lab Order:** 0801213**Tag Number:****Project:** Rowe 1668 B.Hampton, Sag Harbor, NY**Collection Date:** 1/16/2008 9:10:00 AM**Lab ID:** 0801213-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.96	0.0200		mg/L	1	1/22/2008 9:57:58 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 23-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801213
Project: Rowe 1668 B.Hampton, Sag Harbor, NY
Lab ID: 0801213-03C

Client Sample ID: ROWEWQ011608:910NP2-10
Tag Number:
Collection Date: 1/16/2008 9:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.160	0.0200		mg/L	1	1/22/2008 9:55:56 AM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	64.0	1.00		mg/L	1	1/22/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Thursday, January 31, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 0801362

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 1/29/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0801362

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0801362-01A	WQ012408:1100NP2-6		1/24/2008 11:00:00 AM	1/29/2008
0801362-01B	WQ012408:1100NP2-6		1/24/2008 11:00:00 AM	1/29/2008
0801362-01C	WQ012408:1100NP2-6		1/24/2008 11:00:00 AM	1/29/2008
0801362-02A	WQ012408:1105NP2-7		1/24/2008 11:05:00 AM	1/29/2008
0801362-02B	WQ012408:1105NP2-7		1/24/2008 11:05:00 AM	1/29/2008
0801362-02C	WQ012408:1105NP2-7		1/24/2008 11:05:00 AM	1/29/2008
0801362-03A	WQ012408:1110NP2-10		1/24/2008 11:10:00 AM	1/29/2008
0801362-03B	WQ012408:1110NP2-10		1/24/2008 11:10:00 AM	1/29/2008
0801362-03C	WQ012408:1110NP2-10		1/24/2008 11:10:00 AM	1/29/2008

[illegible]

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENBOD-CIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801362
Project: Rowe
Lab ID: 0801362-01A

Client Sample ID: WQ012408:1100NP2-6
Tag Number:
Collection Date: 1/24/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,1,1-Trichloroethane	1.8	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
2-Butanone	U	3.0		µg/L	1	1/31/2008 2:51:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
2-Hexanone	U	2.0		µg/L	1	1/31/2008 2:51:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/31/2008 2:51:00 AM
Acetone	U	2.0		µg/L	1	1/31/2008 2:51:00 AM
Benzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Bromobenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Bromoform	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Bromomethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801362
Project: Rowe
Lab ID: 0801362-01A

Client Sample ID: WQ012408:1100NP2-6
Tag Number:
Collection Date: 1/24/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Chloroform	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Chloromethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Dibromomethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/31/2008 2:51:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Methylene chloride	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Naphthalene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
o-Xylene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Styrene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Tetrachloroethene	5.6	1.0		µg/L	1	1/31/2008 2:51:00 AM
Toluene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Trichloroethene	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/31/2008 2:51:00 AM
Surr: 4-Bromofluorobenzene	109	54-134		%REC	1	1/31/2008 2:51:00 AM
Surr: Dibromofluoromethane	98.0	52-132		%REC	1	1/31/2008 2:51:00 AM
Surr: Toluene-d8	94.3	51-127		%REC	1	1/31/2008 2:51:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801362
Project: Rowe
Lab ID: 0801362-01B

Client Sample ID: WQ012408:1100NP2-6
Tag Number:
Collection Date: 1/24/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.79	0.0200		mg/L	1	1/30/2008 3:57:49 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801362
Project: Rowe
Lab ID: 0801362-01C

Client Sample ID: WQ012408:1100NP2-6
Tag Number:
Collection Date: 1/24/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0437	0.0200		mg/L	1	1/30/2008 3:55:44 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801362
Project: Rowe
Lab ID: 0801362-02A

Client Sample ID: WQ012408:1105NP2-7
Tag Number:
Collection Date: 1/24/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
2-Butanone	U	3.0		µg/L	1	1/31/2008 3:19:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
2-Hexanone	U	2.0		µg/L	1	1/31/2008 3:19:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/31/2008 3:19:00 AM
Acetone	U	2.0		µg/L	1	1/31/2008 3:19:00 AM
Benzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Bromobenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Bromoform	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Bromomethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801362
Project: Rowe
Lab ID: 0801362-02A

Client Sample ID: WQ012408:1105NP2-7
Tag Number:
Collection Date: 1/24/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Chloroform	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Chloromethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Dibromomethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/31/2008 3:19:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Methylene chloride	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Naphthalene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
o-Xylene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Styrene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Toluene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Trichloroethene	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/31/2008 3:19:00 AM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	1/31/2008 3:19:00 AM
Surr: Dibromofluoromethane	102	52-132		%REC	1	1/31/2008 3:19:00 AM
Surr: Toluene-d8	92.9	51-127		%REC	1	1/31/2008 3:19:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ012408:1105NP2-7**Lab Order:** 0801362**Tag Number:****Project:** Rowe**Collection Date:** 1/24/2008 11:05:00 AM**Lab ID:** 0801362-02B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	5.25	0.0200		mg/L	1	1/30/2008 4:01:56 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801362
Project: Rowe
Lab ID: 0801362-02C

Client Sample ID: WQ012408:1105NP2-7
Tag Number:
Collection Date: 1/24/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.174	0.0200		mg/L	1	1/30/2008 3:59:52 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801362
Project: Rowe
Lab ID: 0801362-03A

Client Sample ID: WQ012408:1110NP2-10
Tag Number:
Collection Date: 1/24/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
2-Butanone	U	3.0		µg/L	1	1/31/2008 3:49:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
2-Hexanone	U	2.0		µg/L	1	1/31/2008 3:49:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	1/31/2008 3:49:00 AM
Acetone	U	2.0		µg/L	1	1/31/2008 3:49:00 AM
Benzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Bromobenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Bromochloromethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Bromodichloromethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Bromoform	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Bromomethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Carbon disulfide	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Chlorobenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0801362
Project: Rowe
Lab ID: 0801362-03A

Client Sample ID: WQ012408:1110NP2-10
Tag Number:
Collection Date: 1/24/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LDS		
Chloroethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Chloroform	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Chloromethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Dibromochloromethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Dibromomethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Ethylbenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Isopropylbenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
m,p-Xylene	U	2.0		µg/L	1	1/31/2008 3:49:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Methylene chloride	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Naphthalene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
n-Butylbenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
n-Propylbenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
o-Xylene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Styrene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Tetrachloroethene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Toluene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Trichloroethene	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Vinyl acetate	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Vinyl chloride	U	1.0		µg/L	1	1/31/2008 3:49:00 AM
Surr: 4-Bromofluorobenzene	109	54-134		%REC	1	1/31/2008 3:49:00 AM
Surr: Dibromofluoromethane	100	52-132		%REC	1	1/31/2008 3:49:00 AM
Surr: Toluene-d8	93.8	51-127		%REC	1	1/31/2008 3:49:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ012408:1110NP2-10**Lab Order:** 0801362**Tag Number:****Project:** Rowe**Collection Date:** 1/24/2008 11:10:00 AM**Lab ID:** 0801362-03B**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	4.87	0.0200		mg/L	1	1/30/2008 4:06:04 PM

Qualifiers:

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 31-Jan-08

CLIENT: Leggette Brashears & Graham Inc.**Client Sample ID:** WQ012408:1110NP2-10**Lab Order:** 0801362**Tag Number:****Project:** Rowe**Collection Date:** 1/24/2008 11:10:00 AM**Lab ID:** 0801362-03C**Matrix:** LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.192	0.0200		mg/L	1	1/30/2008 4:04:00 PM
TOTAL DISSOLVED SOLIDS		E160.1				Analyst: SAP
Total Dissolved Solids (Residue, Filterable)	112	1.00		mg/L	1	1/30/2008

Qualifiers:

B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Wednesday, February 13, 2008 *(pm)*

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0802085

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 2/6/2008 for the analyses presented in the following report.

Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,

Lori Beyer
Lori Beyer
Lab Director

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0802085

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0802085-01A	ROWEWQ013008:1000NP		1/30/2008 10:00:00 AM	2/6/2008
0802085-01B	ROWEWQ013008:1000NP		1/30/2008 10:00:00 AM	2/6/2008
0802085-01C	ROWEWQ013008:1000NP		1/30/2008 10:00:00 AM	2/6/2008
0802085-02A	ROWEWQ013008:1005NP		1/30/2008 10:05:00 AM	2/6/2008
0802085-02B	ROWEWQ013008:1005NP		1/30/2008 10:05:00 AM	2/6/2008
0802085-02C	ROWEWQ013008:1005NP		1/30/2008 10:05:00 AM	2/6/2008
0802085-03A	ROWEWQ013008:1010NP		1/30/2008 10:10:00 AM	2/6/2008
0802085-03B	ROWEWQ013008:1010NP		1/30/2008 10:10:00 AM	2/6/2008
0802085-03C	ROWEWQ013008:1010NP		1/30/2008 10:10:00 AM	2/6/2008

TAG # / COC

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

[illegible]

* only one unpreserved bottle available for NP2-10. Please sample accordingly.

COOLER TEMPERATURE:

COMMENTS / INSTRUCTIONS

TURNAROUND REQUIRED:

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL

TYPE G=GRAB; C=COMPOSITE SS=SPLIT SPOON

NORMAL ☒ STAT ☐ BY /

RELINQUISHED BY (SIGNATURE)

PRINTED NAME _____

DATE _____

PRINTED NAME

RELINQUISHED BY (SIGNATURE)

PRINTED NAME

DATE _____

PRINTED NAME _____

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOI DENBOD-CI IDENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: (1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.) (2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of The method allowable holding time

CLIENT: Leggette Brashears & Graham Inc.

Project: Rowe

Lab Order: 0802085

CASE NARRATIVE

Samples were analyzed using the methods outlined throughout the text of the report. Due to the time period that elapsed from sample collection to receipt at the laboratory, the TSS holding time of 7 days was exceeded by one (1) day.

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-01A

Client Sample ID: ROWEWQ013008:1000NP2-6
Tag Number:
Collection Date: 1/30/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,1,1-Trichloroethane	1.8	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
2-Butanone	U	3.0		µg/L	1	2/7/2008 9:50:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
2-Hexanone	U	2.0		µg/L	1	2/7/2008 9:50:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/7/2008 9:50:00 AM
Acetone	U	2.0		µg/L	1	2/7/2008 9:50:00 AM
Benzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Bromobenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Bromoform	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Bromomethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-01A

Client Sample ID: ROWEWQ013008:1000NP2-6
Tag Number:
Collection Date: 1/30/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Chloroform	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Chloromethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Dibromomethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/7/2008 9:50:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Methylene chloride	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Naphthalene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
o-Xylene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Styrene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Tetrachloroethene	6.7	1.0		µg/L	1	2/7/2008 9:50:00 AM
Toluene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Trichloroethene	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/7/2008 9:50:00 AM
Surr: 4-Bromofluorobenzene	111	54-134		%REC	1	2/7/2008 9:50:00 AM
Surr: Dibromofluoromethane	84.2	52-132		%REC	1	2/7/2008 9:50:00 AM
Surr: Toluene-d8	111	51-127		%REC	1	2/7/2008 9:50:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-01B

Client Sample ID: ROWEWQ013008:1000NP2-6
Tag Number:
Collection Date: 1/30/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.92	0.0200		mg/L	1	2/11/2008 3:02:02 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-01C

Client Sample ID: ROWEWQ013008:1000NP2-6
Tag Number:
Collection Date: 1/30/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0204	0.0200		mg/L	1	2/11/2008 3:00:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-02A

Client Sample ID: ROWEWQ013008:1005NP2-7
Tag Number:
Collection Date: 1/30/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
2-Butanone	U	3.0		µg/L	1	2/7/2008 10:26:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
2-Hexanone	U	2.0		µg/L	1	2/7/2008 10:26:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/7/2008 10:26:00 AM
Acetone	U	2.0		µg/L	1	2/7/2008 10:26:00 AM
Benzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Bromobenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Bromoform	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Bromomethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0802085
 Project: Rowe
 Lab ID: 0802085-02A

Client Sample ID: ROWEWQ013008:1005NP2-7
 Tag Number:
 Collection Date: 1/30/2008 10:05:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Chloroform	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Chloromethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Dibromomethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/7/2008 10:26:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Methylene chloride	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Naphthalene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
o-Xylene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Styrene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Toluene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Trichloroethene	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/7/2008 10:26:00 AM
Surr: 4-Bromofluorobenzene	115	54-134		%REC	1	2/7/2008 10:26:00 AM
Surr: Dibromofluoromethane	81.9	52-132		%REC	1	2/7/2008 10:26:00 AM
Surr: Toluene-d8	107	51-127		%REC	1	2/7/2008 10:26:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-02B

Client Sample ID: ROWEWQ013008:1005NP2-7
Tag Number:
Collection Date: 1/30/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.65	0.0200		mg/L	1	2/11/2008 3:06:06 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-02C

Client Sample ID: ROWEWQ013008:1005NP2-7
Tag Number:
Collection Date: 1/30/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0557	0.0200		mg/L	1	2/11/2008 3:04:04 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-03A

Client Sample ID: ROWEWQ013008:1010NP2-10
Tag Number:
Collection Date: 1/30/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
2-Butanone	U	3.0		µg/L	1	2/7/2008 11:04:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
2-Hexanone	U	2.0		µg/L	1	2/7/2008 11:04:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/7/2008 11:04:00 AM
Acetone	U	2.0		µg/L	1	2/7/2008 11:04:00 AM
Benzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Bromobenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Bromoform	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Bromomethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-03A

Client Sample ID: ROWEWQ013008:1010NP2-10
Tag Number:
Collection Date: 1/30/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Chloroform	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Chloromethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Dibromomethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/7/2008 11:04:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Methylene chloride	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Naphthalene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
o-Xylene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Styrene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Toluene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Trichloroethene	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/7/2008 11:04:00 AM
Surr: 4-Bromofluorobenzene	111	54-134		%REC	1	2/7/2008 11:04:00 AM
Surr: Dibromofluoromethane	82.7	52-132		%REC	1	2/7/2008 11:04:00 AM
Surr: Toluene-d8	111	51-127		%REC	1	2/7/2008 11:04:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-03B

Client Sample ID: ROWEWQ013008:1010NP2-10
Tag Number:
Collection Date: 1/30/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.55	0.0200		mg/L	1	2/11/2008 3:10:11 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 13-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802085
Project: Rowe
Lab ID: 0802085-03C

Client Sample ID: ROWEWQ013008:1010NP2-10
Tag Number:
Collection Date: 1/30/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0925	0.0200		mg/L	1	2/11/2008 3:08:08 PM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	125	1.00	H	mg/L	1	2/7/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

H8A180110 Analytical Report	1
Sample Receipt Documentation	15
Total Number of Pages	17

ANALYTICAL REPORT


Rowe-NABSAG 0401

Lot #: H8A180110

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

TESTAMERICA LABORATORIES, INC.



Jamie A. McKinney
Project Manager

January 25, 2008

ANALYTICAL METHODS SUMMARY

H8A180110

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15

References:

EPA-2 "Compendium of Methods for the Determination of Toxic
Organic Compounds in Ambient Air", EPA-625/R-96/010b,
January 1999.

SAMPLE SUMMARY

H8A180110

WO #	SAMPLE#	CLIENT SAMPLE ID	SAMPLED DATE	SAMP TIME
KFQHH	001	AQ011608:900NP4-1	01/16/08	09:00
KFQHM	002	AQ011608:905NP4-2	01/16/08	09:05
KFQHP	003	AQ011608:910NP4-3	01/16/08	09:10

NOTE (S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

H8A180110

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

There were no problems with the condition of the samples received.

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

The samples were received on 01/18/08 in Tedlar bags and transferred into Summa Canisters within 72 hours of sampling.

TestAmerica Knoxville maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. #QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ011608:900NP4-1
 GC/MS Volatiles

Lot-Sample # H8A180110 - 001

Work Order # KFQHH1AA

Matrix.....: AIR

Date Sampled...: 1/16/08

Date Received...: 1/18/08

Prep Date.....: 1/23/08

Analysis Date...: 1/23/08

Prep Batch #.....: 8024100

Dilution Factor.: 5

Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	0.42	2.5	1.3	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	0.52	1.0	2.5	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	2.0	1.0	7.9	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	ND	1.0	ND	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	12	2.5	40	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	4.7	1.0	32	6.8
Toluene	ND	1.0	ND	3.8
1,1,1-Trichloroethane	4.1	1.0	22	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	125	70 - 130
Toluene-d8	104	70 - 130
4-Bromofluorobenzene	102	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ011608:900NP4-1
GC/MS Volatiles

Lot-Sample # H8A180110 - 001 Work Order # KFQHH1AA Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ011608:905NP4-2
 GC/MS Volatiles

Lot-Sample # H8A180110 - 002

Work Order # KFQHM1AA

Matrix.....: AIR

Date Sampled...: 1/16/08
 Prep Date.....: 1/23/08
 Prep Batch #.....: 8024100
 Dilution Factor.: 5

Date Received..: 1/18/08
 Analysis Date... 1/24/08
 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	0.78	2.5	2.4	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.4	1.0	6.6	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	3.7	1.0	15	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	ND	1.0	ND	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	ND	2.5	ND	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	31	1.0	210	6.8
Toluene	ND	1.0	ND	3.8
1,1,1-Trichloroethane	14	1.0	79	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	1.3	1.0	7.0	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	126	70 - 130
Toluene-d8	107	70 - 130
4-Bromofluorobenzene	106	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ011608:905NP4-2
GC/MS Volatiles

Lot-Sample # H8A180110 - 002

Work Order # KFQHM1AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ011608:910NP4-3
 GC/MS Volatiles

Lot-Sample # H8A180110 - 003 Work Order # KFQHP1AA Matrix.....: AIR

Date Sampled...: 1/16/08 Date Received...: 1/18/08
 Prep Date.....: 1/23/08 Analysis Date...: 1/24/08
 Prep Batch #.....: 8024100
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	1.1	2.5	3.4 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.7	1.0	8.2	4.9
Chloromethane	ND	2.5	ND	5.2
1,1-Dichloroethane	5.4	1.0	22	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.64	1.0	2.5 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	ND	2.5	ND	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	ND	1.0	ND	6.8
Toluene	0.86	1.0	3.2 J	3.8
1,1,1-Trichloroethane	26	1.0	140	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	ND	1.0	ND	5.4
Vinyl chloride	0.44	1.0	1.1 J	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	119	70 - 130
Toluene-d8	106	70 - 130
4-Bromofluorobenzene	96	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ011608:910NP4-3
GC/MS Volatiles

Lot-Sample # H8A180110 - 003

Work Order # KFQHP1AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: INTRA-LAB BLANK
 GC/MS Volatiles

Lot-Sample # H8A240000 - 100B

Work Order # KF2A61AA

Matrix.....: AIR

Prep Date.....: 1/23/08
 Prep Batch #.....: 8024100
 Dilution Factor.: 1

Date Received..: 1/21/08
 Analysis Date... 1/23/08
 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	1.6
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	ND	0.50	ND	1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	113	70 - 130
Toluene-d8	109	70 - 130
4-Bromofluorobenzene	98	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: INTRA-LAB BLANK
GC/MS Volatiles

Lot-Sample # H8A240000 - 100B

Work Order # KF2A61AA

Matrix.....: AIR

The 'Result' in ug/m3 is calculated using the following equation: $\text{Amount Found}(\text{before rounding}) \times (\text{Molecular Weight}/24.45)$

The 'Reporting Limit' in ug/m3 is calculated using the following equation: $(\text{Reporting Limit}(\text{before rounding}) \times \text{Dilution Factor}) \times (\text{Molecular Weight}/24.45)$

Leggette, Brashears & Graham, Inc.
 Client Sample ID: CHECK SAMPLE
 GC/MS Volatiles

Lot-Sample # H8A240000 - 100C Work Order # KF2A61AC Matrix.....: AIR

Prep Date.....: 1/23/08 Date Received...: 1/21/08
 Prep Batch #.....: 8024100 Analysis Date...: 1/23/08
 Dilution Factor.: 1 Method.....: TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	10.0	9.35	32	30	94	70 - 130
Chlorobenzene	10.0	9.47	46	44	95	70 - 130
1,1-Dichloroethene	10.0	9.92	40	39	99	70 - 130
Toluene	10.0	8.71	38	33	87	70 - 130
Trichloroethene	10.0	9.52	54	51	95	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	115	70 - 130
Toluene-d8	101	70 - 130
4-Bromofluorobenzene	107	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

STL Knoxville

5815 Middlebrook Pike • Knoxville, TN 37921-5947
Phone: (865) 291-3000 • Fax: (865) 584-4315
Receiving: (865) 291-3031

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD*

118A180110

Reference Document No.
Page 1 of 1

Project Name/No. ¹ Rowle
Sample Team Members ² Erin/Steve
Profit Center No. ³ NAK5AG 04 01
Project Manager ⁴ Mark K. Goldberg
Purchase Order No. ⁵ _____
Required Report Date ¹¹ _____

Samples Shipment Date ⁷ 1/17/08
Lab Destination ⁸ _____
Lab Contact ⁹ Jamie McKenney
Project Contact / Phone ¹² _____
Carrier / Waybill No. ¹³ _____

Bill to: ⁵ Mark H. Goldberg
Leggett & Plaskett + Co. Inc.
4 Research Pl. Suite 301
Shelton, CT 06484
Report to: ¹⁰ Same

Required Report Date ¹¹ _____

ONE CONTAINER PER LINE

Sample Number	Sample Type	Date/Time Collected	Container Type	Sample Volume	Pre-19 servative	Requested Testing Program	Condition on Receipt Lab use only
AQ011608:910 NP41	Air	1/16/08 9am	Tedlar	1 L	—	TO-15	Custody seals intact ☒ N NA
AQ011608:905 NP42	↓	1 9:05 am	↓	↓	↓	↓	Temperature received at <u>AMBIENT</u>
AQ011608:910 NP43	↓	↓ 9:10 am	↓	↓	↓	↓	Received by <u>RH</u> Date <u>1/18/08</u>
							Number of packages <u>1</u>
							Tracking # <u>798853943424</u>
							<u>FED EX</u>

Special Instructions: ²³

Possible Hazard Identification: ²⁴

Non-Hazard ☒ Flammable ☐ Skin Irritant ☐ Poison B ☐ Unknown ☐

Turnaround Time Required: ²⁶

Normal ☒ Rush ☐

1. Relinquished by ²⁸

(Signature / Affiliation) Mark M. Goldberg Date: 1/17/08 Time: 17:00

1. Relinquished by

(Signature / Affiliation) _____ Date: _____ Time: _____

Comments: ²⁹

Sample Disposal: ²⁵

Return to Client ☐ Disposal by Lab ☒ Archive (mos.)

Project Specific (specify): Full QA/QC

1. Received by ²⁸

(Signature / Affiliation) Lynne Henry Date: 1/18/08 Time: 0945

1. Received by

(Signature / Affiliation) _____ Date: _____ Time: _____

TESTAMERICA KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: _____ Project: _____ Lot Number: A8A180110

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)	☒			☐ 1a Do not match COC ☐ 1b Incomplete information ☐ 1c Marking smeared ☐ 1d Label torn ☐ 1e No label ☐ 1f COC not received ☐ 1g Other: _____	
2. Is the cooler temperature within limits? (> freezing temp. of water to 6°C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6 °C)			☒	☐ 2a Temp Blank = _____ ☐ 2b Cooler Temp = _____	
3. Were samples received with correct chemical preservative (excluding Encore)?			☒	☐ 3a Sample preservative = _____	
4. Were custody seals present/intact on cooler and/or containers?	☒			☐ 4a Not present ☐ 4b Not intact ☐ 4c Other: _____	
5. Were all of the samples listed on the COC received?	☒			☐ 5a Samples received-not on COC ☐ 5b Samples not received-on COC	
6. Were all of the sample containers received intact?	☒			☐ 6a Leaking ☐ 6b Broken	
7. Were VOA samples received without headspace?			☒	☐ 7a Headspace (VOA only)	
8. Were samples received in appropriate containers?	☒			☐ 8a Improper container	
9. Did you check for residual chlorine, if necessary?			☒	☐ 9a Could not be determined due to matrix interference	
10. Were samples received within holding time?	☒			☐ 10a Holding time expired	
11. For rad samples, was sample activity info. provided?			☒	☐ Incomplete information	
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?			☒	If yes & appears to be >1%, was SOG notified? _____	
13. Are the shipping containers intact?	☒			☐ 13a Leaking ☐ 13b Other: _____	
14. Was COC relinquished? (Signed/Dated/Timed)	☒			☐ 14a Not relinquished	
15. Are tests/parameters listed for each sample?	☒			☐ 15a Incomplete information	
16. Is the matrix of the samples noted?	☒			☐ 15a Incomplete information	
17. Is the date/time of sample collection noted?	☒			☐ 15a Incomplete information	
18. Is the client and project name/# identified?	☒			☐ 15a Incomplete information	
19. Was the sampler identified on the COC?	☒				
Quote #: <u>69110</u> PM Instructions: _____					

Sample Receiving Associate: Ryan Henry Date: 1/8/08 QA026R19.doc, 080707