

PROJECT STATUS MEMORANDUM

NO. 02-08

TO: Pamela Tames, USEPA

FROM: Mark M. Goldberg, P.E.
Tunde H. Komuves-Sandor

DATE: April 7, 2008

PROJECT: Rowe Industries Superfund Site
Ground-Water Recovery and Treatment System
February 2008 Status Report
Sag Harbor, New York

LBG Engineering Services, P.C. (LBG) commenced operation of the ground-water remediation system at the above-referenced site on December 17, 2002. This status report presents a summary of system performance, operation and maintenance, and monitoring activities for the site from February 1, 2008 through February 29, 2008. The report includes a summary of system performance parameters, system operation parameters, and analytical results for ground water, system effluent samples, and air quality results.

SUMMARY OF SYSTEM PERFORMANCE AND OPERATION

(February 1, 2008 through February 29, 2008)

- | | |
|---|----------------------------------|
| 1. Hours of operation during the reporting period: | 598 hours (86%) |
| 2. Alarm conditions during the reporting period: | See Table 1 |
| 3. Was the SPDES VOC discharge permit criteria achieved: | yes, (Table 2) |
| 4. Total volume of water pumped during the reporting period: | 14,491,344 gal. |
| 5. Was the system effluent flow below the SPDES limit of 1,023,000 gpd: yes, (Graph 1) | |
| 6. Mass of VOCs recovered during the reporting period: | 0.6 pounds |
| 7. Cumulative mass of VOCs recovered since startup on 12/17/02:
(calculations can be provided upon request) | 209.2 pounds |
| 8. Effluent VOC vapor concentration for the reporting period: | 0.16 mg/m ³ (Table 3) |
| 9. Was the effluent VOC vapor emission rate below 0.022 lbs/hr.:
(calculations can be provided upon request) | yes (0.00116 lbs/hr) |

GROUND-WATER RECOVERY SYSTEM STATUS SUMMARY

The following table summarizes select recovery well parameters for the reporting period. Table 4 presents a summary of the quality results for water samples collected from recovery wells. Graph 2 presents PCE concentrations for each recovery well. For wells with water quality that meets or is approaching remedial criteria, Graph 3 presents PCE concentrations at an expanded scale in order to compare them to the PCE aquifer restoration concentration of 5 ug/L. Laboratory analytical reports are included as Appendix I.

Well	Volume pumped (gal)	Average Flow (gpm)	Lowest Measured Flow (gpm) ¹	Total VOC Concentration (µg/L)	VOC Recovery (lbs)
RW-2 ⁴	293,750	27	13	8.5	0.02
RW-3 ³	616,025	35	10	0	0
RW-4 ²	701,023	20	10	2.1	0.01
RW-5	1,784,026	50	50	0	0
RW-6	524,905	15	15	25.4	0.11
RW-7	2,101,494	70	69	11	0.19
RW-8	2,104,860	55	41	0	0
RW-9 ²	2,690,142	75	16	0	0

¹Lowest measured flows are based on the lowest average 24-hour pumping rates for each well recorded to date.

²The RW-4 and RW-9 flow meters were not functioning properly so the total volume pumped was calculated using the monthly average flow reading and the hours of operation for the month.

³RW-3 was shut down on December 5, 2007 and was off until February 12, 2008 as part of a planned temporary shutdown in order to evaluate the effect on contaminant concentrations in the ground-water recovered by RW-2. On February 12, 2008 RW-3 was restarted after the RW-2 pump malfunctioned. Flow rates and volume pumped are for February 12 through 29 only.

⁴RW-2 shut down on February 8, 2008 due to a pump fault alarm. Flow rates and volume pumped are for February 1 through 8, 2008. A water quality sample was not collected for RW-2 this month; therefore the total VOCs from January 2008 was used to compare VOC recovery from RW-2.

Based on the results of the updated ground-water model for the site, the plume is not migrating beyond the influence of the FSP&T system if the recovery well pumps operate at or above the “Lowest Measured Flows”. The average monthly pumping rates for all recovery wells in operation are at or above the “Lowest Measured Flows”. The updated ground-water model is discussed in the 2006 Annual Report for the site.

On February 8, 2008, RW-2 shut down due to a pump fault alarm. Troubleshooting the alarm indicated that the pump or pump motor would have to be replaced. A replacement 2 horsepower motor and pump was ordered and RW-3 was restarted on February 12, 2008 until the RW-2 pump and/or motor can be replaced. Because the capture zones of RW-2 and RW-3 overlap slightly, RW-3 was used as a temporary substitute for RW-2. The RW-3 flow set point was increased from 25 gallons per minute (gpm) to 35 gpm.

Alpine Environmental, Inc. conducted FSP&T system maintenance on February 11 and 12, 2008. Maintenance activities consisted of pressure washing and vacuuming the system influent piping, flow meters, well head piping and flow meters at RW-2, RW-4, RW-8 and RW-9, cleaning the Equalization (EQ) Tank, the inspection and replacement of the broken air stripper blower belts, and cleaning the drip trays located beneath the bag filter housings.

On February 12, 2008, a technician from Badger Meter inspected, tested and recalibrated the tower influent flow (EQ-TP101), effluent, off-site combined, on-site combined and RW-9 flow meter transmitters. The flow meter transmitters were calibrated to one percent (1%) of actual flow, which is the limit of accuracy for the flow meter transmitters. The system, effluent and off-site combined flow meter transmitters were successfully recalibrated and are now displaying and transmitting accurate flow readings to the computer, according to the Badger Meter technician. In addition, a crossed wire was discovered and corrected inside the flow meter display at RW-9. The flow reading from the on-site combined flow meter could not be corrected; however, the badger meter technician indicates that a simulated flow signal from the frequency generator was successfully transmitted to the main control panel computer (via the flow meter transmitter). Therefore, according to the Badger Meter technician, the “no flow” reading from the on-site combine flow meter is caused by malfunctioning mechanical components in the “wet end” of the flow meter. A new rotor, spindle and a reed switch have been ordered and will be installed into the on-site combined flow meter.

BAG FILTER STATUS

The following table presents an operational summary of the bag filter usage and configuration for the reporting period.

Dates	Bank 1	Bank 2	Bank 3
February 1 to 29	7 of 8 housings used with 400 micron bag filters	7 of 8 housings used with 400 micron bag filters	Not active

No modifications were made to the filter bank configuration or operation during this reporting period.

OTHER O&M ACTIVITIES AND FUTURE O&M ACTIVITIES

Other O&M activities conducted in February 2008 include:

- On February 5, 2008, RW-1 low level alarms occurred because of a faulty pressure transducer; RW-1 was shut down on July 13, 2005;
- On February 8, 2008, RW-2 pump fault alarm occurs, RW-2 shuts down, FSP&T system remains operating with RW-4 through RW-9;
- On February 11, 2008, FSP&T system was shut down for scheduled maintenance by Alpine Environmental, Inc.;
- On February 12, 2008, FSP&T system maintenance was completed, and system was restarted. A technician from Badger Meter tested and recalibrated the tower influent (EQ TP-101), effluent, on-site combined, off-site combined and RW-9 flow meter transmitters. RW-3 was restarted to replace RW-2, which remains inoperable until a replacement pump and motor can be installed; and
- On February 20, 2008, the tower influent (EQ-TP101) flow meter totalizer was reset, and the low level alarm set point for RW-1 was adjusted to prevent the recurring low level alarms at RW-1 caused by the malfunctioning pressure transducer.

Future O&M activities scheduled for the spring of 2008 include:

- Replace the malfunctioning pressure transducer in RW-8;
- Replace the pump motor in RW-2;
- Replace exterior man-way cover near the top of the air-stripper tower;
- Evaluate option of repairing/recalibrating existing air flow meter compared to purchasing a new hand held air flow meter;
- Evaluate the effect on contaminant concentrations in RW-2 if RW-3 is not operating;
- Conduct semi-annual ground-water quality monitoring; and
- Measure static and pumping depth-to-water levels in all recovery and monitor wells.

MMG:nv

Attachments

cc: Jeff Srulovitz - Kraft Foods Global, Inc. - .pdf
Lisa Krogman, Environ – .pdf
Jeff Trad, NYSDEC – .pdf
Chief-Operation Maintenance and Support Section, NYSDEC – .pdf
William Spitz, RWM, R-1, NYSDEC
Garrett W. Swensen Jr., Esq., Town of Southampton

TABLES

TABLE 1
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

MAINTENANCE LOG
(February 1, 2008 through February 29, 2008)

Date	Time	System Changes/Modifications	Personnel
2/3/2008	4:42 PM	RW-1 Low level alarm (disregarded, RW-1 not operating), RW-1 was shut down on July 13, 2005. A faulty pressure transducer is the cause of the alarm. System remains operating.	
2/5/2008	9:43 AM	RW-1 Low level alarm (disregarded, RW-1 not operating), RW-1 was shut down on July 13, 2005. A faulty pressure transducer is the cause of the alarm. System remains operating. Acknowledged alarm.	SH
		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SH
2/8/2008	7:01 PM	RW-2 Pump Fault alarm. RW-2 shuts down, system remains operating with recovery wells RW-4 through RW-9.	
2/11/2008	8:26 AM	The FSP&T system was shut down for scheduled cleaning of influent pipes and flow meters using high pressure jet washing equipment and vacuum truck. RW-2, 4, 8, 9 and building flow meters were cleaned on 2/11 and 2/12.	Alpine/SH
		Equalization (EQ) tank cleaned with vacuum truck.	Alpine/SH
	2:47 PM	Air stripper blower low pressure alarm was caused by broken V-belts. New V-belts were installed and the system remains off until cleaning activities are completed.	Alpine/SH
2/12/2008	9:08 AM	EQ Tank low level alarm associated with removal of water from EQ tank during cleaning.	Alpine/SH
	9:14 AM	Restarted FSP&T system in preparation for flow meter calibration work with Badger Meter Representative. The system (EQ-TP101), effluent, RW-9, off-site combined and on-site combined flow meters were calibrated.	MC (Badger)/MG
		As part of maintenance activities the drip trays under the bag filter housing were cleaned.	Alpine/SH
		Following cleaning, there was difficulty in re-starting the RW-4 pump because of a faulty motor disconnect switch. After toggling the switch several times, the pump motor started. Troubleshooting of the RW-4 motor disconnect switch will be initiated.	Alpine/SH
	12:00 PM	RW-3 was restarted while RW-2 remains inoperable with a faulty motor. The flow set point of RW-3 was increased from 25 gpm to 35 gpm.	MG
		The flow meter reading from RW-9 was corrected during calibration/troubleshooting work for the flow meters.	MC (Badger)/MG
2/13/2008		The RW-7 vault door is broken. A boulder was placed on the vault to keep the doors shut as a temporary measure until the vault can be repaired.	SN
2/17/2008	9:26 AM	Communication Failure Alarm, system shutdown.	
2/20/2008		Changed multi-bag filter bags (400 mm) in Banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SH
	10:25 AM	Rebooted computer, reset alarms and restarted system.	SH
		Reset the system (EQ-TP-101) flow totalizer.	SH
		Adjusted the RW-1 low level alarm set point in order to prevent recurring low level alarms caused by the faulty pressure transducer.	SH
2/27/2008		Changed multi-bag filter bags (400 mm) in banks 1 and 2 seven of eight housings used. Banks 1 and 2 left open. Bank 3 closed.	SH

TABLE 2

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

EFFLUENT WATER QUALITY RESULTS

Date Sampled ^{2/}	pH ^{1/}	TDS (mg/l)	PCE (ug/l)	1,1,1-TCA (ug/l)	TCE (ug/l)	1,1-DCA (ug/l)	1,1-DCE (ug/l)	1,2-DCE (ug/l)	Xylene (ug/l)	Bromoform (ug/l)	Dibromo-chloromethane (ug/l)	Methylene Chloride (ug/l)	Freon 113 (ug/l)	Acetone (ug/l)	Chloroform (ug/l)	MTBE (ug/l)	Total Iron (mg/l)	Dissolved Iron (mg/l)
SPDES Limits	5.0 to 8.5	---	5	5	5	5	5	5	5	---	---	5	---	50	7	---	---	---
5-Feb-08	6.87	88	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.13	0.100
13-Feb-08	7.15	111	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.17	0.132
20-Feb-08	6.96	107	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.14	0.387
27-Feb-08	6.05	110	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	ND<1.0	1.04	0.136

SPDES: State Pollutant Discharge Elimination System

mg/l: Milligrams per liter

ug/l: Micrograms per liter

---: Not established

J: Analyte detected below quantitation limits

NM: Not Measured

TDS: Total dissolved solids

PCE: Tetrachloroethylene

TCE: Trichloroethene

1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene

1,2-DCE: 1,2-Dichloroethene

MTBE: Methyl tert-butyl ether

Notes:

- Based on the new SPDES criteria from an NY SDEC letter dated on May 11, 2006, the new allowable pH range for the Rowe Site is between 5.0 and 8.5. The pH was measured with a new calibrated electronic pH meter. Influent pH values from recovery wells typically range between 5 and 6.
- "Effluent" samples were collected from sample port labeled NP2-10 unless otherwise noted.

TABLE 4

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)	
RW-1	15-Sep-04	5	5	5	NE	7	NE	300	300	ND<1	ND<1	ND<1	5	NE	NE	ND-2	ND<1	ND<1	NE	
	7-Oct-04	ND<1	ND<1	ND<1	ND<1	2.8	2.2	0.0865	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	3-Nov-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0332	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Dec-04	ND<1	ND<1	ND<1	ND<1	1.9	2.0	0.0155	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	13-Jan-05	ND<1	ND<1	ND<1	ND<1	1.5	2.1	0.0478	0.0229	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	8-Feb-05	ND<1	ND<1	ND<1	ND<1	4.6	2.1	0.0703	0.0326	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	15-Mar-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	19-Apr-05	ND<1	ND<1	ND<1	ND<1	2.5	ND<1	0.0285	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	2-May-05	ND<1	ND<1	ND<1	ND<1	1.5	ND<1	0.0357	0.0217	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	16-Jun-05	ND<1	ND<1	ND<1	ND<1	4.0	ND<1	ND<0.02	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	14-Jul-05	ND<1	ND<1	ND<1	ND<1	2.1	ND<1	0.0289	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-06	ND<1	ND<1	ND<1	ND<1	5.2	ND<1	0.1650	ND<0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.9*
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	1.7	ND<1	NA	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	NA	NA	NA	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1
RW-2	7-Mar-06	6.5	3.5	ND<1	ND<1	ND<1	ND<1	4.76	0.0395	ND<1	3.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	12-Apr-06	12.0	3.9	1.2	ND<1	ND<1	ND<1	4.24	0.0522	ND<1	12.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	17-May-06	19.0	5.1	ND<1	ND<1	ND<1	ND<1	5.95	0.063	ND<1	14.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	21-Jun-06	3.0	3.0	25	ND<1	ND<1	ND<1	3.57	0.083	ND<1	5.0	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Jul-06	8.0	3.4	60	ND<1	ND<1	ND<1	4.49	0.177	ND<1	7.5	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	24-Aug-06	11.0	1.1	25	ND<1	ND<1	ND<1	4.14	0.0172	ND<1	5.7	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	19-Sep-06	2.8	ND<1	200	ND<1	ND<1	ND<1	13.7	0.0184	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	24-Oct-06	5.0	1.6	160	ND<1	ND<1	ND<1	3.6	0.00756	ND<1	3.6	0.91	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	29-Nov-06	6.0	1.8	36	ND<1	ND<1	ND<1	14.1	0.0148	ND<1	3	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	20-Dec-06	2.2	ND<1	110	ND<1	ND<1	ND<1	11.8	0.0197	ND<1	2.8	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	10-Jan-07	4.2	2.7	68	ND<1	ND<1	ND<1	2.77	0.468	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	8-Feb-07	3.4	2.4	62	ND<1	ND<1	ND<1	8.72	0.00829	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	7-Mar-07	ND<1	ND<1	31	ND<1	ND<1	ND<1	4.28	0.107	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	18-Apr-07	3	1.7	23	ND<1	ND<1	ND<1	3.81	0.32	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
	10-May-07	ND<1	ND<1	26	ND<1	ND<1	ND<1	3.04	0.00589	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	
15-Jun-07	1.1	1.2	ND<1	ND<1	ND<1	ND<1	2.7	0.0392	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
18-Jul-07	1.2	0.78	17	ND<1	ND<1	ND<1	2.26	0.198	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
16-Aug-07	0.75	ND<1	10	ND<1	ND<1	ND<1	3.92	0.197	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
12-Sep-07	1.6	ND<1	1.2	ND<1	ND<1	ND<1	1.76	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
3-Oct-07	1.4	ND<1	1.2	ND<1	ND<1	ND<1	1.9	1.28	ND<1	0.65	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
19-Nov-07	5.6	ND<1	ND<1	ND<1	ND<1	ND<1	2.18	0.0132	ND<1	1.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
12-Dec-07	2.2	0.86	8.3	ND<1	ND<1	ND<1	5.55	0.0186	ND<1	0.61	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
16-Jan-08	2	ND<1	5.9	ND<1	ND<1	ND<1	3.09	0.185	0.6	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1		
13-Feb-08	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	

TABLE 4

GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK

RECOVERY WELL WATER QUALITY RESULTS

Recovery Well	Date Sampled	PCE (ug/L)	TCE (ug/L)	TCA (ug/L)	Vinyl Acetate (ug/L)	Chloroform (ug/L)	MTBE (ug/L)	Total Iron (mg/L)	Dissolved Iron (mg/L)	1,1-Dichloro-ethane (ug/L)	cis-1,2-Dichloro-ethene (ug/L)	1,1-Dichloro-ethene (ug/L)	Methylene Chloride (ug/L)	Toluene (ug/L)	Dibromochloromethane (ug/L)	m,p-Xylene (ug/L)	o-Xylene (ug/L)	Ethylbenzene (ug/L)	Acetone (ug/L)
	ARAR's	5	5	5	NE	7	NE	300	300	5	5	5	5	NE	NE				NE
	7-Mar-06	1.3	ND<1	ND<1	ND<1	ND<1	ND<1	3.41	0.333	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Apr-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	1.93	0.108	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	17-May-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.64	0.064	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	21-June-06 ²	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM	NM
	20-Jul-06	ND<1	ND<1	2.2	ND<1	ND<1	ND<1	3.5	0.695	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Aug-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.97	0.0165	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Sep-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	5.16	ND-0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	24-Oct-06	ND<1	ND<1	1.5	ND<1	ND<1	ND<1	6.96	0.00719	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	29-Nov-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.99	ND-0.02	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	20-Dec-06	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.54	0.0119	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-Jan-07	ND<1	ND<1	1.4	ND<1	ND<1	ND<1	5.08	0.0855	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	8-Feb-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.96	0.0076	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	7	2	2.1	ND<1
RW-9	7-Mar-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	6.03	0.389	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Apr-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.77	0.232	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	10-May-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.6	0.0356	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	25-Jun-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.888	0.04	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	18-Jul-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.59	0.0227	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Aug-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.39	0.0250	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Sep-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	4.33	0.4040	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	3-Oct-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	1.18	0.180	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	19-Nov-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	0.704	0.065	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	12-Dec-07	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.2	1.92	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	16-Jan-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	3.85	1.46	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1
	13-Feb-08	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	2.94	0.176	ND<1	ND<1	ND<1	ND<1	ND<1	ND<1	ND<2	ND<1	ND<1	ND<1

ND: Not detected
 <#>: Less than method detection limit
 ug/L: Micrograms per liter
 Not analyzed
 ARAR's are chemical specific aquifer restoration goals for ground water at the Former Rowe Industries Superfund Site
 Bold values indicate an exceedance of the ARAR standard established for the site

PCE: Tetrachloroethylene
 TCE: Trichloroethylene
 TCA: 1,1,1-Trichloroethane
 1,1-DCA: 1,1-Dichloroethane

1,1-DCE: 1,1-Dichloroethene
 1,2-DCE: 1,2-Dichloroethene
 MTBE: Methyl Tertiary Butyl Ether
 NM: Not Measured

NE indicates that the ARAR goal was not established for this compound by the EP.
 *Concentrations with an asterisk following them are due to laboratory contamination
¹ RW-3 is currently non operational weighing for the reprogramming of the drive for the new 4 amp pump
² RW-9 was being rehabilitated during this sampling event, thus no water sample was collect


GRAPHS

GRAPH 1


GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK

EFFLUENT FLOW DATA


(February 1, 2008 through February 29, 2008)



GRAPH 2
GROUND-WATER REMEDIAL ACTION
ROWE INDUSTRIES SUPERFUND SITE
SAG HARBOR, NEW YORK



GRAPH 3
 GROUND-WATER REMEDIAL ACTION
 ROWE INDUSTRIES SUPERFUND SITE
 SAG HARBOR, NEW YORK



APPENDIX I
FEBRUARY 2008 LABORATORY ANALYTICAL REPORTS

Tuesday, February 12, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0802098

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 2/7/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0802098

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0802098-01A	WQ020508:1000NP2-6		2/5/2008 10:00:00 AM	2/7/2008
0802098-01B	WQ020508:1000NP2-6		2/5/2008 10:00:00 AM	2/7/2008
0802098-01C	WQ020508:1000NP2-6		2/5/2008 10:00:00 AM	2/7/2008
0802098-02A	WQ020508:1005NP2-7		2/5/2008 10:05:00 AM	2/7/2008
0802098-02B	WQ020508:1005NP2-7		2/5/2008 10:05:00 AM	2/7/2008
0802098-02C	WQ020508:1005NP2-7		2/5/2008 10:05:00 AM	2/7/2008
0802098-03A	WQ020508:1010NP2-10		2/5/2008 10:10:00 AM	2/7/2008
0802098-03B	WQ020508:1010NP2-10		2/5/2008 10:10:00 AM	2/7/2008
0802098-03C	WQ020508:1010NP2-10		2/5/2008 10:10:00 AM	2/7/2008



CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS
LIB
4 Research Drive Suite 301
Shelton, CT 06484

CONTACT:
Mark Goldberg

SAMPLER (SIGNATURE)
[Signature]

SAMPLER NAME (PRINT)
STEPHEN HUAT

SAMPLE(S) SEALED
 YES / NO

CORRECT CONTAINER(S)
 YES / NO

LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED			FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
					8260	MTR	TDS	
0802098-01ABC		4	2/5/08 1000	W020508: 1000 NP2-6	X	X	X	
02100L		4	2/5/08 1005	W020508: 1005 NP2-7	X	X	X	
03010L		5	2/5/08 1010	W020508: 1010 NP2-10	X	X	X	

COOLER TEMPERATURE:		COMMENTS / INSTRUCTIONS	
MATRIX	S-SOIL; L-LIQUID; SL-SLUDGE; A-AIR; W-WIPE; P-PAINT CHIPS; B-BULK MATERIAL	TURNAROUND REQUIRED:	
TYPE	G-GRAB; C-COMPOSITE, SS-SPLIT SPOON	NORMAL <input checked="checked" type="checkbox"/> STAT <input type="checkbox"/> BY / /	
RELINQUISHED BY (SIGNATURE)	<i>[Signature]</i>	RECEIVED BY LAB (SIGNATURE)	<i>[Signature]</i>
DATE/TIME	02/06/08 17:00	DATE/TIME	2/11/08 11:20
RELINQUISHED BY (SIGNATURE)	<i>[Signature]</i>	RECEIVED BY LAB (SIGNATURE)	<i>[Signature]</i>
DATE/TIME		DATE/TIME	
PRINTED NAME	Kithi Deak	PRINTED NAME	Gary Spruiell

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value.
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of the method allowable holding time.

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0802098
 Project: Rowe
 Lab ID: 0802098-01A

Client Sample ID: WQ020508:1000NP2-6
 Tag Number:
 Collection Date: 2/5/2008 10:00:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,1,1-Trichloroethane	2.3	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
2-Butanone	U	3.0		µg/L	1	2/8/2008 7:43:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
2-Hexanone	U	2.0		µg/L	1	2/8/2008 7:43:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/8/2008 7:43:00 PM
Acetone	U	2.0		µg/L	1	2/8/2008 7:43:00 PM
Benzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Bromobenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Bromoform	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Bromomethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802098
Project: Rowe
Lab ID: 0802098-01A

Client Sample ID: WQ020508:1000NP2-6
Tag Number:
Collection Date: 2/5/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LA
Chloroethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Chloroform	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Chloromethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Dibromomethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/8/2008 7:43:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Methylene chloride	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Naphthalene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
o-Xylene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Styrene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Tetrachloroethene	5.7	1.0		µg/L	1	2/8/2008 7:43:00 PM
Toluene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Trichloroethene	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/8/2008 7:43:00 PM
Surr: 4-Bromofluorobenzene	110	54-134		%REC	1	2/8/2008 7:43:00 PM
Surr: Dibromofluoromethane	93.5	52-132		%REC	1	2/8/2008 7:43:00 PM
Surr: Toluene-d8	104	51-127		%REC	1	2/8/2008 7:43:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802098
Project: Rowe
Lab ID: 0802098-01B

Client Sample ID: WQ020508:1000NP2-6
Tag Number:
Collection Date: 2/5/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.78	0.0200		mg/L	1	2/11/2008 3:26:14 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802098
Project: Rowe
Lab ID: 0802098-01C

Client Sample ID: WQ020508:1000NP2-6
Tag Number:
Collection Date: 2/5/2008 10:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0399	0.0200		mg/L	1	2/11/2008 3:24:11 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802098
Project: Rowe
Lab ID: 0802098-02A

Client Sample ID: WQ020508:1005NP2-7
Tag Number:
Collection Date: 2/5/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
2-Butanone	U	3.0		µg/L	1	2/8/2008 8:21:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
2-Hexanone	U	2.0		µg/L	1	2/8/2008 8:21:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/8/2008 8:21:00 PM
Acetone	U	2.0		µg/L	1	2/8/2008 8:21:00 PM
Benzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Bromobenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Bromofom	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Bromomethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0802098
 Project: Rowe
 Lab ID: 0802098-02A

Client Sample ID: WQ020508:1005NP2-7
 Tag Number:
 Collection Date: 2/5/2008 10:05:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Chloroform	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Chloromethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Dibromomethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/8/2008 8:21:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Methylene chloride	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Naphthalene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
o-Xylene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Styrene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Toluene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Trichloroethene	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/8/2008 8:21:00 PM
Surr: 4-Bromofluorobenzene	111	54-134		%REC	1	2/8/2008 8:21:00 PM
Surr: Dibromofluoromethane	88.2	52-132		%REC	1	2/8/2008 8:21:00 PM
Surr: Toluene-d8	105	51-127		%REC	1	2/8/2008 8:21:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802098
Project: Rowe
Lab ID: 0802098-02B

Client Sample ID: WQ020508:1005NP2-7
Tag Number:
Collection Date: 2/5/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.08	0.0200		mg/L	1	2/11/2008 3:30:19 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0802098
 Project: Rowe
 Lab ID: 0802098-02C

Client Sample ID: WQ020508:1005NP2-7
 Tag Number:
 Collection Date: 2/5/2008 10:05:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0771	0.0200		mg/L	1	2/11/2008 3:28:16 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802098
Project: Rowe
Lab ID: 0802098-03A

Client Sample ID: WQ020508:1010NP2-10
Tag Number:
Collection Date: 2/5/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113						
		SW8260B				Analyst: LA
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
2-Butanone	U	3.0		µg/L	1	2/8/2008 8:58:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
2-Hexanone	U	2.0		µg/L	1	2/8/2008 8:58:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/8/2008 8:58:00 PM
Acetone	U	2.0		µg/L	1	2/8/2008 8:58:00 PM
Benzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Bromobenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Bromoform	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Bromomethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0802098
 Project: Rowe
 Lab ID: 0802098-03A

Client Sample ID: WQ020508:1010NP2-10
 Tag Number:
 Collection Date: 2/5/2008 10:10:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LA
Chloroethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Chloroform	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Chloromethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Dibromomethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/8/2008 8:58:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Methylene chloride	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Naphthalene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
o-Xylene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Styrene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Toluene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Trichloroethene	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/8/2008 8:58:00 PM
Surr: 4-Bromofluorobenzene	109	54-134		%REC	1	2/8/2008 8:58:00 PM
Surr: Dibromofluoromethane	84.2	52-132		%REC	1	2/8/2008 8:58:00 PM
Surr: Toluene-d8	107	51-127		%REC	1	2/8/2008 8:58:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802098
Project: Rowe
Lab ID: 0802098-03B

Client Sample ID: WQ020508:1010NP2-10
Tag Number:
Collection Date: 2/5/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.13	0.0200		mg/L	1	2/11/2008 3:34:24 PM

Qualifiers:					
B	Analyte detected in the associated Method Blank	E	Value above quantitation range		
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits		
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits		
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level		

American Analytical Laboratories, LLC.

Date: 12-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802098
Project: Rowe
Lab ID: 0802098-03C

Client Sample ID: WQ020508:1010NP2-10
Tag Number:
Collection Date: 2/5/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.100	0.0200		mg/L	1	2/11/2008 3:32:21 PM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	88.0	1.00		mg/L	1	2/11/2008

Qualifiers: B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Reporting Limit
U Indicates the compound was analyzed for but not detected

E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits
X Value exceeds Maximum Contaminant Level

Monday, February 25, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484
TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0802198

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 2/15/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0802198

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0802198-01A	WQ021308:1040NP2-6		2/13/2008 10:40:00 AM	2/15/2008
0802198-01B	WQ021308:1040NP2-6		2/13/2008 10:40:00 AM	2/15/2008
0802198-01C	WQ021308:1040NP2-6		2/13/2008 10:40:00 AM	2/15/2008
0802198-02A	WQ021308:1045NP2-7		2/13/2008 10:45:00 AM	2/15/2008
0802198-02B	WQ021308:1045NP2-7		2/13/2008 10:45:00 AM	2/15/2008
0802198-02C	WQ021308:1045NP2-7		2/13/2008 10:45:00 AM	2/15/2008
0802198-03A	WQ021308:1050NP2-10		2/13/2008 10:50:00 AM	2/15/2008
0802198-03B	WQ021308:1050NP2-10		2/13/2008 10:50:00 AM	2/15/2008
0802198-03C	WQ021308:1050NP2-10		2/13/2008 10:50:00 AM	2/15/2008

TAG # / COC _____

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS: **LBG**
 4 Research Drive Suite 301 Shelton, CT 06484

CONTACT: **Mark Goldberg**

SAMPLER (SIGNATURE): *[Signature]*

SAMPLER NAME (PRINT): **Stephen Hnat**

SAMPLE(S) SEALED: YES / NO

CORRECT CONTAINER(S): YES / NO

LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)	
						MTGE	Freeon 113
0602198-01ABC	L	4	2/13/08 1040	WQ021308:1040NPZ-6	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
0602198-02ABC	L	4	2/13/08 1045	WQ021308:1045NPZ-7	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
0602198-03ABC	L	5	2/13/08 1050	WQ021308:1050NPZ-10	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

PROJECT LOCATION: **Rowe**

COOLER TEMPERATURE: _____

COMMENTS / INSTRUCTIONS: _____

TURNAROUND REQUIRED: NORMAL / STAT BY / /

RELINQUISHED BY (SIGNATURE): <i>[Signature]</i>	DATE/TIME: 02/14/08 17:00	PRINTED NAME: Kithi Deak	DATE/TIME: 2/15/08 1025	PRINTED NAME: <i>G. J. Eppich</i>
RELINQUISHED BY (SIGNATURE): _____	DATE/TIME: _____	PRINTED NAME: _____	DATE/TIME: _____	PRINTED NAME: _____

AMERICAN ANALYTICAL LABORATORIES, LLC
56 TOLEDO STREET
FARMINGDALE, NEW YORK 11735
TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value.
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of the method allowable holding time.

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-01A

Client Sample ID: WQ021308:1040NP2-6
Tag Number:
Collection Date: 2/13/2008 10:40:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 2:41:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 2:41:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 2:41:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 2:41:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-01A

Client Sample ID: WQ021308:1040NP2-6
Tag Number:
Collection Date: 2/13/2008 10:40:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 2:41:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Tetrachloroethene	3.9	1.0		µg/L	1	2/20/2008 2:41:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 2:41:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	2/20/2008 2:41:00 AM
Surr: Dibromofluoromethane	99.1	52-132		%REC	1	2/20/2008 2:41:00 AM
Surr: Toluene-d8	99.3	51-127		%REC	1	2/20/2008 2:41:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-01B

Client Sample ID: WQ021308:1040NP2-6
Tag Number:
Collection Date: 2/13/2008 10:40:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.20	0.0200		mg/L	1	2/20/2008 10:55:36 AM

Qualifiers: B Analyte detected in the associated Method Blank E Value above quantitation range
H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
ND Not Detected at the Reporting Limit S Spike Recovery outside accepted recovery limits
U Indicates the compound was analyzed for but not detected X Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ021308:1040NP2-6
Lab Order:	0802198	Tag Number:	
Project:	Rowe	Collection Date:	2/13/2008 10:40:00 AM
Lab ID:	0802198-01C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.0279	0.0200		mg/L	1	2/20/2008 10:53:32 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-02A

Client Sample ID: WQ021308:1045NP2-7
Tag Number:
Collection Date: 2/13/2008 10:45:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 3:18:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 3:18:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 3:18:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 3:18:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-02A

Client Sample ID: WQ021308:1045NP2-7
Tag Number:
Collection Date: 2/13/2008 10:45:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 3:18:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 3:18:00 AM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	2/20/2008 3:18:00 AM
Surr: Dibromofluoromethane	102	52-132		%REC	1	2/20/2008 3:18:00 AM
Surr: Toluene-d8	98.5	51-127		%REC	1	2/20/2008 3:18:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-02B

Client Sample ID: WQ021308:1045NP2-7
Tag Number:
Collection Date: 2/13/2008 10:45:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.13	0.0200		mg/L	1	2/20/2008 10:59:42 AM

Qualifiers:					
B	Analyte detected in the associated Method Blank	E	Value above quantitation range		
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits		
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits		
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level		

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-02C

Client Sample ID: WQ021308:1045NP2-7
Tag Number:
Collection Date: 2/13/2008 10:45:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.130	0.0200		mg/L	1	2/20/2008 10:57:39 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-03A

Client Sample ID: WQ021308:1050NP2-10
Tag Number:
Collection Date: 2/13/2008 10:50:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 3:52:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 3:52:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 3:52:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 3:52:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-03A

Client Sample ID: WQ021308:1050NP2-10
Tag Number:
Collection Date: 2/13/2008 10:50:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 3:52:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 3:52:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	2/20/2008 3:52:00 AM
Surr: Dibromofluoromethane	103	52-132		%REC	1	2/20/2008 3:52:00 AM
Surr: Toluene-d8	97.9	51-127		%REC	1	2/20/2008 3:52:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 27-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802198
Project: Rowe
Lab ID: 0802198-03B

Client Sample ID: WQ021308:1050NP2-10
Tag Number:
Collection Date: 2/13/2008 10:50:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.17	0.0200		mg/L	1	2/20/2008 11:24:49 AM

Qualifiers:					
B	Analyte detected in the associated Method Blank	E	Value above quantitation range		
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits		
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits		
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level		

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0802198
 Project: Rowe
 Lab ID: 0802198-03C

Client Sample ID: WQ021308:1050NP2-10
 Tag Number:
 Collection Date: 2/13/2008 10:50:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.132	0.0200		mg/L	1	2/20/2008 11:22:46 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	111	1.00		mg/L	1	2/20/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Monday, March 03, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555

FAX (203) 926-9140

RE: Rowe

Order No.: 0802306

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 2/26/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director


CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0802306

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0802306-01A	WQ022008:1100NP2-6		2/20/2008 11:00:00 AM	2/26/2008
0802306-01B	WQ022008:1100NP2-6		2/20/2008 11:00:00 AM	2/26/2008
0802306-01C	WQ022008:1100NP2-6		2/20/2008 11:00:00 AM	2/26/2008
0802306-02A	WQ022008:1105NP2-7		2/20/2008 11:05:00 AM	2/26/2008
0802306-02B	WQ022008:1105NP2-7		2/20/2008 11:05:00 AM	2/26/2008
0802306-02C	WQ022008:1105NP2-7		2/20/2008 11:05:00 AM	2/26/2008
0802306-03A	WQ022008:1110NP2-10		2/20/2008 11:10:00 AM	2/26/2008
0802306-03B	WQ022008:1110NP2-10		2/20/2008 11:10:00 AM	2/26/2008
0802306-03C	WQ022008:1110NP2-10		2/20/2008 11:10:00 AM	2/26/2008

TAG # / COC _____

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS <i>Libco 4 Research Drive Suite 301 Shelton, CT 06484</i>	CONTACT: <i>Mark Goldberg</i>	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED <u>YES</u> / NO
		SAMPLER NAME (PRINT) <i>Stephen Hnat</i>	CORRECT CONTAINER(S) <u>YES</u> / NO



PROJECT LOCATION:
Rowe

LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
<i>0802306-01ABC L</i>		<i>4</i>	<i>2/20/08 11:00</i>	<i>WQ022008:1100NP2-6</i>	<i>X X X X</i>	
<i>-02ABC L</i>		<i>4</i>	<i>2/20/08 11:05</i>	<i>WQ022008:1105NP2-7</i>	<i>X X X X</i>	
<i>-03ABC L</i>		<i>5</i>	<i>2/20/08 11:10</i>	<i>WQ022008:1110NP2-10</i>	<i>X X X X</i>	

FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)

COOLER TEMPERATURE: _____

COMMENTS / INSTRUCTIONS

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIFE; P=PAINT CHIPS; B=BULK MATERIAL		TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY / /	
RELINQUISHED BY (SIGNATURE) 	PRINTED NAME <i>Kithi Deak</i>	RECEIVED BY LAB (SIGNATURE) 	RECEIVED BY LAB (SIGNATURE)
DATE <i>02/25/08</i>	TIME <i>11:00</i>	DATE <i>2/26/08</i>	TIME <i>1700</i>
DATE TIME	DATE TIME	DATE TIME	DATE TIME
RECEIVED BY LAB (SIGNATURE)	RECEIVED BY LAB (SIGNATURE)	PRINTED NAME <i>Gary Zplich</i>	PRINTED NAME

WHITE-OFFICE / CANARY-LAB / PINK-SAMPLE CUSTODIAN / GOLDENROD-CLIENT

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value.
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of the method allowable holding time.

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0802306
 Project: Rowe
 Lab ID: 0802306-01A

Client Sample ID: WQ022008:1100NP2-6
 Tag Number:
 Collection Date: 2/20/2008 11:00:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LA
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,1,1-Trichloroethane	1.5	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
2-Butanone	U	3.0		µg/L	1	2/27/2008 1:29:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
2-Hexanone	U	2.0		µg/L	1	2/27/2008 1:29:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/27/2008 1:29:00 PM
Acetone	U	2.0		µg/L	1	2/27/2008 1:29:00 PM
Benzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Bromobenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Bromoform	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Bromomethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802306
Project: Rowe
Lab ID: 0802306-01A

Client Sample ID: WQ022008:1100NP2-6
Tag Number:
Collection Date: 2/20/2008 11:00:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LA
Chloroethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Chloroform	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Chloromethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Dibromomethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/27/2008 1:29:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Methylene chloride	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Naphthalene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
o-Xylene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Styrene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Tetrachloroethene	4.6	1.0		µg/L	1	2/27/2008 1:29:00 PM
Toluene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Trichloroethene	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/27/2008 1:29:00 PM
Surr: 4-Bromofluorobenzene	110	54-134		%REC	1	2/27/2008 1:29:00 PM
Surr: Dibromofluoromethane	112	52-132		%REC	1	2/27/2008 1:29:00 PM
Surr: Toluene-d8	108	51-127		%REC	1	2/27/2008 1:29:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022008:1100NP2-6
Lab Order:	0802306	Tag Number:	
Project:	Rowe	Collection Date:	2/20/2008 11:00:00 AM
Lab ID:	0802306-01B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	2.28	0.0200		mg/L	1	2/26/2008 2:19:25 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022008:1100NP2-6
Lab Order:	0802306	Tag Number:	
Project:	Rowe	Collection Date:	2/20/2008 11:00:00 AM
Lab ID:	0802306-01C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.533	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 2/26/2008 2:17:22 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0802306
 Project: Rowe
 Lab ID: 0802306-02A

Client Sample ID: WQ022008:1105NP2-7
 Tag Number:
 Collection Date: 2/20/2008 11:05:00 AM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
2-Butanone	U	3.0		µg/L	1	2/27/2008 2:04:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
2-Hexanone	U	2.0		µg/L	1	2/27/2008 2:04:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/27/2008 2:04:00 PM
Acetone	U	2.0		µg/L	1	2/27/2008 2:04:00 PM
Benzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Bromobenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Bromoform	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Bromomethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802306
Project: Rowe
Lab ID: 0802306-02A

Client Sample ID: WQ022008:1105NP2-7
Tag Number:
Collection Date: 2/20/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LA
Chloroethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Chloroform	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Chloromethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Dibromomethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/27/2008 2:04:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Methylene chloride	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Naphthalene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
o-Xylene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Styrene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Toluene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Trichloroethene	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/27/2008 2:04:00 PM
Surr: 4-Bromofluorobenzene	111	54-134		%REC	1	2/27/2008 2:04:00 PM
Surr: Dibromofluoromethane	112	52-132		%REC	1	2/27/2008 2:04:00 PM
Surr: Toluene-d8	110	51-127		%REC	1	2/27/2008 2:04:00 PM

Qualifiers:				
B	Analyte detected in the associated Method Blank	E	Value above quantitation range	
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits	
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits	
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level	

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802306
Project: Rowe
Lab ID: 0802306-02B

Client Sample ID: WQ022008:1105NP2-7
Tag Number:
Collection Date: 2/20/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	2.37	E200.7 0.0200		SW3010A mg/L	1	Analyst: JP 2/26/2008 2:23:29 PM

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802306
Project: Rowe
Lab ID: 0802306-02C

Client Sample ID: WQ022008:1105NP2-7
Tag Number:
Collection Date: 2/20/2008 11:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.299	E200.7 0.0200		SW3005A mg/L	1	Analyst: JP 2/26/2008 2:21:27 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802306
Project: Rowe
Lab ID: 0802306-03A

Client Sample ID: WQ022008:1110NP2-10
Tag Number:
Collection Date: 2/20/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113						Analyst: LA
SW8260B						
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
2-Butanone	U	3.0		µg/L	1	2/27/2008 2:40:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
2-Hexanone	U	2.0		µg/L	1	2/27/2008 2:40:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/27/2008 2:40:00 PM
Acetone	U	2.0		µg/L	1	2/27/2008 2:40:00 PM
Benzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Bromobenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Bromochloromethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Bromodichloromethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Bromoform	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Bromomethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Carbon disulfide	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Chlorobenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802306
Project: Rowe
Lab ID: 0802306-03A

Client Sample ID: WQ022008:1110NP2-10
Tag Number:
Collection Date: 2/20/2008 11:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Chloroform	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Chloromethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Dibromochloromethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Dibromomethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Ethylbenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Isopropylbenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
m,p-Xylene	U	2.0		µg/L	1	2/27/2008 2:40:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Methylene chloride	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Naphthalene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
n-Butylbenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
n-Propylbenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
o-Xylene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Styrene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Tetrachloroethene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Toluene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Trichloroethene	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Vinyl acetate	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Vinyl chloride	U	1.0		µg/L	1	2/27/2008 2:40:00 PM
Surr: 4-Bromofluorobenzene	107	54-134		%REC	1	2/27/2008 2:40:00 PM
Surr: Dibromofluoromethane	102	52-132		%REC	1	2/27/2008 2:40:00 PM
Surr: Toluene-d8	109	51-127		%REC	1	2/27/2008 2:40:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022008:1110NP2-10
Lab Order:	0802306	Tag Number:	
Project:	Rowe	Collection Date:	2/20/2008 11:10:00 AM
Lab ID:	0802306-03B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3010A		Analyst: JP
Iron	1.14	0.0200		mg/L	1	2/26/2008 2:46:06 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 03-Mar-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022008:1110NP2-10
Lab Order:	0802306	Tag Number:	
Project:	Rowe	Collection Date:	2/20/2008 11:10:00 AM
Lab ID:	0802306-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: JP
Iron	0.387	0.0200		mg/L	1	2/26/2008 2:27:32 PM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	107	1.00		mg/L	1	2/27/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

Friday, March 07, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484
TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0803013

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 3 sample(s) on 3/4/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,


Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0803013

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0803013-01A	WQ022708:1200NP2-6		2/27/2008 12:00:00 PM	3/4/2008
0803013-01B	WQ022708:1200NP2-6		2/27/2008 12:00:00 PM	3/4/2008
0803013-01C	WQ022708:1200NP2-6		2/27/2008 12:00:00 PM	3/4/2008
0803013-02A	WQ022708:1205NP2-7		2/27/2008 12:05:00 PM	3/4/2008
0803013-02B	WQ022708:1205NP2-7		2/27/2008 12:05:00 PM	3/4/2008
0803013-02C	WQ022708:1205NP2-7		2/27/2008 12:05:00 PM	3/4/2008
0803013-03A	WQ022708:1210NP2-10		2/27/2008 12:10:00 PM	3/4/2008
0803013-03B	WQ022708:1210NP2-10		2/27/2008 12:10:00 PM	3/4/2008
0803013-03C	WQ022708:1210NP2-10		2/27/2008 12:10:00 PM	3/4/2008



CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS
LIBC
4 Research Drive, Suite 301
Sherborn, CT 06484

CONTACT:
Mark Goldberg

SAMPLER (SIGNATURE)
SAMPLER NAME (PRINT) **Stephen Huret**

SAMPLE(S) SEALED **(YES) NO**
CORRECT CONTAINER(S) **(YES) NO**

PROJECT LOCATION:
Rowe

LABORATORY ID #	MATRIX	# CON-TAINERS	SAMPLING DATE/ TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED	STAT	BY	DATE	TIME	FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)
0803013-01ABC	L	4	2/27/08 1200	WG022708: 1200NP2-6	X	X				
02ABC	L	4	2/27/08 1205	WG022708: 1205NP2-7	X	X				
03ABC	L	5	2/27/08 1210	WG022708: 1210NP2-10	X	X				

RELINQUISHED BY (SIGNATURE) DATE **02/03/08** TIME **17:00** PRINTED NAME **Kithi Deak**

RELINQUISHED BY (SIGNATURE) _____ DATE _____ TIME _____ PRINTED NAME _____

MATRIX S=SOIL; L=LIQUID; SL=SLUDGE; A-AIR; W=WIPE; P=PAINT CHIPS; B=BULK MATERIAL
TYPE G=GRAB; C=COMPOSITE, SS=SPLIT SPOON

TURNAROUND REQUIRED: NORMAL STAT BY / /

RECEIVED BY LAB (SIGNATURE) DATE **3/4/08** TIME **1000** PRINTED NAME **Gary Eppich**

RECEIVED BY LAB (SIGNATURE) _____ DATE _____ TIME _____ PRINTED NAME _____

COOLER TEMPERATURE: _____

COMMENTS / INSTRUCTIONS

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value.
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of the method allowable holding time.

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-01A

Client Sample ID: WQ022708:1200NP2-6
Tag Number:
Collection Date: 2/27/2008 12:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
2-Butanone	U	3.0		µg/L	1	3/5/2008 8:25:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
2-Hexanone	U	2.0		µg/L	1	3/5/2008 8:25:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	3/5/2008 8:25:00 PM
Acetone	U	2.0		µg/L	1	3/5/2008 8:25:00 PM
Benzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Bromobenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Bromoform	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Bromomethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-01A

Client Sample ID: WQ022708:1200NP2-6
Tag Number:
Collection Date: 2/27/2008 12:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Chloroform	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Chloromethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Dibromomethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/5/2008 8:25:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Methylene chloride	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Naphthalene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
o-Xylene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Styrene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Tetrachloroethene	3.3	1.0		µg/L	1	3/5/2008 8:25:00 PM
Toluene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Trichloroethene	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/5/2008 8:25:00 PM
Surr: 4-Bromofluorobenzene	98.3	54-134		%REC	1	3/5/2008 8:25:00 PM
Surr: Dibromofluoromethane	97.1	52-132		%REC	1	3/5/2008 8:25:00 PM
Surr: Toluene-d8	101	51-127		%REC	1	3/5/2008 8:25:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-01B

Client Sample ID: WQ022708:1200NP2-6
Tag Number:
Collection Date: 2/27/2008 12:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3005A		Analyst: AH
Iron	4.18	0.0200		mg/L	1	3/6/2008 11:41:17 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-01C

Client Sample ID: WQ022708:1200NP2-6
Tag Number:
Collection Date: 2/27/2008 12:00:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.0644	E200.7 0.0200		SW3005A mg/L	1	Analyst: AH 3/6/2008 11:39:13 AM

Qualifiers:

B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-02A

Client Sample ID: WQ022708:1205NP2-7
Tag Number:
Collection Date: 2/27/2008 12:05:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113						Analyst: LA
SW8260B						
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
2-Butanone	U	3.0		µg/L	1	3/5/2008 8:59:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
2-Hexanone	U	2.0		µg/L	1	3/5/2008 8:59:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	3/5/2008 8:59:00 PM
Acetone	U	2.0		µg/L	1	3/5/2008 8:59:00 PM
Benzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Bromobenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Bromoform	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Bromomethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-02A

Client Sample ID: WQ022708:1205NP2-7
Tag Number:
Collection Date: 2/27/2008 12:05:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113						Analyst: LA
Chloroethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Chloroform	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Chloromethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Dibromomethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/5/2008 8:59:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Methylene chloride	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Naphthalene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
o-Xylene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Styrene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Tetrachloroethene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Toluene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Trichloroethene	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/5/2008 8:59:00 PM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	3/5/2008 8:59:00 PM
Surr: Dibromofluoromethane	100	52-132		%REC	1	3/5/2008 8:59:00 PM
Surr: Toluene-d8	97.5	51-127		%REC	1	3/5/2008 8:59:00 PM

Qualifiers:				
B	Analyte detected in the associated Method Blank	E	Value above quantitation range	
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits	
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits	
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level	

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	WQ022708:1205NP2-7
Lab Order:	0803013	Tag Number:	
Project:	Rowe	Collection Date:	2/27/2008 12:05:00 PM
Lab ID:	0803013-02B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON		E200.7		SW3005A		Analyst: AH
Iron	1.52	0.0200		mg/L	1	3/6/2008 11:46:12 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
 Lab Order: 0803013
 Project: Rowe
 Lab ID: 0803013-02C

Client Sample ID: WQ022708:1205NP2-7
 Tag Number:
 Collection Date: 2/27/2008 12:05:00 PM
 Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON		E200.7		SW3005A		Analyst: AH
Iron	0.140	0.0200		mg/L	1	3/6/2008 11:44:09 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-03A

Client Sample ID: WQ022708:1210NP2-10
Tag Number:
Collection Date: 2/27/2008 12:10:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LA
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,1,1-Trichloroethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,1,2-Trichloroethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,1-Dichloroethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,1-Dichloroethene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,1-Dichloropropene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,2,3-Trichloropropane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,2-Dibromoethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,2-Dichlorobenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,2-Dichloroethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,2-Dichloropropane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,3-Dichlorobenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,3-dichloropropane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
1,4-Dichlorobenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
2,2-Dichloropropane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
2-Butanone	U	3.0		µg/L	1	3/5/2008 9:34:00 PM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
2-Chlorotoluene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
2-Hexanone	U	2.0		µg/L	1	3/5/2008 9:34:00 PM
4-Chlorotoluene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
4-Isopropyltoluene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
4-Methyl-2-pentanone	U	2.0		µg/L	1	3/5/2008 9:34:00 PM
Acetone	U	2.0		µg/L	1	3/5/2008 9:34:00 PM
Benzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Bromobenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Bromochloromethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Bromodichloromethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Bromoform	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Bromomethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Carbon disulfide	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Carbon tetrachloride	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Chlorobenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-03A

Client Sample ID: WQ022708:1210NP2-10
Tag Number:
Collection Date: 2/27/2008 12:10:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B				Analyst: LA
Chloroethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Chloroform	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Chloromethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Dibromochloromethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Dibromomethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Dichlorodifluoromethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Ethylbenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Hexachlorobutadiene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Isopropylbenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
m,p-Xylene	U	2.0		µg/L	1	3/5/2008 9:34:00 PM
Methyl tert-butyl ether	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Methylene chloride	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Naphthalene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
n-Butylbenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
n-Propylbenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
o-Xylene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
sec-Butylbenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Styrene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
tert-Butylbenzene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Tetrachloroethene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Toluene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Trichloroethene	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Trichlorofluoromethane	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Vinyl acetate	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Vinyl chloride	U	1.0		µg/L	1	3/5/2008 9:34:00 PM
Surr: 4-Bromofluorobenzene	94.3	54-134		%REC	1	3/5/2008 9:34:00 PM
Surr: Dibromofluoromethane	101	52-132		%REC	1	3/5/2008 9:34:00 PM
Surr: Toluene-d8	97.1	51-127		%REC	1	3/5/2008 9:34:00 PM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-03B

Client Sample ID: WQ022708:1210NP2-10
Tag Number:
Collection Date: 2/27/2008 12:10:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON Iron	1.04	E200.7 0.0200		mg/L	1	Analyst: AH 3/6/2008 11:50:16 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.


Date: 07-Mar-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0803013
Project: Rowe
Lab ID: 0803013-03C

Client Sample ID: WQ022708:1210NP2-10
Tag Number:
Collection Date: 2/27/2008 12:10:00 PM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON Iron	0.136	E200.7 0.0200		mg/L	1	Analyst: AH 3/6/2008 11:48:15 AM
TOTAL DISSOLVED SOLIDS Total Dissolved Solids (Residue, Filterable)	110	M2540C 1.00		mg/L	1	Analyst: AS 3/4/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level



NYSDOH 11418
NJDEP NY050
CTDOH PH-0205
PADEP 68-00573

Monday, February 25, 2008

Mark Goldberg
Leggette Brashears & Graham Inc.
4 Research Drive
Suite 301
Shelton, CT 06484

TEL: (203) 929-8555
FAX (203) 926-9140

RE: Rowe

Order No.: 0802197

Dear Mark Goldberg:

American Analytical Laboratories, LLC. received 7 sample(s) on 2/15/2008 for the analyses presented in the following report.


Samples were analyzed in accordance with the test procedures documented on the chain of custody and detailed throughout the text of this report.

The limits provided in the data package are analytical reporting limits and not Federal or Local mandated values to which the sample results should be compared.

There were no problems with the analyses and all data for associated QC met laboratory specifications. If there are any exceptions a Case Narrative is provided in the report.

If you have any questions regarding these tests results, please do not hesitate to call (631) 454-6100 or email me directly at lbeyer@american-analytical.com.

Sincerely,



Lori Beyer
Lab Director

CLIENT: Leggette Brashears & Graham Inc.
Project: Rowe
Lab Order: 0802197

Work Order Sample Summary

Lab Sample ID	Client Sample ID	Tag Number	Date Collected	Date Received
0802197-01A	ROWEGWQ021308:1005N		2/13/2008 10:05:00 AM	2/15/2008
0802197-01B	ROWEGWQ021308:1005N		2/13/2008 10:05:00 AM	2/15/2008
0802197-01C	ROWEGWQ021308:1005N		2/13/2008 10:05:00 AM	2/15/2008
0802197-02A	ROWEGWQ021308:1010N		2/13/2008 10:10:00 AM	2/15/2008
0802197-02B	ROWEGWQ021308:1010N		2/13/2008 10:10:00 AM	2/15/2008
0802197-02C	ROWEGWQ021308:1010N		2/13/2008 10:10:00 AM	2/15/2008
0802197-03A	ROWEGWQ021308:1015N		2/13/2008 10:15:00 AM	2/15/2008
0802197-03B	ROWEGWQ021308:1015N		2/13/2008 10:15:00 AM	2/15/2008
0802197-03C	ROWEGWQ021308:1015N		2/13/2008 10:15:00 AM	2/15/2008
0802197-04A	ROWEGWQ021308:1020N		2/13/2008 10:20:00 AM	2/15/2008
0802197-04B	ROWEGWQ021308:1020N		2/13/2008 10:20:00 AM	2/15/2008
0802197-04C	ROWEGWQ021308:1020N		2/13/2008 10:20:00 AM	2/15/2008
0802197-05A	ROWEGWQ021308:1025N		2/13/2008 10:25:00 AM	2/15/2008
0802197-05B	ROWEGWQ021308:1025N		2/13/2008 10:25:00 AM	2/15/2008
0802197-05C	ROWEGWQ021308:1025N		2/13/2008 10:25:00 AM	2/15/2008
0802197-06A	ROWEGWQ021308:1030N		2/13/2008 10:30:00 AM	2/15/2008
0802197-06B	ROWEGWQ021308:1030N		2/13/2008 10:30:00 AM	2/15/2008
0802197-06C	ROWEGWQ021308:1030N		2/13/2008 10:30:00 AM	2/15/2008
0802197-07A	ROWEGWQ021308:1035N		2/13/2008 10:35:00 AM	2/15/2008
0802197-07B	ROWEGWQ021308:1035N		2/13/2008 10:35:00 AM	2/15/2008
0802197-07C	ROWEGWQ021308:1035N		2/13/2008 10:35:00 AM	2/15/2008

TAG # / COC _____

CHAIN OF CUSTODY / REQUEST FOR ANALYSIS DOCUMENT

CLIENT NAME/ADDRESS L-BG 4 Research Drive Suite 301 Shelton, CT 06484	CONTACT: Mark Goldberg	SAMPLER (SIGNATURE) 	SAMPLE(S) SEALED YES / NO (YES)
		SAMPLER NAME (PRINT) Stephen Hnat	CORRECT CONTAINER(S) YES / NO (YES)

LABORATORY ID #	MATRIX	# CONTAINERS	SAMPLING DATE/TIME	SAMPLE # - LOCATION	ANALYSIS REQUIRED								FOR METHANOL PRESERVED SAMPLES (VOLATILE VIAL #)							
					8260 MTRC	FRECON 113	tot + Dis FE	tot + Dis MW	+	D5										
0803147-01ABC	L	5	2/15/08 1005	ROWCG-WND2130B:065-NH-3	X	X	X	X	X	X	X	X								
03ABC	L	5	1010	1010NPI-1-4																
03ABC	L	5	1015	1015NPI-1-5																
04ABC	L	5	1020	1020NPI-1-6																
05ABC	L	5	1025	1025NPI-1-7																
06ABC	L	5	1030	1030NPI-1-8																
07ABC	L	5	1035	1035NPI-1-9																

COOLER TEMPERATURE:	
COMMENTS / INSTRUCTIONS	
TURNAROUND REQUIRED: NORMAL <input checked="" type="checkbox"/> STAT <input type="checkbox"/> BY / /	
RELIQUISHED BY (SIGNATURE) 	RECEIVED BY LAB (SIGNATURE) ESZ
DATE TIME 02/14/08 17:00	DATE TIME 02/15/08 10:25
PRINTED NAME Kathi Deak	PRINTED NAME Gay Eppich
RELIQUISHED BY (SIGNATURE) 	RECEIVED BY LAB (SIGNATURE)
DATE TIME	DATE TIME

AMERICAN ANALYTICAL LABORATORIES, LLC

56 TOLEDO STREET

FARMINGDALE, NEW YORK 11735

TELEPHONE: (631) 454-6100 FAX: (631) 454-8027

DATA REPORTING QUALIFIERS

For reporting results, the following "Results Qualifiers" are used:

Value	If the result is greater than or equal to the detection limit, report the value.
U	Indicates the compound was analyzed for but was not detected. Report the minimum detection limit for the sample with the U, i.e. "10U". This is not necessarily the instrument detection limit attainable for this particular sample based on any concentration or dilution that may have been required.
J	Indicates an estimated value. The flag is used: <ol style="list-style-type: none">(1) When estimating a concentration for a tentatively identified compound (library search hits, where a 1:1 response is assumed.)(2) When the mass spectral data indicated the identification, however the result was less than the specified detection limit greater than zero. If the detection limit was 10ug/L and a concentration of 3ug/L was calculated report as 3J. This flag is used when similar situations arise on any organic parameter i.e. Pesticide, PCBs and others.
B	Indicates the analyte was found in the blank as well as the sample report "10B".
E	Indicates the analytes concentration exceeds the calibrated range of the instrument for that specific analysis.
D	This flag identifies all compounds identified in an analysis at a secondary dilution factor.
P	This flag is used for Pesticide / PCB target analyte when there is >25% difference for detected concentrations between the two GC Columns. The higher of the two values is reported on Form I and flagged with a "P".
N	This flag indicates presumptive evidence of a compound. This is only used for tentatively identified compounds (TICs), where the identification is based on a mass spectral library search. It applies to all TIC results. For generic characterization of a TIC, such as chlorinated hydrocarbon, the flag is not used.
H	Indicates sample was received and/or analyzed outside of the method allowable holding time.

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-01A

Client Sample ID: ROWEGWQ021308:1005NP1-1
Tag Number:
Collection Date: 2/13/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
----------	--------	-------	------	-------	----	---------------

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113				SW8260B		Analyst: LA
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 4:29:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 4:29:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 4:29:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 4:29:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-01A

Client Sample ID: ROWEGWQ021308:1005NP1-1
Tag Number:
Collection Date: 2/13/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 4:29:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 4:29:00 AM
Surr: 4-Bromofluorobenzene	103	54-134		%REC	1	2/20/2008 4:29:00 AM
Surr: Dibromofluoromethane	104	52-132		%REC	1	2/20/2008 4:29:00 AM
Surr: Toluene-d8	99.6	51-127		%REC	1	2/20/2008 4:29:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-01B

Client Sample ID: ROWEGWQ021308:1005NP1-1
Tag Number:
Collection Date: 2/13/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	1.88	0.0200		mg/L	1	2/20/2008 10:04:20 AM
Manganese	0.0943	0.0200		mg/L	1	2/20/2008 10:04:20 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detecte	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-01C

Client Sample ID: ROWEGWQ021308:1005NP1-1
Tag Number:
Collection Date: 2/13/2008 10:05:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	1.09	0.0200		mg/L	1	2/20/2008 10:02:17 AM
Manganese	0.0874	0.0200		mg/L	1	2/20/2008 10:02:17 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	85.0	1.00		mg/L	1	2/20/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-02A

Client Sample ID: ROWEGWQ021308:1010NP1-1
Tag Number:
Collection Date: 2/13/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 5:06:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 5:06:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 5:06:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 5:06:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-02A

Client Sample ID: ROWEGWQ021308:1010NP1-1
Tag Number:
Collection Date: 2/13/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113						
		SW8260B				Analyst: LA
Chloroethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 5:06:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Tetrachloroethene	2.1	1.0		µg/L	1	2/20/2008 5:06:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 5:06:00 AM
Surr: 4-Bromofluorobenzene	106	54-134		%REC	1	2/20/2008 5:06:00 AM
Surr: Dibromofluoromethane	99.1	52-132		%REC	1	2/20/2008 5:06:00 AM
Surr: Toluene-d8	101	51-127		%REC	1	2/20/2008 5:06:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-02B

Client Sample ID: ROWEGWQ021308:1010NP1-1
Tag Number:
Collection Date: 2/13/2008 10:10:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	8.28	0.0200		mg/L	1	2/20/2008 10:08:26 AM
Manganese	0.908	0.0200		mg/L	1	2/20/2008 10:08:26 AM

Qualifiers:				
B	Analyte detected in the associated Method Blank	E	Value above quantitation range	
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits	
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits	
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level	

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	ROWEGWQ021308:1010NP1-1
Lab Order:	0802197	Tag Number:	
Project:	Rowe	Collection Date:	2/13/2008 10:10:00 AM
Lab ID:	0802197-02C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.371	0.0200		mg/L	1	2/20/2008 10:06:23 AM
Manganese	0.910	0.0200		mg/L	1	2/20/2008 10:06:23 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	92.0	1.00		mg/L	1	2/20/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-03A

Client Sample ID: ROWEGWQ021308:1015NP1-1
Tag Number:
Collection Date: 2/13/2008 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
----------	--------	-------	------	-------	----	---------------

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113				SW8260B		Analyst: LA
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 5:40:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 5:40:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 5:40:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 5:40:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-03A

Client Sample ID: ROWEGWQ021308:1015NP1-1
Tag Number:
Collection Date: 2/13/2008 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 5:40:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 5:40:00 AM
Surr: 4-Bromofluorobenzene	104	54-134		%REC	1	2/20/2008 5:40:00 AM
Surr: Dibromofluoromethane	95.0	52-132		%REC	1	2/20/2008 5:40:00 AM
Surr: Toluene-d8	96.9	51-127		%REC	1	2/20/2008 5:40:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-03B

Client Sample ID: ROWEGWQ021308:1015NP1-1
Tag Number:
Collection Date: 2/13/2008 10:15:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.368	0.0200		mg/L	1	2/20/2008 10:12:30 AM
Manganese	0.0168	0.0200	J	mg/L	1	2/20/2008 10:12:30 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	ROWEGWQ021308:1015NP1-1
Lab Order:	0802197	Tag Number:	
Project:	Rowe	Collection Date:	2/13/2008 10:15:00 AM
Lab ID:	0802197-03C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0121	0.0200	J	mg/L	1	2/20/2008 10:10:29 AM
Manganese	0.00999	0.0200	J	mg/L	1	2/20/2008 10:10:29 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	147	1.00		mg/L	1	2/20/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-04A

Client Sample ID: ROWEGWQ021308:1020NP1-1
Tag Number:
Collection Date: 2/13/2008 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,1,1-Trichloroethane	6.4	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 6:16:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 6:16:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 6:16:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 6:16:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-04A

Client Sample ID: ROWEGWQ021308:1020NP1-1
Tag Number:
Collection Date: 2/13/2008 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 6:16:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Tetrachloroethene	19	1.0		µg/L	1	2/20/2008 6:16:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 6:16:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	2/20/2008 6:16:00 AM
Surr: Dibromofluoromethane	103	52-132		%REC	1	2/20/2008 6:16:00 AM
Surr: Toluene-d8	97.5	51-127		%REC	1	2/20/2008 6:16:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	ROWEGWQ021308:1020NP1-1
Lab Order:	0802197	Tag Number:	
Project:	Rowe	Collection Date:	2/13/2008 10:20:00 AM
Lab ID:	0802197-04B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.171	0.0200		mg/L	1	2/20/2008 10:16:37 AM
Manganese	0.181	0.0200		mg/L	1	2/20/2008 10:16:37 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-04C

Client Sample ID: ROWEGWQ021308:1020NP1-1
Tag Number:
Collection Date: 2/13/2008 10:20:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0188	0.0200	J	mg/L	1	2/20/2008 10:14:33 AM
Manganese	0.179	0.0200		mg/L	1	2/20/2008 10:14:33 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	114	1.00		mg/L	1	2/20/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-05A

Client Sample ID: ROWEGWQ021308:1025NP1-1
Tag Number:
Collection Date: 2/13/2008 10:25:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 6:52:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 6:52:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 6:52:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 6:52:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-05A

Client Sample ID: ROWEGWQ021308:1025NP1-1
Tag Number:
Collection Date: 2/13/2008 10:25:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 6:52:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Tetrachloroethene	11	1.0		µg/L	1	2/20/2008 6:52:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 6:52:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	2/20/2008 6:52:00 AM
Surr: Dibromofluoromethane	109	52-132		%REC	1	2/20/2008 6:52:00 AM
Surr: Toluene-d8	97.9	51-127		%REC	1	2/20/2008 6:52:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-05B

Client Sample ID: ROWEGWQ021308:1025NP1-1
Tag Number:
Collection Date: 2/13/2008 10:25:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	0.0982	0.0200		mg/L	1	2/20/2008 10:38:20 AM
Manganese	0.0895	0.0200		mg/L	1	2/20/2008 10:38:20 AM

Qualifiers:			
B	Analyte detected in the associated Method Blank	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	ROWEGWQ021308:1025NP1-1
Lab Order:	0802197	Tag Number:	
Project:	Rowe	Collection Date:	2/13/2008 10:25:00 AM
Lab ID:	0802197-05C	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0381	0.0200		mg/L	1	2/20/2008 10:36:16 AM
Manganese	0.0639	0.0200		mg/L	1	2/20/2008 10:36:16 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	94.0	1.00		mg/L	1	2/20/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-06A

Client Sample ID: ROWEGWQ021308:1030NP1-1
Tag Number:
Collection Date: 2/13/2008 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 7:26:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 7:26:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 7:26:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 7:26:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-06A

Client Sample ID: ROWEGWQ021308:1030NP1-1
Tag Number:
Collection Date: 2/13/2008 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 7:26:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 7:26:00 AM
Surr: 4-Bromofluorobenzene	101	54-134		%REC	1	2/20/2008 7:26:00 AM
Surr: Dibromofluoromethane	104	52-132		%REC	1	2/20/2008 7:26:00 AM
Surr: Toluene-d8	99.0	51-127		%REC	1	2/20/2008 7:26:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	ROWEGWQ021308:1030NP1-1
Lab Order:	0802197	Tag Number:	
Project:	Rowe	Collection Date:	2/13/2008 10:30:00 AM
Lab ID:	0802197-06B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	7.14	0.0200		mg/L	1	2/20/2008 10:42:27 AM
Manganese	0.715	0.0200		mg/L	1	2/20/2008 10:42:27 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-06C

Client Sample ID: ROWEGWQ021308:1030NP1-1
Tag Number:
Collection Date: 2/13/2008 10:30:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.0771	0.0200		mg/L	1	2/20/2008 10:40:23 AM
Manganese	0.647	0.0200		mg/L	1	2/20/2008 10:40:23 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	86.0	1.00		mg/L	1	2/20/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-07A

Client Sample ID: ROWEGWQ021308:1035NP1-1
Tag Number:
Collection Date: 2/13/2008 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113						
		SW8260B				Analyst: LA
1,1,1,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,1,1-Trichloroethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,1,2,2-Tetrachloroethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,1,2-Trichloro-1,2,2-trifluoroethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,1,2-Trichloroethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,1-Dichloroethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,1-Dichloroethene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,1-Dichloropropene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,2,3-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,2,3-Trichloropropane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,2,4-Trichlorobenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,2,4-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,2-Dibromo-3-chloropropane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,2-Dibromoethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,2-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,2-Dichloroethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,3,5-Trimethylbenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,3-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,3-dichloropropane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
1,4-Dichlorobenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
2,2-Dichloropropane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
2-Butanone	U	3.0		µg/L	1	2/20/2008 8:03:00 AM
2-Chloroethyl vinyl ether	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
2-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
2-Hexanone	U	2.0		µg/L	1	2/20/2008 8:03:00 AM
4-Chlorotoluene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
4-Isopropyltoluene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
4-Methyl-2-pentanone	U	2.0		µg/L	1	2/20/2008 8:03:00 AM
Acetone	U	2.0		µg/L	1	2/20/2008 8:03:00 AM
Benzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Bromobenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Bromochloromethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Bromodichloromethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Bromoform	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Bromomethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Carbon disulfide	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Carbon tetrachloride	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Chlorobenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-07A

Client Sample ID: ROWEGWQ021308:1035NP1-1
Tag Number:
Collection Date: 2/13/2008 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
VOLATILE SW-846 8260 + MTBE & FREON113		SW8260B		Analyst: LA		
Chloroethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Chloroform	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Chloromethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
cis-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
cis-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Dibromochloromethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Dibromomethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Dichlorodifluoromethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Ethylbenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Hexachlorobutadiene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Isopropylbenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
m,p-Xylene	U	2.0		µg/L	1	2/20/2008 8:03:00 AM
Methyl tert-butyl ether	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Methylene chloride	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Naphthalene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
n-Butylbenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
n-Propylbenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
o-Xylene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
sec-Butylbenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Styrene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
tert-Butylbenzene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Tetrachloroethene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Toluene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
trans-1,2-Dichloroethene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
trans-1,3-Dichloropropene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Trichloroethene	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Trichlorofluoromethane	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Vinyl acetate	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Vinyl chloride	U	1.0		µg/L	1	2/20/2008 8:03:00 AM
Surr: 4-Bromofluorobenzene	102	54-134		%REC	1	2/20/2008 8:03:00 AM
Surr: Dibromofluoromethane	102	52-132		%REC	1	2/20/2008 8:03:00 AM
Surr: Toluene-d8	96.3	51-127		%REC	1	2/20/2008 8:03:00 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT:	Leggette Brashears & Graham Inc.	Client Sample ID:	ROWEGWQ021308:1035NP1-1
Lab Order:	0802197	Tag Number:	
Project:	Rowe	Collection Date:	2/13/2008 10:35:00 AM
Lab ID:	0802197-07B	Matrix:	LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
TOTAL IRON, MANGANESE		E200.7		SW3010A		Analyst: JP
Iron	2.94	0.0200		mg/L	1	2/20/2008 10:46:33 AM
Manganese	0.572	0.0200		mg/L	1	2/20/2008 10:46:33 AM

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

American Analytical Laboratories, LLC.

Date: 25-Feb-08

CLIENT: Leggette Brashears & Graham Inc.
Lab Order: 0802197
Project: Rowe
Lab ID: 0802197-07C

Client Sample ID: ROWEGWQ021308:1035NP1-1
Tag Number:
Collection Date: 2/13/2008 10:35:00 AM
Matrix: LIQUID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
DISSOLVED IRON, MANGANESE		E200.7		SW3005A		Analyst: JP
Iron	0.176	0.0200		mg/L	1	2/20/2008 10:44:30 AM
Manganese	0.530	0.0200		mg/L	1	2/20/2008 10:44:30 AM
TOTAL DISSOLVED SOLIDS		M2540C				Analyst: AS
Total Dissolved Solids (Residue, Filterable)	102	1.00		mg/L	1	2/20/2008

Qualifiers:	B	Analyte detected in the associated Method Blank	E	Value above quantitation range
	H	Holding times for preparation or analysis exceeded	J	Analyte detected below quantitation limits
	ND	Not Detected at the Reporting Limit	S	Spike Recovery outside accepted recovery limits
	U	Indicates the compound was analyzed for but not detected	X	Value exceeds Maximum Contaminant Level

H8B150117 Analytical Report 1
Sample Receipt Documentation 15
Total Number of Pages 17

ANALYTICAL REPORT


Rowe-NABSAG 0401

Lot #: H8B150117

Mark Goldberg

Leggette, Brashears & Graham,
4 Research Drive
Suite #301
Shelton, CT 06484

TESTAMERICA LABORATORIES, INC.



Jamie A. McKinney
Project Manager

February 26, 2008

ANALYTICAL METHODS SUMMARY

H8B150117

<u>PARAMETER</u>	<u>ANALYTICAL METHOD</u>
Volatile Organics by TO15	EPA-2 TO-15

References:

EPA-2 "Compendium of Methods for the Determination of Toxic Organic Compounds in Ambient Air", EPA-625/R-96/010b, January 1999.

SAMPLE SUMMARY

H8B150117

<u>WO #</u>	<u>SAMPLE#</u>	<u>CLIENT SAMPLE ID</u>	<u>SAMPLED DATE</u>	<u>SAMP TIME</u>
KG5HV	001	AQ021308:1100NP4-1	02/13/08	11:00
KG5HX	002	AQ021308:1105NP4-2	02/13/08	11:05
KG5H0	003	AQ021308:1110NP4-3	02/13/08	11:10

NOTE (S) :

- The analytical results of the samples listed above are presented on the following pages.
- All calculations are performed before rounding to avoid round-off errors in calculated results.
- Results noted as "ND" were not detected at or above the stated limit.
- This report must not be reproduced, except in full, without the written approval of the laboratory.
- Results for the following parameters are never reported on a dry weight basis: color, corrosivity, density, flashpoint, ignitability, layers, odor, paint filter test, pH, porosity pressure, reactivity, redox potential, specific gravity, spot tests, solids, solubility, temperature, viscosity, and weight.

PROJECT NARRATIVE

H8B150117

The results reported herein are applicable to the samples submitted for analysis only.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The original chain of custody documentation is included with this report.

Sample Receipt

There were no problems with the condition of the samples received.

Quality Control and Data Interpretation

Unless otherwise noted, all holding times and QC criteria were met and the test results shown in this report meet all applicable NELAC requirements.

The samples were received on 02/15/08 in Tedlar bags and transferred into Summa Canisters within 72 hours of sampling.

TestAmerica Knoxville maintains the following certifications, approvals and accreditations: Arkansas DEQ Cert. #05-043-0, California DHS ELAP Cert. #2423, Colorado DPHE, Connecticut DPH Cert. #PH-0223, Florida DOH Cert. #E87177, Georgia DNR Cert. #906, Hawaii DOH, Illinois EPA Cert. #000687, Indiana DOH Cert. #C-TN-02, Iowa DNR Cert. #375, Kansas DHE Cert. #E-10349, Kentucky DEP Lab ID #90101, Louisiana DEQ Cert. #03079, Louisiana DOHH Cert. #LA030024, Maryland DHMH Cert. #277, Massachusetts DEP Cert. #M-TN009, Michigan DEQ Lab ID #9933, New Jersey DEP Cert. #TN001, New York DOH Lab #10781, North Carolina DPH Lab ID #21705, North Carolina DEHNR Cert. #64, Ohio EPA VAP Cert. #CL0059, Oklahoma DEQ ID #9415, Pennsylvania DEP Cert. #68-00576, South Carolina DHEC Lab ID #84001001, Tennessee DOH Lab ID #02014, Utah DOH Cert. #QUAN3, Virginia DGS Lab ID #00165, Washington DOE Lab #C120, West Virginia DEP Cert. #345, Wisconsin DNR Lab ID #998044300, Naval Facilities Engineering Service Center and USDA Soil Permit #S-46424. This list of approvals is subject to change and does not imply that laboratory certification is available for all parameters reported in this environmental sample data report.

Sample Data Summary

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ021308:1100NP4-1
 GC/MS Volatiles

Lot-Sample # H8B150117 - 001 Work Order # KG5HV1AA Matrix.....: AIR

Date Sampled...: 2/13/08 Date Received..: 2/15/08
 Prep Date.....: 2/15/08 Analysis Date... 2/15/08
 Prep Batch #....: 8049062
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	1.1	2.5	3.4 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	0.96	1.0	4.7 J	4.9
Chloromethane	1.2	2.5	2.5 J	5.2
1,1-Dichloroethane	3.0	1.0	12	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	ND	1.0	ND	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.56	1.0	2.2 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.61	2.5	2.1 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	9.3	1.0	63	6.8
Toluene	0.73	1.0	2.7 J	3.8
1,1,1-Trichloroethane	4.6	1.0	25	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	0.69	1.0	3.7 J	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	107	70 - 130
Toluene-d8	104	70 - 130
4-Bromofluorobenzene	99	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ021308:1100NP4-1
GC/MS Volatiles

Lot-Sample # H8B150117 - 001

Work Order # KG5HV1AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ021308:1105NP4-2
 GC/MS Volatiles

Lot-Sample # H8B150117 - 002 Work Order # KG5HX1AA Matrix.....: AIR

Date Sampled...: 2/13/08 Date Received...: 2/15/08
 Prep Date.....: 2/15/08 Analysis Date...: 2/15/08
 Prep Batch #....: 8049062
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND	3.2
Bromodichloromethane	ND	1.0	ND	6.7
Bromoform	ND	1.0	ND	10
Bromomethane	ND	1.0	ND	3.9
Carbon disulfide	1.1	2.5	3.5 J	7.8
Carbon tetrachloride	ND	1.0	ND	6.3
Chlorobenzene	ND	1.0	ND	4.6
Dibromochloromethane	ND	1.0	ND	8.5
Chloroethane	ND	1.0	ND	2.6
Chloroform	1.2	1.0	5.9	4.9
Chloromethane	2.1	2.5	4.4 J	5.2
1,1-Dichloroethane	4.2	1.0	17	4.0
1,2-Dichloroethane	ND	1.0	ND	4.0
cis-1,2-Dichloroethene	0.35	1.0	1.4 J	4.0
trans-1,2-Dichloroethene	ND	1.0	ND	4.0
1,1-Dichloroethene	0.66	1.0	2.6 J	4.0
1,2-Dichloropropane	ND	1.0	ND	4.6
cis-1,3-Dichloropropene	ND	1.0	ND	4.5
trans-1,3-Dichloropropene	ND	1.0	ND	4.5
Ethylbenzene	ND	1.0	ND	4.3
Methylene chloride	0.93	2.5	3.2 J B	8.7
Styrene	ND	1.0	ND	4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND	6.9
Tetrachloroethene	4.2	1.0	29	6.8
Toluene	0.54	1.0	2.0 J	3.8
1,1,1-Trichloroethane	12	1.0	66	5.5
1,1,2-Trichloroethane	ND	1.0	ND	5.5
Trichloroethene	0.81	1.0	4.3 J	5.4
Vinyl chloride	ND	1.0	ND	2.6
m-Xylene & p-Xylene	ND	1.0	ND	4.3
o-Xylene	ND	1.0	ND	4.3
SURROGATE		PERCENT RECOVERY		LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4		108		70 - 130
Toluene-d8		102		70 - 130
4-Bromofluorobenzene		101		70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ021308:1105NP4-2
GC/MS Volatiles

Lot-Sample # H8B150117 - 002

Work Order # KG5HX1AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: AQ021308:1110NP4-3
 GC/MS Volatiles

Lot-Sample # H8B150117 - 003 Work Order # KG5H01AA Matrix.....: AIR

Date Sampled...: 2/13/08 Date Received...: 2/15/08
 Prep Date.....: 2/15/08 Analysis Date... 2/16/08
 Prep Batch #....: 8049062
 Dilution Factor.: 5 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)		REPORTING LIMIT (ug/m3)
Benzene	ND	1.0	ND		3.2
Bromodichloromethane	ND	1.0	ND		6.7
Bromoform	ND	1.0	ND		10
Bromomethane	ND	1.0	ND		3.9
Carbon disulfide	1.2	2.5	3.8	J	7.8
Carbon tetrachloride	ND	1.0	ND		6.3
Chlorobenzene	ND	1.0	ND		4.6
Dibromochloromethane	ND	1.0	ND		8.5
Chloroethane	ND	1.0	ND		2.6
Chloroform	1.4	1.0	7.0		4.9
Chloromethane	1.2	2.5	2.5	J	5.2
1,1-Dichloroethane	4.5	1.0	18		4.0
1,2-Dichloroethane	ND	1.0	ND		4.0
cis-1,2-Dichloroethene	0.47	1.0	1.9	J	4.0
trans-1,2-Dichloroethene	ND	1.0	ND		4.0
1,1-Dichloroethene	0.74	1.0	2.9	J	4.0
1,2-Dichloropropane	ND	1.0	ND		4.6
cis-1,3-Dichloropropene	ND	1.0	ND		4.5
trans-1,3-Dichloropropene	ND	1.0	ND		4.5
Ethylbenzene	ND	1.0	ND		4.3
Methylene chloride	0.67	2.5	2.3	J B	8.7
Styrene	ND	1.0	ND		4.3
1,1,2,2-Tetrachloroethane	ND	1.0	ND		6.9
Tetrachloroethene	ND	1.0	ND		6.8
Toluene	0.60	1.0	2.2	J	3.8
1,1,1-Trichloroethane	22	1.0	120		5.5
1,1,2-Trichloroethane	ND	1.0	ND		5.5
Trichloroethene	ND	1.0	ND		5.4
Vinyl chloride	ND	1.0	ND		2.6
m-Xylene & p-Xylene	ND	1.0	ND		4.3
o-Xylene	ND	1.0	ND		4.3

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	114	70 - 130
Toluene-d8	104	70 - 130
4-Bromofluorobenzene	104	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: AQ021308:1110NP4-3
GC/MS Volatiles

Lot-Sample # H8B150117 - 003

Work Order # KG5H01AA

Matrix.....: AIR

Qualifiers

B Method blank contamination. The associated method blank contains the target analyte at a reportable level.
J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: $\text{Amount Found}(\text{before rounding}) * (\text{Molecular Weight}/24.45)$

The 'Reporting Limit' in ug/m3 is calculated using the following equation: $(\text{Reporting Limit}(\text{before rounding}) * \text{Dilution Factor}) * (\text{Molecular Weight}/24.45)$

Leggette, Brashears & Graham, Inc.
 Client Sample ID: INTRA-LAB BLANK
 GC/MS Volatiles

Lot-Sample # H8B180000 - 062B Work Order # KG8GR1AA Matrix.....: AIR

Prep Date.....: 2/15/08 Date Received..: 2/9/08
 Prep Batch #.....: 8049062 Analysis Date... 2/15/08
 Dilution Factor.: 1 Method.....: TO-15

PARAMETER	RESULTS (ppb(v/v))	REPORTING LIMIT (ppb(v/v))	RESULTS (ug/m3)	REPORTING LIMIT (ug/m3)
Benzene	ND	0.20	ND	0.64
Bromodichloromethane	ND	0.20	ND	1.3
Bromoform	ND	0.20	ND	2.1
Bromomethane	ND	0.20	ND	0.78
Carbon disulfide	ND	0.50	ND	1.6
Carbon tetrachloride	ND	0.20	ND	1.3
Chlorobenzene	ND	0.20	ND	0.92
Dibromochloromethane	ND	0.20	ND	1.7
Chloroethane	ND	0.20	ND	0.53
Chloroform	ND	0.20	ND	0.98
Chloromethane	ND	0.50	ND	1.0
1,1-Dichloroethane	ND	0.20	ND	0.81
1,2-Dichloroethane	ND	0.20	ND	0.81
cis-1,2-Dichloroethene	ND	0.20	ND	0.79
trans-1,2-Dichloroethene	ND	0.20	ND	0.79
1,1-Dichloroethene	ND	0.20	ND	0.79
1,2-Dichloropropane	ND	0.20	ND	0.92
cis-1,3-Dichloropropene	ND	0.20	ND	0.91
trans-1,3-Dichloropropene	ND	0.20	ND	0.91
Ethylbenzene	ND	0.20	ND	0.87
Methylene chloride	0.073	0.50	0.25 J	1.7
Styrene	ND	0.20	ND	0.85
1,1,2,2-Tetrachloroethane	ND	0.20	ND	1.4
Tetrachloroethene	ND	0.20	ND	1.4
Toluene	ND	0.20	ND	0.75
1,1,1-Trichloroethane	ND	0.20	ND	1.1
1,1,2-Trichloroethane	ND	0.20	ND	1.1
Trichloroethene	ND	0.20	ND	1.1
Vinyl chloride	ND	0.20	ND	0.51
m-Xylene & p-Xylene	ND	0.20	ND	0.87
o-Xylene	ND	0.20	ND	0.87

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	101	70 - 130
Toluene-d8	102	70 - 130
4-Bromofluorobenzene	95	70 - 130

Leggette, Brashears & Graham, Inc.
Client Sample ID: INTRA-LAB BLANK
GC/MS Volatiles

Lot-Sample # H8B180000 - 062B

Work Order # KG8GR1AA

Matrix.....: AIR

Qualifiers

J Estimated result. Result is less than RL.

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Leggette, Brashears & Graham, Inc.
 Client Sample ID: CHECK SAMPLE
 GC/MS Volatiles

Lot-Sample # H8B180000 - 062C Work Order # KG8GRIAC Matrix.....: AIR

Prep Date.....: 2/15/08 Date Received..: 2/9/08
 Prep Batch #.....: 8049062 Analysis Date... 2/15/08
 Dilution Factor.: 1 Method.....: TO-15

PARAMETER	SPIKE AMOUNT (ppb(v/v))	MEASURED AMOUNT (ppb(v/v))	SPIKE AMOUNT (ug/m3)	MEASURED AMOUNT (ug/m3)	PERCENT RECOVERY	RECOVERY LIMITS
Benzene	10.0	8.14	32	26	81	70 - 130
Chlorobenzene	10.0	10.3	46	47	103	70 - 130
1,1-Dichloroethene	10.0	9.66	40	38	97	70 - 130
Toluene	10.0	9.26	38	35	93	70 - 130
Trichloroethene	10.0	8.90	54	48	89	70 - 130

SURROGATE	PERCENT RECOVERY	LABORATORY CONTROL LIMITS (%)
1,2-Dichloroethane-d4	92	70 - 130
Toluene-d8	98	70 - 130
4-Bromofluorobenzene	98	70 - 130

The 'Result' in ug/m3 is calculated using the following equation: Amount Found(before rounding)*(Molecular Weight/24.45)

The 'Reporting Limit' in ug/m3 is calculated using the following equation: (Reporting Limit(before rounding) * Dilution Factor) * (Molecular Weight/24.45)

Sample Receipt Documentation

STL Knoxville

5815 Middlebrook Pike • Knoxville, TN 37921-5947
 Phone: (865) 291-3000 • Fax: (865) 584-4315
 Receiving: (865) 291-3031

ANALYSIS REQUEST AND CHAIN OF CUSTODY RECORD*

Reference Document No. _____
 Page 1 of 1

Project Name/No. ¹ Runk
 Sample Team Members ² Tepner Street
 Profit Center No. ³ _____
 Project Manager ⁴ Mark Goldberg
 Purchase Order No. ⁶ _____

Samples Shipment Date ⁷ 2/14/08
 Lab Destination ⁸ _____
 Lab Contact ⁹ Jamie McKinney
 Project Contact / Phone ¹² 203-979-8595
 Carrier / Waybill No. ¹³ _____

Bill to: ⁵ Mark Goldberg
Legg & Bashaw's & Graham, Inc
4 Research Dr. Suite 301
Melton, CT 06474
 Report to: ¹⁰ Same

Required Report Date ¹¹ _____

ONE CONTAINER PER LINE

Sample Number	Sample Type	Date/Time Collected	Container Type	Sample Volume	Pre-19 servative	Requested Testing Program	Condition on Receipt Lab use only
AQ021308:11001141	Air	2/13/08 11:00 AM	Fed low bags	1 L	none	TD-15	Custody seals intact (Y) N NA (19.0) Temperature received at <u>ROOM TEMP</u> Received by <u>RH</u> Date <u>2/15/08</u> Number of packages <u>1</u> Tracking # <u>791849668320</u> <u>FED EX</u>
L:11051142		L 11:05 AM					
L:11111143		L 11:05 AM					

Special Instructions: ²³ _____

Possible Hazard Identification: ²⁴ _____

Non-Hazard Flammable Skin Irritant Poison B Unknown Sample Disposal: ²⁵ Return to Client Disposal by Lab Archive (mos.)

Turnaround Time Required: ²⁶ _____

Normal Rush QC Level: ²⁷ I. II. III. Project Specific (specify): Fall QA/QC

1. Relinquished by ²⁸ Mark M. Goldberg Date: 2/14/08
 (Signature / Affiliation) Time: 17:00

1. Received by ²⁸ Lynn Henry Date: 2/15/08
 (Signature / Affiliation) Time: 0930

1. Relinquished by _____ Date: _____
 (Signature / Affiliation) Time: _____

1. Received by _____ Date: _____
 (Signature / Affiliation) Time: _____

Comments: ²⁹ _____

TESTAMERICA KNOXVILLE SAMPLE RECEIPT/CONDITION UPON RECEIPT ANOMALY CHECKLIST

Client: _____ Project: _____ Lot Number: H81SD117

Review Items	Yes	No	NA	If No, what was the problem?	Comments/Actions Taken
1. Do sample container labels match COC? (IDs, Dates, Times)	✓			<input type="checkbox"/> 1a Do not match COC <input type="checkbox"/> 1b Incomplete information <input type="checkbox"/> 1c Marking smeared <input type="checkbox"/> 1d Label torn <input type="checkbox"/> 1e No label <input type="checkbox"/> 1f COC not received <input type="checkbox"/> 1g Other: _____	
2. Is the cooler temperature within limits? (> freezing temp. of water to 6°C; NC, 1668, 1613B: 0-4°C; VOST: 10°C; MA: 2-6 °C)	✓		✓	<input type="checkbox"/> 2a Temp Blank = _____ <input type="checkbox"/> 2b Cooler Temp = _____	
3. Were samples received with correct chemical preservative (excluding Encore)?			✓	<input type="checkbox"/> 3a Sample preservative = _____	
4. Were custody seals present/intact on cooler and/or containers?	✓			<input type="checkbox"/> 4a Not present <input type="checkbox"/> 4b Not intact <input type="checkbox"/> 4c Other: _____	
5. Were all of the samples listed on the COC received?	✓			<input type="checkbox"/> 5a Samples received-not on COC <input type="checkbox"/> 5b Samples not received-on COC	
6. Were all of the sample containers received intact?	✓			<input type="checkbox"/> 6a Leaking <input type="checkbox"/> 6b Broken	
7. Were VOA samples received without headspace?	✓		✓	<input type="checkbox"/> 7a Headspace (VOA only)	
8. Were samples received in appropriate containers?	✓			<input type="checkbox"/> 8a Improper container	
9. Did you check for residual chlorine, if necessary?			✓	<input type="checkbox"/> 9a Could not be determined due to matrix interference	
10. Were samples received within holding time?	✓			<input type="checkbox"/> 10a Holding time expired	
11. For rad samples, was sample activity info. provided?			✓	<input type="checkbox"/> Incomplete information	
12. For SOG water samples (1613B, 1668A, 8290, LR PAHs), do samples have visible solids present?			✓	If yes & appears to be > 1%, was SOG notified? <input type="checkbox"/> 13a Leaking <input type="checkbox"/> 13b Other: _____	
13. Are the shipping containers intact?	✓			<input type="checkbox"/> 14a Not relinquished	
14. Was COC relinquished? (Signed/Dated/Timed)	✓			<input type="checkbox"/> 15a Incomplete information	
15. Are tests/parameters listed for each sample?	✓			<input type="checkbox"/> 15a Incomplete information	
16. Is the matrix of the samples noted?	✓			<input type="checkbox"/> 15a Incomplete information	
17. Is the date/time of sample collection noted?	✓			<input type="checkbox"/> 15a Incomplete information	
18. Is the client and project name/# identified?	✓			<input type="checkbox"/> 15a Incomplete information	
19. Was the sampler identified on the COC?	✓				
Quote #: <u>69610</u>				PM Instructions: _____	

Sample Receiving Associate: Ryan Henry Date: 2/15/08 QA026R19.doc, 080707